



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

November 24, 1982

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
FSAR Accident Analysis
Utilization of a
Non-Existing Plant
Condition
LER 82-105/01 T-0
AECM-82/542

09 NOV 26 12:02
REGIONAL ADMINISTRATOR
ATLANTA, GEORGIA

General Electric has a requirement for five seconds of steam bypass operation after a turbine trip. This requirement is not explicitly stated in the system design specification 22A6084, but is assumed in the FSAR analysis (see Chapter 15, Table 15.2-8). This event is reportable under T.S.6.9.1.12.h. Attached is LER-82-105/01 T-0 with Supplementary Information.

Yours truly,

[Signature]
FOR J. P. Mcgaughy JR.

JPM:sap
Attachment

- cc: Mr. N. L. Stampley (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

IF22

8212020138 821124
PDR ADOCK 05000416
S PDR