

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

1750 Chestnut Street Tower II

November 23, 1982

Mr. James P. O'Reilly, Director  
U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 2 - DOCKET  
NO. 50-260 - FACILITY OPERATING LICENSE DPR-52 - REPORTABLE OCCURRENCE  
REPORT BFRO-50-260/82035

The enclosed report provides details concerning an inoperable upper  
mechanical snubber on the main steam line. This report is submitted  
in accordance with Browns Ferry unit 2 Technical Specification 6.7.2.b(2).

Very truly yours,

TENNESSEE VALLEY AUTHORITY

*J. A. Green*  
J. A. Green  
Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Records Center  
Institute of Nuclear Power Operations  
Suite 1500  
1100 Circle 75 Parkway  
Atlanta, Georgia 30339

NRC Inspector, Browns Ferry

8212020143 821123  
PDR ADOCK 05000260  
S PDR

IE22  
OFFICIAL COPY