(7-77)

Unit 2

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | TNSNP2 (2) | 00-00000-00 (3) | 41111 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T 01 | REPORT SOURCE L (6) | 05000328 (7) | 102982 (8) | 112382 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 With unit 2 in mode 1 (96% power) at 1359 CST on 10/29/82, the essential raw
03 cooling water effluent line radiation monitor 0-RM-90-134/141 was declared
04 inoperable due to loss of sample flow. This event required entry into action
05 statement 32 of LCO 3.3.3.9. There was no effect upon public health and safety.
06 Previous occurrences - one (SQRO-50-327/81029).
07
08

09 SYSTEM CODE MA (11) | CAUSE CODE E (12) | CAUSE SUBCODE B (13) | COMPONENT CODE PMMPXX (14) | COMP. SUBCODE X (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 82 | — | SEQUENTIAL REPORT NO. 125 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN A (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER L (25) | COMPONENT MANUFACTURER X999

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Investigation revealed that the monitor pump to motor coupling failed. The failure
11 was caused by normal wear and expected service life. The coupling was replaced
12 and the monitors returned to service at 0727 CST on 10/30/82. No further action
13 is planned.
14

15 FACILITY STATUS E (28) | % POWER 096 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Operator observation

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES
17 NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

PERSONNEL INJURIES
18 NUMBER 000 (40) | DESCRIPTION (41) NA

8212020191 821123
PDR ADOCK 05000328
S PDR

LOSS OF OR DAMAGE TO FACILITY (43)
19 TYPE Z (42) | DESCRIPTION NA

PUBLICITY
20 ISSUED N (44) | DESCRIPTION (45) NA

NRC USE ONLY

Name of Preparer: H. R. Rogers /M. R. Harding Phone: (615) 751-0349