LICENSEE EVENT REPORT

,	CONTROL BLOCK:
0 1	N C B E P 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 6 5 6 5 6 6 6 6 6 6 6 6 6 6 6
CON'T 0 1 2 8	REPORT L 6 0 5 0 - 0 3 2 5 7 1 0 2 7 8 2 8 1 1 2 3 8 2 9 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10 During plant operation, while performing a special investigation to determine the
0 3	cause of an event where the suppression pool level exceeded the lower specification
0 4	(LER 1-82-114), it was discovered that kHR System discharge valves to the Radwaste
0 5	System, 1-E11-F040 and F049, were not fully closed. In accordance with technical
0 6	specifications, both valves were declared inoperable, deactivated, and manually closed;
0 7	This event did not affect the health and safety of the public.
08	Technical Specifications 3.6.3, 6.9.1.9b
0 9 8	SYSTEM CODE CODE SUBCODE COMPONENT CODE SUBCODE SUBCOD
	Type No. Code Type Code Type No. Code Type Type No. Code Type Type No. Code Type Typ
10	The failure of these valves to fully close is presently under investigation. Following
11	a determination of the cause of the failure, a supplemental report outlining the cause
1 2	and corrective actions will be submitted.
1 3	
1 4	
	FACILITY SPOWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32
7 8	E 28 0 6 0 29 NA B 31 Special Investigation 8 10 10 12 13 44 45 46 80
	ELEASED OF RELEASE AMOUNT OF ACTIVITY (35) NA NA NA
7 8	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
1 7	0 0 0 37 Z 38 NA
	PERSONNEL INJURIES NUMBER DESCRIPTION 41
7 8	9 11 12 86
1 9	LOSS OF OR DAMAGE TO FACILITY 43 TYPE DESCRIPTION NA NA
7 8	9 10 8212020312 821123 NRC USE ONLY PDR ADOCK 05000325 S PDR
7 8	9 10 68 69 80 5 NAME OF BREPARER M. J. Pastva, Jr. PHONE 919-457-9521 2