

ORIGINAL

**OFFICIAL TRANSCRIPT
PROCEEDINGS BEFORE**

NUCLEAR REGULATORY COMMISSION

COMMISSION MEETING

PUBLIC MEETING

DKT/CASE NO.

TITLE BRIEFING ON PRESSURIZED THERMAL SHOCK

PLACE Washington, D. C.

DATE December 1, 1982

PAGES 1 - 86



ALDERSON REPORTING

(202) 628-9300
440 FIRST STREET, N.W.
WASHINGTON, D.C. 20001

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

BRIEFING ON PRESSURIZED THERMAL SHOCK
PUBLIC MEETING

Nuclear Regulatory Commission
Room 1130
1717 H Street, N. W.
Washington, D. C.

Wednesday, December 1, 1982

The Commission convened pursuant to notice, at
2:05 p.m.

COMMISSIONERS PRESENT:

- NUNZIO PALLADINO, Chairman of the Commission
- VICTORY GILINSKY, Commissioner
- THOMAS ROBERTS, Commissioner
- JAMES ASSELSTINE, Commissioner

STAFF AND PRESENTERS SEATED AT COMMISSION TABLE:

- S. CHILK
- M. MALSCH
- J. ZERBE
- H. DENTON
- S. HANAUER
- R. WOODS
- F. SCHROEDER

AUDIENCE SPEAKERS:

- T. MURLEY

DISCLAIMER

This is an unofficial transcript of a meeting of the United States Nuclear Regulatory Commission held on December 1, 1982 in the Commission's offices at 1717 H Street, N. W., Washington, D. C. The meeting was open to public attendance and observation. This transcript has not been reviewed, corrected, or edited, and it may contain inaccuracies.

The transcript is intended solely for general informational purposes. As provided by 10 CFR 9.103, it is not part of the formal or informal record of decision of the matters discussed. Expressions of opinion in this transcript do not necessarily reflect final determinations or beliefs. No pleading or other paper may be filed with the Commission in any proceeding as the result of or addressed to any statement or argument contained herein, except as the Commission may authorize.

P R O C E E D I N G S

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

CHAIRMAN PALLADINO: Good afternoon, ladies and gentlemen.

The purpose of this afternoon's meeting is to have the staff brief the Commissioners on issue of pressurized thermal shock. We have had a number of discussions with the staff on this subject previously, but they have generally concerned status reports and plans for future studies.

Recently, however, the staff has completed a report from which it has based a set of recommendations now before the Commissioners. I understand that the staff is prepared to discuss the details of the report and provide answer to questions on the recommendations.

I have noted that the package of slides to be used today is rather lengthy, and I am fearful that we will not have time to look at each and everyone of them, and still allow time for questions.

COMMISSIONER GILINSKY: I was fearful that we would.

CHAIRMAN PALLADINO: I want to make sure that we provide sufficient time at the end of the meeting to provide time for Commissioner questions, and to discuss the recommendations that are before us.

We do not plan to vote today, but we may vote

1 at the next meeting on this subject, which is scheduled
2 for the week of December 6.

3 Do any of the other Commissioners have opening
4 comments?

5 COMMISSIONER ASSELSTINE: No.

6 COMMISSIONER GILINSKY: I don't have any
7 opening comments, but I did want to --

8 You answered the question I was going to ask,
9 which is, are we going to vote today, because I am going
10 to have to leave before the end of this meeting to catch
11 a plane to the West Coast. I guess that resolves that
12 question.

13 I did have one question of the staff before
14 they began, and that was, whose views does this paper
15 represent?

16 It is signed by Mr. Dircks, and at the bottom
17 it says, Steve Hanauer with his phone number. Is this
18 an NRR view?

19 MR. DENTON: I think it is fair to say that it
20 is an EDO staff view. It has been reviewed by the ACRS,
21 and they have issued their report that agrees with it.
22 It has been reviewed by the CRGR. I am sure Mr. Dircks
23 concurs in this paper. NRR has proposed it. Steve
24 Hanauer is the principal technical expert in this area.

25 COMMISSIONER GILINSKY: But it does represent

1 NRR's views.

2 MR. DENTON: It is NRR's views, and it also
3 represent the EO's and his other offices' views also.

4 COMMISSIONER GILINSKY: Thank you.

5 CHAIRMAN PALLADINO: Any other questions?

6 COMMISSIONER GILINSKY: No.

7 CHAIRMAN PALLADINO: Then I will turn the
8 meeting over to Mr. Denton.

9 MR. DENTON: Thank you, Mr. Chairman.

10 The main presentation will be made by Steve
11 Hanauer. I want to mention that this is his swan song
12 in appearing before the Commission. He is going on to
13 greener pastures in the next few days, he hopes.

14 COMMISSIONER GILINSKY: He hopes it is
15 greener.

16 MR. DENTON: He will be assisted by Roy Woods,
17 who has been the Project Manager for this project over
18 the last couple of years, and he will also be assisted
19 by Frank Schroeder, over on my right, who is the
20 Assistant Director for Generic Projects under Steve.

21 We have had an awful lot of activity in this
22 area over the last couple of years. It has occupied
23 time of many of the technical specialists. We have a
24 number of peer reviews. We have had the Pacific
25 Northwest Laboratory as a consultant to advise us all

1 along the way. We obtained the advice of several
 2 consultants in this area, including consultants such as
 3 Spence Bush, a former ACRS member, Bob Budnitz, whom you
 4 know. We have also gotten advice from Oakridge National
 5 Lab. We have consulted with George Irwin, who is sort
 6 of the father of fracture mechanics in the U.S.

7 We think that the time is ripe for a decision
 8 regarding thermal shock, and it is our view that
 9 adoption of the action we recommend today will provide
 10 adequate public protection against risk from this type
 11 of event.

12 The action is of three types. It recommend
 13 issuance of regulations to deal with those plants which
 14 are a long way from tripping our criteria; it recommends
 15 the issuance of 50-55(f) letters to a group of plants
 16 who need to do something between now and the end of
 17 their life to assure that they stay within the
 18 guidelines that we have proposed; and it recommends the
 19 issuance of an order for one plant, Robinson, which
 20 appears to be unable to reach the end of life without
 21 rather drastic changes in their mode of operation.

22 With that introduction, let me ask Steve to
 23 walk through these slides and answer your questions.

24 MR. HANAUER: Thank you, Harold.

25 Mr. Chairman and gentlemen, the package of

1 handouts which I gave you should not be as awesome as it
2 first appears. Only about the first half of it is
3 intended for discussion, and the last half is backup
4 material in case questions are asked. Many of them are
5 unsuitable for projection, so I plan to work just from
6 the package of handouts.

7 You have from us a paper, SECY-82-465, with a
8 number of enclosures. Separate from that, you have
9 received from us a very thick report which purports to
10 be enclosure A to that SECY paper. More recently, you
11 received from us a package of errata on those, in which
12 certain typos and other things have been fixed.

13 COMMISSIONER GILINSKY: Is that report now a
14 public document?

15 MR. HANAUER: Not until today, but it is now
16 on the back table, we will send it to the Public
17 Document Room immediately.

18 COMMISSIONER GILINSKY: Thank you.

19 MR. HANAUER: The draft of that report was
20 discussed with the ACRS and was sent to the Public
21 Document Room in September.

22 The pressurized thermal shock issue involves
23 over-cooling transients, reactor vessel properties, and
24 the fracture mechanics which establish whether the
25 vessel will, in fact, fail under the stresses which are

7
1 imposed by these over-cooling transients in the presence
2 of the flaws with the various vessel properties.
3 Therefore, it is necessary to discuss all these areas in
4 order to get to the end of this subject.

5 What we have done is --

6 COMMISSIONER ROBERTS: Excuse me, I don't mean
7 to nitpick, but I thought you said, "in the presence of
8 flaws in the vessel wall."

9 MR. HANAUER: Yes, sir.

10 COMMISSIONER ROBERTS: Is that an assumption?
11 Is that known?

12 MR. HANAUER: It is all of those things, sir.
13 In any individual vessel, there is an inspection history
14 which gives you an insight as to the presence or absence
15 of flaws in that vessel.

16 In a generic discussion, in our deterministic
17 work, we assume that there is a flaw, which is a big
18 conservatism, and in our probabilistic work, we have a
19 probability distribution of the presence or absence of
20 flaws of various sizes in order to be more realistic.

21 We believe that a flaw or a discontinuity of
22 some kind is a necessary part of a pressurized thermal
23 shock occurrence, and that a flaw-less vessel will not
24 experience failure.

25 COMMISSIONER ROBERTS: But you assume there

1 are flaws?

2 MR. HANAUER: Yes, sir.

3 COMMISSIONER ROBERTS: Okay.

4 COMMISSIONER GILINSKY: They are human.

5 MR. HANAUER: Page 2 in the handout gives an
6 overview of how we treat overcooling transients. The X
7 axis is temperature and lower temperatures are more
8 severe, so the left-hand side of the drawing, as you go
9 toward the left, you get to more severe things, with
10 colder and colder transients which produce less and less
11 favorable vessel characteristics.

12 The Y axis is probability. Sometimes we know
13 the probability and sometimes we don't, but it is always
14 there. The solid curve is meant to give some idea of
15 the whole range of the probability of things that could
16 happen. The curve is not well delineated, although I
17 will come back to an estimate of this curve later.

18 Up in the right-hand corner is another
19 probability curve which is obtained by analyzing the
20 over-cooling accidents which have actually occurred.
21 There is a limit to that. We have had no accidents more
22 severe than the ones shown on that curve.

23 CHAIRMAN PALLADINO: The probability is
24 probability of what; in-vessel failure?

25 MR. HANAUER: It could be any of those things

1 since this curve is only schematic. It could be vessel
2 failure, or only probability of getting that kind of a
3 transient. Later on I will show you both, transient
4 probability curves and vessel failure probability
5 curves.

6 COMMISSIONER GILINSKY: What are the lowest
7 temperatures we have had to work with, or that we have
8 experienced?

9 MR. HANAUER: The lowest temperature we have
10 experienced is on the order of 200 and a few degrees.

11 COMMISSIONER GILINSKY: Where was this?

12 MR. HANAUER: The most severe one was the
13 TMI-2 accident. It turned out, besides all its other
14 stresses, to have been the worst over-cooling transient
15 we have ever had.

16 COMMISSIONER GILINSKY: An interesting
17 distinction.

18 MR. HANAUER: I have shown not only the
19 experience curve, but also a curve based on
20 probabilistic evaluation and in an effort to be
21 realistic I have shown that they agree only
22 approximately, which is in fact the case.

23 COMMISSIONER GILINSKY: I realize that this is
24 schematic, but when you put down an outlier, that
25 represents the sort of thing that we have just talked

1 about at TMI?

2 MR. HANAUER: No, sir.

3 COMMISSIONER GILINSKY: Is that the
4 experience?

5 MR. HANAUER: TMI is one of the axes on the
6 experience curve.

7 COMMISSIONER GILINSKY: So it would be the end
8 of the experience curve.

9 MR. HANAUER: Yes.

10 The outliers are the sequences that we dream
11 up that appear to us to be severe. We have had about
12 one of these a month in the past six months. They have
13 a tendency to look very bad the first three days you
14 hear about them. Then they get analyzed in much more
15 detail.

16 COMMISSIONER GILINSKY: This is a
17 calculational phenomenon --

18 MR. HANAUER: Yes, sir.

19 COMMISSIONER GILINSKY: -- when you say that
20 we have had one every few months?

21 MR. HANAUER: Yes.

22 Most of them disappear into the curve. Some
23 of them don't, and the ones that don't disappear into
24 the curve, the curve has to be moved to accommodate
25 them.

1 COMMISSIONER GILINSKY: What sort of
2 temperatures are you talking about there?

3 MR. HANAUER: We had one outlier, one day that
4 I remember very well, that went down to 60 degrees and
5 was thought to have a probability in the range of 10 to
6 the minus 4 per reactor year.

7 CHAIRMAN PALLADINO: Which way are these --
8 This curve is telling that if I have a high temperature,
9 then I have a high probability of something?

10 MR. HANAUER: Yes, sir. High temperatures are
11 good for you. It is cold temperatures that give you
12 trouble.

13 CHAIRMAN PALLADINO: That is why I needed to
14 know what this is a probability of.

15 MR. HANAUER: This is the probability of
16 getting a transient worse than some temperature, which
17 means colder than some temperature. So that as the
18 temperature gets lower and lower, the chance of you
19 getting a transient is lower and lower.

20 CHAIRMAN PALLADINO: This is the dividing
21 line.

22 MR. HANAUER: Yes, sir.

23 CHAIRMAN PALLADINO: Okay.

24 COMMISSIONER GILINSKY: You can think of it as
25 the relative probability also.

1 MR. DENTON: The more specific ones may be
2 more useful. This was just to illustrate the ones that
3 connect.

4 MR. HANAUER: Page 3 gives a particular
5 transient, the one that occurred H.B. Robinson when a
6 secondary line developed a large leak. The two small
7 diagrams are the pressure and the temperature that were
8 actually measured as a function of time.

9 As you can see, the pressure went down and
10 then back up again, and the temperature went down by
11 about 200 degrees. So this was an over-cooling
12 transient of some considerable concern, although in that
13 plant it turned out not to do any harm.

14 On the left-hand side of the page, the same
15 transient is plotted in a different way. You have on
16 the X axis the temperature and on the Y axis the
17 pressure, and so a point moves along as the transient
18 developed and draws this funny looking curve.

19 CHAIRMAN PALLADINO: Up at the top?

20 MR. HANAUER: Yes.

21 I have also drawn, on the right-hand side, the
22 saturation curve of boiling water. So if you get into
23 the hash-marks on the right-hand side, you are in the
24 realm of potential under-cooling of the core. On the
25 left-hand side, hashed, is a reactor vessel, this is an

1 over-cooling limit which is chosen for a vessel just at
2 our screening criterion. Not the real vessel as it was
3 that day, but a fictitious vessel that had embrittled just
4 to the proposed screening criterion.

5 The point here is that you have the space
6 in-between where everything is okay. You are never
7 under-cooled nor over-cooled. As you can see, this
8 particular transient started -- If you look at the
9 upper-central curve, it started on the right-hand side
10 and moved toward the left, but it stayed entirely in the
11 acceptable region.

12 COMMISSIONER GILINSKY: What is the
13 significance of the dashed-line?

14 MR. HANAUER: The dashed-line is the limit
15 imposed by the technical specifications for normal
16 heat-ups and cool-downs. You are not allowed in the
17 section to the left of the dashed-line for normal
18 heat-ups.

19 Where you have many of them, you are in normal
20 conditions rather than accident conditions. So that the
21 normal operation of the reactor should be in the more
22 restricted curve region.

23 The next two pages, which we don't have to
24 dwell on, are two more transients. I want to linger on
25 them just long enough to look at their jagged nature.

1 The pressure goes up, the pressure goes down. On page
2 5, the temperature goes down and the temperature goes
3 back up again. These are what actually happened in
4 these particular events, and they are caused by
5 operational things -- valves closed, valves opened,
6 operators did this, operators did that.

7 So the operating point moves around and the
8 pressures go up and down, and the temperatures go down
9 and up.

10 COMMISSIONER GILINSKY: Let me ask you, what
11 is the line with the short dashes beyond saturation; is
12 that the --

13 MR. HANAUER: That is 50 degree sub-cooling,
14 which is a commonly proposed limit for orderly
15 transients that don't -- I am sorry, that is the solid
16 one. The dotted one is saturation.

17 COMMISSIONER GILINSKY: The actual
18 saturation?

19 MR. HANAUER: That is your actual saturation.

20 COMMISSIONER GILINSKY: Okay.

21 MR. HANAUER: On page 6 is a stylized
22 transient. In the present state of our calculational
23 technique, I will try to indicate where, we sometimes
24 have to use this stylized transient. It is an
25 exponential temperature decay and a constant pressure.

1 So it has none of the ups and downs that are encountered
2 in real life in some of these transients. So it is an
3 over-simplification which we use in the present state of
4 our calculational ability. Sometimes we use it, and
5 sometimes we don't, I will try to tell you when.

6 Page 7 gives the result of fitting that
7 stylized transient to the eight transients that have
8 actually occurred. What is plotted here is this
9 temperature that it goes down to, and on the left-hand
10 side a probability, a frequency.

11 So this is a probability curve for transients,
12 and it is the probability of getting a temperature lower
13 than that amount. So the probability of getting a
14 temperature less than 300 degrees for this class of
15 reactors is about three times 10 to the minus 2 per
16 reactor year. So once every 30 reactor years, we expect
17 to get a temperature lower than 300 degrees, and there
18 are about 50 of these reactors, so we expect to see
19 somewhat more than one transient a year like this.

20 COMMISSIONER GILINSKY: Let's see, this lumps
21 together experience from the different reactors, so some
22 have experienced more transients and others less.

23 MR. HANAUER: This curve is for the PWRs in
24 the United States up till now. Now, not all PWRs in the
25 United States are as they were when they had these

1 transients. For example, there was a transient at
2 Rancho Seco, which is one of the transients plotted
3 here. Since that time, Rancho Seco and some other
4 reactors have been fixed, so that initiating event is
5 less likely.

6 COMMISSIONER GILINSKY: This is the estimate
7 based on what?

8 MR. HANAUER: No, there is no fudge factor in
9 here. This is what has happened.

10 COMMISSIONER GILINSKY: Since when?

11 CHAIRMAN PALLADINO: Based on the experience.

12 MR. HANAUER: Based on the eight over-cooling
13 transients worse than 350 that have actually been
14 experienced in the United States.

15 COMMISSIONER GILINSKY: Since when?

16 MR. HANAUER: Since the beginning of the
17 commercial power program.

18 COMMISSIONER GILINSKY: Aren't those more
19 heavily concentrated in the B&W reactors?

20 MR. HANAUER: Yes, sir, they are, and there is
21 a later viewgraph with a statistical analysis of that, a
22 later page.

23 COMMISSIONER GILINSKY: You may come to this
24 later, if you want to put it off. On an earlier curve
25 where you draw the line on the over-cooling side, what

1 sort of margin of safety is there in that line? We have
2 already passed the line for normal operation, and you
3 are now talking about the line beyond which you don't
4 want to get even in an accident condition.

5 MR. HANAUER: There is some considerable
6 margin in that, it comes from the very next page, which
7 is page 8. Page 8 is the result of deterministic
8 fracture mechanics calculations.

9 On this page, we assume that there is a flaw,
10 and we assume that the flaw is as big as it needs to be
11 to crack the vessel. So this is a very conservative
12 page. Later on, we do it more consistent --

13 CHAIRMAN PALLADINO: How big must the crack
14 be, for example?

15 MR. HANAUER: For the eight -- Actually, we
16 have analyzed this for the eight over-cooling transients
17 we actually had, and the critical flaw size is about an
18 inch deep.

19 COMMISSIONER ASSELSTINE: Do you mean big
20 enough to propagate?

21 MR. HANAUER: Yes, sir.

22 CHAIRMAN PALLADINO: An inch deep, but what is
23 the length?

24 MR. HANAUER: The length is very long in this
25 model. Another conservatism, although less conservative

1 than might otherwise be.

2 CHAIRMAN PALLADINO: When you say, very long --

3 MR. HANAUER: Very long. The model says,
4 infinitely long. In fact, it can be -- We have some
5 experimental data. The initial is probably not long,
6 but the flaws that propagates, the experimental data is,
7 gets quite long.

8 COMMISSIONER ROBERTS: Could the flaw that you
9 assume, be detected by ultrasonic testing?

10 MR. HANAUER: Yes, we think so. Perhaps, in a
11 borderline way, by the code required ultrasonic testing,
12 but there are better ultrasonic testing methods
13 available today, they are being used, and we think there
14 is a pretty high probability that they would be
15 detected.

16 COMMISSIONER ROBERTS: Would the ten-year
17 in-service inspection show such a possible flaw?

18 MR. HANAUER: That depends on how it was
19 done. If it were done only to code requirements, yes,
20 with some probability, but not really a high
21 probability. If it were done better than the code
22 requirements, which has in fact been the case in the two
23 or three vessels --

24 COMMISSIONER ROBERTS: Is that what Ocone
25 did?

1 MR. HANAUER: Yes, sir, they did better than
2 the code.

3 MR. DENTON: That is a very important area,
4 and by refining that you can reduce the assumed size of
5 the flaws that remain undetected.

6 COMMISSIONER ROBERTS: It would give you a
7 whole different set of answers.

8 MR. DENTON: They would permit higher and
9 higher vessel irradiations. The standard assumption
10 came out of our research program in which people looked
11 at under-clad cracks assuming that the standard sorts of
12 fabrication techniques and ultrasonic techniques were
13 used. The distribution ranges from very small ones
14 right up to, I guess, ones that are as big as an inch or
15 so in depth.

16 It is interest that such cracks are
17 occasionally found under cladding, so they can't be
18 discounted, but it is a conservative assumption in this
19 model. Plant by plant surveillance could reduce those
20 types of conservatisms.

21 COMMISSIONER GILINSKY: What do we make out of
22 this?

23 MR. HANAUER: This page 8 diagram is, again, a
24 pressure/temperature diagram. These lines delineate a
25 region for which there is cracking on the left and no

1 cracking on the right. The temperature is plotted as
2 the temperature of the cool-down, T-final, in that
3 stylized cool-down, minus RTNDT, the characteristic
4 referenced temperature of the vessel which characterizes
5 the transition between brittle and ductile behavior.

6 (Commissioner Roberts left the meeting.)

7 Now if that were a perfect description of the
8 vessel, all those curves would coalesce to one, but
9 there are effects. There is a pressure effect, which
10 makes these lines slope. There is a small temperature
11 effect, which you see down here at the bottom. Those
12 lines are only 10 or 20 degrees apart, so that is pretty
13 small. There is a small effect on how fast it cools,
14 which is measured by the beta.

15 (Commissioner Roberts returned to the
16 meeting.)

17 CHAIRMAN PALLADINO: I am sorry, but you are
18 going just a little too fast for me.

19 MR. HANAUER: All right. Suppose we have an
20 over-cooling transient --

21 CHAIRMAN PALLADINO: You were trying to tell
22 me about the 10 degrees, and I didn't find 10 degrees.

23 MR. HANAUER: All right. Suppose you have an
24 over-cooling transient that goes down to some
25 temperature, let's say 300 degrees.

1 CHAIRMAN PALLADINO: All right, which one do I
2 want to look at?

3 MR. HANAUER: All right. That depends on the
4 state of your vessel. If you have a 300-degree vessel --

5 CHAIRMAN PALLADINO: I see here it says, "TF
6 300 degrees."

7 MR. HANAUER: Yes.

8 CHAIRMAN PALLADINO: Do I follow that curve?

9 MR. HANAUER: Yes, but the same TF minus the
10 vessel properties. If you have a 300-degree vessel, you
11 go over here to zero.

12 CHAIRMAN PALLADINO: Yes.

13 MR. HANAUER: If you have better vessel, a
14 better vessel has a better RTNDT, you would go to the
15 left here.

16 CHAIRMAN PALLADINO: With a better vessel.

17 MR. HANAUER: A better vessel is on the left.

18 CHAIRMAN PALLADINO: Yes.

19 MR. HANAUER: I am sorry. A better vessel is
20 on the right, and it is less likely to crack.

21 CHAIRMAN PALLADINO: It depends on which way
22 you want to look at it.

23 Let me see if I understand what you are
24 saying. If my referenced NDT were exactly equal to 300
25 -- and I am taking the 300 curve -- then does this say

1 that I could accommodate a pressure of 2000 psi without
2 cracking, or roughly?

3 MR. HANAUER: Yes, that is what it says.

4 CHAIRMAN PALLADINO: Now if I go to 150
5 degrees, it says --

6 MR. HANAUER: Now be careful, 150 degrees --

7 CHAIRMAN PALLADINO: Let me go to 250
8 degrees.

9 MR. HANAUER: All right, 250. Now TF minus
10 RTNDT is minus 50 degrees down across the bottom.

11 CHAIRMAN PALLADINO: Yes.

12 MR. HANAUER: You go up to the 250 degree
13 curve, which is in fact right there with you, and it
14 says that you will crack that vessel because you are 50
15 degrees below the vessel properties.

16 CHAIRMAN PALLADINO: I am following the 250
17 degree curve --

18 MR. HANAUER: You have a 250 degree transient
19 in a 300 degree vessel.

20 CHAIRMAN PALLADINO: Now I understand, okay,
21 and it would roughly hold 1000 psi.

22 MR. HANAUER: Yes, if it comes slowly with a
23 low beta.

24 CHAIRMAN PALLADINO: What is beta?

25 MR. HANAUER: Beta is the exponential

1 constant on page 5.

2 MR. DENTON: It is the time which it takes to
3 reach the final temperature, time constant.

4 CHAIRMAN PALLADINO: Which is faster?

5 MR. HANAUER: Large betas are faster.

6 CHAIRMAN PALLADINO: So I am over to the
7 right, and I am not as good as the one over to the
8 left?

9 MR. HANAUER: That is right, because the
10 over-cooling comes faster and the thermal stress is
11 greater. You see, there is a thermal stress, which is
12 determined by the temperatures and beta, and a pressure
13 stress which is determined by the pressure.

14 CHAIRMAN PALLADINO: So if I take my 250 curve
15 and a 300-degree reference temperature, I couldn't hold
16 any pressure.

17 MR. HANAUER: That is right.

18 CHAIRMAN PALLADINO: Okay.

19 MR. HANAUER: Very crudely, you can stand a
20 transient more or less down to the referenced
21 temperature. In fact, our more refined calculations say
22 that you can go below the referenced temperature by a
23 few degrees, less than 100. This is a very conservative
24 curve. It assumes that there is a flaw right in the
25 cold place.

1 COMMISSIONER GILINSKY: Are you talking about
2 crack initiation or crack propagation?

3 CHAIRMAN PALLADINO: I think he talks of
4 initiation.

5 MR. HANAUER: In the dictionary sense, it is
6 propagation, but the crack-folks call it initiation.
7 The picture is, there is a pre-existing flaw, and this
8 transient makes the flaw run or propagate, which the
9 fracture mechanics people call initiate. It is a
10 confusing terminology.

11 COMMISSIONER GILINSKY: I am a little bit
12 troubled by where you have drawn the line earlier as
13 delineating the acceptable region in that we discussed
14 transients which go to temperatures below that.

15 MR. HANAUER: That is correct. There have
16 been transients which would have cracked this vessel, as
17 shown on those pages, namely, a vessel that has a
18 270-degree RTNDT in the axial welds or a 300-degree in
19 the circumferential welds.

20 COMMISSIONER GILINSKY: So you are drawing the
21 line, or you are proposing a line at a level that would
22 not have coped with all the ones that we have
23 experienced?

24 MR. HANAUER: Would not, in this conservative
25 picture, have coped. Later, I will show you some

1 probabilistic fracture mechanics which give a brighter
2 story.

3 CHAIRMAN PALLADINO: Steve, you are making, or
4 maybe you are not, let me ask you. Are you making an
5 assumption that all the material throughout the
6 thickness has the same heat temperature?

7 MR. HANAUER: No, sir. This is quite a
8 complicated calculation. It gives the variation of
9 material properties through the wall because of the
10 different irradiation, including accounting for the
11 change in the neutron spectrum. It also give the change
12 in the material properties during the transient because
13 different parts of the wall are different temperatures.
14 It accounts for these facts as a function of position in
15 the wall.

16 CHAIRMAN PALLADINO: The running
17 characteristics, though, of a crack are different.

18 MR. HANAUER: Yes. They are dependent on
19 irradiation and temperature, and both of those functions
20 are in this model.

21 COMMISSIONER ROBERTS: Are these vessel
22 stressed relieved at original manufacture?

23 MR. HANAUER: Yes, sir.

24 MR. DENTON: When we started this about a year
25 ago, there were considerable differences between

1 industry and ourselves on how to do these types of
2 calculations. I think now, at least with regard to
3 Westinghouse, in calculation of crack initiation, we are
4 in very close agreement between the staff and the
5 industry.

6 MR. HANAUER: Yes.

7 MR. DENTON: This is not the basis on which we
8 are making recommendations today. It is a more refined
9 curve later in the presentation that we put in more
10 realistic assumptions in certain aspects.

11 COMMISSIONER GILINSKY: I gather a less
12 conservative model.

13 MR. HANAUER: Yes.

14 MR. DENTON: With regard to the type of
15 cracks.

16 MR. HANAUER: Page 9 shows --

17 COMMISSIONER GILINSKY: It does seem to me
18 that if we are going to be conservative about anything,
19 this problem sounds like a candidate for being
20 conservative.

21 MR. DENTON: We agree and we think we are. We
22 will try to show you why.

23 MR. HANAUER: Page 9 shows the only
24 significant difference that I understand to exist
25 between us and the industry, and that is in the shape of

1 the initial flaw and in the shape in which the flaw
2 expands or propagates.

3 The right-hand side is the proposal by the
4 Westinghouse Owners Group. They propose that the
5 initial flaw be assumed to be six to one, that is to
6 say, a long, shallow ellipse, and that the flaw enlarge
7 in the same shape as shown by curve A.

8 The original model, the model which we used
9 and still use, is shown on the left, where we assume
10 that the flaw is infinitely long, a convenient
11 mathematical abstraction, and that it grows as an
12 infinitely long crack.

13 CHAIRMAN PALLADINO: The depth in both cases
14 is the same?

15 MR. HANAUER: The depth is the parameter that
16 you use to characterize your crack. Depending on what
17 you are doing, you have different assumptions.

18 Now, in order to figure out how important this
19 difference is, Westinghouse made some calculations.
20 They first made them in accordance with these
21 curve-shaped A. They then made them their elliptical
22 shaped initial flaw, but assuming that it propagates
23 like B. Once the crack starts to run, it becomes
24 infinitely long. The third set of calculations they
25 made was using our model, and their calculations using

1 our model gave results very close to our results. The
2 total difference between their model and our model is
3 about 100 degrees, so it is really very significant
4 indeed.

5 COMMISSIONER GILINSKY: A hundred degrees in
6 what?

7 MR. HANAUER: That is to say, if you do a
8 fracture mechanics model and you ask which vessels will
9 crack, assuming the Westinghouse flaw gives you 100
10 degrees more margin than assuming the infinite staff
11 flaw.

12 We think the initial Westinghouse flaw is
13 probably more realistic than ours. That the initial
14 flaw is more apt to be an ellipse, or something fairly
15 short.

16 COMMISSIONER ROBERTS: It is certainly not
17 going to be of infinite length.

18 MR. HANAUER: No, sir.

19 COMMISSIONER ROBERTS: You just said that it
20 was convenient mathematically for your model, but that
21 does not in any way mean that it is realistic.

22 MR. HANAUER: That is correct.

23 We think, however, that once they start to
24 run, that they will get quite long, and there is a good
25 deal of experimental evidence from the Heavy Section

1 Steel Technology Program that this is true, although
2 infinity is still a mathematical abstraction.

3 If you look at these two things abstractly,
4 the difference in the initial flaw, where we think
5 Westinghouse is probably right, is of the order of 10 or
6 15 degrees.

7 CHAIRMAN PALLADINO: Say that again, I am
8 sorry.

9 MR. HANAUER: The difference between
10 Westinghouse and us, in the initial flaw shape, is only
11 worth about 10 or 15 degrees.

12 COMMISSIONER GILINSKY: The effect of the
13 initial flaw?

14 MR. HANAUER: Yes, the effect of the different
15 shapes on the calculated failure.

16 CHAIRMAN PALLADINO: I am remembering the 100
17 you just said.

18 COMMISSIONER GILINSKY: He is going to get to
19 that.

20 MR. HANAUER: Yes.

21 The effect of the shape of the flaw once it
22 starts to go is worth about 85 or 90 degrees. So the
23 difference is primarily in how cracks run and arrest,
24 rather than in how cracks are initially.

25 My own view is that the Westinghouse initial

1 crack is probably right, more realistic, and therefore
2 this page which I characterized as very conservative is
3 probably about 10 or 15 degrees conservative for this
4 reason alone.

5 The evidence from the Heavy Section Steel
6 Program is that the reality is closer to the infinite
7 crack than to the short Westinghouse crack. So my own
8 view is that we should not give that large credit for
9 the Westinghouse crack shape.

10 The industry, or the Westinghouse Owners
11 Group's reply to this has been that they think that the
12 shorter crack shape is correct. They have a program
13 underway to demonstrate this, but it is apt to take more
14 than a year's research to show that it is true.

15 COMMISSIONER ROBERTS: Is it on-going?

16 MR. HANAUER: I don't guess I know whether it
17 is actually on-going or not. Perhaps there will be
18 somebody in the room who will know.

19 MR. DENTON: Let us provide that,
20 Commissioner.

21 COMMISSIONER GILINSKY: There is somebody
22 coming up.

23 MR. SAROFF (Westinghouse): I am Ray Saroff
24 from Westinghouse.

25 We do have an on-going Program under the

1 auspices of the Westinghouse Owners Group to look at
2 flaw shape growth characteristics. As Dr. Hanauer
3 indicated, that program extends through 1983.

4 There are other programs within the heavy
5 section steel technology at Oakridge that we think will
6 also produce data that will provide more realistic
7 growth characteristics for flaws as they extend. Again,
8 those are not scheduled for completion before the end of
9 1983.

10 As that data is accumulated, I think we will
11 have a more realistic picture of how the flaws extend.
12 But both programs are on-going.

13 CHAIRMAN PALLADINO: Thank you.

14 MR. HANAUER: Page 10 gives the result of
15 applying this kind of a model to the eight over-cooling
16 transients which have actually occurred.

17 COMMISSIONER GILINSKY: Would you just list
18 those eight?

19 MR. HANAUER: They are listed in this
20 enclosure.

21 CHAIRMAN PALLADINO: When you say, this kind
22 of a model --

23 MR. HANAUER: Enclosure A.

24 CHAIRMAN PALLADINO: When you say, this kind
25 of a model, you mean starting with the ellipse and going

1 to --

2 MR. HANAUER: No, sir. These calculations
3 were done with the infinite crack. So they are 10 to 15
4 degrees conservative.

5 The dotted curve on page 10 is the curve you
6 saw before plotted in final temperature terms. It runs
7 from about 225 degrees up to about 350 degrees. The
8 solid curve, what we did was, we took each transient as
9 it actually occurs, ups and downs and all, and used it
10 with this fracture mechanics model, and asked what
11 vessel at this plant, experiencing this transient, using
12 this conservative model, would have cracked.

13 So for the solid curve, these are values of
14 the reference temperature, the RTNDT, which these
15 transients, using this model, would have cracked.

16 CHAIRMAN PALLADINO: What is the bottom one;
17 that is the final temperature, is that right?

18 MR. HANAUER: The dotted curve is the final
19 fluid temperature that we talked about earlier.

20 CHAIRMAN PALLADINO: So now if they go up at
21 350 degrees, what does this mean?

22 MR. HANAUER: This says that the chance of
23 getting a transient that goes down to 350 degrees is
24 about two times 10 to the minus 2. If you have a 350
25 degree vessel, the probability of cracking it from these

1 eight events, with this conservative model, is just
2 about 10 to the minus 2.

3 What this is is an evaluation of experience of
4 the transients that we have had, and we asked, for each
5 transient, how bad would the vessel have had to be to
6 crack. These calculations were done for us by Oakridge
7 National Laboratory.

8 COMMISSIONER GILINSKY: Did you understand
9 that, Joe?

10 CHAIRMAN PALLADINO: I am trying. I think I
11 did, but I am not sure.

12 COMMISSIONER GILINSKY: I would like to hear
13 it again.

14 MR. HANAUER: Let's take the most severe one,
15 the Rancho Seco transient. The final temperature was
16 225 degrees. The actual water temperature was 225
17 degrees.

18 CHAIRMAN PALLADINO: All right.

19 MR. HANAUER: Now we ask the code what kind of
20 vessel would that transient have cracked. The answer
21 was, using this model, a 209 degree vessel would have
22 cracked by that event.

23 CHAIRMAN PALLADINO: Where did you read 209
24 degrees?

25 MR. HANAUER: So that the left-hand end of the

1 solid curve is at 209 degrees. There are tables of
2 these in enclosure A to the Commission paper.

3 CHAIRMAN PALLADINO: You started out with a
4 225-degree --

5 MR. HANAUER: The water got down to 225, but
6 it went so fast that a 209 degree vessel would have been
7 cracked because the pressure went back up.

8 CHAIRMAN PALLADINO: Where do I see the 209?

9 MR. HANAUER: It is the end of that black
10 line.

11 CHAIRMAN PALLADINO: I thought I would go up
12 from 225.

13 MR. HANAUER: That gets you to the end of the
14 dotted line, which is water temperature. There are two
15 curves here.

16 COMMISSIONER GILINSKY: My dotted line peters
17 out.

18 CHAIRMAN PALLADINO: My dotted line is sort of
19 blurred.

20 COMMISSIONER ASSELSTINE: It ends at 250
21 degrees.

22 MR. HANAUER: Pardon me.

23 CHAIRMAN PALLADINO: I am sorry, at 225
24 degrees, I come up and I read a frequency.

25 MR. HANAUER: Yes, sir, and that is one

1 accident in 350 reactor years.

2 CHAIRMAN PALLADINO: All right.

3 MR. HANAUER: It is about three times 10 to
4 the minus 3.

5 CHAIRMAN PALLADINO: What would have caused --

6 MR. HANAUER: It is the worst one we have
7 had. So we have only had one that bad, and that is why
8 it is plotted down at about three times 10 to the minus
9 3.

10 CHAIRMAN PALLADINO: Where do I go for 209? I
11 am looking at the dotted curve.

12 MR. HANAUER: The dotted curve is water
13 temperature, the transient temperature.

14 CHAIRMAN PALLADINO: What is the solid curve?

15 MR. HANAUER: The solid curve is vessel
16 properties that would have cracked in those transients.

17 CHAIRMAN PALLADINO: So these represent two
18 different things.

19 MR. HANAUER: Yes, sir.

20 CHAIRMAN PALLADINO: Okay, I didn't catch
21 that.

22 MR. DENTON: There is a dashed line right
23 above the solid line in the lower left, and the dashed
24 line is the water temperature. It looks like a smudge
25 there, but it is the dashed line.

1 CHAIRMAN PALLADINO: Okay.

2 MR. DENTON: It goes down to 225. So taking
3 that, and then turning to the code at Oakridge, they
4 back-calculated what vessel properties would have been
5 required to predict failure.

6 CHAIRMAN PALLADINO: How did you know that I
7 had to go the left to pick up to 209, or whatever that
8 number is?

9 MR. DENTON: We plotted the curve.

10 CHAIRMAN PALLADINO: Why is it worse?

11 MR. HANAUER: Why is it worse; because that
12 one happened so fast and the pressure was so high.

13 CHAIRMAN PALLADINO: Is this flat portion the
14 range?

15 MR. HANAUER: No, sir. You had only eight
16 events, so each event makes a lump in the curve.
17 Generally, your probability curve, which is smooth, but
18 here we are trying to figure out probability from only
19 eight things.

20 CHAIRMAN PALLADINO: But you said that it went
21 so fast, so I must assume that part of the band has to
22 do with the speed with which they changed the water
23 temperature.

24 MR. HANAUER: Yes, sir.

25 CHAIRMAN PALLADINO: So 209 is if I go very

1 fast. If I don't go so fast, it could be anything on
2 that bottom line?

3 MR. HANAUER: Yes, sir, it could. Even, if
4 you do it slowly enough, it won't crack it at all more
5 or less at any situation. You see this is the thermal
6 stress, so if you go slowly enough nothing happens.

7 CHAIRMAN PALLADINO: It depends on your delta
8 T.

9 MR. HANAUER: Yes.

10 The next page, number 11, attempts to answer
11 the question: Are reactors alike? The answer is, no,
12 the B&W reactors appear to be different.

13 The big, tall, hatched curve on the left-hand
14 side, these are statistical spreads, this is another way
15 to try and look at what has already happened. Since we
16 have had only eight events, the statistical precision of
17 what we are doing is very wide, and I have purposely
18 drawn these curves wide so people don't try and get
19 precise answers out of them, because they are not to be
20 found.

21 We have had these eight events, and we are
22 plotting here the same thing more or less as was plotted
23 in that solid curve on the preceding curve, except
24 instead of plotting one curve now, I have shown the
25 statistical spread which comes about from having had

1 only a few events.

2 The three worse events have been -- these are
3 the three on the left-hand side of the page -- the three
4 worse events have been in B&W plants. You see, the 209
5 degree point over there, and the next one, have all been
6 in B&W plants, whereas the other events on the page have
7 been in Westinghouse plants. We have had no severe
8 over-cooling events in Combustion-Engineering plants,
9 but we have so few reactor years that the statistics of
10 that are really very poor.

11 CHAIRMAN PALLADINO: Steve, you have this big
12 blob here.

13 MR. HANAUER: Yes.

14 CHAIRMAN PALLADINO: It has hashed lines going
15 to the right, that is the B&W.

16 MR. HANAUER: Yes.

17 CHAIRMAN PALLADINO: What does it tell me? I
18 see a range here of 209 to 285.

19 MR. HANAUER: Those are the three over-cooling
20 transients we have actually had in B&W plants.

21 CHAIRMAN PALLADINO: You are saying that the
22 final temperature range was between the 209 and the
23 285?

24 MR. HANAUER: Actually, this is plotted in
25 terms of the back-calculated how bad would the vessel

1 have to be, and that is why it is 209.

2 CHAIRMAN PALLADINO: All right.

3 MR. DENTON: Many of the meetings that we had
4 with industry dwelt on this point, whether or not there
5 are fundamental differences in the design and
6 operational modes of these plants that we should
7 recognize, and should we treat Westinghouse plants
8 differently from the C-E plants and the B&W plants.

9 One thing I noticed in these meetings is that
10 the Westinghouse and C-E Owners Groups had a very strong
11 owners group and did tend to get a lot of support from
12 C-E and Westinghouse. As we have discussed during our
13 recent meetings on water level instrumentation. In this
14 area, again, the B&W Owners Group is practically
15 non-existent.

16 What we are dealing with in the B&W case is a
17 bunch of owners. So we did not have what I call a
18 coherent view of B&W plants from that owners group as we
19 got from Westinghouse, which has a strong owners group,
20 and tended to treat all their Westinghouse plants and
21 all their operating data altogether. So we tended to
22 get, I think, Steve, some individual B&W owners and
23 their data.

24 MR. HANAUER: That is correct.

25 COMMISSICNER GILINSKY: Where is this spread?

1 You say there is a 90 percent confidence interval.

2 MR. HANAUER: That is the up and down. That
3 is the up and down spread on this. The upper-line is
4 the upper end at 95 percent confidence. The lower-line
5 is the 5 percent confidence.

6 CHAIRMAN PALLADINO: Which lower line?

7 MR. HANAUER: Way down there.

8 COMMISSIONER GILINSKY: This is on the basis
9 of three events?

10 MR. HANAUER: Yes, sir, and that is why the
11 spread is so wide, and on the basis of the small number
12 of reactors.

13 COMMISSIONER GILINSKY: I am not sure which
14 distributions you are using.

15 MR. HANAUER: These are Poisson
16 distributions.

17 CHAIRMAN PALLADINO: These are small
18 populations.

19 MR. HANAUER: Yes, they are.

20 What we did was, we attempted to infer, from
21 what I have been talking about in the last
22 three-quarters of an hour, a tentative screen criterion
23 which we would then test using some probabilistic
24 schemes.

25 What we had to work with was what you have

1 just seen, and what we concluded from this was that we
2 would pick 270 degrees for longitudinal cracks, which is
3 what all this business has been. We later found out
4 that in some vessels, the circumferential welds are the
5 ones with copper in them.

6 COMMISSIONER ROBERTS: Did you misspeak?
7 Didn't you mean longitudinal welds?

8 MR. HANAUER: Yes, sir, thank you.

9 Although we assume the cracks are in the welds
10 because the welds are the places where the high copper
11 is and where the brittle material is.

12 CHAIRMAN PALLADINO: Always?

13 MR. HANAUER: With one possible exception. In
14 one plant, the plate may dominate, but it is not very
15 serious because it is pretty good stuff. So in the
16 problem plants, the problem materials are in the welds.

17 In some vessels, there aren't any longitudinal
18 welds, and in some other vessels the longitudinal welds
19 are low copper but the circumferential welds are high
20 copper.

21 A circumferential weld, in which you assume
22 there is a circumferential crack, is a different beast.
23 In the first place, the pressure stresses are only half
24 as high and, in the second place, the crack is curved
25 and so is restrained by the geometry of the vessel.

1 Therefore, the situation is less severe. We did some
2 calculations and found that there is at least a
3 30-degree decrease in conservatism justified by that.
4 So given 270 for the longitudinal welds, we picked 300
5 degrees for the circumferential welds.

6 COMMISSIONER GILINSKY: How well are these
7 numbers defined?

8 MR. HANAUER: Very poorly in two respects.

9 COMMISSIONER GILINSKY: Plus or minus what?

10 MR. HANAUER: When you go to find out the
11 properties of an individual vessel, the standard
12 deviation is about 30-40 degrees. When you ask, how
13 well are these numbers deduced from the things I just
14 said, the precision is certainly no better than that,
15 and probably worse.

16 CHAIRMAN PALLADINO: These are the
17 temperatures for the NDT -- These are the NDT referenced
18 temperatures --

19 MR. HANAUER: Yes, sir.

20 CHAIRMAN PALLADINO: -- for the longitudinal
21 crack or the circumferential?

22 MR. HANAUER: Yes, sir.

23 COMMISSIONER GILINSKY: So, in actual fact,
24 when you pick a number like 270, you may in reality end
25 up with something like 310.

1 MR. HANAUER: No, sir, because the next page,
2 number 13, shows how we are going to evaluate a specific
3 vessel in a conservative way to avoid just that
4 problem.

5 Number 13 shows how we are going to decide
6 what the properties are of any given weld in any given
7 vessel. We start with measurements of the original
8 properties of that material, and we call that RT-0, the
9 original reference temperature. Then we make a
10 calculation of the change in the referenced temperature
11 due to the irradiation. And we have, in different
12 vessels, measurements of the neutron fluents and
13 measurements of the material properties, and we have
14 also, to help us, the measurements of all those
15 specimens in all the vessels which delineate the curve
16 better than any one specimen and any one vessel because
17 of the scatter.

18 CHAIRMAN PALLADINO: Steve, are you
19 characterizing the inner-most fibers of the steel?

20 MR. HANAUER: Yes. We are characterizing this
21 whole complicated thing.

22 CHAIRMAN PALLADINO: What I am getting at is
23 the delta RT is not constant through the thickness.

24 MR. HANAUER: That is right. I am
25 characterizing the whole vessel and the value of RT at

1 the inside wall, and that is how we characterized our
2 calculations. The calculations include the change
3 through the walls, but in order to use one number, we
4 used the number inside. That is not a conservatism
5 because that changes in the calculations that we use to
6 pick it.

7 CHAIRMAN PALLADINO: Okay.

8 COMMISSIONER GILINSKY: Let me ask you, isn't
9 there a number 200 which is fixed in our regulations, in
10 Appendix G, as having a certain significance?

11 MR. HANAUER: The Appendix G has two things in
12 it. One is the upper-shell toughness, that is to say,
13 the toughness of the material in the ductile range,
14 which is also affected by radiation and which we are not
15 dealing with today, but is also the subject of an
16 investigation that has been going on.

17 The second thing is that there is a provision
18 that the temperature of the vessel -- the pressurization
19 of the vessel and the temperature of the vessel must
20 stay within the bounds dictated by the properties of the
21 vessel. I don't believe that there is a number like
22 200.

23 Neal?

24 MR. MURLEY: Yes, there is. Maybe Neal can
25 explain it further.

1 The 200 degrees is evaluated at the quarter
2 thickness of the wall, so that it means two inches into
3 the wall. If your vessel is expected to get to 200
4 degrees during its lifetime, our regulations require
5 that it has to have the capability for annealing.

6 COMMISSIONER GILINSKY: Do any vessels fall in
7 that category?

8 CHAIRMAN PALLADINO: You said, if the vessel
9 gets to 200, or do you mean if the referenced
10 temperature.

11 MR. MURLEY: The referenced temperature of the
12 vessel is calculated to get to 200 degrees a quarter of
13 the way through the wall, that is two inches into the
14 wall, then it has to show the capability to anneal.

15 CHAIRMAN PALLADINO: It has to what?

16 MR. MURLEY: It has to have the capability to
17 be annealed.

18 CHAIRMAN PALLADINO: It is the referenced
19 temperature.

20 COMMISSIONER GILINSKY: Do any of the vessels
21 in use today fall in that group?

22 MR. HANAUER: Yes, sir, there are vessels
23 which are predicted to have referenced temperature
24 higher than 200 at quarter-thickness by the end of
25 life.

1 COMMISSICNER GILINSKY: Are they exempted from
2 this requirement?

3 MR. HANAUER: No, sir. They have, in fact,
4 made a demonstration that annealing is possible.

5 CHAIRMAN PALLADINO: What is that 2 to
6 squareroot of sigma zero?

7 MR. HANAUER: That is two standard deviations
8 and since there are two components, you add the standard
9 deviations as the squareroot of the sum of the squares.

10 MR. DENTON: This responds, Commissioner
11 Gilinsky, to your concern about conservatism. I think
12 what it shows is that when we are characterizing the
13 vessel, we are taking a conservative view, in my view,
14 of characterizing the properties.

15 Of course, there is a lot of uncertainty in
16 how you arrive at the correct numbers for doing the
17 screening, but when we go to an individual vessel, this
18 is the way we are determining that vessel's properties,
19 which compensates for some of the uncertainties in the
20 rest of the calculation.

21 CHAIRMAN PALLADINO: And the delta RT, you get
22 from some empirical data?

23 MR. HANAUER: Yes. There is a great deal of
24 data shown schematically on page 14, and some of the
25 actual correlation shown on page 15. The Commission has

1 seen some of these before, and perhaps in the interest
2 of time, unless there is a question --

3 CHAIRMAN PALLADINO: I have one question. If
4 I recall, these vessels have samples of original or
5 similar material in them which can be pulled out and
6 checked --

7 MR. HANAUER: Yes.

8 CHAIRMAN PALLADINO: -- which might give you a
9 better handle than some of the general curves on what is
10 happening to the embrittlement.

11 MR. HANAUER: That is correct.

12 CHAIRMAN PALLADINO: Are these used to monitor
13 these vessels?

14 MR. HANAUER: Yes. For each vessel, one
15 marshalls the vessel specific information that is
16 available and also the generic information from all of
17 the samples of that kind of material. We look at both.

18 CHAIRMAN PALLADINO: Do you show that in any
19 of your proposals?

20 MR. HANAUER: It is in enclosure A, in one of
21 the appendices, which discusses this question in some
22 detail.

23 MR. DENTON: When we are talking in these
24 tables about the properties of individual vessels, it
25 does reflect the data that has been derived from those

1 capsules in those plants where such data is available.

2 CHAIRMAN PALLADINO: You didn't use, maybe
3 that was too detailed. In your general recommendations
4 of what to do in the short-term, the monitoring of those
5 specimens was not mentioned.

6 MR. HANAUER: That is where all this
7 information came from, Mr. Chairman. That is where the
8 curves came from is evaluation of one of the capsules
9 that had been measured in all of these vessels. What
10 you do in any given vessel is, you find out what you
11 know about that vessel from its own capsules, and also
12 what you know more generally.

13 The capsules in the specific vessel give you
14 specific information, but the spread on any one
15 measurement is fairly wide. By putting together the
16 measurements of all the similar materials, you establish
17 with better accuracy what the properties are for that
18 family of materials.

19 CHAIRMAN PALLADINO: Let me buy it for a
20 while.

21 MR. HANAUER: There is a great deal of work on
22 this, the latest being by Guthrie of the Hanford
23 Engineering Development Laboratory.

24 COMMISSIONER JTLINSKY: I am going to have to
25 leave in a few minutes, but I did hope you could respond

1 a little more to the question of why you think it is
2 okay to set a temperature level which is well above
3 temperatures which have been attained in the various
4 events that we talked about.

5 MR. HANAUER: The short answer is that our
6 probabilistic calculations show that there was too much
7 conservatism in the assumption of a crack being just
8 where the cold water was, that the probability of that
9 is low. Therefore, the probability of that vessel
10 actually having failed in that transient is quite low.
11 That is why we proposed to set it at that high a value.
12 That is the short answer.

13 COMMISSIONER GILINSKY: On the basis of some
14 notion of the frequency of cracks?

15 MR. HANAUER: Yes, sir. There is in our
16 probabilistic model a crack probability distribution
17 based on a number of measurements in which several
18 thousand meters of welds were dissected to find all the
19 flaws, and the probability of such flaws being there and
20 not being detected was evaluated.

21 CHAIRMAN PALLADINO: Steve, could I use your
22 criterion on slide 8 just for a moment. If I go to
23 zero, and I am going to use your 270 degrees number, and
24 I will go over here and stick to the right-hand group,
25 the 270-degree line for the bottom temperature, and

1 since I have got a 270-degree NDT and zero, this would
2 say that I could carry over 2000 psi, or better than
3 2000.

4 MR. HANAUER: Yes. A 270-degree transient in
5 a 270-degree vessel, even in this conservative model,
6 could stand high pressure.

7 The answer to Commissioner Gilinsky's question
8 concerns a 209-degree transient in a 270-degree vessel.

9 COMMISSIONER GILINSKY: Precisely.

10 MR. HANAUER: In that case --

11 CHAIRMAN PALLADINO: Let me follow this one.
12 Let's follow it on slide 8.

13 MR. HANAUER: You have to go to minus 60 on
14 the aphis.

15 CHAIRMAN PALLADINO: Okay.

16 MR. HANAUER: You find that for the large
17 beta, it will crack for any pressure, because you are to
18 the left of the 209-degree curve. But for the small
19 beta, you can go up to 209 and you can stand about 1000
20 psi.

21 COMMISSIONER GILINSKY: Let me ask you, in
22 setting the limit, what sort of guidance did you use in
23 deciding how much of a safety margin there ought to be?

24 MR. HANAUER: I will tell you where we
25 started. We said, we will pick about a 10 to the minus

1 2, transient, and we will pick a vessel model without a
2 10 to the minus 4 of wrecking the vessel. At that time,
3 we knew both of those numbers very poorly. We looked at
4 10 to the minus 2 transients, some of those curves we
5 showed you earlier, and that is a number about 270
6 degrees.

7 At that time, we knew very little about
8 whether the vessel failure probability was in fact 10 to
9 the minus 4 or not. We had some early probabilistic
10 fracture mechanics curves. Later on, some of these
11 curves shifted around, and in fact, the 270, if we had
12 stuck to our original basis, could have been 300 or
13 higher. In the meanwhile, we had better probabilistic
14 curves and that told us to stay at about 270.

15 This is not a precise business. The original
16 choice of the number --

17 COMMISSIONER GILINSKY: I have not had a
18 chance to go through this six-inches of report, are the
19 assumptions laid out in there?

20 MR. HANAUER: Yes, sir.

21 MR. DENTON: They originally were well below
22 the type of safety goal of 10 to the minus 4 that the
23 Commission was talking about, because of the seriousness
24 of this type of failure. We felt that we were in about
25 a one time 10 to the minus 6 space, but very uncertain.

1 As it has evolved, and Steve has the latest number,
2 which is later in the presentation, but that is what we
3 were kind of shooting for when we first started, to make
4 this a very remote event.

5 COMMISSIONER GILINSKY: We have talked about
6 this before. A severe break in the vessel is something
7 for which we have not provided protection.

8 MR. HANAUER: That is correct.

9 COMMISSIONER GILINSKY: So it is something
10 with which we ought to be extremely careful. I know
11 there is no need to tell you that, but I just wanted to
12 give you my view.

13 MR. DENTON: The numbers for the screening
14 criterion, Steve has some estimates.

15 Do you want to turn to those, Steve, and show
16 what they are.

17 We are also proposing that we take action so
18 that we are not faced with a fait accompli with vessels
19 being right at these limits. If reasonable actions are
20 taken on a number of plants to keep fluence down, and
21 many plants never get to these levels.

22 We are not talking as though this is a speed
23 limit and we expect every plant to run right up to it.
24 We expect to be actions taken in a number of cases for
25 plants to stay below it.

1 CHAIRMAN PALLADINO: Some of the plants will
2 run up to that.

3 MR. DENTON: There is one plant that appears
4 unable to take any fluence reduction action without
5 exceeding it before the end of life, and that is
6 Robinson. There are a few plants which are going to
7 have to take more severe than the normal flux reduction
8 sort of changes.

9 MR. HANAUER: Why don't we turn to the
10 probabilistic results on page 25.

11 These are probabilistic results. They have
12 event-trees in them, and system failure probabilities.
13 What we have tried to do is figure out the various ways
14 in which we can get over-cooling transient, and to
15 consider both their probabilities and what they would
16 do.

17 We also have then a probabilistic model of
18 vessel failure, which I have referred to earlier, which
19 is somewhat complex, but which I can answer the first
20 level of questions on, and Mr. Sneider in the back of
21 the room can answer the second level of questions on,
22 since he did it.

23 The result is shown in these curves which plot
24 the frequency of vessel failing as a function of the
25 vessel properties. The X axis is the properties of the

1 vessel. This egg-shaped curve at the bottom left here
2 is intended to represent the distribution of vessel
3 properties.

4 (Commissioner Gilinsky left the meeting.)

5 You don't really know precisely the vessel
6 properties. So what I have drawn here is a vessel which
7 I evaluate at 270 degrees out at two standard
8 deviations. This vessel is most likely to be a
9 210-degree vessel because two standard deviations is 60
10 degrees. The probabilistic fracture mechanics considers
11 not this very conservative value of the vessel, but what
12 the vessel is most likely to be.

13 CHAIRMAN PALLADINO: Which is 210?

14 MR. HANAUER: Which is 210. That is to say,
15 we picked the way we evaluate vessels conservatively
16 enough so that a vessel we say is 270 is most likely to
17 be 210, although it can, with some small probability, be
18 270. That is what this curve -

19 CHAIRMAN PALLADINO: I wish victor would have
20 heard that, because I was having a little bit the same
21 trouble. I didn't appreciate that.

22 MR. HANAUER: So, a vessel just at the
23 screening criteria is most likely to be a 210, but can
24 be a 270.

25 CHAIRMAN PALLADINO: Two sigma is what, 2.67?

1 MR. HANAUER: No. That is one sigma. Two
2 sigma is .9-something.

3 CHAIRMAN PALLADINO: Okay, thank you.

4 MR. HANAUER: The various curves here are for
5 the various kinds of transients. The left-hand curve is
6 the sum.

7 CHAIRMAN PALLADINO: I am sorry, I was not
8 listening. I was still thinking.

9 MR. HANAUER: The various curves on page 25
10 are for various kinds of transients -- steamline breaks,
11 steam generator ruptures, and so on. The left-hand-most
12 curve, the slanty one here, is the sum for all the
13 different kinds of transients.

14 A new vessel is off on the left-hand side of
15 this thing, and the new vessel has a negligible chance
16 of getting hurt by any of this stuff because it has a
17 referenced temperature that is very low, and the chance
18 of transients down below 200 degree is really pretty
19 small.

20 As the vessel ages, you have to go toward the
21 right. As the vessel ages, its referenced temperature
22 gets higher.

23 CHAIRMAN PALLADINO: But always you are
24 talking about a referenced temperature that is the two
25 sigma temperature?

1 MR. HANAUER: You can talk about either one.
2 The numbers here are for the most probably, not for the
3 two sigma.

4 CHAIRMAN PALLADINO: Wait a minute, then. I
5 am sorry. Let's go to 270 again.

6 MR. HANAUER: Yes.

7 CHAIRMAN PALLADINO: Let's go up to your
8 top-most curve.

9 MR. HANAUER: Yes. If we have a 270 degree
10 vessel, and it is really a 270-degree vessel, then the
11 chance or the frequency of cracking it from pressurized
12 thermal shock in this model is about 10 to the minus 4
13 per reactor year.

14 CHAIRMAN PALLADINO: Ten to the minus 4?

15 MR. HANAUER: Yes, it goes up here to about 10
16 to the minus 4.

17 CHAIRMAN PALLADINO: I can't read that. Yes,
18 okay.

19 Then what is all this other stuff you were
20 telling me about with the two sigma.

21 MR. HANAUER: A vessel which just gets to the
22 screening criterion, I evaluate not at its most probably
23 value, but two sigma.

24 CHAIRMAN PALLADINO: So far as frequency is
25 concerned, it is whatever --

1 MR. HANAUER: It is whatever it, which we
2 still don't know very well. The most probable value for
3 that vessel just at the screening criterion is, in fact,
4 210.

5 CHAIRMAN PALLADINO: When you put the
6 frequency curves on, you don't use the same
7 temperature. You use whatever the temperature is.

8 MR. HANAUER: Yes.

9 CHAIRMAN PALLADINO: Does that say that if I
10 take my 270 one, I should go up here, really, and look
11 at 210?

12 MR. HANAUER: Yes, sir. That is the point of
13 that lower curve, and at 210, the failure probability
14 from pressurized thermal shock is something below 10 to
15 the minus 5.

16 CHAIRMAN PALLADINO: Okay.

17 MR. HANAUER: It is this kind of thing that
18 said don't move up over 270. If you would like a little
19 more conservatism, you get about a factor of 10 for each
20 35 or 40 degrees. If you would like them to be more
21 conservative by a factor of 10, then move down from 270
22 down to about a 235. That brings you down just a little
23 off the left-hand side of the page. That brings you
24 from the 10 to the minus 5 range into the 10 to the
25 minus 6 range.

1 MR. DENTON: One other point, Steve, just to
2 be sure we are conveying the right information. On this
3 curve, it was done using our infinite crack length
4 model. We have talked about those conservatisms
5 before.

6 This model has a crack distribution in it that
7 is the same crack distribution that came out of the
8 so-called Octavia code. So it has an assumed
9 distribution of cracks in the vessel, but the cracks are
10 assumed infinitely long. That is the basis for this
11 calculation.

12 CHAIRMAN PALLADINO: An assumed distribution
13 of cracks, explain what you mean by that.

14 MR. HANAUER: In the probabilistic model, we
15 have a model for the probability of there being a crack
16 of various sizes, a crack size probability
17 distribution. This is fairly high for very small
18 cracks, which you get when you put the beading on, and
19 it is very low for larger cracks.

20 CHAIRMAN PALLADINO: I am sorry, I didn't
21 understand that.

22 MR. HANAUER: Our conclusions are on page 28.
23 I will not quite read them.

24 We believe that vessels at or below the
25 screening criterion are acceptable. Vessels above the

1 criterion may be acceptable, but it takes much more
2 analysis for them than this generic stuff that we have
3 been doing. That is to say, we think we have a good
4 position that vessels below the screening criterion,
5 because of all these conservatisms, are surely okay with
6 high probability.

7 For vessels that reach the screening
8 criterion, or are predicted to reach it, we think that
9 there should be a plant specific analysis to look into
10 some of these things which were done generically and
11 without a lot of precision.

12 Most of the plants will or can be made to stay
13 below the screening criterion throughout their lives by
14 flux reduction measures, which different amounts in
15 different plants. To get a reduction up to a factor of
16 two is essentially free.

17 CHAIRMAN PALLADINO: It is free?

18 MR. HANAUER: It is free, and in fact some
19 plants have gone to this in order to get the benefits of
20 an 18-month cycle. So there are plants that have
21 already done this for other reasons.

22 CHAIRMAN PALLADINO: What do you mean, it is
23 free?

24 MR. HANAUER: You will have to pay more for
25 the fuel, but you get an 18-month cycle instead of a

1 12-month cycle, so you save money on down-time.

2 CHAIRMAN PALLADINO: What are you doing
3 physically?

4 MR. HANAUER: What you do physically, you load
5 the twice-burned fuel in the outside row.

6 CHAIRMAN PALLADINO: The which?

7 MR. HANAUER: You load the burnt down fuel in
8 the outside row. This has advantages for fuel cycle,
9 and at the same time it reduces the leakage flux, it
10 reduces the embrittlement of the vessel. Nothing in
11 life is free, but the cost seems to be low and some
12 plants have chosen to do it on the basis of savings in
13 down-time.

14 If you need more than a factor of two, as a
15 few plants do, then one would have to evaluate on a
16 plant specific basis how much you could get without
17 running into some other limits.

18 As you reduce the leakage flux more and more,
19 you effectively make the core smaller and smaller, and
20 you make the center of the fuel work harder and harder,
21 because the outside of the fuel is working less and
22 less.

23 CHAIRMAN PALLADINO: What do you do, you put
24 more burnt out fuel?

25 MR. HANAUER: Yes. If that isn't enough, then

1 you put dummy fuel in the outer-row. In Finland, where
2 they turned out to have a very susceptible vessel, and
3 in some German plants, they have replaced the entire
4 outer-row of fuel with stainless steel dummies, but this
5 involved some derating.

6 CHAIRMAN PALLADINO: Yes, I was going to say
7 where --

8 MR. HANAUER: We have a series of
9 calculations. The details are given in enclosure A.
10 Appendix I gives a series of calculations as to what can
11 be done and what some of the deratings and prices might
12 be if you need more than a factor of two.

13 CHAIRMAN PALLADINO: Is the derating
14 significant? I have not looked at of those curves.

15 MR. HANAUER: Yes, sir, the derating can be
16 significant. Our calculations show that you may be able
17 to get as high as a factor of four without derating.
18 But now you are into such plant specific questions as to
19 hot channel factors, and loading patterns, and so on
20 that we are in a grey area where we would have to have
21 plant specific information in order to get a --

22 CHAIRMAN PALLADINO: I am surprised you don't
23 get into trouble before that.

24 MR. HANAUER: Apparently not. H.B. Robinson,
25 for example, has already initiated -- reloaded with a

1 low flux factor of two reduction and did not have to
2 derate the core.

3 CHAIRMAN PALLADINO: A factor of how much?

4 MR. HANAUER: Two.

5 CHAIRMAN PALLADINO: No, I said, when you get
6 to four.

7 MR. HANAUER: When you get to three or four,
8 we have some calculations which suggest that most plants
9 can do it, but we don't really know until we look plant
10 specific. We know, for example, or we are told by
11 Carolina Power & Light that the factor of two is the
12 limit for that core, which is being pushed pretty hard.

13 COMMISSIONER ASSELSTINE: Is that strictly by
14 fuel management?

15 MR. HANAUER: It is fuel management, but the
16 limit is imposed by safety limits on the peak power
17 density and the calculated consequences of some
18 accidents and transients. Which accidents and
19 transients dominate depends on the reactor. Sometimes
20 it is loss of coolant accidents, and sometimes it is the
21 pump transients.

22 CHAIRMAN PALLADINO: How has derating been a
23 factor in the estimate of cost, or hasn't it?

24 MR. HANAUER: It has. We have estimated, on
25 the basis that no derating is required, up to a factor

1 of four, but we know that above two that is subject to
2 correction, and we would have to look at it plant by
3 plant.

4 We also recommend that most plants can stay
5 below the screening criteria throughout their lives by
6 flux derating, and we believe that it is prudent that
7 this be done in most plants. This is a real safety
8 improvement in these plants. It actually slows down the
9 embrittlement and keeps it in the acceptable region.
10 Whereas the other alternatives, if this option is not
11 taken, are either potentially very costly or they are
12 pencil-sharpening exercises to show that the
13 increasingly embrittled vessel is, in fact,
14 satisfactory.

15 The reason for emphasizing flux reduction is
16 that the embrittlement of the vessel is cumulative, and
17 that flux reduction to be effective has to be done in a
18 timely way. For vessels which need a factor of two or
19 less, a year more or less doesn't matter very much. For
20 the vessels which are more embrittled than that, a
21 timely flux reduction might be feasible now, whereas
22 later on that option would be foreclosed.

23 The Commission would be presented later on
24 with a fait accompli, where the options would be either
25 to show that a more brittle vessel was all right, to do

1 things like improve control systems, heat the emergency
2 core cooling water.

3 CHAIRMAN PALLADINO: I was going to ask you
4 about that one.

5 MR. HANAUER: At Robinson, they have committed
6 to do that.

7 CHAIRMAN PALLADINO: What is the normal water
8 temperature that you are assuming in these analyses?

9 MR. HANAUER: The assumption in the analysis
10 that we did was that the water was at 60 degrees. Many
11 tech specs require that the water be kept above 40
12 degrees, or above 50 degrees, and in northern climates
13 there is already some heating in that water.

14 There is also a maximum temperature on that
15 water because it is used for core cooling, and if it
16 gets too hot, it doesn't cool. But that maximum is way
17 above the range that I am talking about.

18 You get just about degree for degree
19 improvement in safety by warming this water in this
20 range. The proposal by Carolina Power & Light is to
21 make sure the water stays above 80 degrees, which gives
22 a 20-degree benefit in the safety record in this way,
23 and would push them 20 degrees further on the good side
24 of that probability curve.

25 CHAIRMAN PALLADINO: Why did you stop at 80?

1 MR. HANAUER: That is their proposal.

2 CHAIRMAN PALLADINO: But you are saying that
3 the tech specs could allow them to go up higher?

4 MR. HANAUER: The tech specs allow them to go
5 up higher.

6 CHAIRMAN PALLADINO: How much higher, 100?

7 MR. HANAUER: I don't know what the limit is
8 at Carolina.

9 CHAIRMAN PALLADINO: I am only trying to get a
10 feel.

11 MR. HANAUER: It is pretty high. In general,
12 it is not a problem, because in general the tanks are
13 outside, and something like 100 degrees is as high as
14 they would ever get, even in Carolina.

15 CHAIRMAN PALLADINO: Why not take advantage of
16 that?

17 MR. HANAUER: That is one of the options.

18 MR. DENTON: That is not the only limiting
19 transient either. That works for those transients where
20 that water is controlling the temperature. There are
21 other kinds of transients that eventually would become
22 dominant and further heating would not solve the
23 problem.

24 COMMISSIONER ASSELSTINE: As I read the
25 proposals, you had a set of near-term actions and a set

1 of longer-term actions. The near-term actions were
2 aimed principally at flux reduction. Is the idea that
3 what you fo is minimize the extent to which the problem
4 gets worse over the near-term?

5 MR. HANAUER: That was our objective.

6 Flux reduction is not an irrevocable measure.
7 If later on, some research program shows that we were
8 too conservative, then at the next loading they could
9 pay less attention to that if it turned out to be more
10 economical.

11 CHAIRMAN PALLADINO: Are all options, other
12 than flux reduction, closed out so far?

13 MR. HANAUER: No, sir, there are other
14 options. They tend to be more expensive than flux
15 reduction for most plants.

16 The plant we have looked closest at, to look
17 at the options, is H.B. Robinson, which is by far the
18 most embrittled plant at the present time. Carolina
19 Power & Light has come in with a multi-front program to
20 cope with this question.

21 The first thing they did, which has already
22 been accomplished, is to reduce the flux by a factor of
23 two, which they believe to be the practical limit in
24 that plant without derating. The next thing they have
25 committed to do --

1 CHAIRMAN PALLADINO: Did they look to see how
2 much derating they would have to do to try to get a
3 factor of four?

4 MR. HANAUER: I don't have such a number from
5 them.

6 CHAIRMAN PALLADINO: Did they look at that?

7 MR. HANAUER: I don't know. They have told us
8 informally that any more flux reduction than a factor of
9 two would involve derating, but they haven't told me --
10 I don't know of any number from them.

11 CHAIRMAN PALLADINO: I was thinking, if they
12 extend their life significantly, maybe a small derating
13 wouldn't hurt them. It is a balance of cost.

14 MR. HANAUER: It is, indeed. It is, indeed.

15 Nor do we have for that plant how much rating
16 would be required. In fact, there isn't any reasonable
17 flux rating that will get H.B. Robinson to the end of
18 life because they are already within 20 degrees of the
19 screening criterion.

20 COMMISSIONER ROBERTS: How confident are you
21 of the accuracy of the RTNDT for Robinson?

22 MR. HANAUER: We think it has an error band or
23 standard deviation of about 30 degrees. It is much
24 better known than the range of over-cooling accidents.
25 The error band, the uncertainty band on the vessel

1 properties exists and is significant, but the unknown,
2 the uncertainty in the kinds of over-cooling transients
3 is rather large and dominates the question. But, both
4 have to be considered.

5 COMMISSIONER ROBERTS: It looks to me like you
6 make a radical change. This viewgraph has conclusions,
7 but in the paper we have got here, you are going to
8 issue a show cause order to them.

9 As late as September, in your draft report,
10 and when you appeared before the ACRS, there was never
11 any such talk as this. Now, what has changed that has
12 changed your mind? I can't believe anything in a
13 two-month interval, as far as you know or don't know,
14 could have changed.

15 MR. HANAUER: What changed our mind is a
16 better look at the options and the realization that
17 some of the calculations, which we have, were not
18 realistic. The realization that no doable amount of
19 flux reduction would get H.B. Robinson to the end of its
20 life within the criterion.

21 The show cause order, the answer to such a
22 show cause order would presumably be a plant specific
23 evaluation which would, in fact, give the basis on which
24 further operation would be justified. Carolina Power &
25 Light has told us what their plans for making such an

1 evaluation.

2 Besides the flux reduction that they have
3 already done, the water warming, which they are
4 committed to do, they have also proposed to do an
5 evaluation of transients and to look into the
6 possibility of measuring better the actual properties of
7 their vessel than is implied by the 30 degree
8 uncertainty which I told you about.

9 COMMISSIONER ROBERTS: Why have a show cause
10 order?

11 CHAIRMAN PALLADINO: That is what I was
12 wondering. Why do we need a show cause order? They are
13 not in any dangerous state as far the criteria.

14 COMMISSIONER ROBERTS: That is what makes
15 headlines.

16 MR. HANAUER: They are calculated to reach the
17 screening criterion in a time period of five to seven
18 years from now. So that a show cause order would not
19 imply there is any immediate danger, but that a program
20 --

21 COMMISSIONER ROBERTS: They are not derate,
22 and that is not realistic, and you know that.

23 CHAIRMAN PALLADINO: But, Steve, if they are
24 committed to do all the things you want them to do, why
25 do you need a show cause order?

1 MR. DENTON: By committed, we have only, since
2 we sent the paper down, gotten verbal commitments. They
3 have not committed yet on the docket to do these
4 things. So we have been twisting their arm.

5 We think they can get through the cycle they
6 are in, but it is clear that they need a very ambitious
7 program to couple low leakage cores. They need plant
8 specific analyses. They need to look very carefully at
9 their surveillance specimens. They have a number of
10 actions that they can do to really pindown how good
11 their vessel is.

12 What we wanted to do was to get this from
13 them. If they volunteer it, then maybe we won't need
14 it. But as of today --

15 MR. HANAUER: We want it on the record.

16 COMMISSIONER ROBERTS: Are we reacting to
17 various pressures on this agency, or are we evaluating a
18 factual situation?

19 MR. DENTON: As an advocate of the position, I
20 thought that we should not wait until they get to 270
21 and then be confronted with a "either let me operate or
22 don't" kind of situation. We see that they were not
23 moving as fast in this area, or as aggressively, as we
24 thought they should.

25 They have moved along considerably since we

1 have started in the last month. We thought, when we put
2 this paper together, that we might have to force them to
3 propose a program to resolve it before they got to the
4 point of going above the criteria. If they are willing
5 to cooperate and do it otherwise, that is fine also.

6 CHAIRMAN PALLADINO: Couldn't we do it with a
7 50.54(f) letter?

8 MR. DENTON: It depends on the willingness of
9 the utility to do it. We could certainly start that
10 way.

11 CHAIRMAN PALLADINO: Don't they have to
12 respond to a 50.54(f) letter?

13 MR. DENTON: Yes.

14 CHAIRMAN PALLADINO: A show cause order is a
15 pretty drastic move, and you take it for drastic
16 circumstances. If there was no other way to get them to
17 move, then that would be different. But it sounds like
18 they are moving, and if we can accomplish it with a
19 50.54(f) letter, I wonder why do it with a show cause.

20 MR. DENTON: I think it is --

21 CHAIRMAN PALLADINO: Maybe the circumstances
22 have changed such that you might want to consider that.

23 MR. DENTON: We will consider it. The
24 proposal that is before us, I think we consider still
25 lacking some depth in covering all of the bases that are

1 needed to provide the kind of assurance we will need
2 when they get to cycle 10 and 11.

3 We all agree that they are a few years away
4 from tripping the limit, and we think they need to mount
5 this sort of aggressive program today, and if they would
6 volunteer that kind of program that would provide the
7 information we need. I just didn't want to get out to
8 '84 or '85, and then not have the information available
9 to make an informed decision.

10 CHAIRMAN PALLADINO: I don't think anyone is
11 taking exception with trying to get action in that
12 direction, it is the vehicle for doing it. I know
13 Commissioner Ahearne, he can speak for himself when he
14 comes back, is quite concerned about that route also, if
15 it can be accomplished by a 50.54(f) letter, or some
16 other means, more imaginative means that you might
17 develop.

18 MR. DENTON: We could sure consider that.

19 Steve, would you like to comment on that
20 program, how you see it as it has been outlined to
21 date?

22 MR. HANAUER: The program has been orally
23 described to us with some viewgraphs in a half-day
24 meeting of about three weeks ago. It contains a number
25 of aspects, a number of facts, including the one they

1 have already performed, the flux reduction, and the one
2 they have they will do, namely, to heat the water.

3 It also include plant specific analysis of one
4 transient, which is being done in collaboration with the
5 Electric Power Research Institute, and collaboration
6 with one of our research programs in doing a more
7 detailed probabilistic analysis.

8 But the delineation of when these products
9 will become available and what the options are for plant
10 modifications, if they are needed, has not yet been
11 developed, and we have not seen a fully developed
12 program commensurate with the embrittled state of this
13 vessel. We think that there probably will be such a
14 program, and we would like to see it progress.

15 MR. DENTON: We were just trying to put
16 together a structured response. There are many plants
17 which will not exceed these criteria even at the end of
18 life. Then we saw that Robinson was the highest and
19 needed the most assurance that we would be able to deal
20 with that.

21 Then there were some in the other class, and
22 we proposed the 50-54(f) letter as a way of dealing with
23 those. Then for the few that may need some moderate
24 flux reduction programs, we would propose a rule to the
25 Commission within the next six months, that could be

1 issued as a proposed rule that would deal with making
2 sure that the great bulk of those plants do take those
3 flux reduction measures at the appropriate time.

4 CHAIRMAN PALLADINO: I still had the question
5 why a 50.54(f) letter would not be appropriate.

6 MR. DENTON: That could be used. That is
7 always the first issue. Then if what you get back is
8 not satisfactory, you can proceed further.

9 MR. HANAUER: This is, perhaps, a suitable
10 finish in view of the time. I believe the important
11 questions have been explored, and we are available for
12 further questions and discussions, Mr. Chairman.

13 CHAIRMAN PALLADINO: I am looking over the
14 list of questions. I have gotten most of mine answered
15 along the way, and a few that I won't bother with today,
16 but I might bother with at some later time.

17 What degree of industry activity do we have in
18 the long-term program?

19 MR. HANAUER: The long-term industry program --

20 CHAIRMAN PALLADINO: What share of the burden
21 are they taking?

22 MR. HANAUER: There are several industry
23 programs. There is the Electric Power Institute
24 research program in pressurized thermal shock, which
25 includes vessel properties and the development of

1 methods for analyzing over-cooling transients.

2 The owners groups, there has been a very
3 extensive Westinghouse Owners Group program which is
4 substantially responsible for the probabilistic insights
5 that we have achieved since May and June, when this was
6 first presented to us by the Westinghouse Owners Group.

7 The Combustion-Engineering Owners Group also
8 has a program in both vessel material properties and in
9 the transient analysis.

10 B&W has completed a very extensive, perhaps
11 the most extensive review of vessel material properties,
12 but very little other activity is known to us by the
13 owners group.

14 The plants, which are principally affected --
15 they know very well who they are, and they tend to be
16 the leaders of the owners groups -- are doing plant
17 specific analyses in some areas.

18 There are also in the owners groups additional
19 research programs, such as the one that Mr. Seroff
20 described to you earlier in the afternoon on crack shape
21 in answer to your question. There are a substantial
22 number of those programs that have been reported to us,
23 and there are no doubt others which are not yet in a
24 state to be talked about.

25 There is also substantial cooperation by three

1 plants in the NRC research program into over-cooling
2 transients, which is being led by Oakridge National
3 Laboratory. Also there is participation by Los Alamos
4 and Idaho Nuclear Engineering Laboratories in quite
5 elaborate calculations of over-cooling transient
6 probabilities, and the course and severities.

7 In order to be specific about these, we have
8 chosen to study three specific pressurized water
9 reactors. Oconee, for the B&W plants, is the first one
10 which is well underway. The Westinghouse plant is to be
11 H.B. Robinson and Carolina Power & Light, and we are
12 collaborating, and some of that information will surely
13 be part of the basis for the safety evaluation of the
14 Carolina Power & Light Robinson plant. The third plant
15 is Calvert Cliffs, which is representative of the
16 Combustion design.

17 We are evaluating in our research program, in
18 this collaborative way, these three plants of different
19 designs to get insights into whether the generic
20 requirements should in any way be changed. This is a
21 multi-year program, which has completed about the first
22 year.

23 There is also the very large heavy section
24 steel technology program, contributions by the pressure
25 vessel research Committee of the industry, which has

1 been going on for nearly 20 years, which has already
2 done a substantial number of thermal shock experiments,
3 and which is now getting ready to do some pressurized
4 thermal shock experiments in large model vessels.

5 CHAIRMAN PALLADINO: Is anybody looking into
6 the feasibility of an answer to annealing?

7 MR. HANAUER: There is a program underway,
8 under our auspices, at Idaho, to look into the
9 feasibility and the costs and benefits. We have a
10 preliminary report from them, and research is within a
11 few weeks of making a recommendation to us on whether
12 such a test would be feasible, and whether it would be
13 cost effective.

14 CHAIRMAN PALLADINO: Whether a test --

15 MR. HANAUER: Whether an annealing
16 demonstration test --

17 The metallurgy of the annealing process seems
18 rather well-known. What is not known is whether it is
19 in fact a practical and a practicable procedure, and
20 whether it introduces any safety questions that would
21 have to be resolved, which would give a downside to what
22 would otherwise be a safety improvement, although it is
23 believed to be quite an expensive one.

24 COMMISSIONER ROBERTS: Inexpensive?

25 MR. HANAUER: An expensive one.

1 CHAIRMAN PALLADINO: I just wanted to make
2 sure of that.

3 MR. HANAUER: Yes.

4 CHAIRMAN PALLADINO: If it is cost effective,
5 or if you lose more not doing it than doing it, the
6 answer will come out differently.

7 I had another question, but I forgot it. Do
8 you have any questions, Tom?

9 COMMISSIONER ROBERTS: Most of mine have been
10 answered.

11 COMMISSIONER ASSELSTINE: I have one.

12 CHAIRMAN PALLADINO: Go ahead, Jim.

13 COMMISSIONER ASSELSTINE: The only question I
14 have is for the near-term actions on this middle
15 category of plants, not Robinson and not those where
16 over the lifetime the level can be kept in acceptable
17 ranges simply by fuel management.

18 For the ones that you might have to use the
19 dummy assemblies. Is there general agreement from those
20 licensees of about eight plants that this is the best
21 alternative for the short-term?

22 MR. HANAUER: No, sir. They have rather
23 recently received our calculations and they have now,
24 today, with the public distribution of this version of
25 this report, which has some new data in it -- They have

1 just today gotten the details of the basis for our
2 recommendations.

3 We have no plant specific analyses of these
4 eight plants, although there have been many fuel
5 management calculations for them, I am sure. We don't
6 know whether our generic calculations in fact fit the
7 circumstances of these eight plants. And we have not
8 had a dialogue, we need one, and we intend to have one
9 with these eight plants.

10 COMMISSIONER ASSELSTINE: I guess one of the
11 things I was wondering was to what extent they might
12 want to come in with a proposal somewhat like the
13 heating of the ECCS water, for example, as an
14 alternative to installing dummy assemblies.

15 MR. HANAUER: We don't know.

16 We would welcome an exploration of
17 alternatives in these plants.

18 COMMISSIONER ASSELSTINE: So you are not
19 necessarily locking them into the alternative that you
20 have described here. If they want to come in with an
21 alternative proposals that would involve some of that,
22 but perhaps other alternatives as well, that would be
23 within what you have in mind here?

24 MR. HANAUER: That is correct.

25 But for those plants, a fairly prompt

1 evaluation would be appropriate in order not to
2 foreclose some options.

3 COMMISSIONER ASSELSTINE: Okay.

4 CHAIRMAN PALLADINO: But heating the water
5 doesn't cover all the circumstances.

6 MR. HANAUER: It doesn't cover all the
7 circumstances. For the Westinghouse plants --

8 CHAIRMAN PALLADINO: But it may cover the
9 circumstances of significance to that plant.

10 MR. HANAUER: The analysis we have is for
11 Westinghouse plants, and that analysis in its present
12 state of maturity or immaturity shows that the dominant
13 event would be helped by heating the water. But I would
14 not want to call this a mature evaluation.

15 The fact that we have a new set of sequences
16 every month is clear evidence to me that the evaluation
17 needs to be continued and matured to the point where we
18 have general agreement that we have all the right
19 sequences in there, and that they have been evaluated
20 realistically.

21 CHAIRMAN PALLADINO: Steve --

22 MR. HANAUER: Let me say one more thought on
23 that.

24 I want to emphasize to emphasize that what we
25 have is a Westinghouse analysis. The C-E plants are

1 similar and we feel that the adequacy of these analyses
2 in their present shape is satisfactory for the C-E
3 plants, although we are more than willing to see a more
4 complete C-E plant analysis.

5 The difference in response of the B&W plants,
6 and the difference in experience in the B&W plants,
7 makes this situation a lot less rosy for the B&W plants
8 and we do not have the same degree of assurance for
9 them. Two of the eight plants you mentioned are B&W
10 plants, and it is our plan to use them as lead plants
11 for exploring these questions in B&W plants.

12 COMMISSIONER ASSELSTINE: So the emphasis,
13 really, for these eight plants is to get an analysis, a
14 detailed analysis, a satisfactory analysis as soon as
15 possible right in the near-term and look at what the
16 plans are for B&W plants.

17 MR. HANAUER: Yes, sir, this is our
18 intention.

19 CHAIRMAN PALLADINO: Steve, you said some of
20 the plants, you are clear, won't need any corrective
21 action before the end of the life, and others like
22 Robinson need something soon. Do we have an analysis in
23 this report?

24 MR. HANAUER: Yes, sir, you have detailed
25 tables in the report, and you have in this handout the

1 table which starts on page 16.

2 CHAIRMAN PALLADINO: They are small numbers,
3 small print.

4 MR. HANAUER: Sorry about that, Mr. Chairman.

5 CHAIRMAN PALLADINO: Thank you.

6 MR. HANAUER: The right-hand three typewritten
7 columns are ours, and the licensees' evaluation of the
8 present state of the vessel, and the right-hand
9 handwritten column for a few plants is our evaluation of
10 when they are likely to get to the screening criterion.

11 CHAIRMAN PALLADINO: What is the heading
12 there?

13 MR. HANAUER: Year exceed screening RT.

14 CHAIRMAN PALLADINO: That did not come clear,
15 and maybe I can get a better copy.

16 MR. HANAUER: A more detailed evaluation --

17 COMMISSIONER ROBERTS: There is an error in
18 this.

19 MR. HANAUER: Which one, sir?

20 COMMISSIONER ROBERTS: They are not all on
21 unit 1.

22 CHAIRMAN PALLADINO: What page?

23 COMMISSIONER ROBERTS: Page 16, in the
24 handwritten column.

25 MR. HANAUER: It says 1995.

1 COMMISSIONER ROBERTS: Mine reads 1975.

2 CHAIRMAN PALLADINO: We need better copies.

3 MR. HANAUER: You shall have a better copy if
4 we can provide it.

5 CHAIRMAN PALLADINO: Even if we get somebody
6 to darken those numbers, so that we can see them.

7 MR. HANAUER: Somebody down here has the
8 original, which has those numbers darker, and that can
9 presumably be provided to you. I think the original is
10 down here.

11 CHAIRMAN PALLADINO: All right, we will get
12 it.

13 MR. HANAUER: If you need help from us, we
14 will be glad to supply it.

15 CHAIRMAN PALLADINO: Are you seeking from this
16 Commission -- Are you seeking approval of your program,
17 including action?

18 MR. HANAUER: Yes, sir, approval of the
19 program.

20 For specific action, we will come back to the
21 Commission. The rulemaking for most plants and any
22 orders that would be proposed would come back to the
23 Commission.

24 CHAIRMAN PALLADINO: So in approving this, we
25 would not necessarily be approving the show cause?

1 MR. HANAUER: That is corr ct, or you could
2 explicitly reserve it.

3 CHAIRMAN PALLADINO: Yes.

4 COMMISSIONER ROBERTS: I think if you approve
5 the piece of paper you have, you are approving the show
6 cause order.

7 CHAIRMAN PALLADINO: Unless we express it.

8 MR. DENTON: Perhaps you should approve it
9 with the exception of treating Robinson in the same
10 50.55(f) category as proposed for the others.

11 CHAIRMAN PALLADINO: Yes.

12 COMMISSIONER ROBERTS: That would be my
13 choice.

14 CHAIRMAN PALLADINO: We could live with that.
15 We are going to have another session on this. Probably
16 at that time, we will want to focus on the questins
17 regarding rulemaking and some of the policy issues.

18 MR. DENTON: On the rulemaking, we won't be
19 ready next week with the rule. We figure that if you
20 agree with the rule, it will take us a while to put it
21 together. We think that there is ample time for it.

22 CHAIRMAN PALLADINO: I was thinking of the
23 details.

24 COMMISSIONER ASSELSTINE: But you are asking
25 for Commission direction to prepare a rule, and come to

1 us with it in six months.

2 MR. DENTON: That is right.

3 There is also a table in here, Table 35, that
4 is a little bit clearer than the one that had the
5 handwritten notes, and it shows the --

6 CHAIRMAN PALLADINO: What page is that?

7 MR. DENTON: Page 35.

8 CHAIRMAN PALLADINO: Page 35.

9 MR. DENTON: It shows the plants which will be
10 within the screening criterion at the end of life which
11 will, without any change, be between one and two times
12 the screening criterion, which will be four times the
13 screening criterion. It is just another way of
14 portraying the same information that was on that page 16
15 that we mentioned.

16 CHAIRMAN PALLADINO: Okay, are there any
17 other questions?

18 I thank you. That was a very enlightening and
19 good presentation.

20 I want to take this opportunity to again
21 express to Steve Hanauer our best wishes and our many
22 thanks for his dedicated public service. Good luck to
23 you in your new venture.

24 COMMISSIONER ASSELSTINE: I certainly join in
25 that speech.

1 MR. HANAUER: Thank you, Mr. Chairman. It has
2 been a privilege to serve the Commission in various
3 ways. I will remember it with pleasure.

4 CHAIRMAN PALLADINO: We will stand adjourned.

5 (Whereupon, at 3:45 p.m., the meeting
6 adjourned.)

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the
COMMISSION MEETING

in the matter of: PUBLIC MEETING - BRIEFING ON PRESSURIZED THERMAL
SHOCK

Date of Proceeding: December 1, 1982

Docket Number: _____

Place of Proceeding: Washington, D. C.

were held as herein appears, and that this is the original transcript
thereof for the file of the Commission.

Patricia A. Minson

Official Reporter (Typed)

Patricia A. Minson

Official Reporter (Signature)


PRESSURIZED THERMAL SHOCK
PRESENTATION TO THE
NUCLEAR REGULATORY COMMISSION

DECEMBER 1, 1982

STEPHEN H. HANAUER

OUTLINE

- o GENERAL APPROACH
- o EVALUATION OF EXPERIENCE
- o SCREENING CRITERION
- o APPLICATION TO PLANTS
- o PROBABILISTIC EVALUATION
- o CONCLUSIONS AND RECOMMENDATIONS



TEMPERATURE

PROBABILITY

OUTLIER


PRA

"TAIL"

EXPERIENCE


PRESSURE - TEMPERATURE DIAGRAM

EVENT: H.R. ROBINSON SLB 04/28/70




PRESSURE - TEMPERATURE DIAGRAM

EVENT: RANCHO SECO NNI/ICS 03/20/78




PRESSURE -- TEMPERATURE DIAGRAM

EVENT: RE. GINNA SGTR + PORV 01/25/82




$$T(t) = T_f + (T_0 - T_f) \text{EXP}(-\beta t)$$


P (t) = CONSTANT



FREQUENCY BASED ON OPERATING HISTORY
FINAL FLUID TEMPERATURE




GENERIC CALCULATION OF CRACK
INITIATION FOR STYLIZED TRANSIENTS




ASSUMPTIONS ON FLAW AND CRACK GEOMETRY


STAFF




WOG



FREQUENCY BASED ON OPERATING HISTORY
 CRITICAL RTNDT VALUE (OCA RESULTS) AND FINAL FLUID TEMPERATURE.



OPERATING EXPERIENCES (90% CONFIDENCE INTERVALS)
 CRACK EXTENSION WITHOUT ARREST



SCREENING CRITERION

- o LONGITUDINAL CRACK 270°F
- o CIRCUMFERENTIAL CRACK 300°F


EVALUATING A SPECIFIC VESSEL

$$RT_{NDT} = RT_0 \quad (\text{BEST ESTIMATE})$$

$$+ \Delta RT \quad (\text{BEST ESTIMATE - GUTHRIE})$$


$$+ .2 \sqrt{\sigma_0^2 + \sigma_{\Delta}^2}$$

$$\text{LIMITED BY RG } 1.99 + 2\sigma_0$$



FLUENCE

RTNDT



EXAMPLE OF NRC PRESCRIPTION FOR RT_{NDT} (FOR ASSUMED
 $RT_{NDT}(o)$ OF 0°F)

Table P.1 RT_{NDT} Values for All Plants⁽¹⁾ Calculated Per the Recommendations of the Working Group on RT_{NDT}⁽²⁾ for the Vessel Inside Surface.

Plant NSSS/Vessel Fabricators	EFPY as of 12/31/81	Fluence n/cm ² x10 ¹⁸	Copper %	Nickel %	Mean Initial RT _{NDT}	Mean ΔRT _{NDT}	$2\sqrt{\sigma_D^2 + \sigma_\Delta^2}$ (5)	RT _{NDT} , °F, as of Dec 31, 1981(6) Circum. Axial	Licensee's RT _{NDT} , °F	Year Exceed Screening RT
Robinson 2 W/CE	7.10	(14.1)(3)(8) 14.8 (3)(8)	(0.35) 0.27	(1.20) 0.20	(-56) -56	(303)(4) 151	34 (4) 59	281 154	290 220	1988
Turkey Point 4 W/B&W	5.67	9.1 (9) No Axial Welds	(0.32)	(0.57)	(0)	(200)	59	259	211	1989
Turkey Point 3 W/B&W	5.67	(9.1)(9) No Axial Welds	(0.32)	(0.57)	(0)	(200)	59	259		1989
Fort Calhoun CE/CE	5.07	(7.04) 5.1 (10)	(0.35) 0.35	0.99 0.99	(-56) -56	(264)(4) 248 (4)	34(4) 34 (4)	242 226	209 (239)(7)	1990
Maine Yankee CE/CE	5.90	(5.02) 4.14	(0.36) 0.36	(0.99) 0.99	(-56) -56	(248)(4) 238(4)	34(4) 34(4)	226 216	170 (198)(7)	1995
Indian Point 3 W/CE	2.98	(1.67) Plate Governs	(0.24) 0.24	(0.52) 0.52	(+74) +74	(90) 90	48 48	212 212		
Yankee Rowe W/B&W/B&W	14.56	(11.35) Plate Governs	(0.20) 0.20	(0.63) 0.63	(+30) +30	(133) 133	48 48	211 211		
Rancho Seco B&W/B&W	3.54	(2.33) 2.05	(0.31) 0.35	(0.59) 0.59	(0) 0	(135) 148	59 59	194 207		1993
Three Mile Island 1 B&W/B&W	3.52	(1.87) (1.87)	(0.31) 0.35	(0.68) 0.60	(0) 0	(133) 145	59 59	192 204	145	1995
Oconee 2 B&W/B&W	4.71	(2.87) No Axial Welds	(0.35)	(0.71)	(0)	(172)	59	231		1996

(1) See footnote(s), last page of table.

These values are subject to change when plant-specific analyses yield better information.

Table P-1 (Continued)

Plant NSSS/Vessel Fabricators	FFPY as of 12/31/81	Fluence n/cm ² x10 ¹⁸	Copper %	Nickel %	Mean Initial RT _{NDT}	Mean Δ RT _{NDT}	$2\sqrt{\sigma_{\Delta}^2 + \sigma_{\Delta}^2}$ (5)	RT _{NDT} , °F, as of Dec 31, 1981(6) Circum. Axial	Licensee's RT _{NDT} , °F
Point Beach 1 W/B&W	8.07	(10.01) 7.34	(0.24) 0.24	(0.57) 0.57	(0) 0	(151) 139	59 59	210 198	
Oconee 1 B&W/B&W	5.04	(2.32) 2.73	(0.26) 0.31	(0.61) 0.55	(0) 0	(113) 138	59 59	172 197	160
Zion 1	4.97	(3.13) 0.99	(0.35) 0.31	(0.53) 0.61	(0) 0	(166) 108	59 59	225 167	
Indian Point 2 W/CE	4.40	No Circum Data 2.2	0.34	1.2	-56	211 (4)	34 (4)	189	
Arkansas ANO-1 B&W/B&W	4.42	(2.70) 1.99	(0.31) 0.31	(0.59) 0.59	(0) 0	(140) 129	59 59	199 188	
Point Beach 2 W/B&W, CE	7.54	(9.35) No Axial Welds	(0.25)	(0.59)	(0)	(156)	59	215	
Gianna W/B&W	8.18	(9.49) No Axial Welds	(0.25)	(0.56)	(0)	(154)	59	213	
San Onofre W/CE	9.04	(33.45) 27.12	(0.27) 0.27	(0.20) 0.20	(-56) -56	(188) 178	59 59	191 181	233
Zion 2 W/B&W	4.49	(2.83) 0.90	(0.26) 0.35	(0.61) 0.59	(0) 0	(119) 118	59 59	178 177	
Palisades CE/CE	4.12	(4.78) 4.78	(0.25) 0.25	(1.2) 1.2	(-56) -56	(174) 174	59 59	177 177	
Crystal River 3 B&W/B&W	2.48	(1.44) 1.36	(0.35) 0.31	(0.59) 0.61	(0) 0	(134) 118	59 59	193 177	

Year
Exceed
Screening RT

2000

Table P-1 (Continued)

Plant NSSS/Vessel Fabricators	EFPY as of 12/31/81	Fluence n/cm ² x10 ¹⁸	Copper %	Nickel %	Mean Initial RT _{NDT}	Mean Δ RT _{NDT}	$2\sqrt{\sigma_b^2 + \sigma_a^2}$ (5)	RT _{NDT} , °F, as of Dec 31, 1981(6) Circum. Axial	Licensee's RT _{NDT} , °F
Surry 1 W/B&W	4.88	(7.61) 1.66	(0.25) 0.21	(0.51) 0.59	(0) 0	(141) 81	59 59	200	140
Cook 1 W/CE	4.56	(2.87) 1.55	(0.40) 0.13	(0.82) 0.99	(-56) -56	(222) (4) 58	34(4) 59	200	61
North Anna 1 W/RD	2.41	(4.42) No Axial Welds	(0.14)	(0.80) Forging Governs	(+38)	(76) 48	48	162	162
Beaver Valley W/CE	1.87	(3.16) 0.47	(0.37) 0.36	(0.62) 0.62	(-56) -56	(179, 104	59 59	182	107
North Anna 2 W/RD	0.77	(1.38) No Axial Welds	(0.13)	(0.83) Forging Governs	(+56)	(52) 52	48 48	156	156
Salem 1 W/CE	2.26	(1.49)	(0.24) 0.24	(0.51) 0.51	(+56) Plate Governs	(87) 87	48 48	150	150
Oconee 3 B&W/B&W	4.78	(2.92) No Axial Welds	(0.24)	(0.63)	(0)	(112)	59	(171)	
Surry 2 W/B&W, RD	4.83	(7.54) 1.64	(0.19) 0.21	(0.56) 0.59	(0) 0	(108) 81	59 59	167	140
Calvert Cliffs 1 CE/CE	4.65	(6.84) 6.84	(0.30) 0.21(11)	(0.18) 0.05	(-56) -56	(135) 136	59 59	138	139 205(244)(7)
St. Lucie CE/CE	3.52	(2.22) 2.22	(0.31) 0.30	(0.11) 0.64	(-56) -56	(98) 132	59 59	101	135

Table P-1 (Continued)

Plant NSSS/Vessel Fabricators	EFY as of 12/31/81	Fluence n/cm ² x10 ¹⁸	Copper %	Nickel %	Mean Initial RT _{NDT}	Mean Δ RT _{NDT}	$2\sqrt{\sigma_0^2 + \sigma_\Delta^2}$ (5)	RT _{NDT} , °F, as of Dec 31, 1981(6) Circum.	Licensee's RT _{NDT} , °F Axial
Calvert Cliffs 2 CE/CE	3.63	(5.34)	(0.30) 0.30	(0.18) 0.18	(-56) -56	(127) 127	59 59	130	130
Trojan W/CBI	3.00	(2.07)	(0.16)	(0.62) Plate Governs	(+10)	(65) 65	48 48	123	123
Davis Besse 1 B&W/B&W	1.68	(1.11) No Axial Welds	(0.24)	(0.61)	(9)	(85)	59	144	
Haddam Neck W/CE	10.92	(14.30) 11.90	(0.22) 0.22	(0.10) 0.10	(-56) -56	(111) 106	59 59	114	109
Kewaunee W/CE	5.87	(7.86) No Axial Welds	(0.20)	(0.77)	(-56)	(129)	59	132	
Farley 1 W/CE	2.19	(3.70) 0.83	(0.24) 0.27	(0.60) 0.60	(-56) -56	(117) 89	59 59	120	92
Millstone 2	3.91	(2.19) No Data for Axial Welds	(0.37)	(0.06)	(-56)	(114)	59	117	
Prairie Island 2 W/SFAC	5.62	(7.53) No Axial Welds	(0.19)	(0.13)	(-56)	(81)	59	84	
Prairie Island 1 W/SFAC	5.90	(7.90) No Axial Welds	(0.14)	(0.17)	(-56)	(60)	59	63	


Footnotes

- (1) Arranged in descending order of the RT_{NDT} as of December 31, 1981 considering circumferential to be 30°F less severe than axial orientations.
- (2) Memorandum, M. Vagins to S. Hanauer, August 30, 1982.
- (3) Values shown in parentheses on top line are for circumferential welds, bottom line is for axial welds. When plate governs--both lines.
- (4) Determined by Reg. Guide 1.99, Rev. 1, Upper Limit Line, $\sigma_{\Delta} = 0$.
- (5) σ_0 (17°F) and σ_{Δ} (24°F) are the standard deviations of the initial RT_{NDT} and ΔRT_{NDT} , respectively. If plate or forging governed, actual initial RT_{NDT} was available and $\sigma_0 = 0$.
- (6) The sum of the Mean Initial RT_{NDT} , the mean ΔRT_{NDT} and $2\sqrt{\sigma_0^2 + \sigma_{\Delta}^2}$, as of Dec. 31, 1981.
- (7) Initial RT_{NDT} assumed by licensee to be -50°F and by CE to be -20°F. Values in parentheses are by CE.
- (8) Fluence is per letter from CP&L Co., Sept. 24, 1982.
- (9) Fluence reduced from 11.16 n/cm² per letter from FPL Aug. 31, 1982, on TP 4. TP 3 tentatively assumed to be the same as TP 4.
- (10) Fluence reduced to 0.73 x peak per letter from Omaha PPD, Sept. 1, 1982.
- (11) Cooper and Nickel values reduced per letter from Baltimore G&E, Oct. 28, 1982.

SIGNIFICANT PTS EVENT SEQUENCES


- o SECONDARY (STEAM SIDE) DEPRESSURIZATION
- o MAIN STEAM LINE BREAK
- o SMALL STEAM LINE BREAK (OR STUCK OPEN STEAM GENERATOR SAFETY/RELIEF VALVE)
- o SMALL BREAK LOSS-OF-COOLANT ACCIDENT
- o STEAM GENERATOR TUBE RUPTURE

FREQUENCY BASED ON PRA STUDIES FINAL FLUID TEMPERATURE




Pressure = 1000 psig

Conditional Failure Probability for a Single Longitudinal Beltline Weld




CONDITIONAL FAILURE PROBABILITY AS A FUNCTION OF $T_F - \bar{RT}_{NDT}$ - MEAN VALUE OF RT_{NDT}



CONDITIONAL FAILURE PROBABILITY AS A FUNCTION OF PRESSURE

LONGITUDINAL CRACK EXTENSION NO ARREST
NRC STAFF PRA RESULTS



SAFETY GOAL

- F VESSEL CRACK
- X CORE MELT IF VESSEL CRACKS
- Y SIGNIFICANT EARLY RELEASE IF CORE
 MELTS
- D RISK OF EARLY DEATHS (EFFECTS OF
 DISPERSION, WIND DIRECTION, ETC.)

CORE MELT XF \leq 10^{-5}

RISK XFYD \leq 5×10^{-8}

UNCERTAINTIES

- o OPERATING EXPERIENCE
- o OPERATION ACTIONS
- o FLAWS AND CRACKS
- o STRESSES
- o MATERIAL PROPERTIES
- o FRACTURE MECHANICS
- o PROBABILISTIC CALCULATIONS

CONCLUSIONS

- o IF $RT_{NDT} <$ SCREENING CRITERION, PTS RISK IS ACCEPTABLE
 - NO VESSEL WILL EXCEED CRITERION FOR FEW YEARS
 - THEREFORE NO NEED FOR IMMEDIATE SHUTDOWN OR ANNEALING
- o MOST PLANTS CAN STAY BELOW CRITERION FOR FULL LIFE BY PRACTICABLE FLUX REDUCTION PROGRAMS
 - SUCH PROGRAMS SHOULD BE IMPLEMENTED TO AVOID FORECLOSURE OF THIS OPTION
- o PLANTS PREDICTED TO EXCEED CRITERION SHOULD SUBMIT PLANT-SPECIFIC EVALUATIONS
- o STAFF SHOULD DEVELOP DETAILED GUIDANCE FOR PLANT-SPECIFIC EVALUATIONS
- o STAFF SHOULD CONSIDER CHANGES TO SOME REGULATIONS

RECOMMENDATIONS

- o PROPOSED RULEMAKING
 - ESTABLISH RT_{NDT} SCREENING CRITERION
 - PRESCRIBE METHOD OF CONSERVATIVE DETERMINATION OF RT_{NDT}
 - REQUIRE DETERMINATION OF PROJECTED RT_{NDT}
 - REQUIRE FEASIBLE AND NECESSARY FLUX REDUCTION PROGRAMS
 - REQUIRE PLANT-SPECIFIC EVALUATIONS THREE YEARS BEFORE SCREENING CRITERION REACHED
- o ORDER H. B. ROBINSON TO SUBMIT COMPREHENSIVE PLAN
- o FOR PLANTS THAT NEED NEAR-TERM FLUX REDUCTION OF FACTORS OF 2 TO 5 TO REACH END OF LIFE BELOW CRITERION--DETERMINE LICENSEES' PLANS AND ISSUE 50.54 (f) LETTERS AS APPROPRIATE
- o PREPARE GUIDANCE FOR PLANT-SPECIFIC PTS SAFETY ANALYSES
- o CONSIDER NEED FOR AMENDMENTS TO REGULATIONS
- o CONTINUE PROGRAM TO IMPROVE PROCEDURES AND OPERATOR TRAINING
- o CONTINUE ANALYTICAL AND EXPERIMENTAL PROGRAMS TO RESOLVE
USI A-49

BACKUP INFORMATION

31. OPERATIONS CONSIDERATIONS
32. AUDIT OF PROCEDURES AND TRAINING
33. β_T VS. TIME QUALITATIVE PLOT
34. EFFECTIVENESS OF FLUX REDUCTION
35. FRF TABLE FOR PWRS
36. FRF TABLE FOR PWRS
37. FRF TABLE FOR PWRS
38. ASSUMPTIONS USED BY STAFF FOR FUEL ASSEMBLY SUBSTITUTION
39. ISI
40. PLANT-SPECIFIC PTS EVALUATION
41. H. B. ROBINSON
42. H. B. ROBINSON 2 FLUX REDUCTION SCHEMES
43. H. B. ROBINSON 2 OPTIONS
44. OPTIONS FOR TURKEY POINT 3 AND 4, AND
FORT CALHOUN


OPERATIONS CONSIDERATIONS

- o OPERATOR ACTIONS AFFECT EVENT SEQUENCE
 - INITIATING EVENT
 - TAKE NEEDED ACTION
 - OMIT OR DELAY NEEDED ACTION
 - CREATIVE ACTION TO MITIGATE SEQUENCE
 - BIZARRE ACTION TO AGGRAVATE SEQUENCE

- o OPERATORS NEEDS
 - KNOWLEDGE AND UNDERSTANDING OF PLANT
 - PROCEDURES
 - INFORMATION FROM INSTRUMENTS

AUDIT OF PROCEDURES AND TRAINING

- o SYMPTOM ORIENTED PROCEDURES PROGRAM
 - HANDLE CONFLICTING REQUIREMENTS (SUCH AS UNDER vs. OVERCOOLING)
 - RESOLVE BEFORE OPERATOR IS IN MIDST OF COMPLICATED EVENT
 - INTEGRATED TMI - I.C.1 PROGRAM
- o WOG PTS REVIEW OF NEW GUIDELINES
 - 11 PROPOSED MODIFICATIONS
- o AUDIT AT 7 PLANTS RESULTED IN FOLLOWING RECOMMENDATIONS:
 - ACTIONS TO MITIGATE PTS SHOULD BE INCLUDED IN TECHNICAL GUIDELINES DEVELOPED FOR NUREG-0737, I.C.1, AND SHOULD BE INTEGRATED WITH UNDERCOOLING CONCERNS.
 - SUCH PROCEDURES SHOULD BE IMPLEMENTED BEFORE A PLANT IS WITHIN 3 YEARS OF THE SCREENING CRITERION.
 - THE PROCEDURES SHOULD
 - o INCLUDE ALLOWANCE FOR SYSTEM DELAY TIMES
 - o EVALUATE NEED FOR COOLDOWN RATE LIMITS FOR PERIODS < 1 HOUR
 - o PROVIDE METHODS FOR CONTROLLING COOLDOWN RATE
 - o PROVIDE GUIDANCE FOR COOLDOWN IF BRITTLE FRACTURE LIMITS ARE EXCEEDED
 - o SPECIFY A SUBCOOLING BAND
 - o PROVIDE INSTRUCTIONS FOR CONTROLLING PRESSURE FOR DEPRESSURIZATION TRANSIENTS.



EFFECTIVENESS OF FLUX REDUCTION

- o ABOUT 23 PLANTS DO NOT NEED
- o ABOUT 10 PLANTS CAN REACH END OF LIFE WITH FRF OF ABOUT 2
- o ABOUT 6 PLANTS NEED SUBSTANTIAL AND PROMPT REDUCTION
- o ONE PLANT CANNOT REACH END OF LIFE BY FEASIBLE FLUX REDUCTION

- 1 -
As of 12/31/81

Plant, Vendor/ PV Fabri- cator/ file	Controlling element Axial or Circumferential weld or plate	RT NOT Below Screening Criteria (*F)	Total Fluence E>1.MeV to Meet Screening Criteria $n/cm^2 \times 10^{19}$	EFPY	Fluence $(n/cm^2 \times 10^{19})$	Fluence per EFY $(n/cm^2 \times 10^{19})$	Additional Fluence To Reach Screening Criteria $n/cm^2 \times 10^{19}$	Remaining EFY in Plant Life (32 EFY)	To Reach Screening Criteria at 32 EFY		FRF<1	1<FRF<2	2<FRF<3	FRF>4
									Fluence per ² EFY ¹⁹ $(n/cm^2 \times 10^{19})$	Flux Reduction Factor				
Robinson-2	circ.	19	1.95	7.1	1.41	.199	.54	24.9	.0217	9.2 ⁽¹⁾				X
W/CE/665		12	1.95	7.1	1.64	.230	.31	24.9	.0124	18.5 ⁽¹⁾				
Fort Calhoun	axial	44	1.18	5.07	.51	.100	.67	26.93	.0249	4.0				X
CE/CE/486														
Turkey Pt.-4	circ.	41	1.85	5.67	.91	.160	.94	26.33	.0357	4.5 ⁽²⁾				X
W/B & W/666														
Turkey Pt.-3	circ.	41	1.85	5.67	.91	.160	.94	26.33	.0357	4.5 ⁽²⁾				X
W/B & W/666														
Maine Yankee	axial	54	1.18	5.90	.41	.069	.77	26.10	.0295	2.3			X	
CE/CE/825														
Calvert														
Cliffs-1	axial	55	8.22	4.65	.68	.146	7.54	27.35	.276	.53 ⁽³⁾	X			
CE/CE/850														
Indian Pt.-3	plate	58	1.04	2.98	.167	.056	.873	29.02	.0301	1.9		X		
W/CE/965														
Yankee Rowe	plate	59	4.48	14.56	1.14	.078	3.34	17.44	.1915	.4	X			
W/B & W/175														
Rancho Seco	axial	63	.77	3.54	.205	.058	.565	28.46	.0199	2.9			X	
B & W/B & W/913														
Three Mile														
Island-1	axial	66	.75	3.52	.187	.053	.563	28.48	.0198	2.7			X	
B & W/B & W/792														
Oconee-2	circ.	69	.99	4.71	.287	.061	.703	27.29	.0258	2.4			X	
B & W/B & W/860														
Zion-1	circ.	75	1.25	4.97	.313	.063	.937	27.03	.0347	1.8		X		
W/B & W/1040														
Point Beach-1	axial	72	3.48	8.07	.734	.091	2.750	23.93	.1149	.8	X			
W/B & W/497														
Oconee-1	axial	79	1.33	5.04	.232	.046	1.100	26.96	.0408	1.1		X		
B & W/B & W/860														
Indian Pt.2	axial	81	1.18	4.40	.22	.050	.960	27.60	.0348	1.4		X		
W/CE/873														

- 2 -
As of 12/31/81

Plant, Vendor/ PV Fabricator/ MWe	Controlling element Axial or Circumferential weld or plate	RT NOT Below Screening Criteria (°F)	Total Fluence E>1.MeV to Meet Screening Criteria ¹⁹ n/cm ² x10 ¹⁹	Fluence per EFY ¹⁹ (n/cm ² x10 ¹⁹)	Fluence per EFY ¹⁹ (n/cm ² x10 ¹⁹)	Additional Fluence To Reach Screening Criteria ¹⁹ n/cm ² x10 ¹⁹	Remaining EFY in Plant Life (32 EFY)	To Reach Screening Criteria at 32 EFY		FRF<1	1<FRF<2	2<FRF<3	FRF>4	
								Fluence per ² EFY ¹⁹ (n/cm ² x10 ¹⁹)	Flux Reduction Factor					
Genna W/B & W/490	circ.	87	4.95	8.18	.945	.116	4.000	23.82	.1679	.7	X			
Point Beach-2 W/B & W, CE/497	circ.	85	4.65	7.54	.953	.126	3.700	24.46	.1513	.8	X			
Arkansas, ANO-1 B & W/B & W/836	axial	82	1.23	4.42	.199	.045	1.031	27.58	.0374	1.2		X		
San Onofre-1 W/CE/436	axial	89	12.23	9.04	2.71	.300	9.520	22.96	.4146	.7	X			
Zion-2 W/B & W/1040	axial	93	.77	4.49	.09	.02	.680	27.51	.0247	.8	X			
Pallsades CE/CE/740	axial	93	2.33	4.12	.478	.116	1.852	27.88	.0664	1.7		X		
Crystal River-3 B & W/B & W/825	axial	93	1.18	2.48	.136	.055	1.044	29.52	.0354	1.6		X		
Surry-1 W/B & W/775	circ.	100	5.50	4.88	.761	.159	4.74	27.12	.1748	.9	X			
Cook-1 W/CE/1054	circ.	100	1.94	4.56	.287	.063	1.653	27.44	.060	1.05		X		
North Anna-1 W/RG/865	plate	138	11.57	2.41	.442	.183	11.13	29.59	.376	.486	X			
Beaver Valley W/CE/833	circ.	118	2.06	1.87	.316	.169	1.744	30.13	.058	2.91			X	
North Anna-2 W/RD/890	plate	148	10.1	.77	.138	.179	9.962	31.23	.319	.56	X			
Salem-1 W/CE/1090	axial	150	3.68	2.26	.148	.065	3.532	29.74	.119	.55	X			
Oconee-3 B&W/B&W/860	circ.	129	5.04	4.78	.292	.061	4.748	27.22	.174	.35	X			
Surry-2 W/B&W/775	circ.	133	14.8	4.83	.754	.156	14.05	27.17	.517	.30	X			

- 3 -
As of 12/31/81

Plant, Vendor/ PV Fabricator/ HWC	Controlling element Axial or Circumferential weld or plate	RT NOT Below Screening Criteria (°F)	Total Fluence E 1 MeV to Meet Screening Criteria $n/cm^2 \times 10^{19}$	Fluence			Additional Fluence To Reach Screening Criteria $n/cm^2 \times 10^{19}$	Remaining EPFY in Plant Life (32 EPFY)	To Reach Screening Criteria at 32 EPFY		FRF < 1	1 < FRF < 2	2 < FRF < 3	FRF > 4
				EPFY	$(n/cm^2 \times 10^{19})$	per EPFY $(n/cm^2 \times 10^{19})$			Fluence per EPFY $(n/cm^2 \times 10^{19})$	Flux Reduction Factor				
St. Lucie-1 CE/CE/777	axial	135	3.02	3.52	.222	.063	2.790	28.48	.090	.64	X			
Calvert Cliffs-2 CE/CE/B50	axial	140	8.48	3.63	.534	.147	7.946	28.37	.280	.53	X			
Trojan W/CBI/1130	plate	167	16.2	3.00	.207	.069	16.00	29.00	.552	.13	X			
Davis Besse-1 B&W/B&W/906	circ.	156	5.25	1.68	.111	.066	5.14	30.32	.170	.39	X			
Haddam Neck W/CE/582	axial	161	36.48	10.92	1.190	.109	35.29	21.08	1.674	.07	X			
Kewaunee W/CE/535	circ.	168	17.14	5.87	.786	.134	16.35	26.13	.626	.21	X			
Farley-1 W/CE/B29	circ.	180	11.61	2.19	.370	.169	11.24	29.81	.377	.45	X			
Millstone-2 CE/CE/B70	circ.	183	7.62	3.91	.219	.056	7.40	28.09	.263	.21	X			
Prairie Island-1 W/SFAC/520	axial	216	90.7	5.62	.753	.134	89.95	26.38	3.41	.04	X			
Prairie Island-2 W/SFAC/520	axial	237	292.1	5.90	.790	.139	291.3	26.10	11.16	.01	X			
Summary											23	8	5	4

- (1) The lower line in H. B. Robinson lists the staff's calculations. The differences have not been resolved as of 11/10/82. Note that the current cycle of the Robinson plant (after 12/31/81) is a low leakage cycle, therefore, the FRF would currently be lower by a factor of 2, i.e., 4.6 and 9.2 for licensee and HRC calculations.
- (2) The staff has been notified by Florida Power and Light (Ref. 5) that the fluence at 5.67 EPFY was $.91 \times 10^{19} n/cm^2$ and the projected fluence for the next 3 EPFY will be $1.39 \times 10^{19} n/cm^2$ i.e., the fluence accumulation rate will remain the same. These values have not been reviewed by the staff.
- (3) The value of the fluence required to reach the screening criteria is based on .21% copper content in the weld seam (Ref. 6).

ASSUMPTIONS USED BY STAFF FOR FUEL ASSEMBLY SUBSTITUTION

1. CRITERION FOR FLUX REDUCTION - PEAK FLUENCE TO CRITICAL WELD
2. CORE REDESIGN ALTERNATIVES
 - RELAXATION OF APPENDIX K
 - LOWERING OF MDNBR
 - POWER DERATING^G
3. LINEAR HEAT GENERATION RATE INCREASED BY 20% IF APPENDIX K RELAXED
4. LOWERING DNBR BY 10% ALLOWS RAISING AVERAGE HEAT GENERATION RATE BY 20%
5. POWER REPLACEMENT COSTS = \$0.3M/DAY
6. CORE REDESIGN COST = \$20M

ISI

- o WELDS VOLUMETRICALLY EXAMINED AT HBR, OCONEE 1 AND 2, AND
TURKEY POINT 3 AND 4

- o INSPECTION TECHNIQUES MET REG. GUIDE 1.50 AND SECTION XI
REQUIREMENTS

- o INDICATIONS THAT WERE FOUND WERE MANUFACTURING INDUCED AND
WERE ACCEPTABLE WITHIN REG. REQUIREMENTS


- o NO SERVICE INDUCED INDICATIONS

PLANT-SPECIFIC PTS EVALUATION

- o EVALUATION OF OVERCOOLING EVENT SEQUENCES
- o VESSEL MATERIALS PROPERTIES
- o DETERMINISTIC FRACTURE MECHANICS EVALUATIONS
- o FLUX REDUCTION PROGRAM
- o INSERVICE INSPECTION AND NONDESTRUCTIVE EVALUATION PROGRAM
- o PLANT MODIFICATIONS
 - INSTRUMENTATION AND CONTROLS
 - AUTOMATIC DEPRESSURIZATION LOGIC
 - INCREASED EMERGENCY CORE COOLING WATER AND EMERGENCY FEEDWATER TEMPERATURES
- o OPERATING PROCEDURES AND TRAINING PROGRAM IMPROVEMENTS
- o IN-SITU ANNEALING
- o BASIS FOR CONTINUED OPERATION

H. B. ROBINSON

- o REDUCED FLUX BY FACTOR OF 2 IN EARLY 1982
- o PROCEDURES MODIFIED AND TRAINING CONDUCTED IN RESPONSE TO
STAFF AUDIT
- o STAFF ESTIMATES CIRCUMFERENTIAL WELD WILL REACH SCREENING
CRITERION IN 1988
- o LICENSEE CONSIDERING HEATING ECCS WATER
- o EXTENDED OUTAGE FOR STEAM GENERATOR REPLACEMENT PLANNED FOR
1984



H. B. ROBINSON 2 FLUX REDUCTION SCHEMES

H. B. ROBINSON 2 OPTIONS

FLUX REDUCTION FACTOR 9.2

REPLACE OUTER ROW FUEL WITH DUMMIES

INCREASE PEAK POWER 30%

15% - FUEL MANAGEMENT

15% - ALTERNATIVES

A) APPENDIX K

B) MDNBR

C) DERATE

}
}

\$20M ENGINEERING

DOWNTIME (REFUEL)

\$20M + \$10M/YR

OPTIONS FOR TURKEY POINT 3 AND 4,
AND FORT CALHOUN

FLUX REDUCTION FACTOR (FRF) 4 - 4.5

"LOW LEAKAGE" ~ 2

4 - 12 ELEMENTS REMOVED ~ 2

ENGINEERING \$20M

FUEL NEGLIGIBLE

NO DERATING

TRANSMITTAL TO: Document Control Desk,
016 Phillips

ADVANCED COPY TO: The Public Document Room

DATE: 12/2/82 cc: OPS File

From: SECY OPS Branch

C&R (Natalie)

Attached are copies of a Commission meeting transcript/s/ and related meeting document/s/. They are being forwarded for entry on the Daily Accession List and placement in the Public Document Room. No other distribution is requested or required. Existing DCS identification numbers are listed on the individual documents wherever known.

Meeting Title: Briefing on Pressurized Thermal Shock

MEETING DATE: 12/1/82 Open Closed

ITEM DESCRIPTION:	Copies Advanced To PDR:	*	DCS COPIES: (1 of each Checked)		
			Original Document	May be Dup*	Duplicate Copy*
1. <u>Transcript</u> <u>(with newspaper</u> <u>attached)</u>	<u>1</u>	*	<u>1</u>		
2. <u>Secy-82-465</u> <u>(with serrated pages</u> <u>for Enc A and Enc</u> <u>A-B)</u>	<u>2</u>	*		<u>1</u>	
3. _____	_____	*	_____	_____	_____
4. _____	_____	*	_____	_____	_____
5. _____	_____	*	_____	_____	_____

(PDR is advanced one of each document, two of each SECY paper.)

*Verify if in DCS, and change to "PDR available."