

RECEIVED
NRC

Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000
Docket No. 50-397 1982 NOV 17 AM 10:50

REGION VICE

November 12, 1982
G02-82-905

Mr. R. H. Engelken
U.S. Nuclear Regulatory Commission
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

Subject: NUCLEAR PROJECT NO. 2
RESPONSE TO IE BULLETIN NO. 82-01,
REVISION 1, SUPPLEMENT 1

A review of all ITT Grinnell supplied materials has been performed to determine if IE Bulletin 82-01, Revision 1, Supplement 1 is applicable to materials and work at WNP-2.

The mechanical contractor (Contract 215) utilized material supplied by ITT Grinnell which was shop fabricated subassemblies with pipe wall thickness greater than 1/2 inch. Wall thickness greater than 1/2" is outside the scope of the subject IE Bulletin. The other applicable site contractors (Contract 213, Contract 216, Contract 220, and Contract 240) did not procure fabrications from ITT Grinnell; although they did procure fittings and/or raw materials which do not require radiographs.

Based on the above findings, the WNP-2 Project has determined that IE Bulletin 82-01, Revision 1, Supplement 1, is not applicable to the WNP-2 Project.

If you have any further questions regarding this subject, please contact Roger Johnson at (509) 377-2501, extension 2712.

R. G. Matlock
R. G. Matlock
Program Director, WNP-2

LCF/kd

- cc: W.S. Chin, BPA - Site
- A. Forrest, Burns and Roe - HAPO
- N.D. Lewis, NRC
- T.A. Mangelsdorf
- J. Plunkett, NUS Corp.
- R.E. Snaith, Burns and Roe - NY
- Document Control, NRC
- WNP-2 Files (917B)

IE11