

Appendix

NOTICE OF VIOLATION

Dairyland Power Cooperative

Docket No. 50-409

As a result of the inspection conducted on October 4-15, 1982, and in accordance with the NRC Enforcement Policy, 47 FR 9987 (March 9, 1982), the following violation was identified:

Technical Specifications Section 6.8.1.a requires implementation of written procedures recommended in Appendix A of Regulatory Guide 1.33, Revision 2, February 1978.

Appendix A of Regulatory Guide 1.33 (Revision 2, February 1978) recommends procedures for sampling and monitoring and discharging from the Liquid Radioactive Waste System and procedures to prescribe the nature and frequency of radiochemical sampling and analyses.

Licensee procedure HSP-07.6, "Schedule of Water Samples and Analysis," (Issue 3, July 14, 1980) requires monthly radioactive strontium analysis of a composite of all waste water.

Contrary to the above requirement, strontium analyses of liquid waste composites were not performed between January and July 1982.

This is a Severity Level V violation (Supplement IV).

Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice a written statement or explanation in reply, including for each item of noncompliance: (1) corrective action taken and the results achieved; (2) corrective action to be taken to avoid further noncompliance; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

\_\_\_\_\_  
Dated

\_\_\_\_\_  
C. J. Paperiello, Chief  
Emergency Preparedness and  
Program Support Branch