NAL FURM JUU (7.77) LICENSEE EVENT REPORT CONTROL BLOCK: PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION) N J S G S 2 2 0 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 26 26 LICENSE TYPE 30 57 0 1 CON'T LO 0 5 0 0 0 3 1 10 1 0 2 8 8 2 8 1 1 1 7 8 2 9 0 1 SOURCE EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) On two occasions, on October 28 and November 6, 1982, during routine operation, the 0 2 | Control Room Operator observed that the P-250 Computer was operating erratically. Due 0 3 to the malfunctions of the computer in each case, the Reactor Coolant System (RCS) 0 4 subcooling margin monitor was declared inoperable and Action Statement 3.3.3.7a was 0 5 entered. The wide range RCS temperature and pressure indication was operable allowing 0 6 calculation of the margin. The event constituted operation in a degraded mode in 0 7 accordance with Technical Specification 6.9.1.9.b. (82 - 116)0 8 SYSTEM COMP CODE CODE COMPONENT CODE SUBCODE T | R | U |(14 E 0 9 (13)OCCURRENCE CODE REVISION ORT NO. 3 1 HOURS (22 0 0 0 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) The computer malfunctions were due to the 4VDC power supply drifting low. The power 1 ] supply was properly adjusted; no further problems with the computer have been noted. The subcooling monitor was declared operable and the action statement was terminated. 1 2 1 3 1 4 METHOD OF OTHER STATUS (30) POWER DISCOVERY DESCRIPTION (32) Operator Observation NA CONTENT AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36) 1 6 Z (33) Z (34) NA PERSONNEL EXPOSURES DESCRIPTION (39) 0(37) 1 7 Z (38) PERSONNEL INJURIES DESCRIPTION 1 8 0(40) 0 12 OSS OF OR DAMAGE TO FACILITY (43) DESCRIPTION 9 (42) NA 212060174 821 10 PUBLICITY ADOCK 0500031 NRC USE ONLY DESCRIPTION (45) PHONE 609/935-6000 Ext R. Frahm 3078 NAME OF PREPARER.