

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | NYREG | 12000-000000-0000 | 3411111 | 4 | 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
01 | L | 6050000244 | 7102682 | 8112482 | 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
02 | During performance of PT-3, Containment Spray System periodic test, check valve 862B
03 | failed to close promptly. The 1B Containment Spray Pump was declared inoperable.
04 | This placed the plant in a limiting condition for operation based on Tech. Spec.
05 | 3.3.2.2.b
06 |
07 |
08 |

09 | S B | E | B | V A L V E X | C | A |
9 10 11 12 13 18 19 20
17 | LER/RO REPORT NUMBER | 82 |
21 22
23 |
24 | 026 |
26 27
28 | 03 |
29 30
31 | L |
32 | 0 |
33 | B | 18 | G | 19 | Z | 20 | Z | 21 | 0000 | 22 | N | 23 | N | 24 | A | 25 | A 200 | 26 |
34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
10 | Maintenance was performed on this valve and a retest per PT-3 indicated acceptable
11 | performance. Procedure PT-3 is undergoing a review to determine if a change in the
12 | test criteria is required. The valve testing frequency has been reduced to 2 weeks
13 | from 1 month.
14 |

15 | E | 28 | 100 | 29 | NA | B | 31 | Periodic Test | 32 |
7 8 9 10 12 13 44 45 46 80
16 | Z | 33 | Z | 34 | NA | NA | 36 |
7 8 9 10 11 44 45 80
17 | 000 | 37 | Z | 38 | NA | 39 |
7 8 9 11 12 13 80
18 | 000 | 40 | NA | 41 |
7 8 9 11 12 80
19 | Z | 42 | NA | 43 |
7 8 9 10 80

20 | Z | 44 | NA | 45 |
7 8 9 10 80
8212060175 821124
PDR ADOCK 05000244
S PDR
NRC USE ONLY
78 79 80 81