

*Official*

JAN 18 1991

Docket No. 50-325 and 50-324  
License No. DPR-71 and DPR-62

Carolina Power and Light Company  
ATTN: Mr. Lynn W. Eury  
Executive Vice President  
Power Supply Groups  
P. O. Box 1551  
Raleigh, NC 27602

Gentlemen:

SUBJECT: NOTICE OF VIOLATION  
(NRC INSPECTION REPORT NOS. 50-325/90-52 AND 50-324/90-52)

This refers to the inspection conducted by Richard L. Prevatte of this office on December 1 - 31, 1990. The inspection included a review of activities authorized for your Brunswick facility. At the conclusion of the inspection, the findings were discussed with those members of your staff identified in the enclosed inspection report.

Areas examined during the inspection are identified in the report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observation of activities in progress.

Based on the results of this inspection, certain activities appeared to be in violation of NRC requirements, as specified in the enclosed Notice of Violation (Notice). We are concerned about the violation for the failure to follow procedure because, even though the related event did not have a high degree of safety significance, it may indicate the development of a complacent attitude towards the use of procedures for repetitive tasks. In addition, the event also revealed that control room operators are not fully investigating the reason for all control room annunciator alarms.

In accordance with 10 CFR 2.790, of the NRC's "Rules of Practice," a copy of this letter and its enclosures will be placed in the NRC Public Document Room.

The responses directed by this letter and its enclosures are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, Pub. L. No. 96-511.

910211005B 91011B  
PDR ADDCK 05000324  
G PDR

*TEO*

JAN 18 1991

Carolina Power and Light Company

2

Should you have any questions concerning this letter, please contact us.

Sincerely,

ORIGINAL SIGNED BY  
DAVID M. VERRELLI

David M. Verrelli, Chief  
Reactor Projects Branch 1  
Division of Reactor Projects

Enclosures:

1. Notice of Violation
2. NRC Inspection Report

cc w/encls:

R. B. Starkey, Jr.  
Vice President  
Brunswick Nuclear Project  
P. O. Box 10429  
Southport, NC 28461

J. L. Harness  
Plant General Manager  
Brunswick Steam Electric Plant  
P. O. Box 10429  
Southport NC 28461

R. E. Jones, General Counsel  
Carolina Power & Light Company  
P. O. Box 1551  
Raleigh, NC 27602

Ms. Frankie Rabon  
Board of Commissioners  
P. O. Box 249  
Bolivia, NC 28422

Chrys Bagget  
State Clearinghouse  
Budget and Management  
116 West Jones Street  
Raleigh, NC 27603

(cc w/encls continued - See page 3)

JAN 18 1991

(cc w/encls cont'd)  
Dayne H. Brown, Director  
Division of Radiation Protection  
N. C. Department of Environment,  
Health & Natural Resources  
P. O. Box 27687  
Raleigh, NC 27611-7687

H. A. Cole  
Special Deputy Attorney General  
State of North Carolina  
P. O. Box 629  
Raleigh, NC 27602

Robert P. Gruber  
Executive Director  
Public Staff - NCUC  
P. O. Box 29520  
Raleigh, NC 27626-0520

✓ doc w/encls:  
Document Control Desk  
H. Christensen, RII  
T. Le, NRR

NRC Resident Inspector  
U.S. Nuclear Regulatory Commission  
Star Rte. 1, Box 208  
Southport, NC 28461

RII:DRP  
*[Signature]*  
RCarroll  
01/19/91

RII:DRP  
*[Signature]*  
HChristensen  
01/17/91