

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation and is basically all that is known by IE staff on this date. [Handwritten signature]

Facility: Sacramento Municipal Utility District
 Rancho Seco Nuclear Power Plant
 Sacramento County, California
 Docket No. 50-312

Licensee Emergency Classification:
 Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 Not Applicable

Subject: PERSONAL INJURY

A Babcock and Wilcox employee fell about twenty feet on 11/27/82 while setting up testing equipment on the "A" steam generator. At the time of the event, the plant was in cold shutdown for inspection and repair of a steam generator tube leak (refer to PNO-V-82-47, dated 11/22/82). The worker was slightly contaminated (200 dpm compared to the licensee's unconditional release limit of 100 dpm), and was transported to nearby medical facilities in accordance with the licensee's emergency plan. Medical examination showed the individual to have sustained a broken arm and bruises. He remains hospitalized while being evaluated for possible internal injuries.

Media interest is not expected. Neither the licensee nor the NRC plans to issue a news release. Region V (San Francisco) received notification of this occurrence from the HQ Duty Officer at 10:00 p.m. on 11/28/82. This information is current as of 8:00 a.m. on 11/29/82.

CONTACT: P. Johnson, 463-3745

T. Young, Jr., 463-3853

8212060347 821129
 PDR I&E
 PNO-V-82-049 PDR

DISTRIBUTION:

H St. 10:28 3m ✓	MNBB 10:17	Phillips 10:15	E/W 10:16	Willste 10:46	Mail:
Chairman Palladino	EDO (H) ✓	NRR (H) ✓	IE (H) ✓	NMSS (R) ✓	ADM:DMB
Comm. Gilinsky	PA		OIA ✓	RES (SM)	DOT: Trans Only
Comm. Ahearne	MPA		AEOD		
Comm. Roberts	ELD				
SECY		Air Rights	INPO 10:45 (R)		
ACRS		SP 10:20 3m ✓	NSAC 10:28 (R)		
CA					
PDR					
Comm. ASSELSTINE	Regions: I ✓ II ✓ III ✓ IV ✓				
	Licensee: 10:45 (SM) ✓				
	(Reactor Licensees)				

IE-34