File No P10.2.1
Incident No: PAL-82-07-AD75

NPDES NOTIFICATION
Apparent Difference From Daily Average/Maximum Limitation
August 16, 1982

Plant: Palisades

Permit No: MI 0001457

Outfall Description: Turbine Sump Oil Separator Waste (OOG)

Outfall No: 800218

Parameter: Oil and Grease - Freon

Parameter No: 00556

1. Date of Incident: 7/31/82

2. Identification of specific effluent limitation or monitoring requirement affected:

   Oil and grease monthly average concentration limit of 15 mg/l.

3. Description of Incident:

   During the month of July 1982, the daily maximum limit of 20 mg/l oil and grease was exceeded six days which resulted in the monthly average limit of 15 mg/l being exceeded (average value equals 18.2 mg/l).

4. Apparent Cause:

   Same as identified for individual occurrences PAL-82-07-AD72, AD73 and AD74 submitted on July 22, August 2 and August 6, 1982, respectively.

5. If not immediately corrected, the anticipated time the condition is expected to continue:

   NA

6. Corrective Action - The following corrective action was taken or will be taken to reduce, eliminate and prevent recurrence:

   Same as identified for individual occurrences PAL-82-07-AD72, AD73 and AD74 submitted on July 22, August 2 and August 6, 1982, respectively.

7. Additional Comments:

   NA

8. Signed: Ronald L Fobes RLF

8212060396 821124
PDR ADOCK 05000255
S PDR

mi0882-0343a-42