



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

POWER AUTHORITY OF THE STATE OF NEW YORK

DOCKET NO. 50-333

JAMES A. FITZPATRICK NUCLEAR POWER PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 204
License No. DPR-59


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Power Authority of the State of New York (the licensee) dated September 28, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-59 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 204, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Capra, Director
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 8, 1994

ATTACHMENT TO LICENSE AMENDMENT NO. 204

FACILITY OPERATING LICENSE NO. DPR-59

DOCKET NO. 50-333

Revise Appendix A as follows:

Remove Pages

113
122
132

Insert Pages

113
122
132

JAFNPP

3.5 (cont'd)

4.5 (cont'd)

- | | | |
|----|---|---|
| b. | Flow Rate Test -

Core spray pumps shall deliver at least 4,265 gpm against a system head corresponding to a reactor vessel pressure greater than or equal to 113 psi above primary containment pressure. | Once/3 Months |
| c. | Pump Operability | Once/month |
| d. | Motor Operated Valve | Once/month |
| e. | Core Spray Header Δp Instrumentation
Check
Calibrate
Test | Once/day
Once/3 months
Once/3 months |
| f. | Logic System Functional Test | Once/each operating cycle |
| g. | Testable Check Valves | Tested for operability any time the reactor is in the cold condition exceeding 48 hours, if operability tests have not been performed during the preceding 31 days. |

JAFNPP

3.5 (cont'd)

F. ECCS-Cold Condition

1. A minimum of two low pressure Emergency Core Cooling subsystems shall be operable whenever irradiated fuel is in the reactor, the reactor is in the cold condition, and work is being performed with the potential for draining the reactor vessel.
2. A minimum of one low pressure Emergency Core Cooling subsystem shall be operable whenever irradiated fuel is in the reactor, the reactor is in the cold condition, and no work is being performed with the potential for draining the reactor vessel.
3. Emergency Core Cooling subsystems are not required to be operable provided that the reactor vessel head is removed, the cavity is flooded, the spent fuel pool gates are removed, and the water level above the fuel is in accordance with Specification 3.10.C.
4. With the requirements of 3.5.F.1, 3.5.F.2, or 3.5.F.3 not satisfied, suspend core alterations and all operations with the potential for draining the reactor vessel. Restore at least one system to operable status within 4 hours or establish Secondary Containment Integrity within the next 8 hours.

4.5 (cont'd)

F. ECCS-Cold Condition

Surveillance of the low pressure ECCS systems required by 3.5.F.1 and 3.5.F.2 shall be as follows:

1. Perform a flowrate test at least once every 3 months on the required Core Spray pump(s) and/or the RHR pump(s). Each Core Spray pump shall deliver at least 4,265 gpm against a system head corresponding to a reactor vessel pressure greater than or equal to 113 psi above primary containment pressure. Each RHR pump shall deliver at least 8910 gpm against a system head corresponding to a reactor vessel to primary containment differential pressure of ≥ 20 psid.
2. Perform a monthly operability test on the required Core Spray and/or LPCI motor operated valves.
3. Once each shift verify the suppression pool water level is greater than or equal to 10.33 ft. whenever the low pressure ECCS subsystems are aligned to the suppression pool.
4. Once each shift verify a minimum of 324 inches of water is available in the Condensate Storage Tanks (CST) whenever the Core Spray System(s) is aligned to the tanks.

4.5 BASES

The testing interval for the Core and Containment Cooling Systems is based on a quantitative reliability analysis, industry practice, judgement, and practicality. The Emergency Core Cooling Systems have not been designed to be fully testable during operation. For example, the core spray final admission valves do not open until reactor pressure has fallen to 450 psig; thus, during operation even if high drywell pressure were simulated, the final valves would not open. In the case of the HPCI, automatic initiation during power operation would result in pumping cold water into the reactor vessel which is not desirable.

The systems will be automatically actuated during a refueling outage. In the case of the Core Spray System, condensate storage tank water will be pumped to the vessel to verify the operability of the core spray header. To increase the availability of the individual components of the Core and Containment Cooling Systems the components which make up the system i.e., instrumentation, pumps, valve operators, etc., are tested more frequently. The instrumentation is functionally tested each month. Likewise, the pumps and motor-operated valves are also tested each month to assure their operability. The combination automatic actuation test and monthly tests of the pumps and valve operators is deemed to be adequate testing of these systems.

With components or subsystems out-of-service, overall core and containment cooling reliability is maintained by verifying the operability of the remaining cooling equipment. Consistent with the definition of operable in Section 4.0.C, demonstrate means conduct a test to show; verify means that the associated surveillance activities have been satisfactorily performed within the specified time interval.

The RCIC flow rate is described in the UFSAR. The flow rates to be delivered to the reactor core for HPCI, the LPCI mode of RHR, and CS are based on the SAFER/GESTR LOCA analysis. The flow rates for the LPCI mode of RHR and CS are modified by a 10 percent reduction from the SAFER/GESTR LOCA analysis. The reductions are based on a sensitivity analysis (General Electric MDE-83-0786) performed for the parameters used in the SAFER/GESTR analysis.

The CS surveillance requirement includes an allowance for system leakage in addition to the flow rate required to be delivered to the reactor core. The leak rate from the core spray piping inside the reactor but outside the core shroud is assumed in the UFSAR and includes a known loss of less than 20 gpm from the 1/4 inch diameter vent hole in the core spray T-box connection in each of the loops, and in the B loop, a potential additional loss of less than 40 gpm from a clamshell repair whose structural weld covers only 5/6 of the circumference of the pipe. Both of these identified sources of leakage occur in the space between the reactor vessel wall and the core shroud. Therefore flow lost through these leak sources does not contribute to core cooling.

The surveillance requirements to ensure that the discharge piping of the core spray, LPCI mode of the RHR, HPCI, and RCIC Systems are filled provides for a visual observation that water flows from a high point vent. This ensures that