

THLY REPORT FORM

TOLEDO EDISON COMPANY
 DAVIS-BESSE NUCLEAR
 POWER STATION - UNIT NO. 1
 300 MADISON AV. MSTOP 2101
 TOLEDO 43652 OTTAWA

21800011001

JAN 1994

1 1

12/17/93

OH0003786

001 DISCHARGE TO LAKE ERIE

FORM

TOLEDO EDISON

J. Sturdevant

	1 999 WATER TEMP. °F	3 1 PH S.O.	1 999 CONDUIT FLOW MGD	3 1 CHLOR FREE A MG/L
	00011	00400	50050	50064
1	47.2	8.6	28.2	AA
2	44.5	8.6	28.4	AA
3	53.0	8.7	17.3	AA
4	45.6	8.6	29.2	AA
5	43.2	8.5	28.5	AA
6	44.2	8.5	28.7	AA
7	43.4	8.7	28.7	AA
8	41.9	8.6	28.7	AA
9	42.4	8.7	28.2	AA
0	44.5	8.4	28.2	AA
1	45.1	8.4	32.8	AA
2	45.2	8.4	28.7	AA
3	44.9	8.4	27.9	AA
4	40.6	8.2	32.0	AA
5	40.3	8.5	27.5	AA
6	39.7	8.4	27.8	AA
7	42.3	8.4	27.5	AA
8	37.9	8.2	24.9	AA
9	37.9	8.1	26.2	AA
0	40.0	8.2	26.0	AA
1	41.8	8.2	26.5	AA
2	42.7	8.4	25.5	AA
3	44.9	8.5	25.6	AA
4	44.4	8.6	25.9	AA
5	44.1	8.6	26.1	AA
6	41.6	8.4	26.2	AA
7	43.7	8.5	25.9	AA
8	44.7	8.8	28.2	AA
9	41.8	8.6	27.2	AA
0	40.5	8.6	25.9	AA
1	40.6	8.5	25.9	AA
	1334.6	---	844.3	0.0
	43.0	---	27.0	0.0
	53.0	8.8	32.8	0.0
	37.9	8.1	17.3	0.0

AA: The free available chlorine detection limit is 0.05 mg/L using the direct amperometric titration method.

REPORTER

9402250190 940209
 PDR ADOCK 05000346
 R PDR

02/08/94

W. C. ...

Plant Manager

WLY REPORT FORM

TOLEDO EDISON COMPANY
DAVIS-BESSE NUCLEAR
POWER STATION - UNIT NO. 1
300 MADISON AV. MSTOP 2101
TOLEDO 43652 OTTAWA

21800011002

JAN 1994

1 1

12/17/93

OH0003786

002 OUTFALL TOUSSAINT RIVER

FORM

TOLEDO EDISON

J. Sturdavant

	3	3	3	1
	PH	RESIDU	O&G	CONDUI
	S.U.	T. WFL	TOTAL	FLOW
		MG/L	MG/L	MGD
00400		00530	00550	50050
1	AH	AH	AH	AH
2				AH
3				AH
4				AH
5				AH
6				AH
7				AH
8				AH
9				AH
0	AH	AH	AH	AH
1				AH
2				AH
3				AH
4				AH
5				AH
6				AH
7	AH	AH	AH	AH
8				AH
9				AH
0				AH
1				AH
2				AH
3				AH
4	AH	AH	AH	AH
5				AH
6				AH
7				AH
8				AH
9				AH
0				AH
1				AH
	---	0.0	0.0	0.000
	---	0.0	0.0	0.000
	0.0	0.0	0.0	0.000
	0.0	0.0	0.0	0.000

AH: Outfall 002 frozen throughout January 1994.

REPORTER

02/09/94

Handwritten signature

Plant Manager

TOLEDO EDISON COMPANY
DAVIS-BESSE NUCLEAR
POWER STATION - UNIT NO. 1
300 MADISON AV. WSTOP 2101
TOLEDO 43652 OTTAWA

21B00011601

JAN 1994

1 1

12/17/93

OH0003786

601 DISCHARGE STP

FORM

TOLEDO EDISON

J. Sturdavant

	3 1	3 1	3 1	1 999	3 1	3 1
	COLOR SEVER UNITS	ODOR SEVER UNITS	TURBID SEVER UNITS	CONDOI FLOW MGD	BOD 5 DAY MG/L	RESIDU T. WFL MG/L
	00083	01330	01350	50050	00310	00530
1	AN	AN	AN	0.007		
2	AN	AN	AN	0.007		
3	0	0	0	0.007		
4	0	0	0	0.007	AA	
5	0	0	0	0.007		3.2
6	0	0	0	0.007		
7	0	0	0	0.007		
8	AN	AN	AN	0.007		
9	AN	AN	AN	0.007		
0	AN	AN	AN	AN		
1	0	0	0	0.007	AA	
2	0	0	0	0.007		3.5
3	0	0	0	0.007		
4	0	0	0	0.007		
5	AN	AN	AN	0.007		
6	AN	AN	AN	0.007		
7	0	0	0	0.007		1.9
8	0	0	0	0.007	AA	
9	0	0	0	0.007		
0	0	0	0	0.007		
1	0	0	0	0.007		
2	AN	AN	AN	0.007		
3	AN	AN	AN	0.007		
4	0	0	0	0.007		4.6
5	0	0	0	0.007	AA	
6	0	0	0	0.007		
7	0	0	1	0.007		
8	0	0	0	0.007		
9	AN	AN	AN	0.007		
0	AN	AN	AN	0.007		
1	1	1	1	0.007		
	1	1	2	0.210	0	13.2
	0	0	0	0.007	0	3.3
	1	1	1	0.007	0	4.6
	0	0	0	0.007	0	1.9

AA: The BOD detection limit is 4.0 mg/L using the electrode method.
AB: Outfall 601 was frozen January 10, 1994.

REPORTER

02/08/94

- 1006 - 1

Plant Manager

DAILY REPORT FORM

TOLEDO EDISON COMPANY
DAVIS-BESSE NUCLEAR
POWER STATION - UNIT NO. 1
300 MADISON AV. N5TOP 2101
TOLEDO 43652 OTTAWA

21B00011602

JAN 1994

1 4

12/17/93

OH0003786

602 LOW VOLUME WW SETTLING BASIN OVERFLOW

FORM

TOLEDO EDISON

J. Sturdavant

	1	3	3
	999	1	1
	CONDU	RESIDU	O&G
	FLOW	Y. NPL	TOTAL
	MGD	MG/L	MG/L
	50050	00530	00550
1	0.257		
2	0.257		
3	0.257		
4	0.257		
5	0.257	3.8	
6	0.257		2.1
7	0.257		
8	0.257		
9	0.257		
0	0.257		
1	0.257		
2	0.257		
3	0.257		
4	0.257		
5	0.257		
6	0.257		
7	0.257		
8	0.257		
9	0.257	1.9	
0	AH		
1	AH		
2	AH		
3	AH		
4	AH		
5	0.257		
6	0.257		
7	0.257		AA
8	0.257		
9	0.257		
0	0.257		
1	0.257		
	6.682	5.7	2.1
	0.257	2.9	2.1
	0.257	3.8	2.1
	0.257	1.9	0.0

AH: Outfall 602 frozen January 20 through January 24 1994.

AA: The Oil and Grease detection limit is 1.0 mg/L using the Partition-Gravimetric method.

REPORTER

02/08/94

U.S.O. 1

Plant Manager

WEEKLY REPORT FORM

TOLEDO EDISON COMPANY
DAVIS-BESSE NUCLEAR
POWER STATION - UNIT NO. 1
300 MADISON AV. WSTOP 2101
TOLEDO 43652 OTTAWA

21800011801

JAN 1994

1 1

12/17/93

080003786

801 INTAKE PRIOR COOLING OPERATION

FORM

TOLEDO EDISON

J. Sturdavant

1
999
WATER
TEMP.
Y

00011

- 1 36.3
- 2 35.6
- 3 35.4
- 4 36.5
- 5 36.1
- 6 35.6
- 7 35.9
- 8 36.0
- 9 35.4
- 0 35.9
- 1 36.1
- 2 36.4
- 3 36.7
- 4 36.1
- 5 36.0
- 6 35.3
- 7 35.8
- 8 35.3
- 9 35.5
- 0 35.8
- 1 36.4
- 2 36.4
- 3 36.4
- 4 36.6
- 5 36.6
- 6 35.5
- 7 36.5
- 8 37.7
- 9 36.8
- 0 36.3
- 1 36.9

1119.8
36.1
37.7
35.3

REPORTER

03/08/94

- 144.6 /

03/08/94