

CNS STATION BLACKOUT  
CONTROL ROOM HEATUP  
ANALYSIS

9102110114 910131  
PDR ADOCK 05000298  
P PDR

204

ONE PARTIAL BACKSET  
CONTINUED FROM PREVIOUS  
PAGE

204  
FBI - ALBUQUERQUE  
FBI

SHEET 1 OF 68

JOB NO. NP-110

DATE 11/30/89

PROJECT CNS STATION BLACKOUT (SBO)

SUBJECT CONTROL ROOM HEATUP

CLIENT NPPD

ORIGINATOR E.E. Hcomb

REVIEWER Brandon APPROVED [Signature] 1/9/90

CALCULATION NO. NPP1-SBO-007

CALCULATION NPP1-SBO-007

COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS

JOB NO. NP-110DATE 11/30/89PROJECT CNS STATION BLACKOUT (SBO)SUBJECT CONTROL ROOM HEATUPCLIENT NPPDORIGINATOR EE HuntREVIEWER JBAPPROVED [Signature]CALCULATION NO. NPP1-SBO-007

## REVIEWER'S STATEMENT

THIS CALCULATION WAS REVIEWED AND FOUND TO BE COMPLETE AND CORRECT IN ITS ASSUMPTIONS, CALCULATIONS REFERENCES AND CONCLUSIONS.

THE REVIEW CONSISTED OF:

- AN EXAMINATION OF THE APPROPRIATENESS OF THE USE OF "HEATING-6" AND "CONTEMPT" COMPUTER CODES FOR THIS ANALYSIS.
- AN EXAMINATION OF THE APPROPRIATENESS OF USING THE REFERENCED SOLAR RADIATION AND AIR TEMPERATURE DATA FOR THIS ANALYSIS.
- HEAT TRANSFER CALCULATIONS WERE CHECKED FOR NUMERICAL ACCURACY AND WITH THEIR SOURCE DOCUMENTS IN ORDER TO DETERMINE IF THEIR USE IS APPROPRIATE IN THIS CALCULATION.
- MATERIAL DIMENSIONS AND THERMAL PROPERTIES WERE CHECKED AGAINST THEIR REFERENCES.
- ELECTRICAL LOADS AND THEIR CONVERSION CALCULATIONS WERE CHECKED WITH THEIR REFERENCED SOURCE.

JOB NO. NP-110 DATE 11. 30/89  
PROJECT CNS STATION BLACKOUT (SBO)  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR EEH/cont  
REVIEWER JA APPROVED CE  
CALCULATION NO. NPP1-SBO-007

## REVIEWER'S STATEMENT (CONT'D)

- COMPUTER CODE INPUT DECKS WERE SPOT CHECKED FOR ACCURACY.
- MODELING ASSUMPTIONS WERE REVIEWED FOR REASONABLENESS AND JUDGED TO BE CONSERVATIVE.
- THE RESULTS OF ANALYSIS WERE REVIEWED AND WERE JUDGED TO BE REASONABLE.
- THE CALCULATION WAS REVIEWED FOR COMPLETENESS AND CLARITY.

*John Brandon*  
12/19/89

JOB NO. NP-110 DATE 11/30/89  
 PROJECT CNS STATION BLACKOUT (SBO)  
 SUBJECT CONTROL ROOM HEATUP  
 CLIENT NPPD ORIGINATOR EE Schmitt  
 REVIEWER [Signature] APPROVED \_\_\_\_\_  
 CALCULATION NO. NPP1-SBO-007

## TABLE OF CONTENTS

REVIEWER'S STATEMENT	2
OBJECTIVE	7
CALCULATION OVERVIEW	7
1.0 INTRODUCTION	9
1.1 CONTROL BUILDING LAYOUT	10
1.1.1 CONTROL ROOM DETAIL	10
2.0 METHODOLOGY OVERVIEW	11
2.1 PROBLEM APPROACH	11
2.1.1 COMPUTER CODE STATUS	13
2.2 ASSUMPTIONS AND CONSERVATISM	13
3.0 EXTERNAL HEAT LOADS	17
3.1 EXTERNAL AIR TEMPERATURE	17
3.2 SOLAR HEAT FLUX	17
4.0 INTERNAL HEAT LOADS	19
4.1 ELECTRICAL EQUIPMENT HEAT LOADS	19
4.1.1 ELECTRICAL PANEL LOADS	19
4.1.2 EMERGENCY LIGHTING LOAD	20
4.1.3 COMPUTER SYSTEM LOAD	20
4.1.4 ANNUNCIATOR LOAD	20
4.1.5 SECURITY SYSTEM LOAD	20

5/68  
NPPA-5B0-007  
24 17

4.2	PERSONNEL HEAT LOADS	20
4.3	SUMMARY OF LOADS	20
4.4	CONTROL ROOM INITIAL HEAT STRUCTURE AND BULK AIR TEMPERATURES	21
4.5	ADJOINING ROOM TEMPERATURES	21
5.0	CONTROL ROOM MODELING	23
5.1	CONTROL ROOM AND ACCESS AREA VOLUMES	23
5.2	CONTROL ROOM CEILING AND CONCRETE ROOF	23
5.3	NORTH WALL	25
5.4	SOUTH WALL	26
5.5	WEST WALL	26
5.6	EAST WALL	26
5.7	FLOOR	27
5.8	HEAT SLAB AREAS	27
6.0	CONVECTIVE HEAT TRANSFER	28
6.1	CEILING AND FLOOR	28
6.1.1	HEAT EXCHANGE WITH CONTROL ROOM AIR	28
6.1.2	CEILING AIR SPACE	32
6.2	NORTH AND EAST WALLS	37
6.2.1	WALL AIR SPACES	37
6.2.2	NORTH WALL EXTERNAL HEAT TRANSFER COEFFICIENT	41
7.0	RADIATIVE HEAT TRANSFER	45
7.1	EXTERIOR RADIATION	45
7.2	INTERIOR RADIATION	45
8.0	AIR LEAKAGE	48
9.0	RESULTS	49
9.1	TIMESTEP CONTROL	49
10.0	CONCLUSIONS	50
11.0	REFERENCES	51

ATTACHMENTS

- I. Development of HEATING-6 One-Dimensional Thermal Model of the Control Room Ceiling and Concrete Roof Structures
- II. HEATING-6 Code Output Deck for the One-Dimensional HEATING-6 Thermal Model
- III. Monthly Summary Solar Radiation Data - June 1977
- IV. CNS Control Room Roof Insulation Information
- V. Letter EEH-89-084 from E.E. Holcomb, Enercon Services, Inc. to W. L. Swantz, NNPD, "CNS Control Room Electrical Load Summary", Dated 11/14/89.
- VI. Details of Leakage Coefficient Calculations for CONTEMPT-LT/028 Input Deck.
- VII. CONTEMPT-LT/028 Input and Output for the 4-Hour SBO Simulation



JOB NO. NP-110 DATE 11/30/89  
PROJECT CNS STATION BLACKOUT (SBO)  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR E Holcomb  
REVIEWER ✓ APPROVED \_\_\_\_\_  
CALCULATION NO. NPP1-SBO-007

## OBJECTIVE

The purpose of this calculation is to determine the temperature of the Cooper Nuclear Station (CNS) Control Room during a postulated station blackout (SBO) event lasting 4 hours.

## CALCULATION OVERVIEW

This calculation involves the following principal steps:

- 1) A brief introduction is provided.
- 2) The problem approach is discussed. Key assumptions and conservatism are identified.
- 3) The ambient air and solar insolation boundary conditions are developed.
- 4) Internal heat loads are quantified. Initial conditions are given for the control room and heat structures. Temperatures in the spaces adjacent to the control room are discussed.
- 5) The control room analytical model is developed. Individual heat structure models are detailed, and boundary conditions for each slab are discussed.

- 6) Convective heat transfer coefficients are calculated, for those heat structures where default correlations are not used.
- 7) Radiative heat transfer configuration factors are provided as required.
- 8) A model for air infiltration into the control room is developed.
- 9) Results are presented for a 4-hour simulation of the control room heatup.
- 10) The necessary references and figures complete the main part of the document. Supporting documentation is included as attachments to the calculation.

9/68

JOB NO. NP-110 DATE 11/30/89  
 PROJECT CNS STATION BLACKOUT (SBO)  
 SUBJECT CONTROL ROOM HEATUP  
 CLIENT NPPD ORIGINATOR E Holcomb  
 REVIEWER [Signature] APPROVED \_\_\_\_\_  
 CALCULATION NO. NPP1-SBO-007

1.0 INTRODUCTION

Station blackout and related issues are being addressed by the Nebraska Public Power District (NPPD) in response to the Station Blackout Rule, 10 CFR 50.63, and Regulatory Guide (RG) 1.155. NUMARC 87-00 (Reference 1) also provides guidance that is in large part identical to RG 1.155, and adherence to the guidelines in NUMARC 87-00 is sufficient to demonstrate compliance with the SBO Rule.

NUMARC 87-00 requires that temperature severity be assessed in areas of the plant containing equipment whose function is essential to the mitigation and control of an SBO event, and also in areas where operators are required to perform manual operations. Areas containing essential equipment and whose steady state temperature would be expected to exceed 120 degrees Fahrenheit are designated as SBO dominant areas of concern (DAC). Areas requiring operator presence must be addressed for habitability concerns, especially if the area temperature is expected to exceed 110 degrees F.

The subject of this calculation is the CNS Control Room heatup during a postulated SBO event in which ventilation is lost for 4 hours before offsite AC power can be restored. Four hours is the required CNS SBO coping duration, determined in Reference 2. Insofar as the Control Room is affected, SBO occurrence is accompanied by a loss of forced ventilation and normal lighting, and a loss of power to non-essential electrical panels. Therefore, heat loads in the room are reduced because of the loss of offsite AC power. The problem is basically to determine the magnitude of

10/68

SAI  
24 NPP1-5Bd-007

the remaining loads and to ascertain the steady state room temperature for this situation, i.e. internal room heating less than normal but without the benefit of air conditioning. The methodology applied to problem is discussed in Section 2.

### 1.1 CONTROL BUILDING LAYOUT

The site layout at CNS is shown in Figure 1. The Control Building is located on the north side of the reactor complex, between the Radwaste and Turbine Generator Buildings. The Control Building contains (at elevation 932' - 6") the Control Room and the Computer Room, which are shown in plan view in Figure 2. These two rooms are connected by the double doors on the east side of the Control Room. Another set of double doors, at the southeast corner of the Control Room, leads to the Turbine Generator Building.

The heatup analysis herein focuses on the thermal response of the Control Room, the boundary of which is defined by Figure 2.

#### 1.1.1 CONTROL ROOM DETAIL

It is useful at this point to introduce some details of the Control Room construction, to support discussions in the sequel. Extracted from Burns & Roe Drawing 4526, Figures 3a and 3b show cross sections of the Control Room. These sections illustrate the interior wall and ceiling construction in relation to the concrete building envelope. The interior ceiling, constructed of acoustic tile and gypsum board, covers most of the Control Room area defined in Figure 2, except for the "Access Area" regions on the south and west sides of the Control Room, exterior to the outer rows of electrical panels.

11/68  
NPPM - SBQ - 007  
EA

## 2.0 METHODOLOGY OVERVIEW

The CNS Control Room heatup is determined computationally, using the HEATING-6 (Reference 3) and CONTEMP-LT/028 (Reference 4) computer codes as the primary analytical tools. The Control Room is treated as a single, well-mixed volume, and one-dimensional models are employed for heat conduction through structures.

Appendix E of NUMARC 87-00 provides a simplified methodology that can be used for some room heatup calculations. In the NUMARC methodology, it is assumed that the temperature of major heat sinks, such as the walls and ceiling, is constant. With respect to the CNS Control Room, two aspects of the ceiling heat transfer prevent direct application of the NUMARC methodology:

- i) The roof of the Control Room is subjected to transient solar heating, therefore, the assumption of a constant temperature has to be justified. Also, the roof might prove to be a heat source on a summer day instead of a heat sink.
- ii) The CNS Control Room has a suspended interior ceiling that is composed of acoustic tile and gypsum board. The assumption of a constant temperature for these relatively thin layers of material would be questionable. (See Figures 3a & 3b).

Highlights of the problem approach and key assumptions are presented in the next few subsections.

### 2.1 PROBLEM APPROACH

The CNS Control Room heatup problem is divided into two principal parts. First, the steady periodic temperature of the solar heated roof and ceiling heat structures is

determined, to establish roof initial conditions at the onset of the SBD. This computation is performed with the HEATING-6 computer code. HEATING-6 was chosen for this phase of the calculations, because of tractability in treating the solar heat flux term and because of code features which facilitate treatment of heat transfer in the air space between the Control Room tile ceiling and concrete roof. Since the CNS Control Room roof is constructed of concrete and is over two feet thick, the thermal capacitance and time constant of the roof have a bearing on the problem. Therefore, the HEATING-6 simulation is performed for about four days to ensure that a meaningful steady state is obtained. The HEATING-6 code input model development and the results of the steady state computations are detailed in Attachment I.

For the second phase of the problem, the temperatures obtained from HEATING-6 are used to initialize the roof heat structure for the Control Room transient heatup calculations over the 4-hour SBD time period.

The transient computations are performed with the CONTEMP-LT/028 computer program. The Control Room is treated as a well-mixed lumped volume, for reasons to be discussed in the sections which follow. Six major heat structures (i.e. the walls, roof/ceiling and floor) are modelled. Minor heat structures, including passive heat sinks, are not considered. The roof, air space and ceiling transient response is computed, using simplified external boundary conditions which are based on the results of the HEATING-6 analysis. Control Room internal heat loads consist mainly of electrical equipment, with a minor amount (i.e. < 1 KW) contributed by personnel. The electrical load determination is detailed in Section 4 and its supporting attachments. No credit is taken for forced ventilation (e.g. from battery-powered fans) or opening of doors. The calculation does, however, model air leakage from the Control Room via infiltration. Details of the computer code input model construction are provided in

Sections 5 through 8. The results of the transient ✓  
computations with CONTEMPT-LT/028 are presented in Section 9.  
Key assumptions for the transient analysis are highlighted in  
Section 2.2.

### 2.1.1: COMPUTER CODE STATUS

The computer code calculations used in this were  
run on mainframes at Power Computing Company in Dallas,  
Texas. Both codes exist in a quality assured, fully  
configured status and are controlled by the PCC QA  
program.

The HEATING-6 computations were performed with QA Version  
0584. HEATING-6 is a proven product which has been in  
the commercial marketplace for several years. Developed  
at the Oak Ridge National Laboratory, it has been  
subjected to extensive testing and assessment, as  
documented in Reference 3A.

CONTEMPT-LT/028 was developed at the Idaho National  
Engineering Laboratory for analysis of containment  
behavior. It has generalized compartment modelling  
features which make it well suited to room heatup  
analysis. Version JUL82, installed in the PCC QALIB and  
residing on the NOS2 System for the CYBER 990 computer,  
was utilized for the computations in calc. NPP1-SBO-007.  
Like HEATING-6, the code has undergone thorough testing  
prior to installation in PCC QALIB.

## 2.2 ASSUMPTIONS AND CONSERVATISM

2.2.1 The SBO is assumed to occur from 14:00 to 18:00 hours. ✓  
The combination of highest ambient temperatures and  
highest roof temperatures occurs during this time

interval, based on the results in Attachment 1.

2.2.2 The net free volume of the control room includes all of the enclosed volume. (But see item 2.2.4). The volume of electrical panels, furniture, people, etc. is not subtracted from the room volume since these are not physically modeled. This approach results in a more rapid energy deposition to the room than would actually occur, because electrical energy is immediately dissipated in the room air rather than heating the physical mass of the panels. Conservatively, no credit is taken for passive heat sinks.

2.2.3 Control room and access area (Figure 2) are lumped together as one volume, since both areas contain electrical panels which would be active during SBD.

2.2.4 The air volume between the control room suspended ceiling and the concrete roof slab is not included in the control room net free volume calculation.

2.2.5 The internal energy generated in the control room is assumed to be evenly distributed throughout the room as opposed to modeling localized sources because:

2.2.5.1 The personnel and emergency lighting loads are distributed throughout the room.

2.2.5.2 The computer system heat load results from a total of eleven items, the largest of which is rated at 600W. Terminals, CRTs, etc. are considered to be distributed throughout the room rather than concentrated at a single location.



- 2.2.5.3 The majority of electronic panels have open backs, which greatly enhances panel cooling and energy distribution. The active panels during SB0 are distributed throughout the room. The largest individual panel load is about 2.3KW, which is about the same heat as generated by a kitchen stove burner. Individual panel loads are delineated in Section 4. Also see Figure 4.
- 2.2.5.4 CNS procedures direct the control room operators to obtain portable supply fans in the event of a ventilation failure that cannot be readily corrected, to carry away heat from the control room console. (No credit for fan cooling has been taken in the analysis. Heat transfer from the room air to the major structures is modelled by natural convection).
- 2.2.6 Stored energy within the electrical panels and lighting, which were energized prior to the onset of the SB0, is neglected. This is considered to be a small amount of energy, and neglecting it should be more than offset by not taking credit for the control room interior passive heat sinks.
- 2.2.7 The initial equilibrium temperature of the Control Room just prior to loss of HVAC is assumed to be 23 degrees C. See also Section 4.4.
- 2.2.8 The areas immediately adjacent to the Control Room (see Figures 1 and 2) are assumed to be at a constant temperature of 90 degrees F for the 4-hour SB0. Further discussion regarding this assumption is provided in Section 4.5.

2.2.9 Referring to Figure 2, there are 3 doors between the main portion of the control room and the "Access Areas" on the west, south and east sides. Further, there are two sets of double doors between the Control Room and adjoining areas. Very conservatively, no explicit credit has been taken for opening of doors in the analysis. Implicitly, any opening of doors would further support the assumption that the room is well-mixed.

17/68

NPPM-SBd-007

EA 1/9

### 3.0 EXTERNAL HEAT LOADS

#### 3.1 EXTERNAL AIR TEMPERATURE

The outside air temperature data used in this analysis are ASHRAE 1% design values based on US Weather Bureau records for Omaha, Nebraska. (Use of data from Omaha was considered appropriate for the reasons listed in Section 3.2). The data are presented in Table 1, page 23.10 of ASHRAE (Reference 5). The 1% high temperature value is 94 degrees Fahrenheit, and a conservative value of 76 degrees F was assumed to be the low temperature. The high and low values were used to develop a sinusoidal function of ambient temperature vs. time, which is given in Attachment I.

#### 3.2 SOLAR HEAT FLUX

Solar energy is conservatively assumed to irradiate the entire surface of the control building roof for the entire solar day. Shadows cast on the Control Building roof from other structures were ignored. (Roof elevations are indicated on Figure 1. The Turbine Building, to the east, is 58 feet higher than the Control Building. The Reactor Building, on the south side, is 100 feet higher). The waterproofing material on the surface was assumed to be asphalt. An absorptivity of 0.94 is used for solar heating, based on the 0.938 solar cell value in Reference 6 and the carbon black value in Reference 7. While Reference 8 indicates that an asphalt emissivity value of 0.93 would be a good choice, a slightly conservative value of 0.90 is assumed for reradiation from the heated asphalt surface.

The solar heat flux data used in this analysis are from the National Oceanic and Atmospheric Administration (NOAA) report titled "Monthly Summary Solar Radiation Data". Data from Omaha, Nebraska were used because of its proximity to CNS. The available edited data from June of 1977 to June of 1989 were

18/68

27.7 NPP1-5B4-007

examined. (Reference 9, Attachment III). Omaha, at 41 degrees 22 minutes north latitude, is located sufficiently close to Brownville, at 40 degrees 21 minutes north latitude, such that the Omaha data are considered applicable to CNS. The Omaha data are considered slightly conservative because of a slightly longer day length. Climates are very similar, because Brownville and Omaha are both located on the Missouri River.

A typical day near the summer solstice was selected to represent the CNS roof solar heat flux. The typical day was one which exhibited clear sky features and had a combination of peak mid-day total heat flux and maximum integrated heat flux. June 19, 1977 well fits these criteria, as seen in Attachment III. The data from 6 to 7 AM are indicated to be questionable but were in the same range as other data for that month and thus have been retained. Data from 7 to 8 AM appear anomalously low, possibly indicative of a cloud cover. These data have been edited by taking the maximum, non-questionable value for that time period during the month of June. This "typical day" is in fact considered a representative upper bound of summer conditions. This heat flux condition is assumed to persist for 4 days in the steady periodic solution in Attachment I.

Based on the development in Reference 7, the heated roof reradiates to the sky according to

$$(1) \quad q'' \text{ out} = \epsilon * \sigma * (TR^{**4} - TSKY^{**4}), \text{ where}$$

TR and TSKY are the roof and sky absolute temperatures, respectively, sigma is the Stefan-Boltzmann constant, epsilon is the roof emissivity, and q'' out is the net radiative heat flux between the roof and the sky.

19/68  
Est v. NPP1-SB0-007

The sky temperature is related to the ambient temperature, TAMB, by

$$(2) \text{ TSKY} = 0.0552 * \text{TAMB}^{1.5}, \text{ where}$$

both TSKY and TAMB are in degrees Kelvin, and TAMB varies with time as discussed in Section 3.1.

#### 4.0 INTERNAL HEAT LOADS

##### 4.1 ELECTRICAL EQUIPMENT HEAT LOADS

To determine the Control Room electrical loads, all breakers powering Control Room equipment which would be active during an SBO were examined from the standpoint of determining those which would generate heat in this room. (See NPPD Calculation NEDC-89-1947 for the detailed loads breakdown). The systems of interest are the 125VDC system and the No-Break Power Panel (NBPP), i.e. uninterruptible AC circuits powered through inverters. The electrical loads in the subsections which follow reflect loads which terminate and dissipate heat in the Control Room. Power supplies and other equipment located exterior to the Control Room were not included in the load summaries.

The CNS Control Room electrical loads are summarized in Attachment V and its exhibits and are as follows:

##### 4.1.1 ELECTRICAL PANEL LOADS

AC Loads

No-Break Power Panel 4753W ✓

DC Loads  
Div. I & II 2721W

ETA (P)

- 4.1.2 EMERGENCY LIGHTING LOAD  
(30 - 12W bulbs) 360W  
(Indicating Lights) 344W ✓
- 4.1.3 COMPUTER SYSTEM LOAD  
(CRTs, etc.) 3960W ✓  
-See Exhibit B of Att. V-
- 4.1.4 ANNUCIATOR LOAD 1938W ✓  
-See Exhibit D of Att. V-
- 4.1.5 SECURITY SYSTEM LOAD  
SAS Console 1494W ✓  
-See Exhibit C of Att. V-

The analysis results will show that it is unnecessary to power down the security system from the standpoint of control room heatup. The inclusion of the SAS load is conservative, because the security cubicle is outside of the control room proper.

- 4.2 PERSONNEL HEAT LOADS  
8 people (3000 BTU/hr) 879W ✓  
(Reference 10, page 47)

4.3 SUMMARY OF LOADS

The total heat load is 16,449W . ✓

21/68

ER ✓ NPP1-SB4-007

#### 4.4 CONTROL ROOM INITIAL HEAT STRUCTURE AND BULK AIR TEMPERATURES

The control room, initially air conditioned, is assumed to have a bulk air temperature of 23 degrees C (73.4 degrees F) at the start of the SBO. At time zero the air conditioning is lost. One side of each heat structure is in contact with the Control Room air. The initial temperature of each heat structure is determined via the CONTEMP-LT/02B code, in which a steady state temperature profile is established for each slab prior to commencement of the transient computations.

One comment is in order regarding the heat structure initialization. Adjoining rooms on the south and east and beneath the Control Room are air-conditioned spaces, as will be discussed in the next section. Since interior climate control is continuous, the walls between these spaces would be at approximately the same temperature as the surrounding room air at the onset of an SBO, i.e. about 73 deg. F. The heat structure initialization does not take credit for this. Very conservatively, the side of the structure not in contact with the Control Room air is assumed initially to be at the temperature of the adjoining space, which is 90F.

#### 4.5 ADJOINING ROOM TEMPERATURES

A constant temperature of 90 degrees Fahrenheit is assumed for the bulk room air temperature of the adjoining rooms. This boundary temperature is held constant for the SBO duration.

- a. This assumption is based on the results of the HEATING-6 analysis discussed in Section 7.1 and the reasoning that interior walls and rooms not exposed to solar flux and having insignificant internal heat loads will be at lower temperatures.

b. It is considered conservative, since the normal operating temperatures of the spaces surrounding the Control Room are less than 90 degrees F.

Refer to Figures 1 & 2. The Computer Room, on the east, is normally air conditioned and would have no significant sources of heat during an SBO. (Procedures dictate that the doors between the Control and Computer Rooms be opened in the event of loss of Control Room ventilation, although the analysis has not modelled this large flow path). On the south, the access corridor (i.e. the "Office Bldg. Controlled Corridor") is normally air conditioned and has no heat sources. The access corridor acts as a buffer zone between the Control and Reactor Buildings. The two are separated by massive concrete walls. Similarly, the cable room, immediately beneath the control room, is part of the Control Bldg. envelope and is also air conditioned. Most of the electrical equipment in this room would be inactive during the SBO. Temperatures in the Radwaste and Turbine Generator Buildings normally do not exceed about 85 deg. F. The assumption of a constant temperature of 90F for these adjoining areas is considered conservative.

c. Using the Appendix R drawings (Reference 15) and Burns & Roe Drawing No. 2066, it can be seen that the Control Room is far away and well insulated from areas that would be heated during an SBO (e.g. the drywell, RCIC room and the DC switchgear rooms). In all cases, separation from the Control Room and heated areas is by at least two major floors or walls.

d. It was necessary to select one temperature for all adjoining rooms because of code input constraints.



## 5.0 CONTROL ROOM MODELING

23/68  
NPP1-580-007  
SA 10

Major features of the CONTEMPT-LT/028 model of the CNS Control Room are shown in Figure 5. The modelling approach has been discussed in previous sections. Modelling detail reduces basically to calculation of the room net free volume, to definition of the heat slab areas, thicknesses and constituent materials, to modelling of air infiltration, specification of boundary conditions and internal energy generation, then supplying the necessary control cards required by the input processor. Whenever possible, the LT/028 model development relies on data generated in the HEATING-6 model development in Attachment 1.

### 5.1 CONTROL ROOM AND ACCESS AREA VOLUMES

The dimensions of the Control Room envelope have been presented in Figures 2 and 3. From sheet 24, the Control Room net free volume (NFV) is:

$$\text{NFV} = 54,018 \text{ ft}^3$$

The Control Room is simulated as a "Drywell" (i.e. compartment volume no. 3) in the CONTEMPT-LT/028 deck. This is done because of the greater modelling latitude when using this compartment option.

### 5.2 CONTROL ROOM CEILING AND CONCRETE ROOF - HS2

Based on the discussion in Section IV of Attachment I and on Figures 3a & 3b, the construction of the suspended ceiling and roof is illustrated in Figure 6. This figure also indicates the application of boundary conditions. At the top of the concrete slab, a large heat transfer coefficient (HTC) is used



JOB NO. NP-110 DATE 12/6/89  
 PROJECT CNS STATION BLACKOUT  
 SUBJECT CONTROL ROOM HEATUP  
 CLIENT NPPD ORIGINATOR E. Williams  
 REVIEWER LA APPROVED \_\_\_\_\_  
 CALCULATION NO. NPPD - 1-002

1) ACCESS AREA VOLUME

(SEE FIGURES 2 and 3 FOR SIZES OF SKETCH BELOW)

SOUTH VOLUME

$$V_s = 53.0833' \times 15.5' \times 14.25'$$

$$= 11,724.8 \text{ ft}^3 \checkmark$$


WEST VOLUME

$$V_w = 54' \times 7.33' \times 14.25'$$

$$= 5640.4 \text{ ft}^3$$

TOTAL ACCESS VOLUME

$$V_{AT} = 11,724.8 + 5640.4 = 17,365.2 \text{ ft}^3 \checkmark$$

2) CONTROL ROOM VOLUME BENEATH SUSPENDED CEILINGMAIN ROOM (V<sub>CRM</sub>)

$$V_{CRM} = 56.75' \times 54' \times 11.33' = 34,720.8 \text{ ft}^3 \checkmark$$

'SOUTH' PORTION (V<sub>CRS</sub>)

$$V_{CRS} = 11' \times 15.5' \times 11.33' = 1,931.8 \text{ ft}^3 \checkmark$$

$$V_{CRM} + V_{CRS} = 36,652.6 \text{ ft}^3 \checkmark$$

3) FOR 'ATZB' MODEL, NET FREE VOLUME (NFV)

$$NFV = V_{AT} + (V_{CRM} + V_{CRS}) = 17,365.2 + 36,652.6 \text{ ft}^3 = 54,017.8 \text{ ft}^3 \checkmark$$

to impress a constant surface temperature of 90 degrees F on the slab. The 90 F value is bounding and based on Figure 1-7 of Att. 1. For the air space, heat exchange by natural convection and thermal radiation is allowed. Finer noding is used for the air region adjacent to the thinner layers (i.e. the tile & gypsum) consistent with code manual recommendations for mesh spacing at material interfaces. The acoustic tile is coupled to the room air via a temperature-dependent, natural convective HTC. Heat transfer coefficients for this heat structure (HS) are developed in Sections 6.1.1 and 6.1.2. Material properties are taken from Sect. IV-B of Att. 1.

### 5.3 NORTH WALL - HS1

The north wall heat structure model is shown in Figure 7. The right side of the structure is connected to the control room air via the CONTEMP-LT/02B default correlation for natural convection to vertical surfaces (Ref. 4). The left side is exposed to the outside air temperature, discussed in Section 3.1. A constant HTC of 0.2 Btu/hr-ft<sup>2</sup>-degf is used for the north wall exterior, based on values obtained while initializing the heat slabs with the code. The above HTC takes no credit for wind cooling of the north wall and is conservative with respect to heat losses. (Control Room interior wall natural convection heat transfer coefficients calculated with the code default correlation are about 0.4 to 0.5, for example). Heat transfer across the interior air space in the wall considers natural convection and thermal radiation, discussed in Sections 6.2.1 and 6.2.2.

From Dwg. 4526, Section F2 and Detail 10 (Figure 8) the interior panels are 5/8" thick. The thin plastic laminate facing is neglected. The panels are assumed to be Douglas Fir plywood. From Reference 5, Table 3A, p. 22.13, the thermal properties are:

density = 34 lbm/ft\*\*3;

thermal conductivity = 0.067 Btu/hr-ft-degf;

specific heat = 0.29 Btu/lbm-degf.

#### 5.4 SOUTH WALL - H34

The south wall heat structure model is shown in Figure 9. The wall is taken to be a 2-foot-thick concrete slab. It is assumed that the wall is unfaced, since the spaces adjacent to the wall are access areas. Both sides of the wall are convectively coupled to air in the surrounding spaces via the code's default correlation, as was done for the north wall. The Office Building Controlled Corridor is considered to remain at a constant temperature of 90 F.

#### 5.5 WEST WALL - H55

The west wall modelling, illustrated in Figure 10, is identical to the south wall modelling, except the left and right sides of the structure are switched.

#### 5.6 EAST WALL - H56

The east wall model, based on Dwg. No. 4526 and Detail No. 10, is shown in Figure 11. This wall is assumed to be faced on both sides, with the facing construction the same as discussed in Section 5.3. Natural convection to the adjacent rooms again uses the code default correlation. Natural convection and thermal radiation are modelled in the all interior air spaces via an equivalent conductance, see Section 6.2.1.

27/68  
NPP1-5B6-002  
SJA ✓

### 5.7 FLOOR - HS3

The floor heat structure is simulated as an 8-inch-thick concrete slab, as shown in Figure 12. The bottom of this slab is convectively coupled to the cable room air by a temperature-dependent natural convective HTC, which is entered as tabular input in the LT2B deck. This tab. is developed in Section 6.1. The approach for the bottom side of this slab is the same as used for the Control Room ceiling. For the top surface of the slab, a constant value of 0.21 is used for the heat transfer coefficient, as explained in Item vi) of Section 6.6.1.

### 5.8 HEAT SLAB AREAS

Using Figures 2 & 3, the heat structure areas are determined, as listed below:

- HS1 - NORTH WALL - AREA =  $64.0833' \times 11.3333' = 726.3 \text{ ft}^2$  ✓
- HS2 - CEILING - AREA =  $56.75' \times 54' + 15.5' \times 11'$   
=  $3,235 \text{ ft}^2$  ✓
- (See also sheet 24).
- HS3 - FLOOR - AREA =  $69.5' \times 64.0833' = 4,454 \text{ ft}^2$  ✓
- HS4 - SOUTH WALL - AREA =  $64.0833' \times 14.25' = 913.2 \text{ ft}^2$  ✓
- HS5 - WEST WALL - AREA =  $69.5' \times 14.25' = 990.4 \text{ ft}^2$  ✓
- HS6 - EAST WALL - AREA =  $69.5' \times 11.3333' = 787.7 \text{ ft}^2$  ✓

## 6.0 CONVECTIVE HEAT TRANSFER

20/68  
NPP-520-007  
SCH

### 6.1 CEILING AND FLOOR

#### 6.1.1 HEAT EXCHANGE WITH CONTROL ROOM AIR

For the floor and ceiling, the characteristic lengths are quite large. Approximate heat transfer coefficients are chosen based on the following approach:

- i) The surface temperature is assumed to be approximately equal to 90 deg. F for purposes of HTC calculations.
- ii) To calculate 'h', the following correlation from Ref. 5 for turbulent natural convection is used for the ceiling:

$$Nu = 0.13 * (Gr Pr)^{0.33}$$

This equation has the advantage that the heat transfer coefficient is independent of the characteristic length (L). The equation is valid for GrPr up to 1.0E+12.

- iii) To take into account the range of validity, the Rayleigh number is set to the above value, then the allowable values of the characteristic lengths are determined, as shown on sheet 30. It is seen that the allowable value of 'L' depends on the temperature difference. From Dwg. No. 4526, the largest characteristic length is about 35 to 37 feet on the main control room floor, in reasonably good agreement with the maximum allowable values of 'L' for temperature differences (i.e.  $T_f - T_s$ ) of 20F or less. Using the cube root of the air space volume between

the suspended ceiling and the luminous grid, a value of 'L' of about 20 feet results, with resultant values of Gr\*Pr indicated to be within the range of validity of the correlation (column B).

- iv) It does not matter what value of 'L' is chosen for the heat transfer coefficient calculations, as 'h' depends primarily on delta 'T'. Scoping calculations with the 'LT2B' model indicated that a surface temperature of 90F and delta 'T' values of 5 to 10F are reasonable assumptions.
- v) The values of 'h NC' indicated on sheet 30 were entered into the input deck as a temperature dependent function for the ceiling. For small values of delta 'T', an average value of h = 0.4785 at Tf = 90F is used based on sheet 30.
- vi) For the floor, p. 2.13 of Ref. 5 indicates that a value somewhat less than 1/2 the ceiling value is appropriate. Using a reduction ratio of 12/27, based on the ratios of coefficients in the laminar flow equations in Table 5, p. 2.12, and an assumed delta 'T' of 10F, a heat transfer coefficient of about 0.21 results. This is applied to the floor as a constant value using a tabular function or time in the LT2B input deck.

30/68  
 NPPA-580-007  
 27 0/3

CONTROL ROOM CEILING

h HORIZONTAL SURFACE  
 HOT PLATE FACING UP  
 COLD PLATE FACING DOWN  
 CHARACTERISTIC DIMENSION (ft) 20.0000 140.000 (in)

ASHRAE HANDBOOK 1977 -- p. 2.12 TABLE 5 SEC. 11.  
 HOT PLATE FACING UP ----- COLD PLATE FACING DOWDOWN  
 (HOT GRILL IN COLD KITCHEN) (COLD CEILING IN WARM ROOM)

$$GR*PR = \frac{g(T_f - T_g)(L/12)^3 * 3600^2 * PR}{T_f(R) * v^2}$$

$$NU = 0.56 * (GR*PR)^{1/4}$$

$$1.0E+04 < GR*PR < 1.0E+08$$

$$NU = 0.13 * (GR*PR)^{1/3}$$

$$1.0E+08 < GR*PR < 1.0E+12$$

SURFACE TEMP (F) 90  
 \*\*\*\*\*

NATURAL CONVECTION			16-Nov-89								NATURAL CONVECTION		
k	VISC ft <sup>2</sup> /hr	PR	FILMTEMP	GASTEMP	L (ft)	GR*PR	GR*PR	NU NC	h NC	H-U.C-D	H-U.C-D	H-U.C-D	H-U.C-D
			T <sub>f</sub> (F)	T <sub>g</sub> (F)		HOR SURF H-U.C-D	HOR SURF H-U.C-D	HOR SURF H-U.C-D	HOR SURF H-U.C-D				
0.01466	0.5685	0.712	60	30	20.00	9.0032E+11	9.0032E+11	1255.281	0.9201				
0.01491	0.58815	0.7105	70	50	24.60	1.0000E+12	5.3764E+11	1057.075	0.7890				
0.01516	0.6078	0.709	80	70	32.11	1.0000E+12	2.4170E+11	809.785	0.6138				
0.01529	0.6179	0.7083	85	80	41.17	1.0000E+12	1.1465E+11	631.545	0.4828				
0.01541	0.628	0.7075	90	90	ERR	1.0000E+12	0.0000E+00	0.000	0.0000				
0.01554	0.6381	0.7068	95	100	42.60	1.0000E+12	1.0345E+11	610.261	0.4742				
0.01566	0.6482	0.706	100	110	34.39	1.0000E+12	1.9675E+11	756.110	0.5920				
0.01578	0.6585	0.70525	105	120	30.54	1.0000E+12	2.8074E+11	851.225	0.6716				
0.01615	0.6895	0.703	120	150	25.45	1.0000E+12	4.8537E+11	1021.649	0.8250				
0.01664	0.7316	0.7	140	190	22.84	1.0000E+12	6.7141E+11	1138.344	0.9471				
0.01712	0.7747	0.698	160	230	21.66	1.0000E+12	7.8742E+11	1200.456	1.0276				
0.01759	0.8187	0.696	180	270	21.08	1.0000E+12	8.5436E+11	1233.850	1.0849				
0.01806	0.8636	0.694	200	310	20.81	1.0000E+12	8.8713E+11	1249.124	1.1280				
0.01853	0.9095	0.693	220	350	20.74	1.0000E+12	8.9728E+11	1253.871	1.1617				
0.01899	0.9561	0.691	240	390	20.79	1.0000E+12	8.9018E+11	1250.585	1.1874				
0.01945	1.0034	0.689	260	430	20.93	1.0000E+12	8.7228E+11	1242.117	1.2080				
0.0199	1.0517	0.688	280	470	21.13	1.0000E+12	8.4800E+11	1230.482	1.2243				
0.02034	1.1009	0.687	300	510	21.38	1.0000E+12	8.1889E+11	1216.236	1.2369				





JOB NO. NP-110 DATE 12/12/88  
PROJECT CNS STATION BLACKOUT  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR J. Hunt  
REVIEWER \_\_\_\_\_ APPROVED \_\_\_\_\_  
CALCULATION NO. NPPD-580-667

For the floor structure, use a multiplier of  $12/27$  on the heat transfer coefficients listed on the previous page.

<u><math>\Delta T</math></u>	<u><math>h_{nc}</math></u>	<u><math>h_{nc} * \frac{12}{27}</math></u>
20 F°	0.6138	0.2728
10	0.4828	0.2146
10	0.4742	0.2108
20	0.5920	0.2631

Choose  $h_{nc} = \text{constant} = 0.21 \text{ Btu/hr-ft}^2\text{-}^\circ\text{F}$ , ✓  
based on an assumed average  $\Delta T$  of  $10 \text{ F}^\circ$   
for the transient. If  $\Delta T$  exceeds this value,  
the choice of  $h_{nc}$  is conservative with respect  
to cooling of the room. ✓

6.1.2 CEILING AIR SPACE

(See next four sheets).

32/68

NPPA-526-007

EQ



JOB NO. NP-110 DATE 12/13/89  
PROJECT CNS STATION BLACKOUT  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR E. H. H. H.  
REVIEWER W. J. APPROVED \_\_\_\_\_  
CALCULATION NO. NPPD-586-007


AIR SPACE ABOVE SUSPENDED CEILING

Parker (Ref. 14, p. 288) gives the relationship for determining the natural convective heat transfer coefficient for convection in an enclosed space, where heat is transferred by a fluid placed between two horizontal plates with the lower plate at a higher temperature.


$$Nu_c = 0.069 \sqrt[3]{Gr_c} Pr^{0.074}$$

for  $0.02 < Pr < 8750$  and  $3 \times 10^5 < Gr_c Pr < 7 \times 10^9$ .

The above equation is used to determine the natural convective heat transfer coefficient ( $h_{nc}$ ) from the bottom of the concrete roof slab to the top surface of the gypsum board which covers the control room.



In the above equation the Grashof number,  $Gr_c$ , is based on the plate spacing, and  $Nu_c$  and  $Pr$  are the Nusselt and Prandtl numbers, respectively.



JOB NO. NP-110 DATE 12/13/89  
 PROJECT CNS STATION BLACKOUT  
 SUBJECT CONTROL ROOM HEATUP  
 CLIENT NPPD ORIGINATOR J. Tolson  
 REVIEWER [Signature] API RIVED [Signature]  
 CALCULATION NO. NPPD-580-007

From the HEATING-6 results in Attachment 2, there is a temperature gradient of approximately  $3F^{\circ}$  across the ceiling air space. The average temperature in the air space during the transient is not known, but it should be somewhat higher than at steady state due to room heating. Let  $T_m = 85^{\circ}F$ .

$$Nu_L = 0.069 (Gr_L)^{1/3} Pr^{0.124}, \quad L = 2.8125' \quad \checkmark$$

$$Gr_L = \frac{32.174 ft}{sec^2} * (2.8125 ft)^3 \frac{8600^2}{(459.69 + 85)} * 3F^{\circ} * \frac{ft^2}{0.6179^2 ft^4}$$


$$= 1.3382 * 10^8 \quad \checkmark$$

$$@ T_m = 85^{\circ}F, \quad Pr = 0.70825$$

$$\Rightarrow Nu_L = 34.4015 \quad \checkmark$$

$$h_{NC} = \frac{Nu_L \cdot k}{L} = Nu_L * \frac{0.01528 \dots}{2.8125'} = 0.1870 \quad \checkmark$$

As  $\Delta T$  increases above the  $3F^{\circ}$  value used, the heat transfer coefficient will also increase. Use of the above value will, therefore, be conservative with respect to cooling of the room.  $\checkmark$



JOB NO. NP-110 DATE 12/13/89  
PROJECT CNS STATION BLACKOUT  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR E. Johnson  
REVIEWER CC APPROVED \_\_\_\_\_  
CALCULATION NO. NP9-586-007


For the ceiling air space, heat transfer is treated as combined natural convection and thermal radiation via an effective thermal conductivity. A linearized radiative heat transfer coefficient ( $h_R$ ) is determined, based on  $T_m = 85^\circ$  and  $\Delta T = 3F^\circ$ , discussed above. As temperatures increase,  $h_R$  would increase.

The effective thermal conductivity is the sum of the natural convective and linearized radiative heat transfer coefficients, multiplied by the node thickness. Calculations are shown on the next page.

This procedure enables inclusion of convection and thermal radiation in the CONTEMP-LT/028 model without the complexity of additional heat structures or additional compartments. Isolation of the ceiling air space from the control room <sup>volume</sup> beneath the tile is maintained.\*

The implementation procedure is consistent with the finite differencing procedures for CONTEMP-LT/028 code. The procedure is also consistent with the treatment presented in Reference 3 for HEATING-6, which does have the latitude for direct inclusion of convective and radiative heat transfer across air regions.

\* It should be mentioned that the assumption of total isolation is conservative, as the ceiling air space actually is in lateral communication with the control room access area; see Figures 2 and 3a.



JOB NO. NP-110 DATE 12/13/89  
 PROJECT CNS STATION BLACKOUT  
 SUBJECT CONTROL ROOM HEATUP  
 CLIENT NPPD ORIGINATOR E. Holcomb  
 REVIEWER --- APPROVED ---  
 CALCULATION NO. NPPD-580-007

POUF / CEILING

$$h_{nc} = h_{nc} (T_m)$$

$$T_m = \frac{T_1 + T_2}{2} \quad \checkmark$$

$$h_c = \frac{1}{12} \sqrt{(T_1^2 + T_2^2)} (T_1 + T_2) \quad \checkmark$$

$T_1$	$T_2$	$h_{nc}$	$h_R$	$(h_{nc} + h_R) \bar{\delta}$
16.5°F	83.5	0.1870	0.9430	0.4540 $\frac{\text{Btu}}{\text{ft}^2 \cdot \text{OF}} \quad \checkmark$

where  $\bar{\delta} = 2.8125' / 7 \text{ NODES} = 0.4018 \text{ ft}$ , avg. node spacing.\*

$$T(^{\circ}\text{R}) = T(^{\circ}\text{F}) + 459.69$$

$$\text{@ } T_m = 15^{\circ}\text{F}, \quad \rho = 0.07284 \text{ lb}_m/\text{ft}^3$$

$$c_p = 0.240525 \text{ Btu}/\text{lb}_m \cdot \text{OF} \quad \checkmark$$

$$\Rightarrow \rho c_p = 0.01752 \text{ Btu}/\text{ft}^3 \cdot \text{OF} \quad \checkmark$$

\* The following are implemented in the input deck (Att. VII) for the individual regions of the ceiling air space:

$$\delta_1 = \frac{12.4792 - 12.1042}{2 \text{ NODES}} = 0.1875 \text{ ft} \quad 1^{\text{ST}} \text{ AIR REGION} \quad \checkmark$$

$$\Rightarrow (h_{nc} + h_R) \delta_1 = 0.2119 = k_{\text{eff}_1} \quad \checkmark$$

$$\delta_2 = \frac{14.9167 - 12.4792}{5 \text{ NODES}} = 0.4875 \text{ ft} \quad 2^{\text{ND}} \text{ AIR REGION} \quad \checkmark$$

$$\Rightarrow (h_{nc} + h_R) \delta_2 = 0.5509 = k_{\text{eff}_2} \quad \checkmark$$

57/68

NPP-584-007

EA/1

## 6.2 NORTH AND EAST WALLS

### 6.2.1 WALL AIR SPACES

The procedure used for the wall air spaces is similar to the procedure defined in Section 6.1.2 except that a different convective heat transfer correlation is used to account for the vertical orientation of the walls. A constant, slightly conservative value of the heat transfer coefficient is calculated and used to determine an effective thermal conductivity for the air spaces. As mentioned, this method simplifies the model by reducing the number of heat structures required. The procedure is detailed on the next few pages.



JOB NO. NP-110 DATE 12/13/89  
 PROJECT ENS STATION BLACKOUT  
 SUBJECT CONTROL ROOM HEATUP  
 CLIENT NPPD ORIGINATOR E. K. Kram  
 REVIEWER JK APPROVED \_\_\_\_\_  
 CALCULATION NO. NPPD-586-007

$h_{NC}$  FOR NORTH and EAST INTERIOR WALLS OF CONTROL ROOM

From Reference 14, p. 289,  $h_{NC}$  can be calculated between opposing vertical walls of an enclosure by using the following equations:

$$Nu_L = \frac{h L}{k} = 0.18 (Gr_L)^{1/4} \left(\frac{H}{L}\right)^{1/4}$$

$$\text{for } 2 \times 10^4 < Gr_L < 2 \times 10^5$$


$$Nu_L = 0.065 (Gr_L)^{1/3} \left(\frac{H}{L}\right)^{1/4}$$

$$\text{for } 2 \times 10^5 < Gr_L < 11 \times 10^6$$


These equations are valid for  $H/L > 3$ . Referring to the figure on the right,

$$\frac{H}{L} = \frac{11.33}{0.33} = 34 \gg 3.$$

Because  $H/L$  is large, the air space within the wall is considered to be an enclosed region, ignoring the air space above. Using the above equations,  $h_{NC}$  can be evaluated for desired values of air space and wall surface temperatures.







JOB NO. NP-110 DATE 12/13/89  
PROJECT CNS STATION BLACKOUT  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR E Holcomb  
REVIEWER /s/ APPROVED \_\_\_\_\_  
CALCULATION NO. NPPD-584-007

The temperature gradient across the air space and its average temperature during the transient are unknown. Assume that the  $\Delta T$  is  $4^\circ\text{F}$  and that the mean temperature is  $85^\circ\text{F}$ .

$$Gr_L = \frac{32.174 \text{ ft}}{\text{sec}^2} \times \frac{3600^2}{(85 + 459.69)} \times 4^\circ\text{F} \times \left(\frac{1}{3} \text{ ft}\right)^3 \times \frac{\text{hr}^4}{0.6179^2 \text{ ft}^4}$$
$$= 2.9704 \times 10^5$$


$$Nu_L = 0.065 (Gr_L)^{1/3} \left(\frac{H}{L}\right)^{-1/9}$$

$$= 0.065 \times (2.9704 \times 10^5)^{1/3} \times (34)^{-1/9}$$

$$= 2.9309$$

$$\Rightarrow h_{NC} = Nu_L \frac{k}{L} = Nu_L \times \frac{0.015285}{1/3 \text{ ft}} = 0.1344 \frac{\text{Btu}}{\text{hr-ft}^2-\text{ft}}$$

Larger values of  $h_{NC}$  result at larger values of the temperature difference, even accounting for material property (i.e. air) variations. The assumptions above should therefore be conservative with respect to heat loss through these walls. Using the above  $h_{NC}$ , in combination with a radiative heat transfer coefficient, an effective thermal conductivity can be determined, similar to the procedure used for the roof air space.



JOB NO. NP-110 DATE 12/13/89  
 PROJECT CNS STATION BLACKOUT  
 SUBJECT CONTROL ROOM HEATUP  
 CLIENT NPPD ORIGINATOR E Holcomb  
 REVIEWER JB APPROVED \_\_\_\_\_  
 CALCULATION NO. NPPT-SBB-007

NORTH & EAST WALLS

$$h_{NC} = h_{NC} (T_1, T_2)$$

$$T_m = (T_1 + T_2) / 2$$

$$** h_R = \sigma_{12} \cdot \tau \cdot (T_1^2 + T_2^2)(T_1 + T_2)$$

<u>T<sub>1</sub></u>	<u>T<sub>2</sub></u>	<u>h<sub>NC</sub></u>	<u>h<sub>R</sub></u>	<u>(h<sub>NC</sub> + h<sub>R</sub>) <math>\bar{\delta}</math></u>
87°F	83°F	0.1344	0.7424	0.0731

$$\bar{\delta} = \frac{1/3 \text{ ft}}{4 \text{ WALLS}} = 1/12 \text{ ft}$$

$$@ 85^\circ \text{F}, \quad \rho = 0.07284 \frac{\text{lbm}}{\text{ft}^3}$$

$$c_p = 0.240525 \frac{\text{Btu}}{\text{lbm} \cdot ^\circ \text{F}}$$

$$\rho c_p = 0.01752 \frac{\text{Btu}}{\text{ft}^3 \cdot ^\circ \text{F}}$$


\* This value is the effective thermal conductivity for the north and east walls as implemented in ATT, VII.

\*\* See Section 7.2 for  $\sigma_{12}$ .

41/68  
NPPM-5Bd-007

6.2.2 NORTH WALL EXTERNAL HEAT TRANSFER COEFFICIENT

In Section 5.3, it was noted that a constant HTC of 0.2 was used for heat transfer from the north wall exterior to the ambient air. On the next few pages, calculations are provided which indicate that this is a reasonable assumption for the anticipated range of conditions. ✓



JOB NO. NP-110 DATE 2-17-79  
 PROJECT CNS STATION BLACKOUT  
 SUBJECT CONTROL ROOM HEATUP  
 CLIENT NPPD ORIGINATOR E. Holcomb  
 REVIEWER [Signature] APPROVED \_\_\_\_\_  
 CALCULATION NO. NPPI-580-007

Ref. 4,  
 ENR. (E-27):

$$h_c = 0.13 \left[ \rho_+^2 g \beta_+ \Delta T c_{p+} k_+^2 / \mu_+ \right]^{1/3}$$

Let  $T_g = 90^\circ F$

$T_f = 100^\circ F \Rightarrow \Delta T = 10^\circ F$

$\Rightarrow T_m = 95^\circ F$  normal dry air - v. little difference!


$\rho_+ = 0.07153 \text{ lb}_m/\text{ft}^3$  ✓

$c_{p+} = 0.240575 \text{ Btu}/\text{lb}_m \cdot ^\circ R$  ✓

$k_+ = 0.01554 \text{ Btu}/\text{hr} \cdot \text{ft} \cdot ^\circ F$  ✓

$\mu_+ = 0.04562 \text{ lb}_m/\text{ft} \cdot \text{hr}$  ✓

$$\begin{aligned} \rightarrow h_c &= 0.13 \left[ 0.07153^2 \frac{\text{lb}_m^2}{\text{ft}^6} \cdot \frac{32.174 \text{ ft}}{\text{sec}^2} + \frac{1}{(459.69 + 100)^2 R} \cdot \frac{(100 - 90)^2 \cdot 3600^2 \text{ sec}^2}{\text{hr}^2} \right. \\ &\quad + 0.240575 \frac{\text{Btu}}{\text{lb}_m \cdot ^\circ R} \cdot 0.01554^2 \frac{\text{Btu}^2}{\text{hr}^2 \cdot \text{ft}^2 \cdot ^\circ F^2} \\ &\quad \left. + \frac{1 - \text{ft} \cdot \text{hr}}{0.04562 \text{ lb}_m} \right]^{1/3} \\ &= 0.4742 \frac{\text{Btu}}{\text{hr} \cdot \text{ft}^2 \cdot ^\circ F} \quad \checkmark \end{aligned}$$



JOB NO. NP-110 DATE 12/13/89  
PROJECT CNS STATION BLACKOUT  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR E. Holcomb  
REVIEWER [Signature] APPROVED \_\_\_\_\_  
CALCULATION NO. NPPD-580-007

$$T_f = 80^\circ F \Rightarrow \Delta T = 20^\circ F \quad \checkmark$$

$$\Rightarrow T_m = 15^\circ F$$

$$\rho_f = 0.07284 \quad \checkmark$$

$$c_{pf} = 0.240525 \quad \checkmark$$

$$k_f = 0.01529 \quad \checkmark$$

$$\mu_f = 0.04499 \quad \checkmark$$


$$\Rightarrow h_c = 0.4828 \quad \frac{\text{Btu}}{\text{hr-ft}^2-\text{°F}} \quad \checkmark$$

Use an average of the two,

$$\text{i.e., let } h_c(t) = \text{CONST.} = 0.1785 \quad \checkmark$$

However, note  $h_c = 0.19$  if  $|\Delta T| < 1.0$ , per Ref. 4.

Considering this, and the calc. on next sheet, choice of  $h_c = 0.2$  appears reasonable and slightly conservative. The effect of a small temperature difference is evaluated on the next sheet.



ENERCON SERVICES, INC.

SHEET 44 OF 68

JOB NO. NP-110 DATE 12/13/89  
PROJECT GNS STATION BLACKOUT  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR E. J. [unclear]  
REVIEWER [unclear] APPROVED [unclear]  
CALCULATION NO. NPPD-580-007

Let  $T_c = 86^\circ\text{F}$  and  $T_e = 84^\circ\text{F}$ ,  $\Rightarrow \Delta T = 2^\circ\text{F}$ .

$\Rightarrow T_m = 85^\circ\text{F}$ , use previous properties.

Let  $\Delta T = 2^\circ\text{F}$ ,

$\Rightarrow h_c = 0.2815 \frac{\text{Btu}}{\text{hr} \cdot \text{ft}^2 \cdot ^\circ\text{F}}$

## 7.0 RADIATIVE HEAT TRANSFER

45/68  
NPM-58d-007  
ST 02

### 7.1 EXTERIOR RADIATION

Solar radiation was previously discussed in Section 3.2. Also see Section V.B.2 of Attachment 1.

Because direct application of a heat flux boundary condition to a structure is not possible using the CONTEMPT-LT/02B computer code, the steady periodic temperatures of the ceiling and roof heat structures were first determined using the HEATING-6 conduction code, which does allow heat flux boundary conditions. For the CONTEMPT analysis, the temperature at the top of the roof was then entered as constant boundary temperature and applied to the structure surface using a large heat transfer coefficient, effectively forcing the roof surface temperature to the bounding value determined in the HEATING-6 calculation. ✓

Attachments I and II are the HEATING-6 code thermal model development calculation and printed code output, respectively. Section 3.2 above and the Attachments detail the methodology used in applying the solar heat flux. Attachment I shows the resultant calculated temperatures (Figure I-7) that were used as the basis for the initial conditions for the CONTEMPT-LT/02B analysis. ✓

### 7.2 INTERIOR RADIATION

To evaluate the radiant heat transfer coefficient in the wall and ceiling internal spaces, the assumed geometry is parallel surfaces of infinite extent. The overall configuration factor then depends only on the emissivities of the opposing surfaces, as indicated on the next two pages. This information is used as input to Sections 6.1.2 and 6.2.1 for calculation of the linearized radiative heat transfer coefficient. ✓



JOB NO. NP-110 DATE 12/13/89  
PROJECT CNS STATION BLACKOUT  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR E. Holcomb  
REVIEWER JS APPROVED \_\_\_\_\_  
CALCULATION NO. NPPD-SBD-007

### INTERIOR RADIATION CALCULATION

For the ceiling air space,

$$\text{shape factor } f_{12}^0 = \frac{1}{1/\epsilon_1 + 1/\epsilon_2 - 1} \quad (*)$$

$\epsilon_1$  = emissivity of concrete  $\Omega$ mega 1485  
= 0.94 p. T-28

$\epsilon_2$  = emissivity of gypsum covering  $\Omega$ mega 1485  
Assume 0.90 p. T-28

$$f_{12}^0 = \frac{1}{1/0.94 + 1/0.90 - 1}$$

$$f_{12}^0 = 0.8511 \checkmark$$

The radiative heat transfer is:


$$Q_{12} = f_{12}^0 \sigma (T_1^4 - T_2^4) \quad \text{where } \sigma = \text{Stefan-Boltzmann}$$

$$Q_{12} = (0.85) (0.1714 \times 10^{-8} \text{ BTU/hr}^2 \cdot \text{ft}^2 \cdot \text{R}^4) \Delta T^4 = 0.1714 \times 10^{-8} \text{ BTU/hr}^2 \cdot \text{ft}^2 \cdot \text{R}^4$$

$$Q_{12} = 1.4588 \times 10^{-9} \text{ BTU/hr}^2 \cdot \text{ft}^2 \cdot \text{R}^4 (T_1^4 - T_2^4) \checkmark$$

(\*) See Reference 7.





JOB NO. NP-110 DATE 12/13/89  
PROJECT LNS STATION BLACKOUT  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR E Holcomb  
REVIEWER GH APPROVED \_\_\_\_\_  
CALCULATION NO. NPPD-580-007

For the north end east wall interior,

$$\frac{1}{f_{12}} = \frac{1}{\epsilon_1} + \frac{1}{\epsilon_2} - 1$$

$\epsilon_1 = 0.94$  for concrete

For  $\epsilon_2$ , see below.

$$= \frac{1}{0.94} + \frac{1}{0.7} - 1$$

$$\Rightarrow f_{12} = 0.6701 \quad \checkmark$$

Nothing is known about the back surface of the  
faced panels. Assume  $\epsilon = 0.7$ .  $\checkmark$

4/8/68  
NPPM-580-007  
S.H. W.

### 8.8 AIR LEAKAGE

Because of the temperature difference between the Control Room and adjoining areas, some air flow will occur, mainly through the doors to the Computer Room and the doors leading to the Turbine Building. The following assumptions are made in order to calculate the air exchange:

- a. All doors to the Control Room are assumed to be closed, and only one set of doors is considered to leak. Since AP 2.4.8.4.8 requires that the doors to the Control Room and the Computer Room be opened in the event of loss of ventilation, this approach is conservative.
- b. The door crack width is assumed to be 0.1 inch on the sides and top, and 1/2 inch on the bottom.
- c. The air exchange rate (Q) is determined via Figure 7 on p. 21.7 of ASHRAE. "Q" is then equated to the flow rate which would be calculated by "LT2B", and loss coefficients are determined as a function of differential pressure for input to the code.
- d. The leakage rate from the control room is always less than 0.35 AX/HR during the 4 hour SBO, which is a very "tight" room; thus indicating that the methodology is conservative. (See Figure 13.)
- e. Calculations of leakage coefficients are provided in Attachment VI to support the values used in the input deck.

## 9.0 RESULTS

49/68  
NPPM-580-007  
S.H. J.S.

Results of the analysis using the CONTEMP-LT/028 computer code are plotted in Figure 14. The Control Room heats up quickly to about 92 degrees F in the first 30 minutes after loss of HVAC. The heatup rate slows, with a gradual increase toward equilibrium noted thereafter. The calculated maximum air temperature after 4 hours is 100.3 degrees F. The heatup rate between hours 3 and 4 is 1.05 degrees Fahrenheit per hour. Digital temperature data are listed on the code output provided in Attachment VII.

### 9.1 TIMESTEP CONTROL

A timestep of 0.1 seconds was used for entire 4-hour simulation. The results would not be expected to be sensitive to timestep reductions below this value, say to 0.01 second, because of the relatively slow nature of the room heatup process.

Adequate choice of timestep is indicated by the convergence ratio 'DE/E' listed on the 'LT28' output in Attachment VII. This ratio is of the order of 1.E-06 for the entire transient. Per Reference 4, timestep reductions are warranted when this ratio exceeds about 1.E-03.

The Control Room air temperature was printed every 10 seconds for the first minute of the transient, every minute for the next 39 minutes, and every five minutes thereafter. Heat structure print frequency was somewhat less, to reduce the size of the output listing.

## 10.0 CONCLUSIONS

50/68  
NPP1-SBO-007  
E.H. JS

On the basis of Reference 1, the discussion in Section 1.0 and the computed results, it is concluded that the Control Room at Cooper Nuclear Station would not be a dominant area of concern during a postulated 4-hour station blackout event, since the calculated room temperature is significantly less than 120 degrees Fahrenheit.

Since the calculated maximum room temperature is less than 110 degrees Fahrenheit, with margin, it is concluded that there would be no habitability concerns with respect to performance of operator actions in the Control Room during the 4-hour period.

The computed results have been arrived at using a conservative approach and several, significantly conservative assumptions. There is, therefore, good confidence that the results would bound the actual room temperature for the postulated SBO scenario.


5/68  
NPPA-SB0-007  
EA JA

## 11.0 REFERENCES

1. NUMARC 07-00, "Guidelines and Technical Basis for NUMARC Initiatives Addressing Station Blackout at Light Water Reactors".
2. Enercon Services, Inc., "Station Blackout Coping Assessment for Cooper Nuclear Station", Report No. NPP1-PR-01, Rev. 0, March 30, 1989.
3. Elrod, D. C., G. E. Giles and W. D. Turner, "HEATING-6: A Multidimensional Heat Conduction Analysis with the Finite Difference Formulation", NUREG/CR-0200, Volume 2, Section F10, ORNL/NUREG/CSD-2/V2, October 1981.
- 3A. Bryan, C.B. et. al. "HEATING-6 Verification", Martin Marietta Energy Systems, Inc. Report No. K/CSD/TM-61, December 1986.
4. Hargroves, Don W. and L.J. Metcalfe, "CONTEMPT-LT/028 - A Computer Program for Predicting Containment Pressure-Temperature Response to a Loss-of-Coolant Accident", NUREG/CR-0255, E.G.&G. Idaho, Inc. TREE-1279, March 1979.
5. "ASHRAE Handbook & Product Directory 1977 Fundamentals", American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc., New York, 1977.
6. Chapman, Alan J., "Heat Transfer, 2nd Edition", The Macmillan Co., London, 1967.
7. Duffie, John A. and William A. Beckman, "Solar Energy Thermal Processes", John Wiley & Sons, New York, 1974.
8. Omega Engineering, Inc., "Temperature Measurement Handbook and Encyclopedia", Section 'T', Stamford, Ct., 1985.

52/68  
NPPM-580-007

9. National Oceanic and Atmospheric Administration (NOAA), "Monthly Summary Solar Radiation Data" (for Omaha, Nebraska) June 1977, Volume 1 Number 6, Environmental Data and Information Service, National Climatic Center Asheville, N.C., April 1979.
10. Holman, J. P., "Thermodynamics", McGraw-Hill Book Company, New York, 1969.
11. Burns & Roe Drawing 4526, DCN Rev. No. 1, W.O. 2520, "Control & Computer Rooms Plan, Sections & Details", 11/10/69.
12. Burns & Roe Drawing 4176, Rev. No. 14, W.O. 2520, "Structural Control Building Roof Plan & Sections", 9/1/68.
13. Baumeister, T., editor., "Marks' Standard Handbook for Mechanical Engineers", 8th ed., McGraw-Hill Book Co., New York.
14. Parker, Gerald D., et. al., "Introduction to Fluid Mechanics and Heat Transfer", Addison-Wesley Publishing Co., Reading, Ma., 1974.
15. "Cooper Nuclear Station Safe Shutdown Component Locations & Emergency Route Lighting", NPPD Drawings CNS-EE-175 through 189, May 19, 1987.



ENERCON SERVICES, INC.

SHEET 53 OF 68

JOB NO. NP-110 DATE 12/12/89  
PROJECT CNS STATION BLACKOUT  
SUBJECT CONTR. L ROOM HEATUP  
CLIENT NPPD ORIGINATOR E. Johnson  
REVIEWER [Signature] APPROVED \_\_\_\_\_  
CALCULATION NO. NPP1-584-007

12.0 FIGURES

FIGURE 1

EXTRACTED FROM DWG. 4176

5/68

NPPA-530-007



8/1/79

NON-CONTROLLED PRINT

ROOF ELEVATIONS

CONTROL BLDG. 949' - 1/2"  
 REACTOR BLDG. 1049' - 10"  
 TURBINE BLDG. 1007' - 4 1/2"  
 RADWASTE BLDG. 952' - 10"

U.S. 101389  
 N.P.P.D., R.A.D.




GENERAL CONCRETE NOTES & MISCELLANEOUS  
 DETAILS SEE DWG. 4226.


DIMENSIONS & LOCATION OF ROOF SLAB  
 CONDITIONS NOT NOTED SEE DWG. 4177

EXAMINER SHALL EXAMINE THIS DRAWING FOR ITEMS  
 PART OF CONTRACT E-69-28, ESSENTIALLY  
 AND REFINE FOR CONSTRUCTION



FLOOR PLAN @ ELEVATION 932' - 6"





FOR CABINET & EQUIPT.  
SEE DWG. M-81

FOR CABINETS & EQUIPT.  
SEE DWG. M-81

FIGURE 2

(EXTRACTED FROM B&R  
DWG. 45-26)

DWLC. APP1-584-007



3/21/68

SH. 55/68

ST AIRCURE CARD

Also Available On  
Aperture Card

STAIR. NO. 3-10  
SEE DWG. 4552



4 EL


# ELEVATION "C2"

57/68

SCALE: 1/8" = 1'-0"

NPM-58φ-007

EA *[Signature]*



# SECTION F2

SCALE: 1/2" = 1'-0"

FIGURE 3b  
DWG 4526

EA/1/4




FIGURE 3a

DWG. 4526

SECTION





SCALE: 1/2" = 1'-0"

CALC. NPPA-584-007






SK (11) SH. 58/68

FIGURE 4



665.2 W

FIRE ALARM PANEL



NOTE: LOADS ARE INDICATED FOR THOSE PANELS WITH UNINTERRUPTIBLE POWER SUPPLIES. SEE ATTACHMENT V. ANNUNCIATOR LIGHTING WOULD BE ACTIVE ON ALL PANELS.

COMPUTER & CONTROL ROOMS  
FLOOR PLAN  
EL. 932'-6"

COOPER NUCLEAR STATIC  
APPENDIX "R"  
CIRCUIT SEPARATION

Also Available On  
Aperture Card  
SI  
APERTURE  
CARD

alpha/beta - 42



JOB NO. NP-110 DATE 12/6/89  
PROJECT CNS STATION BLACKOUT  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR E. Williams  
REVIEWER (1) 4/ APPROVED \_\_\_\_\_  
CALCULATION NO. NPPT - SBR - 007





FIGURE 5

SCHEMATIC OF CNS CONTROL ROOM ANALYTICAL MODEL  
FOR CONTEMP-LT/028 COMPUTER CODE



JOB NO. NP-110 DATE 12/6/89  
 PROJECT CNS STATION BLACKOUT  
 SUBJECT CONTROL ROOM HEATUP  
 CLIENT NPPD ORIGINATOR E Holcomb  
 REVIEWER [Signature] APPROVED \_\_\_\_\_  
 CALCULATION NO. NPPI-5BQ-007

$$T = 90^{\circ}F = \text{CONST.}$$

COORDINATE

✓ 17.1042'

LARGE HEAT TRANSFER COEFFICIENT  
 $(h = 10^4)$

CONCRETE SLAB

NOTE: FIGURES 3a & 3b,  
 FROM DWG. 4526, ARE  
 THE BASIS FOR THIS  
 HS MODEL. ALSO SEE  
 ATT. I.





FIGURE 6

CNS CONTROL ROOM CEILING and ROOF HEAT STRUCTURE (HS)  
 MODEL FOR CONCEPT-LT/028 HS2





JOB NO. NP-110 DATE 12/6/89  
PROJECT CNS STATION BLACKOUT  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR E. Holcomb  
REVIEWER JH APPROVED \_\_\_\_\_  
CALCULATION NO. NPP1-580-007

NORTH WALL (REF: DWG. 4526 and FIG. 8)




FIGURE 7


NORTH WALL HEAT STRUCTURE MODEL (HS1) FOR  
CONTEMPT-LT/028

# FLOOR PLAN - CONTROL B

SCALE: 1/3" = 1'-0"

NPP1 - 586 - 007

EX 1.0 62/68




DETAIL NO. 10 (FROM B&R DWG. 4526)

SCALE: 3/8" = 1'-0"

BY	ELEC. ENG.	MECH. ENG.	CIVIL ENG.	PROJ. ARCH	REV. NO.	REVISION
						1
2	11/1/70	11/11/70		11/7/70	2	ISSUED APPROVED FOR CONSTRUCTION FOR CONTRACT E-69
FTS	A.A. Villani / ER			11/10/69		

FIGURE 8



JOB NO. NP-110 DATE 12/2/89  
PROJECT CNS STATION BLACKOUT  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR E. Talbot  
REVIEWER PP APPROVED \_\_\_\_\_  
CALCULATION NO. NPP1-SBQ-007

SOUTH WALL

(RE: DWG. 4526)





FIGURE 9

SOUTH WALL HEAT STRUCTURE MODEL (HS4)  
FOR CONTEMPT - LT/028



JOB NO. NP-110 DATE 12/2/89  
PROJECT CNS STATION BLACKOUT  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR E. Holcomb  
REVIEWER [Signature] APPROVED \_\_\_\_\_  
CALCULATION NO. NPPD-580-007

EAST WALL

(RE: Dwg. No. 4526 &amp; Detail 10)





FIGURE 11

EAST WALL HEAT STRUCTURE MODEL (H56)  
FOR CONTEMPT - LT/028



JOB NO. NP-110 DATE 12/7/89  
PROJECT CNS STATION BLACKOUT  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR E. Holcomb  
REVIEWER [Signature] APPROVED \_\_\_\_\_  
CALCULATION NO. NPPI-SBB-007

FLOOR

(RE: Dwg. No. 4175)





FIGURE 12

FLOOR HEAT STRUCTURE MODEL (HS3)  
FOR CONTEMPT-LT/028

# CNS CONTROL ROOM HEATUP ANALYSIS

LEAKAGE FROM CNTRL. ROOM TO ADJ. AREAS




89/79  
NPP-580-007  
H. H.

FIGURE 13

# CNS CONTROL ROOM HEATUP

CALCULATION NPP1-SB0-007



TIME (HOURS)  
— TAIR

FIGURE 14

NPP1-SB0-007  
89/89  
8/8

AIR TEMPERATURE (DEGF)

JOB NO. NP-110 DATE 11/30/89  
PROJECT CNS STATION BLACKOUT (SBO)  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR E. Holcomb  
REVIEWER L. G. G. G. APPROVED \_\_\_\_\_  
CALCULATION NO. NPP1-SBO-007

ATTACHMENT 1  
OF  
NPP1-SBO-007

DEVELOPMENT OF HEATING-6  
ONE DIMENSIONAL THERMAL MODEL  
OF THE  
COOPER NUCLEAR STATION  
CONTROL ROOM CEILING AND CONCRETE ROOF



JOB NO. NP-110 DATE 11/30/89  
PROJECT CNS STATION BLACKOUT (SBO)  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR E. W. Wierant  
REVIEWER [Signature] APPROVED \_\_\_\_\_  
CALCULATION NO. NPP1-SBO-007

## I. PURPOSE

The purpose of this attachment is to develop a one-dimensional geometric representation of the control room ceiling and concrete roof structures for implementation into the HEATING-6 computer code, in order to determine the steady state temperature of the ceiling and roof structures. A constant control room air temperature, consistent with an air conditioned space, is assumed in addition to a conservative periodic exterior temperature and solar heat flux. The resultant temperatures will be used as initial structure temperatures in the SBO control room heat-up analysis in order to increase modeling accuracy and eliminate excess computer time.

## II. METHODOLOGY

The HEATING-6 computer code is a multidimensional heat conduction code using the finite difference formulation (Reference 3). It can be used to solve steady-state and/or transient problems of one to three dimensions in various coordinate systems. HEATING-6 code input models can be basically categorized into 3 sections - geometric input, boundary conditions, and code options. Geometric input is concerned with the physical configuration, dimensions of the system and constituent materials. Boundary conditions are used to apply radiative and convective heat transfer and define temperature conditions, all of which can vary with time, temperature or position.

Code options are mainly related to input and output requirements. Geometric input is discussed in Section IV, boundary conditions in Section V, and code options in Section VI.

The HEATING-6 code output is included as Attachment II and includes a printout of the input deck. Input values listed here have been converted to units of BTUs, hours, feet and degrees Fahrenheit in the input deck.

### III. ASSUMPTIONS

Referring to Fig. I-1, I-2a and I-2b, the following modelling approach and key assumptions were employed when developing the HEATING-6 thermal model:

- A. The thermal model represents the following structures:
  - 1. Interior control room ceiling materials
  - 2. Concrete slab roof and insulation
  - 3. Air space between the control room ceiling and roof slab
  - 4. The luminous ceiling units, in the control room proper, are not modeled because they do not greatly impede vertical movement of air in the control room volume.
  - 5. The wire hangers and carrier channels which support the suspended control room ceiling will not be modeled for simplicity.
  
- B. Inherent in the one-dimensional geometry for the HEATING-6 thermal model, it is assumed that there is no horizontal heat transfer in any of the materials or air spaces. Neglecting end effects is a reasonable assumption considering the size of the building roof area covering the control room (see Fig. I-1, extracted from Reference 11).
  
- C. The control room is air conditioned and is assumed to have a normal operating, constant bulk air temperature of 23 degrees C (73.4 degrees F).

- D. Convective heat transfer in the air space above the acoustic tile room ceiling to the concrete roof is not included, which is conservative. This is implemented to ensure that roof structure temperatures are conservative. (Natural convection can be reasonably expected to occur in this zone and is included in the CONTEMPT-LT/028 model of the air space).
- E. Heat is transferred across the air space between the control room ceiling and the concrete slab roof by radiative exchange.
- G. The exterior temperature is sinusoidal and based on ASHRAE 1% design temperature values for Omaha, Nebraska.
- H. Solar heat flux is from NOAA's Monthly Summary Solar Radiation Data for Omaha, Nebraska on June 19, 1977. No credit is taken for shading of the Control Bldg. roof by adjacent structures. The Reactor Bldg., adjoining and immediately to the south, is 100 feet higher, for example.
- I. The roof response was computed for a four-day duration prior to SBO occurrence in order to obtain a steady periodic solution.

IV. HEATING-6 THERMAL MODEL GEOMETRIC INPL.

Cross sectional drawings of the areas of interest are presented in Figures 1-2a and 2b. These figures (extracted from Reference 11) list the interior structural dimensions and materials. Figure 1-3 (extracted from Reference 12) details the concrete slab thickness. Details of the roof slab insulation and waterproofing are from Attachments IV and V.

A. MATERIAL DIMENSIONS

Acoustic Ceiling Tile

The thermal model represents a one-dimensional slice beginning at the bottom of the acoustic ceiling tile which is in contact

with the control room air volume. Because no dimensions are given for the tile thickness, a thickness of 3/4 inch will be assumed from scaling of the original drawing. This dimension is consistent with actual measurements of samples of acoustic tile.

#### Gypsum Board

Above and in direct contact with the tile is a 1/2 inch thick gypsum board. It will be assumed for simplicity that the tile and board are in perfect contact and that there is no paper covering on the gypsum board.

#### Dry Air

Between the gypsum board and the concrete roof slab is an air space of 2 feet 9 and 3/4 inches.

#### Concrete

As presented in Figure I-3a, the concrete roof slab has a minimum thickness of 2 feet and a maximum thickness of 2 feet 4 and 1/2 inches. An average thickness of 2 feet 2 and 1/4 inches is used in the model.

#### Firestone ISO 95 Roof Insulation

The Firestone ISO 95 roof insulation has a thickness of 2 and 5/8 inches per Attachment IV.

#### Asphalt Waterproofing

The insulation is covered by a waterproofing material of asphalt. The asphalt is assumed to be 3/8 inch thick. The concrete roof slab, insulation and waterproofing are assumed to be in perfect contact with each other.

The upper surface of the waterproofing is the upper boundary of

24 11 23 I-6/23  
NPPA-58φ-007

the model and is in contact with the atmospheric temperature and solar radiation.

## B. MATERIAL THERMAL PROPERTIES

### Acoustic Ceiling Tile

The tile is assumed to be mineral fiberboard, wet molded acoustical tile. Thermal physical properties are: (Reference 5, Table 3A p. 22.15 @ 75 degF)

Density = 23 lb/cu ft

Thermal Conductivity = 0.42 BTU-in/hr-sq ft-degF

Specific Heat = 0.14 BTU/lb-degF

### Gypsum Board

Thermal properties are for gypsum board

Density = 51 lb/cu ft

(at 99 degF Reference 13, Table 3 p. 4-63)

Thermal Conductivity = 0.062 BTU/hr-sq ft-degF/ft

(at 99 degF Reference 13, Table 3 p. 4-63)

Mean Specific Heat = 0.259 BTU/lb-degF (Gypsum)

(between 32 and 212 degF Reference 13, Table 17 p. 4-9)

### Dry Air

The thermal properties of dry air at one atmosphere are from Reference 6, Table A.7 p.565. Since the density and thermal conductivity of air vary with temperature to a greater degree than the other materials, values for temperatures from 60 to 180

I-7/23  
NPP1-58d-007  
EPL

degrees Fahrenheit are given.

Density (lbm/cu ft) =

0.07633 (60 degF)	0.06614 (140 degF)
0.07350 (80 degF)	0.06401 (160 degF)
0.07087 (100 degF)	0.06201 (180 degF)
0.06843 (120 degF)	

Thermal Conductivity (BTU/hr-ft-F) =

0.01466 (60 degF)	0.01664 (140 degF)
0.01516 (80 degF)	0.01712 (160 degF)
0.01566 (100 degF)	0.01759 (180 degF)
0.01615 (120 degF)	

Specific Heat Cp = 0.24 BTU/lb-F (60 to 180 degF)

Kinematic Viscosity (sq ft/hr) =

0.5685 (60 degF)	0.7316 (140 degF)
0.6078 (80 degF)	0.7747 (160 degF)
0.6482 (100 degF)	0.8187 (180 degF)
0.6895 (120 degF)	

Prandtl Number =

0.712 (60 degF)	0.700 (140 degF)
0.709 (80 degF)	0.698 (160 degF)
0.706 (100 degF)	0.696 (180 degF)
0.703 (120 degF)	

### Concrete

Thermal properties are for sand and gravel concrete

Density = 142 lb/cu ft

(at 75 degF Reference 13, Table 3 p. 4-63)

Thermal Conductivity = 1.05 BTU/hr-sq ft-degF/ft

(at 75 degF Reference 13, Table 3 p. 4-63)

I-8/23  
EPA NPP1-5B4-007

Mean Specific Heat = 0.156 BTU/lb-degF (Concrete)  
(between 32 and 212 degF Reference 13, Table 17 p. 4-9)

Firestone ISO 95 Roof Insulation

Firestone ISO 95 consists of a polyisocyanate (urethane) foam matrix containing Freon R-11 gas (Attachment IV)  
Thermal properties are:

Density = 1.9 lb/cu ft  
(Attachment IV)

Thermal Conductivity = 0.131 BTU-in/hr-sq ft-degF  
(Attachment IV)

Mean Specific Heat = 0.38 BTU/lb-degF  
for Expanded Polyurethane (R-11 exp.) for aged stock  
(Reference 5, Table 3A p. 22.14 @ 75 degF)

Asphalt Waterproofing

The waterproofing material is assumed to be 0.375 inch built-up roofing asphalt (Attachment IV). The thermal physical properties are (Reference 5, Table 3A p. 22.16 @ 75 degF)

Density = 70 lb/cu ft

Thermal Conductance (C) = 3.00 BTU/hr-sq ft-degF

Specific Heat = 0.35 BTU/lb-degF

## V. HEATING-6 THERMAL MODEL BOUNDARY CONDITIONS

I-9/23  
NPP1-5B0-007

EA

### A. INITIAL CONDITIONS

The analysis is started just before sunrise on the first day (time = 4.56hrs) and temperatures for the various structures were initially assumed to range from 73.4 to 100 degrees F. These initial temperature estimates need only be the approximate temperatures that the structures would have in order to initialize the HEATING-6 run and to reduce the computational time required to reach a steady periodic solution.

### B. BOUNDARY CONDITION #1

This boundary condition represents the atmospheric conditions to which the outer surface of the control building is exposed. It consists of a 24 hour periodic change in air temperature, varying solar radiation, and convective air currents. In the HEATING-6 thermal model, this boundary condition is applied to the top surface of the waterproofing as a surface to boundary condition.

#### 1. AIR TEMPERATURE

Air temperature is based on data from "Table 1 - Climatic Conditions for the United States" of Chapter 23 of ASHRAE (Reference 5) and is discussed in more detail in the main body of the calculation, Section 3.1.

Values for the outside air temperature are entered into the HEATING-6 input deck as a function of time in Table 3 of the deck (Attachment II). A temperature value for each hour starting at midnight (time=0) and ending after 4 days was calculated using a sinusoidal equation with a maximum temperature of 94 degrees F and minimum temperature of 76 degrees F; the minimum is assumed to occur at time = 5 hrs, just after sunrise.



I-10/23

NPP1-5Bφ-007

EH

$$T = 85. + 9. \times \sin(\text{PI}/12. \times (t - 11.))$$

where: T = Temperature (degrees F)

t = Time (hours, based on 24-hr cycle)

$$\text{PI} = 3.14159$$

## 2. SOLAR RADIATION

Solar radiative heat flux data from NOAA's "Monthly Summary Solar Radiation Data" for Omaha, Nebraska (Reference 9, Attachment III) are entered into the HEATING-6 deck (Attachment II) as a function of time via the subroutine "BNFLUX". The digitization procedure results in a value approximately 10% conservative on the integrated daily heat flux. Added discussion for using NOAA data is also provided in Section 3.2 of the main body of this calculation. See that section regarding choices of roof absorptivity, emissivity and the treatment of heat losses to the sky.

## 3. CONVECTIVE HEAT TRANSFER

Heat transfer from the upper surface of the control building roof to the atmosphere by convection was estimated using Table 11 p. 22.26 of ASHRAE (Reference 5). For a flat horizontal surface of 4 sq. ft. or more facing upward and a 50 degree temperature differential with the air, the heat transfer coefficient (h) is equal to:

$$h = 2.03 \text{ BTU/hr-sq ft-degF}$$

Although the temperature difference can be greater than 50 degrees for much of the time, a smaller, estimated value of 'h' will be used for conservatism:

$$h = 1.00 \text{ BTU/hr-sq ft-degF}$$

and entered into the input deck as a forced convection heat transfer coefficient. Although input using the code's forced convection option, no credit is actually taken for the

cooling effect of winds on the roof. The value of 'h' used should result in an underestimate of convective heat losses from the surface, thus introducing conservatism into the calculated roof temperatures.

C. BOUNDARY CONDITION #2

This boundary condition represents the heat transferred between the top surface of the gypsum board and the bottom surface of the concrete roof slab by radiation. In the HEATING-6 thermal model, this boundary condition is applied as a surface-to-surface boundary condition. For conservatism, no convective heat transfer was assumed to occur. Again, this contributes to an overcalculation of the roof temperatures in the initialization procedure.

1. RADIATIVE HEAT TRANSFER

For two parallel infinite slabs, the shape factor (SF) for radiation from surface 1 to surface 2 is:

$$SF_{1-2} = \frac{1}{1/e_1 + 1/e_2 - 1}$$

where:

$e_1$  = emissivity of concrete  
= 0.94 (Reference 8)

$e_2$  = emissivity of gypsum board  
= 0.90 \*

$$SF_{1-2} = 0.85$$

\* This value was estimated since the details of the gypsum board covering is uncertain; it was assumed to be paper.

I-12/23  
NPP1-580-007

The radiative heat transfer coefficient  $h_R$  entered into HEATING-6 input deck is the product of the shape factor and the Stefan-Boltzman constant:

$$h_R = (0.85) (0.1714E-08 \text{ BTU/hr-sq ft-degR}^{**4})$$

yielding:

$$h_R = 1.4588E-09 \text{ BTU/hr-sq ft-degR}^{**4} .$$

#### D. BOUNDARY CONDITION #3

This boundary condition represents the interface of the bottom of the acoustic ceiling tile and the constant temperature control room air. This is modeled as a surface to boundary condition and is applied to the bottom surface of the acoustic tile. No radiative heat transfer was modeled. The boundary condition consists only of a constant 73.4 degree F boundary temperature and a constant, estimated heat transfer coefficient of 1.0 Btu/hr-ft\*\*2-degf. Considering that natural convective correlations yield values of 'h' of approximately 0.5 for the large horizontal surfaces in the control room, a value of 1.0 in the presence of a forced air system appears reasonable.

#### VI. HEATING-6 THERMAL MODEL CODE OPTIONS

Code input and output options are described in detail in Reference 3. A few of the code options are presented here in order to clarify the analysis. The HEATING-6 code output deck is presented in Attachment II.

The calculated results were written to the output file at every timestep, per the third entry on the third card in the input deck, and per Section F10.5.5.3 of Reference 3.

TRANSIENT PARAMETERS - The problem was solved with the transient calculation option using the Crank-Nicolson implicit solution scheme per the "TRANSIENT PARAMETERS" card(s):

- initial time step = 0.5 sec.
- T. S. multiplier factor = 1.1
- minimum time step = 0.01 sec.

The above selections are explained on page F10.5.35 of Reference 3. The automatic time step features of the code have also been invoked. A maximum change of 1% is allowed in the temperature at any given node before time step size is decreased. The code default options have been used for convergence criteria.

PRINTOUT TIMES - hardcopy output was provided for selected intervals in order to facilitate comparisons of calculated temperatures to the individual nodes.

NODES MONITORED - the nodes monitored, indicated in Att. II, determine which areas of the thermal model are selected for temperature monitoring. Figure I-4 is a "MAP OF THE NODE NUMBERS", depicting all the nodes in the model along with their coordinates. The "NODES MONITORED" were limited to eleven to simplify data processing, but this parameter allowed for sufficient temperature monitoring.

## 5.0 ANALYSIS RESULTS


Results of the 96 hour thermal response analysis are plotted in Figure I-5. It is apparent that the maximum temperatures for the ceiling and roof structures have been reached and that a periodic steady state has been achieved. The roof surface temperature is characterized by periodic heatup in response to the daily solar load, accompanied by cooldown at night as a result of radiative cooling to the sky. The black asphalt surface gets very hot, perhaps moreso than would be expected. This is due to conservatism in the model. Inner layers of the roof are heated substantially less due to the thermal mass of the

EH *AS* I-14103  
NPP1-580-007

concrete and the protection afforded by the ISO-95 insulation. The results of this analysis provide the basis for the roof boundary conditions in the control room volume analysis using the CONTEMP-LT/02B code.

Figure I-6 is a page from the HEATING-6 output deck which illustrates the node temperatures for Time = 84 hours (4th day at Noon). Figure I-7, plotted on an expanded scale, illustrates the roof response for the last 36 hours of the simulation. Steady state is indicated. A value of 90 degrees F is considered a bounding value for the surface temperature at the top of the concrete layer and one which accounts for variations in the solar insolation and ambient temperature.

I-15/23  
 NPP1-580-007  
 E.H. D.



FLOOR PLAN - CONTROL BLDG. - EL. 932'-6"

FIGURE I-1  
 FROM DWG. 4526

I-16/23  
 NPP-580-007  
 E.H. D.S.





FIGURE I-22  
 DWG. 4526

SECTION E<sub>2</sub>  
 SCALE: 1/2" = 1'-0"

# ELEVATION "C2"

SCALE: 1/8" = 1'-0"

I-17/23  
NPP-580-007  
ET J




# SECTION (F2)

SCALE: 1 1/2" = 1'-0"

FIGURE I-2b  
DWG 4526





PLAN  
CONTROL BUILDING @ EL. 949.15'  
ROOF SLAB REINFORCING.

SCALE 1/8" = 1'-0"  
 SLAB THICKNESS = 2" MIN.  
 SLAB FINISH = G.A. @ TOP OF SLAB  
R.T. @ BOTTOM OF SLAB  
 LIVE LOAD = 20 PSF

FIGURE I-3 FROM DWG 4176

#11 @ 6" E.W., E.F.

TYP. KEY  
3 SIDES

DWG. # 2011  
1/26

I-19/23  
NPP1-580-007  
EX 2/2

# SECTION 500-500

SCALE: 1/4" = 1'-0"




Figure I-3a  
(from DWG. 4176)

# SECTION 501-501

SCALE: 1/4" = 1'-0"

BY	CHKD	APP	DATE	REV. NO.	REVISION	
				14	ADDED HUNG LOAD TO PLAN.	R.
ON PLAN	ZAB	WG	1/16	13	69-23	17
	ZAB	SA	1/16	12	DELETED COVERED ANCHOR SLOT, REV'D SECT. 296	15
D LOUVERS SECTS 500 & DHW SECT 3ED NOTE FOR T. 500.	EHD	RCW		3	ADDED REGLET RETURN IN NORTH WALL SECT 532	EH
				1	REVISED NOTES IN PLAN SECT 291-297 FLOOR 2 & H	
				5	REMOVED COVERED ANCHOR ON PLAN, & REV'D & SPEC SECT. 296-296 ADDED HUNG LOAD TO PLAN	✓

I-20/23  
 NPP1-5Bφ-007

IRM3033/ 0  
 20.57.54 11-16-89

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
 MAP OF THE NODE NUMBERS

HEATING6 02/12/83  
 W9XNP110

GROSS GRID	FINE GRID	DISTANCE	DESCRIPTION
1	1	0.0	CONTROL ROOM AIR SPACE BC #3
2	1	0.03	ACOUSTIC CEILING TILE
3	1	0.06	GYPSUM BOARD
4	1	0.08	
5	1	0.10	
6	1	0.57	AIR SPACE BC #2
7	1	1.04	
8	1	1.51	
9	1	1.98	
10	1	2.45	
11	1	2.92	
12	1	3.14	
13	1	3.35	
14	1	3.57	
15	1	3.79	CONCRETE
16	1	4.01	ROOF SLAB
17	1	4.23	
18	1	4.45	
19	1	4.67	
20	1	4.89	
21	1	5.10	
22	1	5.18	150 9.5 INSULATION
23	1	5.25	
24	1	5.32	WATERPOOFING ASPHALT
25	1	5.35	
ND			OUTDOOR AIR
ND			ATMOSPHERE BC #1


○ - NODE TEMPERATURE MONITORED AT EACH TIMESTEP

ERT  
 W

FIGURE I-4  
 FROM ATT. II

# CNS CONTROL ROOM ROOF TEMPERATURE

1-D CNST. C.R. TEMP 73F - ACT'L SOL Q



□ BOT TILE      + TOP GYP      ◇ BOT CON      × TOP CON      ▽ TOP ROOF  
 BOTTOM OF      TOP OF      BOTTOM OF      TOP OF      TOP OF  
 ACOUSTIC TILE      GYPSUM BOARD      CONCRETE ROOF      CONCRETE ROOF      ROOF  
 (CONTROL RM AIR)

FIGURE I-5

I-21/23  
 NPP1-580-007  
 EOT  
 [Signature]

I-22/23

NPP-5B0-007

ISL JS

18M2033/ 0 11-16-89  
20 58 29

HEATING 02/12/83  
WBXMP110  
COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 1031 TIME STEPS, TIME = 8.400000+01

GROSS GRID	FINE GRID	DISTANCE	TEMPERATURE
1	0	0	75180
2	0	0.03	77104
3	0	0.06	60108
4	0	0.08	60189
5	0	0.10	61169
6	0	0.57	82113
7	1	0.4	82157
8	1	1.51	82199
9	1	1.98	83141
10	2	2.45	83183
11	2	2.92	84123
12	3	3.14	84111
13	3	3.35	85116
14	3	3.57	85157
15	4	4.01	85195
16	4	4.23	86129
17	4	4.45	86162
18	4	4.67	86197
19	4	4.89	87138
20	5	5.10	87196
21	5	5.18	120181
22	5	5.25	153185
23	5	5.32	188175
24	5	5.35	191151
25	5	5.35	191151

CONTROL ROOM AIR  
 ACOUSTIC CEILING TILE  
 GYPSUM BOARD  
 AIR SPACE  
 CONCRETE  
 ROOF SLABS  
 150 95 INSULATION  
 ASPHALT WATERPROOFING  
 ATMOSPHERE  
 TEMPERATURES ON NUMBERED BOUNDARIES

TEMP. 191.51 °F  
 EXAMPLE, 191.51 °F  
 THE CURRENT TIME STEP (DELTA) = 1.658146040-01  
 ELAPSED CPU TIME IS 12.41 SECONDS


THE MAXIMUM TEMPERATURE IS - 1.915050+02 (+-0.1 PERCENT)  
 MAX. TEMP. APPEARS AT NODES - 25  
 THE MINIMUM TEMPERATURE IS - 7.580000+01 (+-0.1 PERCENT)  
 MIN. TEMP. APPEARS AT NODES - 1

FIGURE I-6  
FROM ATT. II

PCC

# CNS CONTROL ROOM ROOF TEMPERATURE


1-D CONST. C.R. TEMP 73F - ACT'L SOL G



ENLARGED SECTION OF FIGURE I-5

FIGURE I-7

I-23/23  
APP1-588-007  
EAK



JOB NO. NP-110 DATE 12/12/89  
PROJECT CNS STATION BLACKOUT  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR E. Wilcomb  
REVIEWER [Signature] APPROVED \_\_\_\_\_  
CALCULATION NO. NPPD-SBQ-007

ATTACHMENT II

HEATING-6 CODE OUTPUT DECK

for the

ONE-DIMENSIONAL HEATING-6 THERMAL MODEL

```

** I B M ** ..... ** I B M **
** I B M ** ..... ** I B M **
** I B M ** ..... ** I B M **

```

```

RRRRRRRRRR 444 HH HH NN NN KK KK 00000000 00000000 00000000
RRRRRRRRRR 4444 HH HH NN NN KK KK 0000000000 0000000000 0000000000
RR RR 44 44 HH HH NN NN NN NN KK KK KK 00 00 00 00 00 00 00 00
RR RR 44 44 HH HH NN NN NN NN KK KK KK 00 00 00 00 00 00 00 00
RR RR 44 44 HH HH NN NN NN NN KK KK KK 00 00 00 00 00 00 00 00
RRRRRRRRRR 444444444444 HHHHHHHHHHHH NN NN NN KKKKKKKK
RRRRRRRRRR 444444444444 HHHHHHHHHHHH NN NN NN KKKKKKKK
RR RR 44 HH HH NN NN NN NN KK KK 0000 00 0000 00 0000 00
RR RR 44 HH HH NN NN NN NN KK KK 000 00 000 00 000 00
RR RR 44 HH HH NN NN NN NN KK KK 0000000000 0000000000 0000000000
RR RR 44 HH HH NN NN NN NN KK KK 00000000 00000000 00000000

```

```

JJJJJJJJJJ BBBB888888 00000000 BBBB888888 777777777777 AAAAAAAAAA
JJJJJJJJJJ BBBB8888888888 0000000000 BBBB8888888888 777777777777 AAAAAAAAAA
JJ 88 88 00 0000 88 88 77 77 AA AA
JJ 88 88 00 00 00 88 88 77 AA AA
JJ 88 88 00 00 00 88 88 77 AA AA
JJ BBBB8888 00 00 00 BBBB8888 77 AA AA
JJ BBBB8888 00 00 00 BBBB8888 77 AA AA
JJ 88 88 00 00 00 88 88 77 AA AA
JJ 88 88 0000 00 88 88 77 AA AA
JJ 88 88 000 00 88 88 77 AA AA
JJJJJJJJJJ BBBB8888888888 0000000000 BBBB8888888888 77 AA AA
JJJJJJJJ BBBB8888888888 00000000 BBBB8888888888 77 AA AA

```

*HEATING - 6*  
*11/16/89*  
*not measured flux*

```

DDDDDDDDDD PPPPPPPPPP LL XX XX
DDDDDDDDDD PPPPPPPPPP LL XX XX
DD DD PP PP LL XX XX
DD DD PP PP LL XX XX
DD DD PP PP LL XXXX
DD DD PPPPPPPPPP LL XXXX
DD DD PP LL XX XX
DD DD PP LL XX XX
DD DD PP LL XX XX
DD DD PP LL XX XX
DDDDDDDDDD PP LLLLLLLLLLLL XX XX
DDDDDDDDDD PP LLLLLLLLLLLL XX XX

```

```

** I B M ** START JOB E087 R4HNK000 FX2046 AI2045 ROOM -B54 15 58 53 - 89 321 - PR13 - SYSOUT = A ** I B M **
** I B M ** START JOB B087 R4HNK000 FX2046 AI2045 ROOM -B54 15 58 53 - 89 321 - PR13 - SYSOUT = A ** I B M **
** I B M ** START JOB B087 R4HNK000 FX2046 AI2045 ROOM -B54 15 58 53 - 85 321 - PR13 - SYSOUT = A ** I B M **

```

```

***** JES2 NEWS BULLETIN *****
* ABEND-A1D WAS UPGRADED TO RELEASE 5.4, WHICH INCLUDES MAJOR ENHANCEMENTS TO ABEND DIAGNOSTICS. MANUALS MAY BE ORDERED FROM *
* COMPUWARE. *
* QUESTIONS? CALL POWER COMPUTING IBM CUSTOMER SUPPORT AT 1-800-527-6003 *
*****

```



```

1 //W9XHP110 JOB HE66VHRK , 'EMERCON' , CLASS='Z' , TIME=10
***JOBPARM ROLING
*** $ACFJ219 ACF2 ACTIVE POWER1 BHRK0001 A12045
***INFO
***PASSWORD $ACFJ201 ACF2 CONTROL CARD SUCCESSFULLY SCANNED
***LOGOMID $ACFJ201 ACF2 CONTROL CARD SUCCESSFULLY SCANNED
***JOBPARM LINES=90 , CARDS=0

```

```

2 //COMPILE EXEC FORTXC , PARM=LIST
3 XXFORTXC PROC FXPGM=IFEAB , FXREGN=512K , FXPDECK=NODECK , FXPOLST=NOLIST ,
FXPOP1=0 , FXTERM= , SYSOUT= , FXLNSPC=3200 , (25 , 6)

```

PARAMETER	DEFAULT VALUE	USAGE	COMPILER NAME
FXPGM	IFEAB		FORT-STEP REGION
FXREGN	256K		COMPILER DECK OPTION
FXPDECK	DECK		COMPILER LIST OPTION
FXPOLST	NOLIST		COMPILER OPTIMIZATION
FXPOP1	0		FORT SYSTEM OPERAND
FXTERM	,		FORT SYSLIN SPACE
FXLNSPC	3200 , (25 , 6)		

```

4 XXFORT EXEC PGM=FXPGM , REGION=FXREGN , COMD={4 , 11} ,
IEF6531 SUBSTITUTION JCL - PGM=IFEAB , REGION=512K , COND={4 , 11} ,
PARM={ , FXPDECK , FXPOLST , OPT1&FXPOP1} ,

```

```

5 IEF6531 SUBSTITUTION JCL - PARM= , NODECK , NOLIST , OPT1{0} ,
XXSTEPLIB DD DSN=SYS1.FORTXC.DISP=SHR
6 XXSYSPRINT DD SYSOUT= , DCB=BLKSIZE=996
7 XXSYSTEM DD &XTERM
8 IEF6531 SUBSTITUTION JCL - SYSOUT= ,
9 XXSYSUT1 DD UNIT=SYSSO , SPACE={3465 , (3 , 3)} , DCB=BLKSIZE=3465
10 XXSYSUT2 DD UNIT=SYSSO , SPACE={2048 , (10 , 10)}
11 XXSYSPLNCH DD SYSOUT=B , DCB=BLKSIZE=3440
12 XXSYSLIN DD DSN=BLKLOADSET , DISP=(MOD , PASS) , UNIT=SYSSO ,
SPACE={8&FXLNSPC} , DCB=BLKSIZE=3200
13 IEF6531 SUBSTITUTION JCL - SPACE={3200 , (25 , 6)} , DCB=BLKSIZE=3200
14 //FORT , SYSIN DD *
// EXEC FORTXLG , PARM='MAP , LIST' , GOREGN=900K
XXFORTXLG PROC LKLNDD='DDNAME=SYSIN' , GDOPGM=MAIN , GOREGN=100K ,
GOF500='DDNAME=SYSIN' , GDF600='SYSOUT= ' ,
GOF700='SYSOUT=B'

```

PARAMETER	DEFAULT VALUE	USAGE
LKLNDD	DDNAME=SYSIN	LKED , SYSIN OPERAND
GOPGM	MAIN	OBJECT PROGRAM NAME
GOREGN	100K	GO-STEP REGION
GOF500	DDNAME=SYSIN	GO F105F001 OPERAND
GOF600	,	GO F106F001 OPERAND
GOF700	,	GO F107F001 OPERAND

```

15 XLKLED EXEC PGM=IEWL , REGION=256K , COMD={4 , 11} ,
PARM='LET , LIST , MAP , XREF'
16 XXSYSPRINT DD SYSOUT=
17 //LKED , SYSLIB DD DSN=KCSO , QA HEAT6 V05B4 SCALE2 , SUBLIB , DISP=SHR
X/SYSLIB DD DSN=SYS1.FORTLIB , DISP=SHR
DD DSN=SYS1.FORTLIB , DISP=SHR
// DD DSN=KCSO , QA HEAT6 V05B4 SCALE2 , DAKRIDGE LIB , DISP=SHR
DD UNIT=SYSDA , SPACE={1024 , (200 , 20)}
18 XXSYSUT1 DD DSN=BLKLOADSET(BGOPGM) , DISP={ , PASS} , UNIT=SYSDA ,
19 XXSYSIMOD DD DSN=BLKLOADSET(BGOPGM) , DISP={ , PASS} , UNIT=SYSDA ,
20 IEF6531 SUBSTITUTION JCL - DSN=BLKLOADSET(MAIN) , DISP={ , PASS} , UNIT=SYSDA ,
21 SPACE={TRK , (10 , 10)}
XX DD BLKLOAD
22 XXSYSLIN DD BLKLOAD
IEF6531 SUBSTITUTION JCL - DDNAME=SYSIN
DD DSN=BLKLOADSET , DISP={ , PASS}

```

```

+00000001
00000002
00000003
00000004
00000005
00000006
00000007
00000008
00000009
00000010
00000011
00000012
00000013
00000014
00000015
00000016
00000017
00000018
00000019
00000020
00000021

```

24	//HT6 DD DSN=SCSD QA HEAT6 V0584 NEWHEAT HT60E ., DISP=SHR	
25	//LKED SYSIN DD *	
26	XXGD EXEC PGM=*. LKED.SYSLMOD,REGION=8GBREGN.COMD=(4,LT)	00000022
	IEF653I SUBSTITUTION JCL - PGM=*. LKED.SYSLMOD,REGION=900K,COMD=(4,LT)	
27	//GO FT05F001 DD *	
	X/FT05F001 DD 8G0F500	00000023
	IEF653I SUBSTITUTION JCL - DDNAME=SYSIN	
28	XXFT06F001 DD 8G0F600	00000024
	IEF653I SUBSTITUTION JCL - SYSOUT=*	
29	XXFT07F001 DD 8G0F700	00000025
	IEF653I SUBSTITUTION JCL - SYSOUT=B	
30	//GO FT05F001 DD UNIT=SYSDA,SPACE=(TRK,(20,10)).	
	// DCB=(RECFM=VBS,LRECL=X,BLKSIZE=3156,BOFL=4088)	
31	//GO FT06F001 DD SYSOUT=*	



```

IEF285I VOL SER NOS= LBOCS3.
IEF285I SYS89320.T205706.RA000.W9XNP110.R0000003 DELETED
IEF285I VOL SER NOS= WORK32.
IEF285I SYS89320.T205706.RA000.W9XNP110.G0SET PASSED
IEF285I VOL SER NOS= W80003.
IEF285I JES2.JOB06723.S1000102 SYSIN
IEF285I SYS89320.T205706.RA000.W9XNP110.LOADSET PASSED
IEF285I VOL SER NOS= WORK31.
IEF285I %CSD.QA.HEAT6.V0584.NEWHEAT.HT60BJ KEPT
IEF285I VOL SER NOS= LBOCS1.
IEF373I STEP /LKED / START 89320.2057
IEF374I STEP /LKED / STOP 89320.2057 CPU OMIN 01.57SEC SRB OMIN 00.46SEC VIRT 288K SYS 280K EXT 4K SYS 886BK

```

KOMAND DATA ACQUISITION SYSTEM

```

* STEP NAME LKED START TIME 20.57.09.89 VIRT SYS USED 280K PAGE INS 3 STEP TCB 00.00.01.57
* PGM NAME IEWL STOP TIME 20.57.43.67 VIRT CORE USED 288K PAGE OUTS 0 JOB TCB 00.00.01.77
* DISPATCH PRY 105 ELAP. TIME 00.00.33.78 SWAPS/PAGES 0/ 0 SRB TIME 00.00.00.46 CONDITION CODE 0000
* PERF. GROUP 1 SRU 21.83 TRANS ACT TIME 00.00.31.49 OCCUPANCY 00.00.00.00

```

EXCP STATISTICS

UNIT	EXCP COUNT	UNIT	EXCP COUNT	UNIT	EXCP COUNT	UNIT	EXCP COUNT	UNIT	EXCP COUNT	UNIT	EXCP COUNT
288	153	288	246	288	0	C42	0	893	376	C54	386
891	2	288	267								
EXCP TOTAL 1.430		VIO PAGE INS 0		VIO PAGE OUTS 0		PAGES SWAPPED IN 0					

```

IEF236I ALLOC. FOR W9XNP110 GO
IEF237I C54 ALLOCATED TO PGM=* DD
IEF237I JES2 ALLOCATED TO FT05FOO1
IEF237I JES2 ALLOCATED TO FT06FOO1
IEF237I JES2 ALLOCATED TO FT07FOO1
IEF237I 893 ALLOCATED TO FT04FOO1
IEF237I JES2 ALLOCATED TO FT06FOO1
IEF142I W9XNP110 GO - STEP WAS EXECUTED - COND CODE 0000
IEF285I SYS89320.T205706.RA000.W9XNP110.G0SET KEPT
IEF285I VOL SER NOS= W80003.
IEF285I JES2.JOB06723.S1000103 SYSIN
IEF285I JES2.JOB06723.S0000108 SYSOUT
IEF285I JES2.JOB06723.S0000109 SYSOUT
IEF285I SYS89320.T205706.RA000.W9XNP110.R0000004 DELETED
IEF285I VOL SER NOS= WORK32.
IEF285I JES2.JOB06723.S0000110 SYSOUT
IEF373I STEP /GO / START 89320.2057
IEF374I STEP /GO / STOP 89320.2058 CPU OMIN 14.85SEC SRB OMIN 00.41SEC VIRT 896K SYS 280K EXT 4K SYS 8852K

```

KOMAND DATA ACQUISITION SYSTEM

```

* STEP NAME GO START TIME 20.57.43.84 VIRT SYS USED 280K PAGE INS 0 STEP TCB 00.00.14.85
* PGM NAME PGM=* DD STOP TIME 20.58.36.08 VIRT CORE USED 896K PAGE OUTS 0 JOB TCB 00.00.16.62
* DISPATCH PRY 105 ELAP. TIME 00.00.52.24 SWAPS/PAGES 0/ 0 SRB TIME 00.00.00.41 CONDITION CODE 0000
* PERF. GROUP 1 SRU 122.37 TRANS ACT TIME 00.00.51.25 OCCUPANCY 00.00.00.00

```

EXCP STATISTICS

UNIT	EXCP COUNT	UNIT	EXCP COUNT	UNIT	EXCP COUNT	UNIT	EXCP COUNT	UNIT	EXCP COUNT
C54	58	893	434						

PCC

```

* EXCP TOTAL      492      VIO PAGE INS      0      VIO PAGE OUTS      0      PAGES SWAPPED IN      0
*
.....
IEF237I B91 ALLOCATED TO SYS00001
IEF285I  SYS89320 T205836 RA000 W9XNP110 R0000001      KEPT
IEF285I  VOL SER NOS= WORK31
IEF285I  SYS89320 T205706 RA000 W9XNP110 LOADSET      DELETED
IEF285I  VOL SER NOS= WORK31
IEF237I C54 ALLOCATED TO SYS00003
IEF285I  SYS89320 T205836 RA000 W9XNP110 R0000003      KEPT
IEF285I  VOL SER NOS= W80003
IEF285I  SYS89320 T205706 RA000 W9XNP110 G05ET      DELETED
IEF285I  VOL SER NOS= W80003
IEF375I JOB /W9XNP110/ START 89320 2057
IEF376I JOB /W9XNP110/ STOP 89320 2058 CPU      0MIN 16 62SEC SRB      0MIN 00 89SEC
.....

```

KOMAND DATA ACQUISITION SYSTEM

```

*
*
* JOB LOG NUMBER - W9XNP110 89320 20 57 00 95      TCB TIME      00 00 16 62      SRB TIME      00 00 00 89
*
* PROGRAMMER ENERCON      INIT DATE      11/16/89      89 320      INITIATION TIME      20 57 06 16
*
* ACCTG DATA HE66YHNK      TERM DATE      11/16/89      89 320      TERMINATION TIME      20 58 36 63
*
* OS-V52 REL 03 8      PGN/SERVICE      1/      146 14      ELAPSED TIME      00 01 30 47
*
* SYSTEM ID PCC4      CLASS      Z      COMPLETION STATUS      C0000
*
.....

```

TOTAL MAINFRAME UNITS

```

*
*
* SYSTEM RESOURCE UNITS (SRU)      146 14
*
* APPLICATION RESOURCE UNITS (ARU)      00
*
.....

```

REQUESTED OPTIONS: LIST

OPTIONS IN EFFECT: NAME(MAIN) OPTIMIZE(2) LINECOUNT(60) SIZE(MAX) AUTODBL(NONE)

SOURCE EBCDIC LIST NODACK OBJECT NOMAP NOFORMAT GOSTMT NOXREF ALC NOANSF TERM IBM FLAG(1)

```

C *****
C *****
C *****
C *****
ISN 0002      SUBROUTINE BNFLUX (RVALUE,R,TH,Z,TIM,TSN,VALUE,NUMBER,N)
C .....
C
C              E. E. HOLCOMB   10/25/89
C .....
C
C ***** SUBROUTINE TO CALCULATE NET HEAT LOAD
C          ON CNS CONTROL ROOM ROOF.
C *****
C
ISN 0003      REAL*8 RVALUE,R,TH,Z,TIM,TSN,VALUE
ISN 0004      COMMON /IOUNIT/ IBIN,IECHO,IEERROR,IMATLB,IN,IO,
Z              IPILOT,IPLOTO,IREFLG,IIPIN,IIPOUT

C
ISN 0005      DIMENSION TIME(20),QS(20)
ISN 0006      DATA TIME/O., 4.56E0, 4.78, 5.5, 6.5, 7.5, 8.5, 9.5, 10.5, 11.5,
Z              12.5, 13.5, 14.5, 15.5, 16.5, 17.5, 18.5, 19.22, 19.44E0, 24./
ISN 0007      DATA QS/O., 0., 3.87, 18.67, 72.91, 135.96, 195.57, 241.89,
Z              268.22, 284.69, 299.57, 298.95, 263.11, 219.70, 160.70,
Z              99.24, 43.15, 10.74, 0., 0./

C
ISN 0008      DATA EPS,SIGMA,ALPHA/O.90, 0.1714E-08, 0.94/
ISN 0009      DATA C1,C2,C3,C4/11.E0,12.E0,85.E0,9.E0/

C
C          1) HEATING-6 INPUT TIME UNITS MUST BE HOURS ***
C          2) 'QS' IS MEASURED SOLAR LOAD AT OMAHA, NEBRASKA
C              NEAR SUMMER SOLSTICE JUNE 19, 1977, EDITED DATA.
C          3) AMBIENT TEMPERATURE IS ASSUMED TO FOLLOW A SINUSOID,
C              BASED ON 1% DESIGN VALUES FOR OMAHA, NEB.

C
ISN 0010      NPTS = 20
ISN 0011      FLUXIN = 0.
ISN 0012      PI = 4.*ATAN(1.OE0)
ISN 0013      ITMP = NPTS - 1

C
ISN 0014      DTIME = TIM/24.
ISN 0015      REFTIM = (DTIME - INT(DTIME))*24.
ISN 0016      ARG1 = PI*(TIM-C1)/C2

C
ISN 0017      TAMB = C3 + C4*SIN(ARG1)
ISN 0018      TAMBR = TAMB + 459.69
ISN 0019      TAMBK = TAMBR/1.8
ISN 0020      TSKYK = 0.0552 * TAMBK**1.5
ISN 0021      TSKYR = 1.8*TSKYK
ISN 0022      TSNR = TSN + 459.69

C
ISN 0023      DO 10 I=1,ITMP
ISN 0024      IF (REFTIM .GE. TIME(I+1)) GO TO 10
ISN 0026      RAT = (REFTIM-TIME(I))/(TIME(I+1)-TIME(I))
ISN 0027      FLUXIN = ALPHA*(QS(I) + RAT*(QS(I+1)-QS(I)))

```

LEVEL 2 3 (FX07)

BNFLUX

05/360 FORTRAN H EXTENDED

DATE 89.320/20.57.08

PAGE 2

1SN 0028

GD 10 10C

1SN 0029

10 CONTINUE

1SN 0030

100 QOUT = EPS \* SIGMA \* (1SNR\*\*4 - 1SKYR\*\*4)

1SN 0031

QNET = FLUXIN - QOUT

1SN 0032

RVALUE = QNET

1SN 0033

RETURN

1SN 0034

END

000000	47 FO F 00C	BNFLUX	BC	15, 12(0, 15)
000004	07		DC	XL 1'07'
000005	C2D5C6D3E4E74D		DC	CL 7'BNFLUX'
00000C	90 EC D 00C		STM	14, 12, 12(13)
000010	18 4D		LR	4, 13
000012	98 CD F 02D		LM	12, 13, 32(15)
000016	50 4D D 004		ST	4, 4(0, 13)
00001A	50 D0 4 00B		ST	13, 8(0, 4)
00001E	07 FC		BCR	15, 12

TEMPORARY FOR FIX/FLOAT

000088	00000000	DC	XL 4'00000000'
00008C	00000000	DC	XL 4'00000000'
000090	4E000000	DC	XL 4'4E000000'
000094	00000000	DC	XL 4'00000000'

CONSTANTS

000098	4F0B0000	DC	XL 4'4F0B0000'
00009C	00000000	DC	XL 4'00000000'
0000A0	4E000000	DC	XL 4'4E000000'
0000A4	80000000	DC	XL 4'80000000'
0000A8	421B0000	DC	XL 4'421B0000'
0000AC	00000000	DC	XL 4'00000000'
0000B0	431CBBOA	DC	XL 4'431CBBOA'
0000B4	00000000	DC	XL 4'00000000'
0000B8	00000000	DC	XL 4'00000000'
0000BC	00000001	DC	XL 4'00000001'
0000C0	00000004	DC	XL 4'00000004'
0000C4	00000014	DC	XL 4'00000014'
0000C8	3FE21965	DC	XL 4'3FE21965'
0000CC	41100000	DC	XL 4'41100000'
0000D0	411B0000	DC	XL 4'411B0000'
0000D4	411CCCCD	DC	XL 4'411CCCCD'
0000D8	41400000	DC	XL 4'41400000'
0000DC	421B0000	DC	XL 4'421B0000'
0000E0	431CBBOA	DC	XL 4'431CBBOA'
0000E4	00000000	DC	XL 4'00000000'
0000E8	00000000	DC	XL 4'00000000'

ADCONS FOR VARIABLES AND CONSTANTS

ADCONS FOR COMMON

000238	00000000	DC	XL 4'00000000'
--------	----------	----	----------------

ADCONS FOR EXTERNAL REFERENCES

00023C	00000000	DC	XL 4'00000000'	SIN
000240	00000000	DC	XL 4'00000000'	ATAN
000244	00000000	DC	XL 4'00000000'	FRXPR#

DATA CONSTANTS

0000F4	41B00000	DC	XL 4'41B00000'	C1
0000FB	41C00000	DC	XL 4'41C00000'	C2
0000FC	42550000	DC	XL 4'42550000'	C3

000100	41900000	DC	XL4'41900000'	C4
000108	40E66666	DC	XL4'40E66666'	EPS
00012C	40FOA3D7	DC	XL4'40FOA3D7'	ALPHA
000134	3975C902	DC	XL4'3975C902'	SIGMA
000190	00000000	DC	XL4'00000000'	Q5
000194	00000000	DC	XL4'00000000'	Q5
000198	413DEB85	DC	XL4'413DEB85'	Q5
00019C	4212AB85	DC	XL4'4212AB85'	Q5
0001A0	4248E8F6	DC	XL4'4248E8F6'	Q5
0001A4	4287F5C3	DC	XL4'4287F5C3'	Q5
0001A8	42C391EC	DC	XL4'42C391EC'	Q5
0001AC	42F1E3D7	DC	XL4'42F1E3D7'	Q5
0001B0	4310C385	DC	XL4'4310C385'	Q5
0001B4	4311C80A	DC	XL4'4311C80A'	Q5
0001B8	4312B91F	DC	XL4'4312B91F'	Q5
0001BC	4312AF33	DC	XL4'4312AF33'	Q5
0001C0	431071C3	DC	XL4'431071C3'	Q5
0001C4	42DBB333	DC	XL4'42DBB333'	Q5
0001C8	42A0B333	DC	XL4'42A0B333'	Q5
0001CC	42633D71	DC	XL4'42633D71'	Q5
0001D0	422B2666	DC	XL4'422B2666'	Q5
0001D4	41ABD70A	DC	XL4'41ABD70A'	Q5
0001D8	00000000	DC	XL4'00000000'	Q5
0001DC	00000000	DC	XL4'00000000'	Q5
0001E0	00000000	DC	XL4'00000000'	TIME
0001E4	4148F5C3	DC	XL4'4148F5C3'	TIME
0001E8	414C7AE1	DC	XL4'414C7AE1'	TIME
0001EC	41580000	DC	XL4'41580000'	TIME
0001F0	41680000	DC	XL4'41680000'	TIME
0001F4	41780000	DC	XL4'41780000'	TIME
0001F8	41880000	DC	XL4'41880000'	TIME
0001FC	41980000	DC	XL4'41980000'	TIME
000200	41A80000	DC	XL4'41A80000'	TIME
000204	41B80000	DC	XL4'41B80000'	TIME
000208	41C80000	DC	XL4'41C80000'	TIME
00020C	41D80000	DC	XL4'41D80000'	TIME
000210	41E80000	DC	XL4'41E80000'	TIME
000214	41F80000	DC	XL4'41F80000'	TIME
000218	42108000	DC	XL4'42108000'	TIME
00021C	42118000	DC	XL4'42118000'	TIME
000220	42128000	DC	XL4'42128000'	TIME
000224	42133852	DC	XL4'42133852'	TIME
000228	421370A4	DC	XL4'421370A4'	TIME
00022C	42180000	DC	XL4'42180000'	TIME
000250	58 A0 D 094	L	10, 148( 0, 13)	1
000254	58 70 D 098	L	7, 152( 0, 13)	4
000258	58 60 D 224	L	5, 548( 0, 13)	19
00025C	78 00 D 090	LE	0, 144( 0, 13)	0
000260	70 00 D 124	STE	0, 292( 0, 13)	FLUXIN
000264	58 F0 D 218	L	15, 536( 0, 13)	ATAN
000268	41 10 D 04C	LA	1, 76( 0, 13)	
00026C	05 EF	BALR	14, 15	
00026E	47 00 O 00C	BC	0, 12( 0, 0)	
000272	78 20 D 0B0	LE	2, 176( 0, 13)	41400000
000276	3C 20	MER	2, 0	
00027B	68 40 D 148	LD	4, 328( 0, 13)	TIME
00027C	6D 40 D 0R0	DD	4, 128( 0, 13)	4218000000000000
000280	2B 00	SDR	0, 0	
000282	38 04	LER	0, 4	



DATE 89 320/20 57 08  
4F0B0000000000000

DS/360 FORTRAN II EXTENDED

BNFLUX

4E0000000800000000  
4E0000000800000000  
42190000  
REFTIM  
C1  
TIM  
C2  
ARG1  
SIN  
C4  
C3  
431CBBOA  
411CCCCD  
TAMBR  
FRXPR#  
3FE21965  
411CCCCD  
TSKYR  
TSN  
431CBBOA0000000000  
TSNR  
I  
REFTIM  
TIME  
10  
I  
I  
TIME  
REFTIM

ID	BNFLUX	DS/360	FORTRAN II	EXTENDED
000284	6A 00 D 070		AD	0 112( 0.13)
000285	50 00 D 060		STD	0 96( 0.13)
000286	58 20 D 064		L	2 100( 0.13)
000287	18 02		LR	0 2
000288	57 00 D 07C		X	0 124( 0.13)
000289	50 00 D 06C		SI	0 108( 0.13)
000290	68 60 D 068		LD	0 104( 0.13)
000291	6B 60 D 078		SD	6 120( 0.13)
000292	38 46		SER	4 6
000293	7C 40 D 0B4		ME	4 180( 0.13)
000294	70 40 D 12C		STE	4 300( 0.13)
000295	2B 44		SDR	4 4
000296	78 40 D 0CC		LE	4 204( 0.13)
000297	23 44		LCDR	4 4
000298	6A 40 D 148		AD	4 328( 0.13)
000299	25 00		SDR	0 0
000300	38 02		LER	0 2
000301	2B 20		LDR	2 0
000302	2C 24		MDR	2 4
000303	2B 44		SDR	4 4
000304	28 44		LE	4 208( 0.13)
000305	78 40 D 0D0		DDR	2 4
000306	20 24		STE	2 232( 0.13)
000307	70 20 D 0E8		L	15 532( 0.13)
000308	58 F0 D 214		LA	1 80( 0.13)
000309	41 10 D 050		BALR	14 15
000310	05 EF		BC	0 17( 0.0)
000311	47 00 D 011		LE	2 216( 0.13)
000312	78 20 D 0D8		MER	2 0
000313	3C 20		AE	2 212( 0.13)
000314	7A 20 D 004		AE	2 184( 0.13)
000315	7A 20 D 0B8		DE	7 172( 0.13)
000316	70 20 D JAC		STE	2 272( 0.13)
000317	70 20 D 110		L	15 540( 0.13)
000318	58 F0 D 21C		LA	1 84( 0.13)
000319	41 10 D 054		BALR	14 15
000320	05 EF		BC	0 20( 0.0)
000321	47 00 D 014		LE	2 160( 0.13)
000322	78 20 D 0A0		MER	2 0
000323	3C 20		ME	2 172( 0.13)
000324	7C 20 D 0AC		STE	2 284( 0.13)
000325	70 20 D 11C		LD	0 236( 0.13)
000326	68 00 D 150		AD	0 136( 0.13)
000327	6A 00 D 0B8		STE	0 256( 0.13)
000328	6A 00 D 100		LR	2 10
000329	78 20 D 0A4		SI	10 196( 0.13)
000330	50 A0 D 0C4		LR	3 7
000331	18 37		LR	8 3
000332	18 83		LR	9 2
000333	18 96		LR	11 6
000334	18 92		LE	6 300( 0.13)
000335	78 50 D 12C	100002	CE	6 440( 8.13)
000336	79 68 D 1B8		BC	10 834( 0.13)
000337	47 A0 D 342		SI	9 196( 0.13)
000338	50 90 D 0C4	100003	L	2 196( 0.13)
000339	58 20 D 0A4		SLL	2 2
000340	89 20 D 002		LE	2 436( 2.13)
000341	78 22 D 184		LE	4 300( 0.13)
000342	78 40 D 12C		SER	4 2
000343	3B 42			

BNFLUX	LCER	TIME	ALPHA FLUXIN
000348	33 22		
00034A	7A 22 D 1B8	2, 2	
00034E	3D 42	2, 440( 2, 13)	
000350	7B 22 D 164	4, 2	
000354	7B 62 D 168	2, 356( 2, 13)	OS
000358	3B 62	6, 360( 2, 13)	OS
00035A	3C 46	5, 2	
00035C	3A 24	6, 2	
00035E	7C 20 D 104	4, 6	
000362	7D 20 D 124	2, 4	
000366	47 F0 D 34C	ME 2, 260( 0, 13)	ALPHA
00036A	1A 87	ST 2, 292( 0, 13)	FLUXIN
00036C	87 9A D 302	BC 15, 844( 0, 13)	100
000370	50 90 D 0C4	10 AF 8, 7	100002
000374	7B 20 D 0E0	BXLE 9, 10, 770( 13)	1
000378	7C 20 D 10C	SI 9, 196( 0, 13)	EPS
00037C	7B 40 D 100	LE 2, 224( 0, 13)	SIGMA
000380	3C 44	ME 2, 268( 0, 13)	TSNR
000382	3C 44	LE 4, 256( 0, 13)	
000384	7B 60 D 11C	MER 4, 4	
000388	3C 66	LE 6, 284( 0, 13)	TSKYR
00038A	3C 66	MER 6, 6	
00038C	3B 46	MER 6, 6	
00038E	3C 24	SER 4, 6	
000390	33 22	MER 2, 4	
000392	7A 20 D 124	LCER 2, 2	
000396	2B 00	AE 2, 292( 0, 13)	FLUXIN
000398	3B 02	SDR 0, 0	
00039A	60 00 D 160	LER 0, 2	
00039E	1B FF	STC 0, 352( 0, 13)	RVALUE
0003A0	5B E0 D 000	SR 15, 15	
0003A4	07 FE	L 14, 0( 0, 13)	
0003A6	5B A0 D 004	BCR 15, 14	
0003AA	5B E0 A 00C	L 10, 4( 0, 13)	
0003AE	5B B0 A 018	L 14, 12( 0, 10)	
0003B2	5B 10 B 000	L 11, 24( 0, 10)	
0003B6	5B 20 D 160	L 1, 0( 0, 11)	
0003BA	60 20 1 000	LD 2, 352( 0, 13)	RVALUE
0003BE	1B DA	STD 2, 0( 0, 1)	
0003C0	92 FF A 00C	LR 13, 10	
0003C4	9B 2C A 01C	MVI 12( 10), 255	
0003C8	07 FE	LM 2, 12, 28( 10)	
0003CA	9B 7B 1 000	BCR 15, 14	
0003CE	6B 20 7 000	LM 7, 11, 0( 1)	
0003D2	60 20 D 160	LD 2, 0( 0, 7)	
0003D6	6B 20 8 000	STD 2, 352( 0, 13)	RVALUE
0003DA	60 20 D 130	LD 2, 0( 0, 8)	R
0003DE	6B 20 9 000	STD 2, 304( 0, 13)	TH
0003E2	50 20 D 140	LD 2, 0( 0, 9)	Z
0003E6	6B 20 A 000	STD 2, 320( 0, 13)	TIM
0003EA	60 20 D 138	LD 2, 0( 0, 10)	
0003EE	6B 20 B 000	STD 2, 312( 0, 13)	
0003F2	60 20 D 148	LD 2, 0( 0, 11)	
0003F6	9B 7A 1 014	LM 7, 10, 20( 1)	
0003FA	6B 20 7 000	LD 2, 0( 0, 7)	
0003FE	60 20 D 150	STD 2, 336( 0, 13)	
000402	6B 20 8 000	LD 2, 0( 0, 8)	

ADDRESS OF EPILOGUE

ADDRESS OF PROLOGUE

DATE 89 320/20 57 08  
VALUE

DS/360 F:PTRAIN H EXTENDED  
STD 2, 3481 ( 0, 13)  
L 2, 01 ( 0, 9)  
ST 2, 2961 ( 0, 13)  
L 2, 01 ( 0, 10)  
ST 2, 2001 ( 0, 13)  
BC 15, 5521 ( 0, 13)

BMFLUX  
000406 50 20 D 158  
00040A 58 20 B 090  
00040E 50 20 D 228  
000412 58 20 A 000  
000416 50 20 D 048  
00041A 47 40 D 228

ADCON FOR PROLOGUE  
000020 000003CA

ADCON FOR SAVE AREA  
000024 00000028

ADCON FOR EPILOGUE  
00002B 000003A8

ADCONS FOR PARAMETER LISTS  
000074 800000CC  
00007B 80000110  
00007C 00000138  
000080 80000000

TEMPORARIES AND GENERATED CONSTANTS  
00024B 00000000  
00024C 00000013

\*OPTIONS IN EFFECT\*(MAIN) OPTIMIZE(2) LINECOUNT(50) SIZE(MAX) AUTODBL(NONE)  
\*OPTIONS IN EFFECT\*SOURCE EBCDIC LIST INDEX OBJECT NOMAP NOFORMAT GDSMT NOXREF ALC NOANSF TERM IBM FLAG(1)  
\*STATISTICS\* SOURCE STATEMENTS = 33, PROGRAM SIZE = 1054, SUBPROGRAM NAME =BMFLUX  
\*STATISTICS\* NO DIAGNOSTICS GENERATED

\*\*\*\*\* END OF COMPILATION \*\*\*\*\*

68K BYTES OF CORE NOT USED

FORTRAN H EXTENDED COMPILER ENTERED

\*STATISTICS\* SOURCE STATEMENTS = 33, PROGRAM SIZE = 1054, SUBPROGRAM NAME -BNFLUX

\*STATISTICS\* NO DIAGNOSTICS GENERATED

\*\*\*\*\* END OF COMPILATION \*\*\*\*\*

GBK BYTES OF CORE NOT USED

MVS/VA DFP VER 2 LINKAGE EDITOR 20 57 11 THU NOV 16 1989  
 JOB W9XNP110 STEP LKED  
 INVOCATION PARAMETERS - MAP.LIST  
 ACTUAL SIZE-(176128.86016)  
 OUTPUT DATA SET SYS89320 T205706 RAO00 W9XNP110 GDSSET IS ON VOLUME NR00003  
 TEM0000 ENTRY MAIN  
 TEM0000 INCLUDE H6COMP  
 TEM0000 INCLUDE HT6  
 TEM0000 ALIAS Q\*010

MODULE MAP

CONTROL SECTION			ENTRY			
NAME	ORIGIN	LENGTH	NAME	LOCATION	NAME	LOCATION
BNFLUX	00	41E	TABLFN	18FC		
ADJUST	420	56C	BDCOCM	288C		
ANALFN	990	102C				
BDCOH0	19C0	10F0				
BESK	2AB0	934				
BIO	33E8	F8				
B11	34E0	13A				
BK0	3620	2A2				
BK1	38C8	2A2				
ARYLNG	3870	58				
FLGTYP	38C8	2C				
TSTOUT	38F8	4				
IOUNIT	3C00	2C				
MAPFMT	3C30	20				
DIVTOR	3C50	2				
TMFMT	3C58	160				
WIDTH	3DB8	10				
BNDTMP	3DC8	24E				
BOUNDR	4018	111E				
BPOINT	5138	1280				
CALOLT	6388	4EEA				
CHKATF	B2A8	7D2				
CONDIN	BAJ0	24E				
CONVTN	BCD0	24E				
CPHEAT	BF20	24E				
DAXPY	C170	4A2				
DCHAR	C618	4F4				
DDGT	CB10	456				
DECRE5	CF68	1E4				
DIFFR	D150	15CE				
DIRECT	E720	151E				
DNSITY	FC40	24E				
DPBFA	FE90	40A				
DPBSL	102A0	30E				
DPTSL	10680	636				
ECHO	10FB8	678				
ERRBHD	11330	A1C				
			CVERT1	C98C	CNVERT	C9F4

NAME LOCATION NAME LOCATION NAME LOCATION NAME LOCATION

NAME	ORIGIN	LENGTH	NAME	LOCATION	NAME	LOCATION	NAME	LOCATION	NAME	LOCATION
ERRCK	11050	1124								
ERRHGN	12178	485								
ERRINT	12300	344								
ERRMAT	12650	704								
ERRMSG	13058	6FA								
ERRREG	14758	1800								
FCHK	15F58	19E2								
FGRID	17940	9D0								
FINCP	18310	10A								
FINEV1	18420	1472	FINEVL	19054						
FINUSR	19E98	2DE								
FMTMAP	1A178	1254								
FUNCTN	1B300	5CA								
GRIDS	1B9A0	446								
HEATGN	1BDE8	24E								
HEATN6	1C038	6E46								
HGENS	22EEO	872	ITEMPS	2368C						
H6	23758	236								
ITREAD	23990	2DA	DOGGAD	23BF4						
INCRS	23C70	22A								
INFACE	23EAO	FAE								
INITIL	24E50	7FA								
INITTP	25650	24E								
INPUT	258A0	3550	INPCM1	2815C	INPCM2	28B3C				
INJE	280FO	288								
IO	29178	292								
OF\$O10	29410	1104								
MAIN	2A518	1194								
MATERL	2B680	F5A								
MATLIB	2C610	12EA								
MATCON	2D900	24E								
MCONE X	2D950	24E								
MCYTRM	2DDA0	378								
NEXTCD	2E118	B9C								
OUTABL	2E088	698								
OUTPUT	2F350	3800								
PLOTTN	32850	C40	PLOT0U	33780						
POINTS	337FO	293C								
PREANA	36130	BEA	ANALYT	36BE4						
PREP	36A20	28C2	PREPCM	3901A						
PRETAB	392E8	DEA	TABLE	3A04A						
PRORDR	3A008	2FA								
PRTOUT	3A308	B6A	NODEMN	3AE3A	SFCPRT	3AE8C	SPECPE	3AEEC		

NAME	ORIGIN	LENGTH	NAME	LOCATION	NAME	LOCATION	NAME	LOCATION	NAME	LOCATION
PTPROP	3AF4B	118E								
QHG	3C10B	21A								
RADITH	3C32B	24E								
READER	3C57B	171E								
REGION	30C90	3F4								
REGONS	3E08B	86B								
REORDR	3E8F0	102B								
			REORMT	3FEB4	REORPC	40040	REORHG	400B0	REORIT	4015C
			REORBC	4020C	REORAF	401E0	REORTF	4056C		
SETTYP	4061B	324								
SSBDCN	40940	CC4								
SSNCJE	4160B	98E								
SURBC	41F9B	17A2								
			SURBCM	4344C						
TEMPR	43740	F3A								
			SSPARM	4458B	TRANS	445CB	TRANS2	4460B		
THRMPR	44680	60AA								
			THRCOM	4402B	THRM1	4B3CB				
TMPOUT	4B430	15FA								
			TMPCM	4C950						
TMSTEP	4CA30	00A								
			UDTS	4D774						
TOBCD	4D810	17B								
TPMNTR	4D98B	360								
TPRNGE	4DCEB	6AE								
TRANO	4E39B	4FB6								
			TRANIM	5324C						
TYPEBC	53320	1C6								
UMONTR	534EB	15B								
			USRMON	53600						
WRITER	53640	58F8								
IHOSATN2*	58F3B	1E8								
			IH\$ATAN2	58F3B	ATAN2	58F3B	ATAN	58F4C	IH\$ATAN	58F4C
IHOLEXP *	59120	2AC								
			DEXP	59120	IH\$DEXP	59120				
IHDLLOG *	59300	224								
			IH\$DLGO	59300	DLOG10	59300	DLOG	593EB	IH\$DLOG	593EB
DREAD *	595F8	CEB								
IHOLSORT*	5A2E0	16B								
			DSQRT	5A2E0	IH\$DSQRT	5A2E0				
IHOFDXPD*	5A44B	18B								
			FDXPDX	5A44B						
IHOFRXPR*	5A600	19B								
			FRXPR#	5A600						
IHOECOMH*	5A7A0	F1B								
			IBCOM#	5A7CC	IBOB1971	5A7CC	FD10CS#	5A88B	INTSWCH	5B5EB
FIOAP# *	5B6BB	6F4								
			APOB1971	5B82C						
IHOECOMH2*	5B0B0	A31								
			SEQDASD	5C18E						
IREAD *	5C7EB	29C								
IHOSSCN *	5C88B	20B								

NAME	ORIGIN	LENGTH	NAME	LOCATION	NAME	LOCATION	NAME	LOCATION	NAME	LOCATION
			CDS	SCARR	IH\$CDS	SCARR	SIN	SCAAA	IH\$SIN	SCAAA
AREAD *	5CC90	880								
CORE *	5D510	144								
IHDLATN2 *	5D658	278								
IHOLSCN *	5D8D0	290	DATAN2	5D658	IH\$DATA2	5D658	DATAN	5D670	IH\$DATAN	5D670
IHDLTNCT *	5D860	2F0	DCOS	5D8D0	IH\$DCOS	5D8D0	DSIN	5D8F4	IH\$DSIN	5D8F4
IHOLTANH *	5DE50	170	DCDTAN	5D860	IH\$DCDTN	5D860	DTAN	5D882	IH\$DTAN	5D882
IHOETRCH *	5DFC0	2AE	DTANH	5DE50	IH\$DTANH	5DE50				
ICLOCK *	5E270	FE	IHDTRCH	5DFC0	IH\$DTRCH	5DFC0				
ICOMPARE *	5E370	48	ICLOCKF	5E270	ITICK	5E354				
SCANON *	5E388	54F	ICOMPA	5E370						
			SCANDF	5E614	ALLOWC	5E654	RESETC	5E694	RSTPTR	5E6D4
			GETPTR	5E734	SETBIN	5E794	RESETB	5E7D4	TOMMS	5E814
			RCRDIN	5C898						
ACDCAT *	5E900	14A								
CREAD *	5EA50	18E								
IHOFOPT *	5EBD8	30C								
IHONAMEL *	5EEE8	C97	ERRSET	5EBD8	ERRSAV	5EDD0	ERRSTR	5EDF6		
IDAY *	5FB80	108	FRNL#	5EEE8	FWRNL#	5F5E4				
INTOBCD *	5FC88	10E								
JOSNUM *	5FD98	98	INTORC	5FC88	INTBCD	5FC9C	INTRCDL	5FC9C		
MODEL *	5FE30	50								
TIME *	5FE80	74								
IHOFCVTH *	5FEF8	A43								
			ADCO#	5FEF8	FCVAOUTP	5FFA2	FCVLOUTP	60032	FCVZOUTP	6018E
IHDEFNTH *	60940	808	FCVLOUTP	60568	FCVEOUTP	6065A	FCVCOUTP	6065A	INT6SWCH	608BC
ENFILE *	61148	112	ARITH#	60940	ADJ5WCH	60EDC				
IHDEFIOS *	61260	11FC								
IHOFIOS2 *	62460	78E	FIOCS#	61260	FIOCSBEP	61266				
IHOSEXP *	62C20	1B0								
IHOSLOG *	62D00	1D4	IH\$SEXP	62C20	EXP	62C20				
IHOERRM *	62FAB	62C	LOG10	62D00	ALOG10	62D00	IH\$ALOGO	62D00	IH\$ALOG	62DE8
IHOUDPT *	635D8	388	LOG	62DE8	ALOG	62DE8				
YOREAD *	63990	1FC	ERRMON	62FAB	IHOERRE	62FC0				

PCC

1-10-68 10:00 AM



NAME	ORIGIN	LENGTH	NAME	LOCATION	NAME	LOCATION	NAME	LOCATION
UNIT	63890	54						
QRDBUF	638E8	27C						
IHOFCONI*	63E68	2FD	FGCONI#	63E68				
IHOFCMO*	64168	4CA	FGCMO*	64168				
IHOJA1B1*	64638	63R						
YOPACK	64C70	102						
IHOFTEN*	64078	198	FTEN#	64078				
TSPAR	64F10	30						
INPTMX	64F40	18						
IOFLAG	64F58	2C						
ABSDEG	64F88	24						
PRRTYP	64F90	1C						
SUBBCD	64FD0	250						
VARDIM	65220	14						
GRD1 IN	65238	38						
CPU	65270	C						
TIERTN	65280	C						
JOBNAM	65290	4C						
MATRLS	652E0	76						
MONTOR	65358	10						
PRINTS	65368	2C						
SSYATE	65398	1C						
TRANST	65388	20						
TM/VAR	653D8	1C						
FINVHC	653F8	40						
PARMID	65438	34						
STATUS	65470	8						
MONREG	65478	88						
MONMAT	65500	48						
MONINT	65548	20						
MONHGN	65568	38						
MONRDC	655A0	CC						
MONGRD	65670	78						
MONSTR	656E8	38						
MONRPT	65720	4C						
MONIPT	65770	74						
MONITR	657E8	8						
PMQMAP	657F0	4						
BINARY	657F8	4						
TPARM	65800	30						
GFACTS	65830	70						
TM/REP	658A0	14						
CLYDE	658B8	4						
INITMP	658C0	58						
ENTRY ADDRESS	2A518							
TOTAL LENGTH	65918							

\*\* MAIN DID NOT PREVIOUSLY EXIST BUT WAS ADDED AND HAS AMODE 24  
\*\* Q#010 IS AN ALIAS AND HAS AMODE 24  
\*\* LOAD MODULE HAS PMODE 24  
\*\* AUTHORIZATION CODE IS 0.

DEFINITION OF INPUT/OUTPUT UNITS

NAME	NO	UNIT NUMBER	DEFINITION
IBIN	95		BINARY INPUT DATA SET (OPTIONAL)
IECHO	5		INITIAL INPUT DATA SET
IERR	0		ERROR MESSAGE DATA SET (OPTIONAL)
IMATL	0		MATERIAL PROPERTIES LIBRARY DATA SET (OPTIONAL)
IN	4		STANDARD INPUT DATA SET
IO	6		STANDARD OUTPUT DATA SET
IPLOT	0		PLOT DATA SET (OPTIONAL)
IPLOT0	0		OLD PLOT DATA SET FOR RESTART CASES (OPTIONAL)
IRECLG	80		RECORD LENGTH IN SINGLE WORDS FOR BINARY DATA SET ON UNIT IBIN (MAXIMUM OF 80)
ITPIN	0		INITIAL TEMPERATURE DATA SET (OPTIONAL)
ITPOUT	0		FINAL TEMPERATURE DATA SET (OPTIONAL)

PRINT INPUT CARD IMAGES W/CARD COLUMNS INDICATED EVERY TENTH CARD

CARD	1	10	20	30	40	50	60	70	80
NO./COL	1	10	20	30	40	50	60	70	80
1	COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL								
2	HEATING 6 DECK FOR TRM								
3	CONTROL ROOM HEAT-UP ANALYSIS								
4	NOVEMBER 16, 1989								
5	MEASURED SOLAR DATA								
6	TLIMIT	GEOM	PROB	TINIT	TFINAL	DT	LEVY	OP	UNITS
7	CONTINUM	MAPFLAG							
8	1177	9	-1	4.55	96	0	0	0	0
9	J- PLOT PLOTFREQ NODEMNH JTPIN JTPOUT MAPFLAG OUTTIME STATUS								
NO./COL	1	10	20	30	40	50	60	70	80
10	OUTOPT								
11	REGION CARDS								
12	REGION	MAT'L	X1	X2	V1	V2	Z1	Z2	
13	TINIT	HEATGEN	BCX1	BCX2	BCY1	BCY2	BCZ1	BCZ2	
14	REGIONS								
15	1	1	0.0	0.0625					
16	1	0	3	0					
17	2	2	0.0625	0.1042					
18	REGIONS								
NO./COL	1	10	20	30	40	50	60	70	80
19	1	0	0	0					
20	3	3	0.1042	2.9167					
21	1	0	2	2					
22	4	4	2.9167	3.3542					
23	2	0	0	0					
24	5	4	3.3542	3.7917					
25	3	0	0	0					
26	6	3	3.7917	4.2292					
27	4	0	0	0					
28	7	4	4.2292	4.6667					
NO./COL	1	10	20	30	40	50	60	70	80
29	3	0	0	0					
30	8	4	4.6667	5.1042					
31	2	0	0	0					
32	9	5	5.1042	5.3229					
33	1	0	0	0					
34	10	6	5.3229	5.3542					
35	1	0	0	1					
36	Y. P. UNITS - k (Btu/hr-ft-F) rho (lb/cu ft) Cp (Btu/lb-F)								
37	MATRIM TYPE k rho Cp								
38	FUNCTIONS								
NO./COL	1	10	20	30	40	50	60	70	80
39	MATERIALS								
40	1	ACUTILE	0.035	23	0.14				
41	2	GYPSPM	0.062	51	0.259				
42	3	DRYAIR	0	0	0.24				
43	4	CONCRETE	1.05	142	0.156				
44	5	ISO95	C.011	1.9	0.38				
45	6	WATERPRF	0.0938	70	0.35				
46	INITIAL TEMPERATURES								
47	1	73.4							
48	2	80.0							
NO./COL	1	10	20	30	40	50	60	70	80
49	3	90.0							
50	4	100.0							
51	HEAT GENERATIONS								
52	BOUNDARY CONDITIONS								
53	BDY NO	BO-TYPE	PO-TEMP	F(t)	F(x)	F(y)	F(z)		

NO	FLAG	HFC	HRC	MCEXP	Q	FINFLAG
54	*	HFC				
55		BOUNDARY CONDITIONS				
56	1	1	1.0	-3		
57	1	0	0	0	0	1
58	0	0	0	0	1	
NO / COL	1	10	20	30	40	50
59	2	3	0	0		
60	0	1.459E-9	0	0	0.0	0
61	3	1	1.0	-4		
62	1	0	0	0	0.0	0
63	*	XY-COORD	GRID BLOCKS & MESH SPACING			
64	XGRID	0.0	0.0625	0.1042	2.9157	3.3542
65	5	1042	5.3229	5.3542	3.7917	4.2292
66	2	6	2	2	2	3
67		ANALYTICAL FUNCTIONS				
68	1	10	20	30	40	50
69	*	TABULAR FUNCTIONS				
70	*	THERMAL CONDUCTIVITY FOR DRY AIR K				
71		Btu/hr-ft-F				
72	*	MATERIAL NUMBER 3				
73	*	TEMPERATURE (DEGF) K				
74	1	1	7			
75	50	0.01465				
76	80	0.01516				
77	100	0.01566				
NO / COL	1	10	20	30	40	50
78	120	0.01615				
79	140	0.01664				
80	160	0.01712				
81	180	0.01759				
76	*	DENSITY FOR DRY AIR RHO				
77		Lbm/Cu ft				
78	*	MATERIAL NUMBER 3				
79	*	TEMPERATURE (DEGF) RHO				
80	2	7				
81	60	0.07633				
NO / COL	1	10	20	30	40	50
81	80	0.07350				
82	100	0.07087				
83	120	0.06843				
84	140	0.06614				
85	160	0.06401				
86	180	0.06201				
82	*	OUTSIDE PERIODIC TEMPERATURE				
83	BC	1				
84	*	FOUR DAY DURATION				
85	*	TIME (hrs) TEMP (DEGF)				
NO / COL	1	10	20	30	40	50
86	3	97				
87	0	82.67				
88	1	80.50				
89	2	78.64				
90	3	77.21				
91	4	76.31				
92	5	76.00				
93	6	76.31				
94	7	77.21				
95	8	78.64				
NO / COL	1	10	20	30	40	50
96	9	80.50				
97	10	82.67				
98	11	85.00				
99	12	87.33				
100	13	89.50				



87	74	78	64													
87	75	77	21													
87	76	76	31													
87	77	76	00													
87	78	76	31													
NO./COL.	1	10	20	30	40	50	60	70	80							
87	79	77	21													
87	80	78	64													
87	81	80	50													
87	82	82	67													
87	83	85	00													
87	84	87	33													
87	85	89	50													
87	86	91	36													
87	87	92	79													
87	88	93	69													
NO./COL.	1	10	20	30	40	50	60	70	80							
87	89	94	00													
87	90	92	79													
87	91	92	79													
87	92	91	36													
87	93	89	50													
87	94	87	33													
87	95	85	00													
87	96	82	37													
88	* CONTROL ROOM CONSTANT TEMPERATURE															
89	* BC 3															
NO./COL.	1	10	20	30	40	50	60	70	80							
90	* TIME (hrs) TEMPERATURE (F)															
91	4	2														
92	0	73	4	1000	73	4										
93	PRINTOUT TIMES															
94	0	1	2	3	4	4	55									
94	5	6	7	8	9	10	11	12	13	14	15	16	17			
94	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33
94	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49
94	50	52	54	56	58	60	62	64	66	68	70	72	74	76	78	80
94	82	84	86	88	90	92	94	96								
NO./COL.	1	10	20	30	40	50	60	70	80							
95	NODES MONITORED															
96	1	3	5	11	13	15	17	19	21	24	25					
97	TRANSIENT PARAMETERS															
98	0.5	1.1	0	0	0	0	1.0	0.01								
100	%															

LIMIT (DIMENSIONS FOR THE D-ARRAY) IS 118272 WHICH USES 463K BYTES OF CORE  
(LIMIT IS COMPUTED BY ALLOCAT AND IS A FUNCTION OF THE COMPUTER CORE REQUEST.)  
THE VARIABLY DIMENSIONED ARRAYS REQUIRE 13045 SINGLE WORDS OR 51K BYTES OF CORE.  
THUS, THE CORE REQUIREMENTS MAY BE REDUCED BY 410K BYTES



CODE: HEATINGS 02/12/83 DATE: 11-16-89 TIME: 20:57:50 COMPUTER: JOM3033/ 0

HEATINGS A MULTI-DIMENSIONAL HEAT CONDUCTION CODE WITH TEMPERATURE DEPENDENT THERMAL PROPERTIES, NON-LINEAR AND SURFACE-TO-SURFACE BOUNDARY CONDITIONS. FINED SURFACE ANALYSIS TECHNIQUES AND CHANGE OF PHASE CAPABILITIES. STEADY STATE MODELS MAY BE SOLVED BY EITHER OVERRELAXATION WITH EXTRAPOLATION OR BY DIRECT SOLUTION TECHNIQUES EPISL OR FIBFA AND DPBSL FROM LIMPACT. THE DIRECT SOLUTION TECHNIQUES ARE LIMITED TO ONE AND TWO DIMENSIONAL PROBLEMS. TRANSIENT MODELS MAY BE SOLVED BY IMPLICIT TECHNIQUES (CRANK-NICOLSON OR BACKWARDS EULER). BY LEVI'S EXPLICIT PROCEDURE. OR THE CLASSICAL EXPLICIT PROCEDURE. THE TIME STEP SIZE FOR THE IMPLICIT TRANSIENT CALCULATIONS MAY BE A FUNCTION OF THE MAXIMUM TEMPERATURE CHANGE. THE IMPLICIT TECHNIQUE MAY NOT BE USED FOR PROBLEMS INVOLVING CHANGE OF PHASE CALCULATIONS. EACH ARRAY WHOSE LENGTH IS A FUNCTION OF THE INPUT DATA IS VARIABLY DIMENSIONED EXCEPT FOR THE NUMBER OF MATERIALS THAT CAN CHANGE PHASE (EQUAL TO 5) AND THE NUMBER OF PARAMETERS IN AN ANALYTICAL FUNCTION (EQUAL TO 11). HEATINGS USES THE SCALE FREE FORM READING ROUTINES TO PROCESS ITS STANDARD INPUT DATA.

HEATINGS WAS WRITTEN BY  
D.C. ELROD

G.E. GILES  
W.D. TURNER  
COMPUTER SCIENCES DIVISION  
UNION CARBIDE CORPORATION, NUCLEAR DIVISION  
BUILDING W-1007, MAIL STOP NO. 53  
POST OFFICE BOX P  
DAK RIDGE, TENNESSEE 37830

PHONE - 615-574-8677  
FIS 624-8677

THIS RUN WITH HEATINGS CAN HANDLE A MAXIMUM OF THE FOLLOWING PARAMETERS:  
(CONTROLLED BY THE USER THROUGH NAMELIST /OPTION/ IN THE INPUT DATA OR THROUGH A BLOCK DATA SUBPROGRAM)

- MAXPTS = 50. LATTICE POINTS
- MAXREG = 2. REGIONS
- MAXMAT = 6. MATERIALS WITH PHASE CHANGE CAPABILITIES (FIXED)
- MAXKCP = 5. INITIAL TEMPERATURE FUNCTIONS
- MAXINT = 5. HEAT GENERATION FUNCTIONS
- MAXHGN = 5. BOUNDARY CONDITION FUNCTIONS
- MAXBDC = 1. POSITION DEPENDENT BOUNDARY TEMPERATURES
- MAXPBT = 50. FINE GRID LINES, RADIAL (OR X)
- MAXKFG = 50. FINE GRID LINES, THETA (OR Y)
- MAXZFG = 50. FINE GRID LINES, AXIAL (OR Z)
- MAXFGI = 50. GROSS GRID LINES ALONG ANY AXIS (CALCULATED)
- MAXGGI = 11. GROSS GRID LINES ALONG ANY AXIS (MAY HAVE BEEN REDUCED)
- MAXANA = 5. ANALYTICAL FUNCTIONS
- MAXPAR = 11. PARAMETERS PER ANALYTICAL FUNCTION (FIXED)
- MAXTBL = 5. TABULAR FUNCTIONS
- MAXPRS = 100. PAIRS PER TABULAR FUNCTION
- MAXPRT = 111. STANDARD PRINTOUT TIMES
- MAXNSN = 11. NODES FOR SPECIAL MONITORING OF TEMPERATURES
- MAXSPC = 10. SPECIFIED PLANE PRINTOUT TIMES
- MAXSPL = 20. PLANES PRINTED FOR THREE DIMENSIONAL MODELS
- MAXSUR = 50. SURFACE-TO-SURFACE CONNECTORS
- MAXWTH = 7. BAND WIDTH FOR STEADY STATE DIRECT SOLUTION TECHNIQUE
- NDIMEN = 3. DIMENSIONS ALLOWED

ANALYSIS COMPONENTS ALLOWED BY BLOCKDATA.(T), NOT ALLOWED.(F):  
(-F) CLASSICAL EXPLICIT (CEP-F)  
(-F) DIRECT SOLUTION (SS) (DIRECT-F)  
(-F) LEVI EXTRAPOLATION (LEVI-F)  
(-F) TRANSIENT IMPLICIT (IMPLG-F)  
(-F) HEAT GENERATION (HGEN-F)  
(-F) CHANGE OF PHASE (MELTG-F)  
(-F) FINISHED BOUNDARIES (FIN-F)  
(-F) POSITION DEPENDENT BOUNDARY TEMPERATURES (PBIND-F)

INPUT RETURN

JOB DESCRIPTION -- COOPER NUCLEAR STATION CONTROL ROOM CEILING T-D MODEL

\*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*

HEATING-6 DECK FOR IBM  
CONTROL ROOM HEAT-UP ANALYSIS  
NOVEMBER 06, 1989  
MEASURED SOLAR DATA  
TINIT TFINAL DT LEVY DP UNITS  
-----  
PROB TINIT TFINAL DT LEVY DP UNITS  
-----  
\*\*\*\*\*

TLIMIT GEOM -----  
CONTINUE MAPFLAG -----  
JPLOT PLATFREQ NODEWIDWJ JTPIN JTPOUT MAPFLAG OUTTIME STATUS  
-----  
\*\*\*\*\*

THE PROBLEM WILL BE TERMINATED AFTER  
1177 SECONDS  
9 (FOR K)

GEOMETRY TYPE NUMBER  
PROBLEM TYPE NUMBER  
INITIAL TIME  
FINAL TIME  
TIME INCREMENT  
IF RADIATION IS INVOLVED, TEMPERATURE UNITS ARE ASSUMED TO BE IN DEGREES FAHRENHEIT  
THIS IS A NEW PROBLEM  
TEMPERATURES OF SELECTED NODES WILL BE MONITORED EVERY 1 ITERATIONS OR TIME STEPS  
THE FOLLOWING INFORMATION WILL BE PRINTED ON UNIT 6 DURING THE CALCULATIONS:  
THE CAPACITANCE, POWER, AND EFFECTIVE CONDUCTANCES ASSOCIATED WITH EACH  
NODE AT THE INITIAL TIME LEVEL.

DEFINITION OF INPUT/OUTPUT UNITS FOR CASE NUMBER 1

NAME NO UNIT NUMBER DEFINITION  
IBIN 95 BINARY INPUT DATA SET (OPTIONAL)  
IECHO 5 INITIAL INPUT DATA SET (OPTIONAL)  
IERROR 0 ERROR MESSAGE DATA SET (OPTIONAL)  
IMATLB 0 MATERIAL PROPERTIES LIBRARY DATA SET (OPTIONAL)  
IN 4 STANDARD INPUT DATA SET  
IO 6 STANDARD OUTPUT DATA SET  
IPLOT 0 PLOT DATA SET (OPTIONAL)  
IPLOTO 0 OLD PLOT DATA SET FOR RESTART CASES (OPTIONAL)  
IRECLG 80 RECORD LENGTH IN SINGLE WORDS FOR BINARY DATA SET ON UNIT IBIN (MAXIMUM OF 80)  
ITPIN 0 INITIAL TEMPERATURE DATA SET (OPTIONAL)  
ITPOT 0 FINAL TEMPERATURE DATA SET (OPTIONAL)

\*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*  
\*\*\*\*\* COMMENT \*\*\*\*\*

REGION CARDS -----  
X1 X2 Y1 Y2 Z1 Z2  
BCX1 BCX2 BCY1 BCY2 BCZ1 BCZ2  
rho (lb/cu ft) Cp (Btu/lb-f) k rho Cp  
MATNUM TYPE k  
RHO CP k rho Cp  
BOUNDARY CONDITIONS -----  
PO-TEMP F(X) F(Y) F(Z)  
HRC HRC HRC HRC  
NCEXP Q: T/F FLAG FINFLAG  
XY-COORD. GRID BLOCKS & MESH SPACING  
THERMAL CONDUCTIVITY FOR DRY AIR k  
Btu/hr-ft-F  
MATERIAL NUMBER 3  
TEMPERATURE (DEG) k  
DENSITY FOR DRY AIR rho  
Lbm/Cu ft  
MATERIAL NUMBER 3  
TEMPERATURE (DEG) rho  
OUTSIDE PERIODIC TEMPERATURE  
BC 1  
FOUR DAY DURATION  
TIME (hrs) TEMP (DEG)  
CONTROL ROOM CONSTANT TEMPERATURE  
BC 3  
TIME (hrs) TEMPERATURE (F)

NUMBER OF PARAMETERS SPECIFIED BY THE INPUT DATA

NUMBER OF REGIONS	10
NUMBER OF MATERIALS	6
NUMBER OF INITIAL TEMPERATURE FUNCTIONS	4
NUMBER OF HEAT GENERATION FUNCTIONS	0
NUMBER OF DIFFERENT KINDS OF BOUNDARIES	3
NUMBER OF POINTS IN GROSS X OR R LATTICE	17
NUMBER OF POINTS IN GROSS Y OR THETA LATTICE	1
NUMBER OF POINTS IN GROSS Z LATTICE	1
NUMBER OF ANALYTIC FUNCTIONS	4
NUMBER OF TABULAR FUNCTIONS	75
NUMBER OF TRANSIENT PRINTOUT TIMES	11
NUMBER OF NODES FOR MONITORING OF TEMPERATURES	

SUMMARY OF REGION DATA

R.G. NO.	MATERIAL NO.	FCN NUMBER	INIT TEMP	HEAT GEN.	LEFT-X		RIGHT-X		LOWER-Y		UPPER-Y		LEFT-THETA		RIGHT-THETA		FRONT-Z	REAR-Z	BOUNDARY NUMBERS		FF-Z
					INNER-R	LEFT-X-L <sub>m</sub>	INNER-R	RIGHT-X-OR-DUTER-R	LOWER-Y	UPPER-Y	LEFT-THETA	RIGHT-THETA	LF-X	RT-X	LF-Y	RT-Y			LF-0	RT-0	
1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
2	2	1	0	0	0.0625	0	0.0625	0	0.0625	0	0	0	0	0	0	0	0	0	0	0	0
3	3	1	0	0	0.1042	0	0.1042	0	0.1042	0	0	0	0	0	0	0	0	0	0	0	0
4	4	2	0	0	2.9167	2	2.9167	3	3.3542	0	0	0	0	0	0	0	0	0	0	0	0
5	4	3	0	0	3.3542	3	3.3542	3	3.7917	0	0	0	0	0	0	0	0	0	0	0	0
6	4	4	0	0	3.7917	4	4.2292	4	4.6667	0	0	0	0	0	0	0	0	0	0	0	0
7	4	3	0	0	4.2292	4	4.6667	5	5.1042	0	0	0	0	0	0	0	0	0	0	0	0
8	4	2	0	0	4.6667	5	5.1042	5	5.3229	0	0	0	0	0	0	0	0	0	0	0	0
9	5	1	0	0	5.1042	5	5.3229	5	5.3229	0	0	0	0	0	0	0	0	0	0	0	0
10	6	1	0	0	5.3229	5	5.3229	5	5.3542	0	0	0	0	0	0	0	0	0	0	0	0

\*\*\*\*\* SUMMARY OF MATERIAL DATA \*\*\*\*\*

MATERIAL NUMBER	MATERIAL NAME	THERMAL PARAMETERS			
		TEMPERATURE-DEPENDENT FUNCTION NUMBERS	DENSITY	SPECIFIC HEAT	
1	ACRITTLE	3 500000-02	2 300000+01	1 400000-01	
2	GYP SUM	6 200000-02	5 100000+01	2 590000-01	
3	DRY AIR	0 0	0 0	2 403000-01	
4	CONCRETE	1 050000+00	1 420000+02	1 560000-01	
5	15095	1 100000-02	1 900000+00	3 800000-01	
6	WATERPRF	9 380000-02	7 000000+01	3 500000-01	

\*\*\*\*\* SUMMARY OF INITIAL TEMPERATURE DATA \*\*\*\*\*

NUMBER	INITIAL TEMPERATURE	POSITION-DEPENDENT FUNCTION NUMBERS		
		X	Y	TH
1	7 34000+01	0	0	2
2	8 00000+01	0	0	0
3	9 00000+01	0	0	0
4	1 00000+02	0	0	0

\*\*\*\*\*SUMMARY OF BOUNDARY DATA\*\*\*\*\*

---GENERAL---

HEAT TRANSFER COEFFICIENTS  
RELATED FUNCTION NUMBERS

---TEMPERATURE  
INFORMATION---

NO.	TYPE	FCT FLAG	X	Y	Z	ASSOC. FCIS	FORCED CONV.	RADIATION	NATURAL CONV.	EXPONENT	FLUX
1	1	1	1	0	0	0	1.000000+00	0.0	0.0	0.0	0.0
			-3	0	0	0	0	0	0	0	1
			0	0	0	0	0	0	0	0	0
2	3	0	0	0	0	0	0.0	1.459000-09	0.0	0.0	0.0
3	1	0	1	0	0	0	1.000000+00	0.0	0.0	0.0	0.0
			-4	0	0	0					

GROSS LATTICES AND NUMBERS OF INCREMENTS

R OR X	0.0	0.062500	0.104200	2.916700	3.354200	3.791700	4.229200	4.666700
5.104200	5.322900	5.354200	6	2	2	2	2	2
2	2	1						
3	1							

LISTING OF ANALYTIC FUNCTIONS

$$F(V) = A(1) + A(2)*V + A(3)*V**2 + A(4)*COS(A(5)*V) + A(6)*EXP(A(7)*V) + A(8)*SIN(A(9)*V) + A(10)*LOG(A(11)*V)$$

NO. A(1) A(2) A(3) A(4) A(5) A(6) A(7) A(8) A(9) A(10) A(11)

ANALYTIC FUNCTION NO 1 IS USER SUPPLIED

LISTING OF TABULAR FUNCTIONS

TABLE NUMBER 1

ARGUMENT	VALUE
6 000000000+01	1 466000000-02
8 000000000+01	1 516000000-02
1 000000000+02	1 566000000-02
1 200000000+02	1 615000000-02
1 400000000+02	1 664000000-02
1 600000000+02	1 712000000-02
1 800000000+02	1 759000000-02

TABLE NUMBER 2

ARGUMENT	VALUE
6 000000000+01	7 633000000-02
8 000000000+01	7 350000000-02
1 000000000+02	7 087000000-02
1 200000000+02	6 843000000-02
1 400000000+02	6 614000000-02
1 600000000+02	6 401000000-02
1 800000000+02	6 201000000-02

TABLE NUMBER 3

ARGUMENT	VALUE
0 0	8 267000000+01
1 000000000+00	8 050000000+01
2 000000000+00	7 864000000+01
3 000000000+00	7 721000000+01
4 000000000+00	7 631000000+01
5 000000000+00	7 600000000+01
6 000000000+00	7 531000000+01
7 000000000+00	7 472100000+01
8 000000000+00	7 424000000+01
9 000000000+01	8 050000000+01
1 000000000+01	8 267000000+01
1 200000000+01	8 500000000+01
1 400000000+01	8 733000000+01
1 600000000+01	8 950000000+01
1 800000000+01	9 136000000+01
1 600000000+01	9 279000000+01
1 700000000+01	9 369000000+01
1 800000000+01	9 400000000+01
1 900000000+01	9 369000000+01
2 000000000+01	9 279000000+01
2 100000000+01	9 136000000+01
2 200000000+01	8 950000000+01
2 300000000+01	8 733000000+01
2 400000000+01	8 500000000+01
2 500000000+01	8 267000000+01
2 600000000+01	8 050000000+01
2 700000000+01	7 864000000+01
2 800000000+01	7 721000000+01
2 900000000+01	7 631000000+01
3 000000000+01	7 600000000+01
3 100000000+01	7 531000000+01
3 200000000+01	7 472100000+01
3 300000000+01	7 424000000+01
3 400000000+01	8 050000000+01
3 500000000+01	8 267000000+01
3 600000000+01	8 500000000+01
3 700000000+01	8 733000000+01
3 800000000+01	8 950000000+01
3 900000000+01	9 136000000+01

3	7000000000+01	8	9500000000+01
3	8000000000+01	9	1360000000+01
3	9000000000+01	9	2750000000+01
4	0000000000+01	9	3690000000+01
4	1000000000+01	9	4000000000+01
4	2000000000+01	9	3690000000+01
4	3000000000+01	9	2790000000+01
4	4000000000+01	9	1360000000+01
4	5000000000+01	8	9500000000+01
4	6000000000+01	8	7330000000+01
4	7000000000+01	8	5000000000+01
4	8000000000+01	8	2670000000+01
4	9000000000+01	8	0500000000+01
5	0000000000+01	7	8640000000+01
5	1000000000+01	7	7210000000+01
5	2000000000+01	7	6310000000+01
5	3000000000+01	7	6000000000+01
5	4000000000+01	7	6310000000+01
5	5000000000+01	7	7210000000+01
5	6000000000+01	7	8640000000+01
5	7000000000+01	8	0500000000+01
5	8000000000+01	8	2670000000+01
5	9000000000+01	8	5000000000+01
6	0000000000+01	8	7330000000+01
6	1000000000+01	8	9500000000+01
6	2000000000+01	9	1360000000+01
6	3000000000+01	9	2790000000+01
6	4000000000+01	9	3690000000+01
6	5000000000+01	9	4000000000+01
6	6000000000+01	9	3690000000+01
6	7000000000+01	9	2790000000+01
6	8000000000+01	9	1360000000+01
6	9000000000+01	8	9500000000+01
7	0000000000+01	8	7330000000+01
7	1000000000+01	8	5000000000+01
7	2000000000+01	8	2670000000+01
7	3000000000+01	8	0500000000+01
7	4000000000+01	7	8640000000+01
7	5000000000+01	7	7210000000+01
7	6000000000+01	7	6310000000+01
7	7000000000+01	7	6000000000+01
7	8000000000+01	7	6310000000+01
7	9000000000+01	7	7210000000+01
8	0000000000+01	7	8640000000+01
8	1000000000+01	8	0500000000+01
8	2000000000+01	8	2670000000+01
8	3000000000+01	8	5000000000+01
8	4000000000+01	8	7330000000+01
8	5000000000+01	8	9500000000+01
8	6000000000+01	9	1360000000+01
8	7000000000+01	9	2790000000+01
8	8000000000+01	9	3690000000+01
8	9000000000+01	9	4000000000+01
9	0000000000+01	9	3690000000+01
9	1000000000+01	9	2790000000+01
9	2000000000+01	9	1360000000+01
9	3000000000+01	8	9500000000+01
9	4000000000+01	8	7330000000+01
9	5000000000+01	8	5000000000+01
9	6000000000+01	8	2670000000+01

TABLE NUMBER	ARGUMENT	NUMBER OF PAIRS	VALUE
0	0	7	3400000000+01
1	0000000000+03	7	3400000000+01



TABLE OF OUTPUT TIMES

OUTPUT NO.	OUTPUT TIME	OUTPUT NO.	OUTPUT TIME	OUTPUT NO.	OUTPUT TIME	OUTPUT NO.	OUTPUT TIME
1	0 0	26	2 400000+01	51	4 900000+01		
2	1 000000+00	27	2 500000+01	52	5 000000+01		
3	2 000000+00	28	2 600000+01	53	5 200000+01		
4	3 000000+00	29	2 700000+01	54	3 400000+01		
5	4 000000+00	30	2 800000+01	55	5 600000+01		
6	4 550000+00	31	2 900000+01	56	5 800000+01		
7	5 000000+00	32	3 000000+01	57	6 000000+01		
8	6 000000+00	33	3 100000+01	58	6 200000+01		
9	7 000000+00	34	3 200000+01	59	6 400000+01		
10	8 000000+00	35	3 300000+01	60	6 600000+01		
11	9 000000+00	36	3 400000+01	61	6 800000+01		
12	1 000000+01	37	3 500000+01	62	7 000000+01		
13	1 100000+01	38	3 600000+01	63	7 200000+01		
14	1 200000+01	39	3 700000+01	64	7 400000+01		
15	1 300000+01	40	3 800000+01	65	7 600000+01		
16	1 400000+01	41	3 900000+01	66	7 800000+01		
17	1 500000+01	42	4 000000+01	67	8 000000+01		
18	1 600000+01	43	4 100000+01	68	8 200000+01		
19	1 700000+01	44	4 200000+01	69	8 400000+01		
20	1 800000+01	45	4 300000+01	70	8 600000+01		
21	1 900000+01	46	4 400000+01	71	8 800000+01		
22	2 000000+01	47	4 500000+01	72	9 000000+01		
23	2 100000+01	48	4 600000+01	73	9 200000+01		
24	2 200000+01	49	4 700000+01	74	9 400000+01		
25	2 300000+01	50	4 800000+01	75	9 600000+01		

SPECIAL MONITORING OF SELECTED NODAL TEMPERATURES OPTION

TEMPERATURES OF THE FOLLOWING NODES WILL BE MONITORED EVERY 1 ITERATIONS OR TIME STEPS

NUMBER	NODE
1	1
2	3
3	5
4	11
5	13
6	15
7	17
8	19
9	21
10	24
11	25

FINE LATTICE LINES GENERATED BY HEATINGS

X OR R FINE LATTICE LINES

1	0.0	2	0.031250	3	0.062500	4	0.083350	5	0.104200
6	0.572950	7	1.041700	8	1.510450	9	1.979200	10	2.447950
11	2.916700	12	3.135450	13	3.354200	14	3.572950	15	3.791700
16	4.010450	17	4.229200	18	4.447950	19	4.666700	20	4.885450
21	5.104200	22	5.177100	23	5.250000	24	5.322900	25	5.354200

THIS PROBLEM INVOLVES TEMPERATURE-DEPENDENT PROPERTIES.

SINCE THIS PROBLEM INVOLVES RADIATION, 459.69 WILL BE ADDED TO THE TEMPERATURES FOR THE RELATED HEAT FLOW CALCULATIONS TO CONVERT THEM TO ABSOLUTE TEMPERATURES.

THIS PROBLEM CONTAINS 25 NODES.

SURFACE - TO - SURFACE CONNECTIONS

NUMBER	NODE	TO	NODE
1	5		11

TIME = 4.55000000+00  
 NO. OF ITERATIONS OR TIME STEPS = 0

TABLE GIVING TEMPERATURE DEPENDENCE FOR HEAT CAPACITANCE (H), EFFECTIVE CONDUCTANCE (K), POWER (Q), AND THERMAL PROPERTIES (ANY OF THE ABOVE) (P), TEMPERATURE, HEAT CAPACITANCE, AND POWER AT EACH NODE  
 TOTAL POWER IS SUM OF PRODUCT OF POWER AND TIME FUNCTION FOR HEAT GENERATION FUNCTION NUMBER (INTERNAL) TIME

N	HWOP	TEMPERATURE	HEAT CAP.	TIME	POWER	TIME	POWER	TIME	POWER	TIME	POWER	TIME	POWER
1	FFFF	7.340000+01	5.031250-02										
2	FFFF	7.340000+01	1.006250-01										
3	FFFF	7.340000+01	1.880160-01										
4	FFFF	7.340000+01	2.754080-01										
5	FFFF	7.340000+01	1.418910-01										
6	FFFF	7.340000+01	8.373810-03										
7	FFFF	7.340000+01	8.373810-03										
8	FFFF	7.340000+01	8.373810-03										
9	FFFF	7.340000+01	8.373810-03										
10	FFFF	7.340000+01	8.373810-03										
11	FFFF	7.998660+01	2.427010+00										
12	FFFF	8.000000+01	4.845750+00										
13	FFFF	8.000000+01	4.845750+00										
14	FFFF	8.000000+01	4.845750+00										
15	FFFF	9.500000+01	4.845750+00										
16	FFFF	1.000000+02	4.845750+00										
17	FFFF	9.500000+01	4.845750+00										
18	FFFF	9.000000+01	4.845750+00										
19	FFFF	8.500000+01	4.845750+00										
20	FFFF	8.000000+01	4.845750+00										
21	FFFF	7.992910+01	2.463190+00										
22	FFFF	7.340000+01	5.263380-02										
23	FFFF	7.340000+01	5.263380-02										
24	FFFF	7.340000+01	4.097420-01										
25	FFFF	7.340000+01	3.834250-01										

HEATING: 02/12/83  
W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING I D MODE I

100000/ O  
20 57 50 11 16 89

TIME = 4.55000000+00  
NO. OF ITERATIONS OR TIME STEPS = 0

TABLE GIVING THE NEIGHBOR AND RELATED EFFECTIVE CONDUCTANCE OF EACH CONNECTOR FOR EVERY NODE FOR BOUNDARY CONNECTORS. THE NEIGHBOR NODE CONSISTS OF THE BOUNDARY CONDITION NUMBER (INTERNAL), OR FOR POSITION DEPENDENT BOUNDARY TEMPERATURES THE NEIGHBOR NODE CONSISTS OF THE BOUNDARY NODE NUMBER AND A NEGATIVE EFFECTIVE CONDUCTANCE MEANS THE NODAL TEMPERATURE WILL BE SET TO THE BOUNDARY TEMPERATURE.

N NODE	CONDUCTANCE	NODE	CONDUCTANCE	NODE	CONDUCTANCE	NODE	CONDUCTANCE	NODE	CONDUCTANCE
1	2	1	1.20000+00	-3	1	0.00000+00			
2	1	1	1.20000+00	3	1	1.20000+00			
3	2	1	1.20000+00	4	2	973620-00			
4	3	2	973620+00	5	2	973620+00			
5	4	2	973620+00	6	3	198930-02			
6	5	3	198930-02	7	3	198930-02			11 9 006580-01
7	6	3	198930-02	8	3	198930-02			
8	7	3	198930-02	9	3	198930-02			
9	8	3	198930-02	10	3	198930-02			
10	9	3	198930-02	11	3	216500-02			
11	10	3	216500-02	12	4	800000+00			
12	11	4	800000+00	13	4	800000+00			5 9 006580-01
13	12	4	800000+00	14	4	800 30+00			
14	13	4	800000+00	15	4	800000+00			
15	14	4	800000+00	16	4	800000+00			
16	15	4	800000+00	17	4	800000+00			
17	16	4	800000+00	18	4	800000+00			
18	17	4	800000+00	19	4	800000+00			
19	18	4	800000+00	20	4	800000+00			
20	19	4	800000+00	21	4	800000+00			
21	20	4	800000+00	22	1	508920-01			
22	21	1	508920-01	23	1	508920-01			
23	22	1	508920-01	24	1	508920-01			
24	23	1	508920-01	25	2	946810+00			
25	24	2	946810+00	-1	1	0.00000+00			0-2 005070+01

STABILITY CRITERION FOR EACH NODE

1	2	3732D-02	2	4	4922D-02	3	4	5929D-02	4	4	6308D-02	5	3	6324D-02	6	1	3088D-01
7	1	3088D-01	8	1	3088D-01	9	1	3088D-01	10	1	3053D-01	11	4	2395D-01	12	5	0477D-01
13	5	0477D-01	14	5	0477D-01	15	5	0477D-01	16	5	0477D-01	17	5	0477D-01	18	5	0477D-01
19	5	0477D-01	20	5	0477D-01	21	4	9470D-01	22	1	7441D-01	23	1	7441D-01	24	1	3017D-01
25	9	5933D-02															


PCC

HEATING 02/12/83  
W94NP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
MAP OF THE NODE NUMBERS

IBM033/ 0  
20.57.54 11-16-89

GROSS GRID	FINE GRID	0.0	1
1	1	0.0	11
2	2	0.03	21
3	3	0.06	31
4	4	0.08	41
5	5	0.10	51
6	6	0.57	61
7	7	1.04	71
8	8	1.51	81
9	9	1.98	91
10	10	2.45	101
11	11	2.92	111
12	12	3.14	121
13	13	3.35	131
14	14	3.57	141
15	15	3.79	151
16	16	4.01	161
17	17	4.23	171
18	18	4.45	181
19	19	4.67	191
20	20	4.89	201
21	21	5.10	211
22	22	5.18	221
23	23	5.25	231
24	24	5.32	241
25	25	5.35	251



PCC

THE STABILITY CRITERION IS 2.3732311D-02 FOR POINT 1  
THE INPUT TIME STEP SIZE IS 0.0  
TIMES. THE TIME STEP SIZE WILL BE SET EQUAL TO THE STABILITY CRITERION OR 2.3732311D-02.



HEATING6 02/12/E3  
 WBY:P110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 0 TIME STEPS, TIME = 4.550000+00

LJM3033/  
 20 57 54 0 11-16-89

GROSS GRID	1	1	1
FT	0.0	0.0	0.0
1	0.0	73140	
2	0.03	73140	
3	0.06	73140	
4	0.08	73140	
5	0.10	73140	
6	0.57	73140	
7	1.04	73140	
8	1.51	73140	
9	1.98	73140	
10	2.45	73140	
11	2.92	79199	
12	3.14	80100	
13	3.35	85100	
14	3.57	90100	
15	3.79	95100	
16	4.01	100100	
17	4.23	95100	
18	4.45	90100	
19	4.67	85100	
20	4.89	80100	
21	5.10	79193	
22	5.18	73140	
23	5.25	73140	
10 23	5.32	73140	
11 25	5.35	73140	

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	76.139500
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 2.373231130-02

ELAPSED CPU TIME IS 0.0 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.000000+02 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 16

THE MINIMUM TEMPERATURE IS - 7.340000+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES	1	2	3	4	5
	6	7	8	9	10
	22	23	24	25	

THE INITIAL TIME STEP = 5.000000-01

AFTER EACH TIME STEP THE TIME STEP SIZE WILL BE MULTIPLIED BY A FACTOR OF 1.100000+00 SUBJECT TO ANY CONDITIONS WHICH MAY FOLLOW.

IF THE MAXIMUM TEMPERATURE CHANGE AT A NODE EXCEEDS 1.000000+00 PER CENT OVER A TIME STEP, THEN THE TIME STEP SIZE WILL BE DECREASED ACCORDINGLY.

THE MINIMUM TIME STEP ALLOWED IS 1.000000-02

THE IMPLICIT PROCEDURE WILL BE USED TO CALCULATE THE TRANSIENT TEMPERATURE DISTRIBUTION

MAXIMUM NORMALIZED HEAT RESIDUAL CONVERGENCE CRITERION = 1.00000D-05

(CORRESPONDS TO EPSILON SUB 1, DEFAULT=1.00D-5)

NUMBER-OF-ITERATIONS BETWEEN TESTS FOR CONVERGENCE, LINEAR LOOP (DEFAULT = 1) = 1

AVERAGE L1 NORM OF RELATIVE TEMPERATURE DIFFERENCE CONVERGENCE CRITERION

FOR TEMPERATURE DEPENDENT PROPERTIES = 1.00000D-05

(CORRESPONDS TO EPSILON SUB 3, DEFAULT=1.00D-5)

THETA (0.5 FOR CRANK-NICOLSON, 1.0 FOR CLASSICAL IMPLICIT) = 5.00000D-01

THE SOR ACCELERATION PARAMETER (BETA) WILL BE OPTIMIZED EMPIRICALLY

BETA = 1.00000D+00

A BETA UPDATE WILL BE ATTEMPTED EVERY 1 TIME STEPS (DEFAULT=1)

NUMBER-OF-ITERATIONS TOLERANCE FOR BETA UPDATE CALCULATIONS, OUTER LOOP (DEFAULT=5) = 5

NUMBER-OF-ITERATIONS TOLERANCE FOR BETA UPDATE CALCULATIONS, INNER LOOP (DEFAULT=2) = 2

PER CENT CHANGE IN BETA UPDATE CALCULATIONS (DEFAULT=10) = 10

THE FOLLOWING TABLE IS PRINTED OUT FOR INFORMATION PURPOSES DURING THE IMPLICIT TRANSIENT CALCULATIONS. A LINE IS PRINTED EACH TIME THE INNER LOOP CONVERGES. A LINE IS ALSO PRINTED AFTER THE VERY FIRST ITERATION FOR EACH TIME STEP. THUS, ONE CAN DETERMINE HOW MUCH THE MAXIMUM NORMALIZED HEAT RESIDUAL DECREASES DURING THE ITERATIVE PROCESS. ENTRIES IN EACH COLUMN ARE DESCRIBED BELOW.

NO TIME	-- NUMBER OF TIME STEPS
TIME	-- TIME AT WHICH TEMPERATURE DISTRIBUTION IS BEING CALCULATED
NO ITER	-- NUMBER OF ITERATIONS REQUIRED FOR INNER (LINEAR) LOOP TO CONVERGE
MAX HEAT RESIDUAL	-- THE MAXIMUM NORMALIZED HEAT RESIDUAL AFTER THE NUMBER OF ITERATIONS INDICATED IN THE PREVIOUS COLUMN (COMPARES TO EPSILON SUB 1)
BETA	-- CURRENT VALUE OF THE SOR ACCELERATION PARAMETER
L1 NORM OF TEMP DIFF	-- THE L1 NORM OF THE TEMPERATURE DIFFERENCE OVER THE CURRENT ITERATION FOR INNER (LINEAR) LOOP. THIS COLUMN AND THE NEXT TWO ARE USED ONLY WHEN THE OPTIMUM ACCELERATION PARAMETER IS BEING ESTIMATED USING CARRE S TECHNIQUE
RHO(ITERATION)	-- SPECTRAL RADIUS FOR THE SOR ITERATION MATRIX
RHO(JACOBI)	-- SQUARE OF SPECTRAL RADIUS FOR THE JACOBI ITERATION MATRIX
NO ITER	-- NUMBER OF ITERATIONS COMPLETED FOR OUTER (NON-LINEAR) LOOP
L1 NORM OF TEMP DIFF	-- THE AVERAGE L1 NORM OF THE RELATIVE TEMPERATURE DIFFERENCE OVER THE CURRENT ITERATION FOR OUTER (NON-LINEAR) LOOP. NON-ZERO FOR NON-LINEAR PROBLEMS ONLY (COMPARES TO EPSILON SUB 3)
NODE	-- NODE NUMBER
MAX TEMP CHANGE	-- MAXIMUM TEMPERATURE CHANGE AT A NODE OVER THE CURRENT TIME STEP. THIS CHANGE OCCURRED AT THE NODE SHOWN IN THE PREVIOUS COLUMN
NODE	-- NODE NUMBER
MAX PERCENT TEMP CHANGE	-- MAXIMUM PERCENTAGE OF RELATIVE CHANGE IN TEMPERATURE AT A NODE OVER THE CURRENT TIME STEP. THIS CHANGE OCCURRED AT THE NODE SHOWN IN THE PREVIOUS COLUMN

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	MODE	MAX PERCENT TEMP CHANGE
1	5.00000+00	0	9.30271D-02	1.00000+00	0.0	0.0	0.0	1	2.11207D-02			
1	5.00000+00	1	5.25885D-02	1.00000+00	0.0	0.0	0.0	2	1.18450D-03			
1	5.00000+00	19	6.48414D-06	1.00000+00	0.0	0.0	0.0	3	2.16468D-04			
1	5.00000+00	5	7.03219D-06	1.00000+00	0.0	0.0	0.0	4	4.01016D-05			
1	5.00000+00	6	6.42616D-06	1.00000+00	0.0	0.0	0.0	5	6.85845D-06	25.4	78899D+00	25.6
1	5.00000+00	5	4.23433D-06	1.00000+00	0.0	0.0	0.0					
1	5.00000+00	3	8.85315D-06	1.00000+00	0.0	0.0	0.0					
1	4.61552D+00	1	4.30688D-03	1.00000+00	0.0	0.0	0.0	1	2.52296D-03			
1	4.61552D+00	6	3.46678D-06	1.00000+00	0.0	0.0	0.0	2	5.50011D-05			
1	4.61552D+00	3	1.46314D-06	1.00000+00	0.0	0.0	0.0	3	3.08998D-06	25.1	98919D+00	25.2
1	4.61552D+00	2	1.06987D-06	1.00000+00	0.0	0.0	0.0					
1	4.57297D+00	1	3.26247D-04	1.00000+00	0.0	0.0	0.0	1	4.07449D-04			
1	4.57297D+00	3	4.52037D-06	1.00000+00	0.0	0.0	0.0	2	3.00310D-06	25.8	85003D-01	25.1
1	4.57297D+00	1	5.35334D-06	1.00000+00	0.0	0.0	0.0					
1	4.56810D+00	1	3.68970D-05	1.00000+00	0.0	0.0	0.0	1	5.23152D-05			
1	4.56810D+00	2	4.21507D-06	1.00000+00	0.0	0.0	0.0	2	5.29757D-07	25.7	19868D-01	25.9
1	4.56810D+00	1	4.08016D-07	1.00000+00	0.0	0.0	0.0					

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
 \*\*\*\*\* NODE NUMBERS AND TEMPERAT \*\*\*\*\*

NUMBER OF TIME STEPS	TIME	5	13	19	21	24	25
1	4.56810D+00	17.9	49984D+01	3.7	34061D+01	5.7	40122D+01
2	4.58619D+00	17.9	49939D+01	3.7	34050D+01	5.7	40320D+01
3	4.60430D+00	17.9	49866D+01	3.7	34783D+01	5.7	46753D+01
4	6.22390D+00	17.9	49767D+01	3.7	35457D+01	5.7	48800D+01
5	4.64050D+00	17.9	49643D+01	3.7	36253D+01	5.7	50444D+01
6	6.60390D+00	17.9	49550D+01	3.7	37228D+01	5.7	51961D+01
7	4.68230D+00	17.9	49492D+01	3.7	38361D+01	5.7	53403D+01
8	4.70638D+00	17.9	49400D+01	3.7	40020D+01	5.7	55952D+01

8	4	706380+00	1	1.12613D-06	1.055000+00	0.0	0.0	2	1.70457D-06	24	2.89663D-01	24	4.01500D-01
	8	4.7064D+00		1.7.34683D+01	3.7.39631D+01	5.7.54806D+01	11.7.58262D+01		13.8.50479D+01				
				15.9.49018D+01	17.9.49018D+01	19.8.50482D+01	21.7.99989D+01		24.7.18555D+01				
				25.7.01563D+01		0.0	0.0						
				5.64191D-05	1.055000+00	0.0	0.0		1.1.20386D-04				24.4.22265D-01
9	4	73287D+00	1	2.3973D-06	1.055000+00	0.0	0.0		2.1.71964D-06				
	9	4.73287D+00		1.32325D-06	1.055000+00	0.0	0.0		11.7.98281D+01				
				1.7.35015D+01	3.7.41021D+01	5.7.56201D+01	11.7.98281D+01		13.8.50632D+01				
				15.9.48699D+01	17.9.48699D+01	19.8.50638D+01	21.8.00276D+01		24.7.15521D+01				
				25.6.99332D+01		0.0	0.0						
10	4	320+00	1	5.24626D-05	1.055000+00	0.0	0.0		1.1.26444D-04				24.4.33826D-01
	10	4.320D+00		2.6.14254D-06	1.055000+00	0.0	0.0		2.1.75514D-06				
				1.55063D-06	1.055000+00	0.0	0.0		11.7.98368D+01				
				1.7.35428D+01	3.7.42515D+01	5.7.57608D+01	11.7.98368D+01		13.8.50817D+01				
				15.9.48312D+01	17.9.48312D+01	19.8.50828D+01	21.8.00633D+01		24.7.12416D+01				
				25.6.97304D+01		0.0	0.0						
11	4	79408D+00	1	5.05008D-05	1.055000+00	0.0	0.0		1.1.32494D-04				24.4.35396D-01
	11	4.79408D+00		2.6.24591D-06	1.055000+00	0.0	0.0		2.1.85182D-06				
				1.87800D-06	1.055000+00	0.0	0.0		11.7.98535D+01				
				1.7.35921D+01	3.7.41100D+01	5.7.59045D+01	11.7.98535D+01		13.8.51038D+01				
				15.9.47846D+01	17.9.47846D+01	19.8.51056D+01	21.8.01069D+01		24.7.09315D+01				
				25.6.95488D+01		0.0	0.0						
12	4	82934D+00	1	6.39962D-05	1.055000+00	0.0	0.0		1.1.41631D-04				24.4.25196D-01
	12	4.82934D+00		2.7.79341D-06	1.055000+00	0.0	0.0		2.2.22002D-06				
				1.2.70360D-06	1.055000+00	0.0	0.0		11.7.98792D+01				
				1.7.36486D+01	3.7.45765D+01	5.7.60523D+01	11.7.98792D+01		13.8.51299D+01				
				15.9.47292D+01	17.9.47292D+01	19.8.51326D+01	21.8.01593D+01		24.7.06299D+01				
				25.6.93965D+01		0.0	0.0						
13	4	86814D+00	1	5.70362D-05	1.055000+00	0.0	0.0		1.1.46924D-04				24.4.01457D-01
	13	4.86814D+00		2.8.34620D-06	1.055000+00	0.0	0.0		2.2.43288D-06				
				1.3.34228D-06	1.055000+00	0.0	0.0		11.7.99151D+01				
				1.7.37116D+01	3.7.47501D+01	5.7.62052D+01	11.7.99151D+01		13.8.51604D+01				
				15.9.46640D+01	17.9.46640D+01	19.8.51643D+01	21.8.02216D+01		24.7.03463D+01				
				25.6.92769D+01		0.0	0.0						
14	4	91081D+00	1	7.36464D-05	1.055000+00	0.0	0.0		1.1.52512D-04				24.4.63464D-01
	14	4.91081D+00		2.9.15761D-06	1.055000+00	0.0	0.0		2.2.70261D-06				
				1.4.16262D-06	1.055000+00	0.0	0.0		11.7.99624D+01				
				1.7.37796D+01	3.7.49301D+01	5.7.63641D+01	11.7.99624D+01		13.8.51957D+01				
				15.9.45880D+01	17.9.45881D+01	19.8.52011D+01	21.8.02948D+01		24.7.00906D+01				
				25.6.91943D+01		0.0	0.0						
15	4	95540D+00	1	7.27101D-05	1.055000+00	0.0	0.0		1.1.45389D-04				24.4.97211D-01
	15	4.95540D+00		2.9.12431D-06	1.055000+00	0.0	0.0		2.2.68424D-06				
				1.4.45043D-06	1.055000+00	0.0	0.0		11.8.00190D+01				
				1.7.38495D+01	3.7.51069D+01	5.7.65215D+01	11.8.00190D+01		13.8.52340D+01				
				15.9.45048D+01	17.9.45048D+01	19.8.52414D+01	21.8.03755D+01		24.6.98823D+01				
				25.6.91554D+01		0.0	0.0						
16	5	00000D+00	1	6.42381D-05	1.055000+00	0.0	0.0		1.1.28059D-04				9.2.35004D-01
	16	5.00000D+00		2.8.22911D-06	1.055000+00	0.0	0.0		2.2.34928D-06				
				1.3.99864D-06	1.055000+00	0.0	0.0		11.8.00817D+01				
				1.7.39169D+01	3.7.52731D+01	5.7.66712D+01	11.8.00817D+01		13.8.52733D+01				
				15.9.44184D+01	17.9.44185D+01	19.8.52829D+01	21.8.04595D+01		24.6.97294D+01				
				25.6.91594D+01		0.0	0.0						

HEATING6 02/12/83  
W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

IBM3033/ 0  
20.57.54 11-16-89

STEADY STATE TEMPERATURE DISTRIBUTION AFTER 16 TIME STEPS, TIME = 5.000000+00

GROSS GRID			
		1	
		1	
	FINE GRID	1	
	DISTANCE	0.0	
1	1	0.0	73192
	2	0.03	74147
2	3	0.06	75127
	4	0.08	75180
3	5	0.10	76167
	6	0.57	75104
	7	1.04	74129
	8	1.51	74136
	9	1.98	75132
	10	2.45	77127
4	11	2.92	80108
	12	3.14	81149
5	13	3.35	85127
	14	3.57	89196
6	15	3.79	94142
	16	4.01	96189
7	17	4.23	94142
	18	4.45	89196
8	19	4.67	85128
	20	4.89	81156
9	21	5.10	80146
	22	5.18	76158
	23	5.25	73133
10	24	5.32	69173
11	25	5.35	69116

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	76.000000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTAT) = 4.45958938D-02

ELAPSED CPU TIME IS 0.24 SECONDS

THE MAXIMUM TEMPERATURE IS - 9.68924D+01 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 16

THE MINIMUM TEMPERATURE IS - 6.91594D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 25

NO TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF NODE TEMP DIFF	MAX TEMP CHANGE	NODE TEMP CHANGE	MAX PERCENT TEMP CHANGE	
17 5.04906D+00	1 8	37280-05	1.055000+00	0.0	0.0	0.0	1 1	320700-04	16.2	338120-01	9.2	452530-01
17 5.04906D+00	2 9	82390-06	1.055000+00	0.0	0.0	0.0	2 2	731740-06				
17 5.04906D+00	1 5	298500-06	1.055000+00	0.0	0.0	0.0						

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
 \*\*\*\*\* NODE NUMBERS AND TEMPERATURES \*\*\*\*\*

NUMBER OF TIME STEPS	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF NODE TEMP DIFF	MAX TEMP CHANGE	NODE TEMP CHANGE	MAX PERCENT TEMP CHANGE	
17	5.04910+00	1 7	398610+01	3 7	544490+01	5 7	682840+01	11 8	015620+01	13 8	531740+01		
		15 9	432070-01	17 9	432080+01	19 8	532980+01	21 8	055510+01	24 6	961980+01		
		25 6	921080+01			0.0	0.0						
18	5.103070+00	1 9	979010-05	1.055000+00	0.0	0.0	0.0	1 1	387820-04				
18 5.103070+00	3 3	106450-06	1.055000+00	0.0	0.0	0.0	0.0	2 1	715880-06	16.2	428100-01	9.2	583510-01
18 5.103070+00	1 7	445960-06	1.055000+00	0.0	0.0	0.0	0.0						
18 5.103070+00	1 7	405740+01	1.055000+00	3 7	562220+01	5 7	699310+01	11 8	024360+01	13 8	536640+01		
18 5.103070+00	15 9	421090+01	17 9	421110+01	19 8	538220+01	21 8	066290+01	24 6	956390+01			
		25 6	931680+01			0.0	0.0						
19 5.162370+00	1 1	210260-04	1.055000+00	0.0	0.0	0.0	0.0	1 1	451450-04				
19 5.162370+00	3 4	137530-06	1.055000+00	0.0	0.0	0.0	0.0	2 1	961750-06	16.2	516780-01	8.2	719500-01
19 5.162370+00	1 9	335090-06	1.055000+00	0.0	0.0	0.0	0.0						
19 5.162370+00	1 7	413040+01	3 7	580440+01	5 7	716560+01	11 8	034160+01	13 8	542040+01			
19 5.162370+00	15 9	408830+01	17 9	408860+01	19 8	548040+01	21 8	078370+01	24 6	957240+01			
		25 6	948600+01			0.0	0.0						
20 5.227670+00	1 1	450730-04	1.055000+00	0.0	0.0	0.0	0.0	1 1	517210-04				
20 5.227670+00	3 5	537080-06	1.055000+00	0.0	0.0	0.0	0.0	2 2	554640-06	16.2	604420-01	25.3	476360-01
20 5.227670+00	2 8	814240-07	1.055000+00	0.0	0.0	0.0	0.0						
20 5.227670+00	1 7	420500+01	3 7	599120+01	5 7	734600+01	11 8	046000+01	13 8	547950+01			
20 5.227670+00	15 9	395220+01	17 9	395270+01	19 8	550450+01	21 8	091830+01	24 6	965570+01			
		25 6	972760+01			0.0	0.0						
21 5.299490+00	1 1	708800-04	1.055000+00	0.0	0.0	0.0	0.0	1 1	605260-04				
21 5.299490+00	3 7	264750-06	1.055000+00	0.0	0.0	0.0	0.0	2 2	919950-06	25.3	236490-01	25.4	641630-01
21 5.299490+00	2 1	163930-06	1.055000+00	0.0	0.0	0.0	0.0						
21 5.299490+00	1 7	428100+01	3 7	618260+01	5 7	753440+01	11 8	059070+01	13 8	554370+01			
21 5.299490+00	15 9	380240+01	17 9	380310+01	19 8	557460+01	21 8	106740+01	24 6	98730+01			
		25 7	005120+01			0.0	0.0						
22 5.378490+00	1 2	014160-04	1.055000+00	0.0	0.0	0.0	0.0	1 1	764690-04				
22 5.378490+00	3 9	384660-06	1.055000+00	0.0	0.0	0.0	0.0	2 3	408750-06	25.4	162570-01	25.5	942190-01
22 5.378490+00	2 1	550470-06	1.055000+00	0.0	0.0	0.0	0.0						
22 5.378490+00	1 7	435810+01	3 7	637820+01	5 7	773070+01	11 8	073580+01	13 8	561270+01			
22 5.378490+00	15 9	363850+01	17 9	363960+01	19 8	565050+01	21 8	123140+01	24 6	009580+01			
		25 7	046750+01			0.0	0.0						
23 5.465400+00	1 2	333160-04	1.055000+00	0.0	0.0	0.0	0.0	1 1	937430-04				
23 5.465400+00	4 3	164230-06	1.055000+00	0.0	0.0	0.0	0.0	2 3	423580-06	25.5	198610-01	25.7	377320-01
23 5.465400+00	2 2	008740-06	1.055000+00	0.0	0.0	0.0	0.0						
23 5.465400+00	1 7	443620+01	3 7	657810+01	5 7	793490+01	11 8	089680+01	13 8	568630+01			
23 5.465400+00	15 9	346040+01	17 9	346190+01	19 8	573210+01	21 8	141070+01	24 6	047640+01			
		25 7	098730+01			0.0	0.0						
24 5.560990+00	1 5	992330-04	1.055000+00	0.0	0.0	0.0	0.0	1 2	595420-04				
24 5.560990+00	4 4	463560-06	1.055000+00	0.0	0.0	0.0	0.0	2 7	450760-06	25.6	976880-01	25.9	828350-01
24 5.560990+00	2 5	120770-06	1.055000+00	0.0	0.0	0.0	0.0						
24 5.560990+00	1 7	451530+01	3 7	678210+01	5 7	814710+01	11 8	107350+01	13 8	516410+01			
24 5.560990+00	15 9	326820+01	17 9	327040+01	19 8	581910+01	21 8	160580+01	24 6	099640+01			
		25 7	168500+01			0.0	0.0						
25 5.656590+00	1 2	457650-03	1.055000+00	0.0	0.0	0.0	0.0	1 5	399550-04				
25 5.656590+00	4 4	067010-06	1.055000+00	0.0	0.0	0.0	0.0	2 2	823070-05				
25 5.656590+00	3 2	127560-06	1.055000+00	0.0	0.0	0.0	0.0	3 2	222010-06	25.1	163010+00	25.1	650290+00
25 5.656590+00	2 1	491550-06	1.055000+00	0.0	0.0	0.0	0.0						
25 5.656590+00	1 2	633240-05	1.055000+00	0.0	0.0	0.0	0.0	1 4	432210-05				
25 5.656590+00	2 1	670420-06	1.055000+00	0.0	0.0	0.0	0.0	2 4	813380-07	25.6	729170-01	25.9	387140-01
25 5.656590+00	1 1	095420-06	1.055000+00	0.0	0.0	0.0	0.0	1 1	81740+01	13 8	580720+01		
25 5.656590+00	1 7	456590+01	3 7	689310+01	5 7	826380+01	11 8	17140+01	13 8	580720+01			
25 5.656590+00	15 9	315900+01	17 9	316270+01	19 8	586770+01	21 8	17140+01	24 6	138360+01			





34	5.99800+00	1 7.483260+01	3 7.755550+01	5 7.898720+01	11 8.184360+01	13 8.607400+01
		15 9.245430+01	17 9.246150+01	19 8.617330+01	21 8.245360+01	24 7.549530+01
		25 7.891030+01		0.0	1 1.178920.05	25 2.636800.01
35	6.007960+00	1 6.970010-06	1 0.550000+00	0.0	0.0	0.0
		1 6.970010-06	1 0.550000+00	0.0	0.0	0.0
		1 4.652550-07	1 0.550000+00	0.0	0.0	0.0
35	6.007960+00	1 7.483980+01	3 7.758110+01	5 7.900440+01	11 8.186020+01	13 8.608020+01
		15 9.243700+01	17 9.244440+01	19 8.618060+01	21 8.247210+01	24 7.667130+01
		25 7.911920+01				

IBM3033/ 0  
20.57.55 11-16-89

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 35 TIME STEPS, TIME = 6.00796D+00

HEATING6 02/12/83  
W9XNP110

GROSS GRID	1	1
FINE GRID	1	1
DISTANCE	O.O	
1	0.0	74184
2	0.03	76116
3	0.06	77158
4	0.08	78122
5	0.10	79100
6	0.57	77189
7	1.04	77136
8	1.51	77150
9	1.98	78134
10	2.45	79183
11	2.92	81186
12	3.14	83126
13	3.35	86108
14	3.57	89153
15	3.79	92144
16	4.01	93161
17	4.23	92144
18	4.45	89156
19	4.67	86118
20	4.89	83154
21	5.10	82147
22	5.18	78159
23	5.25	76114
24	5.32	75167
25	5.35	79112

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	76.317161
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 1.000000000D-02

ELAPSED CPU TIME IS 0.50 SECONDS

THE MAXIMUM TEMPERATURE IS - 9.36058D+01 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 16

THE MINIMUM TEMPERATURE IS - 7.48398D+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1





15	9	167880+01	17	9	169520+01	19	8	648870+01	21	8	331070+01	24	3	648750+01
25	8	980050+01												
57	6	522080+00	1	7	246640-06	1	055000+00	0	0	0	0	1	1	996740-05
57	6	522080+00	1	7	246640-06	1	055000+00	0	0	0	0	2	1	047950-06
57	6	522080+00	1	1	425160-05	1	055000+00	0	0	0	0	11	8	264770+01
57	6	522080+00	1	1	510750+01	3	782890+01	19	8	650910+01	21	8	337030+01	
57	6	52210+00	1	7	162700+01	17	9	164420+01	19	8	650910+01	21	8	337030+01
58	6	558000+00	1	3	691410-05	1	055000+00	0	0	0	0	1	2	906560-05
58	6	558000+00	2	3	774500-06	1	055000+00	0	0	0	0	2	7	145200-07
58	6	558000+00	1	1	390260-06	1	055000+00	0	0	0	0	11	8	269770+01
58	6	558000+00	1	7	512380+01	3	783320+01	19	8	652910+01	21	8	342960+01	
58	6	558000+00	1	7	512380+01	3	783320+01	19	8	652910+01	21	8	342960+01	
59	6	593920+00	1	2	254870-05	1	055000+00	0	0	0	0	1	2	663760-05
59	6	593920+00	2	2	545650-06	1	055000+00	0	0	0	0	2	4	946960-07
59	6	593920+00	1	9	916500-07	1	055000+00	0	0	0	0	11	8	274710+01
59	6	593920+00	1	7	513980+01	3	7837500+01	19	8	654870+01	21	8	348810+01	
59	6	593920+00	1	7	513980+01	3	7837500+01	19	8	654870+01	21	8	348810+01	
60	6	629840+00	1	1	464520-05	1	055000+00	0	0	0	0	1	2	482380-05
60	6	629840+00	2	1	841410-06	1	055000+00	0	0	0	0	2	3	751960-07
60	6	629840+00	1	7	742100-07	1	055000+00	0	0	0	0	11	8	279590+01
60	6	629840+00	1	7	515560+01	3	7841700+01	19	8	656810+01	21	8	354680+01	
60	6	629840+00	1	7	515560+01	3	7841700+01	19	8	656810+01	21	8	354680+01	
61	6	665760+00	1	1	027350-05	1	055000+00	0	0	0	0	1	2	333960-05
61	6	665760+00	2	1	427000-06	1	055000+00	0	0	0	0	2	3	081110-07
61	6	665760+00	1	6	495730-07	1	055000+00	0	0	0	0	11	8	284400+01
61	6	66580+00	1	7	517120+01	3	7845830+01	19	8	658710+01	21	8	360470+01	
61	6	66580+00	1	7	517120+01	3	7845830+01	19	8	658710+01	21	8	360470+01	
62	6	701680+00	1	7	627260-06	1	055000+00	0	0	0	0	1	2	169680-05
62	6	701680+00	1	7	627260-06	1	055000+00	0	0	0	0	2	1	409300-06
62	6	701680+00	1	1	809070-06	1	055000+00	0	0	0	0	11	8	289450+01
62	6	70170+00	1	7	518650+01	3	7849910+01	19	8	660580+01	21	8	366230+01	
62	6	70170+00	1	7	518650+01	3	7849910+01	19	8	660580+01	21	8	366230+01	
63	6	737600+00	1	6	360230-06	1	055000+00	0	0	0	0	1	2	059930-05
63	6	737600+00	1	6	360230-06	1	055000+00	0	0	0	0	2	1	030030-06
63	6	737600+00	1	1	590260-06	1	055000+00	0	0	0	0	11	8	293810+01
63	6	737600+00	1	7	520160+01	3	7853920+01	19	8	662420+01	21	8	371940+01	
63	6	737600+00	1	7	520160+01	3	7853920+01	19	8	662420+01	21	8	371940+01	
64	6	773520+00	1	5	379020-06	1	055000+00	0	0	0	0	1	1	951340-05
64	6	773520+00	1	5	379020-06	1	055000+00	0	0	0	0	2	9	143850-07
64	6	773520+00	1	1	349140-06	1	055000+00	0	0	0	0	11	8	298450+01
64	6	77350+00	1	7	521640+01	3	7857870+01	19	8	664240+01	21	8	377620+01	
64	6	77350+00	1	7	521640+01	3	7857870+01	19	8	664240+01	21	8	377620+01	
65	6	809440+00	1	4	696610-06	1	055000+00	0	0	0	0	1	1	847140-05
65	6	809440+00	1	4	696610-06	1	055000+00	0	0	0	0	2	8	217160-07
65	6	809440+00	1	1	659190-06	1	055000+00	0	0	0	0	11	8	303020+01
65	6	80940+00	1	7	523100+01	3	7861760+01	19	8	666020+01	21	8	383260+01	
65	6	80940+00	1	7	523100+01	3	7861760+01	19	8	666020+01	21	8	383260+01	
66	6	845360+00	1	4	147180-06	1	055000+00	0	0	0	0	1	1	749530-05
66	6	845360+00	1	4	147180-06	1	055000+00	0	0	0	0	2	7	534600-07
66	6	845360+00	1	1	051280-06	1	055000+00	0	0	0	0	11	8	307520+01
66	6	84540+00	1	7	524540+01	3	7865600+01	19	8	667780+01	21	8	388850+01	
66	6	84540+00	1	7	524540+01	3	7865600+01	19	8	667780+01	21	8	388850+01	
67	6	881280+00	1	3	720810-06	1	055000+00	0	0	0	0	1	1	659660-05
67	6	881280+00	1	3	720810-06	1	055000+00	0	0	0	0	2	7	094650-07
67	6	881280+00	1	9	229720-07	1	055000+00	0	0	0	0	11	8	311960+01
67	6	88130+00	1	1	113500+01	3	7869380+01	19	8	670290+01	21	8	401870+01	

68	6.91720+00	15 9.11445D+01	17 9.11704D+01	19 8.66951D+01	21 8.39441D+01	24 9.60173D+01	
		25 9.99577+01		0.0	0.0		
68	6.91720+00	1 3.23477D-06	1.05500D+00	0.0	0.0	1 1.56800D-05	
		1 3.23477D-03	1.05500D+00	0.0	0.0	2 6.65222D-07	25 9.71276D-01
68	6.91720+00	1 8.15963D-07	1.05500D+00	0.0	0.0	11 8.31634D+01	13 8.65160D+01
		1 7.52736D+01	3 7.87310D+01	5 8.02912D+01	11 8.31634D+01	24 9.69437D+01	
68	6.91720+00	15 9.10956D+01	17 9.11264D+01	19 8.67121D+01	21 8.39993D+01		
		25 1.00938D+02		0.0	0.0		
69	6.95312D+00	1 2.87088D-06	1.05500D+00	0.0	0.0	1 1.48443D-05	
		1 2.87088D-06	1.05500D+00	0.0	0.0	2 6.29100D-07	25 9.75509D-01
69	6.95312D+00	1 7.24076D-07	1.05500D+00	0.0	0.0	11 8.32066D+01	13 8.65288D+C1
		1 7.52873D+01	3 7.87677D+01	5 8.03227D+01	11 8.32066D+01	24 9.78769D+01	
69	6.9531D+00	15 9.10553D+01	17 9.10831D+01	19 8.67289D+01	21 8.40531D+01		
		25 1.01914D+02		0.0	0.0		
70	6.97656D+00	1 8.01792D-06	1.05500D+00	0.0	0.0	1 1.15795D-05	
		1 8.01792D-05	1.05500D+00	0.0	0.0	2 8.57867D-07	25 6.47052D-01
70	6.97656D+00	1 1.24428D-06	1.05500D+00	0.0	0.0	11 8.32345D+01	13 8.65370D+01
		1 7.52969D+01	3 7.87913D+01	5 8.03595D+01	11 8.32345D+01	24 9.84900D+01	
70	6.9766D+00	15 9.10267D+01	17 9.10551D+01	19 8.67397D+01	21 8.40897D+01		
		25 1.02561D+02		0.0	0.0		
71	7.00000D+00	1 2.49912D-06	1.05500D+00	0.0	0.0	1 6.10058D-06	
		1 2.49912D-06	1.05500D+00	0.0	0.0	2 2.20877D-07	25 6.46592D-01
71	7.00000D+00	1 1.57225D-07	1.05500D+00	0.0	0.0	11 8.32621D+01	13 8.65451D+01
		1 7.53059D+01	3 7.88148D+01	5 8.03861D+01	11 8.32621D+01	24 9.91065D+01	
71	7.0000D+00	15 9.09983D+01	17 9.10274D+01	19 8.67504D+01	21 8.41251D+01		
		25 1.03208D+02		0.0	0.0		

IBM3033/ 0  
20 57 55 11 16 89

HEATING6 02/12/83  
WBXNP110  
COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 71 TIME STEPS, TIME = 7.000000+00

GROSS GRID	1
1	75131
2	77103
3	78181
4	79155
5	80139
6	79176
7	79153
8	79177
9	80149
10	81168
11	83126
12	84142
13	86155
14	89101
15	91100
16	91177
17	91103
18	89110
19	86175
20	84186
21	84113
22	85120
23	89126
24	99111
25	103121

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	77.210000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 2.343945040-02

ELAPSED CPU TIME IS 0.85 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.032080+02 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 25

THE MINIMUM TEMPERATURE IS - 7.530590+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO	MAX HEAT	BETA	1.1 NORM OF	RHO	RHO	NO	1.1 NORM OF	NO	MAX TEMP	MAX PERCENT	
TIME	RESIDUAL	ITER	RESIDUAL	TEMP DIFF	{ITERATION}	{JACOBI}	ITER	TEMP DIFF	CHANGE	NO	CHANGE	TEMP CHANGE	
72	7.02578D+00	1	3.10037D-06	1.05500D+00	0.0	0.0	0.0	1.6	86161D-06	25	7.10211D-01	25.6	88139D-01
72	7.02578D+00	1	3.10037D-06	1.05500D+00	0.0	0.0	0.0	2.2	77651D-07	25	7.10211D-01	25.6	88139D-01
72	7.02578D+00	1	2.31173D-07	1.05500D+00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
 \*\*\*\*\* NODE NUMBERS AND TEMPERATURES \*\*\*\*\*

NUMBER OF	TIME	NO	MAX HEAT	BETA	1.1 NORM OF	RHO	RHO	NO	1.1 NORM OF	NO	MAX TEMP	MAX PERCENT	
TIME STEPS		ITER	RESIDUAL	TEMP DIFF	{ITERATION}	{JACOBI}	ITER	TEMP DIFF	CHANGE	NO	CHANGE	TEMP CHANGE	
72	7.0258D+00	1	1.753156D+01	3.788403D+01	5.804150D+01	11.832922D+01	13.865538D+01	11	8.32922D+01	13	8.65538D+01		
			15.909674D+01	17.909971D+01	19.867621D+01	21.841639D+01	24.997879D+01	21	8.41639D+01	24	9.97879D+01		
			25.103918D+02										
73	7.05415D+00	1	2.47875D-06	1.05500D+00	0.0	0.0	0.0	1.7	36240D-06	25	7.80762D-01	24.7	54271D-01
73	7.05415D+00	1	2.47875D-06	1.05500D+00	0.0	0.0	0.0	2.2	94509D-07	25	7.80762D-01	24.7	54271D-01
73	7.05415D+00	1	1.75596D-07	1.05500D+00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
73	7.0541D+00	1	1.753259D+01	3.788681D+01	5.804465D+01	11.833250D+01	13.865633D+01	11	8.33250D+01	13	8.65633D+01		
			15.909337D+01	17.909642D+01	19.867748D+01	21.842064D+01	24.100541D+02	21	8.42064D+01	24	1.00541D+02		
			25.104698D+02										
74	7.08534D+00	1	1.84069D-06	1.05500D+00	0.0	0.0	0.0	1.8	06883D-06	25	8.56823D-01	24.8	26530D-01
74	7.08534D+00	1	1.84069D-06	1.05500D+00	0.0	0.0	0.0	2.3	27981D-07	25	8.56823D-01	24.8	26530D-01
74	7.08534D+00	1	9.05591D-08	1.05500D+00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
74	7.0853D+00	1	1.753370D+01	3.788983D+01	5.804807D+01	11.833606D+01	13.865735D+01	11	8.33606D+01	13	8.65735D+01		
			15.908970D+01	17.909284D+01	19.867886D+01	21.842528D+01	24.101372D+02	21	8.42528D+01	24	1.01372D+02		
			25.105557D+02										
75	7.11966D+00	1	1.42395D-06	1.05500D+00	0.0	0.0	0.0	1.9	25721D-06	25	9.45069D-01	24.9	04665D-01
75	7.11966D+00	1	1.42395D-06	1.05500D+00	0.0	0.0	0.0	2.3	81836D-07	25	9.45069D-01	24.9	04665D-01
75	7.11966D+00	1	1.49559D-07	1.05500D+00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
75	7.1197D+00	1	1.753490D+01	3.789310D+01	5.805178D+01	11.833593D+01	13.865846D+01	11	8.33593D+01	13	8.65846D+01		
			15.908572D+01	17.908895D+01	19.868036D+01	21.843036D+01	24.102289D+02	21	8.43036D+01	24	1.02289D+02		
			25.106502D+02										
76	7.15570D+00	1	1.63893D-06	1.05500D+00	0.0	0.0	0.0	1.1	04368D-05	25	9.94513D-01	24.9	44395D-01
76	7.15570D+00	1	1.63893D-06	1.05500D+00	0.0	0.0	0.0	2.4	92671D-07	25	9.94513D-01	24.9	44395D-01
76	7.15570D+00	1	3.64617D-07	1.05500D+00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
76	7.1557D+00	1	1.753615D+01	3.789649D+01	5.805563D+01	11.834394D+01	13.865959D+01	11	8.34394D+01	13	8.65959D+01		
			15.908158D+01	17.908492D+01	19.868192D+01	21.843566D+01	24.103255D+02	21	8.43566D+01	24	1.03255D+02		
			25.107497D+02										
77	7.19195D+00	1	2.92752D-06	1.05500D+00	0.0	0.0	0.0	1.1	07161D-05	25	1.00361D+00	24.9	44017D-01
77	7.19195D+00	1	2.92752D-06	1.05500D+00	0.0	0.0	0.0	2.5	79850D-07	25	1.00361D+00	24.9	44017D-01
77	7.19195D+00	1	5.62087D-07	1.05500D+00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
77	7.1919D+00	1	1.753740D+01	3.789885D+01	5.805944D+01	11.834792D+01	13.866071D+01	11	8.34792D+01	13	8.66071D+01		
			15.907748D+01	17.908092D+01	19.868346D+01	21.844095D+01	24.104229D+02	21	8.44095D+01	24	1.04229D+02		
			25.108501D+02										
78	7.22843D+00	1	1.64909D-06	1.05500D+00	0.0	0.0	0.0	1.1	01892D-05	25	1.01228D+00	24.9	43956D-01
78	7.22843D+00	1	1.64909D-06	1.05500D+00	0.0	0.0	0.0	2.4	86688D-07	25	1.01228D+00	24.9	43956D-01
78	7.22843D+00	1	3.90430D-07	1.05500D+00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
78	7.2284D+00	1	1.753864D+01	3.790319D+01	5.806323D+01	11.835186D+01	13.866180D+01	11	8.35186D+01	13	8.66180D+01		
			15.907340D+01	17.907695D+01	19.868499D+01	21.844525D+01	24.105213D+02	21	8.44525D+01	24	1.05213D+02		
			25.109513D+02										
79	7.26514D+00	1	1.35418D-06	1.05500D+00	0.0	0.0	0.0	1.9	65819D-06	25	1.02034D+00	24.9	43755D-01
79	7.26514D+00	1	1.35418D-06	1.05500D+00	0.0	0.0	0.0	2.4	23615D-07	25	1.02034D+00	24.9	43755D-01
79	7.26514D+00	1	2.66728D-07	1.05500D+00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
79	7.2651D+00	1	1.753987D+01	3.790649D+01	5.806698D+01	11.835578D+01	13.866289D+01	11	8.35578D+01	13	8.66289D+01		
			15.906935D+01	17.907300D+01	19.868651D+01	21.845154D+01	24.106206D+02	21	8.45154D+01	24	1.06206D+02		
			25.110533D+02										
80	7.30210D+00	1	1.35686D-06	1.05500D+00	0.0	0.0	0.0	1.9	23607D-06	25	1.02836D+00	24.9	43481D-01
80	7.30210D+00	1	1.35686D-06	1.05500D+00	0.0	0.0	0.0	2.3	93808D-07	25	1.02836D+00	24.9	43481D-01
80	7.30210D+00	1	2.20073D-07	1.05500D+00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
80	7.3021D+00	1	1.754110D+01	3.790977D+01	5.807070D+01	11.835966D+01	13.866395D+01	11	8.35966D+01	13	8.66395D+01		
			15.906533D+01	17.906909D+01	19.868803D+01	21.845684D+01	24.107208D+02	21	8.45684D+01	24	1.07208D+02		
			25.111561D+02										
81	7.33931D+00	1	1.36110D-06	1.05500D+00	0.0	0.0	0.0	1.8	80693D-06	25	1.03637D+00	24.9	43169D-01
81	7.33931D+00	1	1.36110D-06	1.05500D+00	0.0	0.0	0.0	2.3	67259D-07	25	1.03637D+00	24.9	43169D-01
81	7.33931D+00	1	2.21230D-07	1.05500D+00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
81	7.3393D+00	1	1.754231D+01	3.791302D+01	5.807439D+01	11.836351D+01	13.866500D+01	11	8.36351D+01	13	8.66500D+01		
			15.907439D+01	17.909302D+01	19.868999D+01	21.846351D+01	24.108208D+02	21	8.46351D+01	24	1.08208D+02		



	15 9. 061330+01	17 9. 065200+01	19 8. 689530+01	21 8. 462130+01	24 1. 082190+02
	25 1. 125980+02				
82 7. 376790+00	1 1. 367480-06	1 055000+00 0 0	0 0 0 0	1 8. 377140-06	
82 7. 376790+00	1 1. 367480-06	1 055000+00 0 0	0 0 0 0	2 3. 603080-07	25 1. 044400+00
82 7. 376790+00	1 2. 234100-07	1 055000+00 0 0	0 0 0 0	11 8. 367330+01	24 9. 428830-01
	1 7. 543520+01	3 7. 916240+01	5 8. 078050+01	21 8. 467430+01	24 1. 092400+02
82 7. 37680+00	15 9. 057350+01	17 9. 061330+01	19 8. 691030+01		
	25 1. 136420+02				
83 7. 414560+00	1 1. 375960-06	1 055000+00 0 0	0 0 0 0	1 7. 981090-06	
83 7. 414560+00	1 1. 375960-06	1 055000+00 0 0	0 0 0 0	2 3. 662230-07	25 1. 052530+00
83 7. 414560+00	1 2. 262980-07	1 055000+00 0 0	0 0 0 0	11 8. 371130+01	24 9. 425810-01
	1 7. 544710+01	3 7. 919450+01	5 8. 081690+01	21 8. 472740+01	24 1. 102700+02
83 7. 41460+00	15 9. 052400+01	17 9. 057500+01	19 8. 692510+01		
	25 1. 146950+02				
84 7. 452620+00	1 1. 386400-06	1 055000+00 0 0	0 0 0 0	1 7. 644750-06	
84 7. 452620+00	1 1. 386400-06	1 055000+00 0 0	0 0 0 0	2 3. 533880-07	25 1. 060940+00
84 7. 452620+00	1 2. 297390-07	1 055000+00 0 0	0 0 0 0	11 8. 374890+01	24 9. 422940-01
	1 7. 545900+01	3 7. 922620+01	5 8. 085300+01	21 8. 478050+01	24 1. 113090+02
84 7. 45260+00	15 9. 049470+01	17 9. 053690+01	19 8. 693990+01		
	25 1. 157560+02				
85 7. 490990+00	1 1. 398610-06	1 055000+00 0 0	0 0 0 0	1 7. 401920-06	
85 7. 490990+00	1 1. 398610-06	1 055000+00 0 0	0 0 0 0	2 3. 659750-07	25 1. 069460+00
85 7. 490990+00	1 2. 336460-07	1 055000+00 0 0	0 0 0 0	11 8. 378630+01	24 9. 420340-01
	1 7. 547080+01	3 7. 925780+01	5 8. 088880+01	21 8. 483370+01	24 1. 123570+02
85 7. 49100+00	15 9. 045560+01	17 9. 049900+01	19 8. 695470+01		
	25 1. 168250+02				
86 7. 529690+00	1 4. 591310-06	1 055000+00 0 0	0 0 0 0	1 8. 213880-06	
86 7. 529690+00	1 4. 591310-06	1 055000+00 0 0	0 0 0 0	2 5. 953190-07	25 1. 075480+00
86 7. 529690+00	1 6. 197070-07	1 055000+00 0 0	0 0 0 0	11 8. 382340+01	24 9. 414500-01
	1 7. 548250+01	3 7. 928910+01	5 8. 092440+01	21 8. 488700+01	24 1. 134150+02
86 7. 52970+00	15 9. 041680+01	17 9. 046130+01	19 8. 696940+01		
	25 1. 179010+02				
87 7. 568730+00	1 1. 322980-05	1 055000+00 0 0	0 0 0 0	1 1. 057470-05	
87 7. 568730+00	1 1. 322980-05	1 055000+00 0 0	0 0 0 0	2 2. 670410-07	25 1. 075610+00
87 7. 568730+00	1 5. 543060-07	1 055000+00 0 0	0 0 0 0	11 8. 386030+01	24 9. 400690-01
	1 7. 549410+01	3 7. 932030+01	5 8. 095980+01	21 8. 492050+01	24 1. 144810+02
87 7. 56870+00	15 9. 037810+01	17 9. 042390+01	19 8. 698410+01		
	25 1. 189760+02				
88 7. 608190+00	1 8. 188830-06	1 055000+00 0 0	0 0 0 0	1 9. 647950-06	
88 7. 608190+00	1 8. 188830-06	1 055000+00 0 0	0 0 0 0	2 8. 974660-07	25 1. 080220+00
88 7. 608190+00	1 1. 294530-06	1 055000+00 0 0	0 0 0 0	11 8. 389700+01	24 9. 385080-01
	1 7. 550570+01	3 7. 935120+01	5 8. 099490+01	21 8. 499410+01	24 1. 155560+02
88 7. 60820+00	15 9. 033950+01	17 9. 038650+01	19 8. 699870+01		
	25 1. 200570+02				
89 7. 648140+00	1 6. 274670-06	1 055000+00 0 0	0 0 0 0	1 9. 303850-06	
89 7. 648140+00	1 6. 274670-06	1 055000+00 0 0	0 0 0 0	2 7. 955580-07	25 1. 087760+00
89 7. 648140+00	1 1. 055550-06	1 055000+00 0 0	0 0 0 0	11 8. 393350+01	24 9. 379290-01
	1 7. 551720+01	3 7. 938210+01	5 8. 103000+01	21 8. 504810+01	24 1. 166390+02
89 7. 64810+00	15 9. 030100+01	17 9. 034930+01	19 8. 701340+01		
	25 1. 211440+02				
90 7. 68860+00	1 4. 815030-06	1 055000+00 0 0	0 0 0 0	1 8. 925170-06	
90 7. 68860+00	1 4. 815030-06	1 055000+00 0 0	0 0 0 0	2 7. 335790-07	25 1. 096970+00
90 7. 68860+00	1 9. 070710-07	1 055000+00 0 0	0 0 0 0	11 8. 396590+01	24 9. 376090-01
	1 7. 552870+01	3 7. 941290+01	5 8. 106490+01	21 8. 510240+01	24 1. 177330+02
90 7. 68860+00	15 9. 026250+01	17 9. 031220+01	19 8. 702810+01		
	25 1. 222410+02				
91 7. 729590+00	1 4. 440980-06	1 055000+00 0 0	0 0 0 0	1 8. 671510-06	
91 7. 729590+00	1 4. 440980-06	1 055000+00 0 0	0 0 0 0	2 7. 152070-07	25 1. 106880+00
91 7. 729590+00	1 8. 468490-07	1 055000+00 0 0	0 0 0 0	11 8. 400620+01	24 9. 374920-01
	1 7. 554020+01	3 7. 944350+01	5 8. 109970+01	21 8. 515700+01	24 1. 188370+02
91 7. 72960+00	15 9. 022410+01	17 9. 027510+01	19 8. 704280+01		
	25 1. 233480+02				
92 7. 771130+00	1 3. 905570-06	1 055000+00 0 0	0 0 0 0	1 8. 341960-06	
92 7. 771130+00	1 3. 905570-06	1 055000+00 0 0	0 0 0 0	2 6. 986650-07	25 1. 117480+00
92 7. 771130+00	1 8. 151000-07	1 055000+00 0 0	0 0 0 0	11 8. 404110+01	24 9. 374790-01
	1 7. 541000+01	3 7. 947410+01	5 8. 119410+01	21 8. 519410+01	24 1. 175530+02

93	7.81320+00	15 9.018570+01	17 9.023810+01	19 8.705750+01	21 8.521200+01	24 1.199510+02	
		25 1.244660+02	0.0	0.0	1 8.404970-06		24 9.375070-01
		1 4.078220-06	1.055000+00	0.0	2 7.077630-07	25 1.128130+00	
		1 4.078220-06	1.055000+00	0.0	11 8.407830+01	13 8.676410+01	
		1 8.332630-07	1.055000+00	0.0	21 8.526730+01	24 1.210750+02	
		1 7.556290+01	3 7.950450+01	5 8.116890+01			
		15 9.014740+01	17 9.020120+01	19 8.707230+01			
		25 1.255940+02	0.0	0.0	1 8.435740-06		24 9.375420-01
		1 3.95240-06	1.055000+00	0.0	2 7.043620-07	25 1.139010+00	
		1 3.95240-06	1.055000+00	0.0	11 8.411410+01	13 8.677280+01	
		1 8.248650-07	1.055000+00	0.0	21 8.532300+01	24 1.232100+02	
		1 7.557430+01	3 7.953490+01	5 8.120340+01			
		1 7.557430+01	3 7.953490+01	19 8.708720+01			
		15 9.010910+01	17 9.016440+01	0.0	1 8.430220-06		24 9.376040-01
		25 1.267330+02	0.0	0.0	2 6.901810-07	25 1.150120+00	
		1 3.793900-06	1.055000+00	0.0	11 8.414980+01	13 8.678130+01	
		1 3.793900-06	1.055000+00	0.0	21 8.537900+01	24 1.233560+02	
		1 7.759260-07	1.055000+00	0.0	5 8.123760+01		
		1 7.558560+01	3 7.956510+01	19 8.710200+01			
		15 9.007090+01	17 9.012770+01	0.0	1 8.538500-06		24 9.376440-01
		25 1.278830+02	0.0	0.0	2 7.055800-07	25 1.161170+00	
		1 4.045690-06	1.055000+00	0.0	11 8.418520+01	13 8.678980+01	
		1 4.045690-06	1.055000+00	0.0	21 8.543530+01	24 1.245130+02	
		1 8.106500-07	1.055000+00	0.0	5 8.127180+01		
		1 7.555680+01	3 7.959510+01	19 8.711700+01			
		1 7.555680+01	3 7.959510+01	0.0	1 7.470820-06		24 6.048650-01
		15 9.003280+01	17 9.009110+01	0.0	2 8.266200-07	25 7.667570-01	
		25 1.290440+02	0.0	0.0	11 8.420800+01	13 8.679510+01	
		1 9.862460-06	1.055000+00	0.0	21 8.547180+01	24 1.252660+02	
		1 9.862460-06	1.055000+00	0.0	5 8.129370+01		
		1 1.307870-06	1.055000+00	0.0	19 8.712660+01		
		1 7.560450+01	3 7.961450+01	0.0	0.0		
		15 9.000820+01	17 9.006760+01	0.0	0.0		
		25 1.298110+02	0.0	0.0	1 4.372510-06		24 6.009800-01
		1 4.403740-06	1.055000+00	0.0	2 4.205510-07	25 7.620300-01	
		1 4.403740-06	1.055000+00	0.0	11 8.423050+01	13 8.680040+01	
		1 6.195010-07	1.055000+00	0.0	21 8.550820+01	24 1.260190+02	
		1 7.561200+01	3 7.963360+01	5 8.131530+01			
		15 8.998390+01	17 9.004430+01	19 8.713620+01			
		25 1.305730+02	0.0	0.0			

IRMJ033/ 0  
20 57 56 11-16-89

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 98 TIME STEPS, TIME = 8.000000+00

HEATING6 02/12/83  
W9XNP110

GROSS GRID	1	1
FINE GRID	1	1
DISTANCE	0.0	0.0
1	0.0	75161
2	0.03	77160
3	0.06	79163
4	0.08	80134
5	0.10	81137
6	0.57	81105
7	1.04	81105
8	1.51	81137
9	1.98	82102
10	2.45	82199
11	2.92	84123
12	3.14	85120
13	3.35	86180
14	3.57	88158
15	3.79	89198
16	4.01	90153
17	4.23	90104
18	4.45	88174
19	4.67	87114
20	4.89	85187
21	5.10	85151
22	5.18	94163
23	5.25	107115
10	5.32	126102
11	5.35	130157

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	78.640000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 2.855305360-02

ELAPSED CPU TIME IS 1.11 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.305730+02 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 25

THE MINIMUM TEMPERATURE IS - 7.551200+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHD (ITERATION)	RHD (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	MODE	MAX PERCENT TEMP CHANGE
99 8.0314D+00	1 5.33807D-06	1.05500D+00	3.79654D+01	5.81338D+01	11.84255D+01	13.86061D+01	1 5.10772D-06	25 8.32639D-01	24 6.56225D-01		
99 8.0314D+00	1 5.33807D-06	1.05500D+00	17.900189D+01	19.871467D+01	21.85548D+01	24.126846D+02	2 4.88731D-07				
99 8.0314D+00	1 7.81527D-07	1.05500D+00	0.0	0.0	0.0	0.0					
TABLE FOR SPECIAL MONITORING OF TEMPERATURES											
***** NODE NUMBERS AND TEMPERATURES *****											
100 8.06596D+00	1 4.79512D-06	1.05500D+00	0.0	0.0	0.0	0.0	1 5.83469D-06				
100 8.06596D+00	1 4.79512D-06	1.05500D+00	0.0	0.0	0.0	0.0	2 5.15607D-07	25 9.10813D-01	24 7.15359D-01		
100 8.06596D+00	1 7.93018D-07	1.05500D+00	0.0	0.0	0.0	0.0	11.842815D+01	13.868122D+01			
							21.855915D+01	24.127753D+02			
100 8.0666D+00	1 7.56281D+01	17.89914D+01	0.0	0.0	0.0	0.0	1 6.81242D-06				
							2 5.72192D-07	25 9.96321D-01	24 7.78695D-01		
101 8.10396D+00	1 4.65639D-06	1.05500D+00	0.0	0.0	0.0	0.0	11.843103D+01	13.868187D+01			
101 8.10396D+00	1 8.20738D-07	1.05500D+00	0.0	0.0	0.0	0.0	21.856391D+01	24.128748D+02			
							1 7.56371D+01	3.787014D+01			
101 8.1040D+00	1 7.56371D+01	3.787014D+01	17.89915D+01	19.871707D+01	21.856391D+01	24.128748D+02	1 7.95716D-06				
							2 6.58105D-07	25 1.09171D+00	24 8.46575D-01		
102 8.14577D+00	1 4.65862D-06	1.05500D+00	0.0	0.0	0.0	0.0	11.843413D+01	13.868257D+01			
102 8.14577D+00	1 4.65862D-06	1.05500D+00	0.0	0.0	0.0	0.0	21.856911D+01	24.129838D+02			
102 8.14577D+00	1 8.89620D-07	1.05500D+00	0.0	0.0	0.0	0.0	1 9.41110D-06				
							2 8.07253D-07	25 1.19555D+00	24 9.19321D-01		
102 8.1458D+00	1 7.56468D+01	3.787278D+01	17.89921D+01	19.871843D+01	21.856911D+01	24.129838D+02	1 9.41110D-06				
							2 8.07253D-07	25 1.19555D+00	24 9.19321D-01		
103 8.19175D+00	1 5.45560D-06	1.05500D+00	0.0	0.0	0.0	0.0	11.843749D+01	13.868332D+01			
103 8.19175D+00	1 5.45560D-06	1.05500D+00	0.0	0.0	0.0	0.0	21.857479D+01	24.131032D+02			
103 8.19175D+00	1 1.08408D-06	1.05500D+00	0.0	0.0	0.0	0.0	1 9.08284D-06				
							2 6.05046D-07	25 1.23314D+00	24 9.37381D-01		
103 8.1918D+00	1 7.56573D+01	3.7897564D+01	17.898941D+01	19.871992D+01	21.857479D+01	24.131032D+02	1 9.08284D-06				
							2 6.05046D-07	25 1.23314D+00	24 9.37381D-01		
104 8.23927D+00	1 2.13243D-06	1.05500D+00	0.0	0.0	0.0	0.0	11.844089D+01	13.868407D+01			
104 8.23927D+00	1 2.13243D-06	1.05500D+00	0.0	0.0	0.0	0.0	21.858062D+01	24.132260D+02			
104 8.23927D+00	1 4.35245D-07	1.05500D+00	0.0	0.0	0.0	0.0	1 9.07680D-06				
							2 5.97530D-07	25 1.24748D+00	24 9.37749D-01		
104 8.2393D+00	1 7.56680D+01	3.7897853D+01	17.898585D+01	19.872145D+01	21.858062D+01	24.132260D+02	1 9.07680D-06				
							2 5.97530D-07	25 1.24748D+00	24 9.37749D-01		
105 8.28743D+00	1 2.07801D-06	1.05500D+00	0.0	0.0	0.0	0.0	11.844426D+01	13.868481D+01			
105 8.28743D+00	1 2.07801D-06	1.05500D+00	0.0	0.0	0.0	0.0	21.858648D+01	24.133500D+02			
105 8.28743D+00	1 4.45356D-07	1.05500D+00	0.0	0.0	0.0	0.0	1 9.31578D-06				
							2 6.88435D-07	25 1.26063D+00	24 9.38109D-01		
105 8.2874D+00	1 7.56787D+01	3.798141D+01	17.898231D+01	19.872298D+01	21.858648D+01	24.133500D+02	1 9.31578D-06				
							2 6.88435D-07	25 1.26063D+00	24 9.38109D-01		
106 8.33622D+00	1 3.01868D-06	1.05500D+00	0.0	0.0	0.0	0.0	11.844761D+01	13.868553D+01			
106 8.33622D+00	1 3.01868D-06	1.05500D+00	0.0	0.0	0.0	0.0	21.859237D+01	24.134753D+02			
106 8.33622D+00	1 7.1618D-07	1.05500D+00	0.0	0.0	0.0	0.0	1 9.49978D-06				
							2 7.33646D-07	25 1.27286D+00	24 9.38243D-01		
106 8.3362D+00	1 7.56893D+01	3.798427D+01	17.897879D+01	19.872452D+01	21.859237D+01	24.134753D+02	1 9.49978D-06				
							2 7.33646D-07	25 1.27286D+00	24 9.38243D-01		
107 8.38563D+00	1 4.00990D-06	1.05500D+00	0.0	0.0	0.0	0.0	11.845093D+01	13.868623D+01			
107 8.38563D+00	1 4.00990D-06	1.05500D+00	0.0	0.0	0.0	0.0	21.859829D+01	24.136017D+02			
107 8.38563D+00	1 8.19034D-07	1.05500D+00	0.0	0.0	0.0	0.0	1 9.57472D-06				
							2 7.49168D-07	25 1.28502D+00	24 9.38266D-01		
107 8.3856D+00	1 7.56990D+01	3.798710D+01	17.897529D+01	19.872607D+01	21.859829D+01	24.136017D+02	1 9.57472D-06				
							2 7.49168D-07	25 1.28502D+00	24 9.38266D-01		
108 8.43565D+00	1 4.13718D-06	1.05500D+00	0.0	0.0	0.0	0.0	11.845422D+01	13.868692D+01			
108 8.43565D+00	1 4.13718D-06	1.05500D+00	0.0	0.0	0.0	0.0					
108 8.43565D+00	1 8.57198D-07	1.05500D+00	0.0	0.0	0.0	0.0					
108 8.4357D+00	1 7.57104D+01	3.798992D+01	17.89892D+01	19.872607D+01	21.859829D+01	24.136017D+02					

109	8.486300+00	15 8.954110+01	17 8.971800+01	19 8.727630+01	21 8.603230+01	24 1.372930+02
109	8.486300+00	25 1.419000+02	0 0	0 0	1 9.719340-06	24 9.382420-01
109	8.486300+00	1 4.618740-06	1 0.550000+00	0 0	2 7.809630-07	25 1.296990+00
109	8.486300+00	1 4.618740-06	1 0.550000+00	0 0	11 8.457480+01	13 8.687590+01
109	8.486300+00	1 9.305820-07	1 0.550000+00	0 0	21 8.610200+01	24 1.385810+02
109	8.486300+00	1 7.572090+01	3 7.992710+01	5 8.164780+01	19 8.729200+01	
109	8.486300+00	15 8.960440+01	17 8.969350+01	0 0	1 1.526380-05	24 9.365060-01
110	8.537590+00	25 1.431970+02	0 0	0 0	2 5.979030-07	
110	8.537590+00	1 2.610820-05	1 0.550000+00	0 0	11 8.460700+01	13 8.688250+01
110	8.537590+00	2 2.752360-06	1 0.550000+00	0 0	21 8.616200+01	24 1.398790+02
110	8.537590+00	1 1.819250-06	1 0.550000+00	0 0	5 8.167910+01	
110	8.537590+00	1 1.819250-06	1 0.550000+00	0 0	19 8.730770+01	
110	8.537590+00	15 8.956800+01	17 8.964910+01	0 0	1 3.117090-05	24 9.287300-01
110	8.537590+00	25 1.444910+02	0 0	0 0	2 1.877100-06	
111	8.589610+00	1 8.754840-05	1 0.550000+00	0 0	11 8.463900+01	13 8.688990+01
111	8.589610+00	2 7.468930-06	1 0.550000+00	0 0	21 8.622230+01	24 1.411780+02
111	8.589610+00	1 6.097770-06	1 0.550000+00	0 0	5 8.171020+01	
111	8.589610+00	1 7.574150+01	3 7.998210+01	5 8.1732360+01	19 8.732360+01	
111	8.589610+00	15 8.953160+01	17 8.961490+01	0 0	1 2.867410-05	24 9.217130-01
111	8.589610+00	25 1.457440+02	0 0	0 0	2 1.237410-06	
112	8.642800+00	1 5.067910-05	1 0.550000+00	0 0	11 8.467100+01	13 8.689510+01
112	8.642800+00	2 4.702080-06	1 0.550000+00	0 0	21 8.628350+01	24 1.424790+02
112	8.642800+00	1 4.110820-06	1 0.550000+00	0 0	5 8.174120+01	
112	8.642800+00	1 7.575170+01	3 8.000960+01	5 8.1733970+01	19 8.733970+01	
112	8.642800+00	15 8.949500+01	17 8.958070+01	0 0	1 2.823240-05	24 9.194830-01
112	8.642800+00	25 1.469870+02	0 0	0 0	2 9.611570-07	
113	8.697680+00	1 3.520450-05	1 0.550000+00	0 0	11 8.470320+01	13 8.690130+01
113	8.697680+00	2 3.508590-06	1 0.550000+00	0 0	21 8.634600+01	24 1.437690+02
113	8.697680+00	1 3.287230-06	1 0.550000+00	0 0	5 8.177250+01	
113	8.697680+00	1 7.576210+01	3 8.063730+01	5 8.1735620+01	19 8.735620+01	
113	8.697680+00	15 8.945810+01	17 8.954610+01	0 0	1 2.843960-05	24 9.194970-01
113	8.697680+00	25 1.482370+02	0 0	0 0	2 8.499980-07	
114	8.754350+00	1 2.891130-05	1 0.550000+00	0 0	11 8.473560+01	13 8.690750+01
114	8.754350+00	2 2.977600-06	1 0.550000+00	0 0	21 8.641010+01	24 1.451120+02
114	8.754350+00	1 3.007750-06	1 0.550000+00	0 0	5 8.180410+01	
114	8.754350+00	1 7.577250+01	3 8.006520+01	5 8.183590+01	19 8.737320+01	
114	8.754350+00	15 8.942060+01	17 8.951110+01	0 0	1 2.875870-05	24 9.204140-01
114	8.754350+00	25 1.495030+02	0 0	0 0	2 7.895660-07	
115	8.812900+00	1 2.616320-05	1 0.550000+00	0 0	11 8.476830+01	13 8.691350+01
115	8.812900+00	2 2.697640-06	1 0.550000+00	0 0	21 8.617570+01	24 1.464470+02
115	8.812900+00	1 2.867450-06	1 0.550000+00	0 0	5 8.183590+01	
115	8.812900+00	1 7.578300+01	3 8.009330+01	5 8.183590+01	19 8.739060+01	
115	8.812900+00	15 8.938260+01	17 8.947570+01	0 0	1 2.899500-05	24 9.216670-01
115	8.812900+00	25 1.507890+02	0 0	0 0	2 7.632500-07	
116	8.873330+00	1 2.477290-05	1 0.550000+00	0 0	11 8.480110+01	13 8.691950+01
116	8.873330+00	2 2.513060-06	1 0.550000+00	0 0	21 8.654270+01	24 1.477970+02
116	8.873330+00	1 2.856360-06	1 0.550000+00	0 0	5 8.186790+01	
116	8.873330+00	1 7.579350+01	3 8.012170+01	5 8.186790+01	19 8.740850+01	
116	8.873330+00	15 8.934410+01	17 8.944000+01	0 0	1 2.908050-05	24 9.230360-01
116	8.873330+00	25 1.520940+02	0 0	0 0	2 7.359190-07	
117	8.935630+00	1 2.395650-05	1 0.550000+00	0 0	11 8.483400+01	13 8.692530+01
117	8.935630+00	2 2.369510-06	1 0.550000+00	0 0	21 8.661110+01	24 1.491610+02
117	8.935630+00	1 2.807130-06	1 0.550000+00	0 0	5 8.190000+01	
117	8.935630+00	1 7.580410+01	3 8.015010+01	5 8.190000+01	19 8.742680+01	
117	8.935630+00	15 8.930530+01	17 8.940410+01	0 0	1 2.921940-05	24 9.281580-01
117	8.935630+00	25 1.534190+02	0 0	0 0	2 7.308700-07	
118	9.000000+00	1 2.374920-05	1 0.550000+00	0 0	11 8.486710+01	13 8.693100+01
118	9.000000+00	2 2.270900-06	1 0.550000+00	0 0	21 8.668110+01	24 1.505460+02
118	9.000000+00	1 2.859330-06	1 0.550000+00	0 0	5 8.193230+01	
118	9.000000+00	1 7.581480+01	3 8.017880+01	5 8.193230+01	19 8.744570+01	
118	9.000000+00	15 8.926600+01	17 8.936790+01	0 0	1 2.921940-05	24 9.281580-01
118	9.000000+00	25 1.547700+02	0 0	0 0	2 7.308700-07	

HEATING5 02/12/83  
W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

IRM3033/ 0  
20.57.57 11-16-89

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 118 TIME STEPS, TIME = 9.000000+00

GROSS GRID	1
FINE GRID	1
DISTANCE	0.0
1	0.0
2	75181
3	0.03
4	77198
5	0.06
6	80118
7	0.08
8	81103
9	0.10
10	81193
11	0.57
12	81192
13	1.04
14	82108
15	1.51
16	82146
17	1.98
18	83106
19	2.45
20	83187
21	2.92
22	84187
23	3.14
24	85170
25	3.35
26	86193
27	3.57
28	88125
29	3.79
30	89127
31	4.01
32	89167
33	4.23
34	89137
35	4.45
36	88150
37	4.67
38	87145
39	4.89
40	86169
41	5.10
42	86168
43	5.18
44	104108
45	5.25
46	124155
47	5.32
48	150155
49	5.35
50	154177

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	80.500000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 6.43749457D-02

ELAPSED CPU TIME IS 1.32 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.54770D+02 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 25

THE MINIMUM TEMPERATURE IS - 7.58148D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF NODE TEMP DIFF	MAX TEMP CHANGE	MINI TEMP CHANGE	MAX PERCENT TEMP CHANGE
119	9.065890+00	1	1.732160-05	1.055000+00	0.0	0.0	0.0	1	2.777810-05			
119	9.065890+00	2	1.736300-06	1.055000+00	0.0	0.0	0.0	2	5.871950-07	24	1.394090+00	24
119	9.065890+00	1	2.278250-06	1.055000+00	0.0	0.0	0.0					
TABLE FOR SPECIAL MONITORING OF TEMPERATURES												
***** NODE NUMBERS AND TEMPERATURES *****												
NUMBER OF	TIME											
TIME STEPS												
119	9.065890+00	1	1.758250+01	3.8	0.20730+01	5.8	1.96450+01	11	8.48990+01	13	8.693650+01	
			15.8	9.22660+01	17.8	9.33180+01	19.8	7.46490+01	21.8	6.75200+01	24	1.519400+02
			25	1.561380+02								
120	9.133490+00	1	1.945220-05	1.055000+00	0.0	0.0	0.0	1	2.752290-05			
120	9.133490+00	2	1.796450-06	1.055000+00	0.0	0.0	0.0	2	6.193800-07	24	1.409530+00	24
120	9.133490+00	1	2.450860-06	1.055000+00	0.0	0.0	0.0					
120	9.133500+00	1	1.7583610+01	3.8	0.23570+01	5.8	1.99650+01	11	8.493260+01	13	8.694190+01	
			15.8	9.18720+01	17.8	9.29560+01	19.8	7.48450+01	21.8	6.82390+01	24	1.533490+02
			25	1.575270+02								
121	9.202710+00	1	1.898530-05	1.055000+00	0.0	0.0	0.0	1	2.689140-05			
121	9.202710+00	2	1.693970-06	1.055000+00	0.0	0.0	0.0	2	6.047510-07	24	1.424530+00	24
121	9.202710+00	1	2.403250-06	1.055000+00	0.0	0.0	0.0					
121	9.20270+00	1	1.7584670+01	3.8	0.26390+01	5.8	2.02830+01	11	8.49510+01	13	8.694700+01	
			15.8	9.14760+01	17.8	9.25960+01	19.8	7.50450+01	21.8	6.89670+01	24	1.547740+02
			25	1.583350+02								
122	9.273500+00	1	1.887330-05	1.055000+00	0.0	0.0	0.0	1	2.627450-05			
122	9.273500+00	2	1.672530-06	1.055000+00	0.0	0.0	0.0	2	5.946020-07	24	1.439370+00	24
122	9.273500+00	1	2.349180-06	1.055000+00	0.0	0.0	0.0					
122	9.27350+00	1	1.7585720+01	3.8	0.29190+01	5.8	2.05990+01	11	8.499720+01	13	8.695190+01	
			15.8	9.10810+01	17.8	9.22380+01	19.8	7.52490+01	21.8	6.97030+01	24	1.562130+02
			25	1.603620+02								
123	9.345810+00	1	1.775630-05	1.055000+00	0.0	0.0	0.0	1	2.546820-05			
123	9.345810+00	2	1.615480-06	1.055000+00	0.0	0.0	0.0	2	5.728690-07	24	1.454200+00	24
123	9.345810+00	1	2.610800-06	1.055000+00	0.0	0.0	0.0					
123	9.34580+00	1	1.7586760+01	3.8	0.31970+01	5.8	2.09110+01	11	8.502890+01	13	8.695660+01	
			15.8	9.06870+01	17.8	9.18820+01	19.8	7.54560+01	21.8	7.04450+01	24	1.576670+02
			25	1.618060+02								
124	9.419610+00	1	1.701070-05	1.055000+00	0.0	0.0	0.0	1	2.466310-05			
124	9.419610+00	2	1.591470-06	1.055000+00	0.0	0.0	0.0	2	5.658410-07	24	1.469090+00	24
124	9.419610+00	1	2.253800-06	1.055000+00	0.0	0.0	0.0					
124	9.41960+00	1	1.7587790+01	3.8	0.34710+01	5.8	2.12200+01	11	8.506020+01	13	8.696100+01	
			15.8	9.02950+01	17.8	9.15290+01	19.8	7.56670+01	21.8	7.11930+01	24	1.591360+02
			25	1.632690+02								
125	9.494850+00	1	1.680760-05	1.055000+00	0.0	0.0	0.0	1	2.392250-05			
125	9.494850+00	2	1.618900-06	1.055000+00	0.0	0.0	0.0	2	5.509120-07	24	1.483980+00	24
125	9.494850+00	1	2.166580-06	1.055000+00	0.0	0.0	0.0					
125	9.49480+00	1	1.7588800+01	3.8	0.37410+01	5.8	2.15240+01	11	8.509100+01	13	8.696510+01	
			15.8	8.99040+01	17.8	9.11800+01	19.8	7.58810+01	21.8	7.19470+01	24	1.606200+02
			25	1.647500+02								
126	9.571500+00	1	1.680380-04	1.055000+00	0.0	0.0	0.0	1	4.932370-05			
126	9.571500+00	3	2.139500-06	1.055000+00	0.0	0.0	0.0	2	3.225790-06	24	1.482430+00	24
126	9.571500+00	2	1.975030-06	1.055000+00	0.0	0.0	0.0					
126	9.57150+00	1	1.7589800+01	3.8	0.40080+01	5.8	2.18230+01	11	8.51210+01	13	8.696900+01	
			15.8	8.95160+01	17.8	9.08350+01	19.8	7.60990+01	21.8	7.27040+01	24	1.621030+02
			25	1.661700+02								
127	9.650400+00	1	2.915340-04	1.055000+00	0.0	0.0	0.0	1	7.961400-05			
127	9.650400+00	3	3.737880-06	1.055000+00	0.0	0.0	0.0	2	5.768400-06	24	1.454650+00	24
127	9.650400+00	2	3.713980-06	1.055000+00	0.0	0.0	0.0					
127	9.65040+00	1	1.7590800+01	3.8	0.42730+01	5.8	2.21210+01	11	8.51510+01	13	8.697260+01	
			15.8	8.91270+01	17.8	9.04910+01	19.8	7.63220+01	21.8	7.34730+01	24	1.635580+02
			25	1.674790+02								
128	9.733930+00	1	1.615060-04	1.055000+00	0.0	0.0	0.0	1	7.489650-05			
128	9.733930+00	3	2.130290-06	1.055000+00	0.0	0.0	0.0	2	3.650790-06	24	1.439600+00	24
128	9.733930+00	2	2.576650-06	1.055000+00	0.0	0.0	0.0					
128	9.73390+00	1	1.7591800+01	3.8	0.45430+01	5.8	2.24240+01	11	8.51810+01	13	8.697600+01	





HEATING6 02/12/83  
W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 131 TIME STEPS, TIME = 1.000000E+01

18M3033/ 0  
20 57 57 11-16 89

GROSS GRID	FINE GRID	DISTANCE	TEMPERATURE
1	1	0.0	82.670000
1	2	0.03	0.0
2	3	0.06	73.400000
4	4	0.08	
3	5	0.10	
6	6	0.57	
7	7	1.04	
8	8	1.51	
9	9	1.98	
10	10	2.45	
4	11	2.92	
12	12	3.14	
5	13	3.35	
14	14	3.57	
6	15	3.79	
16	16	4.01	
17	17	4.23	
18	18	4.45	
8	19	4.67	
20	20	4.89	
9	21	5.10	
22	22	5.18	
23	23	5.25	
10	24	5.32	
11	25	5.35	

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	82.670000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 8.795992250E-02

ELAPSED CPU TIME IS 1.46 SECONDS

THE MAXIMUM TEMPERATURE IS 1.725190E+02 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 25

THE MINIMUM TEMPERATURE IS 7.594800E+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEN DIFF	MAX TEMP CHANGE	NODE	MAX PERCENT TEMP CHANGE	
132	1.00968D+01	1	8.87966D-05	1.05500D+00	0.0	0.0	0.0	1	6.3695E-05	24	1.33502D+00	24	7.89710D-01
132	1.00968D+01	2	9.78092D-06	1.05500D+00	0.0	0.0	0.0	2	2.89465D-06	24	1.33502D+00	24	7.89710D-01
132	1.00968D+01	2	1.77721D-06	1.05500D+00	0.0	0.0	0.0	2	2.89465D-06	24	1.33502D+00	24	7.89710D-01

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
 \*\*\*\*\* NODE NUMBERS AND TEMPERATURES \*\*\*\*\*

NUMBER OF TIME STEPS	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEN DIFF	MAX TEMP CHANGE	NODE	MAX PERCENT TEMP CHANGE	
132	1.0097D+01	1	7.59579D+01	5.805605D+01	5.805605D+01	5.823613D+01	11.852009D+01	13.869898D+01	13.869898D+01	24.170387D+02	24	1.1076D-01	
		15	8.87105D+01	17.888743D+01	19.877576D+01	19.877576D+01	21.877633D+01	24.170387D+02	24.170387D+02		24	1.1076D-01	
		25	1.73783D+02								24	1.1076D-01	
133	1.02032D+01	1	8.90402D-05	1.05500D+00	0.0	0.0	0.0	1	6.79811D-05	24	1.40766D+00	24	8.26157D-01
133	1.02032D+01	3	1.56135D-06	1.05500D+00	0.0	0.0	0.0	2	2.18137D-06	24	1.40766D+00	24	8.26157D-01
133	1.02032D+01	2	2.10648D-06	1.05500D+00	0.0	0.0	0.0	2	2.18137D-06	24	1.40766D+00	24	8.26157D-01
133	1.0203D+01	1	7.59682D+01	3.805884D+01	5.823925D+01	5.823925D+01	11.853319D+01	13.869898D+01	13.869898D+01	24.171795D+02	24	1.1076D-01	
		15	8.86664D+01	17.888373D+01	19.877873D+01	19.877873D+01	21.878575D+01	24.171795D+02	24.171795D+02		24	1.1076D-01	
		25	1.75132D+02								24	1.1076D-01	
134	1.03203D+01	1	9.20473D-05	1.05500D+00	0.0	0.0	0.0	1	7.11425D-05	24	1.49065D+00	24	8.67695D-01
134	1.03203D+01	3	2.14932D-06	1.05500D+00	0.0	0.0	0.0	2	2.28336D-06	24	1.49065D+00	24	8.67695D-01
134	1.03203D+01	2	2.47897D-06	1.05500D+00	0.0	0.0	0.0	2	2.28336D-06	24	1.49065D+00	24	8.67695D-01
134	1.0320D+01	1	7.59790D+01	3.806175D+01	5.824250D+01	5.824250D+01	11.853641D+01	13.869904D+01	13.869904D+01	24.173285D+02	24	1.1076D-01	
		15	8.86197D+01	17.887985D+01	19.878199D+01	19.878199D+01	21.879589D+01	24.173285D+02	24.173285D+02		24	1.1076D-01	
		25	1.76576D+02								24	1.1076D-01	
135	1.04484D+01	1	9.55181D-05	1.05500D+00	0.0	0.0	0.0	1	7.30949D-05	24	1.52876D+00	24	9.11076D-01
135	1.04484D+01	3	2.85132D-06	1.05500D+00	0.0	0.0	0.0	2	2.38826D-06	24	1.52876D+00	24	9.11076D-01
135	1.04484D+01	2	2.87730D-06	1.05500D+00	0.0	0.0	0.0	2	2.38826D-06	24	1.52876D+00	24	9.11076D-01
135	1.0448D+01	1	7.59902D+01	3.806475D+01	5.824585D+01	5.824585D+01	11.853972D+01	13.869915D+01	13.869915D+01	24.174864D+02	24	1.1076D-01	
		15	8.85706D+01	17.887583D+01	19.878555D+01	19.878555D+01	21.880672D+01	24.174864D+02	24.174864D+02		24	1.1076D-01	
		25	1.78121D+02								24	1.1076D-01	
136	1.05821D+01	1	1.46794D-04	1.05500D+00	0.0	0.0	0.0	1	7.58902D-05	24	1.59482D+00	24	9.12034D-01
136	1.05821D+01	3	4.01873D-06	1.05500D+00	0.0	0.0	0.0	2	3.35749D-06	24	1.59482D+00	24	9.12034D-01
136	1.05821D+01	2	4.33663D-06	1.05500D+00	0.0	0.0	0.0	2	3.35749D-06	24	1.59482D+00	24	9.12034D-01
136	1.0582D+01	1	7.60013D+01	3.806769D+01	5.824913D+01	5.824913D+01	11.854294D+01	13.869920D+01	13.869920D+01	24.176459D+02	24	1.1076D-01	
		15	8.85215D+01	17.887188D+01	19.878926D+01	19.878926D+01	21.881772D+01	24.176459D+02	24.176459D+02		24	1.1076D-01	
		25	1.79681D+02								24	1.1076D-01	
137	1.07213D+01	1	7.39914D-04	1.05500D+00	0.0	0.0	0.0	1	1.42021D-04	24	1.54538D+00	24	8.75775D-01
137	1.07213D+01	4	2.09033D-06	1.05500D+00	0.0	0.0	0.0	2	1.46766D-05	24	1.54538D+00	24	8.75775D-01
137	1.0721D+01	3	4.06504D-06	1.05500D+00	0.0	0.0	0.0	3	2.51571D-06	24	1.54538D+00	24	8.75775D-01
137	1.07213D+01	2	2.66548D-06	1.05500D+00	0.0	0.0	0.0	2	2.51571D-06	24	1.54538D+00	24	8.75775D-01
137	1.0721D+01	1	7.60121D+01	3.807056D+01	5.825231D+01	5.825231D+01	11.854606D+01	13.869918D+01	13.869918D+01	24.178004D+02	24	1.1076D-01	
		15	8.84726D+01	17.886801D+01	19.879310D+01	19.879310D+01	21.882887D+01	24.178004D+02	24.178004D+02		24	1.1076D-01	
		25	1.81069D+02								24	1.1076D-01	
138	1.08607D+01	1	2.05940D-04	1.05500D+00	0.0	0.0	0.0	1	1.08017D-04	24	1.40416D+00	24	7.88833D-01
138	1.08607D+01	3	4.29492D-06	1.05500D+00	0.0	0.0	0.0	2	5.17321D-06	24	1.40416D+00	24	7.88833D-01
138	1.08607D+01	2	7.33410D-06	1.05500D+00	0.0	0.0	0.0	2	5.17321D-06	24	1.40416D+00	24	7.88833D-01
138	1.0861D+01	1	7.60224D+01	3.807323D+01	5.825528D+01	5.825528D+01	11.854894D+01	13.869909D+01	13.869909D+01	24.179408D+02	24	1.1076D-01	
		15	8.84258D+01	17.886439D+01	19.879694D+01	19.879694D+01	21.883972D+01	24.179408D+02	24.179408D+02		24	1.1076D-01	
		25	1.82380D+02								24	1.1076D-01	
139	1.10000D+01	1	1.96453D-04	1.05500D+00	0.0	0.0	0.0	1	9.40167D-05	24	1.30346D+00	24	7.29878D-01
139	1.10000D+01	3	5.10312D-06	1.05500D+00	0.0	0.0	0.0	2	4.66801D-06	24	1.30346D+00	24	7.29878D-01
139	1.10000D+01	2	6.54685D-06	1.05500D+00	0.0	0.0	0.0	2	4.66801D-06	24	1.30346D+00	24	7.29878D-01
139	1.1000D+01	1	7.60320D+01	3.807574D+01	5.825804D+01	5.825804D+01	11.855161D+01	13.869894D+01	13.869894D+01	24.180718D+02	24	1.1076D-01	
		15	8.83810D+01	17.886100D+01	19.880076D+01	19.880076D+01	21.885026D+01	24.180718D+02	24.180718D+02		24	1.1076D-01	
		25	1.83623D+02								24	1.1076D-01	

HEATINGS 02/12/83  
 V9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
 TRANSIENT TEMPERATURE DISTRIBUTION AFTER 139 TIME STEPS, TIME = 1.107000D+01

10M8033/  
 20 57 57 0 11 16 89

COARSE GRID	1
FINE GRID	1
DISTANCE	O.O
1	0.0
2	0.03
3	0.06
4	0.08
5	0.10
6	0.57
7	1.04
8	1.51
9	1.98
10	2.45
11	2.92
12	3.14
13	3.35
14	3.57
15	3.79
16	4.01
17	4.23
18	4.45
19	4.67
20	4.89
21	5.10
22	5.18
23	5.25
24	5.32
25	5.35

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	85.000000
2	0.0
3	73.000000

THE CURRENT TIME STEP (DELTA T) = 1.39341286D-01

ELAPSED CPU TIME IS 1.57 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.83623D+02 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 25

THE MINIMUM TEMPERATURE IS - 7.60320D+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	1.1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	1.1 NORM OF NODE TEMP DIFF	MAX TEMP CHANGE	NOSE	MAX PERCENT TEMP CHANGE
140	1.115330+01	1	1.948040-06	1.055000+00	0.0	0.0	0.0	1	9.310420-05	24.1.358040+00	24.7	5.14690-01
140	1.115330+01	3	6.001300-06	1.055000+00	0.0	0.0	0.0	2	4.624490-06			
140	1.115330+01	7	2.252060-06	1.055000+00	0.0	0.0	0.0	2	4.624490-06			

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
 \*\*\*\*\* NODE NUMBERS AND TEMPERATURES \*\*\*\*\*

NUMBER OF TIME STEPS	TIME	1.1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	1.1 NORM OF NODE TEMP DIFF	MAX TEMP CHANGE	NOSE	MAX PERCENT TEMP CHANGE
140	1.11530+01	3.8.078290+01	5.8.26080+01	11.8.554310+01	13.8.698710+01				
		15.8.832410+01	17.8.857530+01	21.8.861510+01	24.1.820760+02				
		25.1.849270+02							
141	1.132190+01	1.1.675130-04	1.055000+00	0.0	0.0				
141	1.132190+01	3.5.827020-06	1.055000+00	0.0	0.0				
141	1.132190+01	2.7.148050-05	1.055000+00	0.0	0.0				
141	1.13220+01	1.7.605130+01	3.8.080870+01	5.8.263700+01	11.8.557010+01	13.8.698390+01	24.1.421430+05	24.7	8.16780-01
		15.8.825510+01	17.8.854010+01	19.8.809530+01	21.8.873430+01	24.1.834970+02			
		25.1.863130+02							
142	1.150730+01	1.1.549020-04	1.055000+00	0.0	0.0				
142	1.150730+01	3.6.775520-06	1.055000+00	0.0	0.0				
142	1.150730+01	2.7.306250-06	1.055000+00	0.0	0.0				
142	1.15070+01	1.7.606110+01	3.8.083450+01	5.8.266530+01	11.8.559680+01	13.8.607950+01	24.1.504020+00	24.8	1.96400-01
		15.8.823430+01	17.8.850480+01	19.8.814530+01	21.8.886190+01	24.1.850010+02			
		25.1.877970+02							
143	1.171140+01	1.3.033480-04	1.055000+00	0.0	0.0				
143	1.171140+01	4.5.007920-06	1.055000+00	0.0	0.0				
143	1.171140+01	3.3.737030-06	1.055000+00	0.0	0.0				
143	1.17110+01	1.7.607070+01	3.8.085990+01	5.8.269110+01	11.8.562270+01	13.8.637370+01	24.1.591800+00	24.8	5.04280-01
		15.8.818190+01	17.8.846990+01	19.8.820020+01	21.8.899630+01	24.1.865930+02			
		25.1.893620+02							
144	1.185570+01	1.4.421670-05	1.055000+00	0.0	0.0				
144	1.185570+01	2.5.327990-06	1.055000+00	0.0	0.0				
144	1.185570+01	1.5.542640-06	1.055000+00	0.0	0.0				
144	1.18560+01	1.7.607800+01	3.8.087640+01	5.8.271090+01	11.8.563900+01	13.8.696920+01	25.1.097350+00	24.5	8.65440-01
		15.8.814680+01	17.8.844750+01	19.8.823840+01	21.8.908810+01	24.1.876880+02			
		25.1.904590+02							
145	1.200000+01	1.1.096590-04	1.055000+00	0.0	0.0				
145	1.200000+01	3.3.697610-06	1.055000+00	0.0	0.0				
145	1.200000+01	2.3.561220-06	1.055000+00	0.0	0.0				
145	1.20000+01	1.7.608390+01	3.8.089150+01	5.8.272140+01	11.8.565370+01	13.8.696420+01	24.1.075490+00	24.5	7.30210-01
		15.8.811340+01	17.8.842700+01	19.8.82760+01	21.8.917740+01	24.1.887630+02			
		25.1.915220+02							

IRM5033/ 0 11-16-80  
20 57.57

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 145 TIME STEPS, TIME = 1.20000E+01

HEATING6 02 / 12/83  
W9XNP110

GROSS GRID	1
1	76108
2	78148
3	80189
4	81180
5	82173
6	83109
7	83150
8	83196
9	84147
10	85104
11	85165
12	86128
13	86196
14	87161
15	88131
16	88139
17	88143
18	88133
19	88128
20	88149
21	89118
22	121101
23	153194
24	188176
25	191152

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	87.330000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 1.44324401D-01

ELAPSED CPU TIME IS 1.65 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.91522D+02 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 25

THE MINIMUM TEMPERATURE IS - 7.60839D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO	MAX HEAT	BETA	L1 NORM OF	RHS	RHS	NO	L1 NORM OF	MAX TEMP	MAX PERCENT	
TIME	ITER	RESIDUAL		TEMP DIFF	(ITERATION)	(JACOBI)	ITER	TEMP DIFF	CHANGE	TEMP	TEMP CHANGE	
145	1.215880+01	1	9.506750-05	1.05000+00	0.0	0.0	1	4.258110-05	24	1.151720+00	24	6.101750-01
146	1.215880+01	3	3.255500-06	1.05000+00	0.0	0.0	2	2.319410-06	24	1.151720+00	24	6.101750-01
146	1.215880+01	2	3.662000-06	1.05000+00	0.0	0.0						

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
 \*\*\*\*\* NODE NUMBERS AND TEMPERATURES \*\*\*\*\*

NUMBER OF	TIME	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	
TIME STEPS												
146	1.21590+01	1	7.608970+01	3.8	090650+01	5.8	274350+01	11.8	565820+01	13.8	525830+01	
		15	8.807850+01	17.8	840E40+01	19.8	831820+01	21.8	927290+01	24	1.899150+02	
		25	1.926620+02									
147	1.233340+01	1	7.209570-05	1.05000+00	0.0	0.0	0.0	0.0	1.4	326570-05		
147	1.233340+01	3	4.020960-06	1.05000+00	0.0	0.0	0.0	0.0	2.1	935190-06	24	1.236840+00
147	1.233340+01	2	3.250210-06	1.05000+00	0.0	0.0	0.0	0.0	2.1	935190-06	24	1.236840+00
147	1.233340+01	1	7.609540+01	3.8	092160+01	5.8	275360+01	11.8	568220+01	13.8	595140+01	
		15	8.804210+01	17.8	838610+01	19.8	836370+01	21.8	937490+01	24	1.911520+02	
		25	1.938050+02									
148	1.252550+01	1	7.454110-05	1.05000+00	0.0	0.0	0.0	0.0	1.4	467080-05		
148	1.252550+01	3	5.092880-06	1.05000+00	0.0	0.0	0.0	0.0	2.2	068030-06	25	1.337510+00
148	1.252550+01	2	3.729560-06	1.05000+00	0.0	0.0	0.0	0.0	11.8	569550+01	13.8	594340+01
148	1.25250+01	1	7.610110+01	3.8	093630+01	5.8	217530+01	11.8	348360+01	24	1.924870+02	
		15	8.800450+01	17.8	836640+01	19.8	841330+01	21.8	934830+01	24	1.924870+02	
		25	1.952330+02									
149	1.273680+01	1	1.947670-03	1.05000+00	0.0	0.0	0.0	0.0	1.2	124680-04		
149	1.273680+01	4	3.785180-06	1.05000+00	0.0	0.0	0.0	0.0	2.4	137350-05		
149	1.273680+01	4	2.796320-07	1.05000+00	0.0	0.0	0.0	0.0	3.9	529010-06	24	1.262860+00
149	1.273680+01	3	6.025950-06	1.05000+00	0.0	0.0	0.0	0.0	11.8	570780+01	13.8	693400+01
149	1.27370+01	1	7.610650+01	3.8	095030+01	5.8	279010+01	11.8	959930+01	24	1.937500+02	
		15	8.796590+01	17.8	834770+01	19.8	846720+01	21.8	937500+01	24	1.937500+02	
		25	1.962580+02									
150	1.286840+01	1	4.391950-04	1.05000+00	0.0	0.0	0.0	0.0	1.1	173270-04		
150	1.286840+01	4	1.254930-06	1.05000+00	0.0	0.0	0.0	0.0	2.1	030900-05		
150	1.286840+01	3	6.059000-06	1.05000+00	0.0	0.0	0.0	0.0	3.1	831560-06	24	5.934E50-01
150	1.286840+01	2	3.473650-06	1.05000+00	0.0	0.0	0.0	0.0	11.8	571420+01	13.8	692790+01
150	1.28680+01	1	7.611010+01	3.8	095810+01	5.8	279820+01	11.8	966930+01	24	1.943490+02	
		15	8.794320+01	17.8	833750+01	19.8	850050+01	21.8	966930+01	24	1.943490+02	
		25	1.967210+02									
151	1.300000+01	1	1.685800-04	1.05000+00	0.0	0.0	0.0	0.0	1.7	550620-05		
151	1.300000+01	3	3.670210-06	1.05000+00	0.0	0.0	0.0	0.0	2.4	325650-06	23	4.926000-01
151	1.300000+01	2	5.825440-06	1.05000+00	0.0	0.0	0.0	0.0	11.8	571980+01	13.8	692170+01
151	1.30000+01	1	7.611300+01	3.8	096520+01	5.8	280550+01	11.8	973770+01	24	1.948370+02	
		15	8.792160+01	17.8	832840+01	19.8	853360+01	21.8	973770+01	24	1.948370+02	
		25	1.971140+02									

IBM3033/ 0 11-16-83  
20 57.58

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 151 TIME STEPS, TIME = 1.300000+01

HEATING: 02/12/83  
W9XNP110

GROSS GRID	1
FINE GRID	1
DISTANCE	O.O
1	76111
2	0.03
3	0.06
4	0.08
5	0.10
6	0.57
7	1.04
8	1.51
9	1.98
10	2.45
11	2.92
12	3.14
13	3.35
14	3.57
15	3.79
16	4.01
17	4.23
18	4.45
19	4.67
20	4.89
21	5.10
22	5.18
23	5.25
24	5.32
25	5.35

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	89.500000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 1.316047500-01

ELAPSED CPU TIME IS 1.75 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.97114D+02 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 25

THE MINIMUM TEMPERATURE IS - 7.61130D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO	MAX HEAT	BETA	L1 NORM OF	DND	RND	RND	NO	L1 NORM OF	MAX TEMP	NOISE	MAX PERCENT				
ITER	RESIDUAL	ITER	TEMP DIFF	TEMP DIFF	(ITERATION)	(JACOBI)	ITER	TEMP DIFF	TEMP DIFF	CHANGE	CHANGE	TEMP CHANGE					
152	1.314480+01	1	2.00537-04	1.055000+00	0.0	0.0	11	572510+01	13	8	691470+01						
152	1.314480+01	2	7.430800-06	1.055000+00	0.0	0.0	21	981120+01	24	1	952800+02						
152	1.314480+01	3	5.753190-06	1.055000+00	0.0	0.0						23	4	679380-01	23	2	948160-01
152	1.314480+01	4	4.02660-06	1.055000+00	0.0	0.0											
TABLE FOR SPECIAL MONITORING OF TEMPERATURES																	
***** NODE NUMBERS AND TEMPERATURES *****																	
153	1.330400+01	1	1.663270-04	1.055000+00	0.0	0.0	11	572980+01	13	8	690680+01						
153	1.330400+01	2	7.032290-06	1.055000+00	0.0	0.0	21	988970+01	24	1	956840+02						
153	1.330400+01	3	5.319880-06	1.055000+00	0.0	0.0						23	4	370700-01	23	2	745520-01
153	1.330400+01	4	3.032290-06	1.055000+00	0.0	0.0											
154	1.347920+01	1	1.532040-04	1.055000+00	0.0	0.0	11	572980+01	13	8	690680+01						
154	1.347920+01	2	7.218390-06	1.055000+00	0.0	0.0	21	988970+01	24	1	956840+02						
154	1.347920+01	3	5.742530-06	1.055000+00	0.0	0.0						23	4	039930-01	23	2	530850-01
154	1.347920+01	4	2.18390-06	1.055000+00	0.0	0.0											
155	1.367190+01	1	1.7612090-04	1.055000+00	0.0	0.0	11	573700+01	13	8	688800+01						
155	1.367190+01	2	5.406230-06	1.055000+00	0.0	0.0	21	997310+01	24	1	960620+02						
155	1.367190+01	3	3.730960-06	1.055000+00	0.0	0.0						23	3	312890-01	22	2	115530-01
155	1.367190+01	4	2.402660-06	1.055000+00	0.0	0.0											
155	1.36720+01	1	1.7612330-04	1.055000+00	0.0	0.0	11	573700+01	13	8	688800+01						
155	1.36720+01	2	5.406230-06	1.055000+00	0.0	0.0	21	997310+01	24	1	960620+02						
155	1.36720+01	3	3.730960-06	1.055000+00	0.0	0.0						23	3	312890-01	22	2	115530-01
155	1.36720+01	4	2.402660-06	1.055000+00	0.0	0.0											
156	1.383590+01	1	1.592500-03	1.055000+00	0.0	0.0	11	573700+01	13	8	688800+01						
156	1.383590+01	2	5.406230-06	1.055000+00	0.0	0.0	21	997310+01	24	1	960620+02						
156	1.383590+01	3	3.730960-06	1.055000+00	0.0	0.0						23	3	312890-01	22	2	115530-01
156	1.383590+01	4	2.402660-06	1.055000+00	0.0	0.0											
156	1.38360+01	1	1.7612520-04	1.055000+00	0.0	0.0	11	573870+01	13	8	687940+01						
156	1.38360+01	2	5.406230-06	1.055000+00	0.0	0.0	21	997310+01	24	1	960620+02						
156	1.38360+01	3	3.730960-06	1.055000+00	0.0	0.0						23	3	312890-01	22	2	115530-01
156	1.38360+01	4	2.402660-06	1.055000+00	0.0	0.0											
157	1.400000+01	1	1.475960-04	1.055000+00	0.0	0.0	11	573870+01	13	8	687940+01						
157	1.400000+01	2	5.406230-06	1.055000+00	0.0	0.0	21	997310+01	24	1	960620+02						
157	1.400000+01	3	3.730960-06	1.055000+00	0.0	0.0						23	3	312890-01	22	2	115530-01
157	1.400000+01	4	2.402660-06	1.055000+00	0.0	0.0											
157	1.400000+01	1	1.7612560-04	1.055000+00	0.0	0.0	11	573870+01	13	8	687940+01						
157	1.400000+01	2	5.406230-06	1.055000+00	0.0	0.0	21	997310+01	24	1	960620+02						
157	1.400000+01	3	3.730960-06	1.055000+00	0.0	0.0						23	3	312890-01	22	2	115530-01
157	1.400000+01	4	2.402660-06	1.055000+00	0.0	0.0											



18M3033/ 0  
20 57 58 11-16-89

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 157 TIME STEPS, TIME = 1.400000

HEATING6 02/12/83  
W9XNP110

GROSS GRID	FINE GRID	O-O DISTANCE	O-O
1	1	0.0	76113
2	2	0.03	78156
3	3	0.06	81100
4	4	0.08	81192
5	5	0.10	82184
6	6	0.57	83129
7	7	1.04	83175
8	8	1.51	84123
9	9	1.98	84172
10	10	2.45	85123
11	11	2.92	85174
12	12	3.14	86131
13	13	3.35	86187
14	14	3.57	87128
15	15	3.79	87179
16	16	4.01	88108
17	17	4.23	88129
18	18	4.45	88148
19	19	4.67	88178
20	20	4.89	89121
21	21	5.10	90120
22	22	5.18	125125
23	23	5.25	160135
24	24	5.32	194192
25	25	5.35	195179

TEMPERATURES AT NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	91.360000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 1.64072295D-01

ELAPSED CPU TIME IS 1.86 SECS

THE MAXIMUM TEMPERATURE IS - 1.95787D+02 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 25

THE MINIMUM TEMPERATURE IS - 7.61266D+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO TIME	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHD (ITERATION)	RHD (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	NODE	MAX PERCENT TEMP CHANGE
158	1.4180D+01	1	7.61279D+01	3.810018D+01	3.810018D+01	5.828409D+01	11.857397D+01	1	3.810018D+01	13.858612D+01		
		25	7.7664D+01	17.88288D+01	17.88288D+01	19.888198D+01	21.902748D+01	24	1.93636D+02			
			9.4263D+02									
159	1.4379D+01	1	5.87230D+04	1.05500D+00	0.0	0.0	0.0	1	2.22074D-04			
		4	4.4593D+06	1.05500D+00	0.0	0.0	0.0	2	1.38819D-05			
		3	5.3808D+06	1.05500D+00	0.0	0.0	0.0	3	3.09803D-06	25	1.83764D+00	25.945955D-01
		2	6.9588D+06	1.05500D+00	0.0	0.0	0.0					
159	1.4379D+01	1	7.6129D+01	3.810018D+01	3.810018D+01	5.828427D+01	11.857388D+01	1	3.810018D+01	13.868506D+01		
		15	7.7463D+01	17.88287D+01	17.88287D+01	19.88658D+01	21.903487D+01	24	1.91983D+02			
		25	9.4242D+02									
160	1.4528D+01	1	5.24506D+04	1.05500D+00	0.0	0.0	0.0	1	1.84198D-04			
		4	4.0264D+06	1.05500D+00	0.0	0.0	0.0	2	1.19283D-05			
		3	6.47188D+06	1.05500D+00	0.0	0.0	0.0	3	2.66686D-06	25	1.98304D+00	25.103055D+00
		2	5.99364D+06	1.05500D+00	0.0	0.0	0.0					
160	1.4528D+01	1	5.58527D+05	1.05500D+00	0.0	0.0	0.0	1	6.86666D-06			
		3	2.51903D+06	1.05500D+00	0.0	0.0	0.0	2	1.14053D-06	25	1.84127D+00	25.956879D-01
		2	3.0892D+05	1.05500D+00	0.0	0.0	0.0					
160	1.45628D+01	1	7.6129D+01	3.810018D+01	3.810018D+01	5.828435D+01	11.857372D+01	1	3.810018D+01	13.868408D+01		
		15	7.7290D+01	17.88287D+01	17.88287D+01	19.889075D+01	21.903116D+01	24	1.90290D+02			
		25	9.0584D+02									
161	1.47466D+01	1	1.10893D+03	1.05500D+00	0.0	0.0	0.0	1	2.03567D-04			
		4	1.99961D+06	1.05500D+00	0.0	0.0	0.0	2	2.38068D-05			
		4	3.4352D+07	1.05500D+00	0.0	0.0	0.0	3	4.97618D-06	25	2.13415D+00	25.119880D+00
		3	2.31964D+06	1.05500D+00	0.0	0.0	0.0					
161	1.47466D+01	1	8.01914D+05	1.05500D+00	0.0	0.0	0.0	1	1.01806D-05			
		3	3.14173D+06	1.05500D+00	0.0	0.0	0.0	2	1.57801D-06	25	1.83218D+00	25.961355D-01
		2	2.56298D+06	1.05500D+00	0.0	0.0	0.0					
161	1.4719D+01	1	7.6120D+01	3.810018D+01	3.810018D+01	5.828435D+01	11.857352D+01	1	3.810018D+01	13.868375D+01		
		15	7.7153D+01	17.88289D+01	17.88289D+01	19.889423D+01	21.904608D+01	24	1.88685D+02			
		25	8.8751D+02									
162	1.48594D+01	1	2.46569D+04	1.05500D+00	0.0	0.0	0.0	1	1.07068D-04			
		3	5.71316D+06	1.05500D+00	0.0	0.0	0.0	2	5.04157D-06	25	1.74582D+00	25.924932D-01
		2	8.65568D+06	1.05500D+00	0.0	0.0	0.0					
162	1.48594D+01	1	7.61304D+01	3.810018D+01	3.810018D+01	5.828432D+01	11.857330D+01	1	3.810018D+01	13.868250D+01		
		15	7.7037D+01	17.88291D+01	17.88291D+01	19.889732D+01	21.905019D+01	24	1.87085D+02			
		25	8.7006D+02									
163	1.50000D+01	1	1.53232D+04	1.05500D+00	0.0	0.0	0.0	1	1.798656D-05			
		3	3.75848D+06	1.05500D+00	0.0	0.0	0.0	2	2.374726D-06	25	1.80315D+00	25.964223D-01
		2	5.32182D+06	1.05500D+00	0.0	0.0	0.0					
163	1.50000D+01	1	7.61305D+01	3.810018D+01	3.810018D+01	5.828425D+01	11.857305D+01	1	3.810018D+01	13.868175D+01		
		15	7.6927D+01	17.88293D+01	17.88293D+01	19.890034D+01	21.905398D+01	24	1.85392D+02			
		25	8.85202D+02									

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
 NODE NUMBERS AND TEMPERATURES

NUMBER OF TIME STEPS	TIME	MONITORING OF TEMPERATURES
158	1.4180D+01	11 8 57397D+01 13 8 58612D+01
		19 8 88198D+01 21 9 02748D+01 24 1 93636D+02
159	1.4379D+01	1 2 22074D-04
		2 1 38819D-05
		3 3 09803D-06 25 1 83764D+00 25 9 45955D-01
159	1.4379D+01	11 8 57388D+01 13 8 68506D+01
		21 9 03487D+01 24 1 91983D+02
160	1.4528D+01	1 1 84198D-04
		2 1 19283D-05
		3 2 66686D-06 25 1 98304D+00 25 1 03055D+00
160	1.4528D+01	1 6 86666D-06
		2 1 14053D-06 25 1 84127D+00 25 9 56879D-01
160	1.45628D+01	11 8 57372D+01 13 8 68408D+01
		21 9 03116D+01 24 1 90290D+02
161	1.47466D+01	1 2 03567D-04
		2 2 38068D-05
		3 4 97618D-06 25 2 13415D+00 25 1 19880D+00
161	1.47466D+01	1 1 01806D-05
		2 1 57801D-06 25 1 83218D+00 25 9 61355D-01
161	1.4719D+01	11 8 57352D+01 13 8 68375D+01
		21 9 04608D+01 24 1 88685D+02
162	1.48594D+01	1 1 07068D-04
		2 5 04157D-06 25 1 74582D+00 25 9 24932D-01
162	1.48594D+01	11 8 57330D+01 13 8 68250D+01
		21 9 05019D+01 24 1 87085D+02
163	1.50000D+01	1 1 798656D-05
		2 3 74726D-06 25 1 80315D+00 25 9 64223D-01
163	1.50000D+01	11 8 57305D+01 13 8 68175D+01
		21 9 05398D+01 24 1 85392D+02

IBM3033/ 0 11-16-89  
2J 57.58

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 163 TIME STEPS, TIME = 1.500000+01

HEATING6 02/12/83  
M9XNP110

GROSS GRID	1
FINE GRID	1
DISTANCE	O.O
1	76113
2	76157
3	81101
4	81192
5	82184
6	83131
7	83179
8	84127
9	84175
10	85124
11	85173
12	86129
13	86182
14	87129
15	87169
16	88102
17	88129
18	88159
19	89100
20	89163
21	90154
22	123166
23	155175
24	185139
25	185120

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	92.790000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 1.406389290-01

ELAPSED CPU TIME IS 1.98 SECONDS

THE MAXIMUM TEMPERATURE IS 1.853920+02 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES 24

THE MINIMUM TEMPERATURE IS 7.613050+01 (+0.1 PERCENT)

M'N. TEMP. APPEARS AT NODES 1

NO	TIME	NO	MAX HEAT	BETA	1.1 NORM OF	DIAG	DIAG	NO	1.1 NORM OF	MAX TEMP	DIFF	MAX PERCENT	
TIME	TIER	TIER	RESIDUAL		TEMP DIFF	(ITERATION)	(JACOBI)	TIER	TEMP DIFF	CHANGE		TEMP CHANGE	
164	1.51406D+01	1	1.78751D-04	1.05500D+00	0.0	0.0	0.0	1	1.9646D-05	25	1.86496D+00	25	1.00693D+00
164	1.51406D+01	2	1.98357D-06	1.05500D+00	0.0	0.0	0.0	2	1.05493D-06	25	1.86496D+00	25	1.00693D+00
164	1.51406D+01	3	1.70860D-06	1.05500D+00	0.0	0.0	0.0	3	1.92734D-06	25	1.86496D+00	25	1.00693D+00
164	1.51327D+01	1	1.31798D-05	1.05500D+00	0.0	0.0	0.0	1	1.42454D-06	25	1.76985D+00	25	1.00693D+00
164	1.51327D+01	2	1.06911D-06	1.05500D+00	0.0	0.0	0.0	2	1.04508D-07	25	1.76985D+00	25	1.00693D+00
164	1.51327D+01	3	1.28853D-06	1.05500D+00	0.0	0.0	0.0	3	1.04508D-07	25	1.76985D+00	25	1.00693D+00

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NUMBER OF	TIME	DIAG	DIAG	NO	1.1 NORM OF	MAX TEMP	DIFF	MAX PERCENT	
TIME	STEPS	(ITERATION)	(JACOBI)	TIER	TEMP DIFF	CHANGE		TEMP CHANGE	
164	1.5133D+01	5	8	11	8	68105D+01	13	8	83726D+02
		19	8	21	9	05727D+01	24	1	83726D+02
165	1.5265D+01	0	0	0	0	0	0	0	0
165	1.5265D+01	1	7	1	5	12505D-05	2	2	43347D-06
165	1.5265D+01	2	9	2	2	43347D-06	25	1	79987D+00
165	1.5265D+01	3	2	11	8	57248D+01	13	8	68035D+01
165	1.5265D+01	5	8	21	9	06029D+01	24	1	82006D+02
165	1.5265D+01	19	8	21	9	06029D+01	24	1	82006D+02
166	1.5390D+01	0	0	0	0	0	0	0	0
166	1.5390D+01	1	8	1	4	51190D-05	2	1	97294D-06
166	1.5390D+01	3	2	11	8	57248D+01	13	8	67970D+01
166	1.5390D+01	5	8	21	9	06288D+01	24	1	80345D+02
166	1.5390D+01	19	8	21	9	06288D+01	24	1	80345D+02
167	1.5515D+01	0	0	0	0	0	0	0	0
167	1.5515D+01	1	3	1	3	31366D-05	2	1	01943D-06
167	1.5515D+01	2	4	11	8	57180D+01	13	8	67905D+01
167	1.5515D+01	5	8	21	9	06524D+01	24	1	78653D+02
167	1.5515D+01	19	8	21	9	06524D+01	24	1	78653D+02
168	1.5640D+01	0	0	0	0	0	0	0	0
168	1.5640D+01	1	6	1	9	92892D-05	2	1	20256D-05
168	1.5640D+01	4	1	11	8	57180D+01	13	8	67905D+01
168	1.5640D+01	5	8	21	9	06524D+01	24	1	78653D+02
168	1.5640D+01	19	8	21	9	06524D+01	24	1	78653D+02
168	1.5622D+01	0	0	0	0	0	0	0	0
168	1.5622D+01	1	2	1	4	53602D-06	2	5	19592D-07
168	1.5622D+01	3	8	11	8	57157D+01	13	8	67850D+01
168	1.5622D+01	5	8	21	9	06709D+01	24	1	71129D+02
168	1.5622D+01	19	8	21	9	06709D+01	24	1	71129D+02
169	1.5730D+01	0	0	0	0	0	0	0	0
169	1.5730D+01	1	3	1	8	66386D-05	2	7	10815D-06
169	1.5730D+01	2	6	11	8	57157D+01	13	8	67850D+01
169	1.5730D+01	5	8	21	9	06863D+01	24	1	75633D+02
169	1.5730D+01	19	8	21	9	06863D+01	24	1	75633D+02
169	1.5720D+01	0	0	0	0	0	0	0	0
169	1.5720D+01	1	4	1	4	37741D-06	2	6	04244D-07
169	1.5720D+01	2	6	11	8	57157D+01	13	8	67850D+01
169	1.5720D+01	5	8	21	9	06863D+01	24	1	75633D+02
169	1.5720D+01	19	8	21	9	06863D+01	24	1	75633D+02
170	1.5818D+01	0	0	0	0	0	0	0	0
170	1.5818D+01	1	1	1	6	03726D-05	2	2	82718D-06
170	1.5818D+01	2	2	11	8	57157D+01	13	8	67850D+01
170	1.5818D+01	5	8	21	9	06996D+01	24	1	74119D+02
170	1.5818D+01	19	8	21	9	06996D+01	24	1	74119D+02
170	1.5813D+01	0	0	0	0	0	0	0	0
170	1.5813D+01	1	1	1	2	46274D-06	2	3	17734D-07
170	1.5813D+01	2	2	11	8	57102D+01	13	8	67530D+01
170	1.5813D+01	5	8	21	9	06996D+01	24	1	74119D+02
170	1.5813D+01	19	8	21	9	06996D+01	24	1	74119D+02

171	1.590610+01	1	7.753690-05	1	055000+00	0	0	0	0	0	0	0	0	1	4.934710-05	25	1	712560+00	25	9	894150-01					
171	1.590610+01	2	7.050920-06	1	055000+00	0	0	0	0	0	0	0	0	2	2.507830-06	25	1	712560+00	25	9	894150-01					
171	1.590610+01	2	1.477620-06	1	055000+00	0	0	0	0	0	0	0	0	11	8.570740+01	13	8	677070+01	13	8	677070+01					
171	1.590610+01	1	7.612850+01	3	8.099340+01	5	8	283070+01	21	9	071170+01	24	1	725330+02	24	1	725330+02	24	1	725330+02	24	1	725330+02			
171	1.590610+01	15	8.763590+01	17	8.832140+01	19	8	918110+01	19	8	918110+01	21	9	071170+01	24	1	725330+02	24	1	725330+02	24	1	725330+02			
171	1.590610+01	25	1.713760+02	25	1.713760+02	25	1	713760+02	25	1	713760+02	25	1	713760+02	25	1	713760+02	25	1	713760+02	25	1	713760+02			
172	1.600000+01	1	7.413820-05	1	055000+00	0	0	0	0	0	0	0	0	1	4.589120-05	25	1	776300+00	25	1	036500+00	25	1	036500+00		
172	1.600000+01	2	7.314770-06	1	055000+00	0	0	0	0	0	0	0	0	2	2.288990-06	25	1	776300+00	25	1	036500+00	25	1	036500+00		
172	1.600000+01	2	1.380250-06	1	055000+00	0	0	0	0	0	0	0	0	1	3.748180-06	25	1	776300+00	25	1	036500+00	25	1	036500+00		
172	1.599220+01	1	2.089630-05	1	055000+00	0	0	0	0	0	0	0	0	2	4.358560-07	25	1	637820+00	25	9	555860-01	25	9	555860-01		
172	1.599220+01	2	2.414400-06	1	055000+00	0	0	0	0	0	0	0	0	11	8.570470+01	13	8	676640+01	13	8	676640+01	13	8	676640+01		
172	1.599220+01	1	2.425040-06	1	055000+00	0	0	0	0	0	0	0	0	21	9.072180+01	24	1	710060+02	24	1	710060+02	24	1	710060+02		
172	1.599220+01	1	7.612810+01	3	8.099830+01	5	8	282900+01	19	8	919620+01	19	8	919620+01	21	9	072180+01	24	1	710060+02	24	1	710060+02	24	1	710060+02
172	1.599220+01	15	8.763160+01	17	8.832490+01	19	8	919620+01	19	8	919620+01	21	9	072180+01	24	1	710060+02	24	1	710060+02	24	1	710060+02	24	1	710060+02
172	1.599220+01	25	1.697380+02	25	1.697380+02	25	1	697380+02	25	1	697380+02	25	1	697380+02	25	1	697380+02	25	1	697380+02	25	1	697380+02	25	1	697380+02
173	1.600220+01	1	7.008610-06	1	055000+00	0	0	0	0	0	0	0	0	1	7.065560-06	25	2	102740-01	25	2	102740-01	25	2	102740-01		
173	1.600220+01	1	7.008610-06	1	055000+00	0	0	0	0	0	0	0	0	2	5.623480-07	25	2	102740-01	25	2	102740-01	25	2	102740-01		
173	1.600220+01	1	5.291640-07	1	055000+00	0	0	0	0	0	0	0	0	11	8.570440+01	13	8	676590+01	13	8	676590+01	13	8	676590+01		
173	1.600220+01	1	7.612810+01	3	8.099810+01	5	8	282880+01	19	8	919790+01	19	8	919790+01	21	9	072230+01	24	1	708250+02	24	1	708250+02	24	1	708250+02
173	1.600220+01	15	8.763110+01	17	8.832530+01	19	8	919790+01	19	8	919790+01	21	9	072230+01	24	1	708250+02	24	1	708250+02	24	1	708250+02	24	1	708250+02
173	1.600220+01	25	1.695280+02	25	1.695280+02	25	1	695280+02	25	1	695280+02	25	1	695280+02	25	1	695280+02	25	1	695280+02	25	1	695280+02	25	1	695280+02

HEATING 02/12/83  
W9YMP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

18M3033/ 0  
20 57 59 11-16-89

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 173 TIME STEPS, TIME = 1.60022D+01

GROSS GRID 1

FINE GRID 1

DISTANCE 0.0

1	0.0	76113
2	0.03	78156
3	0.06	81100
4	0.08	81191
5	0.10	82183
6	0.57	83131
7	1.04	83180
8	1.51	84128
9	1.98	84176
10	2.45	85123
11	2.92	85170
12	3.14	86125
13	3.35	86177
14	3.57	87123
15	3.79	87163
16	4.01	87199
17	4.23	88133
18	4.45	88171
19	4.67	89120
20	4.89	89187
21	5.10	90172
22	5.18	119178
23	5.25	147115
24	5.32	170182
25	5.35	169153

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	93.690670
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 1.00000000D-02

ELAPSED CPU TIME IS 2.16 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.70825D+02 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 24

THE MINIMUM TEMPERATURE IS - 7.61281D+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO	MAX HEAT	BETA	L1 NORM OF	RMS	RMS	MD	L1 NORM OF	MAX TEMP	NODE	MAX PERCENT	
		ITER	RESIDUAL		TEMP DIFF	(ITERATION)	(JACOBI)	ITER	TEMP DIFF	CHANGE		TEMP	
174	1.601220+01	1	9.570280-07	1.055000+00	0.0	0.0	0.0	1	1.110330-06	25	2.085700-01	25	1.230300-01
174	1.601220+01	1	9.570280-07	1.055000+00	0.0	0.0	0.0	2	7.223310-08	25	2.085700-01	25	1.230300-01
174	1.601220+01	1	7.885930-08	1.055000+00	0.0	0.0	0.0	1	1.014670-06	25	2.085700-01	25	1.230300-01
175	1.602220+01	1	8.550840-07	1.055000+00	0.0	0.0	0.0	1	1.014670-06	25	2.085700-01	25	1.230300-01
175	1.602220+01	1	8.550840-07	1.055000+00	0.0	0.0	0.0	2	6.540830-08	25	2.071200-01	25	1.223250-01
175	1.602220+01	1	7.035860-08	1.055000+00	0.0	0.0	0.0	1	8.570380+01	13	8.676490+01	13	8.676490+01
175	1.602220+01	1	7.612790+01	3.8099780+01	3.8099780+01	5.828280+01	11	8.920140+01	24	1.704580+02	24	1.704580+02	
175	1.602220+01	1	7.612790+01	3.8099780+01	3.8099780+01	5.828280+01	11	8.920140+01	24	1.704580+02	24	1.704580+02	
176	1.603220+01	1	7.156430-07	1.055000+00	0.0	0.0	0.0	1	8.913230-07	25	2.059670-01	25	1.217930-01
176	1.603220+01	1	7.156430-07	1.055000+00	0.0	0.0	0.0	2	5.372300-08	25	2.059670-01	25	1.217930-01
176	1.603220+01	1	5.741600-08	1.055000+00	0.0	0.0	0.0	1	8.570350+01	13	8.676440+01	13	8.676440+01
176	1.603220+01	1	7.612790+01	3.8099770+01	3.8099770+01	5.828280+01	11	8.920140+01	24	1.702720+02	24	1.702720+02	
176	1.603220+01	1	7.612790+01	3.8099770+01	3.8099770+01	5.828280+01	11	8.920140+01	24	1.702720+02	24	1.702720+02	
177	1.604320+01	1	7.836560-07	1.055000+00	0.0	0.0	0.0	1	8.762410-07	25	2.252640-01	25	1.333660-01
177	1.604320+01	1	7.836560-07	1.055000+00	0.0	0.0	0.0	2	6.317580-08	25	2.252640-01	25	1.333660-01
177	1.604320+01	1	5.744010-08	1.055000+00	0.0	0.0	0.0	1	8.570310+01	13	8.676380+01	13	8.676380+01
177	1.604320+01	1	7.612790+01	3.8099750+01	3.8099750+01	5.828280+01	11	8.920140+01	24	1.700670+02	24	1.700670+02	
177	1.604320+01	1	7.612790+01	3.8099750+01	3.8099750+01	5.828280+01	11	8.920140+01	24	1.700670+02	24	1.700670+02	
178	1.605530+01	1	8.076630-07	1.055000+00	0.0	0.0	0.0	1	1.031030-06	25	2.465850-01	25	1.461850-01
178	1.605530+01	1	8.076630-07	1.055000+00	0.0	0.0	0.0	2	6.405420-08	25	2.465850-01	25	1.461850-01
178	1.605530+01	1	6.949090-08	1.055000+00	0.0	0.0	0.0	1	8.570270+01	13	8.676320+01	13	8.676320+01
178	1.605530+01	1	7.612790+01	3.8099740+01	3.8099740+01	5.828280+01	11	8.920140+01	24	1.698390+02	24	1.698390+02	
178	1.605530+01	1	7.612790+01	3.8099740+01	3.8099740+01	5.828280+01	11	8.920140+01	24	1.698390+02	24	1.698390+02	
179	1.606860+01	1	8.385400-07	1.055000+00	0.0	0.0	0.0	1	1.102100-06	25	2.701040-01	25	1.603620-01
179	1.606860+01	1	8.385400-07	1.055000+00	0.0	0.0	0.0	2	6.390180-08	25	2.701040-01	25	1.603620-01
179	1.606860+01	1	6.990850-08	1.055000+00	0.0	0.0	0.0	1	8.570230+01	13	8.676260+01	13	8.676260+01
179	1.606860+01	1	7.612790+01	3.8099720+01	3.8099720+01	5.828270+01	11	8.920140+01	24	1.695880+02	24	1.695880+02	
179	1.606860+01	1	7.612790+01	3.8099720+01	3.8099720+01	5.828270+01	11	8.920140+01	24	1.695880+02	24	1.695880+02	
180	1.608320+01	1	8.049300-07	1.055000+00	0.0	0.0	0.0	1	1.146650-06	25	2.962030-01	25	1.761390-01
180	1.608320+01	1	8.049300-07	1.055000+00	0.0	0.0	0.0	2	6.307000-08	25	2.962030-01	25	1.761390-01
180	1.608320+01	1	6.849250-08	1.055000+00	0.0	0.0	0.0	1	8.570180+01	13	8.676190+01	13	8.676190+01
180	1.608320+01	1	7.612790+01	3.8099700+01	3.8099700+01	5.828270+01	11	8.921180+01	24	1.693100+02	24	1.693100+02	
180	1.608320+01	1	7.612790+01	3.8099700+01	3.8099700+01	5.828270+01	11	8.921180+01	24	1.693100+02	24	1.693100+02	
181	1.609930+01	1	7.749800-07	1.055000+00	0.0	0.0	0.0	1	1.214350-06	25	3.250960-01	25	1.936610-01
181	1.609930+01	1	7.749800-07	1.055000+00	0.0	0.0	0.0	2	5.799180-08	25	3.250960-01	25	1.936610-01
181	1.609930+01	1	6.039110-08	1.055000+00	0.0	0.0	0.0	1	8.570130+01	13	8.676110+01	13	8.676110+01
181	1.609930+01	1	7.612790+01	3.8099670+01	3.8099670+01	5.828260+01	11	8.921450+01	24	1.690030+02	24	1.690030+02	
181	1.609930+01	1	7.612790+01	3.8099670+01	3.8099670+01	5.828260+01	11	8.921450+01	24	1.690030+02	24	1.690030+02	
182	1.611700+01	1	7.066710-07	1.055000+00	0.0	0.0	0.0	1	1.283120-06	25	3.571430-01	25	2.131650-01
182	1.611700+01	1	7.066710-07	1.055000+00	0.0	0.0	0.0	2	5.456250-08	25	3.571430-01	25	2.131650-01
182	1.611700+01	1	5.342280-08	1.055000+00	0.0	0.0	0.0	1	8.570070+01	13	8.676020+01	13	8.676020+01
182	1.611700+01	1	7.612790+01	3.8099650+01	3.8099650+01	5.828250+01	11	8.921750+01	24	1.686540+02	24	1.686540+02	
182	1.611700+01	1	7.612790+01	3.8099650+01	3.8099650+01	5.828250+01	11	8.921750+01	24	1.686540+02	24	1.686540+02	
183	1.613650+01	1	6.360390-07	1.055000+00	0.0	0.0	0.0	1	1.381810-06	25	3.926130-01	25	2.348370-01
183	1.613650+01	1	6.360390-07	1.055000+00	0.0	0.0	0.0	2	4.792980-08	25	3.926130-01	25	2.348370-01
183	1.613650+01	1	3.768710-08	1.055000+00	0.0	0.0	0.0	1	8.570010+01	13	8.675920+01	13	8.675920+01
183	1.613650+01	1	7.612790+01	3.8099620+01	3.8099620+01	5.828240+01	11	8.926760+01	24	1.675920+01	24	1.675920+01	
183	1.613650+01	1	7.612790+01	3.8099620+01	3.8099620+01	5.828240+01	11	8.926760+01	24	1.675920+01	24	1.675920+01	

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

\*\*\*\*\* NODE NUMBERS AND TEMPERATURES \*\*\*\*\*

NUMBER OF TIME  
 TIME STEPS  
 174 1.60120+01  
 175 1.60220+01  
 176 1.60320+01  
 177 1.60430+01  
 178 1.60550+01  
 179 1.60680+01  
 180 1.60830+01  
 181 1.60990+01  
 182 1.61170+01  
 183 1.61360+01

184	1.615800+01	15 8.762490+01	17 8.833090+01	19 8.922080+01	21 9.073620+01	24 1.582890+02			
		25 1.667930+02							
184	1.615800+01	1 5.162650-07	1 0.055000+00	0 0	0 0	0 0			
184	1.615800+01	1 5.162650-07	1 0.055000+00	0 0	0 0	0 0			
184	1.615800+01	1 2.194480-08	1 0.055000+00	0 0	0 0	0 0			
184	1.615800+01	1 7.612720+01	3 8.099580+01	5 8.282560+01	11 8.569940+01	13 8.675820+01	25 4.319720-01	25 2.589870-01	
		15 8.762390+01	17 8.833180+01	19 8.922430+01	21 9.073810+01	24 1.678750+02			
		25 1.663610+02							
185	1.618150+01	1 6.032880-07	1 0.055000+00	0 0	0 0	0 0			
185	1.618150+01	1 6.032880-07	1 0.055000+00	0 0	0 0	0 0			
185	1.618150+01	1 2.978550-08	1 0.055000+00	0 0	0 0	0 0			
185	1.618150+01	1 7.612710+01	3 8.099550+01	5 8.282510+01	11 8.569860+01	13 8.675700+01	25 4.755970-01	25 2.858820-01	
		15 8.762280+01	17 8.833280+01	19 8.922820+01	21 9.074010+01	24 1.674180+02			
		25 1.658860+02							
186	1.620750+01	1 6.897140-07	1 0.055000+00	0 0	0 0	0 0			
186	1.620750+01	1 6.897140-07	1 0.055000+00	0 0	0 0	0 0			
186	1.620750+01	1 3.931120-08	1 0.055000+00	0 0	0 0	0 0			
186	1.620750+01	1 7.612700+01	3 8.099510+01	5 8.282460+01	11 8.569780+01	13 8.675580+01	25 2.239050-01	25 3.158230-01	
		15 8.762170+01	17 8.833380+01	19 8.923250+01	21 9.074210+01	24 1.669140+02			
		25 1.653620+02							
187	1.623600+01	1 7.709430-07	1 0.055000+00	0 0	0 0	0 0			
187	1.623600+01	1 7.709430-07	1 0.055000+00	0 0	0 0	0 0			
187	1.623600+01	1 9.528850-08	1 0.055000+00	0 0	0 0	0 0			
187	1.623600+01	1 7.612680+01	3 8.099460+01	5 8.282400+01	11 8.569680+01	13 8.675440+01	25 5.774330-01	25 3.491940-01	
		15 8.762050+01	17 8.833510+01	19 8.923710+01	21 9.074430+01	24 1.663570+02			
		25 1.647840+02							
188	1.626740+01	1 8.420020-07	1 0.055000+00	0 0	0 0	0 0			
188	1.626740+01	1 8.420020-07	1 0.055000+00	0 0	0 0	0 0			
188	1.626740+01	1 1.651020-07	1 0.055000+00	0 0	0 0	0 0			
188	1.626740+01	1 7.612670+01	3 8.099410+01	5 8.282330+01	11 8.569580+01	13 8.675280+01	25 6.367830-01	25 3.864240-01	
		15 8.761910+01	17 8.833650+01	19 8.924220+01	21 9.074650+01	24 1.657430+02			
		25 1.641470+02							
189	1.630190+01	1 8.882800-07	1 0.055000+00	0 0	0 0	0 0			
189	1.630190+01	1 8.882800-07	1 0.055000+00	0 0	0 0	0 0			
189	1.630190+01	1 2.251230-07	1 0.055000+00	0 0	0 0	0 0			
189	1.630190+01	1 7.612650+01	3 8.099350+01	5 8.282250+01	11 8.569460+01	13 8.675120+01	25 7.024040-01	25 4.779110-01	
		15 8.761770+01	17 8.833800+01	19 8.924770+01	21 9.074880+01	24 1.650640+02			
		25 1.634450+02							
190	1.633990+01	1 1.408250-06	1 0.055000+00	0 0	0 0	0 0			
190	1.633990+01	1 1.408250-06	1 0.055000+00	0 0	0 0	0 0			
190	1.633990+01	1 3.451010-07	1 0.055000+00	0 0	0 0	0 0			
190	1.633990+01	1 7.612630+01	3 8.099290+01	5 8.282170+01	11 8.569330+01	13 8.674940+01	25 7.751970-01	25 4.742860-01	
		15 8.761610+01	17 8.833970+01	19 8.925370+01	21 9.075110+01	24 1.643150+02			
		25 1.626700+02							
191	1.638170+01	1 1.894890-06	1 0.055000+00	0 0	0 0	0 0			
191	1.638170+01	1 1.894890-06	1 0.055000+00	0 0	0 0	0 0			
191	1.638170+01	1 4.511950-07	1 0.055000+00	0 0	0 0	0 0			
191	1.638170+01	1 7.612600+01	3 8.099220+01	5 8.282070+01	11 8.569190+01	13 8.674730+01	25 8.556510-01	25 5.260040-01	
		15 8.761440+01	17 8.834160+01	19 8.926020+01	21 9.075330+01	24 1.634870+02			
		25 1.618140+02							
192	1.642760+01	1 2.761200-06	1 0.055000+00	0 0	0 0	0 0			
192	1.642760+01	1 2.761200-06	1 0.055000+00	0 0	0 0	0 0			
192	1.642760+01	1 6.022480-07	1 0.055000+00	0 0	0 0	0 0			
192	1.642760+01	1 7.612580+01	3 8.099140+01	5 8.281970+01	11 8.569030+01	13 8.674530+01	25 9.448020-01	25 5.638810-01	
		15 8.761260+01	17 8.834370+01	19 8.926730+01	21 9.075550+01	24 1.625170+02			
		25 1.608690+02							
193	1.647820+01	1 4.072240-06	1 0.055000+00	0 0	0 0	0 0			
193	1.647820+01	1 4.072240-06	1 0.055000+00	0 0	0 0	0 0			
193	1.647820+01	1 8.556750-07	1 0.055000+00	0 0	0 0	0 0			
193	1.647820+01	1 7.612550+01	3 8.099060+01	5 8.281850+01	11 8.568860+01	13 8.674280+01	25 1.043730+00	25 6.488050-01	
		15 8.761070+01	17 8.834600+01	19 8.927490+01	21 9.075750+01	24 1.615610+02			
		25 1.598260+02							
194	1.653380+01	1 7.547200-06	1 0.055000+00	0 0	0 0	0 0			
194	1.653380+01	1 7.547200-06	1 0.055000+00	0 0	0 0	0 0			
194	1.653380+01	1 1.486910-06	1 0.055000+00	0 0	0 0	0 0			
194	1.653380+01	1 7.612510+01	3 8.098960+01	5 8.281720+01	11 8.568660+01	13 8.674010+01	25 1.154760+00	25 7.275150-01	
		15 8.761070+01	17 8.834600+01	19 8.927490+01	21 9.075750+01	24 1.615610+02			
		25 1.598260+02							



195	1.659490+01	1.2.889510-05	1.055000+00	0.0	0.0	0.0	0.0	0.0	1.0.075920+01	24.1.604420+02	25.8.131130-01
195	1.659490+01	2.2.442840-06	1.055000+00	0.0	0.0	0.0	0.0	0.0	1.1.333350-05	25.1.220110+00	25.8.131130-01
195	1.659490+01	1.2.602800-06	1.055000+00	0.0	0.0	0.0	0.0	0.0	2.6.707380-07	25.1.220110+00	25.8.131130-01
195	1.659500+01	1.7.612480+01	3.8.098500+01	3.8.098500+01	19.8.929210+01	19.8.835140+01	17.8.835140+01	0.0	11.8.568450+01	13.8.673720+01	24.1.592030+02
		15.8.760640+01	17.8.835140+01	17.8.835140+01	19.8.929210+01	19.8.835140+01	17.8.835140+01	0.0	21.9.076050+01	24.1.592030+02	25.8.131130-01
		25.1.573810+02	17.8.835140+01	17.8.835140+01	19.8.929210+01	19.8.835140+01	17.8.835140+01	0.0	1.1.459180-05	25.1.435800+00	25.8.123100-01
196	1.666220+01	1.2.428490-05	1.055000+00	0.0	0.0	0.0	0.0	0.0	2.5.847740-07	25.1.435800+00	25.8.123100-01
196	1.666220+01	2.2.010750-06	1.055000+00	0.0	0.0	0.0	0.0	0.0	1.1.459180-05	25.1.435800+00	25.8.123100-01
196	1.666220+01	1.2.538370-06	1.055000+00	0.0	0.0	0.0	0.0	0.0	2.5.847740-07	25.1.435800+00	25.8.123100-01
196	1.666200+01	1.7.612480+01	3.8.098500+01	3.8.098500+01	19.8.930170+01	19.8.835450+01	17.8.835450+01	0.0	11.8.568210+01	13.8.673440+01	24.1.578240+02
		15.8.760400+01	17.8.835450+01	17.8.835450+01	19.8.930170+01	19.8.835450+01	17.8.835450+01	0.0	21.9.076130+01	24.1.578240+02	25.8.131130-01
		25.1.559450+02	17.8.835450+01	17.8.835450+01	19.8.930170+01	19.8.835450+01	17.8.835450+01	0.0	1.1.689560-05	25.1.514740+00	25.8.113320-01
197	1.673220+01	1.3.040860-05	1.055000+00	0.0	0.0	0.0	0.0	0.0	2.7.312880-07	25.1.514740+00	25.8.113320-01
197	1.673220+01	2.2.578440-06	1.055000+00	0.0	0.0	0.0	0.0	0.0	1.1.689560-05	25.1.514740+00	25.8.113320-01
197	1.673220+01	1.3.243310-06	1.055000+00	0.0	0.0	0.0	0.0	0.0	2.7.312880-07	25.1.514740+00	25.8.113320-01
197	1.673200+01	1.7.612390+01	3.8.098500+01	3.8.098500+01	19.8.931140+01	19.8.835790+01	17.8.835790+01	0.0	11.8.567960+01	13.8.673090+01	24.1.563720+02
		15.8.760170+01	17.8.835790+01	17.8.835790+01	19.8.931140+01	19.8.835790+01	17.8.835790+01	0.0	21.9.076140+01	24.1.563720+02	25.8.131130-01
		25.1.544300+02	17.8.835790+01	17.8.835790+01	19.8.931140+01	19.8.835790+01	17.8.835790+01	0.0	1.1.737940-05	25.1.534430+00	25.8.936100-01
198	1.680230+01	1.3.025210-05	1.055000+00	0.0	0.0	0.0	0.0	0.0	1.1.737940-05	25.1.534430+00	25.8.936100-01
198	1.680230+01	2.2.519310-06	1.055000+00	0.0	0.0	0.0	0.0	0.0	2.7.193380-07	25.1.534430+00	25.8.936100-01
198	1.680230+01	1.3.233730-06	1.055000+00	0.0	0.0	0.0	0.0	0.0	1.1.737940-05	25.1.534430+00	25.8.936100-01
198	1.680200+01	1.7.612340+01	3.8.098460+01	3.8.098460+01	19.8.932090+01	19.8.836120+01	17.8.836120+01	0.0	11.8.567740+01	13.8.672770+01	24.1.549010+02
		15.8.759940+01	17.8.836120+01	17.8.836120+01	19.8.932090+01	19.8.836120+01	17.8.836120+01	0.0	21.9.076070+01	24.1.549010+02	25.8.131130-01
		25.1.528560+02	17.8.836120+01	17.8.836120+01	19.8.932090+01	19.8.836120+01	17.8.836120+01	0.0	1.1.633350-05	25.1.550480+00	25.8.114080+00
199	1.687230+01	1.2.359270-05	1.055000+00	0.0	0.0	0.0	0.0	0.0	2.5.900970-07	25.1.550480+00	25.8.114080+00
199	1.687230+01	2.1.957690-06	1.055000+00	0.0	0.0	0.0	0.0	0.0	1.1.976230-06	25.1.457870+00	25.8.535070-01
199	1.687230+01	1.2.674150-06	1.055000+00	0.0	0.0	0.0	0.0	0.0	2.5.102270-07	25.1.457870+00	25.8.535070-01
199	1.686790+01	1.9.625720-06	1.055000+00	0.0	0.0	0.0	0.0	0.0	1.1.976230-06	25.1.457870+00	25.8.535070-01
199	1.686790+01	1.9.625720-05	1.055000+00	0.0	0.0	0.0	0.0	0.0	2.5.102270-07	25.1.457870+00	25.8.535070-01
199	1.686790+01	1.4.866050-05	1.055000+00	0.0	0.0	0.0	0.0	0.0	11.8.567470+01	13.8.672470+01	24.1.535060+02
		15.8.759370+01	17.8.836440+01	17.8.836440+01	19.8.932940+01	19.8.836440+01	17.8.836440+01	0.0	21.9.075940+01	24.1.535060+02	25.8.131130-01
		25.1.514380+02	17.8.836440+01	17.8.836440+01	19.8.932940+01	19.8.836440+01	17.8.836440+01	0.0	1.1.332950-05	25.1.467730+00	25.8.691960-01
200	1.693350+01	1.1.119840-05	1.055000+00	0.0	0.0	0.0	0.0	0.0	2.3.326540-07	25.1.467730+00	25.8.691960-01
200	1.693350+01	2.1.151130-06	1.055000+00	0.0	0.0	0.0	0.0	0.0	1.1.332950-05	25.1.467730+00	25.8.691960-01
200	1.693350+01	1.4.400400-06	1.055000+00	0.0	0.0	0.0	0.0	0.0	2.3.326540-07	25.1.467730+00	25.8.691960-01
200	1.693400+01	1.7.612250+01	3.8.098200+01	3.8.098200+01	19.8.933780+01	19.8.836750+01	17.8.836750+01	0.0	11.8.567230+01	13.8.672170+01	24.1.520250+02
		15.8.759540+01	17.8.836750+01	17.8.836750+01	19.8.933780+01	19.8.836750+01	17.8.836750+01	0.0	21.9.075750+01	24.1.520250+02	25.8.131130-01
		25.1.499700+02	17.8.836750+01	17.8.836750+01	19.8.933780+01	19.8.836750+01	17.8.836750+01	0.0	1.1.293910-05	25.1.496280+00	25.8.977220-01
201	1.700000+01	1.1.307140-05	1.055000+00	0.0	0.0	0.0	0.0	0.0	2.3.542790-07	25.1.496280+00	25.8.977220-01
201	1.700000+01	2.1.222370-06	1.055000+00	0.0	0.0	0.0	0.0	0.0	1.1.293910-05	25.1.496280+00	25.8.977220-01
201	1.700000+01	1.1.550160-06	1.055000+00	0.0	0.0	0.0	0.0	0.0	2.3.542790-07	25.1.496280+00	25.8.977220-01
201	1.700000+01	1.7.612210+01	3.8.098060+01	3.8.098060+01	19.8.934600+01	19.8.837080+01	17.8.837080+01	0.0	11.8.565980+01	13.8.671870+01	24.1.506520+02
		15.8.759350+01	17.8.837080+01	17.8.837080+01	19.8.934600+01	19.8.837080+01	17.8.837080+01	0.0	21.9.075490+01	24.1.506520+02	25.8.131130-01
		25.1.484740+02	17.8.837080+01	17.8.837080+01	19.8.934600+01	19.8.837080+01	17.8.837080+01	0.0	1.1.793910-05	25.1.506520+02	25.8.131130-01

HEATING6 02/12/83

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 201 TIME STEPS. TIME = 1.700000E+01

W9XNP110

BM3033/ 0  
20 57.59 11 5-R9

BOUNDARY NUMBER	TEMPERATURE
1	94.000000
2	0.0
3	73.400000

TEMPERATURES (CN NUMBERED BOUNDARIES)

BOUNDARY NUMBER	TEMPERATURE
1	94.000000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 6.64504772D-02

ELAPSED CPU TIME IS 2.44 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.50652D+02 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 24

THE MINIMUM TEMPERATURE IS - 7.61221D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHD (ITERATION)	RHD (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	RHOE TEMP CHANGE	MAX PERCENT TEMP CHANGE
202	1 70650+01	1 2.5076D-05	1.055000+00	0.0	0.0	0.0	1 1.47348D-05	25 1.512610+00	25 1.01877D+00		
202	1 70650+01	2 2.0490D-06	1.055000+00	0.0	0.0	0.0	2 5.88579D-07				
202	1 70650+01	1 2.52240D-06	1.055000+00	0.0	0.0	0.0					
202	1 70650+01	1 9.18545D-06	1.055000+00	0.0	0.0	0.0					
202	1 706200+01	1 9.18545D-06	1.055000+00	0.0	0.0	0.0	1 1.97012D-06	25 1.41578D+00	25 9.53558D-01		
202	1 706200+01	1 1.41338D-06	1.055000+00	0.0	0.0	0.0	2 4.96767D-07				

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NUMBER OF TIME STEPS	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHD (ITERATION)	RHD (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	RHOE TEMP CHANGE
202	1 70620+01	1 7.61216D+01	3.8 09794D+01	5.8 28038D+01	11.8 56675D+01	13.8 67160D+01					
		15.8 75917D+01	17.8 83738D+01	19.8 93534D+01	21.9 07519D+01	24.1 49293D+02					
		25 1.47058D+02									
203	1 71239D+01	1 1.00790D-05	1.055000+00	0.0	0.0	0.0	1 1.17110D-05	25 1.42475D+00	25 9.68834D-01		
203	1 71239D+01	2 1.04815D-06	1.055000+00	0.0	0.0	0.0	2 2.91251D-07				
203	1 71239D+01	1 1.18719D-06	1.055000+00	0.0	0.0	0.0					
203	1 7124D+01	1 7.61212D+01	3.8 09781D+01	5.8 28021D+01	11.8 56657D+01	13.8 67137D+01					
		15.8 75901D+01	17.8 83768D+01	19.8 93660D+01	21.9 07483D+01	24.1 47921D+02					
		25 1.45633D+02									
204	1 71859D+01	1 1.22136D-05	1.055000+00	0.0	0.0	0.0	1 1.15047D-05	25 1.43446D+00	25 9.84980D-01		
204	1 71859D+01	2 1.16790D-06	1.055000+00	0.0	0.0	0.0	2 3.23455D-07				
204	1 71859D+01	1 1.31035D-06	1.055000+00	0.0	0.0	0.0					
204	1 7186D+01	1 7.61207D+01	3.8 09768D+01	5.8 28004D+01	11.8 56629D+01	13.8 67105D+01					
		15.8 75885D+01	17.8 83798D+01	19.8 93676D+01	21.9 07444D+01	24.1 46537D+02					
		25 1.44139D+02									
205	1 72479D+01	1 1.25875D-05	1.055000+00	0.0	0.0	0.0	1 1.17069D-05	25 1.44412D+00	25 1.00148D+00		
205	1 72479D+01	2 1.17608D-06	1.055000+00	0.0	0.0	0.0	2 3.16849D-07				
205	1 72479D+01	1 1.26912D-06	1.055000+00	0.0	0.0	0.0					
205	1 72447D+01	1 6.08158D-06	1.055000+00	0.0	0.0	0.0	1 1.35172D-06	25 1.37346D+00	25 9.52478D-01		
205	1 72447D+01	1 6.08158D-06	1.055000+00	0.0	0.0	0.0	2 3.44012D-07				
205	1 72447D+01	1 9.85942D-07	1.055000+00	0.0	0.0	0.0					
205	1 7245D+01	1 7.61203D+01	3.8 09755D+01	5.8 27988D+01	11.8 56607D+01	13.8 67080D+01					
		15.8 75870D+01	17.8 83827D+01	19.8 93740D+01	21.9 07397D+01	24.1 45213D+02					
		25 1.42825D+02									
206	1 73035D+01	1 7.34739D-06	1.055000+00	0.0	0.0	0.0	1 9.22949D-06	25 1.38031D+00	25 9.66425D-01		
206	1 73035D+01	1 7.34739D-06	1.055000+00	0.0	0.0	0.0	2 7.53430D-07				
206	1 73035D+01	1 1.71437D-06	1.055000+00	0.0	0.0	0.0					
206	1 7303D+01	1 7.61198D+01	3.8 09743D+01	5.8 27972D+01	11.8 56585D+01	13.8 67055D+01					
		15.8 75856D+01	17.8 83855D+01	19.8 93803D+01	21.9 07347D+01	24.1 43879D+02					
		25 1.41445D+02									
207	1 73622D+01	1 9.24221D-06	1.055000+00	0.0	0.0	0.0	1 9.05162D-06	25 1.38789D+00	25 9.81219D-01		
207	1 73622D+01	1 9.24221D-06	1.055000+00	0.0	0.0	0.0	2 8.09188D-07				
207	1 73622D+01	1 9.4432D-06	1.055000+00	0.0	0.0	0.0					
207	1 7362D+01	1 7.61194E+01	3.8 09730D+01	5.8 27956D+01	11.8 56563D+01	13.8 67030D+01					
		15.8 75842D+01	17.8 83894D+01	19.8 93863D+01	21.9 07293D+01	24.1 42536D+02					
		25 1.40057D+02									
208	1 74210D+01	1 9.98262D-06	1.055000+00	0.0	0.0	0.0	1 8.89586D-06	25 1.39571D+00	25 9.96525D-01		
208	1 74210D+01	1 9.98262D-06	1.055000+00	0.0	0.0	0.0	2 8.21304D-07				
208	1 74210D+01	1 1.99509D-06	1.055000+00	0.0	0.0	0.0					
208	1 7421D+01	1 7.61189D+01	3.8 09717D+01	5.8 27940D+01	11.8 56541D+01	13.8 67005D+01					
		15.8 75829D+01	17.8 83912D+01	19.8 93921D+01	21.9 07233D+01	24.1 41184D+02					
		25 1.38652D+02									
209	1 74798D+01	1 1.01190D-05	1.055000+00	0.0	0.0	0.0	1 9.10518D-06	25 1.40347D+00	25 1.01215D+00		
209	1 74798D+01	2 9.61473D-07	1.055000+00	0.0	0.0	0.0	2 2.60227D-07				
209	1 74798D+01	1 9.88103D-07	1.055000+00	0.0	0.0	0.0					
209	1 74762D+01	1 6.86268D-06	1.055000+00	0.0	0.0	0.0	1 1.57655D-06	25 1.32152D+00	25 9.53055D-01		
209	1 74762D+01	1 6.86268D-06	1.055000+00	0.0	0.0	0.0	2 3.77215D-07				
209	1 74762D+01	1 1.01487D-06	1.055000+00	0.0	0.0	0.0					
209	1 7476D+01	1 7.61185D+01	3.8 09705D+01	5.8 27924D+01	11.8 56520D+01	13.8 66982D+01					
		15.8 75817D+01	17.8 83939D+01	19.8 93973D+01	21.9 07173D+01	24.1 39907D+02					
		25 1.37340D+02									
210	1 75314D+01	1 2.43239D-06	1.055000+00	0.0	0.0	0.0					

210	1.753140+01	1	2.432390-06	1.055000+00	0.0	0.0	0.0	1.6	74390-06	25	1.324320+00	25	9.642650-01
210	1.753140+01	1	6.472850-07	1.055000+00	0.0	0.0	0.0	2.3	42930-07	25	1.324320+00	25	9.642650-01
210	1.753140+01	1	7.611810+01	3.8	096530+01	5.8	279090+01	11.8	564990+01	13.8	669360+01	21	9.071090+01
210	1.753140+01	1	7.611810+01	17.8	839650+01	19.8	940240+01	21.9	071090+01	24.1	386220+02	24	1.386220+02
211	1.758650+01	1	3.720250-05	1.055000+00	0.0	0.0	0.0	1.1	091120-05	25	1.302980+00	25	9.579650-01
211	1.758650+01	2	8.52280-06	1.055000+00	0.0	0.0	0.0	2.7	197700-07	25	1.302980+00	25	9.579650-01
211	1.758650+01	1	2.374530-06	1.055000+00	0.0	0.0	0.0	11.8	564780+01	13.8	669360+01	21	9.071090+01
211	1.758650+01	1	7.611760+01	3.8	096810+01	5.8	278930+01	11.8	564780+01	13.8	669360+01	21	9.071090+01
211	1.758650+01	1	7.611760+01	17.8	839920+01	19.8	940730+01	21.9	070400+01	24.1	373360+02	24	1.373360+02
212	1.764170+01	1	1.439930-05	1.055000+00	0.0	0.0	0.0	1.7	241820-06	25	1.293670+00	25	9.603190-01
212	1.764170+01	2	1.208480-06	1.055000+00	0.0	0.0	0.0	2.3	129330-07	25	1.293670+00	25	9.603190-01
212	1.764170+01	1	1.027770-06	1.055000+00	0.0	0.0	0.0	11.8	564570+01	13.8	669130+01	21	9.069670+01
212	1.76420+01	1	7.611720+01	3.8	096680+01	5.8	278780+01	11.8	564570+01	13.8	669130+01	21	9.069670+01
212	1.76420+01	1	7.611720+01	17.8	840180+01	19.8	941200+01	21.9	069670+01	24.1	360530+02	24	1.360530+02
213	1.769690+01	1	5.375180-06	1.055000+00	0.0	0.0	0.0	1.5	390740-06	25	1.289350+00	25	9.663890-01
213	1.769690+01	1	5.375180-06	1.055000+00	0.0	0.0	0.0	2.5	534510-07	25	1.289350+00	25	9.663890-01
213	1.769690+01	1	1.073840-06	1.055000+00	0.0	0.0	0.0	11.8	564360+01	13.8	668910+01	21	9.068900+01
213	1.76970+01	1	7.611670+01	3.8	096560+01	5.8	278620+01	11.8	564360+01	13.8	668910+01	21	9.068900+01
213	1.76970+01	1	7.611670+01	17.8	840440+01	19.8	941650+01	21.9	068900+01	24.1	347750+02	24	1.347750+02
214	1.775200+01	1	3.522660-06	1.055000+00	0.0	0.0	0.0	1.3	996880-06	25	1.287470+00	25	9.743960-01
214	1.775200+01	1	3.522660-06	1.055000+00	0.0	0.0	0.0	2.2	771410-07	25	1.287470+00	25	9.743960-01
214	1.775200+01	1	4.131210-07	1.055000+00	0.0	0.0	0.0	11.8	564160+01	13.8	668690+01	21	9.068090+01
214	1.77520+01	1	7.611630+01	3.8	096440+01	5.8	278460+01	11.8	564160+01	13.8	668690+01	21	9.068090+01
214	1.77520+01	1	7.611630+01	17.8	840700+01	19.8	942090+01	21.9	068090+01	24.1	335010+02	24	1.335010+02
215	1.780720+01	1	2.706160-06	1.055000+00	0.0	0.0	0.0	1.2	990610-06	25	1.286850+00	25	9.835110-01
215	1.780720+01	1	2.706160-06	1.055000+00	0.0	0.0	0.0	2.1	640460-07	25	1.286850+00	25	9.835110-01
215	1.780720+01	1	2.208250-07	1.055000+00	0.0	0.0	0.0	11.8	563950+01	13.8	668470+01	21	9.067240+01
215	1.78070+01	1	7.611590+01	3.8	096310+01	5.8	278300+01	11.8	563950+01	13.8	668470+01	21	9.067240+01
215	1.78070+01	1	7.611590+01	17.8	840960+01	19.8	942500+01	21.9	067240+01	24.1	322290+02	24	1.322290+02
216	1.786240+01	1	1.911960-06	1.055000+00	0.0	0.0	0.0	1.2	295310-06	25	1.287090+00	25	9.934700-01
216	1.786240+01	1	1.911960-06	1.055000+00	0.0	0.0	0.0	2.1	527750-07	25	1.287090+00	25	9.934700-01
216	1.786240+01	1	2.108240-07	1.055000+00	0.0	0.0	0.0	11.8	563740+01	13.8	668250+01	21	9.066340+01
216	1.78620+01	1	7.611540+01	3.8	096190+01	5.8	278150+01	11.8	563740+01	13.8	668250+01	21	9.066340+01
216	1.78620+01	1	7.611540+01	17.8	841220+01	19.8	942890+01	21.9	066340+01	24.1	309600+02	24	1.309600+02
217	1.791750+01	1	2.380510-06	1.055000+00	0.0	0.0	0.0	1.2	110960-06	25	1.288130+00	25	1.004250+00
217	1.791750+01	1	2.380510-06	1.055000+00	0.0	0.0	0.0	2.1	833570-07	25	1.288130+00	25	1.004250+00
217	1.791750+01	1	2.587490-07	1.055000+00	0.0	0.0	0.0	1.1	165230-06	25	1.221770+00	25	9.525080-01
217	1.791460+01	1	5.243670-06	1.055000+00	0.0	0.0	0.0	2.3	005870-07	25	1.221770+00	25	9.525080-01
217	1.791460+01	1	5.243670-06	1.055000+00	0.0	0.0	0.0	11.8	563540+01	13.8	668040+01	21	9.065460+01
217	1.791460+01	1	8.158630-07	1.055000+00	0.0	0.0	0.0	21.9	065460+01	24.1	297590+02	24	1.297590+02
217	1.79150+01	1	7.611500+01	3.8	096070+01	5.8	278000+01	11.8	563540+01	13.8	668040+01	21	9.065460+01
217	1.79150+01	1	7.611500+01	17.8	841460+01	19.8	943250+01	21.9	065460+01	24.1	297590+02	24	1.297590+02
218	1.795730+01	1	1.212610-05	1.055000+00	0.0	0.0	0.0	1.4	423360-06	25	1.009210+00	25	7.983610-01
218	1.795730+01	1	1.102550-06	1.055000+00	0.0	0.0	0.0	2.2	440600-07	25	1.009210+00	25	7.983610-01
218	1.795730+01	1	6.101680-07	1.055000+00	0.0	0.0	0.0	11.8	563380+01	13.8	667880+01	21	9.064710+01
218	1.79570+01	1	7.611450+01	3.8	095970+01	5.8	277870+01	11.8	563380+01	13.8	667880+01	21	9.064710+01
218	1.79570+01	1	7.611450+01	17.8	841650+01	19.8	943530+01	21.9	064710+01	24.1	287750+02	24	1.287750+02
219	1.800000+01	1	4.661020-06	1.055000+00	0.0	0.0	0.0	1.2	425250-06	25	1.006540+00	25	7.986030-01
219	1.800000+01	1	4.661020-06	1.055000+00	0.0	0.0	0.0	2.2	977300-07	25	1.006540+00	25	7.986030-01
219	1.800000+01	1	5.534670-07	1.055000+00	0.0	0.0	0.0	11.8	563210+01	13.8	667710+01	21	9.063940+01
219	1.80000+01	1	7.611430+01	3.8	095870+01	5.8	277750+01	11.8	563210+01	13.8	667710+01	21	9.063940+01
219	1.80000+01	1	7.611430+01	17.8	841840+01	19.8	943800+01	21.9	063940+01	24.1	277890+02	24	1.277890+02
219	1.80000+01	1	7.611430+01	17.8	841840+01	19.8	943800+01	21.9	063940+01	24.1	277890+02	24	1.277890+02
219	1.80000+01	25	1.250310+02										

HEATING6 02/12/83  
 W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-0 MODEL

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 219 TIME STEPS, TIME = 1.800000+01

TRM0037/ 0  
 20 58 00 11-16-89

GROSS GRID	1
FINE GRID	1
DISTANCE	0.0
1	0.0
2	0.03
3	0.06
4	0.08
5	0.10
6	0.57
7	1.04
8	1.51
9	1.98
10	2.45
11	2.92
12	3.14
13	3.35
14	3.57
15	3.79
16	4.01
17	4.23
18	4.45
19	4.67
20	4.89
21	5.10
22	5.18
23	5.25
24	5.32
25	5.35

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	93.690000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 4.27173945D-02

ELAPSED CPU TIME IS 2.66 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.27789D+02 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 24

THE MINIMUM TEMPERATURE IS - 7.61143D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO	MAX HEAT	BETA	L1 NORM OF	RHO	RHO	NO	L1 NORM OF	MAX TEMP	NOISE	MAX PERCENT
TIME	TIER	TIER	RESIDUAL		TEMP DIFF	(ITERATION)	(JACOBI)	ITER	TEMP DIFF	CHANGE		TEMP CHANGE
220	1.804270+01	1	1.437940-06	1.055000+00	0.0	0.0	0.0	1	1.576890-06	0.000000+00	25	8.062220-01
220	1.804270+01	1	1.437940-06	1.055000+00	0.0	0.0	0.0	2	1.256470-07	0.000000+00	25	8.062220-01
220	1.804270+01	1	2.650180-07	1.055000+00	0.0	0.0	0.0					

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NUMBER OF	TIME	NO	MAX HEAT	BETA	L1 NORM OF	RHO	RHO	NO	L1 NORM OF	MAX TEMP	NOISE	MAX PERCENT
TIME STEPS		TIER	RESIDUAL		TEMP DIFF	(ITERATION)	(JACOBI)	ITER	TEMP DIFF	CHANGE		TEMP CHANGE
220	1.80430+01	1	1.7611390+01	3.8095770+01	5.8277630+01	11.8277630+01	11.8277630+01	1	1.3853050+01	1.3853050+01	24	1.258020+02
			15.8752180+01	17.8842040+01	19.8844050+01	19.8844050+01	21.9063150+01	2	1.258020+02			
			25.1240230+02									
221	1.808540+01	1	2.023860-06	1.055000+00	0.0	0.0	0.0	1	1.826000-06			
221	1.808540+01	1	2.023860-06	1.055000+00	0.0	0.0	0.0	2	1.608750-07	25.1009910+00	25	8.142930-01
221	1.808540+01	1	3.501850-07	1.055000+00	0.0	0.0	0.0					
221	1.80850+01	1	1.7611360+01	3.8095670+01	5.8277500+01	11.8277500+01	11.8277500+01	1	1.3852890+01	1.3852890+01	24	1.258140+02
			15.8757120+01	17.8842230+01	19.8844230+01	19.8844230+01	21.9062330+01	2	1.258140+02			
			25.1230130+02									
222	1.813240+01	1	3.731670-06	1.055000+00	0.0	0.0	0.0	1	2.107360-06			
222	1.813240+01	1	3.731670-06	1.055000+00	0.0	0.0	0.0	2	2.249890-07	25.1108860+00	25	9.014210-01
222	1.81320+01	1	4.377500-07	1.055000+00	0.0	0.0	0.0					
222	1.81320+01	1	1.7611320+01	3.8095570+01	5.8277370+01	11.8277370+01	11.8277370+01	1	1.38562710+01	1.38562710+01	24	1.287250+02
			15.8751050+01	17.8842430+01	19.8844550+01	19.8844550+01	21.9061400+01	2	1.287250+02			
			25.1219040+02									
223	1.818190+01	1	3.027780-06	1.055000+00	0.0	0.0	0.0	1	2.005820-06			
223	1.818190+01	1	3.027780-06	1.055000+00	0.0	0.0	0.0	2	2.094430-07	25.1170710+00	25	9.603530-01
223	1.818190+01	1	5.045230-07	1.055000+00	0.0	0.0	0.0					
223	1.81820+01	1	1.7611280+01	3.8095450+01	5.8277230+01	11.8277230+01	11.8277230+01	1	1.38562530+01	1.38562530+01	24	1.235770+02
			15.8756990+01	17.8842650+01	19.8844800+01	19.8844800+01	21.9060400+01	2	1.235770+02			
			25.1207330+02									
224	1.823150+01	1	7.800670-06	1.055000+00	0.0	0.0	0.0	1	3.279440-06			
224	1.823150+01	1	7.800670-06	1.055000+00	0.0	0.0	0.0	2	3.769510-07	25.1175820+00	25	9.739010-01
224	1.823150+01	1	1.181910-06	1.055000+00	0.0	0.0	0.0					
224	1.82310+01	1	1.7611240+01	3.8095340+01	5.8277080+01	11.8277080+01	11.8277080+01	1	1.38562310+01	1.38562310+01	24	1.224270+02
			15.8756920+01	17.8842860+01	19.8845040+01	19.8845040+01	21.9059370+01	2	1.224270+02			
			25.1195570+02									
225	1.828100+01	1	6.203250-06	1.055000+00	0.0	0.0	0.0	1	3.332190-06			
225	1.828100+01	1	6.203250-06	1.055000+00	0.0	0.0	0.0	2	3.293220-07	25.1180130+00	25	9.871360-01
225	1.828100+01	1	1.031440-06	1.055000+00	0.0	0.0	0.0					
225	1.82810+01	1	1.7611200+01	3.8095220+01	5.8276940+01	11.8276940+01	11.8276940+01	1	1.38562150+01	1.38562150+01	24	1.217740+02
			15.8756860+01	17.8843070+01	19.8845260+01	19.8845260+01	21.9058310+01	2	1.217740+02			
			25.1183770+02									
226	1.833050+01	1	5.340060-06	1.055000+00	0.0	0.0	0.0	1	3.440730-06			
226	1.833050+01	1	5.340060-06	1.055000+00	0.0	0.0	0.0	2	4.003160-07	25.1184180+00	25	1.000350+00
226	1.833050+01	1	9.315200-07	1.055000+00	0.0	0.0	0.0					
226	1.832800+01	1	3.899760-06	1.055000+00	0.0	0.0	0.0	1	9.835540-07			
226	1.832800+01	1	3.899760-06	1.055000+00	0.0	0.0	0.0	2	2.206840-07	25.1127030+00	25	9.520670-01
226	1.832800+01	1	5.347520-07	1.055000+00	0.0	0.0	0.0					
226	1.83280+01	1	1.7611160+01	3.8095110+01	5.8276800+01	11.8276800+01	11.8276800+01	1	1.38561980+01	1.38561980+01	24	1.201770+02
			15.8756810+01	17.8843270+01	19.8845460+01	19.8845460+01	21.9057270+01	2	1.201770+02			
			25.1172500+02									
227	1.837500+01	1	2.406840-06	1.055000+00	0.0	0.0	0.0	1	3.120650-06			
227	1.837500+01	1	2.406840-06	1.055000+00	0.0	0.0	0.0	2	2.634100-07	25.11200570+00	25	9.630850-01
227	1.837500+01	1	5.469750-07	1.055000+00	0.0	0.0	0.0					
227	1.83750+01	1	1.7611200+01	3.8095030+01	5.8276670+01	11.8276670+01	11.8276670+01	1	1.38561800+01	1.38561800+01	24	1.190760+02
			15.8756750+01	17.8843370+01	19.8845540+01	19.8845540+01	21.9056210+01	2	1.190760+02			
			25.1161210+02									
228	1.842210+01	1	3.556570-06	1.055000+00	0.0	0.0	0.0	1	3.356710-06			
228	1.842210+01	1	3.556570-06	1.055000+00	0.0	0.0	0.0	2	3.193490-07	25.1132780+00	25	9.755300-01
228	1.842210+01	1	6.914900-07	1.055000+00	0.0	0.0	0.0					
228	1.84220+01	1	1.7611080+01	3.8094960+01	5.8276530+01	11.8276530+01	11.8276530+01	1	1.38561610+01	1.38561610+01	24	1.179710+02
			15.8756700+01	17.8843660+01	19.8845800+01	19.8845800+01	21.9055130+01	2	1.179710+02			
			25.1149880+02									
229	1.846910+01	1	3.970320-06	1.055000+00	0.0	0.0	0.0					

229	1 846910+01	1 3 970320-06	1 055000+00	0 0	0 0	0 0	1 3 479760-06	25 9 880580-01
229	1 846910+01	1 7 647990-07	1 055000+00	0 0	0 0	0 0	2 3 428890-07	25 1 136150+00
229	1 846910+01	1 7 611040+01	3 8 094780+01	0 0	0 0	5 8 276390+01	11 8 564350+01	13 8 665930+01
229	1 846910+01	15 8 756650+01	17 8 843850+01	0 0	0 0	19 8 945960+01	21 9 054020+01	24 1 168630+02
229	1 846910+01	25 1 138520+02	0 0	0 0	0 0	0 0	1 3 633930-06	25 1 001060+00
230	1 851610+01	1 4 336130-06	1 055000+00	0 0	0 0	0 0	2 3 564320-07	25 1 139720+00
230	1 851610+01	1 4 336130-06	1 055000+00	0 0	0 0	0 0	1 3 633930-06	25 1 001060+00
230	1 851610+01	1 4 336130-06	1 055000+00	0 0	0 0	0 0	2 3 564320-07	25 1 139720+00
230	1 85170+01	1 3 674990-06	1 055000+00	0 0	0 0	0 0	1 9 857280-07	25 1 083930+00
230	1 85170+01	1 3 674990-06	1 055000+00	0 0	0 0	0 0	2 2 446880-07	25 1 083930+00
230	1 85170+01	1 3 674990-06	1 055000+00	0 0	0 0	0 0	1 9 857280-07	25 1 083930+00
230	1 85170+01	1 5 122510-07	1 055000+00	0 0	0 0	0 0	11 8 561280+01	13 8 665810+01
230	1 85170+01	1 7 611000+01	3 8 094680+01	0 0	0 0	5 8 276270+01	21 9 052940+01	24 1 158030+02
230	1 85170+01	15 8 756600+01	17 8 844030+01	0 0	0 0	19 8 946090+01	21 9 052940+01	24 1 158030+02
230	1 85170+01	25 1 127680+02	0 0	0 0	0 0	0 0	1 1 331120-05	25 9 384120-01
231	1 855840+01	1 4 858040-05	1 055000+00	0 0	0 0	0 0	2 8 990600-07	25 1 053720+00
231	1 855840+01	2 4 230360-06	1 055000+00	0 0	0 0	0 0	11 8 561120+01	13 8 665650+01
231	1 855840+01	2 4 230360-06	1 055000+00	0 0	0 0	0 0	21 9 051650+01	24 1 147550+02
231	1 855840+01	1 2 276250-06	1 055000+00	0 0	0 0	5 8 276140+01	11 8 561120+01	13 8 665650+01
231	1 855840+01	1 7 610960+01	3 8 094580+01	0 0	0 0	19 8 946210+01	21 9 051650+01	24 1 147550+02
231	1 855840+01	15 8 756560+01	17 8 844200+01	0 0	0 0	0 0	11 8 560950+01	13 8 665490+01
231	1 855840+01	25 1 117140+02	0 0	0 0	0 0	0 0	21 9 050720+01	24 1 137100+02
232	1 860300+01	1 3 699990-05	1 055000+00	0 0	0 0	0 0	1 1 354600-05	25 9 205980-01
232	1 860300+01	2 3 439440-06	1 055000+00	0 0	0 0	0 0	2 7 391270-07	24 1 044930+00
232	1 860300+01	1 907290-06	1 055000+00	0 0	0 0	0 0	11 8 560950+01	13 8 665490+01
232	1 860300+01	1 7 610930+01	3 8 094470+01	0 0	0 0	5 8 276010+01	21 9 050720+01	24 1 137100+02
232	1 860300+01	15 8 756510+01	17 8 844380+01	0 0	0 0	19 8 946310+01	21 9 050720+01	24 1 137100+02
232	1 860300+01	25 1 106860+02	0 0	0 0	0 0	0 0	1 1 113340-05	25 9 186260-01
233	1 864760+01	1 2 021680-05	1 055000+00	0 0	0 0	0 0	2 4 604940-07	24 1 033290+00
233	1 864760+01	2 2 092040-06	1 055000+00	0 0	0 0	0 0	11 8 560790+01	13 8 665340+01
233	1 864760+01	1 1 219020-06	1 055000+00	0 0	0 0	0 0	21 9 049580+01	24 1 126770+02
233	1 864760+01	1 7 610890+01	3 8 094370+01	0 0	0 0	5 8 275880+01	11 8 560790+01	13 8 665340+01
233	1 864760+01	15 8 756470+01	17 8 844550+01	0 0	0 0	19 8 946410+01	21 9 049580+01	24 1 126770+02
233	1 864760+01	25 1 096730+02	0 0	0 0	0 0	0 0	1 9 858090-06	25 9 127570-01
234	1 869230+01	1 1 211790-05	1 055000+00	0 0	0 0	0 0	2 3 102590-07	24 1 021200+00
234	1 869230+01	2 1 410170-06	1 055000+00	0 0	0 0	0 0	1 8 438750-06	25 9 526360-01
234	1 869230+01	1 8 365110-07	1 055000+00	0 0	0 0	0 0	2 7 795860-07	24 1 040190+00
234	1 869230+01	1 7 610850+01	3 8 094260+01	0 0	0 0	5 8 275750+01	11 8 560670+01	13 8 665180+01
234	1 869230+01	15 8 756430+01	17 8 844710+01	0 0	0 0	19 8 946490+01	21 9 048420+01	24 1 116560+02
234	1 869230+01	25 1 096720+02	0 0	0 0	0 0	0 0	1 1 023910-05	25 9 486380-01
235	1 873870+01	1 1 230540-05	1 055000+00	0 0	0 0	0 0	2 3 203310-07	24 1 050510+00
235	1 873870+01	2 1 422520-06	1 055000+00	0 0	0 0	0 0	11 8 560370+01	13 8 665020+01
235	1 873870+01	1 9 128690-07	1 055000+00	0 0	0 0	0 0	21 9 047190+01	24 1 106050+02
235	1 873870+01	1 7 610810+01	3 8 094160+01	0 0	0 0	5 8 275620+01	11 8 560370+01	13 8 665020+01
235	1 873870+01	15 8 756390+01	17 8 844810+01	0 0	0 0	19 8 946560+01	21 9 047190+01	24 1 106050+02
235	1 873870+01	25 1 076410+02	0 0	0 0	0 0	0 0	1 8 438750-06	25 9 526360-01
236	1 878520+01	1 5 817510-06	1 055000+00	0 0	0 0	0 0	2 7 795860-07	24 1 040190+00
236	1 878520+01	1 5 817510-06	1 055000+00	0 0	0 0	0 0	11 8 560280+01	13 8 664870+01
236	1 878520+01	1 1 507370-06	1 055000+00	0 0	0 0	0 0	21 9 045930+01	24 1 095650+02
236	1 878520+01	1 7 610770+01	3 8 094050+01	0 0	0 0	5 8 275480+01	11 8 560280+01	13 8 664870+01
236	1 878520+01	15 8 756350+01	17 8 845050+01	0 0	0 0	19 8 946620+01	21 9 045930+01	24 1 095650+02
236	1 878520+01	25 1 066160+02	0 0	0 0	0 0	0 0	1 7 861320-06	25 9 562740-01
237	1 883170+01	1 4 899970-06	1 055000+00	0 0	0 0	0 0	2 6 632460-07	24 1 030610+00
237	1 883170+01	1 4 899970-06	1 055000+00	0 0	0 0	0 0	11 8 560100+01	13 8 664710+01
237	1 883170+01	1 1 277880-06	1 055000+00	0 0	0 0	0 0	21 9 044650+01	24 1 085340+02
237	1 883170+01	1 7 610740+01	3 8 093940+01	0 0	0 0	5 8 275350+01	11 8 560100+01	13 8 664710+01
237	1 883170+01	15 8 756310+01	17 8 845220+01	0 0	0 0	19 8 946660+01	21 9 044650+01	24 1 085340+02
237	1 883170+01	25 1 055960+02	0 0	0 0	0 0	0 0	1 7 295150-06	25 9 608000-01
238	1 887830+01	1 4 047580-06	1 055000+00	0 0	0 0	0 0	2 5 577770-07	24 1 022100+00
238	1 887830+01	1 4 047580-06	1 055000+00	0 0	0 0	0 0	11 8 559940+01	13 8 664550+01
238	1 887830+01	1 1 062510-06	1 055000+00	0 0	0 0	0 0	21 9 043350+01	24 1 075120+02
238	1 887830+01	1 7 610700+01	3 8 093830+01	0 0	0 0	5 8 275220+01	11 8 559940+01	13 8 664550+01
238	1 887830+01	15 8 756270+01	17 8 845390+01	0 0	0 0	19 8 946690+01	21 9 043350+01	24 1 075120+02
238	1 887830+01	25 1 045820+02	0 0	0 0	0 0	0 0	1 6 689650-06	25 9 662810-01
239	1 892480+01	1 3 111320-06	1 055000+00	0 0	0 0	0 0	2 4 709180-07	24 1 014800+00
239	1 892480+01	1 3 111320-06	1 055000+00	0 0	0 0	0 0	11 8 559170+01	13 8 664400+01
239	1 892480+01	1 9 183040-07	1 055000+00	0 0	0 0	0 0	21 9 041800+00	25 9 662810-01
239	1 892480+01	1 7 610660+01	3 8 093720+01	0 0	0 0	5 8 275080+01	11 8 559170+01	13 8 664400+01
239	1 892480+01	15 8 756230+01	17 8 845450+01	0 0	0 0	19 8 946720+01	21 9 041800+00	25 9 662810-01
239	1 892480+01	25 1 045810+02	0 0	0 0	0 0	0 0	1 6 689650-06	25 9 662810-01

15	8	756240+01	17	8	845530+01	19	8	846700+01	21	9	042030+01	24	1	064970+02
25	1	035710+02												
1	8	652360-06	1	055000+00	0	0	0	0	0	0	0	0	0	0
1	8	652360-06	1	055000+00	0	0	0	0	0	0	0	0	0	0
1	9	607290-07	1	055000+00	0	0	0	0	0	0	0	0	0	0
1	7	610630+01	3	8	093640+01	5	8	274980+01	11	8	559640+01	13	8	664270+01
15	8	756210+01	17	8	845660+01	19	8	846700+01	21	9	040940+01	24	1	056810+02
25	1	027500+02												
1	4	815420-06	1	055000+00	0	0	0	0	0	0	0	0	0	0
1	4	815420-06	1	055000+00	0	0	0	0	0	0	0	0	0	0
1	8	167420-07	1	055000+00	0	0	0	0	0	0	0	0	0	0
1	7	610590+01	3	8	093550+01	5	8	274870+01	11	8	559500+01	13	8	664150+01
15	8	756180+01	17	8	845780+01	19	8	846700+01	21	9	039850+01	24	1	048660+02
25	1	019330+02												



IBM3033/ 0 11 16 89  
20 58 01

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 241 TIME STEPS. TIME = 1.900000+01

HEATING6 02/12/83  
W9XHP110

GROSS GRID	FINE GRID	DISTANCE	TEMPERATURE
1	0 0	76111	92.790000
2	0 03	78152	0.0
3	0 06	80194	73.400000
4	0 08	81184	
5	0 10	82175	
6	0 57	83124	
7	1 04	83173	
8	1 51	84121	
9	1 98	84168	
10	2 45	85114	
11	2 92	85160	
12	3 14	86114	
13	3 35	86164	
14	3 57	87111	
15	3 79	87156	
16	4 01	88100	
17	4 23	88146	
18	4 45	88195	
19	4 67	89147	
20	4 89	89199	
21	5 10	90140	
22	5 18	98177	
23	5 25	104143	
24	5 32	104187	
25	5 35	101193	

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	92.790000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 3.76103209D-02

ELAPSED CPU TIME IS 2.90 SECONDS

THE MAXIMUM TEMPERATURE IS 1.04866D+02 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES 24

THE MINIMUM TEMPERATURE IS 7.61059D+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES 1

NO	TIME	NO ITER	MAX HEAT	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	NOUE	MAX PERCENT TEMP CHANGE	
242	1.904140+01	1	5.805280-06	1.055000+00	0.0	0.0	0.0	1	3.8093460+01	3.8 093460+01	5 8 274750+01	11 8 559350+01	13 8 664020+01
242	1.904140+01	1	5.805780-06	1.055000+00	0.0	0.0	0.0	2	17.8 845910+01	17 8 845910+01	19 8 946680+01	21 9 038620+01	24 1 039740+02
242	1.904140+01	1	9.977340-07	1.055000+00	0.0	0.0	0.0	25	1.010380+02				
243	1.908620+01	1	3.285060-06	1.055000+00	0.0	0.0	0.0	1	3.285060-06	3 2 285060-06	0 0 0	1 4 808610-06	
243	1.908620+01	1	3.285060-06	1.055000+00	0.0	0.0	0.0	2	3.285060-06	3 2 285060-06	0 0 0	2 3 282110-07	25 9 652810-01
243	1.908620+01	1	6.983980-07	1.055000+00	0.0	0.0	0.0	1	6.983980-07	6 9 83980-07	0 0 0	2 3 282110-07	25 9 652810-01
243	1.908620+01	1	1.7610520+01	3.8 093350+01	3 8 093350+01	5 8 274620+01	11 8 559190+01	13 8 663870+01	19 8 946650+01	19 8 946650+01	21 9 037280+01	24 1 030120+02	
244	1.913100+01	1	3.682090-06	1.055000+00	0.0	0.0	0.0	1	3.682090-06	3 6 82090-06	0 0 0	1 3 878260-06	
244	1.913100+01	1	3.682090-06	1.055000+00	0.0	0.0	0.0	2	3.682090-06	3 6 82090-06	0 0 0	2 2 268580-07	25 9 662350-01
244	1.913100+01	1	2.729350-07	1.055000+00	0.0	0.0	0.0	1	2.729350-07	2 7 29350-07	0 0 0	1 3 878260-06	
244	1.913100+01	1	1.7610490+01	3.8 0932250+01	3 8 0932250+01	5 8 274500+01	11 8 559030+01	13 8 663730+01	19 8 946600+01	19 8 946600+01	21 9 035930+01	24 1 020520+02	
245	1.917580+01	1	1.580690-06	1.055000+00	0.0	0.0	0.0	1	1.580690-06	1 5 80690-06	0 0 0	1 3 103190-06	
245	1.917580+01	1	1.580690-06	1.055000+00	0.0	0.0	0.0	2	1.580690-06	1 5 80690-06	0 0 0	2 1 390020-07	25 9 665830-01
245	1.917580+01	1	1.426880-07	1.055000+00	0.0	0.0	0.0	1	1.426880-07	1 4 26880-07	0 0 0	1 3 103190-06	
245	1.917580+01	1	1.7610450+01	3.8 093150+01	3 8 093150+01	5 8 274370+01	11 8 558870+01	13 8 663440+01	19 8 946540+01	19 8 946540+01	21 9 034550+01	24 1 010950+02	
246	1.92210+01	1	1.7610410+01	3.8 093040+01	3 8 093040+01	5 8 274250+01	11 8 558710+01	13 8 663440+01	19 8 946470+01	19 8 946470+01	21 9 033160+01	24 1 001400+02	
246	1.92210+01	1	1.7610410+01	3.8 093040+01	3 8 093040+01	5 8 274250+01	11 8 558710+01	13 8 663440+01	19 8 946470+01	19 8 946470+01	21 9 033160+01	24 1 001400+02	
247	1.926540+01	1	1.442510-05	1.055000+00	0.0	0.0	0.0	1	1.442510-05	1 4 42510-05	0 0 0	1 5 227110-06	
247	1.926540+01	1	1.442510-05	1.055000+00	0.0	0.0	0.0	2	1.442510-05	1 4 42510-05	0 0 0	2 2 554000-07	25 9 746470-01
247	1.926540+01	1	1.246120-06	1.055000+00	0.0	0.0	0.0	1	1.246120-06	1 2 46120-06	0 0 0	1 5 227110-06	
247	1.926540+01	1	1.246120-06	1.055000+00	0.0	0.0	0.0	2	1.246120-06	1 2 46120-06	0 0 0	2 2 554000-07	25 9 746470-01
247	1.926300+01	1	3.042250-06	1.055000+00	0.0	0.0	0.0	1	3.042250-06	3 0 42250-06	0 0 0	1 8 722330-07	
247	1.926300+01	1	3.042250-06	1.055000+00	0.0	0.0	0.0	2	3.042250-06	3 0 42250-06	0 0 0	2 1 812700-07	25 9 249060-01
247	1.926300+01	1	4.181170-07	1.055000+00	0.0	0.0	0.0	1	4.181170-07	4 1 81170-07	0 0 0	2 1 812700-07	25 9 249060-01
248	1.930540+01	1	1.674990-05	1.055000+00	0.0	0.0	0.0	1	1.674990-05	1 6 74990-05	0 0 0	1 7 096760-06	
248	1.930540+01	1	1.674990-05	1.055000+00	0.0	0.0	0.0	2	1.674990-05	1 6 74990-05	0 0 0	2 3 126890-07	25 9 351910-01
248	1.930540+01	1	1.567830-06	1.055000+00	0.0	0.0	0.0	1	1.567830-06	1 5 67830-06	0 0 0	1 7 096760-06	
248	1.930540+01	1	1.567830-06	1.055000+00	0.0	0.0	0.0	2	1.567830-06	1 5 67830-06	0 0 0	2 3 126890-07	25 9 351910-01
248	1.930540+01	1	1.7351390-07	1.055000+00	0.0	0.0	0.0	1	1.7351390-07	1 7 351390-07	0 0 0	1 5 227110-06	
248	1.930540+01	1	1.7351390-07	1.055000+00	0.0	0.0	0.0	2	1.7351390-07	1 7 351390-07	0 0 0	2 2 554000-07	25 9 746470-01
249	1.934780+01	1	1.061800-05	1.055000+00	0.0	0.0	0.0	1	1.061800-05	1 0 61800-05	0 0 0	1 6 160300-06	
249	1.934780+01	1	1.061800-05	1.055000+00	0.0	0.0	0.0	2	1.061800-05	1 0 61800-05	0 0 0	2 2 260970-07	25 9 425100-01
249	1.934780+01	1	5.514720-07	1.055000+00	0.0	0.0	0.0	1	5.514720-07	5 5 14720-07	0 0 0	1 6 160300-06	
249	1.934780+01	1	5.514720-07	1.055000+00	0.0	0.0	0.0	2	5.514720-07	5 5 14720-07	0 0 0	2 2 260970-07	25 9 425100-01
249	1.93480+01	1	1.7610310+01	3.8 092750+01	3 8 092750+01	5 8 273890+01	11 8 558250+01	13 8 663050+01	19 8 946200+01	19 8 946200+01	21 9 029130+01	24 9 741360+01	
250	1.939030+01	1	1.732750-06	1.055000+00	0.0	0.0	0.0	1	1.732750-06	1 7 32750-06	0 0 0	1 5 430860-06	
250	1.939030+01	1	1.732750-06	1.055000+00	0.0	0.0	0.0	2	1.732750-06	1 7 32750-06	0 0 0	2 6 549670-07	25 9 484640-01
250	1.939030+01	1	1.337630-06	1.055000+00	0.0	0.0	0.0	1	1.337630-06	1 3 37630-06	0 0 0	1 5 430860-06	
250	1.939030+01	1	1.337630-06	1.055000+00	0.0	0.0	0.0	2	1.337630-06	1 3 37630-06	0 0 0	2 6 549670-07	25 9 484640-01
250	1.938800+01	1	3.203860-06	1.055000+00	0.0	0.0	0.0	1	3.203860-06	3 2 03860-06	0 0 0	1 9 939450-07	
250	1.938800+01	1	3.203860-06	1.055000+00	0.0	0.0	0.0	2	3.203860-06	3 2 03860-06	0 0 0	2 1 932100-07	25 9 983820-01
250	1.938800+01	1	4.214860-07	1.055000+00	0.0	0.0	0.0	1	4.214860-07	4 2 14860-07	0 0 0	1 9 939450-07	
250	1.938800+01	1	4.214860-07	1.055000+00	0.0	0.0	0.0	2	4.214860-07	4 2 14860-07	0 0 0	2 1 932100-07	25 9 983820-01
250	1.93880+01	1	1.7610270+01	3.8 092660+01	3 8 092660+01	5 8 273780+01	11 8 558120+01	13 8 662930+01	19 8 946120+01	19 8 946120+01	21 9 029130+01	24 9 741360+01	

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
 NODE NUMBERS AND TEMPERATURES

NUMBER OF TIME  
 TIME STEP:

251	1 942810+01	1 3 916630-06	1 055000+00	0 0 0 0	0 0	0 0	0 0	1 4 312780-06	25 9 623980-01	24 9 554640+01	25 9 624200-01
251	1 942810+01	1 3 916630-06	1 055000+00	0 0 0 0	0 0	0 0	0 0	2 4 424510-07	25 9 623980-01	24 9 554640+01	25 9 624200-01
251	1 942810+01	1 8 271330-07	1 055000+00	0 0 0 0	0 0	0 0	0 0	11 8 557380+01	13 8 662800+01	21 9 026520+01	24 9 567440+01
251	1 942810+01	1 7 610240+01	3 8 092570+01	3 8 092570+01	19 8 945980+01	17 8 847000+01	17 8 847000+01	15 8 755310+01	17 8 847000+01	17 8 847000+01	17 8 847000+01
251	1 942810+01	1 7 610240+01	3 8 092570+01	3 8 092570+01	19 8 945980+01	17 8 847000+01	17 8 847000+01	15 8 755310+01	17 8 847000+01	17 8 847000+01	17 8 847000+01
252	1 946820+01	1 4 622950-05	1 055000+00	0 0 0 0	0 0	0 0	0 0	1 1 260250-05	25 8 763490-01	24 9 567440+01	25 9 624200-01
252	1 946820+01	2 4 127510-06	1 055000+00	0 0 0 0	0 0	0 0	0 0	2 7 857080-07	25 8 763490-01	24 9 567440+01	25 9 624200-01
252	1 946820+01	1 1 666850-06	1 055000+00	0 0 0 0	0 0	0 0	0 0	11 8 557850+01	13 8 662680+01	21 9 026520+01	24 9 567440+01
252	1 946820+01	1 7 610240+01	3 8 092480+01	3 8 092480+01	19 8 945860+01	17 8 847100+01	17 8 847100+01	15 8 755330+01	17 8 847100+01	17 8 847100+01	17 8 847100+01
252	1 946820+01	1 7 610240+01	3 8 092480+01	3 8 092480+01	19 8 945860+01	17 8 847100+01	17 8 847100+01	15 8 755330+01	17 8 847100+01	17 8 847100+01	17 8 847100+01
253	1 950830+01	1 2 246430-04	1 055000+00	0 0 0 0	0 0	0 0	0 0	1 7 104200-05	24 8 988960-01	24 8 988960-01	24 8 988960-01
253	1 950830+01	3 1 684420-06	1 055000+00	0 0 0 0	0 0	0 0	0 0	2 2 912480-06	24 8 988960-01	24 8 988960-01	24 8 988960-01
253	1 950830+01	1 9 894780-06	1 055000+00	0 0 0 0	0 0	0 0	0 0	11 8 557710+01	13 8 662560+01	24 9 567440+01	25 9 624200-01
253	1 950830+01	1 7 610170+01	3 8 092320+01	3 8 092320+01	19 8 945720+01	17 8 847190+01	17 8 847190+01	15 8 755870+01	17 8 847190+01	17 8 847190+01	17 8 847190+01
253	1 950830+01	1 7 610170+01	3 8 092320+01	3 8 092320+01	19 8 945720+01	17 8 847190+01	17 8 847190+01	15 8 755870+01	17 8 847190+01	17 8 847190+01	17 8 847190+01
254	1 954840+01	1 1 299050-04	1 055000+00	0 0 0 0	0 0	0 0	0 0	1 6 108040-05	24 8 988960-01	24 8 988960-01	24 8 988960-01
254	1 954840+01	3 9 782310-07	1 055000+00	0 0 0 0	0 0	0 0	0 0	2 1 911390-06	24 8 988960-01	24 8 988960-01	24 8 988960-01
254	1 954840+01	1 6 539900-06	1 055000+00	0 0 0 0	0 0	0 0	0 0	11 8 557570+01	13 8 662480+01	24 9 567440+01	25 9 624200-01
254	1 954840+01	1 7 610140+01	3 8 092300+01	3 8 092300+01	19 8 945580+01	17 8 847280+01	17 8 847280+01	15 8 755840+01	17 8 847280+01	17 8 847280+01	17 8 847280+01
254	1 954840+01	1 7 610140+01	3 8 092300+01	3 8 092300+01	19 8 945580+01	17 8 847280+01	17 8 847280+01	15 8 755840+01	17 8 847280+01	17 8 847280+01	17 8 847280+01
255	1 959250+01	1 1 095170-04	1 055000+00	0 0 0 0	0 0	0 0	0 0	1 6 536550-05	24 8 933720-01	24 8 933720-01	24 8 933720-01
255	1 959250+01	3 8 862710-07	1 055000+00	0 0 0 0	0 0	0 0	0 0	2 1 755300-06	24 8 933720-01	24 8 933720-01	24 8 933720-01
255	1 959250+01	1 6 629900-06	1 055000+00	0 0 0 0	0 0	0 0	0 0	11 8 557420+01	13 8 662310+01	24 9 567440+01	25 9 624200-01
255	1 959250+01	1 7 610110+01	3 8 092200+01	3 8 092200+01	19 8 945410+01	17 8 847380+01	17 8 847380+01	15 8 755820+01	17 8 847380+01	17 8 847380+01	17 8 847380+01
255	1 959250+01	1 7 610110+01	3 8 092200+01	3 8 092200+01	19 8 945410+01	17 8 847380+01	17 8 847380+01	15 8 755820+01	17 8 847380+01	17 8 847380+01	17 8 847380+01
256	1 963940+01	1 9 201860-05	1 055000+00	0 0 0 0	0 0	0 0	0 0	1 6 918190-05	24 8 939760-01	24 8 939760-01	24 8 939760-01
256	1 963940+01	3 7 863180-07	1 055000+00	0 0 0 0	0 0	0 0	0 0	2 1 597670-06	24 8 939760-01	24 8 939760-01	24 8 939760-01
256	1 963940+01	1 6 442280-06	1 055000+00	0 0 0 0	0 0	0 0	0 0	11 8 557250+01	13 8 662170+01	24 9 567440+01	25 9 624200-01
256	1 963940+01	1 7 610070+01	3 8 092100+01	3 8 092100+01	19 8 945210+01	17 8 847470+01	17 8 847470+01	15 8 755800+01	17 8 847470+01	17 8 847470+01	17 8 847470+01
256	1 963940+01	1 7 610070+01	3 8 092100+01	3 8 092100+01	19 8 945210+01	17 8 847470+01	17 8 847470+01	15 8 755800+01	17 8 847470+01	17 8 847470+01	17 8 847470+01
257	1 968980+01	1 9 025170-05	1 055000+00	0 0 0 0	0 0	0 0	0 0	1 7 503020-05	24 8 918250-01	24 8 918250-01	24 8 918250-01
257	1 968980+01	3 8 155910-07	1 055000+00	0 0 0 0	0 0	0 0	0 0	2 1 628050-06	24 8 918250-01	24 8 918250-01	24 8 918250-01
257	1 968980+01	1 7 071080-06	1 055000+00	0 0 0 0	0 0	0 0	0 0	11 8 557090+01	13 8 662030+01	24 9 567440+01	25 9 624200-01
257	1 968980+01	1 7 610030+01	3 8 091980+01	3 8 091980+01	19 8 944990+01	17 8 847570+01	17 8 847570+01	15 8 755770+01	17 8 847570+01	17 8 847570+01	17 8 847570+01
257	1 968980+01	1 7 610030+01	3 8 091980+01	3 8 091980+01	19 8 944990+01	17 8 847570+01	17 8 847570+01	15 8 755770+01	17 8 847570+01	17 8 847570+01	17 8 847570+01
258	1 974450+01	1 9 796590-05	1 055000+00	0 0 0 0	0 0	0 0	0 0	1 8 292100-05	24 8 637470-01	24 8 637470-01	24 8 637470-01
258	1 974450+01	3 9 319600-07	1 055000+00	0 0 0 0	0 0	0 0	0 0	2 1 721070-06	24 7 887720-01	24 7 887720-01	24 7 887720-01
258	1 974450+01	1 8 104430-06	1 055000+00	0 0 0 0	0 0	0 0	0 0	11 8 556930+01	13 8 661870+01	24 9 567440+01	25 9 624200-01
258	1 974450+01	1 7 609990+01	3 8 091860+01	3 8 091860+01	19 8 944730+01	17 8 847670+01	17 8 847670+01	15 8 755740+01	17 8 847670+01	17 8 847670+01	17 8 847670+01
258	1 974450+01	1 7 609990+01	3 8 091860+01	3 8 091860+01	19 8 944730+01	17 8 847670+01	17 8 847670+01	15 8 755740+01	17 8 847670+01	17 8 847670+01	17 8 847670+01
259	1 980420+01	1 1 128320-04	1 055000+00	0 0 0 0	0 0	0 0	0 0	1 9 256780-05	24 8 637470-01	24 8 637470-01	24 8 637470-01
259	1 980420+01	3 1 122280-06	1 055000+00	0 0 0 0	0 0	0 0	0 0	2 1 890460-06	24 7 760980-01	24 7 760980-01	24 7 760980-01
259	1 980420+01	1 9 718020-06	1 055000+00	0 0 0 0	0 0	0 0	0 0	11 8 556700+01	13 8 661700+01	24 9 567440+01	25 9 624200-01
259	1 980420+01	1 7 609940+01	3 8 091730+01	3 8 091730+01	19 8 944420+01	17 8 847780+01	17 8 847780+01	15 8 755710+01	17 8 847780+01	17 8 847780+01	17 8 847780+01
259	1 980420+01	1 7 609940+01	3 8 091730+01	3 8 091730+01	19 8 944420+01	17 8 847780+01	17 8 847780+01	15 8 755710+01	17 8 847780+01	17 8 847780+01	17 8 847780+01
260	1 986980+01	1 1 344200-04	1 055000+00	0 0 0 0	0 0	0 0	0 0	1 1 039500-04	24 8 572760-01	24 8 572760-01	24 8 572760-01
260	1 986980+01	3 1 366960-06	1 055000+00	0 0 0 0	0 0	0 0	0 0	2 2 449580-06	24 7 640470-01	24 7 640470-01	24 7 640470-01
260	1 986980+01	2 9 153610-07	1 055000+00	0 0 0 0	0 0	0 0	0 0	11 8 556480+01	13 8 661510+01	24 9 567440+01	25 9 624200-01
260	1 986980+01	1 7 609890+01	3 8 091590+01	3 8 091590+01	19 8 944060+01	17 8 847860+01	17 8 847860+01	15 8 755560+01	17 8 847860+01	17 8 847860+01	17 8 847860+01
260	1 986980+01	1 7 609890+01	3 8 091590+01	3 8 091590+01	19 8 944060+01	17 8 847860+01	17 8 847860+01	15 8 755560+01	17 8 847860+01	17 8 847860+01	17 8 847860+01
261	1 993490+01	1 1 091370-04	1 055000+00	0 0 0 0	0 0	0 0	0 0	1 9 780620-05	23 8 863750-01	23 8 863750-01	23 8 863750-01
261	1 993490+01	3 1 142870-06	1 055000+00	0 0 0 0	0 0	0 0	0 0	2 2 076050-06	23 8 863750-01	23 8 863750-01	23 8 863750-01
261	1 993490+01	2 7 667980-07	1 055000+00	0 0 0 0	0 0	0 0	0 0	11 8 556270+01	13 8 661390+01	24 9 567440+01	25 9 624200-01
261	1 993490+01	1 7 609840+01	3 8 091440+01	3 8 091440+01	19 8 944420+01	17 8 847940+01	17 8 847940+01	15 8 755620+01	17 8 847940+01	17 8 847940+01	17 8 847940+01
261	1 993490+01	1 7 609840+01	3 8 091440+01	3 8 091440+01	19 8 944420+01	17 8 847940+01	17 8 847940+01	15 8 755620+01	17 8 847940+01	17 8 847940+01	17 8 847940+01

262	2	000000+01	1	8	755650+01	17	8	847980+01	19	8	943680+01	21	9	009080+01	24	8	768490+01
			25	8	614780+01				0	0	0						
			1	000490-04	1	055000+00	0	0	0	0	0						
			2	9	823020-06	1	055000+00	0	0	0	0						
			262	2	000000+01	1	8	635110-05	1	055000+00	0	0	0	0	0	0	0
			262	2	000000+01	1	7	609790+01	3	8	091300+01	5	8	272110+01	11	8	556050+01
						15	8	755610+01	17	8	848060+01	19	8	943270+01	21	9	006770+01
						25	8	567770+01									

GRUSS GRID	1	1
FINE GRID	1	1
DISTANCE	0.0	76110
1	0.0	78151
2	0.03	80191
3	0.06	81182
4	0.08	82172
5	0.10	83170
6	0.57	84118
7	1.04	84165
8	1.51	85111
9	1.98	85156
10	2.45	86110
11	2.92	86161
12	3.14	87109
13	3.35	87156
14	3.57	88101
15	3.79	88148
16	4.01	88196
17	4.23	89143
18	4.45	89184
19	4.67	90107
20	4.89	90152
21	5.10	90193
22	5.18	87108
23	5.25	85168
24	5.32	
25	5.35	

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	91.360000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 6.508338270-02

ELAPSED CPU TIME IS 3.14 SECONDS

THE MAXIMUM TEMPERATURE IS - 9.151550+01 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 22

THE MINIMUM TEMPERATURE IS - 7.609790+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

Table with columns: NO, TIME, NO ITER, MAX HEAT RESIDUAL, BETA, L1 NORM OF TEMP DIFF, RHO (ITERATION), (JACOBI), RHO, NO ITER, L1 NORM OF NODE TEMP DIFF, MAX TEMP CHANGE, NODE TEMP, MAX PERCENT TEMP CHANGE. The table contains numerical data for iterations 263 through 272. A section titled 'TABLE FOR SPECIAL MONITORING OF TEMPERATURES' is also present.

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

15 B 155040\*01 17 B 848150\*01 19 B 934400\*01 21 B 973830\*01 24 B 205880\*01  
25 R 145610\*01

HEATING5 02/12/83  
WSXNP110

COPPER NUCLEAR STATION CONTROL 1

D MODEL

IBM3033/ 0  
20 58 02 11-16-89

TRANSIENT TEMPERATURE DISTRIBUTION - ILE0 272 TIME STEPS, TIME = 2.100000+01

GROSS GRID 1

FINE GRID 1

	FINE GRID	DISTANCE	O. O.
1	1	0.0	76100
2	2	0.03	78143
3	3	0.06	80185
4	4	0.08	81180
5	5	0.10	82170
6	6	0.57	83119
7	7	1.04	83167
8	8	1.51	84115
9	9	1.98	84162
10	10	2.45	85108
11	11	2.92	85153
12	12	3.14	86107
13	13	3.35	86159
14	14	3.57	87108
15	15	3.79	87155
16	16	4.01	88102
17	17	4.23	88148
18	18	4.45	88193
19	19	4.67	89134
20	20	4.89	89164
21	21	5.10	89174
22	22	5.18	87198
23	23	5.25	85154
24	24	5.32	82106
25	25	5.35	81146

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	89.500000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 9.064254470-02

ELAPSED CPU TIME IS 3.26 SECONDS

THE MAXIMUM TEMPERATURE IS - 8.973830+01 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 21

THE MINIMUM TEMPERATURE IS - 7.609050+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1



NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	NOSE	MAX PERCENT TEMP CHANGE
273	2.11000+01	1	7.608980+01	3.808904D+01	5.826937D+01	11.855268D+01	13.865837D+01	1	3.08647D-05	24.304487D-01	24	3.71059D-01
		2	8.75497D+01	17.884803D+01	19.893330D+01	21.897094D+01	24.817543D+01	2	4.68363D-07			
		25	8.116930+01		0.0	0.0		1	3.11006D-05			24.3934D-01
274	2.12094D+01	1	3.32788D-05	1.05500D+00	0.0	0.0		2	5.72630D-07	23.321687D-01	23	3.934D-01
		2	3.39271D-06	1.05500D+00	0.0	0.0		13	8.65812D+01		13	8.65812D+01
		1	3.72233D-06	1.05500D+00	0.0	0.0		21	8.96784D+01	24.814326D+01	24	8.14326D+01
274	2.12094D+01	1	1.750890D+01	3.808883D+01	5.826911D+01	11.855237D+01	13.865812D+01	1	3.11006D-05			
		2	8.754880D+01	94787D-01	19.893207D+01	21.896784D+01	24.814326D+01	2	4.68363D-07			
		25	8.08611D+01		0.0	0.0		1	3.04162D-05			19479D-01
275	2.13300+01	1	3.68642D-05	1.05500D+00	0.0	0.0		2	6.05993D-07	24.341593D-01	24	3.41593D-01
		2	4.04496D-06	1.05500D+00	0.0	0.0		13	8.65785D+01		13	8.65785D+01
		1	4.36670D-06	1.05500D+00	0.0	0.0		21	8.96453D+01	24.810910D-01	24	8.10910D-01
275	2.13300+01	1	1.750882D+01	3.808860D+01	5.826884D+01	11.855203D+01	13.865785D+01	1	3.11006D-05			
		2	8.75476D+01	17.884766D+01	19.893068D+01	21.896453D+01	24.810910D-01	2	4.68363D-07			
		25	8.05299D+01		0.0	0.0		1	2.91985D-05			19479D-01
276	2.14627D+01	1	3.91442D-05	1.05500D+00	0.0	0.0		2	6.09136D-07	24.364449D-01	24	3.6449D-01
		2	4.7577D-06	1.05500D+00	0.0	0.0		13	8.65755D+01		13	8.65755D+01
		1	4.8529D-06	1.05500D+00	0.0	0.0		21	8.96099D+01	24.807266D+01	24	8.07266D+01
276	2.14627D+01	1	1.750873D+01	3.808836D+01	5.826854D+01	11.855166D+01	13.865755D+01	1	3.11006D-05			
		2	8.75466D+01	17.884739D+01	19.892911D+01	21.896099D+01	24.807266D+01	2	4.68363D-07			
		25	8.01730D+01		0.0	0.0		1	2.59312D-05			24.484196D-01
277	2.16087D+01	1	3.56936D-05	1.05500D+00	0.0	0.0		2	5.31940D-07	24.390875D-01	24	3.90875D-01
		2	4.37392D-06	1.05500D+00	0.0	0.0		13	8.65722D+01		13	8.65722D+01
		1	4.65645D-06	1.05500D+00	0.0	0.0		21	8.95127D+01	24.803357D+01	24	8.03357D+01
277	2.16087D+01	1	1.750864D+01	3.808809D+01	5.826824D+01	11.855127D+01	13.865722D+01	1	3.11006D-05			
		2	8.75451D+01	17.884705D+01	19.892736D+01	21.895721D+01	24.803357D+01	2	4.68363D-07			
		25	7.97855D+01		0.0	0.0		1	2.42437D-05			25.526670D-01
278	2.17693D+01	1	3.48632D-05	1.05500D+00	0.0	0.0		2	4.79842D-07	24.421561D-01	24	4.21561D-01
		2	4.07354D-06	1.05500D+00	0.0	0.0		13	8.65687D+01		13	8.65687D+01
		1	4.56819D-06	1.05500D+00	0.0	0.0		21	8.95084D+01	24.799142D+01	24	7.99142D+01
278	2.17693D+01	1	1.750853D+01	3.808780D+01	5.826786D+01	11.855084D+01	13.865687D+01	1	3.11006D-05			
		2	8.75434D+01	17.884662D+01	19.892539D+01	21.895318D+01	24.799142D+01	2	4.68363D-07			
		25	7.93663D+01		0.0	0.0		1	1.03778D-05			25.380388D-01
279	2.18846D+01	1	1.13455D-05	1.05500D+00	0.0	0.0		2	4.82636D-08	25.301900D-01	25	3.01900D-01
		2	5.46906D-07	1.05500D+00	0.0	0.0		13	8.65662D+01		13	8.65662D+01
		1	5.10849D-08	1.05500D+00	0.0	0.0		21	8.95036D+01	24.796143D+01	24	7.96143D+01
279	2.18846D+01	1	1.750845D+01	3.808759D+01	5.826761D+01	11.855054D+01	13.86562D+01	1	3.11006D-05			
		2	8.75421D+01	17.884628D+01	19.892396D+01	21.895036D+01	24.796143D+01	2	4.68363D-07			
		25	7.90644D+01		0.0	0.0		1	1.755066D-06			25.379295D-01
280	2.20000D+01	1	1.03276D-05	1.05500D+00	0.0	0.0		2	4.605162D-07	25.299887D-01	25	2.99887D-01
		2	1.25807D-06	1.05500D+00	0.0	0.0		13	8.65638D+01		13	8.65638D+01
		1	8.97048D-07	1.05500D+00	0.0	0.0		21	8.94760D+01	24.793162D+01	24	7.93162D+01
280	2.20000D+01	1	1.750838D+01	3.808739D+01	5.826737D+01	11.855024D+01	13.865638D+01	1	3.11006D-05			
		2	8.75360D+01	17.884592D+01	19.892252D+01	21.894760D+01	24.793162D+01	2	4.68363D-07			
		25	7.87645D+01		0.0	0.0		1	2.91985D-05			19479D-01

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
 \*\*\*\*\* NODE NUMBERS AND TEMPERATURES \*\*\*\*\*

HEATING 02/12/83  
W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

1BM3033/ C  
20 58 02 11-16-83

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 280 TIME STEPS, TIME = 2.200000+01

GROSS GRID 1

FINE GRID 1  
DISTANCE 0.0

1	0.0	76108
2	0.03	78148
3	0.06	80187
4	0.08	81177
5	0.10	82167
6	0.57	83116
7	1.04	83164
8	1.51	84112
9	1.98	84159
10	2.45	85105
11	2.92	85150
12	3.14	86105
13	3.35	86156
14	3.57	87106
15	3.79	87154
16	4.01	88101
17	4.23	88146
18	4.45	88188
19	4.67	89123
20	4.89	89145
21	5.10	89148
22	5.18	86157
23	5.25	83127
24	5.32	79132
25	5.35	78176

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	87.330000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 1.15350611D-01

ELAPSED CPU TIME IS 3.35 SECONDS

THE MAXIMUM TEMPERATURE IS - 8.947600+01 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 20 21

THE MINIMUM TEMPERATURE IS - 7.608380+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO TIME	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	NO ITER	MAX TEMP CHANGE
281	2.21259L+01	1	1.50448D-05	1.05500D+00	0.0	0.0	0.0	1	6.77687D-06			
281	2.21269D+01	2	1.86674D-06	1.05500D+00	0.0	0.0	0.0	2	2.07136D-07	25 3	3.2055D-01	25 4 2.592D-01
281	2.21263D+01	1	1.40070D-06	1.05500D+00	0.0	0.0	0.0					
TABLE FOR SPECIAL MONITORING OF TEMPERATURES												
***** NODE NUMBERS AND TEMPERATURES *****												
281	2.2127D+01	1	7.60830D+01	3.8 08717D+01	5.8 26711D+01	11.8 54992D+01	11.8 54992D+01	13.8 65611D+01				
		15	8.75390D+01	17.8 84549D+01	19.8 92092D+01	21.8 94462D+01	21.8 94462D+01	24.7 89889D+01				
		25	7.84324D+01									
282	2.2265D+01	1	9.18838D-06	1.05500D+00	0.0	0.0	0.0	1	5.40918D-06			
282	2.2265D+01	1	9.18838D-06	1.05500D+00	0.0	0.0	0.0	2	6.51342D-07	25 3	6.6651D-01	25 4 6.7474D-01
282	2.22665D+01	1	1.06138D-06	1.05500D+00	0.0	0.0	0.0	11.8 54958D+01	13.8 65581D+01			
282	2.2266D+01	1	7.60821D+01	3.8 08694D+01	5.8 26682D+01	11.8 54958D+01	11.8 54958D+01	13.8 65581D+01				
		15	8.75373D+01	17.8 84498D+01	19.8 91915D+01	21.8 94114D+01	21.8 94114D+01	24.7 86283D+01				
		25	7.80658D+01									
283	2.24200D+01	1	6.86713D-06	1.05500D+00	0.0	0.0	0.0	1	4.97012D-06			
283	2.24200D+01	1	6.86713D-06	1.05500D+00	0.0	0.0	0.0	2	5.86927D-07	25 4	0.4317D-01	25 5 1.7918D-01
283	2.24200D+01	1	8.12415D-07	1.05500D+00	0.0	0.0	0.0	11.8 54920D+01	13.8 65549D+01			
283	2.2420D+01	1	7.60812D+01	3.8 08668D+01	5.8 26651D+01	11.8 54920D+01	11.8 54920D+01	13.8 65549D+01				
		15	8.75347D+01	17.8 84337D+01	19.8 91719D+01	21.8 93794D+01	21.8 93794D+01	24.7 82306D+01				
		25	7.76615D+01									
284	2.25889D+01	1	7.78231D-06	1.05500D+00	0.0	0.0	0.0	1	4.53331D-06			
284	2.25889D+01	1	7.78231D-06	1.05500D+00	0.0	0.0	0.0	2	5.81226D-07	25 4	4.5777D-01	25 5 7.4000D-01
284	2.25889D+01	1	9.79957D-07	1.05500D+00	0.0	0.0	0.0	11.8 54879D+01	13.8 65514D+01			
284	2.2589D+01	1	7.60803D+01	3.8 08640D+01	5.8 26618D+01	11.8 54879D+01	11.8 54879D+01	13.8 65514D+01				
		15	8.75319D+01	17.8 84367D+01	19.8 91502D+01	21.8 93421D+01	21.8 93421D+01	24.7 77922D+01				
		25	7.72157D+01									
285	2.27746D+01	1	1.39759D-05	1.05500D+00	0.0	0.0	0.0	1	4.99949D-06			
285	2.27746D+01	2	2.01603D-06	1.05500D+00	0.0	0.0	0.0	2	2.38761D-07	25 4	9.1964D-01	25 6 3.7129D-01
285	2.27746D+01	1	8.6483D-06	1.05500D+00	0.0	0.0	0.0	11.8 54836D+01	13.8 65476D+01			
285	2.2775D+01	1	7.60792D+01	3.8 08611D+01	5.8 26582D+01	11.8 54836D+01	11.8 54836D+01	13.8 65476D+01				
		15	8.75287D+01	17.8 84283D+01	19.8 91263D+01	21.8 93019D+01	21.8 93019D+01	24.7 73086D+01				
		25	7.67237D+01									
286	2.28873D+01	1	1.49222D-05	1.05500D+00	0.0	0.0	0.0	1	3.61842D-06			
286	2.28873D+01	2	1.61223D-06	1.05500D+00	0.0	0.0	0.0	2	2.08140D-07	25 3	0.1083D-01	25 3 3.2425D-01
286	2.28873D+01	1	1.28606D-06	1.05500D+00	0.0	0.0	0.0	11.8 54810D+01	13.8 65453D+01			
286	2.2887D+01	1	7.60785D+01	3.8 08593D+01	5.8 26561D+01	11.8 54810D+01	11.8 54810D+01	13.8 65453D+01				
		15	8.75266D+01	17.8 84231D+01	19.8 91118D+01	21.8 92779D+01	21.8 92779D+01	24.7 70140D+01				
		25	7.64226D+01									
287	2.30000D+01	1	5.16254D-06	1.05500D+00	0.0	0.0	0.0	1	1.79706D-06			
287	2.30000D+01	1	5.16254D-06	1.05500D+00	0.0	0.0	0.0	2	3.03179D-07	25 3	0.0380D-01	25 3 9.3051D-01
287	2.30000D+01	1	7.00724D-07	1.05500D+00	0.0	0.0	0.0	11.8 54784D+01	13.8 65430D+01			
287	2.3000D+01	1	7.60778D+01	3.8 08576D+01	5.8 26540D+01	11.8 54784D+01	11.8 54784D+01	13.8 65430D+01				
		15	8.75243D+01	17.8 84176D+01	19.8 90972D+01	21.8 92541D+01	21.8 92541D+01	24.7 67186D+01				
		25	7.61223D+01									

HEATING6 02/12/83  
 W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
 TRANSIENT TEMPERATURE DISTRIBUTION AFTER 287 TIME STEPS, TIME = 2.300000+01

IBM3033/ 0  
 20.58.02 11-16-89

GROSS GRID	FINE GRID	DISTANCE	O.O
1	0.0	76108	
2	0.03	78147	
3	0.06	80186	
4	0.08	81176	
5	0.10	82165	
6	0.57	83114	
7	1.04	83162	
8	1.51	84109	
9	1.98	84156	
10	2.45	85102	
11	2.92	85148	
12	3.14	86102	
13	3.35	86154	
14	3.57	87104	
15	3.79	87152	
16	4.01	87199	
17	4.23	88142	
18	4.45	88180	
19	4.67	89110	
20	4.89	89126	
21	5.10	89125	
22	5.18	85152	
23	5.25	81144	
24	5.32	76172	
25	5.35	76112	

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	85.000000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTAT) = 1.126751400-01  
 ELAPSED CPU TIME IS 3.44 SECONDS

THE MAXIMUM TEMPERATURE IS - 8.926420+01 (+-0.1 PERCENT)  
 MAX. TEMP. APPEARS AT NODES - 20 21  
 THE MINIMUM TEMPERATURE IS - 7.607780+01 (+-0.1 PERCENT)  
 MIN. TEMP. APPEARS AT NODES - 1 25

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERAT,UN)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	MODE	MAX PERCENT TEMP CHANGE	
288	2.31239D+01	1	1.77803D-06	1.05500D+00	0.0	0.0	0.0	1	1.08692D-06	25.3	30157D-01	25.4	33719D-01
288	2.31239D+01	1	1.77803D-06	1.05500D+00	0.0	0.0	0.0	2	1.46748D-07	25.3	30157D-01	25.4	33719D-01
288	2.31239D+01	1	2.48945D-07	1.05500D+00	0.0	0.0	0.0	1	1.00723D-06	25.3	30157D-01	25.4	33719D-01
288	2.31239D+01	1	1.77803D-06	1.05500D+00	0.0	0.0	0.0	2	1.46748D-07	25.3	30157D-01	25.4	33719D-01
289	2.32603D+01	1	1.38337D-06	1.05500D+00	0.0	0.0	0.0	1	1.00723D-06	25.3	30157D-01	25.4	33719D-01
289	2.32603D+01	1	1.38337D-06	1.05500D+00	0.0	0.0	0.0	2	1.32857D-07	25.3	30157D-01	25.4	33719D-01
289	2.32603D+01	1	2.74097D-07	1.05500D+00	0.0	0.0	0.0	1	1.00723D-06	25.3	30157D-01	25.4	33719D-01
289	2.32603D+01	1	1.76076D-07	1.05500D+00	0.0	0.0	0.0	2	1.32857D-07	25.3	30157D-01	25.4	33719D-01
289	2.32603D+01	1	1.76076D-07	1.05500D+00	0.0	0.0	0.0	1	1.00723D-06	25.3	30157D-01	25.4	33719D-01
289	2.32603D+01	1	1.76076D-07	1.05500D+00	0.0	0.0	0.0	2	1.32857D-07	25.3	30157D-01	25.4	33719D-01
290	2.34103D+01	1	2.88163D-06	1.05500D+00	0.0	0.0	0.0	1	1.25060D-06	25.3	30157D-01	25.4	33719D-01
290	2.34103D+01	1	2.88163D-06	1.05500D+00	0.0	0.0	0.0	2	1.76716D-07	25.3	30157D-01	25.4	33719D-01
290	2.34103D+01	1	3.81664D-07	1.05500D+00	0.0	0.0	0.0	1	1.25060D-06	25.3	30157D-01	25.4	33719D-01
290	2.34103D+01	1	1.76076D-07	1.05500D+00	0.0	0.0	0.0	2	1.76716D-07	25.3	30157D-01	25.4	33719D-01
290	2.34103D+01	1	1.76076D-07	1.05500D+00	0.0	0.0	0.0	1	1.25060D-06	25.3	30157D-01	25.4	33719D-01
290	2.34103D+01	1	1.76076D-07	1.05500D+00	0.0	0.0	0.0	2	1.76716D-07	25.3	30157D-01	25.4	33719D-01
291	2.35752D+01	1	5.98297D-06	1.05500D+00	0.0	0.0	0.0	1	1.72085D-06	25.3	30157D-01	25.4	33719D-01
291	2.35752D+01	1	5.98297D-06	1.05500D+00	0.0	0.0	0.0	2	8.18570D-07	25.3	30157D-01	25.4	33719D-01
291	2.35752D+01	1	8.28194D-07	1.05500D+00	0.0	0.0	0.0	1	1.72085D-06	25.3	30157D-01	25.4	33719D-01
291	2.35752D+01	1	1.76076D-07	1.05500D+00	0.0	0.0	0.0	2	8.18570D-07	25.3	30157D-01	25.4	33719D-01
291	2.35752D+01	1	1.76076D-07	1.05500D+00	0.0	0.0	0.0	1	1.72085D-06	25.3	30157D-01	25.4	33719D-01
291	2.35752D+01	1	1.76076D-07	1.05500D+00	0.0	0.0	0.0	2	8.18570D-07	25.3	30157D-01	25.4	33719D-01
292	2.37567D+01	1	8.82386D-06	1.05500D+00	0.0	0.0	0.0	1	1.27206D-06	25.3	30157D-01	25.4	33719D-01
292	2.37567D+01	1	8.82386D-06	1.05500D+00	0.0	0.0	0.0	2	4.19429D-07	25.3	30157D-01	25.4	33719D-01
292	2.37567D+01	1	1.26259D-06	1.05500D+00	0.0	0.0	0.0	1	1.27206D-06	25.3	30157D-01	25.4	33719D-01
292	2.37567D+01	1	1.76076D-07	1.05500D+00	0.0	0.0	0.0	2	4.19429D-07	25.3	30157D-01	25.4	33719D-01
292	2.37567D+01	1	1.76076D-07	1.05500D+00	0.0	0.0	0.0	1	1.27206D-06	25.3	30157D-01	25.4	33719D-01
292	2.37567D+01	1	1.76076D-07	1.05500D+00	0.0	0.0	0.0	2	4.19429D-07	25.3	30157D-01	25.4	33719D-01
293	2.38780D+01	1	6.41879D-06	1.05500D+00	0.0	0.0	0.0	1	1.70348D-06	25.3	30157D-01	25.4	33719D-01
293	2.38780D+01	1	6.41879D-06	1.05500D+00	0.0	0.0	0.0	2	2.86880D-07	25.3	30157D-01	25.4	33719D-01
293	2.38780D+01	1	7.81248D-07	1.05500D+00	0.0	0.0	0.0	1	1.70348D-06	25.3	30157D-01	25.4	33719D-01
293	2.38780D+01	1	1.76076D-07	1.05500D+00	0.0	0.0	0.0	2	2.86880D-07	25.3	30157D-01	25.4	33719D-01
293	2.38780D+01	1	1.76076D-07	1.05500D+00	0.0	0.0	0.0	1	1.70348D-06	25.3	30157D-01	25.4	33719D-01
293	2.38780D+01	1	1.76076D-07	1.05500D+00	0.0	0.0	0.0	2	2.86880D-07	25.3	30157D-01	25.4	33719D-01
294	2.40000D+01	1	1.16983D-06	1.05500D+00	0.0	0.0	0.0	1	1.88281D-06	25.3	30157D-01	25.4	33719D-01
294	2.40000D+01	1	1.16983D-06	1.05500D+00	0.0	0.0	0.0	2	1.42868D-07	25.3	30157D-01	25.4	33719D-01
294	2.40000D+01	1	9.34554D-07	1.05500D+00	0.0	0.0	0.0	1	1.88281D-06	25.3	30157D-01	25.4	33719D-01
294	2.40000D+01	1	1.76076D-07	1.05500D+00	0.0	0.0	0.0	2	1.42868D-07	25.3	30157D-01	25.4	33719D-01
294	2.40000D+01	1	1.76076D-07	1.05500D+00	0.0	0.0	0.0	1	1.88281D-06	25.3	30157D-01	25.4	33719D-01
294	2.40000D+01	1	1.76076D-07	1.05500D+00	0.0	0.0	0.0	2	1.42868D-07	25.3	30157D-01	25.4	33719D-01

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
\*\*\*\*\* NODE NUMBERS AND TEMPERATURES \*\*\*\*\*

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 294 TIME STEPS, TIME = 2.400000+01

HEATING6 02/12/83  
W9XNP110

GROSS GRID	FINE GRID	C.O.
1	0.0	76107
2	0.03	78146
3	0.06	80184
4	0.08	81174
5	0.10	82164
6	0.57	83112
7	1.04	83160
8	1.51	84107
9	1.98	84154
10	2.45	85100
11	2.92	85146
12	3.14	86100
13	3.35	86152
14	3.57	87102
15	3.79	87150
16	4.01	87195
17	4.23	88136
18	4.45	88171
19	4.67	88197
20	4.89	89109
21	5.10	89105
22	5.18	84151
23	5.25	79162
24	5.32	74110
25	5.35	73147

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	82.670000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 1.216588510-01

ELAPSED CPU TIME IS 3.52 SECONDS

THE MAXIMUM TEMPERATURE IS - 8.909300+01 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 20 21

THE MINIMUM TEMPERATURE IS - 7.346670+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 25

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHD (ITERATION)	RHS (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	MODE	MAX PERCENT TEMP CHANGE
295	2.41340+01	1	7.60718D+01	3.80841D+01	5.826339D+01	11.854537D+01	13.865193D+01	25.348007D+01	25.348007D+01	25.348007D+01	25.348007D+01	25.348007D+01
295	2.41380+01	2	8.8572D-05	1.05500D+00	0.0	0.0	0.0	1.565813D-06	1.565813D-06	25.348007D+01	25.348007D+01	25.348007D+01
295	2.41380+01	1	3.37186D-06	1.05500D+00	0.0	0.0	0.0	2.503207D-07	2.503207D-07	25.348007D+01	25.348007D+01	25.348007D+01
295	2.41380+01	2	7.5446D-06	1.05500D+00	0.0	0.0	0.0	0.0	0.0	25.348007D+01	25.348007D+01	25.348007D+01
295	2.41380+01	1	4.05833D-06	1.05500D+00	0.0	0.0	0.0	0.0	0.0	25.348007D+01	25.348007D+01	25.348007D+01

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
 \*\*\*\*\* NODE NUMBERS AND TEMPERATURES \*\*\*\*\*

NUMBER OF TIME STEPS	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHD (ITERATION)	RHS (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	MODE	MAX PERCENT TEMP CHANGE
296	2.42810D+01	1	2.83073D-05	1.05500D+00	0.0	0.0	0.0	1.623510D-06	1.623510D-06	25.378742D+01	25.378742D+01	25.378742D+01
296	2.42810D+01	2	3.37186D-06	1.05500D+00	0.0	0.0	0.0	2.377959D-07	2.377959D-07	25.378742D+01	25.378742D+01	25.378742D+01
296	2.42810D+01	1	3.14062D-06	1.05500D+00	0.0	0.0	0.0	11.854506D+01	13.865161D+01	25.378742D+01	25.378742D+01	25.378742D+01
296	2.42810D+01	2	7.60711D+01	3.808391D+01	5.826315D+01	11.854506D+01	24.733774D+01	21.889964D+01	24.733774D+01	25.378742D+01	25.378742D+01	25.378742D+01
296	2.42810D+01	1	7.74928D+01	17.883446D+01	19.889315D+01	21.889315D+01	0.0	0.0	0.0	25.378742D+01	25.378742D+01	25.378742D+01
296	2.42810D+01	2	7.27399D+01	17.883446D+01	19.889315D+01	21.889315D+01	0.0	0.0	0.0	25.378742D+01	25.378742D+01	25.378742D+01
297	2.44430D+01	1	3.11705D-05	1.05500D+00	0.0	0.0	0.0	1.726015D-06	1.726015D-06	25.412513D+01	25.412513D+01	25.412513D+01
297	2.44430D+01	2	3.92686D-06	1.05500D+00	0.0	0.0	0.0	2.418034D-07	2.418034D-07	25.412513D+01	25.412513D+01	25.412513D+01
297	2.44430D+01	1	3.63113D-06	1.05500D+00	0.0	0.0	0.0	11.854172D+01	13.865126D+01	25.412513D+01	25.412513D+01	25.412513D+01
297	2.44430D+01	2	7.60703D+01	3.808369D+01	5.826288D+01	11.854172D+01	24.729672D+01	21.889650D+01	24.729672D+01	25.412513D+01	25.412513D+01	25.412513D+01
297	2.44430D+01	1	7.74880D+01	17.883342D+01	19.889105D+01	21.889105D+01	0.0	0.0	0.0	25.412513D+01	25.412513D+01	25.412513D+01
297	2.44430D+01	2	7.23274D+01	17.883342D+01	19.889105D+01	21.889105D+01	0.0	0.0	0.0	25.412513D+01	25.412513D+01	25.412513D+01
298	2.46210D+01	1	4.36107D-05	1.05500D+00	0.0	0.0	0.0	1.887249D-06	1.887249D-06	25.448677D+01	25.448677D+01	25.448677D+01
298	2.46210D+01	2	5.93897D-06	1.05500D+00	0.0	0.0	0.0	2.583542D-07	2.583542D-07	25.448677D+01	25.448677D+01	25.448677D+01
298	2.46210D+01	1	5.42794D-06	1.05500D+00	0.0	0.0	0.0	11.854435D+01	13.865087D+01	25.448677D+01	25.448677D+01	25.448677D+01
298	2.46210D+01	2	7.60695D+01	3.808345D+01	5.826258D+01	11.854435D+01	24.725211D+01	21.889308D+01	24.725211D+01	25.448677D+01	25.448677D+01	25.448677D+01
298	2.46210D+01	1	7.74825D+01	17.883225D+01	19.888875D+01	21.888875D+01	0.0	0.0	0.0	25.448677D+01	25.448677D+01	25.448677D+01
298	2.46210D+01	2	7.18787D+01	17.883225D+01	19.888875D+01	21.888875D+01	0.0	0.0	0.0	25.448677D+01	25.448677D+01	25.448677D+01
299	2.48105D+01	1	4.97236D-05	1.05500D+00	0.0	0.0	0.0	1.987304D-06	1.987304D-06	25.471843D+01	25.471843D+01	25.471843D+01
299	2.48105D+01	2	7.09421D-06	1.05500D+00	0.0	0.0	0.0	2.679224D-07	2.679224D-07	25.471843D+01	25.471843D+01	25.471843D+01
299	2.48105D+01	1	6.62508D-06	1.05500D+00	0.0	0.0	0.0	11.854396D+01	13.865044D+01	25.471843D+01	25.471843D+01	25.471843D+01
299	2.48105D+01	2	7.50686D+01	3.808320D+01	5.826227D+01	11.854396D+01	24.720523D+01	21.889460D+01	24.720523D+01	25.471843D+01	25.471843D+01	25.471843D+01
299	2.48105D+01	1	7.74764D+01	17.883099D+01	19.888630D+01	21.888630D+01	0.0	0.0	0.0	25.471843D+01	25.471843D+01	25.471843D+01
299	2.48105D+01	2	7.14069D+01	17.883099D+01	19.888630D+01	21.888630D+01	0.0	0.0	0.0	25.471843D+01	25.471843D+01	25.471843D+01
300	2.50000D+01	1	5.09677D-05	1.05500D+00	0.0	0.0	0.0	1.999813D-06	1.999813D-06	25.466314D+01	25.466314D+01	25.466314D+01
300	2.50000D+01	2	7.29577D-06	1.05500D+00	0.0	0.0	0.0	2.656214D-07	2.656214D-07	25.466314D+01	25.466314D+01	25.466314D+01
300	2.50000D+01	1	6.21376D-06	1.05500D+00	0.0	0.0	0.0	11.854357D+01	13.865004D+01	25.466314D+01	25.466314D+01	25.466314D+01
300	2.50000D+01	2	7.60670D+01	3.808295D+01	5.826197D+01	11.854357D+01	24.715889D+01	21.889587D+01	24.715889D+01	25.466314D+01	25.466314D+01	25.466314D+01
300	2.50000D+01	1	7.74770D+01	17.882969D+01	19.888386D+01	21.888386D+01	0.0	0.0	0.0	25.466314D+01	25.466314D+01	25.466314D+01
300	2.50000D+01	2	7.09406D+01	17.882969D+01	19.888386D+01	21.888386D+01	0.0	0.0	0.0	25.466314D+01	25.466314D+01	25.466314D+01

HEATING6 02/12/83  
 W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 300 TIME STEPS, TIME = 2.500000E-01

TRM3033/ 0  
 20.56 02 11-16-89

GROSS GRID	1
FINE GRID	1
DISTANCE	0.0
1	0.0
2	0.03
3	0.06
4	0.08
5	0.10
6	0.57
7	1.04
8	1.51
9	1.98
10	2.45
11	2.92
12	3.14
13	3.35
14	3.57
15	3.79
16	4.01
17	4.23
18	4.45
19	4.67
20	4.89
21	5.10
22	5.18
23	5.25
24	5.32
25	5.35

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	80.500000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 1.894597010E-01

ELAPSED CPU TIME IS 3.59 SECONDS

THE MAXIMUM TEMPERATURE IS - 8.893000E+01 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 20 21

THE MINIMUM TEMPERATURE IS - 7.094060E+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 25



NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	NODE	MAX PERCENT TEMP CHANGE
301	2 52084D+01	1	2 47502D-04	1 05500D+00	0 0	0 0	0 0	1	2 80335D-05	24 4 96588D-01	24 4	9 3666D-01
301	2 52084D+01	2	3 7 16903D-06	1 05500D+00	0 0	0 0	0 0	2	2 78581D-06			
301	2 52084D+01	2	4 98331D-06	1 05500D+00	0 0	0 0	0 0					
TABLE FOR SPECIAL MONITORING OF TEMPERATURES												
***** NODE NUMBERS AND TEMPERATURES *****												
301	2 5208D+01	1	7 60668D+01	3 8 08268D+01	5 8 26163D+01	11 8 54314D+01	13 8 64953D+01					
301	2 5208D+01	15	8 74629D+01	17 8 82824D+01	19 8 88116D+01	21 8 88195D+01	24 7 10923D+01					
301	2 5208D+01	21	7 04506D+01		0 0	0 0						
302	2 54377D+01	1	1 6 708D-04	1 05500D+00	0 0	0 0	0 0	1	2 97185D-05			
302	2 54377D+01	3	4 8948D-06	1 05500D+00	0 0	0 0	0 0	2	2 02143D-06	24 5 26286D-01	25 7	4 3272D-01
302	2 54377D+01	2	4 09024D-06	1 05500D+00	0 0	0 0	0 0	11 8 54267D+01	13 8 64899D+01			
302	2 54377D+01	1	7 60657D+01	3 8 08238D+01	5 8 26126D+01	11 8 87767D+01	24 7 05660D+01					
302	2 5438D+01	1	7 60657D+01	3 8 08238D+01	5 8 26126D+01	11 8 87767D+01	24 7 05660D+01					
302	2 5438D+01	15	8 74547D+01	17 8 82661D+01	19 8 87820D+01	21 8 87767D+01	24 7 05660D+01					
302	2 5438D+01	25	6 99269D+01		0 0	0 0						
303	2 56898D+01	1	1 18551D-04	1 05500D+00	0 0	0 0	0 0	1	3 34733D-05			
303	2 56898D+01	3	7 40328D-06	1 05500D+00	0 0	0 0	0 0	2	2 50926D-06	24 5 60488D-01	25 7	9 8660D-01
303	2 56898D+01	2	5 60528D-06	1 05500D+00	0 0	0 0	0 0	11 8 54215D+01	13 8 64838D+01			
303	2 56898D+01	1	7 60646D+01	3 8 08205D+01	5 8 26086D+01	11 8 87300D+01	24 7 00055D+01					
303	2 5690D+01	1	7 60646D+01	3 8 08205D+01	5 8 26086D+01	11 8 87300D+01	24 7 00055D+01					
303	2 5690D+01	15	8 74453D+01	17 8 82479D+01	19 8 87495D+01	21 8 87300D+01	24 7 00055D+01					
303	2 5690D+01	25	6 93685D+01		0 0	0 0						
304	2 58449D+01	1	4 48875D-05	1 05500D+00	0 0	0 0	0 0	1	1 37556D-05			
304	2 58449D+01	2	5 26281D-06	1 05500D+00	0 0	0 0	0 0	2	6 11196D-07	25 3 37434D-01	25 4	8 6437D-01
304	2 58449D+01	1	5 52983D-06	1 05500D+00	0 0	0 0	0 0	11 8 54183D+01	13 8 64800D+01			
304	2 58449D+01	1	7 60637D+01	3 8 08185D+01	5 8 26061D+01	11 8 87014D+01	24 6 96568D+01					
304	2 5845D+01	1	7 60637D+01	3 8 08185D+01	5 8 26061D+01	11 8 87014D+01	24 6 96568D+01					
304	2 5845D+01	15	8 74393D+01	17 8 82365D+01	19 8 87295D+01	21 8 87014D+01	24 6 96568D+01					
304	2 5845D+01	25	6 90310D+01		0 0	0 0						
305	2 60000D+01	1	6 64133D-05	1 05500D+00	0 0	0 0	0 0	1	1 23482D-05			
305	2 60000D+01	2	8 58144D-06	1 05500D+00	0 0	0 0	0 0	2	7 99267D-07	24 3 30780D-01	25 4	7 6983D-01
305	2 60000D+01	1	7 18945D-06	1 05500D+00	0 0	0 0	0 0	11 8 54150D+01	13 8 64767D+01			
305	2 60000D+01	1	7 60630D+01	3 8 08165D+01	5 8 26036D+01	11 8 86731D+01	24 6 93381D+01					
305	2 60000D+01	1	7 60630D+01	3 8 08165D+01	5 8 26036D+01	11 8 86731D+01	24 6 93381D+01					
305	2 60000D+01	15	8 74333D+01	17 8 82249D+01	19 8 87094D+01	21 8 86731D+01	24 6 93381D+01					
305	2 60000D+01	25	6 87018D+01		0 0	0 0						

GROSS GRID	1
FINE GRID	1
DISTANCE	0.0
1	0.0
2	0.03
3	0.06
4	0.08
5	0.10
6	0.57
7	1.04
8	1.51
9	1.98
10	2.45
11	2.92
12	3.14
13	3.35
14	3.57
15	3.79
16	4.01
17	4.23
18	4.45
19	4.67
20	4.89
21	5.10
22	5.18
23	5.25
24	5.32
25	5.35

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	78.640000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 1.55088615D-01

ELAPSED CPU TIME IS 3.66 SECONDS

THE MAXIMUM TEMPERATURE IS - 8.87707D+01 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 19 20

THE MINIMUM TEMPERATURE IS - 5.87018D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 25

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RND (ITERATION)	RND (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	NODE	MAX PERCENT TEMP CHANGE			
306	2.61706D+01	1	2.17126D-04	1.05500D+00	0.0	0.0	0.0	1	2.91787D-05	24	3	502590-01	24	5	051470-01
306	2.61706D+01	3	4.75997D-05	1.05500D+00	0.0	0.0	0.0	2	2.49329D-06	24	3	502590-01	24	5	051470-01
306	2.61706D+01	2	3.47183D-06	1.05500D+00	0.0	0.0	0.0	2	2.49329D-06	24	3	502590-01	24	5	051470-01

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NUMBER OF TIME	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****			
TIME STEPS	2.6171D+01	3.808143D+01	5.82608D+01	11.851114D+01	13.864718D+01	19.89879D+01	21.886421D+01	24.86421D+01	24.86421D+01	24.86421D+01	24.86421D+01	24.86421D+01			
307	2.63583D+01	1	1.52900D-04	1.05500D+00	0.0	0.0	0.0	1	3.09576D-05	24	3	647660-01	24	5	287460-01
307	2.63583D+01	3	3.30565D-06	1.05500D+00	0.0	0.0	0.0	2	1.83436D-06	24	3	647660-01	24	5	287460-01
307	2.63583D+01	2	9.0838D-06	1.05500D+00	0.0	0.0	0.0	1	5.84074D+01	13	8	64670D+01	13	8	64670D+01
307	2.6358D+01	1	1.760614D+01	3.808118D+01	3.808118D+01	5.825977D+01	11.854074D+01	13.864670D+01	13.864670D+01	13.864670D+01	13.864670D+01	13.864670D+01			
307	2.6358D+01	15	8.74187D+01	17.881978D+01	17.881978D+01	19.896532D+01	21.886082D+01	24.866731D+01	24.866731D+01	24.866731D+01	24.866731D+01	24.866731D+01			
308	2.65647D+01	1	1.81691D-04	1.05500D+00	0.0	0.0	0.0	1	3.41107D-05	24	3	817370-01	24	5	56281D-01
308	2.65647D+01	3	4.63412D-06	1.05500D+00	0.0	0.0	0.0	2	2.12352D-06	24	3	817370-01	24	5	56281D-01
308	2.65647D+01	2	3.74832D-06	1.05500D+00	0.0	0.0	0.0	1	5.84074D+01	13	8	64616D+01	13	8	64616D+01
308	2.6565D+01	1	1.760614D+01	3.808118D+01	3.808118D+01	5.825943D+01	11.854030D+01	13.864616D+01	13.864616D+01	13.864616D+01	13.864616D+01	13.864616D+01			
308	2.6565D+01	15	8.74101D+01	17.881819D+01	17.881819D+01	19.886366D+01	21.885712D+01	24.862414D+01	24.862414D+01	24.862414D+01	24.862414D+01	24.862414D+01			
309	2.67823D+01	1	1.97716D-04	1.05500D+00	0.0	0.0	0.0	1	3.55275D-05	24	3	83491D-01	24	5	61967D-01
309	2.67823D+01	3	5.44729D-06	1.05500D+00	0.0	0.0	0.0	2	2.26124D-06	24	3	83491D-01	24	5	61967D-01
309	2.67823D+01	2	4.22508D-06	1.05500D+00	0.0	0.0	0.0	1	5.84074D+01	13	8	64557D+01	13	8	64557D+01
309	2.6782D+01	1	1.760594D+01	3.808062D+01	3.808062D+01	5.825907D+01	11.853983D+01	13.864557D+01	13.864557D+01	13.864557D+01	13.864557D+01	13.864557D+01			
309	2.6782D+01	15	8.74007D+01	17.881650D+01	17.881650D+01	19.886086D+01	21.885325D+01	24.878579D+01	24.878579D+01	24.878579D+01	24.878579D+01	24.878579D+01			
310	2.70000D+01	1	1.87046D-04	1.05500D+00	0.0	0.0	0.0	1	3.36446D-05	24	3	65991D-01	24	5	31349D-01
310	2.70000D+01	3	5.15582D-06	1.05500D+00	0.0	0.0	0.0	2	2.17089D-06	24	3	65991D-01	24	5	31349D-01
310	2.70000D+01	2	4.04982D-06	1.05500D+00	0.0	0.0	0.0	1	5.84074D+01	13	8	64897D+01	13	8	64897D+01
310	2.7000D+01	1	1.760584D+01	3.808033D+01	3.808033D+01	5.825871D+01	11.853935D+01	13.864897D+01	13.864897D+01	13.864897D+01	13.864897D+01	13.864897D+01			
310	2.7000D+01	15	8.73911D+01	17.881478D+01	17.881478D+01	19.885806D+01	21.884912D+01	24.874919D+01	24.874919D+01	24.874919D+01	24.874919D+01	24.874919D+01			
310	2.7000D+01	25	6.68960D+01	17.881478D+01	17.881478D+01	19.885806D+01	21.884912D+01	24.874919D+01	24.874919D+01	24.874919D+01	24.874919D+01	24.874919D+01			

HEATING6 02/12/83  
W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

IDM3033/ 0 11-16-89  
20.58.03

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 310 TIME STEPS, TIME = 2.700000+01

GROSS GRID	1
FINE GRID	1
DISTANCE	O.O
1	0.0
2	0.03
3	0.06
4	0.08
5	0.10
6	0.57
7	1.04
8	1.51
9	1.98
10	2.45
11	2.92
12	3.14
13	3.35
14	3.57
15	3.79
16	4.01
17	4.23
18	4.45
19	4.67
20	4.89
21	5.10
22	5.18
23	5.25
24	5.32
25	5.35

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	77.210000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 2.17661176D-01

ELAPSED CPU TIME IS 3.73 SECONDS

THE MAXIMUM TEMPERATURE IS - 8.86150D+01 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 19 20

THE MINIMUM TEMPERATURE IS - 6.68960D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 25

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	ITER	L1 NORM OF TEMP DIFF	NODE	MAX TEMP CHANGE	MAX PERCENT TEMP CHANGE	
311	2.72394D+01	1	6.60649D-04	1.05500D+00	0.0	0.0	0.0	1	7.24261D-05	24	3.68869D-01	24.5	4.6538D-01
311	2.72394D+01	4	3.58522D-07	1.05500D+00	0.0	0.0	0.0	2	7.19893D-06	24	3.68869D-01	24.5	4.6538D-01
311	2.72394D+01	3	2.96882D-06	1.05500D+00	0.0	0.0	0.0	2	7.19893D-06	24	3.68869D-01	24.5	4.6538D-01

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
 \*\*\*\*\* NODE NUMBERS AND TEMPERATURES \*\*\*\*\*

NUMBER OF TIME STEPS	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	ITER	L1 NORM OF TEMP DIFF	NODE	MAX TEMP CHANGE	MAX PERCENT TEMP CHANGE	
311	2.7239D+01	1	7.60573D-01	3.80800D+01	5.825831D+01	11.853881D+01	13.854430D+01	13	8.4430D+01	24	3.68869D-01	24.5	4.6538D-01
			15.873803D+01	17.881287D+01	19.885498D+01	21.884525D+01	24.671230D+01						
			25.665510D+01										
312	2.75028D+01	1	4.58182D-04	1.05500D+00	0.0	0.0	0.0	1	7.42516D-05	24	3.60296D-01	24.5	3.6770D-01
312	2.75028D+01	4	6.03896D-07	1.05500D+00	0.0	0.0	0.0	2	5.27076D-05	24	3.60296D-01	24.5	3.6770D-01
312	2.75028D+01	3	2.54779D-06	1.05500D+00	0.0	0.0	0.0	2	5.27076D-05	24	3.60296D-01	24.5	3.6770D-01
312	2.7503D+01	1	7.60556D+01	3.807965D+01	5.825785D+01	11.853822D+01	13.854354D+01	13	8.4430D+01	24	3.68869D-01	24.5	4.6538D-01
			15.873681D+01	17.881075D+01	19.885158D+01	21.884071D+01	24.657627D+01						
			25.662061D+01										
313	2.77514D+01	1	3.87208D-04	1.05500D+00	0.0	0.0	0.0	1	6.24007D-05	24	3.08198D-01	24.4	6.1632D-01
313	2.77514D+01	4	3.17277D-07	1.05500D+00	0.0	0.0	0.0	2	3.97511D-06	24	3.08198D-01	24.4	6.1632D-01
313	2.77514D+01	2	9.45835D-06	1.05500D+00	0.0	0.0	0.0	1	8.53764D+01	13	8.64281D+01		
313	2.7751D+01	1	7.60548D+01	3.807931D+01	5.825742D+01	11.853764D+01	13.854281D+01	13	8.4430D+01	24	3.68869D-01	24.5	4.6538D-01
			15.873564D+01	17.880872D+01	19.884841D+01	21.883649D+01	24.654545D+01						
			25.659105D+01										
314	2.8000D+01	1	2.45937D-04	1.05500D+00	0.0	0.0	0.0	1	5.46641D-05	24	2.80750D-01	24.4	2.2469D-01
314	2.8000D+01	4	2.82840D-07	1.05500D+00	0.0	0.0	0.0	2	3.57330D-06	24	2.80750D-01	24.4	2.2469D-01
314	2.8000D+01	2	8.48967D-06	1.05500D+00	0.0	0.0	0.0	1	8.53705D+01	13	8.64206D+01		
314	2.8000D+01	1	7.60535D+01	3.807896D+01	5.825698D+01	11.853705D+01	13.854206D+01	13	8.4430D+01	24	3.68869D-01	24.5	4.6538D-01
			15.873443D+01	17.880668D+01	19.884523D+01	21.883232D+01	24.651738D+01						
			25.656414D+01										

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 314 TIME STEPS. TIME = 2.800000+01

GROSS GRID	FINE GRID	DISTANCE	TEMPERATURE
1	1	0.0	76105
2	2	0.03	78142
3	3	0.06	80179
4	4	0.08	81168
5	5	0.10	82157
6	6	0.57	83105
7	7	1.04	83152
8	8	1.51	83199
9	9	1.98	84146
10	10	2.45	84192
11	11	2.92	85137
12	12	3.14	85191
13	13	3.35	86142
14	14	3.57	86190
15	15	3.79	87134
16	16	4.01	87174
17	17	4.23	88107
18	18	4.45	88131
19	19	4.67	88145
20	20	4.89	88146
21	21	5.10	88132
22	22	5.18	81117
23	23	5.25	73182
24	24	5.32	66117
25	25	5.35	65164

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	76.310000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 2.48601342D-01

ELAPSED CPU TIME IS 3.79 SECONDS

THE MAXIMUM TEMPERATURE IS - 8.84632D+01 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 19 20

THE MINIMUM TEMPERATURE IS - 6.66414D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 25

NO	TIME	NO ITER	MAX HEAT RES:FINAL	BETA	L1 NORM OF TEMP DIFF	RHD (ITERATION)	RHD (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	NODE	MAX PERCENT TEMP CHANGE	
315	2.82730+01	1	1 7.605220+01	3 8.078570+01	5 8.256490+01	11 8.536390+01	13 8.641210+01	24 2	574570-01	24 3	890630-01		
		2	15 8.73080+01	17 8.804410+01	19 8.8417+00	21 8.827810+01	24 6	591630+01					
		25	6.541940+01										
316	2.857430+01	1	6 871950-04	1 055000+00	0 0	0 0	0 0	1	073300-04	24 2	189660-01	24 3	321880-01
		4	1 939910-06	1 055000+00	0 0	0 0	0 0	2	752400-06	24 2	189660-01		
		3	4 651930-06	1 055000+00	0 0	0 0	0 0	11 8	535650+01	13 4	640260+01		
316	2.85740+01	1	1 7.605070+01	3 8.078130+01	5 8.255930+01	11 8.535930+01	13 4	640260+01	24 6	569740+01			
		15	8.731570+01	17 8.801880+01	19 8.831920+01	21 8.822930+01	24 6	569740+01					
		25	6.522050+01										
317	2.878710+01	1	6 133300-03	1 055000+00	0 0	0 0	0 0	1	5 632530-04	25 3	756560-01	25 5	759790-01
		4	1 661170-06	1 055000+00	0 0	0 0	0 0	2	6 557620-05	25 3	756560-01		
		4	2 024780-07	1 055000+00	0 0	0 0	0 0	3	7 917940-06	25 3	756560-01		
317	2.878710+01	3	2 638570-06	1 055000+00	0 0	0 0	0 0	11 8	535110+01	13 8	639560+01		
		1	1 7.604940+01	3 8.077810+01	5 8.255520+01	11 8.535110+01	13 8	639560+01	24 6	578020+01			
317	2.87870+01	1	15 8.730470+01	17 8.800080+01	19 8.835220+01	21 8.819540+01	24 6	578020+01					
		25	6.559610+01										
318	2.900000+01	1	6 964760-03	1 055000+00	0 0	0 0	0 0	1	8 598950-04	25 9	894200-01	25 1	508350+00
		4	2 071270-06	1 055000+00	0 0	0 0	0 0	2	7 723370-05	25 9	894200-01		
		4	2 416520-07	1 055000+00	0 0	0 0	0 0	3	9 322850-06	25 9	894200-01		
318	2.900000+01	3	3 148550-06	1 055000+00	0 0	0 0	0 0	1	5 653190-05	25 6	128730-01	25 9	343130-01
		1	1 023620-04	1 055000+00	0 0	0 0	0 0	2	6 652480-07	25 6	128730-01		
318	2.892120+01	3	7 009540-07	1 055000+00	0 0	0 0	0 0	11 8	534770+01	13 8	639120+01		
		1	1 7.694130-06	1 055000+00	0 0	0 0	0 0	21 8	817450+01	24 6	610520+01		
318	2.89210+01	1	15 8.729770+01	17 8.798950+01	19 8.833530+01	21 8.817450+01	24 6	610520+01					
		25	6.620900+01										
319	2.900000+01	1	3 286200-04	1 055000+00	0 0	0 0	0 0	1	1 627520-04	25 4	516830-01	25 6	822070-01
		3	3 247730-06	1 055000+00	0 0	0 0	0 0	2	4 747460-06	25 4	516830-01		
319	2.900000+01	2	2 263750-06	1 055000+00	0 0	0 0	0 0	11 8	534560+01	13 8	638860+01		
		1	1 7.504810+01	3 8.077480+01	5 8.255110+01	11 8.534560+01	13 8	638860+01	24 6	641300+01			
319	2.90000+01	1	15 8.729360+01	17 8.798270+01	19 8.832540+01	21 8.816230+01	24 6	641300+01					
		25	6.666070+01										

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
 NODE NUMBERS AND TEMPERATURES

HEATING6 02/12/83  
W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 319 TIME STEPS, TIME = 2.900000+01

IBM3033/ 0  
20.58.03 11-16-89

GROSS GRID	1
FINE GRID	1
DISTANCE	0.0
1	76105
2	78141
3	80177
4	81166
5	82155
6	83103
7	83151
8	83197
9	84144
10	84189
11	85135
12	85188
13	86139
14	86186
15	87129
16	87167
17	87198
18	88121
19	88133
20	88132
21	88116
22	80178
23	73141
24	66141
25	66166

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	76.000000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 7.87970745D-02

ELAPSED CPU TIME IS 3.89 SECONDS

THE MAXIMUM TEMPERATURE IS - 8.83254D+01 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 19 20

THE MINIMUM TEMPERATURE IS - 6.64130D+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 24



NO TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	MODE	MAX PERCENT TEMP CHANGE
320 2.90788D+01	1	1.55789D-04	1.05500D+00	0.0	0.0	0.0	1	1.00541D-04	25.4	98054D-01	25.7
320 2.90788D+01	3	1.58080D-06	1.05500D+00	0.0	0.0	0.0	2	2.38540D-06	25.4	98054D-01	25.7
320 2.90788D+01	2	1.14640D-06	1.05500D+00	0.0	0.0	0.0	2	2.38540D-06	25.4	98054D-01	25.7

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
 NODE NUMBERS AND TEMPERATURES

NO TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	MODE	MAX PERCENT TEMP CHANGE
320 2.9079D+01	1	1.760476D+01	3.8	0.7736D+01	5.8	75496D+01	11	8.53436D+01	13.8	638590D+01	13.8
	15	8.72894D+01	17.8	79760D+01	19.8	83154D+01	21	8.81504D+01	24.6	67898D+01	24.6
	25	6.71588D+01									
321 2.91576D+01	1	1.44712D-04	1.05500D+00	0.0	0.0	0.0	1	9.10214D-05	25.5	39879D-01	25.8
321 2.91576D+01	3	1.47320D-06	1.05500D+00	0.0	0.0	0.0	2	2.14745D-06	25.5	39879D-01	25.8
321 2.91576D+01	2	1.03507D-06	1.05500D+00	0.0	0.0	0.0	1	8.53137D+01	13.8	63833D+01	13.8
	1	1.760471D+01	3.8	0.7723D+01	5.8	25480D+01	21	8.81387D+01	24.6	72238D+01	24.6
	15	8.72853D+01	17.8	79693D+01	19.8	82056D+01	21	8.81387D+01	24.6	72238D+01	24.6
	25	6.76986D+01									
322 2.92364D+01	1	1.26029D-04	1.05500D+00	0.0	0.0	0.0	1	8.16751D-05	25.5	76220D-01	25.8
322 2.92364D+01	2	9.93538D-06	1.05500D+00	0.0	0.0	0.0	2	2.51950D-06	25.5	76220D-01	25.8
322 2.92364D+01	2	8.27665D-07	1.05500D+00	0.0	0.0	0.0	1	8.53394D+01	13.8	63806D+01	13.8
	1	1.760467D+01	3.8	0.7711D+01	5.8	25465D+01	21	8.82957D+01	24.6	77057D+01	24.6
	15	8.72811D+01	17.8	79625D+01	19.8	82957D+01	21	8.82957D+01	24.6	77057D+01	24.6
	25	6.82749D+01									
323 2.93231D+01	1	1.17853D-04	1.05500D+00	0.0	0.0	0.0	1	8.03365D-05	25.6	65376D-01	25.9
323 2.93231D+01	2	8.5552D-06	1.05500D+00	0.0	0.0	0.0	2	2.37025D-06	25.6	65376D-01	25.9
323 2.93231D+01	2	9.30027D-07	1.05500D+00	0.0	0.0	0.0	1	8.53371D+01	13.8	63776D+01	13.8
	1	1.760462D+01	3.8	0.7697D+01	5.8	25447D+01	21	8.82848D+01	24.6	82848D+01	24.6
	15	8.72764D+01	17.8	79551D+01	19.8	82848D+01	21	8.82848D+01	24.6	82848D+01	24.6
	25	6.89402D+01									
324 2.94097D+01	1	1.34817D-04	1.05500D+00	0.0	0.0	0.0	1	1.50228D-06	25.6	57230D-01	25.9
324 2.94097D+01	3	1.39615D-06	1.05500D+00	0.0	0.0	0.0	2	1.52822D-07	25.6	57230D-01	25.9
324 2.94097D+01	2	1.07530D-06	1.05500D+00	0.0	0.0	0.0	1	7.78789D-05	25.6	57230D-01	25.9
324 2.94097D+01	1	1.15856D-05	1.05500D+00	0.0	0.0	0.0	2	1.90878D-06	25.6	99371D-01	25.9
324 2.94097D+01	2	1.03621D-06	1.05500D+00	0.0	0.0	0.0	1	8.53394D+01	13.8	63748D+01	13.8
324 2.94097D+01	1	1.03764D-07	1.05500D+00	0.0	0.0	0.0	2	1.50228D-06	25.6	57230D-01	25.9
	1	1.760457D+01	3.8	0.7684D+01	5.8	25431D+01	21	8.82747D+01	24.6	88653D+01	24.6
	15	8.72721D+01	17.8	79481D+01	19.8	82747D+01	21	8.82747D+01	24.6	88653D+01	24.6
	25	6.95975D+01									
325 2.94854D+01	1	1.91340D-05	1.05500D+00	0.0	0.0	0.0	1	5.96092D-05	25.6	80316D-01	25.9
325 2.94854D+01	2	6.16564D-06	1.05500D+00	0.0	0.0	0.0	2	1.37104D-06	25.6	80316D-01	25.9
325 2.94854D+01	1	6.92510D-06	1.05500D+00	0.0	0.0	0.0	1	5.3328D+01	13.8	63726D+01	13.8
	1	1.760453D+01	3.8	0.7671D+01	5.8	25414D+01	21	8.80936D+01	24.6	94792D+01	24.6
	15	8.72677D+01	17.8	79411D+01	19.8	82647D+01	21	8.80936D+01	24.6	94792D+01	24.6
	25	7.02778D+01									
326 2.95666D+01	1	5.83738D-04	1.05500D+00	0.0	0.0	0.0	1	1.55620D-05	25.6	52501D-01	25.9
326 2.95666D+01	3	5.75060D-06	1.05500D+00	0.0	0.0	0.0	2	8.20487D-07	25.6	52501D-01	25.9
326 2.95666D+01	2	5.81400D-06	1.05500D+00	0.0	0.0	0.0	1	1.36693D-04	25.6	52501D-01	25.9
326 2.95666D+01	1	5.30672D-05	1.05500D+00	0.0	0.0	0.0	2	6.92359D-06	25.8	12558D-01	25.9
326 2.95666D+01	2	3.99344D-06	1.05500D+00	0.0	0.0	0.0	1	5.56200D-05	25.8	12558D-01	25.9
326 2.95666D+01	1	3.17594D-06	1.05500D+00	0.0	0.0	0.0	2	8.20487D-07	25.6	52501D-01	25.9
	1	1.760449D+01	3.8	0.7666D+01	5.8	25401D+01	21	8.80853D+01	24.7	00192D+01	24.7
	15	8.72640D+01	17.8	79354D+01	19.8	82564D+01	21	8.80853D+01	24.7	00192D+01	24.7
	25	7.09303D+01									
327 2.96188D+01	1	8.12843D-04	1.05500D+00	0.0	0.0	0.0	1	2.01903D-04	25.8	79069D-01	25.9
327 2.96188D+01	3	7.69337D-06	1.05500D+00	0.0	0.0	0.0	2	9.74195D-06	25.8	79069D-01	25.9
327 2.96188D+01	2	3.73222D-06	1.05500D+00	0.0	0.0	0.0	1	1.42821D-06	25.8	79069D-01	25.9
327 2.96188D+01	1	6.74528D-06	1.05500D+00	0.0	0.0	0.0	2	5.21847D-07	25.6	71719D-01	25.9
327 2.96188D+01	1	5.74528D-06	1.05500D+00	0.0	0.0	0.0	1	5.32968D+01	13.8	63679D+01	13.8
327 2.96188D+01	1	1.3881D-07	1.05500D+00	0.0	0.0	0.0	2	8.0792D+01	24.7	04875D+01	24.7
	1	1.760446D+01	3.8	0.7652D+01	5.8	25390D+01	21	8.82501D+01	24.7	04875D+01	24.7
	15	8.72613D+01	17.8	79309D+01	19.8	82501D+01	21	8.82501D+01	24.7	04875D+01	24.7
	25	7.16020D+01									
328 2.96543D+01	1	1.77668D-04	1.05500D+00	0.0	0.0	0.0	1	0.0	0.0	0.0	0.0

328	2 965430+01	3 1 543590-06	1 055000+00	0 0	0 0	0 0	1 1 024790-04	25 7 528690-01	25 1 051460+00
328	2 965430+01	2 9 221830-07	1 055000+00	0 0	0 0	0 0	2 2 542650-06		
328	2 965430+01	1 3 745880-06	1 055000+00	0 0	0 0	0 0	1 2 577150-06	25 6 807440-01	25 9 507340-01
328	2 965430+01	1 3 745880-06	1 055000+00	0 0	0 0	0 0	2 2 283750-07	25 6 807440-01	25 9 507340-01
328	2 965430+01	1 3 745880-06	1 055000+00	0 0	0 0	0 0	1 1 8 532830+01	13 8 636630+01	
328	2 965430+01	1 3 050530-07	1 055000+00	0 0	5 8 253810+01	19 8 824440+01	21 8 807390+01	24 7 097340+01	
328	2 965430+01	1 1 7 604430+01	3 8 076440+01	17 8 792700+01	19 8 823380+01	5 8 253720+01	21 8 806900+01	24 7 148350+01	
328	2 965430+01	15 8 725870+01	17 8 792700+01		19 8 823380+01	5 8 253720+01	21 8 806900+01	24 7 148350+01	
328	2 965430+01	25 7 228270+01			19 8 823380+01	5 8 253720+01	21 8 806900+01	24 7 148350+01	
329	2 969560+01	1 8 614680-05	1 055000+00	0 0	0 0	0 0	1 7 711600-05	25 7 323380-01	25 1 013160+00
329	2 969560+01	3 7 339050-07	1 055000+00	0 0	0 0	0 0	2 1 392320-06		
329	2 969560+01	1 5 832100-06	1 055000+00	0 0	0 0	0 0	1 1 913210-06	25 6 874190-01	25 9 510140-01
329	2 969560+01	1 3 375370-06	1 055000+00	0 0	0 0	0 0	2 2 083780-07		
329	2 969560+01	1 3 375370-06	1 055000+00	0 0	0 0	0 0	11 8 532710+01	13 8 636470+01	
329	2 969560+01	1 3 224710-07	1 055000+00	0 0	0 0	0 0	21 8 806900+01	24 7 148350+01	
329	2 969560+01	1 7 604400+01	3 8 076570+01	17 8 792330+01		0 0	1 6 369740-05	25 7 260080-01	25 9 949380-01
329	2 969560+01	25 7 297020+01				0 0	2 1 279150-06		
330	2 973600+01	1 5 345350-05	1 055000+00	0 0	0 0	0 0	11 8 532590+01	13 8 636320+01	
330	2 973600+01	2 6 997770-06	1 055000+00	0 0	0 0	0 0	21 8 806630+01	24 7 204340+01	
330	2 973600+01	1 3 433010-06	1 055000+00	0 0	5 8 253630+01	19 8 823380+01	11 8 532480+01	13 8 636180+01	
330	2 973600+01	1 7 604380+01	3 8 076300+01	17 8 791950+01		0 0	24 7 259920+01		
330	2 973600+01	15 8 725400+01	17 8 791950+01			0 0	1 5 992600-05	25 7 606810-01	25 1 032180+00
330	2 973600+01	25 7 369620+01				0 0	2 1 121090-06		
331	2 977920+01	1 4 683260-05	1 055000+00	0 0	0 0	0 0	1 2 247200-06	25 7 014450-01	25 9 518060-01
331	2 977920+01	2 6 206440-06	1 055000+00	0 0	0 0	0 0	2 2 436420-07		
331	2 977920+01	1 3 017910-06	1 055000+00	0 0	0 0	0 0	11 8 532480+01	13 8 636180+01	
331	2 977920+01	1 4 246420-06	1 055000+00	0 0	0 0	0 0	21 8 806020+01	24 7 259920+01	
331	2 977920+01	1 4 246420-06	1 055000+00	0 0	0 0	0 0	1 4 501860-05	25 7 508120-01	25 9 994210-01
331	2 977920+01	1 4 218760-07	1 055000+00	0 0	0 0	0 0	2 6 794770-07		
331	2 977920+01	1 7 604350+01	3 8 076230+01	17 8 791600+01		0 0	11 8 532260+01	13 8 635890+01	
331	2 977920+01	15 8 725180+01	17 8 791600+01			0 0	21 8 805230+01	24 7 381640+01	
331	2 977920+01	25 7 439760+01				0 0	1 4 253340-05	25 7 727630-01	25 1 018460+00
332	2 981580+01	1 2 749580-05	1 055000+00	0 0	0 0	0 0	2 6 387500-07		
332	2 981580+01	2 4 122820-06	1 055000+00	0 0	0 0	0 0	1 1 704820-06	25 7 221520-01	25 9 517560-01
332	2 981580+01	1 1 883250-06	1 055000+00	0 0	5 8 253460+01	19 8 822410+01	2 1 985470-07		
332	2 981580+01	1 7 604330+01	3 8 076170+01	17 8 791250+01		0 0	2 1 985470-07	25 7 221520-01	25 9 517560-01
332	2 981580+01	15 8 724960+01	17 8 791250+01			0 0	11 8 532260+01	13 8 635760+01	
332	2 981580+01	25 7 512470+01				0 0	21 8 805230+01	24 7 381640+01	
333	2 985560+01	1 2 545690-05	1 055000+00	0 0	0 0	0 0	1 4 501860-05	25 7 508120-01	25 9 994210-01
333	2 985560+01	2 3 778950-06	1 055000+00	0 0	0 0	0 0	2 6 794770-07		
333	2 985560+01	1 1 716880-06	1 055000+00	0 0	5 8 253380+01	19 8 821930+01	11 8 532260+01	13 8 635890+01	
333	2 985560+01	1 7 604300+01	3 8 076100+01	17 8 790910+01		0 0	2 6 387500-07	25 7 727630-01	25 1 018460+00
333	2 985560+01	15 8 724740+01	17 8 790910+01			0 0	1 4 253340-05	25 7 727630-01	25 1 018460+00
334	2 989550+01	1 2 372800-05	1 055000+00	0 0	0 0	0 0	2 6 387500-07		
334	2 989550+01	2 3 487450-06	1 055000+00	0 0	0 0	0 0	1 1 704820-06	25 7 221520-01	25 9 517560-01
334	2 989550+01	1 1 616920-06	1 055000+00	0 0	0 0	0 0	2 1 985470-07		
334	2 989550+01	1 3 405920-06	1 055000+00	0 0	0 0	0 0	11 8 532150+01	13 8 635760+01	
334	2 989550+01	1 3 405920-06	1 055000+00	0 0	0 0	0 0	21 8 804890+01	24 7 442700+01	
334	2 989550+01	1 3 851690-07	1 055000+00	0 0	5 8 253300+01	19 8 821480+01	11 8 532150+01	13 8 635760+01	
334	2 989550+01	1 7 604280+01	3 8 076040+01	17 8 790590+01		0 0	21 8 804890+01	24 7 442700+01	
334	2 989550+01	15 8 724530+01	17 8 790590+01			0 0	1 3 478000-05	25 7 390290-01	25 9 648160-01
335	2 993000+01	1 534700-05	1 055000+00	0 0	0 0	0 0	2 4 539510-07		
335	2 993000+01	2 2 419170-06	1 055000+00	0 0	0 0	0 0	2 4 539510-07	25 7 390290-01	25 9 648160-01
335	2 993000+01	1 072930-06	1 055000+00	0 0	0 0	0 0	11 8 532050+01	13 8 635620+01	
335	2 993000+01	1 7 604260+01	3 8 075980+01	17 8 790260+01		0 0	24 7 506230+01		
335	2 993000+01	15 8 733670+01	17 8 790260+01			0 0	21 8 804560+01	24 7 506230+01	
336	2 996500+01	1 424850-05	1 055000+00	0 0	0 0	0 0	1 3 095010-05	25 7 119100-01	25 9 205330-01
336	2 996500+01	2 2 206470-06	1 055000+00	0 0	0 0	0 0	2 4 097350-07		
336	2 996500+01	1 8 797450-07	1 055000+00	0 0	0 0	0 0	2 4 097350-07	25 7 119100-01	25 9 205330-01
336	2 996500+01	1 7 604240+01	3 8 075920+01	17 8 789960+01		0 0	11 8 531950+01	13 8 635500+01	
336	2 996500+01	15 8 724130+01	17 8 789960+01			0 0	21 8 804270+01	24 7 568140+01	
337	3 000000+01	1 1 106160-05	1 055000+00	0 0	0 0	0 0	19 8 820610+01		
337	3 000000+01	25 7 804870+01				0 0	0 0		

337	3	000000+01	2	1.63556D-06	1.05500D+00	0.0	0.0	0.0	1	2	73576D-05	25	9.28249D-01	
337	3	000000+01	1	6.70520D-07	1.05500D+00	0.0	0.0	0.0	2	3	08799D-07	25	7.24486D-01	
337	3	00000+01	1	7.6042E+01	3.9	07586D+01	5.8	25308D+01	11	8	5318.0+01	13	8.63537D+01	
				15	8	72334D+01	17	8	78966D+01	21	8	80399D+01	24	7.63191D+01
				25	7	87731D+01								

GROSS GRID	FINE GRID	DISTANCE	O.C.
1	0	0	76104
2	0	0.03	78140
3	0	0.06	80176
4	0	0.08	81165
5	0	0.10	82153
6	0	0.57	83101
7	1	0.04	83148
8	1	0.51	83195
9	1	0.98	84141
10	2	0.45	84187
11	2	0.92	85132
12	3	0.14	85185
13	3	0.35	86135
14	3	0.57	86182
15	3	0.79	87124
16	4	0.01	87160
17	4	0.23	87190
18	4	0.45	88110
19	4	0.67	88120
20	4	0.89	88118
21	5	0.10	88104
22	5	0.18	82129
23	5	0.25	77174
24	5	0.32	76132
25	5	0.35	78177

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	76.310000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 3.501050520-02

ELAPSED CPU TIME IS 4.15 SECONDS

THE MAXIMUM TEMPERATURE IS - 8.820190+01 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 19 20

THE MINIMUM TEMPERATURE IS - 7.604220+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF NODE TEMP DIFF	MAX TEMP CHANGE	NODE MAX PERCENT TEMP CHANGE
338	3.003500+01	1	1.154450-05	1.055000+00	0.0	0.0	0.0	1	2.669700-05	25.737740-01	25.9365430-01
338	3.003500+01	2	1.789070-06	1.055000+00	0.0	0.0	0.0	2	3.335000-07		
338	3.003500+01	1	1.724180-07	1.055000+00	0.0	0.0	0.0				
TABLE FOR SPECIAL MONITORING OF TEMPERATURES											
***** NODE NUMBERS AND TEMPERATURES *****											
338	3.00350+01	1	7.604200+01	3.8075800+01	5.8253000+01	11.8531750+01	13.8635240+01	11.8531750+01	13.8635240+01	25.7603120-01	25.9562360-01
338	3.00350+01	2	8.723740+01	17.8789350+01	19.8819780+01	21.8803730+01	24.7697430+01	21.8803730+01	24.7697430+01		
338	3.00350+01	3	7.951090+01								
339	3.007050+01	1	1.034000-05	1.055000+00	0.0	0.0	0.0	1	2.545850-05		
339	3.007050+01	2	1.598110-06	1.055000+00	0.0	0.0	0.0	2	3.038780-07	25.7603120-01	25.9562360-01
339	3.007050+01	1	6.575120-07	1.055000+00	0.0	0.0	0.0	11.8531650+01	13.8635110+01		
339	3.00710+01	1	1.7604180+01	3.8075740+01	5.8252920+01	11.8531650+01	13.8635110+01	11.8531650+01	13.8635110+01		
339	3.00710+01	2	1.7604180+01	3.8075740+01	5.8252920+01	11.8531650+01	13.8635110+01	21.8803480+01	24.7765550+01		
339	3.00710+01	3	8.723540+01	17.8789040+01	19.8819360+01	21.8803480+01	24.7765550+01				
339	3.00710+01	4	8.027120+01								
340	3.010600+01	1	9.813780-06	1.055000+00	0.0	0.0	0.0	1	2.416400-05		
340	3.010600+01	2	8.13780-06	1.055000+00	0.0	0.0	0.0	2	1.034170-06	25.7717280-01	25.9614010-01
340	3.010600+01	3	3.45019-06	1.055000+00	0.0	0.0	0.0	11.8531550+01	13.8634980+01		
340	3.010600+01	4	1.7604150+01	3.8075680+01	5.8252850+01	11.8531550+01	13.8634980+01	11.8531550+01	13.8634980+01		
340	3.01060+01	5	8.723340+01	17.8788730+01	19.8818940+01	21.8803250+01	24.7835230+01	21.8803250+01	24.7835230+01		
340	3.01060+01	6	8.104290+01								
341	3.014160+01	1	8.762400-06	1.055000+00	0.0	0.0	0.0	1	2.258450-05		
341	3.014160+01	2	8.762400-06	1.055000+00	0.0	0.0	0.0	2	9.427260-07	25.7820270-01	25.9649540-01
341	3.014160+01	3	2.086930-06	1.055000+00	0.0	0.0	0.0	11.8531450+01	13.8634850+01		
341	3.01420+01	4	1.7604130+01	3.8075620+01	5.8252770+01	11.8531450+01	13.8634850+01	11.8531450+01	13.8634850+01		
341	3.01420+01	5	8.723140+01	17.8788420+01	19.8818520+01	21.8803040+01	24.7906350+01	21.8803040+01	24.7906350+01		
341	3.01420+01	6	8.182490+01								
342	3.01770+01	1	8.039180-06	1.055000+00	0.0	0.0	0.0	1	2.126430-05		
342	3.01770+01	2	8.038180-06	1.055000+00	0.0	0.0	0.0	2	8.835250-07	25.7915670-01	25.9673910-01
342	3.01770+01	3	1.929610-06	1.055000+00	0.0	0.0	0.0	11.8531350+01	13.8634720+01		
342	3.01770+01	4	1.7604110+01	3.8075560+01	5.8252700+01	11.8531350+01	13.8634720+01	11.8531350+01	13.8634720+01		
342	3.01770+01	5	8.722940+01	17.8788120+01	19.8818110+01	21.8802850+01	24.7978810+01	21.8802850+01	24.7978810+01		
342	3.01770+01	6	8.261650+01								
343	3.021260+01	1	7.222290-06	1.055000+00	0.0	0.0	0.0	1	1.990710-05		
343	3.021260+01	2	7.222290-06	1.055000+00	0.0	0.0	0.0	2	7.959510-07	25.8002440-01	25.9686250-01
343	3.021260+01	3	1.699970-06	1.055000+00	0.0	0.0	0.0	11.8531240+01	13.8634590+01		
343	3.02130+01	4	1.7604090+01	3.8075500+01	5.8252620+01	11.8531240+01	13.8634590+01	11.8531240+01	13.8634590+01		
343	3.02130+01	5	8.722740+01	17.8787810+01	19.8817690+01	21.8802680+01	24.8052500+01	21.8802680+01	24.8052500+01		
343	3.02130+01	6	8.341680+01								
344	3.024810+01	1	6.563070-06	1.055000+00	0.0	0.0	0.0	1	1.866150-05		
344	3.024810+01	2	6.563070-06	1.055000+00	0.0	0.0	0.0	2	7.452410-07	25.8081900-01	25.9688590-01
344	3.024810+01	3	1.577720-06	1.055000+00	0.0	0.0	0.0	11.8531140+01	13.8634460+01		
344	3.02480+01	4	1.7604070+01	3.8075440+01	5.8252540+01	11.8531140+01	13.8634460+01	11.8531140+01	13.8634460+01		
344	3.02480+01	5	8.722540+01	17.8787500+01	19.8817280+01	21.8802530+01	24.8127340+01	21.8802530+01	24.8127340+01		
344	3.02480+01	6	8.422500+01								
345	3.028360+01	1	5.951280-06	1.055000+00	0.0	0.0	0.0	1	1.746480-05		
345	3.028360+01	2	5.951280-06	1.055000+00	0.0	0.0	0.0	2	6.824140-07	25.8154820-01	25.9682180-01
345	3.028360+01	3	1.413140-06	1.055000+00	0.0	0.0	0.0	11.8531040+01	13.8634330+01		
345	3.02840+01	4	1.7604050+01	3.8075380+01	5.8252470+01	11.8531040+01	13.8634330+01	11.8531040+01	13.8634330+01		
345	3.02840+01	5	8.722340+01	17.8787190+01	19.8816880+01	21.8802400+01	24.8203240+01	21.8802400+01	24.8203240+01		
345	3.02840+01	6	8.504040+01								
346	3.031910+01	1	5.335240-06	1.055000+00	0.0	0.0	0.0	1	1.629540-05		
346	3.031910+01	2	5.335240-06	1.055000+00	0.0	0.0	0.0	2	6.276810-07	25.8220710-01	25.9666830-01
346	3.031910+01	3	1.284430-06	1.055000+00	0.0	0.0	0.0	11.8530940+01	13.8634200+01		
346	3.03190+01	4	1.7604020+01	3.8075320+01	5.8252390+01	11.8530940+01	13.8634200+01	11.8530940+01	13.8634200+01		
346	3.03190+01	5	8.722140+01	17.8786880+01	19.8816470+01	21.8802300+01	24.8280110+01	21.8802300+01	24.8280110+01		
346	3.03190+01	6	8.586250+01								
347	3.035460+01	1	4.892990-06	1.055000+00	0.0	0.0	0.0	1	1.525370-05		
347	3.035460+01	2	4.892990-06	1.055000+00	0.0	0.0	0.0	2	5.858970-07	25.8281810-01	25.9645430-01
347	3.035460+01	3	1.176910-06	1.055000+00	0.0	0.0	0.0	11.8530830+01	13.8634070+01		
347	3.03550+01	4	1.7604000+01	3.8075300+01	5.8252310+01	11.8530830+01	13.8634070+01	11.8530830+01	13.8634070+01		
347	3.03550+01	5	8.722040+01	17.8786600+01	19.8816200+01	21.8802200+01	24.8300000+01	21.8802200+01	24.8300000+01		
347	3.03550+01	6	8.586250+01								

348	3.0390+01	15 8 721940+01	17 8 786570+01	19 8 816070+01	21 8 802210+01	24 8 357880+01	25 9 617010-01
		25 8 669070+01		0 0 0 0			
		1 4 369490-06	1 055000+00	0 0 0 0		1 1 420100-05	
		1 4 369490-06	1 055000+00	0 0 0 0		2 5 254790-07	25 8 337060-01
		1 1 076430-06	1 055000+00	0 0 0 0		13 8 633930+01	
		1 7 603980+01	3 8 075190+01	5 8 252230+01	11 8 530720+01	24 8 436480+01	
		15 8 721740+01	17 8 786260+01	19 8 815670+01	21 8 802150+01		
		25 8 752440+01		0 0 0 0			
		1 3 951830-06	1 055000+00	0 0 0 0		1 1 324080-05	
		1 3 951830-06	1 055000+00	0 0 0 0		2 4 858910-07	25 8 387480-01
		1 9 342720-07	1 055000+00	0 0 0 0		13 8 633800+01	
		1 7 603960+01	3 8 075130+01	5 8 252160+01	11 8 530620+01	24 8 515830+01	
		15 8 721530+01	17 8 785950+01	19 8 815270+01	21 8 802100+01		
		25 8 836310+01		0 0 0 0			
		1 3 573280-06	1 055000+00	0 0 0 0		1 1 233550-05	
		1 3 573280-06	1 055000+00	0 0 0 0		2 4 484040-07	25 8 433540-01
		1 8 470630-07	1 055000+00	0 0 0 0		13 8 633670+01	
		1 7 603940+01	3 8 075070+01	5 8 252080+01	11 8 530520+01	24 8 535890+01	
		15 8 721335+01	17 8 785640+01	19 8 814880+01	21 8 802090+01		
		25 8 920650+01		0 0 0 0			
		1 3 107860-06	1 055000+00	0 0 0 0		1 1 140760-05	
		1 3 107860-06	1 055000+00	0 0 0 0		2 4 045330-07	25 8 473820-01
		1 7 553180-07	1 055000+00	0 0 0 0		13 8 633530+01	
		1 7 603910+01	3 8 075010+01	5 8 252000+01	11 8 530420+01	24 8 676580+01	
		15 8 721130+01	17 8 785330+01	19 8 814490+01	21 8 802090+01		
		25 9 005390+01		0 0 0 0			
		1 1 655630-05	1 055000+00	0 0 0 0		1 1 516560-05	
		2 1 794470-06	1 055000+00	0 0 0 0		2 3 334550-07	25 8 600420-01
		1 6 670720-07	1 055000+00	0 0 0 0		13 8 633400+01	
		1 7 603890+01	3 8 074950+01	5 8 251920+01	11 8 530310+01	24 8 757950+01	
		15 8 720920+01	17 8 785020+01	19 8 814100+01	21 8 802120+01		
		25 9 091390+01		0 0 0 0			
		1 3 060950-05	1 055000+00	0 0 0 0		1 2 026730-05	
		2 3 188960-06	1 055000+00	0 0 0 0		2 5 757570-07	25 8 820670-01
		1 1 162480-06	1 055000+00	0 0 0 0		13 8 633260+01	
		1 7 603870+01	3 8 074880+01	5 8 251840+01	11 8 530210+01	24 8 840280+01	
		15 8 720720+01	17 8 784720+01	19 8 813720+01	21 8 802170+01		
		25 9 179600+01		0 0 0 0			
		1 1 878010-05	1 055000+00	0 0 0 0		1 1 825890-05	
		2 2 165720-06	1 055000+00	0 0 0 0		2 3 952820-07	25 8 980690-01
		1 8 344420-07	1 055000+00	0 0 0 0		13 8 633130+01	
		1 7 603850+01	3 8 074820+01	5 8 251760+01	11 8 530100+01	24 8 923730+01	
		15 8 720520+01	17 8 784410+01	19 8 813340+01	21 8 802240+01		
		25 9 269410+01		0 0 0 0			
		1 1 247560-05	1 055000+00	0 0 0 0		1 1 684040-05	
		2 1 598630-06	1 055000+00	0 0 0 0		2 2 982380-07	25 9 106210-01
		1 6 533180-07	1 055000+00	0 0 0 0		13 8 632990+01	
		1 7 603830+01	3 8 074760+01	5 8 251680+01	11 8 529990+01	24 9 008390+01	
		15 8 720310+01	17 8 784100+01	19 8 812960+01	21 8 802330+01		
		25 9 360470+01		0 0 0 0			
		1 8 771830-06	1 055000+00	0 0 0 0		1 1 540320-05	
		1 8 771830-06	1 055000+00	0 0 0 0		2 8 773430-07	25 9 208570-01
		1 1 910790-06	1 055000+00	0 0 0 0		13 8 632860+01	
		1 7 603800+01	3 8 074700+01	5 8 251600+01	11 8 529890+01	24 9 094750+01	
		15 8 720110+01	17 8 783790+01	19 8 812190+01	21 8 802450+01		
		25 9 452550+01		0 0 0 0			
		1 6 821280-06	1 055000+00	0 0 0 0		1 1 439420-05	
		1 6 821280-06	1 055000+00	0 0 0 0		2 7 381620-07	25 9 296410-01
		1 1 614360-06	1 055000+00	0 0 0 0		13 8 632720+01	
		1 7 603780+01	3 8 074630+01	5 8 251520+01	11 8 529780+01	24 9 181220+01	
		15 8 719900+01	17 8 783480+01	19 8 812220+01	21 8 802600+01		
		25 9 545520+01		0 0 0 0			
		1 5 434390-06	1 055000+00	0 0 0 0		1 1 344910-05	
		1 5 434390-06	1 055000+00	0 0 0 0		2 6 164490-07	25 9 372460-01
		1 1 349280-06	1 055000+00	0 0 0 0		13 8 632590+01	
		1 7 603760+01	3 8 074570+01	5 8 251440+01	11 8 529670+01	24 9 094750+01	
		15 8 719500+01		0 0 0 0			
		1 5 434390-06	1 055000+00	0 0 0 0		1 1 344910-05	
		1 5 434390-06	1 055000+00	0 0 0 0		2 6 164490-07	25 9 372460-01
		1 1 349280-06	1 055000+00	0 0 0 0		13 8 632590+01	
		1 7 603760+01	3 8 074570+01	5 8 251440+01	11 8 529670+01	24 9 094750+01	
		15 8 719500+01		0 0 0 0			

359	3 078080+01	1 4 67911D-06	1 055000+00	0 0	0 0	19 8 811850+01	21 8 802760+01	24 9 269250+01	
359	3 078080+01	1 4 67911D-06	1 055000+00	0 0	0 0	0 0	0 0	1 1 253800-05	25 9 791000-01
359	3 078080+01	1 1 16597D-06	1 055000+00	0 0	0 0	0 0	0 0	2 5 247200-07	25 9 438460-01
359	3 078080+01	1 1 16597D-06	1 055000+00	0 0	0 0	0 0	0 0	11 8 529540+01	13 8 632450+01
359	3 07810D+01	1 1 7 60374D+01	3 8 074510+01	0 0	0 0	19 8 811490+01	21 8 802950+01	24 9 358250+01	
360	3 08163D+01	1 4 25309D-06	1 055000+00	0 0	0 0	0 0	0 0	1 1 179560-05	
360	3 08163D+01	1 4 25309D-06	1 055000+00	0 0	0 0	0 0	0 0	2 4 703800-07	25 9 498070-01
360	3 08163D+01	1 1 06074D-06	1 055000+00	0 0	0 0	0 0	0 0	11 8 529460+01	13 8 632310+01
360	3 08160+01	1 1 7 60371D+01	3 8 074430+01	0 0	0 0	19 8 811140+01	21 8 803150+01	24 9 448140+01	
361	3 085190+01	1 3 71686D-06	1 055000+00	0 0	0 0	0 0	0 0	1 1 099170-05	
361	3 085190+01	1 3 71686D-06	1 055000+00	0 0	0 0	0 0	0 0	2 4 071040-07	25 9 552630-01
361	3 085190+01	1 9 11345D-07	1 055000+00	0 0	0 0	0 0	0 0	11 8 529350+01	13 8 632170+01
361	3 08520+01	1 1 7 60369D+01	3 8 074380+01	0 0	0 0	19 8 810790+01	21 8 803400+01	24 9 538840+01	
362	3 08874D+01	1 3 24955D-06	1 055000+00	0 0	0 0	0 0	0 0	1 1 022600-05	
362	3 08874D+01	1 3 24955D-06	1 055000+00	0 0	0 0	0 0	0 0	2 3 618060-07	25 9 600030-01
362	3 08874D+01	1 7 76248D-07	1 055000+00	0 0	0 0	0 0	0 0	11 8 529240+01	13 8 632040+01
362	3 08870+01	1 1 7 60367D+01	3 8 074310+01	0 0	0 0	19 8 810440+01	21 8 803650+01	24 9 630290+01	
363	3 09229D+01	1 2 77575D-06	1 055000+00	0 0	0 0	0 0	0 0	1 9 457660-06	
363	3 09229D+01	1 2 77575D-06	1 055000+00	0 0	0 0	0 0	0 0	2 3 228970-07	25 9 640790-01
363	3 09229D+01	1 6 72125D-07	1 055000+00	0 0	0 0	0 0	0 0	11 8 529140+01	13 8 631900+01
363	3 09230+01	1 1 7 60364D+01	3 8 074250+01	0 0	0 0	19 8 810100+01	21 8 803940+01	24 9 722410+01	
364	3 09584D+01	1 2 56499D-06	1 055000+00	0 0	0 0	0 0	0 0	1 8 853380-06	
364	3 09584D+01	1 2 56499D-06	1 055000+00	0 0	0 0	0 0	0 0	2 3 071350-07	25 9 678970-01
364	3 09584D+01	1 6 11167D-07	1 055000+00	0 0	0 0	0 0	0 0	11 8 529030+01	13 8 631760+01
364	3 09580+01	1 1 7 60362D+01	3 8 074180+01	0 0	0 0	19 8 809760+01	21 8 804240+01	24 9 815140+01	
365	3 100000+01	1 8 26457D-06	1 055000+00	0 0	0 0	0 0	0 0	1 9 526240-06	
365	3 100000+01	1 8 26457D-06	1 055000+00	0 0	0 0	0 0	0 0	2 4 755250-07	25 1 130960+00
365	3 100000+01	1 7 10855D-07	1 055000+00	0 0	0 0	0 0	0 0	1 2 790020-06	
365	3 099390+01	1 7 92130D-06	1 055000+00	0 0	0 0	0 0	0 0	2 4 963930-07	25 9 711710-01
365	3 099390+01	1 7 92130D-06	1 055000+00	0 0	0 0	0 0	0 0	11 8 528920+01	13 8 631620+01
365	3 099390+01	1 1 08731D-06	1 055000+00	0 0	0 0	19 8 809430+01	21 8 804570+01	24 9 908430+01	
366	3 100390+01	1 4 98758D-06	1 055000+00	0 0	0 0	0 0	0 0	1 4 848610-06	
366	3 100390+01	1 4 98758D-06	1 055000+00	0 0	0 0	0 0	0 0	2 3 989340-07	25 2 824550-01
366	3 100390+01	1 3 96537D-07	1 055000+00	0 0	0 0	0 0	0 0	11 8 528890+01	13 8 631580+01
366	3 10040+01	1 1 7 60359D+01	3 8 074100+01	0 0	0 0	19 8 809340+01	21 8 804670+01	24 9 934820+01	
367	3 10040+01	1 5 8 718190+01	17 8 780940+01	0 0	0 0	0 0	0 0		
367	3 10040+01	25 1 03387D+02		0 0	0 0	0 0	0 0		

HEATING6 02/12/83  
W9XNP11

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

IRMC003/ 0  
20 58.05 11-16-89

TRANSIENT TEMPERATURE DISTRIBUTION AFT.R 365 TIME STEPS, TIME = 3.100390+01

GR05	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	
F	0.0	78139	80174	81163	82151	83141	84131	85129	86132	87177	88178	89181	90184	91184	92184	93184	94184	95184	96184	97184	98184	99184	100184	101184	102184	103199

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	77.215612
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 1.000000000-02

ELAPSED CPU TIME IS 4.45 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.03387D+02 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 25

THE MINIMUM TEMPERATURE IS - 7.60359D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1



NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	MODE	MAX PERCENT TEMP CHANGE			
367	3.10390+01	1	7.30550E-07	1.055000E+00	0.0	0.0	0.0	1	9.76628E-07	25	2	8.1591E-01	25	2	7.2367E-01
367	3.10390+01	1	7.30550E-07	1.055000E+00	0.0	0.0	0.0	2	5.41592E-08	25	2	8.1591E-01	25	2	7.2367E-01
367	3.10390+01	1	5.31345E-06	1.055000E+00	0.0	0.0	0.0								
TABLE FOR SPECIAL MONITORING OF TEMPERATURES															
NUMBER OF TIME															
TIME STEPS															
368	3.10239D+01	1	7.60358D+01	1.055000E+00	0.0	0.0	0.0	1	9.24874D-07	25	2	8.1084E-01	25	2	7.1138E-01
368	3.10239D+01	1	7.3969D-07	1.055000E+00	0.0	0.0	0.0	2	5.13962E-08	25	2	8.1084E-01	25	2	7.1138E-01
368	3.10239D+01	1	4.2055E-08	1.055000E+00	0.0	0.0	0.0	11	8.52887E+01	13	3	6.3150E+01	13	3	6.3150E+01
368	3.10239D+01	1	1.7.60358D+01	1.055000E+00	0.0	0.0	0.0	21	8.80487E+01	24	9	9.98785E+01	24	9	9.98785E+01
368	3.10239D+01	1	1.7.60358D+01	1.055000E+00	0.0	0.0	0.0	19	8.80915D+01	24	9	9.98785E+01	24	9	9.98785E+01
369	3.10339D+01	1	5.70105D-07	1.055000E+00	0.0	0.0	0.0	1	8.32763E-07	25	2	8.0703E-01	25	2	7.0038E-01
369	3.10339D+01	1	5.70105D-07	1.055000E+00	0.0	0.0	0.0	2	4.35999E-08	25	2	8.0703E-01	25	2	7.0038E-01
369	3.10339D+01	1	4.16718E-08	1.055000E+00	0.0	0.0	0.0	11	8.52879E+01	13	3	6.3147E+01	13	3	6.3147E+01
369	3.10339D+01	1	1.7.60357D+01	1.055000E+00	0.0	0.0	0.0	21	8.80497E+01	24	1	0.0145E+02	24	1	0.0145E+02
369	3.10339D+01	1	1.7.60357D+01	1.055000E+00	0.0	0.0	0.0	19	8.80906E+01	24	1	0.0145E+02	24	1	0.0145E+02
370	3.10449D+01	1	7.24960E-07	1.055000E+00	0.0	0.0	0.0	1	1.01713E-06	25	3	3.8200E-01	25	3	3.8200E-01
370	3.10449D+01	1	7.24960E-07	1.055000E+00	0.0	0.0	0.0	2	6.00282E-08	25	3	3.8200E-01	25	3	3.8200E-01
370	3.10449D+01	1	5.82424E-08	1.055000E+00	0.0	0.0	0.0	11	8.52876E+01	13	8	6.3142E+01	13	8	6.3142E+01
370	3.10449D+01	1	1.7.60356D+01	1.055000E+00	0.0	0.0	0.0	21	8.80508E+01	24	1	0.0438E+02	24	1	0.0438E+02
370	3.10449D+01	1	1.7.60356D+01	1.055000E+00	0.0	0.0	0.0	19	8.80896E+01	24	1	0.0438E+02	24	1	0.0438E+02
371	3.10570D+01	1	7.75450E-07	1.055000E+00	0.0	0.0	0.0	1	1.11529E-06	25	3	3.8200E-01	25	3	3.8200E-01
371	3.10570D+01	1	7.75450E-07	1.055000E+00	0.0	0.0	0.0	2	6.34013E-08	25	3	3.8200E-01	25	3	3.8200E-01
371	3.10570D+01	1	6.16883E-08	1.055000E+00	0.0	0.0	0.0	11	8.52872E+01	13	8	6.3137E+01	13	8	6.3137E+01
371	3.10570D+01	1	1.7.60355D+01	1.055000E+00	0.0	0.0	0.0	21	8.80521E+01	24	1	0.0762E+02	24	1	0.0762E+02
371	3.10570D+01	1	1.7.60355D+01	1.055000E+00	0.0	0.0	0.0	19	8.80885E+01	24	1	0.0762E+02	24	1	0.0762E+02
372	3.10703D+01	1	7.92796E-07	1.055000E+00	0.0	0.0	0.0	1	1.19894E-06	25	3	7.1376E-01	24	3	5.4176E-01
372	3.10703D+01	1	7.92796E-07	1.055000E+00	0.0	0.0	0.0	2	6.70810E-08	25	3	7.1376E-01	24	3	5.4176E-01
372	3.10703D+01	1	6.48941E-08	1.055000E+00	0.0	0.0	0.0	11	8.52868E+01	13	8	6.3132E+01	13	8	6.3132E+01
372	3.10703D+01	1	1.7.60354D+01	1.055000E+00	0.0	0.0	0.0	21	8.80536E+01	24	1	0.1119E+02	24	1	0.1119E+02
372	3.10703D+01	1	1.7.60354D+01	1.055000E+00	0.0	0.0	0.0	19	8.80873E+01	24	1	0.1119E+02	24	1	0.1119E+02
373	3.10850D+01	1	8.06081E-07	1.055000E+00	0.0	0.0	0.0	1	1.29669E-06	25	4	0.7917E-01	24	3	8.8992E-01
373	3.10850D+01	1	8.06081E-07	1.055000E+00	0.0	0.0	0.0	2	6.97517E-08	25	4	0.7917E-01	24	3	8.8992E-01
373	3.10850D+01	1	6.64739E-08	1.055000E+00	0.0	0.0	0.0	11	8.52864E+01	13	8	6.3126E+01	13	8	6.3126E+01
373	3.10850D+01	1	1.7.60354D+01	1.055000E+00	0.0	0.0	0.0	21	8.80552E+01	24	1	0.1512E+02	24	1	0.1512E+02
373	3.10850D+01	1	1.7.60354D+01	1.055000E+00	0.0	0.0	0.0	19	8.80850E+01	24	1	0.1512E+02	24	1	0.1512E+02
374	3.11011D+01	1	7.92766E-07	1.055000E+00	0.0	0.0	0.0	1	1.39540E-06	25	4	4.8191E-01	24	4	2.7011E-01
374	3.11011D+01	1	7.92766E-07	1.055000E+00	0.0	0.0	0.0	2	6.94535E-08	25	4	4.8191E-01	24	4	2.7011E-01
374	3.11011D+01	1	6.30648E-08	1.055000E+00	0.0	0.0	0.0	11	8.52859E+01	13	8	6.3120E+01	13	8	6.3120E+01
374	3.11011D+01	1	1.7.60352D+01	1.055000E+00	0.0	0.0	0.0	21	8.80570E+01	24	1	0.946E+02	24	1	0.946E+02
374	3.11011D+01	1	1.7.60352D+01	1.055000E+00	0.0	0.0	0.0	19	8.80846E+01	24	1	0.946E+02	24	1	0.946E+02
375	3.11188D+01	1	8.38929E-07	1.055000E+00	0.0	0.0	0.0	1	1.55162E-06	25	4	9.2470E-01	24	4	6.8485E-01
375	3.11188D+01	1	8.38929E-07	1.055000E+00	0.0	0.0	0.0	2	7.56563E-08	25	4	9.2470E-01	24	4	6.8485E-01
375	3.11188D+01	1	6.86757E-08	1.055000E+00	0.0	0.0	0.0	11	8.52853E+01	13	8	6.3113E+01	13	8	6.3113E+01
375	3.11188D+01	1	1.7.60351D+01	1.055000E+00	0.0	0.0	0.0	21	8.80330E+01	24	1	0.2423E+02	24	1	0.2423E+02
375	3.11188D+01	1	1.7.60351D+01	1.055000E+00	0.0	0.0	0.0	19	8.80830E+01	24	1	0.2423E+02	24	1	0.2423E+02
376	3.11383D+01	1	7.26247E-07	1.055000E+00	0.0	0.0	0.0	1	1.63726E-06	25	5	4.1369E-01	24	5	1.3694E-01
376	3.11383D+01	1	7.26247E-07	1.055000E+00	0.0	0.0	0.0	2	7.15539E-08	25	5	4.1369E-01	24	5	1.3694E-01
376	3.11383D+01	1	5.77529E-08	1.055000E+00	0.0	0.0	0.0	11	8.52847E+01	13	8	6.3103E+01	13	8	6.3103E+01
376	3.11383D+01	1	1.7.60350D+01	1.055000E+00	0.0	0.0	0.0	21	8.80330E+01	24	1	0.6103E+02	24	1	0.6103E+02
376	3.11383D+01	1	1.7.60350D+01	1.055000E+00	0.0	0.0	0.0	19	8.80830E+01	24	1	0.6103E+02	24	1	0.6103E+02

377	3	11597D+01	1 7 89785D-07	1 055000+00	0 0	0 0	0 0	1 1 82619D-06	21 8 80614D+01	24 1 02950D+02
377	3	11597D+01	1 7 89585D-07	1 055000+00	0 0	0 0	0 0	2 7 84263D-08	25 5 95153D-01	24 5 62927D-01
377	3	11597D+01	1 6 45591D-08	1 055000+00	0 0	0 0	0 0	13 8 63091D+01	21 8 80641D+01	24 1 03529D+02
377	3	1160D+01	1 7 60349D+01	3 8 07382D+01	3 8 07382D+01	19 8 80795D+01	5 8 25049D+01	21 8 80641D+01	24 1 03529D+02	
378	3	1183D+01	1 7 60347D+01	3 8 07377D+01	3 8 07377D+01	19 8 80795D+01	5 8 25049D+01	21 8 80641D+01	24 1 03529D+02	
378	3	1183D+01	1 7 60347D+01	3 8 07377D+01	3 8 07377D+01	19 8 80795D+01	5 8 25049D+01	21 8 80641D+01	24 1 03529D+02	
378	3	1183D+01	1 7 60347D+01	3 8 07377D+01	3 8 07377D+01	19 8 80795D+01	5 8 25049D+01	21 8 80641D+01	24 1 03529D+02	
379	3	1209D+01	1 7 60345D+01	3 8 07372D+01	3 8 07372D+01	19 8 80795D+01	5 8 25049D+01	21 8 80641D+01	24 1 03529D+02	
379	3	1209D+01	1 7 60345D+01	3 8 07372D+01	3 8 07372D+01	19 8 80795D+01	5 8 25049D+01	21 8 80641D+01	24 1 03529D+02	
379	3	1209D+01	1 7 60345D+01	3 8 07372D+01	3 8 07372D+01	19 8 80795D+01	5 8 25049D+01	21 8 80641D+01	24 1 03529D+02	
380	3	12378D+01	1 2 3891D-06	1 055000+00	0 0	0 0	0 0	1 2 44754D-06	25 7 91172D-01	24 7 37835D-01
380	3	12378D+01	1 2 3891D-06	1 055000+00	0 0	0 0	0 0	2 9 34244D-08	25 7 91172D-01	24 7 37835D-01
380	3	12378D+01	1 2 3891D-06	1 055000+00	0 0	0 0	0 0	13 8 63065D+01	21 8 80745D+01	24 1 06496D+02
380	3	1238D+01	1 7 60344D+01	3 8 07367D+01	3 8 07367D+01	19 8 80795D+01	5 8 25049D+01	21 8 80745D+01	24 1 06496D+02	
381	3	1269D+01	1 4 1304D-06	1 055000+00	0 0	0 0	0 0	1 2 70416D-06	25 8 69998D-01	24 8 06283D-01
381	3	1269D+01	1 4 1304D-06	1 055000+00	0 0	0 0	0 0	2 1 02473D-07	25 8 69998D-01	24 8 06283D-01
381	3	1269D+01	1 7 28818D-08	1 055000+00	0 0	0 0	0 0	13 8 63053D+01	21 8 80790D+01	24 1 06496D+02
381	3	1269D+01	1 7 28818D-08	1 055000+00	0 0	0 0	0 0	24 1 06496D+02	21 8 80790D+01	24 1 06496D+02
382	3	13037D+01	1 6 0072D-06	1 055000+00	0 0	0 0	0 0	1 2 99054D-06	25 9 56623D-01	24 8 80352D-01
382	3	13037D+01	1 6 0072D-06	1 055000+00	0 0	0 0	0 0	2 1 19100D-07	25 9 56623D-01	24 8 80352D-01
382	3	13037D+01	1 9 43231D-08	1 055000+00	0 0	0 0	0 0	13 8 63040D+01	21 8 80790D+01	24 1 06496D+02
382	3	1304D+01	1 7 60339D+01	3 8 07355D+01	3 8 07355D+01	19 8 80795D+01	5 8 25016D+01	21 8 80790D+01	24 1 06496D+02	
383	3	13409D+01	1 1 75680D-06	1 055000+00	0 0	0 0	0 0	1 3 06220D-06	25 1 03240D+00	24 9 42205D-01
383	3	13409D+01	1 1 75680D-06	1 055000+00	0 0	0 0	0 0	2 1 05337D-07	25 1 03240D+00	24 9 42205D-01
383	3	13409D+01	1 1 75680D-06	1 055000+00	0 0	0 0	0 0	13 8 63025D+01	21 8 80899D+01	24 1 08445D+02
383	3	13409D+01	1 1 75680D-06	1 055000+00	0 0	0 0	0 0	24 1 08445D+02	21 8 80899D+01	24 1 08445D+02
384	3	13785D+01	1 2 80824D-06	1 055000+00	0 0	0 0	0 0	1 2 75300D-06	25 1 04316D+00	24 9 41838D-01
384	3	13785D+01	1 2 80824D-06	1 055000+00	0 0	0 0	0 0	2 2 61641D-07	25 1 04316D+00	24 9 41838D-01
384	3	13785D+01	1 4 27381D-07	1 055000+00	0 0	0 0	0 0	13 8 63010D+01	21 8 80960D+01	24 1 09467D+02
384	3	1378D+01	1 7 60334D+01	3 8 07341D+01	3 8 07341D+01	19 8 80619D+01	5 8 24938D+01	21 8 80960D+01	24 1 09467D+02	
385	3	14164D+01	1 1 31350D-06	1 055000+00	0 0	0 0	0 0	1 3 30209D-06	25 1 05337D+00	24 9 42020D-01
385	3	14164D+01	1 1 31350D-06	1 055000+00	0 0	0 0	0 0	2 1 46792D-07	25 1 05337D+00	24 9 42020D-01
385	3	14164D+01	1 9 6671D-07	1 055000+00	0 0	0 0	0 0	13 8 62995D+01	21 8 81024D+01	24 1 10498D+02
385	3	1416D+01	1 7 60332D+01	3 8 07334D+01	3 8 07334D+01	19 8 80591D+01	5 8 24989D+01	21 8 81024D+01	24 1 10498D+02	
386	3	14546D+01	1 1 0981D-06	1 055000+00	0 0	0 0	0 0	1 2 97409D-06	25 1 06292D+00	24 9 42039D-01
386	3	14546D+01	1 1 0981D-06	1 055000+00	0 0	0 0	0 0	2 8 88321D-08	25 1 06292D+00	24 9 42039D-01
386	3	14546D+01	1 8 10888D-08	1 055000+00	0 0	0 0	0 0	13 8 62979D+01	21 8 81091D+01	24 1 11539D+02
386	3	14546D+01	1 8 10888D-08	1 055000+00	0 0	0 0	0 0	24 1 11539D+02	21 8 81091D+01	24 1 11539D+02
387	3	14931D+01	1 1 01453D-06	1 055000+00	0 0	0 0	0 0	1 2 60744D-06	25 1 07196D-00	24 9 41922D-01
387	3	14931D+01	1 1 01453D-06	1 055000+00	0 0	0 0	0 0	2 7 28743D-08	25 1 07196D-00	24 9 41922D-01
387	3	14931D+01	1 6 8357D-08	1 055000+00	0 0	0 0	0 0	13 8 62964D+01	21 8 81024D+01	24 1 10498D+02
387	3	14931D+01	1 6 8357D-08	1 055000+00	0 0	0 0	0 0	24 1 10498D+02	21 8 81024D+01	24 1 10498D+02
388	3	1493D+01	1 7 60327D+01	3 8 07319D+01	3 8 07319D+01	19 8 80554D+01	5 8 24970D+01	21 8 81024D+01	24 1 10498D+02	



399	3	200000+01	15 8 712590+01	17 8 773103+01	19 8 802830+01	21 8 821700+01	24 1 247700+02
			25 1 252410+02				
399	3	200000+01	1 2 395280-05	1 055000+00	0 0	0 0	
399	3	200000+01	2 2 111120-06	1 055000+00	0 0	0 0	
399	3	200000+01	1 1 655510-06	1 055000+00	0 0	0 0	
399	3	199230+01	1 1 162430-05	1 055000+00	0 0	0 0	
399	3	199230+01	2 1 048110-06	1 055000+00	0 0	0 0	
399	3	199230+01	1 6 458340-07	1 055000+00	0 0	0 0	
399	3	199230+01	1 7 602930+01	3 8 012230+01	5 8 248490+01	11 8 525720+01	13 8 627590+01
			15 8 712320+01	17 8 772740+01	19 8 802640+01	21 8 822870+01	24 1 259570+03
			25 1 304330+02				
400	3	200230+01	1 4 587520-06	1 055000+00	0 0	0 0	
400	3	200230+01	1 4 587520-06	1 055000+00	0 0	0 0	
400	3	200230+01	1 4 123140-07	1 055000+00	0 0	0 0	
400	3	20020+01	1 7 602920+01	3 8 072210+01	5 8 248460+01	11 8 525690+01	13 8 627540+01
			15 8 7 2260+01	17 8 772660+01	19 8 802600+01	21 8 823130+01	24 1 262200+02
			25 1 307070+02				

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 400 TIME STEPS, TIME = 3.200230+01

HEATING 04/12/83  
W9XNP110

GROSS GRID	T
1	78103
2	78128
3	80172
4	81150
5	82148
6	82196
7	83144
8	83190
9	84136
10	84181
11	85126
12	85178
13	86128
14	86172
15	87112
16	87146
17	87173
18	87191
19	88103
20	88110
21	88123
22	96173
23	108138
24	126122
25	130171

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	78.644264
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 1.00000000-02

ELAPSED CPU TIME IS 4.78 SECONDS

THE MAXIMUM TEMPERATURE IS 1.307070+02 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES 25

THE MINIMUM TEMPERATURE IS 7.602920+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES 1

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	MODE	MAX PERCENT TEMP CHANGE	
401	3.201230+01	1	6.22750-07	1.055000+00	0.0	0.0	0.0	1	6.417410-07	25	2	2.724320-01	
401	3.201230+01	1	6.227150-07	1.055000+00	0.0	0.0	0.0	2	6.186220-08	25	2	2.724320-01	
401	3.201230+01	1	6.370890-08	1.055000+00	0.0	0.0	0.0	2	6.186220-08	25	2	2.724320-01	
TABLE FOR SPECIAL MONITORING OF TEMPERATURES													
***** NODE NUMBERS AND TEMPERATURES *****													
401	3.20120+01	1	7.602910+01	3.8	0.72190+01	5.8	2.48440+01	11	8	5.75660+01	13	8	6.27500+01
			15.8	7.12200+01	17.8	7.72580+01	19.8	8.02560+01	21.8	8.23400+01	24.1	25.4	2.54820+02
			25	1.309790+02									
402	3.202230+01	1	5.418650-07	1.055000+00	0.0	0.0	0.0	1	5	6.22490-07			
402	3.202230+01	1	5.418650-07	1.055000+00	0.0	0.0	0.0	2	5	4.32350-08	25	2	7.12600-01
402	3.202230+01	1	5.90160-08	1.055000+00	0.0	0.0	0.0	2	5	4.32350-08	25	2	7.12600-01
402	3.202230+01	1	7.60290+01	3.8	0.72170+01	5.8	2.48440+01	11	8	5.75620+01	13	8	6.27460+01
			15.8	7.12140+01	17.8	7.72510+01	19.8	8.02520+01	21.8	8.23370+01	24.1	25.4	2.54820+02
			25	1.312500+02									
403	3.203230+01	1	4.460180-07	1.055000+00	0.0	0.0	0.0	1	4	6.04620-07			
403	3.203230+01	1	4.460180-07	1.055000+00	0.0	0.0	0.0	2	4	3.42690-06	25	2	7.02640-01
403	3.203230+01	1	4.482720-08	1.055000+00	0.0	0.0	0.0	2	4	3.42690-06	25	2	7.02640-01
403	3.20320+01	1	7.60280+01	3.8	0.72150+01	5.8	2.48390+01	11	8	5.25590+01	13	8	6.27420+01
			15.8	7.12080+01	17.8	7.72430+01	19.8	8.02490+01	21.8	8.23330+01	24.1	25.4	2.54820+02
			25	1.315210+02									
404	3.204330+01	1	6.028960-07	1.055000+00	0.0	0.0	0.0	1	5	5.42030-07			
404	3.204330+01	1	6.028960-07	1.055000+00	0.0	0.0	0.0	2	5	5.68910-06	25	2	2.81330-01
404	3.204330+01	1	6.289440-08	1.055000+00	0.0	0.0	0.0	2	5	5.68910-06	25	2	2.81330-01
404	3.20430+01	1	7.60280+01	3.8	0.72130+01	5.8	2.48360+01	11	8	5.25550+01	13	8	6.27370+01
			15.8	7.12010+01	17.8	7.72340+01	19.8	8.02450+01	21.8	8.24230+01	24.1	25.4	2.54820+02
			25	1.318170+02									
405	3.205540+01	1	6.229960-07	1.055000+00	0.0	0.0	0.0	1	5	4.25090-07			
405	3.205540+01	1	6.229960-07	1.055000+00	0.0	0.0	0.0	2	5	3.89000-06	25	3	2.41650-01
405	3.205540+01	1	6.754060-08	1.055000+00	0.0	0.0	0.0	2	5	3.89000-06	25	3	2.41650-01
405	3.20550+01	1	7.60280+01	3.8	0.72100+01	5.8	2.48330+01	11	8	5.25510+01	13	8	6.27320+01
			15.8	7.11940+01	17.8	7.72250+01	19.8	8.02400+01	21.8	8.24560+01	24.1	25.4	2.54820+02
			25	1.321410+02									
406	3.206870+01	1	6.599710-07	1.055000+00	0.0	0.0	0.0	1	5	5.70000-07			
406	3.206870+01	1	6.599710-07	1.055000+00	0.0	0.0	0.0	2	6	1.23530-08	25	3	5.51260-01
406	3.206870+01	1	6.54080-08	1.055000+00	0.0	0.0	0.0	2	6	1.23530-08	25	3	5.51260-01
406	3.20690+01	1	7.60280+01	3.8	0.72070+01	5.8	2.48290+01	11	8	5.25470+01	13	8	6.27260+01
			15.8	7.11860+01	17.8	7.72140+01	19.8	8.02360+01	21.8	8.24920+01	24.1	25.4	2.54820+02
			25	1.324960+02									
407	3.208330+01	1	7.011500-07	1.055000+00	0.0	0.0	0.0	1	6	6.150-07			
407	3.208330+01	1	7.011500-07	1.055000+00	0.0	0.0	0.0	2	6	4.77840-08	25	3	8.91030-01
407	3.208330+01	1	6.77950-08	1.055000+00	0.0	0.0	0.0	2	6	4.77840-08	25	3	8.91030-01
407	3.20830+01	1	7.60280+01	3.8	0.72050+01	5.8	2.48260+01	11	8	5.25420+01	13	8	6.27200+01
			15.8	7.11770+01	17.8	7.72030+01	19.8	8.02310+01	21.8	8.25320+01	24.1	25.4	2.54820+02
			25	1.328550+02									
408	3.209940+01	1	7.099950-07	1.055000+00	0.0	0.0	0.0	1	6	8.31150-07			
408	3.209940+01	1	7.099950-07	1.055000+00	0.0	0.0	0.0	2	6	9.23430-08	25	4	2.64740-01
408	3.209940+01	1	9.674340-08	1.055000+00	0.0	0.0	0.0	2	6	9.23430-08	25	4	2.64740-01
408	3.20990+01	1	7.60280+01	3.8	0.72010+01	5.8	2.48220+01	11	8	5.25370+01	13	8	6.27130+01
			15.8	7.11680+01	17.8	7.71910+01	19.8	8.02250+01	21.8	8.25770+01	24.1	25.4	2.54820+02
			25	1.333110+02									
409	3.211720+01	1	7.452470-07	1.055000+00	0.0	0.0	0.0	1	7	9.23270-07			
409	3.211720+01	1	7.452470-07	1.055000+00	0.0	0.0	0.0	2	7	5.80270-08	25	4	6.75180-01
409	3.211720+01	1	1.00710-07	1.055000+00	0.0	0.0	0.0	2	7	5.80270-08	25	4	6.75180-01
409	3.21170+01	1	7.60280+01	3.8	0.71980+01	5.8	2.48170+01	11	8	5.25310+01	13	8	6.27060+01
			15.8	7.11570+01	17.8	7.71770+01	19.8	8.02190+01	21.8	8.26760+01	24.1	25.4	2.54820+02
			25	1.337790+02									
410	3.213670+01	1	7.705800-07	1.055000+00	0.0	0.0	0.0	1	9	1.20720-07			
410	3.213670+01	1	7.705800-07	1.055000+00	0.0	0.0	0.0	2	7	9.56960-08	25	5	1.26180-01
410	3.213670+01	1	1.91070-07	1.055000+00	0.0	0.0	0.0	2	7	9.56960-08	25	5	1.26180-01
410	3.21370+01	1	7.60280+01	3.8	0.71940+01	5.8	2.48120+01	11	8	5.25240+01	13	8	6.26980+01

411	3. 215810+01	1 8 502930-07 1 055000+00 0 0	17 8 771620+01	19 8 802130+01	21 8 826810+01	24 1 297530+02	
		25 1 342920+02		0 0 0 0			
411	3. 215810+01	1 8 502930-07 1 055000+00 0 0	0 0 0 0	0 0 0 0	1 1 088430-06	25 5 520650 01	24 4 323250-01
411	3. 215810+01	1 8 502930-07 1 055000+00 0 0	0 0 0 0	0 0 0 0	2 9 013430-08	25 5 520650 01	24 4 323250-01
411	3. 215810+01	1 1 395920-07 1 055000+00 0 0	0 0 0 0	0 0 0 0	11 8 525170+01	13 8 626880+01	
411	3. 215810+01	1 7 502800+01	3 8 071900+01	5 8 248070+01	11 8 827440+01	24 1 303140+02	
412	3. 218170+01	15 8 711320+01	17 8 771660+01	19 8 802070+01	21 8 827440+01		
		25 1 348540+02		0 0 0 0			
412	3. 218170+01	1 9 286410-07 1 055000+00 0 0	0 0 0 0	0 0 0 0	1 1 283010-06	25 6 162970-01	24 4 723640-01
412	3. 218170+01	1 9 286410-07 1 055000+00 0 0	0 0 0 0	0 0 0 0	2 1 016320-07	25 6 162970-01	24 4 723640-01
412	3. 218170+01	1 1 520360-07 1 055000+00 0 0	0 0 0 0	0 0 0 0	11 8 525080+01	13 8 626790+01	
412	3. 218170+01	1 7 502790+01	3 8 071850+01	5 8 248010+01	11 8 828090+01	24 1 309300+02	
413	3. 220760+01	15 8 711180+01	17 8 771280+01	19 8 802000+01	21 8 828090+01		
		25 1 354700+02		0 0 0 0			
413	3. 220760+01	1 9 904780-07 1 055000+00 0 0	0 0 0 0	0 0 0 0	1 1 505960-06	25 6 758520-01	24 5 157360-01
413	3. 220760+01	1 9 904780-07 1 055000+00 0 0	0 0 0 0	0 0 0 0	2 1 191640-07	25 6 758520-01	24 5 157360-01
413	3. 220760+01	1 1 994180-07 1 055000+00 0 0	0 0 0 0	0 0 0 0	11 8 525000+01	13 8 626680+01	
413	3. 220760+01	1 7 502770+01	3 8 071800+01	5 8 247940+01	11 8 828840+01	24 1 316050+02	
414	3. 223610+01	15 8 711020+01	17 8 771080+01	19 8 801930+01	21 8 828840+01		
		25 1 361460+02		0 0 0 0			
414	3. 223610+01	1 1 139510-06 1 055000+00 0 0	0 0 0 0	0 0 0 0	1 1 807140-06	24 5 626720-01	
414	3. 223610+01	1 1 139510-06 1 055000+00 0 0	0 0 0 0	0 0 0 0	2 1 416570-07	25 7 410560-01	24 5 626720-01
414	3. 223610+01	1 2 438020-07 1 055000+00 0 0	0 0 0 0	0 0 0 0	11 8 524910+01	13 8 626560+01	
414	3. 223610+01	1 7 502750+01	3 8 071740+01	5 8 247870+01	11 8 829670+01	24 1 323450+02	
415	3. 226750+01	15 8 710850+01	17 8 770860+01	19 8 801860+01	21 8 829670+01		
		25 1 368870+02		0 0 0 0			
415	3. 226750+01	1 1 329550-06 1 055000+00 0 0	0 0 0 0	0 0 0 0	1 2 119950-06	25 8 125970-01	24 6 134170-01
415	3. 226750+01	1 1 329550-06 1 055000+00 0 0	0 0 0 0	0 0 0 0	2 1 716850-07	25 8 125970-01	24 6 134170-01
415	3. 226750+01	1 3 120280-07 1 055000+00 0 0	0 0 0 0	0 0 0 0	11 8 524800+01	13 8 626420+01	
415	3. 226750+01	1 7 502730+01	3 8 071680+01	5 8 247790+01	11 8 830600+01	24 1 331570+02	
416	3. 230200+01	15 8 710660+01	17 8 770630+01	19 8 801790+01	21 8 830600+01		
		25 1 376390+02		0 0 0 0			
416	3. 230200+01	1 1 756360-06 1 055000+00 0 0	0 0 0 0	0 0 0 0	1 2 522320-06	25 8 909220-01	24 6 682290-01
416	3. 230200+01	1 1 756360-06 1 055000+00 0 0	0 0 0 0	0 0 0 0	2 2 130080-07	25 8 909220-01	24 6 682290-01
416	3. 230200+01	1 4 055020-07 1 055000+00 0 0	0 0 0 0	0 0 0 0	11 8 524680+01	13 8 626280+01	
416	3. 230200+01	1 7 502700+01	3 8 071610+01	5 8 247700+01	11 8 831640+01	24 1 340470+02	
417	3. 234000+01	15 8 710480+01	17 8 770370+01	19 8 801720+01	21 8 831640+01		
		25 1 385900+02		0 0 0 0			
417	3. 234000+01	1 2 323540-06 1 055000+00 0 0	0 0 0 0	0 0 0 0	1 2 991310-06	25 9 766230-01	24 7 273609-01
417	3. 234000+01	1 2 323540-06 1 055000+00 0 0	0 0 0 0	0 0 0 0	2 2 560290-07	25 9 766230-01	24 7 273609-01
417	3. 234000+01	1 4 961320-07 1 055000+00 0 0	0 0 0 0	0 0 0 0	11 8 524550+01	13 8 626160+01	
417	3. 234000+01	1 7 502680+01	3 8 071530+01	5 8 247610+01	11 8 832800+01	24 1 350220+02	
418	3. 238180+01	15 8 710320+01	17 8 770090+01	19 8 801650+01	21 8 832800+01		
		25 1 395670+02		0 0 0 0			
418	3. 238180+01	1 3 230980-06 1 055000+00 0 0	0 0 0 0	0 0 0 0	1 3 580390-06	25 1 070280+00	24 7 510480-01
418	3. 238180+01	1 3 230980-06 1 055000+00 0 0	0 0 0 0	0 0 0 0	2 3 344580-07	25 1 070280+00	24 7 510480-01
418	3. 238180+01	1 6 918050-07 1 055000+00 0 0	0 0 0 0	0 0 0 0	11 8 524410+01	13 8 625940+01	
418	3. 238180+01	1 7 502650+01	3 8 071440+01	5 8 247500+01	11 8 834090+01	24 1 360960+02	
419	3. 242770+01	15 8 709980+01	17 8 769780+01	19 8 801580+01	21 8 834090+01		
		25 1 406370+02		0 0 0 0			
419	3. 242770+01	1 4 195040-06 1 055000+00 0 0	0 0 0 0	0 0 0 0	1 4 214200-06	25 1 172770+00	24 8 595540-01
419	3. 242770+01	1 4 195040-06 1 055000+00 0 0	0 0 0 0	0 0 0 0	2 4 195880-07	25 1 172770+00	24 8 595540-01
419	3. 242770+01	1 9 179450-07 1 055000+00 0 0	0 0 0 0	0 0 0 0	11 8 524250+01	13 8 625740+01	
419	3. 242770+01	1 7 502610+01	3 8 071350+01	5 8 24738 401	11 8 835530+01	24 1 372600+02	
420	3. 247830+01	15 8 709700+01	17 8 769450+01	19 8 80152100	21 8 835530+01		
		25 1 418100+02		0 0 0 0			
420	3. 247830+01	1 5 625890-06 1 055000+00 0 0	0 0 0 0	0 0 0 0	1 4 972860-06	25 1 284720+00	24 9 331290-01
420	3. 247830+01	1 5 625890-06 1 055000+00 0 0	0 0 0 0	0 0 0 0	2 5 170930-07	25 1 284720+00	24 9 331290-01
420	3. 247830+01	1 1 157490-06 1 055000+00 0 0	0 0 0 0	0 0 0 0	11 8 524080+01	13 8 625520+01	
420	3. 247830+01	1 7 502580+01	3 8 071250+01	5 8 247250+01	11 8 837150+01	24 1 385410+02	
421	3. 252970+01	15 8 709400+01	17 8 769080+01	19 8 801470+01	21 8 837150+01		
		25 1 430950+02		0 0 0 0			
421	3. 252970+01	1 6 452550-06 1 055000+00 0 0	0 0 0 0	0 0 0 0	1 5 345100-06	25 1 302090+00	24 9 367690-01
421	3. 252970+01	1 6 452550-06 1 055000+00 0 0	0 0 0 0	0 0 0 0	2 5 668110-07	25 1 302090+00	24 9 367690-01
421	3. 252970+01	1 1 296120-06 1 055000+00 0 0	0 0 0 0	0 0 0 0	11 8 523970+01	13 8 625300+01	
421	3. 252970+01	1 7 502540+01	3 8 071140+01	5 8 247120+01	11 8 837900+01	24 1 395300+01	

422	3.258190+01	15 8.709090+01	17 8.768710+01	19 8.801430+01	21 8.838820+01	24 1.398390+02
		25 1.443970+02				
422	3.258190+01	1 9.283840-05	1 0.550000+00	0 0	0 0	1 2.568660-05
422	3.258190+01	2 7.843940-06	1 0.550000+00	0 0	0 0	2 1.911590-06
422	3.258190+01	1 6.371180-06	1 0.550000+00	0 0	0 0	2 1.911590-06
422	3.258190+01	1 7.602500+01	3 8.071040+01	5 8.246980+01	11 8.523720+01	13 8.625080+01
422	3.258190+01	15 8.708780+01	17 8.768350+01	19 8.801410+01	21 8.840550+01	24 1.411390+02
		25 1.456540+02				
423	3.263520+01	1 5.295860-05	1 0.550000+00	0 0	0 0	1 2.280470-05
423	3.263520+01	2 4.865020-06	1 0.550000+00	0 0	0 0	2 1.229570-06
423	3.263520+01	1 4.270940-06	1 0.550000+00	0 0	0 0	2 1.229570-06
423	3.263520+01	1 7.602460+01	3 8.070930+01	5 8.246840+01	11 8.523540+01	13 8.624850+01
423	3.263520+01	15 8.708460+01	17 8.767980+01	19 8.801420+01	21 8.842340+01	24 1.424400+02
		25 1.466980+02				
424	3.269020+01	1 3.592340-05	1 0.550000+00	0 0	0 0	1 2.194980-05
424	3.269020+01	2 3.559090-06	1 0.550000+00	0 0	0 0	2 9.316090-07
424	3.269020+01	1 3.407330-06	1 0.550000+00	0 0	0 0	2 9.316090-07
424	3.269020+01	1 7.602420+01	3 8.070810+01	5 8.246700+01	11 8.523350+01	13 8.624610+01
424	3.269020+01	15 8.708130+01	17 8.767600+01	19 8.801440+01	21 8.844210+01	24 1.437500+02
		25 1.481500+02				
425	3.274690+01	1 2.932980-05	1 0.550000+00	0 0	0 0	1 2.183680-05
425	3.274690+01	2 3.005580-06	1 0.550000+00	0 0	0 0	2 8.033840-07
425	3.274690+01	1 3.079980-06	1 0.550000+00	0 0	0 0	2 8.033840-07
425	3.274690+01	1 7.602380+01	3 8.070680+01	5 8.246550+01	11 8.523150+01	13 8.624360+01
425	3.274690+01	15 8.707790+01	17 8.767220+01	19 8.801480+01	21 8.845180+01	24 1.450720+02
		25 1.494170+02				
426	3.280550+01	1 2.649270-05	1 0.550000+00	0 0	0 0	1 2.184670-05
426	3.280550+01	2 2.721060-06	1 0.550000+00	0 0	0 0	2 7.328620-07
426	3.280550+01	1 2.924020-06	1 0.550000+00	0 0	0 0	2 7.328620-07
426	3.280550+01	1 7.602340+01	3 8.070570+01	5 8.246400+01	11 8.522940+01	13 8.624110+01
426	3.280550+01	15 8.707240+01	17 8.766830+01	19 8.801540+01	21 8.848240+01	24 1.464070+02
		25 1.507020+02				
427	3.286610+01	1 2.477440-05	1 0.550000+00	0 0	0 0	1 2.171760-05
427	3.286610+01	2 2.512070-06	1 0.550000+00	0 0	0 0	2 6.856350-07
427	3.286610+01	1 2.844800-06	1 0.550000+00	0 0	0 0	2 6.856350-07
427	3.286610+01	1 7.602290+01	3 8.070440+01	5 8.246240+01	11 8.522730+01	13 8.623840+01
427	3.286610+01	15 8.707080+01	17 8.766430+01	19 8.801630+01	21 8.850400+01	24 1.477570+02
		25 1.520080+02				
428	3.292840+01	1 2.380340-05	1 0.550000+00	0 0	0 0	1 2.146660-05
428	3.292840+01	2 2.356740-06	1 0.550000+00	0 0	0 0	2 6.412340-07
428	3.292840+01	1 2.740670-06	1 0.550000+00	0 0	0 0	2 6.412340-07
428	3.292840+01	1 7.602250+01	3 8.070310+01	5 8.246070+01	11 8.522510+01	13 8.623570+01
428	3.292840+01	15 8.706700+01	17 8.766030+01	19 8.801750+01	21 8.852660+01	24 1.491200+02
		25 1.533340+02				
429	3.300000+01	1 4.766470-05	1 0.550000+00	0 0	0 0	1 4.770930-05
429	3.300000+01	2 4.167950-06	1 0.550000+00	0 0	0 0	2 1.128100-06
429	3.300000+01	1 5.438860-06	1 0.550000+00	0 0	0 0	2 1.128100-06
429	3.300000+01	1 1.018810-05	1 0.550000+00	0 0	0 0	1 2.916190-06
429	3.300000+01	2 9.279980-07	1 0.550000+00	0 0	0 0	2 2.227500-07
429	3.300000+01	1 9.720160-07	1 0.550000+00	0 0	0 0	2 2.227500-07
429	3.300000+01	1 7.602200+01	3 8.070170+01	5 8.245890+01	11 8.522700+01	13 8.623280+01
429	3.300000+01	15 8.706310+01	17 8.765620+01	19 8.801910+01	21 8.855080+01	24 1.505400+02
		25 1.547180+02				
430	3.300450+01	1 4.402000-06	1 0.550000+00	0 0	0 0	1 4.740360-06
430	3.300450+01	1 4.402000-06	1 0.550000+00	0 0	0 0	2 4.147600-07
430	3.300450+01	1 4.282600-07	1 0.550000+00	0 0	0 0	2 4.147600-07
430	3.300450+01	1 7.602190+01	3 8.070150+01	5 8.245870+01	11 8.522440+01	13 8.623230+01
430	3.300450+01	15 8.706250+01	17 8.765550+01	19 8.801930+01	21 8.855450+01	24 1.507530+02
		25 1.549390+02				



HEATING6 02/12/83  
MSXNP110

COOPER NUCLEAR STATION CONTROL ROOM CELLS 1-D MODEL

IBM3033/ 0  
20 58 07 11-16-89

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 430 TIME STEPS, TIME = 3.300450+01

GROSS GRID	1
FINE GRID	1
DISTANCE	0.0
1	0.0 76102
2	0.03 78136
3	0.06 80170
4	0.08 81158
5	0.10 82146
6	0.57 82194
7	1.04 83141
8	1.51 83188
9	1.98 84133
10	2.45 84178
11	2.92 85122
12	3.14 85175
13	3.35 86123
14	3.57 86167
15	3.79 87106
16	4.01 87139
17	4.23 87166
18	4.45 87186
19	4.67 88102
20	4.89 88121
21	5.10 88155
22	5.18 105157
23	5.25 125146
24	5.32 150175
25	5.35 154194

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	80.508658
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 1.000000000-02

ELAPSED CPU TIME IS 5.09 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.549390+02 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 25

THE MINIMUM TEMPERATURE IS - 7.602190+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO	MAX HEAT	BETA	L1 WORM OF	RHO	RHO	NO	L1 WORM OF	MAX TEMP	MODE	MAX PERCENT
TIME	ITER	ITER	RESIDUAL	TEMP DIFF	(ITERATION)	(JACOBI)	ITER	TEMP DIFF	CHANGE	TEMP	CHANGE	TEMP
431	3.301450+01	1	7.602180+01	3.8 070130+01	5.8 245840+01	11.8 522700+01	13.8 623180+01					
431	3.301450+01	1	15.8 706190+01	17.8 765490+01	19.8 801960+01	21.8 855820+01	24.1 509660+02					
431	3.301450+01	1	25.1 551580+02									
431	3.301450+01	1	7.031090-07	1.055000+00	0.0	0.0	0.0	1.8 256060-07				
431	3.301450+01	1	7.031090-07	1.055000+00	0.0	0.0	0.0	2.7 272170-08	25.2 190430-01	24.1 413790-01		
431	3.301450+01	1	6.722240-08	1.055000+00	0.0	0.0	0.0					

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
 \*\*\*\*\* NODE NUMBERS AND TEMPERATURES \*\*\*\*\*

NUMBER OF	TIME	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
TIME STEPS		*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
431	3.30150+01	1	7.602180+01	3.8 070130+01	5.8 245840+01	11.8 522700+01	13.8 623180+01					
431	3.30150+01	1	15.8 706190+01	17.8 765490+01	19.8 801960+01	21.8 855820+01	24.1 509660+02					
431	3.30150+01	1	25.1 551580+02									
432	3.302450+01	1	6.254390-07	1.055000+00	0.0	0.0	0.0	1.7 397230-01				
432	3.302450+01	1	6.254390-07	1.055000+00	0.0	0.0	0.0	2.6 620890-08	25.2 174030-01	24.1 412800-01		
432	3.302450+01	1	6.045080-08	1.055000+00	0.0	0.0	0.0	11.8 522170+01	13.8 623150+01			
432	3.30250+01	1	7.602170+01	3.8 070110+01	5.8 245810+01	11.8 522170+01	13.8 623150+01					
432	3.30250+01	1	15.8 706130+01	17.8 765430+01	19.8 801990+01	21.8 856190+01	24.1 511190+02					
432	3.30250+01	1	25.1 553760+02									
433	3.303450+01	1	5.448670-07	1.055000+00	0.0	0.0	0.0	1.6 360290-07				
433	3.303450+01	1	5.448670-07	1.055000+00	0.0	0.0	0.0	2.5 522780-08	25.2 158670-01	24.1 411010-01		
433	3.303450+01	1	4.934270-08	1.055000+00	0.0	0.0	0.0	11.8 522170+01	13.8 623100+01			
433	3.30350+01	1	7.602160+01	3.8 070090+01	5.8 245790+01	11.8 522170+01	13.8 623100+01					
433	3.30350+01	1	15.8 706080+01	17.8 765370+01	19.8 802020+01	21.8 856570+01	24.1 513930+02					
433	3.30350+01	1	25.1 555910+02									
434	3.304550+01	1	6.436390-07	1.055000+00	0.0	0.0	0.0	1.7 118010-07				
434	3.304550+01	1	6.436390-07	1.055000+00	0.0	0.0	0.0	2.6 475320-08	25.2 358780-01	24.1 549290-01		
434	3.304550+01	1	6.247430-08	1.055000+00	0.0	0.0	0.0	11.8 522090+01	13.8 623050+01			
434	3.30460+01	1	7.602150+01	3.8 070060+01	5.8 245760+01	11.8 522090+01	13.8 623050+01					
434	3.30460+01	1	15.8 706010+01	17.8 765300+01	19.8 802050+01	21.8 856970+01	24.1 516270+02					
434	3.30460+01	1	25.1 558270+02									
435	3.305760+01	1	6.813630-07	1.055000+00	0.0	0.0	0.0	1.8 190040-07				
435	3.305760+01	1	6.813630-07	1.055000+00	0.0	0.0	0.0	2.6 850610-08	24.2 577540-01	24.1 699920-01		
435	3.305760+01	1	6.988860-08	1.055000+00	0.0	0.0	0.0	11.8 522050+01	13.8 623000+01			
435	3.30580+01	1	7.602140+01	3.8 070040+01	5.8 245720+01	11.8 522050+01	13.8 623000+01					
435	3.30580+01	1	15.8 705940+01	17.8 765230+01	19.8 802080+01	21.8 857130+01	24.1 518850+02					
435	3.30580+01	1	25.1 560850+02									
436	3.307100+01	1	7.205960-07	1.055000+00	0.0	0.0	0.0	1.9 456290-07				
436	3.307100+01	1	7.205960-07	1.055000+00	0.0	0.0	0.0	2.7 192470-08	24.2 830810-01	24.1 863780-01		
436	3.307100+01	1	7.798680-08	1.055000+00	0.0	0.0	0.0	11.8 522000+01	13.8 622940+01			
436	3.30710+01	1	7.602130+01	3.8 070010+01	5.8 245690+01	11.8 522000+01	13.8 622940+01					
436	3.30710+01	1	15.8 705860+01	17.8 765150+01	19.8 802120+01	21.8 857920+01	24.1 521580+02					
436	3.30710+01	1	25.1 563670+02									
437	3.308560+01	1	7.712550-07	1.055000+00	0.0	0.0	0.0	1.1 101090-06				
437	3.308560+01	1	7.712550-07	1.055000+00	0.0	0.0	0.0	2.7 861720-08	24.3 106990-01	24.2 041810-01		
437	3.308560+01	1	9.204540-08	1.055000+00	0.0	0.0	0.0	11.8 521950+01	13.8 622880+01			
437	3.30860+01	1	7.602120+01	3.8 069980+01	5.8 245650+01	11.8 521950+01	13.8 622880+01					
437	3.30860+01	1	15.8 705770+01	17.8 765060+01	19.8 802170+01	21.8 858470+01	24.1 524790+02					
437	3.30860+01	1	25.1 566740+02									
438	3.310170+01	1	7.773420-07	1.055000+00	0.0	0.0	0.0	1.1 248490-06				
438	3.310170+01	1	7.773420-07	1.055000+00	0.0	0.0	0.0	2.7 465190-08	24.3 408000-01	24.2 235070-01		
438	3.310170+01	1	9.262420-08	1.055000+00	0.0	0.0	0.0	11.8 521890+01	13.8 622810+01			
438	3.31020+01	1	7.602110+01	3.8 069940+01	5.8 245610+01	11.8 521890+01	13.8 622810+01					
438	3.31020+01	1	15.8 705680+01	17.8 764960+01	19.8 802220+01	21.8 859080+01	24.1 528190+02					
438	3.31020+01	1	25.1 570110+02									
439	3.311940+01	1	8.251870-07	1.055000+00	0.0	0.0	0.0	1.1 449870-06				
439	3.311940+01	1	8.251870-07	1.055000+00	0.0	0.0	0.0	2.7 844690-08	24.3 735890-01	24.2 444640-01		
439	3.311940+01	1	1.063140-07	1.055000+00	0.0	0.0	0.0	11.8 521830+01	13.8 622730+01			
439	3.31190+01	1	7.602090+01	3.8 069900+01	5.8 245560+01	11.8 521830+01	13.8 622730+01					
439	3.31190+01	1	15.8 705570+01	17.8 764860+01	19.8 802280+01	21.8 859740+01	24.1 531930+02					
439	3.31190+01	1	25.1 573790+02									
440	3.313890+01	1	8.739020-07	1.055000+00	0.0	0.0	0.0	1.1 679950-06				
440	3.313890+01	1	8.739020-07	1.055000+00	0.0	0.0	0.0	2.8 539700-08	24.4 092900-01	24.2 671730-01		
440	3.313890+01	1	1.288920-07	1.055000+00	0.0	0.0	0.0	11.8 521760+01	13.8 622640+01			
440	3.31390+01	1	7.602080+01	3.8 069860+01	5.8 245500+01	11.8 521760+01	13.8 622640+01					
440	3.31390+01	1	15.8 705570+01	17.8 764860+01	19.8 802280+01	21.8 859740+01	24.1 531930+02					
440	3.31390+01	1	25.1 573790+02									

441	3.316030+01	1	9.744820-07	1	055000+00	0.0	0.0	0.0	0.0	1 1 975970-06	24 4 481480-01	24 2 917580-01
441	3.316030+01	1	9.744820-07	1	055000+00	0.0	0.0	0.0	0.0	2 9 503320-08	24 4 481480-01	24 2 917580-01
441	3.316030+01	1	5.205200-07	1	055000+00	0.0	0.0	0.0	0.0	11 8 521680+01	13 8 622550+01	
441	3.316030+01	1	1.760200+01	3	069820+01	0.0	0.0	0.0	0.0	21 8 861290+01	24 1 540500+02	
442	3.318390+01	1	1.034380-06	1	055000+00	0.0	0.0	0.0	0.0	1 2 281010-06		24 3 183590-01
442	3.318390+01	1	1.034380-06	1	055000+00	0.0	0.0	0.0	0.0	2 1 026680-07	24 4 804340-01	
442	3.318390+01	1	1.859220-07	1	055000+00	0.0	0.0	0.0	0.0	11 8 521590+01	13 8 622480+01	
442	3.318390+01	1	1.760200+01	3	069770+01	0.0	0.0	0.0	0.0	21 8 862280+01	24 1 545410+02	
443	3.320990+01	1	1.089230-06	1	055000+00	0.0	0.0	0.0	0.0	1 2 610920-06		24 3 471300-01
443	3.320990+01	1	1.089230-06	1	055000+00	0.0	0.0	0.0	0.0	2 1 116410-07	24 5 364580-01	
443	3.320990+01	1	2.166500-07	1	055000+00	0.0	0.0	0.0	0.0	11 8 521500+01	13 8 622330+01	
443	3.32100+01	1	1.760200+01	3	069710+01	0.0	0.0	0.0	0.0	21 8 863170+01	24 1 550770+02	
444	3.32380+01	1	1.282760-06	1	055000+00	0.0	0.0	0.0	0.0	1 3 085290-06		24 3 782740-01
444	3.32380+01	1	1.282760-06	1	055000+00	0.0	0.0	0.0	0.0	2 1 410570-07	24 5 665410-01	
444	3.32380+01	1	2.871420-07	1	055000+00	0.0	0.0	0.0	0.0	11 8 521400+01	13 8 622200+01	
444	3.32380+01	1	1.760200+01	3	069650+01	0.0	0.0	0.0	0.0	21 8 864260+01	24 1 556640+02	
445	3.326980+01	1	1.365940-06	1	055000+00	0.0	0.0	0.0	0.0	1 3 528200-06		24 4 481010-01
445	3.326980+01	1	1.365940-06	1	055000+00	0.0	0.0	0.0	0.0	2 1 672300-07	24 6 410580-01	
445	3.326980+01	1	3.489930-07	1	055000+00	0.0	0.0	0.0	0.0	11 8 521280+01	13 8 622060+01	
445	3.32700+01	1	1.760190+01	3	069580+01	0.0	0.0	0.0	0.0	21 8 865470+01	24 1 563030+02	
446	3.330430+01	1	1.548550-06	1	055000+00	0.0	0.0	0.0	0.0	1 4 089370-06		24 4 481010-01
446	3.330430+01	1	1.548550-06	1	055000+00	0.0	0.0	0.0	0.0	2 2 130420-07	24 7 004050-01	
446	3.330430+01	1	4.546000-07	1	055000+00	0.0	0.0	0.0	0.0	11 8 521160+01	13 8 621910+01	
446	3.330430+01	1	1.760190+01	3	069500+01	0.0	0.0	0.0	0.0	21 8 866800+01	24 1 570050+02	
447	3.334230+01	1	2.242820-06	1	055000+00	0.0	0.0	0.0	0.0	1 4 718590-06		24 4 872580-01
447	3.334230+01	1	2.242820-06	1	055000+00	0.0	0.0	0.0	0.0	2 2 692280-07	24 7 650220-01	
447	3.334230+01	1	5.868280-07	1	055000+00	0.0	0.0	0.0	0.0	11 8 521020+01	13 8 621740+01	
447	3.33420+01	1	1.760190+01	3	069420+01	0.0	0.0	0.0	0.0	21 8 868270+01	24 1 577700+02	
448	3.33840+01	1	2.850250-06	1	055000+00	0.0	0.0	0.0	0.0	1 5 377640-06		24 5 295020-01
448	3.33840+01	1	2.850250-06	1	055000+00	0.0	0.0	0.0	0.0	2 3 271310-07	24 8 353980-01	
448	3.33840+01	1	1.760190+01	3	069330+01	0.0	0.0	0.0	0.0	11 8 520870+01	13 8 621550+01	
448	3.33840+01	1	15.8704020+01	17	763360+01	0.0	0.0	0.0	0.0	21 8 869890+01	24 1 586060+02	
449	3.34300+01	1	3.911590-06	1	055000+00	0.0	0.0	0.0	0.0	1 6 159250-06		24 5 750420-01
449	3.34300+01	1	3.911590-06	1	055000+00	0.0	0.0	0.0	0.0	2 4 115680-07	24 9 120430-01	
449	3.34300+01	1	9.257320-07	1	055000+00	0.0	0.0	0.0	0.0	11 8 520700+01	13 8 621340+01	
449	3.34300+01	1	1.760190+01	3	069230+01	0.0	0.0	0.0	0.0	21 8 871690+01	24 1 595180+02	
450	3.348050+01	1	4.785710-06	1	055000+00	0.0	0.0	0.0	0.0	1 6 922010-06		24 6 241220-01
450	3.348050+01	1	4.785710-06	1	055000+00	0.0	0.0	0.0	0.0	2 5 010800-07	24 9 955850-01	
450	3.348050+01	1	1.165910-06	1	055000+00	0.0	0.0	0.0	0.0	11 8 520510+01	13 8 621120+01	
450	3.34810+01	1	1.7601820+01	3	069120+01	0.0	0.0	0.0	0.0	21 8 873580+01	24 1 605130+02	
451	3.353610+01	1	2.861250-05	1	055000+00	0.0	0.0	0.0	0.0	1 1 304180-05		24 6 752710-01
451	3.353610+01	1	2.460360-06	1	055000+00	0.0	0.0	0.0	0.0	2 4 648240-07	24 1 083900+00	
451	3.353610+01	1	4.399370-06	1	055000+00	0.0	0.0	0.0	0.0	11 8 520310+01	13 8 620870+01	
451	3.353610+01	1	1.7601780+01	3	069000+01	0.0	0.0	0.0	0.0	21 8 874430+01	24 1 605130+02	

15	8	203140+01	17	8	762570+01	19	8	804220+01	21	8	875870+01	24	1	515970+02
25	1	556750+02												
452	3	359730+01	1	1	759340-C4	1	055000+00	0	0	0	0	0	0	
452	3	359730+01	3	2	088010-C6	1	055000+00	0	0	0	0	0	0	
452	3	359730+01	2	1	471970-C6	1	055000+00	0	0	0	0	0	0	
452	3	35970+01	1	1	750170+01	3	8	068860+01	11	8	520090+01	13	8	620590+01
452	3	35970+01	15	8	702790+01	17	8	762270+01	19	8	804590+01	21	8	878300+01
452	3	35970+01	25	1	567300+02									
453	3	366460+01	1	1	135520-04	1	055000+00	0	0	0	0	0	0	
453	3	366460+01	2	9	438670-06	1	055000+00	0	0	0	0	0	0	
453	3	366460+01	2	1	159190-06	1	055000+00	0	0	0	0	0	0	
453	3	36650+01	1	1	750160+01	3	8	068710+01	5	8	244060+01	11	8	519830+01
453	3	36650+01	15	8	702400+01	17	8	761940+01	19	8	805030+01	21	8	880980+01
453	3	36650+01	25	1	678120+02									
454	3	373860+01	1	9	124300-05	1	055000+00	0	0	0	0	0	0	
454	3	373860+01	2	7	368480-06	1	055000+00	0	0	0	0	0	0	
454	3	373860+01	2	1	210770-06	1	055000+00	0	0	0	0	0	0	
454	3	37390+01	1	1	750160+01	3	8	068550+01	5	8	243850+01	11	8	519560+01
454	3	37390+01	15	8	701980+01	17	8	761600+01	19	8	805540+01	21	8	883950+01
454	3	37390+01	25	1	589400+02									
455	3	382000+01	1	8	999810-05	1	055000+00	0	0	0	0	0	0	
455	3	382000+01	2	7	688580-06	1	055000+00	0	0	0	0	0	0	
455	3	382000+01	2	1	429240-06	1	055000+00	0	0	0	0	0	0	
455	3	38200+01	1	1	7501560+01	3	8	068370+01	5	8	243620+01	11	8	519250+01
455	3	38200+01	15	8	701520+01	17	8	761240+01	19	8	806130+01	21	8	887230+01
455	3	38200+01	25	1	701210+02									
456	3	390950+01	1	9	513950-05	1	055000+00	0	0	0	0	0	0	
456	3	390950+01	2	9	024400-06	1	055000+00	0	0	0	0	0	0	
456	3	390950+01	2	1	761890-06	1	055000+00	0	0	0	0	0	0	
456	3	39100+01	1	1	7501490+01	3	8	068170+01	5	8	243370+01	11	8	518920+01
456	3	39100+01	15	8	701020+01	17	8	760870+01	19	8	806830+01	21	8	890860+01
456	3	39100+01	25	1	713660+02									
457	3	400000+01	1	6	923170-05	1	055000+00	0	0	0	0	0	0	
457	3	400000+01	2	6	468110-06	1	055000+00	0	0	0	0	0	0	
457	3	400000+01	2	1	362310-06	1	055000+00	0	0	0	0	0	0	
457	3	40000+01	1	1	7501420+01	3	8	067960+01	5	8	243110+01	11	8	518580+01
457	3	40000+01	15	8	700520+01	17	8	760510+01	19	8	807580+01	21	8	894530+01
457	3	40000+01	25	1	725820+02									

HEATING6 02/12/83  
 W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

TRM0033/ 0  
 20 58 08 11-16-89

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 457 TIME STEPS, TIME = 3.400000+01

GROSS GRID	FINE GRID	DISTANCE	TEMPERATURE
1	1	0.0	76101
2	2	0.03	78195
3	3	0.06	80168
4	4	0.08	81156
5	5	0.10	82143
6	6	0.57	82191
7	7	1.04	83138
8	8	1.51	83185
9	9	1.98	84130
10	10	2.45	84175
11	11	2.92	85119
12	12	3.14	85171
13	13	3.35	86119
14	14	3.57	86162
15	15	3.79	87101
16	16	4.01	87133
17	17	4.23	87161
18	18	4.45	87184
19	19	4.67	88108
20	20	4.89	88140
21	21	5.10	88195
22	22	5.18	112192
23	23	5.25	139109
24	24	5.32	169116
25	25	5.35	172158

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	82.670000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 9.04838561D-02

ELAPSED CPU TIME IS 5.37 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.72582D+02 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 25

THE MINIMUM TEMPERATURE IS - 7.60142D+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO	MAX HEAT	BETA	L1 NORM OF	RHO	RHO	NO	L1 NORM OF	MAX TEMP	MODE	MAX PERCENT
TIME	RESIDUAL	ITER	RESIDUAL	TEMP DIFF	TEMP DIFF	(ITERATION)	(JACOBI)	ITER	TEMP DIFF	CHANGE		TEMP CHANGE
458	3.409950+01	1	9.051920-05	1.055000+00	0.0	0.0	0.0	1	5.390750-05	24	8	0.38070-01
458	3.409950+01	3	1.365350-06	1.055000+00	0.0	0.0	0.0	2	2.118540-06	24	8	0.38070-01
458	3.409950+01	2	1.943710-06	1.055000+00	0.0	0.0	0.0					

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NUMBER OF	TIME	NO	MAX HEAT	BETA	L1 NORM OF	RHO	RHO	NO	L1 NORM OF	MAX TEMP	MODE	MAX PERCENT
TIME STEPS	RESIDUAL	ITER	RESIDUAL	TEMP DIFF	TEMP DIFF	(ITERATION)	(JACOBI)	ITER	TEMP DIFF	CHANGE		TEMP CHANGE
458	3.41000+01	1	7.601340+01	3.8067730+01	5.8242820+01	11.8518200+01	13.8618320+01					
			15.8699970+01	17.8760140+01	19.8808460+01	21.8898570+01	24.1705190+02					
			25.1738730+02									
459	3.420900+01	1	9.142600-05	1.055000+00	0.0	0.0	0.0	1	5.548550-05	24	8	4.11990-01
459	3.420900+01	3	1.606670-06	1.055000+00	0.0	0.0	0.0	2	2.120520-06	24	8	4.11990-01
459	3.420900+01	2	2.231370-06	1.055000+00	0.0	0.0	0.0					
459	3.420900+01	1	7.601250+01	3.8067480+01	5.8242510+01	11.8517780+01	13.8617820+01					
			15.8699380+01	17.8759760+01	19.8809480+01	21.8903000+01	24.1719530+02					
			25.1752520+02									
460	3.432950+01	1	9.655940-05	1.055000+00	0.0	0.0	0.0	1	5.626200-05	24	8	8.39670-01
460	3.432950+01	3	2.022150-06	1.055000+00	0.0	0.0	0.0	2	2.209050-06	24	8	8.39670-01
460	3.432950+01	2	2.658910-06	1.055000+00	0.0	0.0	0.0					
460	3.432900+01	1	7.601160+01	3.8067210+01	5.8242160+01	11.8517320+01	13.8617270+01					
			15.8698730+01	17.8759380+01	19.8810670+01	21.8907860+01	24.1734730+02					
			25.1767280+02									
461	3.445890+01	1	8.629260-05	1.055000+00	0.0	0.0	0.0	1	5.294380-05	24	8	12.230-01
461	3.445890+01	3	2.025880-06	1.055000+00	0.0	0.0	0.0	2	2.976800-06	24	8	12.230-01
461	3.445890+01	2	2.632110-06	1.055000+00	0.0	0.0	0.0					
461	3.445890+01	1	7.601050+01	3.8066910+01	5.8241780+01	11.8516870+01	13.8616680+01					
			15.8698050+01	17.8759020+01	19.8812030+01	21.8913050+01	24.1750560+02					
			25.1782820+02									
462	3.459370+01	1	2.062950-04	1.055000+00	0.0	0.0	0.0	1	6.155580-05	24	8	10.1940-01
462	3.459370+01	3	5.861170-06	1.055000+00	0.0	0.0	0.0	2	4.273430-06	24	8	10.1940-01
462	3.459370+01	2	5.972580-06	1.055000+00	0.0	0.0	0.0					
462	3.459370+01	1	7.600940+01	3.8066590+01	5.8241390+01	11.8516300+01	13.8616060+01					
			15.8697350+01	17.8758690+01	19.8813520+01	21.8918420+01	24.1766490+02					
			25.1798320+02									
463	3.473440+01	1	7.129650-04	1.055000+00	0.0	0.0	0.0	1	1.197710-04	24	8	7.33890-01
463	3.473440+01	4	1.989660-06	1.055000+00	0.0	0.0	0.0	2	1.434440-05	24	8	7.33890-01
463	3.473440+01	3	4.001050-06	1.055000+00	0.0	0.0	0.0					
463	3.473440+01	2	3.624440-06	1.055000+00	0.0	0.0	0.0	3	2.456740-06	24	8	7.33890-01
463	3.47340+01	1	7.600830+01	3.8066260+01	5.8240970+01	11.8515750+01	13.8615420+01					
			15.8696630+01	17.8758330+01	19.8814510+01	21.8923960+01	24.1781920+02					
			25.1812220+02									
464	3.486720+01	1	5.97870-04	1.055000+00	0.0	0.0	0.0	1	7.864540-05	24	8	4.52970-01
464	3.486720+01	3	2.825330-06	1.055000+00	0.0	0.0	0.0	2	3.958130-06	24	8	4.52970-01
464	3.486720+01	2	5.518790-06	1.055000+00	0.0	0.0	0.0					
464	3.486720+01	1	7.600710+01	3.8065950+01	5.8240580+01	11.8515270+01	13.8614810+01					
			15.8695970+01	17.8758160+01	19.8816770+01	21.8929150+01	24.1795200+02					
			25.1824690+02									
465	3.500000+01	1	7.66130-04	1.055000+00	0.0	0.0	0.0	1	6.722660-05	24	8	9.35910-01
465	3.500000+01	3	4.343860-06	1.055000+00	0.0	0.0	0.0	2	3.993700-06	24	8	9.35910-01
465	3.500000+01	2	5.506090-06	1.055000+00	0.0	0.0	0.0					
465	3.500000+01	1	7.600600+01	3.8065630+01	5.8240180+01	11.8514700+01	13.8614200+01					
			15.8695330+01	17.8757980+01	19.8818450+01	21.8934290+01	24.1807650+02					
			25.1836520+02									

HEATING 02/12/83  
W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 465 TIME STEPS, TIME = 3 500000+01

10M033/ 0  
20 58 08 11 16-89

GROSS GRID	1	FINE GRID	0 0	DISTANCE	0 0
1	1	0 0	76101		
2	2	0 03	78133		
3	3	0 06	80166		
4	4	0 08	81153		
5	5	0 10	82140		
6	6	0 57	82188		
7	7	1 04	83135		
8	8	1 51	83181		
9	9	1 98	84127		
10	10	2 45	84171		
11	11	2 92	85115		
12	12	3 14	85167		
13	13	3 35	86114		
14	14	3 57	86157		
15	15	3 79	86195		
16	16	4 01	87129		
17	17	4 23	87158		
18	18	4 45	87186		
19	19	4 67	88118		
20	20	4 89	88164		
21	21	5 10	89134		
22	22	5 18	118102		
23	23	5 25	148114		
24	24	5 32	180176		
25	25	5 35	183165		

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	85.000000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 1.328224790-01

ELAPSED CPU TIME IS 5.48 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.836520+02 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 25

THE MINIMUM TEMPERATURE IS - 7.600600+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO	MAX HEAT	BETA	L 1 NORM OF	RWD	RWD	NO	L 1 NORM OF	MAX TEMP	NO	MAX PERCENT	
TIME	RESIDUAL	ITER	RESIDUAL		TEMP DIFF	(ITERATION)	(JACOBI)	ITER	TEMP DIFF	CHANGE	NODE	TEMP CHANGE	
466	3.51461D+01	1	1.69211D-04	1.055000+00	0.0	0.0	0.0	1	6.50556D-05	24	1.29437D+00	24	7.16070D-01
466	3.51461D+01	3	4.81938D-06	1.055000+00	0.0	0.0	0.0	2	3.77927D-06				
466	3.51461D+01	2	5.93643D-06	1.055000+00	0.0	0.0	0.0						
TABLE FOR SPECIAL MONITORING OF TEMPERATURES													
***** NODE NUMBERS AND TEMPERATURES *****													
466	3.5146D+01	1	7.60048D+01	3.8	0.6528D+01	5.8	2.3974D+01	11	8	5.1413D+01	13	8	5.1354D+01
		15	8	5.9454D+01	17	8	2.5783D+01	19	8	8.2037D+01	21	8	9.1986D+01
		25	1	8.4895D+02									
467	3.53068D+01	1	1.4609D-04	1.055000+00	0.0	0.0	0.0						
467	3.53068D+01	3	4.6972D-06	1.055000+00	0.0	0.0	0.0						
467	3.53068D+01	2	5.88318D-06	1.055000+00	0.0	0.0	0.0						
467	3.5307D+01	1	7.60034D+01	3.8	0.6489D+01	5.8	2.3925D+01	11	8	5.1349D+01	13	8	6.1281D+01
		15	8	5.9390D+01	17	8	7.5773D+01	19	8	8.2255D+01	21	8	9.4597D+01
		25	1	8.6218D+02									
468	3.54836D+01	1	1.3827D-04	1.055000+00	0.0	0.0	0.0						
468	3.54836D+01	3	5.20421D-06	1.055000+00	0.0	0.0	0.0						
468	3.54836D+01	2	6.16144D-06	1.055000+00	0.0	0.0	0.0						
468	3.5484D+01	1	7.60019D+01	3.8	0.6447D+01	5.8	2.3872D+01	11	8	5.1278D+01	13	8	6.1201D+01
		15	8	5.9312D+01	17	8	7.5770D+01	19	8	8.2503D+01	21	8	9.5246D+01
		25	1	8.7635D+02									
469	3.56781D+01	1	2.39095D-04	1.055000+00	0.0	0.0	0.0						
469	3.56781D+01	4	3.4080D-07	1.055000+00	0.0	0.0	0.0						
469	3.56781D+01	3	2.71145D-06	1.055000+00	0.0	0.0	0.0						
469	3.5678D+01	1	7.60003D+01	3.8	0.6399D+01	5.8	2.3812D+01	11	8	5.1200D+01	13	8	6.1113D+01
		15	8	5.9229D+01	17	8	7.5776D+01	19	8	8.2784D+01	21	8	9.5953D+01
		25	1	8.9136D+02									
470	3.58390D+01	1	9.52302D-05	1.055000+00	0.0	0.0	0.0						
470	3.58390D+01	3	3.19631D-06	1.055000+00	0.0	0.0	0.0						
470	3.5839D+01	2	3.8835D-06	1.055000+00	0.0	0.0	0.0						
470	3.5838D+01	1	7.59988D+01	3.8	0.6360D+01	5.8	2.3763D+01	11	8	5.1135D+01	13	8	6.1041D+01
		15	8	5.9164D+01	17	8	7.5787D+01	19	8	8.3024D+01	21	8	9.6528D+01
		25	1	9.0350D+02									
471	3.60000D+01	1	1.10018D-04	1.055000+00	0.0	0.0	0.0						
471	3.60000D+01	3	3.9782D-06	1.055000+00	0.0	0.0	0.0						
471	3.60000D+01	2	4.23706D-06	1.055000+00	0.0	0.0	0.0						
471	3.6000D+01	1	7.59974D+01	3.8	0.6320D+01	5.8	2.3713D+01	11	8	5.1071D+01	13	8	6.0969D+01
		15	8	5.9101D+01	17	8	7.5805D+01	19	8	8.3268D+01	21	8	9.7094D+01
		25	1	9.1513D+02									



HEATING 02/12/83  
W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1.0 MIDEI

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 471 TIME STEPS, TIME = 3.600000E+01

10M0333/ 0  
20 58 08 11-16-89

GROSS GRID	1
FINE GRID	1
DISTANCE	0.0
1	0.0 76100
2	0.03 78132
3	0.06 80167
4	0.08 81150
5	0.10 82137
6	0.57 82185
7	1.04 83132
8	1.51 83178
9	1.98 84123
10	2.45 84167
11	2.92 85111
12	3.14 85162
13	3.35 86110
14	3.57 86153
15	3.79 86191
16	4.01 87126
17	4.23 87158
18	4.45 87192
19	4.67 88133
20	4.89 88189
21	5.10 89171
22	5.18 121144
23	5.25 154119
10 24	5.32 188179
11 25	5.35 191153

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	87.300000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 1.60963982E-01

ELAPSED CPU TIME IS 5.56 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.91531E+02 (+0.1 PERCENT)

MAY. TEMP. APPEARS AT NODES 25

THE MINIMUM TEMPERATURE IS - 7.59974E+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES 1

NO	TIME	NO	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	MODE	MAX PERCENT TEMP CHANGE	
472	3.617710+01	1	240650-04	1.055000+00	0.0	0.0	0.0	1	3.277920-05	24	1.275670+00	24	6.757080-01
472	3.617710+01	3	4.985960-06	1.055000+00	0.0	0.0	0.0	2	2.665890-06	24	1.275670+00	24	6.757080-01
472	3.617710+01	2	5.415420-06	1.055000+00	0.0	0.0	0.0	2	2.665890-06	24	1.275670+00	24	6.757080-01
TABLE FOR SPECIAL MONITORING OF TEMPERATURES													
NUMBER OF TIME													
MODE NUMBERS AND TEMPERATURES													
472	3.61770+01	1	7.599580+01	3.8	062760+01	5.8	236580+01	11	8	509920+01	13	8	608910+01
		15	8	690350+01	17	8	758310+01	19	8	835420+01	21	8	977090+01
		25	1	927970+02									
473	3.63720+01	1	9.328390-05	1.055000+00	0.0	0.0	0.0	1	3.050630-05	24	1.369410+00	24	7.204930-01
473	3.637180+01	3	4.025330-06	1.055000+00	0.0	0.0	0.0	2	2.090830-06	24	1.369410+00	24	7.204930-01
472	3.637180+01	2	4.805170-06	1.055000+00	0.0	0.0	0.0	11	8	509210+01	13	8	608060+01
473	3.63720+01	1	7.599420+01	3.8	062270+01	5.8	235980+01	11	8	509210+01	13	8	608060+01
		15	8	689670+01	17	8	758690+01	19	8	838490+01	21	8	983750+01
		25	1	941660+02									
474	3.658610+01	1	9.339160-05	1.055000+00	0.0	0.0	0.0	1	2.865490-05	25	1.484540+00	24	7.723190-01
474	3.658610+01	3	4.707110-06	1.055000+00	0.0	0.0	0.0	2	2.049650-06	25	1.484540+00	24	7.723190-01
474	3.658610+01	2	5.263890-06	1.055000+00	0.0	0.0	0.0	11	8	508340+01	13	8	607140+01
474	3.658610+01	1	7.599230+01	3.8	061740+01	5.8	235310+01	11	8	508340+01	13	8	607140+01
474	3.658610+01	15	8	688970+01	17	8	759190+01	19	8	841920+01	21	8	990970+01
		25	1	956510+02									
475	3.679300+01	1	2.630990-03	1.055000+00	0.0	0.0	0.0	1	2.526430-04	24	1.158880+00	24	6.007260-01
475	3.679300+01	4	2.181770-06	1.055000+00	0.0	0.0	0.0	2	5.563500-05	24	1.158880+00	24	6.007260-01
475	3.679300+01	4	5.111320-07	1.055000+00	0.0	0.0	0.0	3	1.278160-05	24	1.158880+00	24	6.007260-01
475	3.679300+01	3	7.769440-06	1.055000+00	0.0	0.0	0.0	4	2.969920-06	24	1.158880+00	24	6.007260-01
475	3.679300+01	2	7.223450-06	1.055000+00	0.0	0.0	0.0	11	8	507510+01	13	8	606260+01
475	3.67930+01	1	7.599040+01	3.8	061220+01	5.8	234670+01	11	8	507510+01	13	8	606260+01
475	3.67930+01	15	8	688340+01	17	8	759770+01	19	8	845280+01	21	8	997840+01
		25	1	964800+02									
476	3.700000+01	1	6.560610-04	1.055000+00	0.0	0.0	0.0	1	1.803600-04	23	7.948790-01	23	5.028060-01
476	3.700000+01	4	6.587270-07	1.055000+00	0.0	0.0	0.0	2	1.623580-05	23	7.948790-01	23	5.028060-01
476	3.700000+01	3	9.866530-06	1.055000+00	0.0	0.0	0.0	3	3.790500-06	23	7.948790-01	23	5.028060-01
476	3.700000+01	2	9.203760-06	1.055000+00	0.0	0.0	0.0	11	8	506680+01	13	8	605400+01
476	3.700000+01	1	7.598860+01	3.8	060700+01	5.8	234020+01	11	8	506680+01	13	8	605400+01
476	3.700000+01	15	8	687760+01	17	8	760430+01	19	8	848690+01	21	9	004600+01
		25	1	971270+02									

HEATING6 02/12/83  
 W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 476 TIME STEPS, TIME = 3.700000+01

IBM J033/ 0  
 20 58 08 11-16-89

GROSS GRID	1	1
FINE GRID	1	1
DISTANCE	0.0	0.0
1	75199	
2	78130	
3	80161	
4	81147	
5	82134	
6	83129	
7	84120	
8	85107	
9	86105	
10	87124	
11	88149	
12	89114	
13	90105	
14	91108	
15	92188	
16	93186	
17	94186	
18	95113	
19		
20		
21		
22		
23		
24		
25		

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	89.500000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 2.069650710-01

ELAPSED CPU TIME IS 5.65 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.971270+02 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 25

THE MINIMUM TEMPERATURE IS - 7.58860+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	MODE	MAX PERCENT TEMP CHANGE
477	3.722770+01	1	7.598660+01	3.8.060130+01	5.8.233310+01	11.8.505770+01	13.8.604460+01					
		15	8.687170+01	17.8.761250+01	19.8.852470+01	21.9.011870+01	24.1.955180+02					
		25	1.976630+02									
478	3.747810+01	1	4.621590-04	1.055000+00	0.0	0.0	1.409680-04					
		4	7.342280-07	1.055000+00	0.0	0.0	2.1.072550-05					
		3	9.077520-06	1.055000+00	0.0	0.0	3.2.840400-06	23	5.825080-01	23	3.650530-01	
478	3.747810+01	2	6.570370-06	1.055000+00	0.0	0.0	11.8.504770+01	13	8.603460+01			
		15	8.685600+01	17.8.762250+01	19.8.856680+01	21.9.019600+01	24.1.960730+02					
		25	1.981510+02									
479	3.773900+01	1	4.096790-03	1.055000+00	0.0	0.0	1.4.773890-04					
		5	4.429520-07	1.055000+00	0.0	0.0	2.1.079470-04					
		4	3.510490-06	1.055000+00	0.0	0.0	3.2.907050-05					
479	3.773900+01	4	9.485450-07	1.055000+00	0.0	0.0	4.7.664540-06	25	4.286240-01	22	2.440820-01	
		3	6.924150-06	1.055000+00	0.0	0.0	11.8.503750+01	13	8.602440+01			
479	3.773900+01	1	7.598210+01	3.8.058860+01	5.8.231740+01	11.8.503750+01	13.8.602440+01					
		15	8.686080+01	17.8.763410+01	19.8.861080+01	21.9.027320+01	24.1.961350+02					
		25	1.977230+02									
480	3.800000+01	1	7.223070-03	1.055000+00	0.0	0.0	1.8.088630-04					
		5	6.464170-07	1.055000+00	0.0	0.0	2.1.596900-04					
		4	5.146350-06	1.055000+00	0.0	0.0	3.4.273310-05					
480	3.800000+01	4	1.381570-06	1.055000+00	0.0	0.0	4.1.146060-05					
		4	3.705740-07	1.055000+00	0.0	0.0	5.2.685250-05	25	1.827110+00	25	9.248500-01	
480	3.800000+01	2	9.281510-06	1.055000+00	0.0	0.0	11.8.502730+01	13	8.601460+01			
		15	8.685640+01	17.8.764670+01	19.8.865500+01	21.9.034630+01	24.1.950700+02					
		25	1.959000+02									

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

\*\*\*\*\* NODE NUMBERS AND TEMPERATURES \*\*\*\*\*

NUMBER OF TIME

TIME STEPS

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 480 TIME STEPS, TIME = 3.800000E+01

HEATING6 02/12/B3  
W9XMP110

GROSS GRID	FINE GRID	DISTANCE	TEMPERATURE
1	0	0.0	75198
2	0	0.03	78128
3	0	0.06	80158
4	0	0.08	81145
5	0	0.10	82131
6	0	0.10	82178
7	1	1.04	83125
8	1	1.51	83171
9	1	1.98	84116
10	2	2.45	84160
11	2	2.92	85103
12	3	3.14	85154
13	3	3.35	86101
14	3	3.57	86145
15	3	3.79	86186
16	4	4.01	87125
17	4	4.23	87165
18	4	4.45	88110
19	4	4.67	88155
20	4	4.89	89138
21	5	5.10	90135
22	5	5.18	125138
23	5	5.25	160147
24	5	5.32	195107
25	5	5.35	195190

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	91.360000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 2.609553430E-01

ELAPSED CPU TIME IS 5.76 SECONDS

THE MAXIMUM TEMPERATURE IS 1.959000E+02 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES 25

THE MINIMUM TEMPERATURE IS 7.597990E+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES 1

NO TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	NO NODE	MAX TEMP CHANGE	NO NODE	MAX PERCENT TEMP CHANGE
481	3.82680+01	1 844950-03	1.055000+00	0.0	0.0	0.0	1 5	432540-04					
481	3.82680+01	4 798750-06	1.055000+00	0.0	0.0	0.0	2 4	629830-05					
481	3.82680+01	4 1856420-06	1.055000+00	0.0	0.0	0.0	3 1	251650-05					
481	3.82680+01	4 5027480-07	1.055000+00	0.0	0.0	0.0	4 3	346580-06	25 2	2.270370+00	25 1	158940+00	
481	3.82680+01	3 311380-06	1.055000+00	0.0	0.0	0.0	1 2	250570-05					
481	3.822040+01	1 372150-04	1.055000+00	0.0	0.0	0.0	2 2	716200-06	25 1	887680+00	25 9	635980-01	
481	3.822040+01	3 828230-06	1.055000+00	0.0	0.0	0.0							
481	3.822040+01	2 6855450-06	1.055000+00	0.0	0.0	0.0							

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NUMBER OF TIME STEPS	TIME	***** NODE NUMBERS AND TEMPERATURES	***** NODE NUMBERS AND TEMPERATURES
481	3.82200+01	1 7.59770+01	3 8.057680+01
		15 8.685320+01	17 8.765820+01
		25 1.940120+02	
482	3.84400+01	1 9.784370-04	1.055000+00
482	3.84400+01	4 2.991850-07	1.055000+00
482	3.84400+01	4 8.745320-08	1.055000+00
482	3.84400+01	3 3.441020-06	1.055000+00
482	3.84120+01	1 9.958670-05	1.055000+00
482	3.84120+01	3 4.955130-05	1.055000+00
482	3.84120+01	2 4.256940-06	1.055000+00
482	3.84120+01	1 7.597600+01	3 8.057210+01
		15 8.685090+01	17 8.765870+01
		25 1.921470+02	
483	3.86030+01	1 3.055640-04	1.055000+00
483	3.86030+01	4 8.576940-07	1.055000+00
483	3.86030+01	3 3.505110-06	1.055000+00
483	3.859190+01	1 3.101560-05	1.055000+00
483	3.859190+01	2 6.110430-06	1.055000+00
483	3.859190+01	1 6.538020-06	1.055000+00
483	3.85920+01	1 7.597430+01	3 8.056770+01
		15 8.684910+01	17 8.767850+01
		25 1.903140+02	
484	3.877170+01	1 1.191950-03	1.055000+00
484	3.877170+01	4 2.309490-06	1.055000+00
484	3.877170+01	4 4.901530-07	1.055000+00
484	3.877170+01	3 2.325560-06	1.055000+00
484	3.874310+01	1 9.220220-05	1.055000+00
484	3.874310+01	3 3.454920-06	1.055000+00
484	3.874310+01	2 2.828440-06	1.055000+00
484	3.87430+01	1 7.597290+01	3 8.056400+01
		15 8.684780+01	17 8.768780+01
		25 1.884800+02	
485	3.887150+01	1 1.360580-04	1.055000+00
485	3.887150+01	3 1.984130-06	1.055000+00
485	3.887150+01	2 4.741510-06	1.055000+00
485	3.88720+01	1 7.597180+01	3 8.056100+01
		15 8.684700+01	17 8.769550+01
		25 1.868580+02	
486	3.900000+01	1 8.789740-05	1.055000+00
486	3.900000+01	3 1.753890-06	1.055000+00
486	3.900000+01	2 2.657500-06	1.055000+00
486	3.90000+01	1 7.597070+01	3 8.055790+01
		15 8.684530+01	17 8.770340+01
		25 1.851980+02	

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 486 TIME STEPS. TIME = 3.900000E+01

HEATING6 02/12/83  
W9ANP110

GROSS GRID	1
FINE GRID	1
DISTANCE	0 0
1	75197
2	78127
3	80156
4	81142
5	82128
6	82175
7	83122
8	83167
9	84112
10	84156
11	84199
12	85150
13	85198
14	86142
15	86185
16	87126
17	87170
18	88121
19	88182
20	89150
21	90156
22	123172
23	155180
24	185140
25	185120

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	92.790000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 1.28465412D-01

ELAPSED CPU TIME IS 5 90 SECONDS

THE MAXIMUM TEMPERATURE IS 1.85404D+02 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES 24

THE MINIMUM TEMPERATURE IS 7.59707D+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES 1

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	DRD (ITERATION)	GRD (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	NO. MAX. PERCENT TEMP CHANGE
487	3 912850+01	1	1.282380-04	1.055000+00	0.0	0.0	0.0	1	5.528560-05	25 1.709100+00	25 9.228490-01
487	3 912850+01	3	3.196210-06	1.055000+00	0.0	0.0	0.0	2	2.916970-06		
487	3 912850+01	2	3.654060-06	1.055000+00	0.0	0.0	0.0				

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NUMBER OF TIME STEPS	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	DRD (ITERATION)	GRD (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	NO. MAX. PERCENT TEMP CHANGE
487	3 91280+01	1	1.596960+01	3.8 055490+01	5.8 227600+01	11.8 498520+01	13.8 597580+01	1	5.528560-05	25 1.709100+00	25 9.228490-01
		15	8.684570+01	17.8 771150+01	19.8 884130+01	21.9 057960+01	24.1 837840+02	2	2.916970-06		
		25	1.834290+02		0.0	0.0	0.0	1	4.612530-05	25 1.744240+00	25 9.595940-01
488	3 925630+01	1	8.948900-05	1.055000+00	0.0	0.0	0.0	2	2.089610-06	25 1.744240+00	25 9.595940-01
488	3 925690+01	3	2.101910-06	1.055000+00	0.0	0.0	0.0	11.8 498070+01	13.8 597180+01		
488	3 925690+01	2	2.614730-06	1.055000+00	0.0	0.0	0.0	21.9 059590+01	24.1 821180+02		
488	3 925690+01	1	1.7596850+01	3.8 055190+01	5.8 227230+01	11.8 498070+01	13.8 597180+01	1	5.528560-05		
488	3 92570+01	15	8.684530+01	17.8 771970+01	19.8 886120+01	21.9 059590+01	24.1 821180+02	2	2.916970-06		
		25	1.817450+02		0.0	0.0	0.0	1	3.919680-05	25 1.773240+00	25 9.756750-01
489	3 939540+01	1	7.483340-05	1.055000+00	0.0	0.0	0.0	2	1.727900-06	25 1.773240+00	25 9.756750-01
489	3 938540+01	3	1.777390-06	1.055000+00	0.0	0.0	0.0	11.8 497620+01	13.8 596800+01		
489	3 938540+01	2	2.152830-06	1.055000+00	0.0	0.0	0.0	21.9 061900+01	24.1 804140+02		
489	3 93850+01	1	1.7596740+01	3.8 054890+01	5.8 226870+01	11.8 497620+01	13.8 596800+01	1	5.528560-05		
489	3 93850+01	15	8.684510+01	17.8 772800+01	19.8 888070+01	21.9 061900+01	24.1 804140+02	2	2.916970-06		
		25	1.799710+02		0.0	0.0	0.0	1	3.352770-05	25 1.798420+00	25 9.992810-01
490	3 951390+01	1	6.621790-05	1.055000+00	0.0	0.0	0.0	2	1.894360-06	25 1.798420+00	25 9.992810-01
490	3 951390+01	2	9.197690-06	1.055000+00	0.0	0.0	0.0	11.8 497170+01	13.8 596420+01		
490	3 951390+01	2	8.794000-06	1.055000+00	0.0	0.0	0.0	21.9 062230+01	24.1 786730+02		
490	3 95140+01	1	1.7596630+01	3.8 054600+01	5.8 226510+01	11.8 497170+01	13.8 596420+01	1	5.528560-05		
490	3 95140+01	15	8.684510+01	17.8 773640+01	19.8 889970+01	21.9 062230+01	24.1 786730+02	2	2.916970-06		
		25	1.781730+02		0.0	0.0	0.0	1	1.008090-04	25 2.019330+00	25 1.133350+00
491	3 964230+01	1	6.413260-04	1.055000+00	0.0	0.0	0.0	2	1.265820-05	25 2.019330+00	25 1.133350+00
491	3 964230+01	4	1.762860-06	1.055000+00	0.0	0.0	0.0	3	2.048790-06		
491	3 964230+01	3	2.789340-06	1.055000+00	0.0	0.0	0.0	1	4.313400-06	25 1.688410+00	25 9.567750-01
491	3 964230+01	2	2.512420-06	1.055000+00	0.0	0.0	0.0	2	6.030320-07	25 1.688410+00	25 9.567750-01
491	3 964230+01	1	3.138310-05	1.055000+00	0.0	0.0	0.0	1	5.268420-06	25 1.703900+00	25 9.563170-01
491	3 962150+01	2	4.621580-06	1.055000+00	0.0	0.0	0.0	2	2.6287070-07	25 1.703900+00	25 9.563170-01
491	3 962150+01	1	4.115160-06	1.055000+00	0.0	0.0	0.0	11.8 496810+01	13.8 596110+01		
491	3 962150+01	1	1.7596540+01	3.8 054350+01	5.8 226220+01	11.8 496810+01	13.8 596110+01	1	5.528560-05		
491	3 96220+01	15	8.684520+01	17.8 774360+01	19.8 891530+01	21.9 063100+01	24.1 771540+02	2	2.916970-06		
		25	1.764690+02		0.0	0.0	0.0	1	8.536140-05	25 1.845940+00	25 1.046040+00
492	3 972920+01	1	3.285800-04	1.055000+00	0.0	0.0	0.0	2	1.726960-06	25 1.845940+00	25 1.046040+00
492	3 972920+01	3	5.770020-06	1.055000+00	0.0	0.0	0.0	1	4.313400-06	25 1.688410+00	25 9.567750-01
492	3 972920+01	2	6.850200-06	1.055000+00	0.0	0.0	0.0	2	6.030320-07	25 1.688410+00	25 9.567750-01
492	3 971930+01	1	2.923590-05	1.055000+00	0.0	0.0	0.0	1	5.268420-06	25 1.703900+00	25 9.563170-01
492	3 971930+01	2	3.837290-06	1.055000+00	0.0	0.0	0.0	11.8 496480+01	13.8 595830+01		
492	3 971930+01	1	3.780160-06	1.055000+00	0.0	0.0	0.0	21.9 063370+01	24.1 756580+02		
492	3 97190+01	1	1.7596460+01	3.8 054130+01	5.8 225950+01	11.8 496480+01	13.8 595830+01	1	5.528560-05		
492	3 97190+01	15	8.684530+01	17.8 775010+01	19.8 892910+01	21.9 064290+01	24.1 741440+02	2	2.916970-06		
		25	1.747810+02		0.0	0.0	0.0	1	5.930320-05	25 1.751010+00	25 1.001830+00
493	3 981710+01	1	1.118330-04	1.055000+00	0.0	0.0	0.0	2	2.823340-06	25 1.751010+00	25 1.001830+00
493	3 981710+01	3	1.437960-06	1.055000+00	0.0	0.0	0.0	1	4.313400-06	25 1.688410+00	25 9.567750-01
493	3 981710+01	2	2.379300-06	1.055000+00	0.0	0.0	0.0	2	6.030320-07	25 1.688410+00	25 9.567750-01
493	3 981710+01	1	1.446590-05	1.055000+00	0.0	0.0	0.0	1	2.350560-05	25 1.666690+00	25 9.535880-01
493	3 981210+01	2	1.799150-06	1.055000+00	0.0	0.0	0.0	2	2.988180-07	25 1.666690+00	25 9.535880-01
493	3 981210+01	1	1.786950-06	1.055000+00	0.0	0.0	0.0	11.8 496170+01	13.8 595580+01		
493	3 981210+01	1	1.7596380+01	3.8 053930+01	5.8 225700+01	11.8 496170+01	13.8 595580+01	1	5.528560-05		
493	3 981210+01	15	8.684560+01	17.8 775630+01	19.8 894190+01	21.9 064290+01	24.1 741440+02	2	2.916970-06		
		25	1.731140+02		0.0	0.0	0.0	1	4.850360-05	25 1.712970+00	25 9.895060-01
494	3 990480+01	1	7.839360-05	1.055000+00	0.0	0.0	0.0	2	2.512890-06	25 1.712970+00	25 9.895060-01
494	3 990480+01	2	7.146750-06	1.055000+00	0.0	0.0	0.0	11.8 495860+01	13.8 595320+01		
494	3 990480+01	2	1.489260-06	1.055000+00	0.0	0.0	0.0	21.9 064720+01	24.1 725580+02		
494	3 99050+01	1	1.7596310+01	3.8 053720+01	5.8 225450+01	11.8 495860+01	13.8 595320+01	1	5.528560-05		
494	3 99050+01	15	8.674590+01	17.8 776260+01	19.8 895440+01	21.9 064720+01	24.1 725580+02	2	2.916970-06		
		25	1.714010+02		0.0	0.0	0.0	1	1.140100-04	25 1.725580+02	25 9.895060-01



495 4 000000+01	1 7 224620-05	1 055000+00	0 0	0 0	1 4 519520-05	25 1 798330+00	25 1 049190+00
495 4 000000+01	2 7 097760-06	1 055000+00	0 0	0 0	2 2 228060-06		
495 4 000000+01	2 1 378220-06	1 055000+00	0 0	0 0			
495 3 999100+01	1 2 308260-05	1 055000+00	0 0	0 0	1 4 118220-06		
495 3 999100+01	2 2 670830-06	1 055000+00	0 0	0 0	2 4 738770-07	25 1 639080+00	25 9 562860-01
495 3 999100+01	1 2 625360-06	1 055000+00	0 0	0 0			
495 3 999100+01	1 7 596240+01	3 8 053530+01	5 8 225270+01	11 8 495580+01	13 8 595100+01		
495 3 999100+01	15 8 684620+01	17 8 776840+01	19 8 896570+01	21 9 065010+01	24 1 710290+02		
	25 1 697620+02						
496 4 000100+01	1 7 019100-06	1 055000+00	0 0	0 0	1 7 027610-06		
496 4 000100+01	1 7 019100-06	1 055000+00	0 0	0 0	2 5 618310-07	25 2 102560-01	25 1 238540-01
496 4 000100+01	1 5 401320-07	1 055000+00	0 0	0 0			
496 4 000100+01	1 7 596220+01	3 8 053510+01	5 8 225190+01	11 8 495550+01	13 8 595070+01		
496 4 000100+01	15 8 684630+01	17 8 776910+01	19 8 896700+01	21 9 065040+01	24 1 708480+02		
	25 1 695520+02						

HEATING6 02/12/83  
W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

18W3033/ 0  
20 58.09 11-16-89

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 496 TIME STEPS, TIME = 4.000100+01

GROSS GRID 1

FINE GRID 1

	O. O.
1	0 0 75196
2	0 03 78125
3	0 06 80154
4	0 08 81139
5	0 10 82125
6	0 57 82172
7	1 04 83119
8	1 51 83164
9	1 98 84109
10	2 45 84153
11	2 92 84196
12	3 14 85147
13	3 35 85195
14	3 57 86141
15	3 79 86185
16	4 01 87129
17	4 23 87177
18	4 45 88132
19	4 67 88197
20	4 89 89175
21	5 10 90165
22	5 18 119175
23	5 25 147116
10 24	5 32 170185
11 25	5 35 169155

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	93.690310
2	0 0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 1.000000000-02

ELAPSED CPU TIME IS 6.07 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.708480+02 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 24

THE MINIMUM TEMPERATURE IS - 7.596220+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF NODE TEMP DIFF	MAX TEMP CHANGE	NODE MAX PERCENT TEMP CHANGE
497	4.001100+01	1	7.596210+01	3.8053480+01	3.8053480+01	5.8225170+01	11.8495510+01	13.8595040+01	13.8595040+01	25.2085730-01	25.1230140-01
497	4.001100+01	2	8.684630+02	17.8776970+01	17.8776970+01	19.8896830+01	21.9065070+01	24.1706650+02	24.1706650+02		
498	4.002100+01	1	8.598600-07	1.055000+00	0.0	0.0	0.0	1.1011480-06	1.1011480-06	25.2071040-01	25.1222980-01
498	4.002100+01	2	8.598600-07	1.055000+00	0.0	0.0	0.0	2.6554590-05	2.6554590-05		
498	4.002100+01	3	7.084160-08	1.055000+00	0.0	0.0	0.0	11.8495480+01	13.8595020+01		
498	4.002100+01	4	1.7596200+01	3.8053470+01	3.8053470+01	5.8225140+01	11.8495480+01	13.8595020+01	13.8595020+01	24.1704810+02	
498	4.002100+01	5	8.684640+01	17.8777040+01	17.8777040+01	19.8896960+01	21.9065100+01	24.1704810+02	24.1704810+02		
499	4.003100+01	1	7.098910-07	1.055000+00	0.0	0.0	0.0	1.8756750-07	1.8756750-07	25.2059780-01	25.1217820-01
499	4.003100+01	2	7.098910-07	1.055000+00	0.0	0.0	0.0	2.5400470-08	2.5400470-08		
499	4.003100+01	3	5.677890-08	1.055000+00	0.0	0.0	0.0	11.8495450+01	13.8594990+01		
499	4.003100+01	4	1.7596190+01	3.8053440+01	3.8053440+01	5.8225110+01	11.8495450+01	13.8594990+01	13.8594990+01	24.1702950+02	
499	4.003100+01	5	8.684640+01	17.8777110+01	17.8777110+01	19.8897090+01	21.9065120+01	24.1702950+02	24.1702950+02		
500	4.004200+01	1	7.884390-07	1.055000+00	0.0	0.0	0.0	1.9700240-07	1.9700240-07	25.2252590-01	25.1333450-01
500	4.004200+01	2	7.884390-07	1.055000+00	0.0	0.0	0.0	2.6310080-08	2.6310080-08		
500	4.004200+01	3	6.791920-08	1.055000+00	0.0	0.0	0.0	11.8495410+01	13.8594960+01		
500	4.004200+01	4	1.7596180+01	3.8053420+01	3.8053420+01	5.8225080+01	11.8495410+01	13.8594960+01	13.8594960+01	24.1700900+02	
500	4.004200+01	5	8.684650+01	17.8777180+01	17.8777180+01	19.8897230+01	21.9065150+01	24.1700900+02	24.1700900+02		
501	4.005410+01	1	8.070920-07	1.055000+00	0.0	0.0	0.0	1.1017310-06	1.1017310-06	25.2465850-01	25.1464630-01
501	4.005410+01	2	8.070920-07	1.055000+00	0.0	0.0	0.0	2.6336430-08	2.6336430-08		
501	4.005410+01	3	6.939670-08	1.055000+00	0.0	0.0	0.0	11.8495370+01	13.8594930+01		
501	4.005410+01	4	1.7596170+01	3.8053390+01	3.8053390+01	5.8225050+01	11.8495370+01	13.8594930+01	13.8594930+01	24.1698520+02	
501	4.005410+01	5	8.684650+01	17.8777270+01	17.8777270+01	19.8897380+01	21.9065170+01	24.1698520+02	24.1698520+02		
502	4.006740+01	1	8.229620-07	1.055000+00	0.0	0.0	0.0	1.1077190-06	1.1077190-06	25.2701450-01	25.1603630-01
502	4.006740+01	2	8.229620-07	1.055000+00	0.0	0.0	0.0	2.6304370-08	2.6304370-08		
502	4.006740+01	3	6.972690-08	1.055000+00	0.0	0.0	0.0	11.8495330+01	13.8594900+01		
502	4.006740+01	4	1.7596160+01	3.8053370+01	3.8053370+01	5.8225020+01	11.8495330+01	13.8594900+01	13.8594900+01	24.1696110+02	
502	4.006740+01	5	8.684660+01	17.8777360+01	17.8777360+01	19.8897550+01	21.9065200+01	24.1696110+02	24.1696110+02		
503	4.008210+01	1	8.270080-07	1.055000+00	0.0	0.0	0.0	1.144190-06	1.144190-06	25.2961850-01	25.1761040-01
503	4.008210+01	2	8.270080-07	1.055000+00	0.0	0.0	0.0	2.6300750-08	2.6300750-08		
503	4.008210+01	3	6.966760-08	1.055000+00	0.0	0.0	0.0	11.8495280+01	13.8594860+01		
503	4.008210+01	4	1.7596150+01	3.8053330+01	3.8053330+01	5.8224980+01	11.8495280+01	13.8594860+01	13.8594860+01	24.1693330+02	
503	4.008210+01	5	8.684670+01	17.8777450+01	17.8777450+01	19.8897740+01	21.9065230+01	24.1693330+02	24.1693330+02		
504	4.009820+01	1	7.758290-07	1.055000+00	0.0	0.0	0.0	1.1191930-06	1.1191930-06	25.3250860-01	25.1936280-01
504	4.009820+01	2	7.758290-07	1.055000+00	0.0	0.0	0.0	2.5997080-08	2.5997080-08		
504	4.009820+01	3	6.473410-08	1.055000+00	0.0	0.0	0.0	11.8495230+01	13.8594820+01		
504	4.009820+01	4	1.7596140+01	3.8053300+01	3.8053300+01	5.8224940+01	11.8495230+01	13.8594820+01	13.8594820+01	24.1690260+02	
504	4.009820+01	5	8.684670+01	17.8777570+01	17.8777570+01	19.8897930+01	21.9065250+01	24.1690260+02	24.1690260+02		
505	4.011590+01	1	7.142420-07	1.055000+00	0.0	0.0	0.0	1.260200-06	1.260200-06	25.3571140-01	25.1131180-01
505	4.011590+01	2	7.142420-07	1.055000+00	0.0	0.0	0.0	2.5373570-08	2.5373570-08		
505	4.011590+01	3	5.392440-08	1.055000+00	0.0	0.0	0.0	11.8495180+01	13.8594770+01		
505	4.011590+01	4	1.7596120+01	3.8053260+01	3.8053260+01	5.8224890+01	11.8495180+01	13.8594770+01	13.8594770+01	24.1686860+02	
505	4.011590+01	5	8.684680+01	17.8777690+01	17.8777690+01	19.8898170+01	21.9065280+01	24.1686860+02	24.1686860+02		
506	4.013540+01	1	6.417190-07	1.055000+00	0.0	0.0	0.0	1.1351560-06	1.1351560-06	25.3925690-01	25.2347760-01
506	4.013540+01	2	6.417190-07	1.055000+00	0.0	0.0	0.0	2.4717730-08	2.4717730-08		
506	4.013540+01	3	3.829820-08	1.055000+00	0.0	0.0	0.0	11.8495110+01	13.8594720+01		
506	4.013540+01	4	1.7596110+01	3.8052220+01	3.8052220+01	5.8224840+01	11.8495110+01	13.8594720+01	13.8594720+01	24.1684720+01	
506	4.013540+01	5	8.684680+01	17.8777810+01	17.8777810+01	19.8898340+01	21.9065300+01	24.1684720+01	24.1684720+01		

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
\*\*\*\*\* NODE NUMBERS AND TEMPERATURES \*\*\*\*\*

NUMBER OF TIME STEPS	TIME	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF NODE TEMP DIFF	MAX TEMP CHANGE	NODE MAX PERCENT TEMP CHANGE
497	4.001100+01	5.8225170+01	11.8495510+01	13.8595040+01	13.8595040+01	25.2085730-01	25.1230140-01
498	4.002100+01	0.0	0.0	1.1011480-06	1.1011480-06	25.2071040-01	25.1222980-01
499	4.003100+01	0.0	0.0	1.8756750-07	1.8756750-07	25.2059780-01	25.1217820-01
500	4.004200+01	0.0	0.0	1.9700240-07	1.9700240-07	25.2252590-01	25.1333450-01
501	4.005410+01	0.0	0.0	1.1017310-06	1.1017310-06	25.2465850-01	25.1464630-01
502	4.006740+01	0.0	0.0	1.1077190-06	1.1077190-06	25.2701450-01	25.1603630-01
503	4.008210+01	0.0	0.0	1.144190-06	1.144190-06	25.2961850-01	25.1761040-01
504	4.009820+01	0.0	0.0	1.1191930-06	1.1191930-06	25.3250860-01	25.1936280-01
505	4.011590+01	0.0	0.0	1.260200-06	1.260200-06	25.3571140-01	25.1131180-01
506	4.013540+01	0.0	0.0	1.1351560-06	1.1351560-06	25.3925690-01	25.2347760-01

507 4 015680+01	1 5 151070-07	1 055000+00	0 0	0 0	1 1 485870-06	25 4 319060-01	25 2 589100-01
507 4 015680+01	1 5 151070-07	1 055000+00	0 0	0 0	2 4 781050-08	25 4 319060-01	25 2 589100-01
507 4 015680+01	1 2 255520-08	1 055000+00	0 0	0 0	11 8 495050+01	24 1 678980+02	
507 4 015680+01	1 7 596090+01	3 8 053170+01	5 8	224780+01	21 9 065320+01	24 1 678980+02	
507 4 015680+01	1 5 8 584710+01	17 8 777960+01	19 8	898680+01	21 9 065320+01	24 1 678980+02	
508 4 018040+01	25 1 663850+02		0 0	0 0	1 1 801560-06	25 2 858340-01	25 2 858340-01
508 4 018040+01	1 6 023810-07	1 055000+00	0 0	0 0	2 5 610310-08	25 4 755850-01	25 2 858340-01
508 4 018040+01	1 6 023810-07	1 055000+00	0 0	0 0	11 8 494970+01	24 1 674410+02	
508 4 018040+01	1 2 992800-08	1 055000+00	0 0	0 0	21 9 065330+01	24 1 674410+02	
508 4 018040+01	1 7 596070+01	3 8 053120+01	5 8	224720+01	11 8 494970+01	24 1 674410+02	
508 4 018040+01	1 7 596070+01	3 8 053120+01	19 8	898970+01	21 9 065330+01	24 1 674410+02	
509 4 020630+01	25 1 659100+02		0 0	0 0	1 2 107540-06	25 5 238500-01	25 3 157440-01
509 4 020630+01	1 6 663250-07	1 055000+00	0 0	0 0	2 6 692040-08	25 5 238500-01	25 3 157440-01
509 4 020630+01	1 6 663250-07	1 055000+00	0 0	0 0	11 8 494870+01	24 1 669370+02	
509 4 020630+01	1 4 492600-08	1 055000+00	0 0	0 0	21 9 065340+01	24 1 669370+02	
509 4 020630+01	1 7 596050+01	3 8 053060+01	5 8	224650+01	11 8 494870+01	24 1 669370+02	
509 4 020630+01	1 7 596050+01	3 8 053060+01	19 8	899280+01	21 9 065340+01	24 1 669370+02	
510 4 023480+01	25 1 653860+02		0 0	0 0	1 2 502430-06	25 6 367820-01	25 3 863770-01
510 4 023480+01	1 7 697750-07	1 055000+00	0 0	0 0	2 7 515150-08	25 6 367820-01	25 3 863770-01
510 4 023480+01	1 7 697750-07	1 055000+00	0 0	0 0	11 8 494800+01	24 1 663800+02	
510 4 023480+01	1 7 517500-08	1 055000+00	0 0	0 0	21 9 065340+01	24 1 663800+02	
510 4 023480+01	1 7 596030+01	3 8 053000+01	5 8	224580+01	11 8 494800+01	24 1 663800+02	
510 4 023480+01	1 7 596030+01	3 8 053000+01	19 8	899630+01	21 9 065340+01	24 1 663800+02	
511 4 026620+01	25 1 648080+02		0 0	0 0	1 2 958410-06	25 6 367820-01	25 3 863770-01
511 4 026620+01	1 8 351440-07	1 055000+00	0 0	0 0	2 1 190540-07	25 6 367820-01	25 3 863770-01
511 4 026620+01	1 8 351440-07	1 055000+00	0 0	0 0	1 3 443820-06	25 7 024900-01	25 4 278000-01
511 4 026620+01	1 2 454880-07	1 055000+00	0 0	0 0	2 1 553330-07	25 7 024900-01	25 4 278000-01
511 4 026620+01	1 1 653020-07	1 055000+00	0 0	0 0	11 8 494700+01	24 1 657660+02	
511 4 026620+01	1 7 596010+01	3 8 052940+01	5 8	224500+01	21 9 065320+01	24 1 657660+02	
511 4 026620+01	1 7 596010+01	3 8 052940+01	19 8	900000+01	11 8 494700+01	24 1 657660+02	
512 4 030080+01	25 1 641720+02		0 0	0 0	1 3 972070-06	25 7 751790-01	25 4 742050-01
512 4 030080+01	1 8 810460-07	1 055000+00	0 0	0 0	2 1 835790-07	25 7 751790-01	25 4 742050-01
512 4 030080+01	1 8 810460-07	1 055000+00	0 0	0 0	11 8 494590+01	24 1 650870+02	
512 4 030080+01	1 2 454880-07	1 055000+00	0 0	0 0	21 9 065280+01	24 1 650870+02	
512 4 030080+01	1 7 595980+01	3 8 052860+01	5 8	224410+01	11 8 494590+01	24 1 650870+02	
512 4 030080+01	1 7 595980+01	3 8 052860+01	19 8	900410+01	21 9 065280+01	24 1 650870+02	
513 4 033870+01	25 1 634650+02		0 0	0 0	1 3 972070-06	25 7 751790-01	25 4 742050-01
513 4 033870+01	1 1 270500-06	1 055000+00	0 0	0 0	2 1 835790-07	25 7 751790-01	25 4 742050-01
513 4 033870+01	1 1 270500-06	1 055000+00	0 0	0 0	11 8 494470+01	24 1 643370+02	
513 4 033870+01	1 3 035330-07	1 055000+00	0 0	0 0	21 9 065230+01	24 1 643370+02	
513 4 033870+01	1 7 595950+01	3 8 052780+01	5 8	224310+01	11 8 494470+01	24 1 643370+02	
513 4 033870+01	1 7 595950+01	3 8 052780+01	19 8	900850+01	21 9 065230+01	24 1 643370+02	
514 4 038050+01	25 1 626940+02		0 0	0 0	1 4 609700-06	25 8 557340-01	25 5 259780-01
514 4 038050+01	1 1 957050-06	1 055000+00	0 0	0 0	2 2 337360-07	25 8 557340-01	25 5 259780-01
514 4 038050+01	1 1 957050-06	1 055000+00	0 0	0 0	11 8 494340+01	24 1 635090+02	
514 4 038050+01	1 4 235580-07	1 055000+00	0 0	0 0	21 9 065140+01	24 1 635090+02	
514 4 038050+01	1 7 595920+01	3 8 052690+01	5 8	224210+01	11 8 494340+01	24 1 635090+02	
514 4 038050+01	1 7 595920+01	3 8 052690+01	19 8	901340+01	21 9 065140+01	24 1 635090+02	
515 4 042640+01	25 1 618380+02		0 0	0 0	1 5 293250-06	25 9 448320-01	25 5 838130-01
515 4 042640+01	1 2 694290-06	1 055000+00	0 0	0 0	2 2 975320-07	25 9 448320-01	25 5 838130-01
515 4 042640+01	1 2 694290-06	1 055000+00	0 0	0 0	11 8 494200+01	24 1 625950+02	
515 4 042640+01	1 6 076620-07	1 055000+00	0 0	0 0	21 9 065020+01	24 1 625950+02	
515 4 042640+01	1 7 595890+01	3 8 052660+01	5 8	224090+01	11 8 494200+01	24 1 625950+02	
515 4 042640+01	1 7 595890+01	3 8 052660+01	19 8	901850+01	21 9 065020+01	24 1 625950+02	
516 4 047700+01	25 1 608930+02		0 0	0 0	1 6 123190-06	25 1 043690+00	25 6 486870-01
516 4 047700+01	1 4 004540-06	1 055000+00	0 0	0 0	2 3 859260-07	25 1 043690+00	25 6 486870-01
516 4 047700+01	1 4 004540-06	1 055000+00	0 0	0 0	11 8 494050+01	24 1 615830+02	
516 4 047700+01	1 9 626710-07	1 055000+00	0 0	0 0	21 9 064850+01	24 1 615830+02	
516 4 047700+01	1 7 595850+01	3 8 052490+01	5 8	223960+01	11 8 494050+01	24 1 615830+02	
516 4 047700+01	1 7 595850+01	3 8 052490+01	19 8	902430+01	21 9 064850+01	24 1 615830+02	
517 4 053260+01	25 1 588560+02		0 0	0 0	1 7 349920-06	25 1 154440+00	25 7 222010-01
517 4 053260+01	1 7 118080-06	1 055000+00	0 0	0 0	2 5 654770-07	25 1 154440+00	25 7 222010-01
517 4 053260+01	1 7 118080-06	1 055000+00	0 0	0 0	11 8 493880+01	24 1 615830+02	
517 4 053260+01	1 1 393490-06	1 055000+00	0 0	0 0	21 9 064770+01	24 1 615830+02	
517 4 053260+01	1 7 595810+01	3 8 052380+01	5 8	223830+01	11 8 493880+01	24 1 615830+02	
517 4 053260+01	1 7 595810+01	3 8 052380+01	19 8	902380+01	21 9 064770+01	24 1 615830+02	

518	4.059380+01	1 2.902370-05	1 055000+00	0 0	0 0	19 8.803030+01	21 9.064620+01	24 1.604650+02	25 8.127860-01
518	4.059380+01	2 2.456500-06	1 055000+00	0 0	0 0	0 0	0 0	1 1.307880-05	25 1.289870+00
518	4.059380+01	1 2.517650-06	1 055000+00	0 0	0 0	0 0	0 0	2 6.732190-07	25 1.593670+01
518	4.059400+01	1 1.595760+01	3 8.052250+01	0 0	0 0	5 8.223670+01	11 8.493490+01	13 8.593670+01	24 1.592220+02
518	4.059400+01	15 8.685040+01	17 8.780920+01	0 0	0 0	19 8.903680+01	21 9.064320+01	24 1.592220+02	
519	4.066100+01	25 1.574050+02	0 0	0 0	0 0	0 0	0 0	1 1.434650-05	25 9.122950-01
519	4.066100+01	1 2.452940-05	1 055000+00	0 0	0 0	0 0	0 0	2 5.987760-07	25 1.435610+00
519	4.066100+01	2 2.044320-06	1 055000+00	0 0	0 0	0 0	0 0	13 8.593470+01	
519	4.066100+01	1 2.619740-06	1 055000+00	0 0	0 0	5 8.223510+01	11 8.493490+01	24 1.578470+02	
519	4.066100+01	1 1.759570+01	3 8.052120+01	0 0	0 0	19 8.904380+01	21 9.064380+01		
520	4.073110+01	15 8.685100+01	17 8.781370+01	0 0	0 0	0 0	0 0	1 1.645040-05	25 9.714490-01
520	4.073110+01	25 1.559700+02	0 0	0 0	0 0	0 0	0 0	2 7.349140-07	
520	4.073110+01	1 3.074900-05	1 055000+00	0 0	0 0	0 0	0 0	13 8.593320+01	
520	4.073110+01	2 2.610800-06	1 055000+00	0 0	0 0	0 0	0 0	24 1.563940+0*	
520	4.073110+01	3 3.33780-06	1 055000+00	0 0	0 0	5 8.223340+01	11 8.493280+01		
520	4.073110+01	1 1.759560+01	3 8.051000+01	0 0	0 0	19 8.905090+01	21 9.064360+01		
520	4.073110+01	15 8.685170+01	17 8.781940+01	0 0	0 0	0 0	0 0	1 1.704700-05	25 9.946060-01
520	4.073110+01	25 1.544580+02	0 0	0 0	0 0	0 0	0 0	2 7.164630-07	
521	4.080120+01	1 2.993780-05	1 055000+00	0 0	0 0	0 0	0 0	25 1.534670+00	
521	4.080120+01	2 2.487180-06	1 055000+00	0 0	0 0	0 0	0 0	13 8.593170+01	
521	4.080120+01	1 3.255270-06	1 055000+00	0 0	0 0	5 8.224170+01	11 8.493080+01	24 1.542230+02	
521	4.080120+01	1 1.759560+01	3 8.051840+01	0 0	0 0	19 8.905170+01	21 9.062920+01		
521	4.080120+01	15 8.685250+01	17 8.782310+01	0 0	0 0	0 0	0 0	1 1.610840-05	25 1.014180+00
521	4.080120+01	25 1.529200+02	0 0	0 0	0 0	0 0	0 0	2 5.905960-07	
522	4.087120+01	1 2.389700-05	1 055000+00	0 0	0 0	0 0	0 0	1 1.980320-06	25 9.535310-01
522	4.087120+01	2 1.977260-06	1 055000+00	0 0	0 0	0 0	0 0	2 5.127470-07	25 1.458140+00
522	4.087120+01	1 2.674720-06	1 055000+00	0 0	0 0	0 0	0 0	13 8.593030+01	
522	4.086680+01	1 9.689130-06	1 055000+00	0 0	0 0	0 0	0 0	1 1.980320-06	
522	4.086680+01	1 9.689130-06	1 055000+00	0 0	0 0	0 0	0 0	2 5.127470-07	
522	4.086680+01	1 1.493590-06	1 055000+00	0 0	0 0	0 0	0 0	13 8.593030+01	
522	4.086680+01	1 1.759550+01	3 8.051710+01	0 0	0 0	5 8.223010+01	11 8.492890+01	24 1.535280+02	
522	4.086680+01	15 8.685320+01	17 8.782750+01	0 0	0 0	19 8.906380+01	21 9.062360+01		
523	4.093250+01	1 1.261170-05	1 055000+00	0 0	0 0	0 0	0 0	1 1.314800-05	25 9.692150-01
523	4.093250+01	2 1.55950-06	1 055000+00	0 0	0 0	0 0	0 0	2 3.455380-07	25 1.467980+00
523	4.093250+01	1 1.518850-06	1 055000+00	0 0	0 0	0 0	0 0	13 8.592890+01	
523	4.093250+01	1 1.759520+01	3 8.051580+01	0 0	0 0	5 8.222860+01	11 8.492710+01	24 1.521160+02	
523	4.093250+01	15 8.685390+01	17 8.783160+01	0 0	0 0	19 8.906980+01	21 9.061740+01		
524	4.100000+01	25 1.499940+02	0 0	0 0	0 0	0 0	0 0	1 1.248560-05	25 1.011000+00
524	4.100000+01	1 1.081970-05	1 055000+00	0 0	0 0	0 0	0 0	2 3.077870-07	25 1.519460+00
524	4.100000+01	2 1.059830-06	1 055000+00	0 0	0 0	0 0	0 0	1 1.810410-06	25 9.533320-01
524	4.100000+01	1 1.382200-06	1 055000+00	0 0	0 0	0 0	0 0	2 4.737830-07	25 1.429540+00
524	4.099580+01	1 8.770370-06	1 055000+00	0 0	0 0	0 0	0 0	13 8.592760+01	
524	4.099580+01	1 8.176220-06	1 055000+00	0 0	0 0	0 0	0 0	2 4.737830-07	
524	4.099580+01	1 1.397650-06	1 055000+00	0 0	0 0	5 8.222710+01	11 8.492530+01	24 1.507400+02	
524	4.099580+01	1 1.759540+01	3 8.051460+01	0 0	0 0	19 8.907540+01	21 9.061080+01		
524	4.099580+01	15 8.685400+01	17 8.783600+01	0 0	0 0	0 0	0 0	1 5.294710-06	25 1.624520-01
524	4.099580+01	25 1.485540+02	0 0	0 0	0 0	0 0	0 0	2 3.942320-07	25 2.413440-01
525	4.100580+01	1 6.239580-06	1 055000+00	0 0	0 0	0 0	0 0	13 8.592740+01	
525	4.100580+01	1 6.239580-06	1 055000+00	0 0	0 0	0 0	0 0	1 1.505210+02	
525	4.100580+01	1 4.948380-07	1 055000+00	0 0	0 0	5 8.222690+01	11 8.492500+01		
525	4.100580+01	1 1.759540+01	3 8.051440+01	0 0	0 0	19 8.907620+01	21 9.060980+01		
525	4.100580+01	15 8.685480+01	17 8.783650+01	0 0	0 0	0 0	0 0	1 5.294710-06	25 1.624520-01
525	4.100580+01	25 1.483220+02	0 0	0 0	0 0	0 0	0 0	2 3.942320-07	25 2.413440-01

BOUNDARY NUMBER	TEMPERATURE
1	93.998203
2	0.0
3	73.400000

TEMPERATURES ON NUMBERED BOUNDARIES

THE CURRENT TIME STEP (DELTA T) = 1.00000000D-02  
 ELAPSED CPU TIME IS 5.38 SECONDS

THE MAXIMUM TEMPERATURE IS 1.50521D+02 (+0.1 PERCENT)  
 MAX. TEMP. APPEARS AT NODES 24

THE MINIMUM TEMPERATURE IS 7.56546D+01 (+0.1 PERCENT)  
 MIN. TEMP. APPEARS AT NODES 1

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	I10 I1ER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	NODE	MAX TEMP CHANGE	NODE	MAX PERCENT TEMP CHANGE
526	4.10158D+01	1	8.20010D-07	1.05500D+00	0.0	0.0	0.0	1 8	9.3242D-07	25 2	3.9979D-01	25 1	6.1796D-01	
526	4.10158D+01	1	8.20010D-07	1.05500D+00	0.0	0.0	0.0	2 6	4.4594D-08	25 2	3.9979D-01	25 1	6.1796D-01	
526	4.10158D+01	1	6.99601D-08	1.05500D+00	0.0	0.0	0.0							

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NUMBER OF TIME STEPS	TIME	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	I10 I1ER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	NODE	MAX TEMP CHANGE	NODE	MAX PERCENT TEMP CHANGE
526	4.1016D+01	1 7.59546D+01	3 8.05142D+01	5 8.22266D+01	11 8.49247D+01	13 8.59272D+01							
		15 8.68548D+01	17 8.78373D+01	19 8.90779D+01	21 9.06076D+01	23 9.22460D+01							
		25 1.48683D+02											
527	4.10259D+01	1 7.34642D-07	1.05500D+00	0.0	0.0	0.0	1 8	1.2946D-07	25 2	3.2804D-01	25 1	6.1264D-01	
527	4.10258D+01	1 7.34642D-07	1.05500D+00	0.0	0.0	0.0	2 5	7.2550D-08	25 2	3.2804D-01	25 1	6.1264D-01	
527	4.10258D+01	1 6.26437E-08	1.05500D+00	0.0	0.0	0.0							
527	4.1026D+01	1 7.59545D+01	3 8.05140D+01	5 8.22266D+01	11 8.49243D+01	13 8.59270D+01							
		15 8.68550D+01	17 8.78379D+01	19 8.90779D+01	21 9.06076D+01	23 9.22460D+01							
		25 1.47844D+02											
528	4.10359D+01	1 6.17542D-07	1.05500D+00	0.0	0.0	0.0	1 7	1.0103D-07	25 2	3.7838D-01	25 1	6.0871D-01	
528	4.10358D+01	1 6.17542D-07	1.05500D+00	0.0	0.0	0.0	2 4	6.31759D-08	25 2	3.7838D-01	25 1	6.0871D-01	
528	4.10358D+01	1 3.07059D-08	1.05500D+00	0.0	0.0	0.0							
528	4.1036D+01	1 7.59544D+01	3 8.05138D+01	5 8.22270D+01	11 8.49244D+01	13 8.59268D+01							
		15 8.68552D+01	17 8.78386D+01	19 8.90788D+01	21 9.06064D+01	23 9.22460D+01							
		25 1.47606D+02											
529	4.10468D+01	1 7.07355D-07	1.05500D+00	0.0	0.0	0.0	1 8	0.00519D-07	25 2	6.0446D-01	25 1	7.6447D-01	
529	4.10468D+01	1 7.07355D-07	1.05500D+00	0.0	0.0	0.0	2 5	7.4190D-08	25 2	6.0446D-01	25 1	7.6447D-01	
529	4.10468D+01	1 6.39981D-08	1.05500D+00	0.0	0.0	0.0							
529	4.1047D+01	1 7.59543D+01	3 8.05136D+01	5 8.22259D+01	11 8.49238D+01	13 8.59266D+01							
		15 8.68553D+01	17 8.78393D+01	19 8.90797D+01	21 9.06052D+01	23 9.22460D+01							
		25 1.47345D+02											
530	4.10589D+01	1 7.18567D-07	1.05500D+00	0.0	0.0	0.0	1 8	2.4255D-07	25 2	8.5384D-01	25 1	9.3684D-01	
530	4.10589D+01	1 7.18567D-07	1.05500D+00	0.0	0.0	0.0	2 5	4.8630D-08	25 2	8.5384D-01	25 1	9.3684D-01	
530	4.10589D+01	1 6.25749D-08	1.05500D+00	0.0	0.0	0.0							
530	4.1059D+01	1 7.59542D+01	3 8.05133D+01	5 8.22256D+01	11 8.49235D+01	13 8.59264D+01							
		15 8.68554D+01	17 8.78401D+01	19 8.90807D+01	21 9.06038D+01	23 9.22460D+01							
		25 1.47060D+02											
531	4.10722D+01	1 7.42662D-07	1.05500D+00	0.0	0.0	0.0	1 8	6.5214D-07	25 3	3.363D-01	25 2	1.2745D-01	
531	4.10722D+01	1 7.42662D-07	1.05500D+00	0.0	0.0	0.0	2 5	9.5080D-08	25 3	3.363D-01	25 2	1.2745D-01	
531	4.10722D+01	1 6.95763D-08	1.05500D+00	0.0	0.0	0.0							
531	4.1072D+01	1 7.59541D+01	3 8.05131D+01	5 8.22253D+01	11 8.49231D+01	13 8.59261D+01							
		15 8.68556D+01	17 8.78403D+01	19 8.90818D+01	21 9.06022D+01	23 9.22460D+01							
		25 1.46747D+02											
532	4.10868D+01	1 7.36854D-07	1.05500D+00	0.0	0.0	0.0	1 8	9.1763D-07	25 3	4.3192D-01	25 2	3.7866D-01	
532	4.10868D+01	1 7.36854D-07	1.05500D+00	0.0	0.0	0.0	2 5	7.7524D-08	25 3	4.3192D-01	25 2	3.7866D-01	
532	4.10868D+01	1 6.83309D-08	1.05500D+00	0.0	0.0	0.0							
532	4.1087D+01	1 7.59540D+01	3 8.05128D+01	5 8.22250D+01	11 8.49227D+01	13 8.59258D+01							
		15 8.68558D+01	17 8.78419D+01	19 8.90830D+01	21 9.06005D+01	23 9.22460D+01							
		25 1.46404D+02											
533	4.11030D+01	1 6.63028D-07	1.05500D+00	0.0	0.0	0.0	1 8	8.4194D-07	25 3	7.6800D-01	25 2	5.7370D-01	
533	4.11030D+01	1 6.63028D-07	1.05500D+00	0.0	0.0	0.0	2 5	2.0895D-08	25 3	7.6800D-01	25 2	5.7370D-01	
533	4.11030D+01	1 6.07075D-08	1.05500D+00	0.0	0.0	0.0							
533	4.1103D+01	1 7.59539D+01	3 8.05125D+01	5 8.22246D+01	11 8.49223D+01	13 8.59255D+01							
		15 8.68560D+01	17 8.78429D+01	19 8.90843D+01	21 9.05986D+01	23 9.22460D+01							
		25 1.46027D+02											
534	4.11207D+01	1 6.47114D-07	1.05500D+00	0.0	0.0	0.0	1 9	3.5248D-07	25 4	1.3844D-01	25 2	8.3403D-01	
534	4.11207D+01	1 6.47114D-07	1.05500D+00	0.0	0.0	0.0	2 4	7.5322D-08	25 4	1.3844D-01	25 2	8.3403D-01	
534	4.11207D+01	1 5.29313D-08	1.05500D+00	0.0	0.0	0.0							
534	4.1121D+01	1 7.59538D+01	3 8.05122D+01	5 8.22242D+01	11 8.49218D+01	13 8.59252D+01							
		15 8.68562D+01	17 8.78441D+01	19 8.90857D+01	21 9.05964D+01	23 9.22460D+01							
		25 1.45613D+02											
535	4.11402D+01	1 5.15042D-07	1.05500D+00	0.0	0.0	0.0	1 9	3.4797D-07	25 4	5.4903D-01	25 3	1.2405D-01	
535	4.11402D+01	1 5.15042D-07	1.05500D+00	0.0	0.0	0.0	2 4	2.5231D-08	25 4	5.4903D-01	25 3	1.2405D-01	
535	4.11402D+01	1 4.22159D-08	1.05500D+00	0.0	0.0	0.0							
535	4.1140D+01	1 7.59537D+01	3 8.05118D+01	5 8.22238D+01	11 8.49213D+01	13 8.59248D+01							

536	4. 1162D+01	15 8 68555D+01	17 8 78453D+01	19 8 90872D+01	21 9 05940D+01	24 1 47509D+02
		25 1 45158D+02		0.0 0.0		
536	4. 11616D+01	1 4 29439D-07	1 05500D+00 0.0	0.0 0.0		
		1 4 29499D-07	1 05500D+00 0.0	0.0 0.0	1 9 88556D-07	
536	4. 11616D+01	1 4 29499D-07	1 05500D+00 0.0	0.0 0.0	2 3 58154D-08	25 5 00240D-01
		1 2 57342D-08	1 05500D+00 0.0	0.0 0.0	13 8 59244D+01	
536	4. 1162D+01	1 7 59535D+01	3 8 05114D+01	5 8 22233D+01	11 8 49207D+01	25 5 00240D-01
		15 8 68567D+01	17 8 78467D+01	19 8 90889D+01	21 9 05912D+01	24 1 47023D+02
		25 1 44658D+02				
537	4. 11852D+01	1 3 98897D-07	1 05500D+00 0.0	0.0 0.0		
		1 3 98897D-07	1 05500D+00 0.0	0.0 0.0	1 1 09422D-06	
537	4. 11852D+01	1 3 98897D-07	1 05500D+00 0.0	0.0 0.0	2 3 60860D-08	25 5 50328D-01
		1 1 90624D-08	1 05500D+00 0.0	0.0 0.0	13 8 59239D+01	
537	4. 11852D+01	1 1 90624D-08	1 05500D+00 0.0	0.0 0.0	11 8 49200D+01	25 5 50328D-01
		1 7 59533D+01	3 8 05109D+01	5 8 22228D+01	21 9 05881D+01	24 1 45488D+02
537	4. 1185D+01	15 8 68570D+01	17 8 78482D+01	19 8 90907D+01	21 9 05881D+01	24 1 45488D+02
		25 1 44108D+02				
538	4. 12111D+01	1 4 61238D-07	1 05500D+00 0.0	0.0 0.0		
		1 4 61238D-07	1 05500D+00 0.0	0.0 0.0	1 1 33841D-06	
538	4. 12111D+01	1 4 61238D-07	1 05500D+00 0.0	0.0 0.0	2 3 69542D-08	25 6 05768D-01
		1 2 50839D-08	1 05500D+00 0.0	0.0 0.0	13 8 59234D+01	
538	4. 12111D+01	1 2 50839D-08	1 05500D+00 0.0	0.0 0.0	11 8 49193D+01	25 6 05768D-01
		1 7 59532D+01	3 8 05104D+01	5 8 22222D+01	21 9 05847D+01	24 1 45898D+02
538	4. 1211D+01	15 8 66374D+01	17 8 78499D+01	19 8 90927D+01	21 9 05847D+01	24 1 45898D+02
		25 1 43502D+02				
539	4. 12396D+01	1 5 14474D-07	1 05500D+00 0.0	0.0 0.0		
		1 5 14474D-07	1 05500D+00 0.0	0.0 0.0	1 1 63287D-06	
539	4. 12396D+01	1 5 14474D-07	1 05500D+00 0.0	0.0 0.0	2 5 54327D-08	25 6 67105D-01
		1 5 50637D-08	1 05500D+00 0.0	0.0 0.0	13 8 59229D+01	
539	4. 12396D+01	1 5 50637D-08	1 05500D+00 0.0	0.0 0.0	11 8 49185D+01	25 6 67105D-01
		1 7 59530D+01	3 8 05099D+01	5 8 22215D+01	21 9 05807D+01	24 1 45216D+02
539	4. 1240D+01	15 8 68578D+01	17 8 78517D+01	19 8 90948D+01	21 9 05807D+01	24 1 45216D+02
		25 1 42835D+02				
540	4. 12710D+01	1 5 51190D-07	1 05500D+00 0.0	0.0 0.0		
		1 5 51190D-07	1 05500D+00 0.0	0.0 0.0	1 1 92225D-06	
540	4. 12710D+01	1 5 51190D-07	1 05500D+00 0.0	0.0 0.0	2 7 89609D-08	25 7 34782D-01
		1 1 02788D-07	1 05500D+00 0.0	0.0 0.0	13 8 59223D+01	
540	4. 1271D+01	1 1 02788D-07	1 05500D+00 0.0	0.0 0.0	11 8 49177D+01	25 7 34782D-01
		15 8 68582D+01	17 8 78537D+01	19 8 90971D+01	21 9 05763D+01	24 1 45310D+02
		25 1 42100D+02				
541	4. 13055D+01	1 8 09575D-07	1 05500D+00 0.0	0.0 0.0		
		1 8 09575D-07	1 05500D+00 0.0	0.0 0.0	1 2 31052D-06	
541	4. 13055D+01	1 8 09575D-07	1 05500D+00 0.0	0.0 0.0	2 1 20597D-07	25 8 09635D-01
		1 1 98203D-07	1 05500D+00 0.0	0.0 0.0	13 8 59217D+01	
541	4. 13055D+01	1 1 98203D-07	1 05500D+00 0.0	0.0 0.0	11 8 49168D+01	25 8 09635D-01
		1 7 59525D+01	3 8 05087D+01	5 8 22201D+01	21 9 05712D+01	24 1 43742D+02
541	4. 1306D+01	15 8 68586D+01	17 8 78559D+01	19 8 90955D+01	21 9 05712D+01	24 1 43742D+02
		25 1 41291D+02				
542	4. 13435D+01	1 1 39213D-06	1 05500D+00 0.0	0.0 0.0		
		1 1 39213D-06	1 05500D+00 0.0	0.0 0.0	1 2 77192D-06	
542	4. 13435D+01	1 1 39213D-06	1 05500D+00 0.0	0.0 0.0	2 1 62629D-07	25 8 92488D-01
		1 2 98285D-07	1 05500D+00 0.0	0.0 0.0	13 8 59210D+01	
542	4. 13435D+01	1 2 98285D-07	1 05500D+00 0.0	0.0 0.0	11 8 49158D+01	25 8 92488D-01
		1 7 59523D+01	3 8 05080D+01	5 8 22192D+01	21 9 05655D+01	24 1 42872D+02
542	4. 1344D+01	15 8 68592D+01	17 8 78583D+01	19 8 91021D+01	21 9 05655D+01	24 1 42872D+02
		25 1 40398D+02				
543	4. 13853D+01	1 2 15370D-06	1 05500D+00 0.0	0.0 0.0		
		1 2 15370D-06	1 05500D+00 0.0	0.0 0.0	1 3 32110D-06	
543	4. 13853D+01	1 2 15370D-06	1 05500D+00 0.0	0.0 0.0	2 2 64545D-07	25 9 84250D-01
		1 3 98282D-07	1 05500D+00 0.0	0.0 0.0	13 8 59202D+01	
543	4. 13853D+01	1 3 98282D-07	1 05500D+00 0.0	0.0 0.0	11 8 49147D+01	25 9 84250D-01
		1 7 59520D+01	3 8 05072D+01	5 8 22183D+01	21 9 05590D+01	24 1 41912D+02
543	4. 1385D+01	15 8 68597D+01	17 8 78609D+01	19 8 91049D+01	21 9 05590D+01	24 1 41912D+02
		25 1 39414D+02				
544	4. 14312D+01	1 2 90714D-06	1 05500D+00 0.0	0.0 0.0		
		1 2 90714D-06	1 05500D+00 0.0	0.0 0.0	1 3 91757D-06	
544	4. 14312D+01	1 2 90714D-06	1 05500D+00 0.0	0.0 0.0	2 2 63032D-07	25 1 08565D+00
		1 5 81627D-07	1 05500D+00 0.0	0.0 0.0	13 8 59194D+01	
544	4. 14312D+01	1 5 81627D-07	1 05500D+00 0.0	0.0 0.0	11 8 49135D+01	25 1 08565D+00
		1 7 59517D+01	3 8 05064D+01	5 8 22173D+01	21 9 05516D+01	24 1 40854D+02
544	4. 1431D+01	15 8 68604D+01	17 8 78638D+01	19 8 91079D+01	21 9 05516D+01	24 1 40854D+02
		25 1 38328D+02				
545	4. 14818D+01	1 4 26840D-06	1 05500D+00 0.0	0.0 0.0		
		1 4 26840D-06	1 05500D+00 0.0	0.0 0.0	1 4 67830D-06	
545	4. 14818D+01	1 4 26840D-06	1 05500D+00 0.0	0.0 0.0	2 3 46118D-07	25 1 19798D+00
		1 8 35911D-07	1 05500D+00 0.0	0.0 0.0	13 8 59185D+01	
545	4. 14818D+01	1 8 35911D-07	1 05500D+00 0.0	0.0 0.0	11 8 49122D+01	25 1 19798D+00
		1 7 59514D+01	3 8 05055D+01	5 8 22162D+01	21 9 05431D+01	24 1 39687D+02
545	4. 1482D+01	15 8 68611D+01	17 8 78569D+01	19 8 91110D+01	21 9 05431D+01	24 1 39687D+02
		25 1 37130D+02				
546	4. 15372D+01	1 1 60662D-06	1 05500D+00 0.0	0.0 0.0		
		1 1 60662D-06	1 05500D+00 0.0	0.0 0.0	1 4 06678D-06	
546	4. 15372D+01	1 1 60662D-06	1 05500D+00 0.0	0.0 0.0	2 1 42248D-07	25 1 31427D+00
		1 1 15133D-07	1 05500D+00 0.0	0.0 0.0	13 8 59176D+01	
546	4. 1537D+01	1 1 15133D-07	1 05500D+00 0.0	0.0 0.0	11 8 49107D+01	25 1 31427D+00
		1 7 59510D+01	3 8 05045D+01	5 8 22150D+01	21 9 05410D+01	24 1 39687D+02



547	4. 15927D+01	1 2. 58297D-05	1 0.55000+00	0 0 0	0 0	0 0	1 7 91171D-06	24 1. 38403D+02	25 9. 56563D-01
547	4. 15927D+01	2 2. 00729D-06	1 0.55000+00	0 0 0	0 0	0 0	2 5 01422D-07		
547	4. 15927D+01	1 1. 65131D-06	1 0.55000+00	0 0 0	0 0	0 0	11 8 49093D+01		13 8. 59167D+01
547	4. 15927D+01	1 1. 75950D+01	3 8 05035D+01	17 8 78737D+01	19 8 91174D+01	21 9 05233D+01	24 1. 37119D+02		
547	4. 15927D+01	1 1. 75950D+01	3 8 05035D+01	17 8 78737D+01	19 8 91174D+01	21 9 05233D+01	24 1. 37119D+02		
548	4. 16481D+01	1 9. 38866D-06	1 0.55000+00	0 0 0	0 0	0 0	1 5 39767D-06		25 9. 61119D-01
548	4. 16481D+01	1 9. 38866D-06	1 0.55000+00	0 0 0	0 0	0 0	2 7 19511D-07		
548	4. 16481D+01	1 1. 60624D-06	1 0.55000+00	0 0 0	0 0	0 0	11 8 49079D+01		13 8. 59157D+01
548	4. 16481D+01	1 1. 60624D-06	1 0.55000+00	0 0 0	0 0	0 0	24 1. 35839D+02		
548	4. 16481D+01	1 1. 75950D+01	3 8 05025D+01	17 8 78770D+01	19 8 91203D+01	21 9 05129D+01	24 1. 35839D+02		
548	4. 16481D+01	1 1. 75950D+01	3 8 05025D+01	17 8 78770D+01	19 8 91203D+01	21 9 05129D+01	24 1. 35839D+02		
549	4. 17036D+01	1 3. 27019D-06	1 0.55000+00	0 0 0	0 0	0 0	1 4 07363D-06		25 9. 68294D-01
549	4. 17036D+01	1 3. 27019D-06	1 0.55000+00	0 0 0	0 0	0 0	2 3 60981D-07		
549	4. 17036D+01	1 6. 51238D-07	1 0.55000+00	0 0 0	0 0	0 0	11 8 49066D+01		13 8. 59142D+01
549	4. 17036D+01	1 6. 51238D-07	1 0.55000+00	0 0 0	0 0	0 0	24 1. 34562D+02		
549	4. 17036D+01	1 1. 75950D+01	3 8 05015D+01	17 8 78803D+01	19 8 91230D+01	21 9 05020D+01	24 1. 34562D+02		
549	4. 17036D+01	1 1. 75950D+01	3 8 05015D+01	17 8 78803D+01	19 8 91230D+01	21 9 05020D+01	24 1. 34562D+02		
550	4. 17590D+01	1 2. 71981D-06	1 0.55000+00	0 0 0	0 0	0 0	1 3 00405D-06		25 9. 77084D-01
550	4. 17590D+01	1 2. 71981D-06	1 0.55000+00	0 0 0	0 0	0 0	2 1 63687D-07		
550	4. 17590D+01	1 2. 29172D-07	1 0.55000+00	0 0 0	0 0	0 0	11 8 49052D+01		13 8. 59146D+01
550	4. 17590D+01	1 1. 759496D+01	3 8 05006D+01	17 8 78836D+01	19 8 91256D+01	21 9 04908D+01	24 1. 33288D+02		
550	4. 17590D+01	1 1. 759496D+01	3 8 05006D+01	17 8 78836D+01	19 8 91256D+01	21 9 04908D+01	24 1. 33288D+02		
551	4. 18145D+01	1 1. 98644D-06	1 0.55000+00	0 0 0	0 0	0 0	1 2 26111D-06		25 9. 86927D-01
551	4. 18145D+01	1 1. 98644D-06	1 0.55000+00	0 0 0	0 0	0 0	2 1 50023D-07		
551	4. 18145D+01	1 2. 15528D-07	1 0.55000+00	0 0 0	0 0	0 0	11 8 49038D+01		25 1. 28937D+00
551	4. 18145D+01	1 1. 759493D+01	3 8 04956D+01	17 8 78868D+01	19 8 91280D+01	21 9 04792D+01	24 1. 32016D+02		
551	4. 18145D+01	1 1. 759493D+01	3 8 04956D+01	17 8 78868D+01	19 8 91280D+01	21 9 04792D+01	24 1. 32016D+02		
552	4. 18699D+01	1 2. 23889D-06	1 0.55000+00	0 0 0	0 0	0 0	1 2 04091D-06		25 9. 97491D-01
552	4. 18699D+01	1 2. 23889D-06	1 0.55000+00	0 0 0	0 0	0 0	2 1 77586D-07		
552	4. 18699D+01	1 2. 48809D-07	1 0.55000+00	0 0 0	0 0	0 0	11 8 49025D+01		13 8. 59123D+01
552	4. 18699D+01	1 1. 759489D+01	3 8 04987D+01	17 8 78900D+01	19 8 91302D+01	21 9 04672D+01	24 1. 30745D+02		
552	4. 18699D+01	1 1. 759489D+01	3 8 04987D+01	17 8 78900D+01	19 8 91302D+01	21 9 04672D+01	24 1. 30745D+02		
553	4. 19253D+01	1 2. 71560D-06	1 0.55000+00	0 0 0	0 0	0 0	1 1 84167D-06		25 1. 00961D+00
553	4. 19253D+01	1 2. 71560D-06	1 0.55000+00	0 0 0	0 0	0 0	2 2 01431D-07		
553	4. 19253D+01	1 4. 11514D-07	1 0.55000+00	0 0 0	0 0	0 0	1 1 30374D-06		25 9. 52852D-01
553	4. 19253D+01	1 5. 88026D-06	1 0.55000+00	0 0 0	0 0	0 0	2 3 37770D-07		
553	4. 19253D+01	1 5. 88026D-06	1 0.55000+00	0 0 0	0 0	0 0	11 8 49013D+01		13 8. 59115D+01
553	4. 19253D+01	1 9. 16811D-07	1 0.55000+00	0 0 0	0 0	0 0	24 1. 29548D+02		
553	4. 19253D+01	1 1. 759486D+01	3 8 04978D+01	17 8 78929D+01	19 8 91322D+01	21 9 04556D+01	24 1. 29548D+02		
553	4. 19253D+01	1 1. 759486D+01	3 8 04978D+01	17 8 78929D+01	19 8 91322D+01	21 9 04556D+01	24 1. 29548D+02		
554	4. 19611D+01	1 1. 44055D-05	1 0.55000+00	0 0 0	0 0	0 0	1 5 42734D-06		25 7. 26824D-01
554	4. 19611D+01	2 1. 35861D-06	1 0.55000+00	0 0 0	0 0	0 0	2 2 92085D-07		
554	4. 19611D+01	1 6. 59177D-07	1 0.55000+00	0 0 0	0 0	0 0	11 8 49004D+01		13 8. 59109D+01
554	4. 19611D+01	1 7. 59484D+01	3 8 04972D+01	17 8 78951D+01	19 8 91335D+01	21 9 04467D+01	24 1. 28653D+02		
554	4. 19611D+01	1 7. 59484D+01	3 8 04972D+01	17 8 78951D+01	19 8 91335D+01	21 9 04467D+01	24 1. 28653D+02		
555	4. 20000D+01	1 5. 74405D-06	1 0.55000+00	0 0 0	0 0	0 0	1 2 73925D-06		25 9. 18357D-01
555	4. 20000D+01	1 5. 74405D-06	1 0.55000+00	0 0 0	0 0	0 0	2 3 71597D-07		
555	4. 20000D+01	1 6. 77655D-07	1 0.55000+00	0 0 0	0 0	0 0	11 8 48994D+01		13 8. 59104D+01
555	4. 20000D+01	1 1. 759481D+01	3 8 04965D+01	17 8 78973D+01	19 8 91348D+01	21 9 04377D+01	24 1. 27756D+02		
555	4. 20000D+01	1 1. 759481D+01	3 8 04965D+01	17 8 78973D+01	19 8 91348D+01	21 9 04377D+01	24 1. 27756D+02		
555	4. 20000D+01	1 5. 86662D+01	17 8 78973D+01	17 8 78973D+01	19 8 91348D+01	21 9 04377D+01	24 1. 27756D+02		
555	4. 20000D+01	1 5. 86662D+01	17 8 78973D+01	17 8 78973D+01	19 8 91348D+01	21 9 04377D+01	24 1. 27756D+02		
555	4. 20000D+01	25 1. 25005D+02							

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 555 TIME STEPS, TIME = 4.200000E+01

HEATING 02/12/83  
W9XNP110

GROSS GRID	1	1
FINE GRID	1	1
DISTANCE	0.0	75195
1	0.0	78122
2	0.03	80150
3	0.06	81135
4	0.08	82121
5	0.10	82167
6	0.57	83113
7	1.04	83158
8	1.51	84103
9	1.98	84147
10	2.45	84190
11	2.92	85142
12	3.14	85191
13	3.35	86139
14	3.57	86187
15	3.79	87136
16	4.01	87190
17	4.23	88149
18	4.45	89113
19	4.67	89181
20	4.89	90144
21	5.10	106145
22	5.18	119177
23	5.25	127176
24	5.32	125100
25	5.35	

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	93.690000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 3.89380005D-02

ELAPSED CPU TIME IS 6.68 SECONDS (+-0.1 PERCENT)

THE MAXIMUM TEMPERATURE IS 1.27756D+02 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES 24

THE MINIMUM TEMPERATURE IS 7.59481D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES 1

NO	TIME	NO ITER	MAX RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	NODE	MAX PERCENT TEMP CHANGE	
556	4.20389D+01		4.74678D-07	1.05500D+00	0.0	0.0	0.0	1	1.40142D-06	25.9	190730-01	25.7	35232D-01
556	4.20389D+01		4.74678D-07	1.05500D+00	0.0	0.0	0.0	2	5.49632D-08				
556	4.20389D+01		1.77265D-08	1.05500D+00	0.0	0.0	0.0						
***** NODE NUMBERS AND TEMPERATURES *****													
TABLE FOR SPECIAL MONITORING OF TEMPERATURES													
557	4.20779D+01		1.831165D-07	1.05500D+00	0.0	0.0	0.0	1	1.50507D-06	25.9	20259D-01	25.7	41633D-01
557	4.20779D+01		1.831165D-07	1.05500D+00	0.0	0.0	0.0	2	8.9414D-08				
557	4.20779D+01		1.60076D-07	1.05500D+00	0.0	0.0	0.0	11	8.48976D+01	13.8	59093D+01		
557	4.20779D+01		1.759476D+01	3.804952D+01	5.822031D+01	19.891381D+01	21.904191D+01	24	1.25957D+02				
557	4.2078D+01		15.868705D+01	17.879015D+01	19.891370D+01	19.891370D+01	21.904191D+01	24	1.25957D+02				
558	4.21207D+01		3.11245D-06	1.05500D+00	0.0	0.0	0.0	1	1.88044D-06	25.8	20448D-01		
558	4.21207D+01		3.11245D-06	1.05500D+00	0.0	0.0	0.0	2	2.00842D-07	25.1	01051D+00	25.8	20448D-01
558	4.21207D+01		3.84350D-07	1.05500D+00	0.0	0.0	0.0	11	8.48967D+01	13.8	59087D+01		
558	4.2121D+01		1.759474D+01	3.804946D+01	5.822031D+01	19.891381D+01	21.904085D+01	24	1.24966D+02				
558	4.2121D+01		15.868712D+01	17.879039D+01	19.891381D+01	19.891381D+01	21.903962D+01	24	1.23875D+01				
559	4.2168D+01		1.01924D-06	1.05500D+00	0.0	0.0	0.0	1	1.34815D-06	25.1	11116D+00	25.9	09630D-01
559	4.2168D+01		1.01924D-06	1.05500D+00	0.0	0.0	0.0	2	7.45344D-08	25.1	11116D+00	25.9	09630D-01
559	4.2168D+01		1.08094D-07	1.05500D+00	0.0	0.0	0.0	5	8.22027D+01	11.8	48956D+01	13.8	59080D+01
559	4.2168D+01		1.759471D+01	3.804938D+01	5.822027D+01	19.891391D+01	21.903962D+01	24	1.23875D+01				
559	4.2168D+01		15.868720D+01	17.879064D+01	19.891391D+01	19.891391D+01	21.903962D+01	24	1.23875D+01				
560	4.22170D+01		5.06337D-06	1.05500D+00	0.0	0.0	0.0	1	2.40386D-06	25.9	16380D+00	25.9	61469D-01
560	4.22170D+01		5.06337D-06	1.05500D+00	0.0	0.0	0.0	2	3.23338D-07	25.1	16380D+00	25.9	61469D-01
560	4.22170D+01		7.50806D-07	1.05500D+00	0.0	0.0	0.0	11	8.48945D+01	13.8	59074D+01		
560	4.2217D+01		1.759468D+01	3.804930D+01	5.822013D+01	19.89141D+01	21.903843D+01	24	1.22734D+02				
560	4.2217D+01		15.868728D+01	17.879089D+01	19.89141D+01	19.89141D+01	21.903843D+01	24	1.22734D+02				
561	4.22662D+01		8.44825D-06	1.05500D+00	0.0	0.0	0.0	1	3.48303D-06	25.1	16935D+00	25.9	75436D-01
561	4.22662D+01		8.44825D-06	1.05500D+00	0.0	0.0	0.0	2	5.31092D-07	25.1	16935D+00	25.9	75436D-01
561	4.22662D+01		1.31896D-06	1.05500D+00	0.0	0.0	0.0	11	8.48934D+01	13.8	59067D+01		
561	4.2266D+01		1.759465D+01	3.804922D+01	5.822004D+01	19.891409D+01	21.903714D+01	24	1.21591D+02				
561	4.2266D+01		15.868736D+01	17.879115D+01	19.891409D+01	19.891409D+01	21.903714D+01	24	1.21591D+02				
562	4.23154D+01		6.38790D-06	1.05500D+00	0.0	0.0	0.0	1	3.51737D-06	25.9	17390D+00	25.9	88875D-01
562	4.23154D+01		6.38790D-06	1.05500D+00	0.0	0.0	0.0	2	4.58175D-07	25.1	17390D+00	25.9	88875D-01
562	4.23154D+01		1.10107D-06	1.05500D+00	0.0	0.0	0.0	11	8.48924D+01	13.8	59061D+01		
562	4.2315D+01		1.759463D+01	3.804915D+01	5.821995D+01	19.891416D+01	21.903584D+01	24	1.20445D+02				
562	4.2315D+01		15.868745D+01	17.879140D+01	19.891416D+01	19.891416D+01	21.903584D+01	24	1.20445D+02				
563	4.23646D+01		5.58428D-06	1.05500D+00	0.0	0.0	0.0	1	3.63749D-06	25.1	17809D+00	25.1	00232D+00
563	4.23646D+01		5.58428D-06	1.05500D+00	0.0	0.0	0.0	2	4.30910D-07	25.1	17809D+00	25.1	00232D+00
563	4.23646D+01		1.00593D-06	1.05500D+00	0.0	0.0	0.0	11	8.48914D+01	13.8	59055D+01		
563	4.23621D+01		4.14346D-06	1.05500D+00	0.0	0.0	0.0	1	1.05621D-06	25.1	11921D+00	25.9	52277D-01
563	4.23621D+01		4.14346D-06	1.05500D+00	0.0	0.0	0.0	2	2.32659D-07	25.1	11921D+00	25.9	52277D-01
563	4.23621D+01		5.56118D-07	1.05500D+00	0.0	0.0	0.0	11	8.48914D+01	13.8	59055D+01		
563	4.23621D+01		1.759460D+01	3.804907D+01	5.821986D+01	19.891421D+01	21.903457D+01	24	1.19356D+02				
563	4.2362D+01		15.868753D+01	17.879164D+01	19.891421D+01	19.891421D+01	21.903457D+01	24	1.19356D+02				
564	4.24087D+01		2.45906D-06	1.05500D+00	0.0	0.0	0.0	1	3.27896D-06	25.9	12187D+00	25.9	63663D-01
564	4.24087D+01		2.45906D-06	1.05500D+00	0.0	0.0	0.0	2	2.76884D-07	25.1	12187D+00	25.9	63663D-01
564	4.24087D+01		5.70354D-07	1.05500D+00	0.0	0.0	0.0	11	8.48904D+01	13.8	59050D+01		
564	4.2409D+01		1.759457D+01	3.804500D+01	5.821978D+01	19.891425D+01	21.903329D+01	24	1.18264D+02				
564	4.2409D+01		15.868761D+01	17.879187D+01	19.891425D+01	19.891425D+01	21.903329D+01	24	1.18264D+02				
565	4.24554D+01		3.33694D-06	1.05500D+00	0.0	0.0	0.0	1	3.27896D-06	25.9	12187D+00	25.9	63663D-01

565	4. 245540+01	1 3 326940-06	1 055000+00	0 0	0 0	0 0	1 3 418820-06	25 9 757160-01
565	4. 245540+01	1 6 683960-07	1 055000+00	0 0	0 0	0 0	2 3 125870-07	
565	4. 245550+01	1 7 594550+01	3 8 048930+01	5 8 219690+01	19 8 914270+01	21 9 031980+01	11 8 488930+01	25 1 124960+00
565	4. 245550+01	15 8 687690+01	17 8 792090+01	19 8 914270+01	21 9 031980+01	24 1 171670+02	24 1 171670+02	
566	4. 250200+01	25 1 141700+02	1 055000+00	0 0	0 0	0 0	1 3 627530-06	25 9 884150-01
566	4. 250200+01	1 4 136040-06	1 055000+00	0 0	0 0	0 0	2 3 516000-07	
566	4. 250200+01	1 4 136040-06	1 055000+00	0 0	0 0	0 0	1 9 084280-06	25 9 806560-01
566	4. 250200+01	1 7 660790-07	1 055000+00	0 0	0 0	0 0	2 6 237960-07	
566	4. 250200+01	1 7 594520+01	3 8 048860+01	5 8 219610+01	19 8 914290+01	21 9 030650+01	11 8 488840+01	25 1 108550+00
567	4. 25490+01	15 8 687770+01	17 8 792320+01	19 8 914290+01	21 9 030650+01	24 1 160670+02	11 8 488740+01	25 1 149680+02
567	4. 25490+01	25 1 130420+02	1 055000+00	0 0	0 0	0 0	1 9 084280-06	
567	4. 254860+01	1 3 382150-05	1 055000+00	0 0	0 0	0 0	2 6 237960-07	25 1 108550+00
567	4. 254860+01	2 2 872480-06	1 055000+00	0 0	0 0	0 0	2 9 416930-07	
567	4. 254860+01	1 1 658470-06	1 055000+00	0 0	0 0	0 0	11 8 488650+01	24 1 138760+02
567	4. 25490+01	1 7 594500+01	3 8 048790+01	5 8 219530+01	19 8 914290+01	21 9 029300+01	11 8 488740+01	24 1 149680+02
567	4. 25490+01	15 8 687850+01	17 8 792540+01	19 8 914290+01	21 9 029300+01	24 1 149680+02	21 9 029300+01	
568	4. 259530+01	25 1 119330+02	1 055000+00	0 0	0 0	0 0	1 1 565760-05	25 9 627510-01
568	4. 259530+01	1 4 902710-05	1 055000+00	0 0	0 0	0 0	2 9 416930-07	
568	4. 259530+01	2 4 372240-06	1 055000+00	0 0	0 0	0 0	1 1 565760-05	
568	4. 259530+01	1 2 524280-06	1 055000+00	0 0	0 0	0 0	2 9 416930-07	24 1 092190+00
568	4. 259530+01	1 7 594470+01	3 8 048720+01	5 8 219450+01	19 8 914270+01	21 9 027930+01	11 8 488650+01	24 1 138760+02
568	4. 259530+01	15 8 687930+01	17 8 792750+01	19 8 914270+01	21 9 027930+01	24 1 138760+02	21 9 027930+01	
569	4. 264190+01	25 1 108560+02	1 055000+00	0 0	0 0	0 0	1 1 233100-05	25 9 552150-01
569	4. 264190+01	1 2 571870-05	1 055000+00	0 0	0 0	0 0	2 5 662950-07	
569	4. 264190+01	2 2 542970-06	1 055000+00	0 0	0 0	0 0	1 1 085500-05	25 9 527670-01
569	4. 264190+01	1 1 561980-06	1 055000+00	0 0	0 0	0 0	2 3 766720-07	
569	4. 264190+01	1 7 594450+01	3 8 048660+01	5 8 219360+01	19 8 914250+01	21 9 025530+01	11 8 488560+01	24 1 127960+02
569	4. 26420+01	15 8 688020+01	17 8 792960+01	19 8 914250+01	21 9 025530+01	24 1 127960+02	21 9 025530+01	
570	4. 268850+01	25 1 097970+02	1 055000+00	0 0	0 0	0 0	1 1 085500-05	25 9 527670-01
570	4. 268850+01	1 1 503540-05	1 055000+00	0 0	0 0	0 0	2 3 766720-07	
570	4. 268850+01	2 1 669830-06	1 055000+00	0 0	0 0	0 0	1 1 085500-05	
570	4. 268850+01	1 0 663240-06	1 055000+00	0 0	0 0	0 0	2 3 766720-07	24 1 067020+00
570	4. 268890+01	1 7 594420+01	3 8 048590+01	5 8 219280+01	19 8 914210+01	21 9 025120+01	11 8 488460+01	24 1 117290+02
570	4. 268890+01	15 8 688100+01	17 8 793170+01	19 8 914210+01	21 9 025120+01	24 1 117290+02	21 9 025120+01	
571	4. 273520+01	25 1 087510+02	1 055000+00	0 0	0 0	0 0	1 9 342750-06	25 9 531380-01
571	4. 273520+01	1 9 869650-06	1 055000+00	0 0	0 0	0 0	2 1 034300-06	
571	4. 273520+01	1 9 869650-06	1 055000+00	0 0	0 0	0 0	1 9 342750-06	
571	4. 273520+01	1 2 113510-06	1 055000+00	0 0	0 0	0 0	2 1 034300-06	24 1 054520+00
571	4. 273520+01	1 7 594400+01	3 8 048520+01	5 8 219210+01	19 8 914150+01	21 9 023680+01	11 8 488370+01	24 1 106740+02
571	4. 27350+01	15 8 688180+01	17 8 793380+01	19 8 914150+01	21 9 023680+01	24 1 106740+02	21 9 023680+01	
572	4. 278180+01	25 1 077140+02	1 055000+00	0 0	0 0	0 0	1 8 479030-06	25 9 552600-01
572	4. 278180+01	1 7 229660-06	1 055000+00	0 0	0 0	0 0	2 8 363490-07	
572	4. 278180+01	1 7 229660-06	1 055000+00	0 0	0 0	0 0	1 8 479030-06	
572	4. 278180+01	1 1 651410-06	1 055000+00	0 0	0 0	0 0	2 8 363490-07	24 1 043430+00
572	4. 27820+01	1 7 594370+01	3 8 048460+01	5 8 219130+01	19 8 914090+01	21 9 022220+01	11 8 488280+01	24 1 085970+02
572	4. 27820+01	15 8 688260+01	17 8 793580+01	19 8 914090+01	21 9 022220+01	24 1 085970+02	21 9 022220+01	
573	4. 282850+01	25 1 066850+02	1 055000+00	0 0	0 0	0 0	1 7 947160-06	25 9 585450-01
573	4. 282850+01	1 5 775100-06	1 055000+00	0 0	0 0	0 0	2 7 142540-07	
573	4. 282850+01	1 5 775100-06	1 055000+00	0 0	0 0	0 0	1 7 947160-06	
573	4. 282850+01	1 4 146800-06	1 055000+00	0 0	0 0	0 0	2 7 142540-07	24 1 033620+00
573	4. 28280+01	1 7 594350+01	3 8 048390+01	5 8 219050+01	19 8 914010+01	21 9 020740+01	11 8 488190+01	24 1 085970+02
573	4. 28280+01	15 8 688340+01	17 8 793770+01	19 8 914010+01	21 9 020740+01	24 1 085970+02	21 9 020740+01	
574	4. 287510+01	25 1 055630+02	1 055000+00	0 0	0 0	0 0	1 7 339650-06	25 9 629460-01
574	4. 287510+01	1 4 412660-06	1 055000+00	0 0	0 0	0 0	2 5 873490-07	
574	4. 287510+01	1 4 412660-06	1 055000+00	0 0	0 0	0 0	1 7 339650-06	
574	4. 287510+01	1 1 142140-06	1 055000+00	0 0	0 0	0 0	2 5 873490-07	24 1 025080+00
574	4. 287510+01	1 7 594330+01	3 8 048320+01	5 8 218970+01	19 8 913920+01	21 9 019240+01	11 8 488100+01	24 1 075720+02
574	4. 28750+01	15 8 688430+01	17 8 793960+01	19 8 913920+01	21 9 019240+01	24 1 075720+02	21 9 019240+01	
575	4. 292170+01	25 1 046450+02	1 055000+00	0 0	0 0	0 0	1 6 776360-06	25 9 682330-01
575	4. 292170+01	1 3 515270-06	1 055000+00	0 0	0 0	0 0	2 4 928770-07	
575	4. 292170+01	1 3 515270-06	1 055000+00	0 0	0 0	0 0	1 6 776360-06	
575	4. 292170+01	1 9 588110-07	1 055000+00	0 0	0 0	0 0	2 4 928770-07	24 1 017690+00
575	4. 29220+01	1 7 594300+01	3 8 048260+01	5 8 218900+01	19 8 913810+01	21 9 017730+01	11 8 488010+01	24 1 065540+02
575	4. 29220+01	15 8 688510+01	17 8 794150+01	19 8 913810+01	21 9 017730+01	24 1 065540+02	21 9 017730+01	
576	4. 296090+01	25 1 036320+02	1 055000+00	0 0	0 0	0 0	1 6 776360-06	25 9 682330-01
576	4. 296090+01	1 7 551050-06	1 055000+00	0 0	0 0	0 0	2 4 928770-07	
576	4. 296090+01	1 7 551050-06	1 055000+00	0 0	0 0	0 0	1 6 776360-06	

576	4.23609D+01	1 7.55105D-06	1.05500D+00	0.0	0.0	0.0	1 5.08976D-06	25 8.23643D-01
576	4.29609D+01	1 7.76675D-07	1.05500D+00	0.0	0.0	0.0	2 4.74139D-07	25 8.53557D-01
576	4.2961D+01	1 7.59428D+01	3 8.04821D+01	5 8.21887D+01	11 8.48794D+01	13 8.58991D+01	11 8.48794D+01	24 1.05704D+02
		15 8.68858D+01	17 8.73430D+01	19 8.91371D+01	21 9.01644D+01	24 1.05704D+02		
577	4.30000D+01	1 4.57281D-06	1.05500D+00	0.0	0.0	0.0	1 4.40795D-06	25 8.26539D-01
577	4.30000D+01	1 4.57281D-06	1.05500D+00	0.0	0.0	0.0	2 3.70775D-07	25 8.49504D-01
577	4.30000D+01	1 7.76777D-07	1.05500D+00	0.0	0.0	0.0	11 8.48787D+01	13 8.58987D+01
577	4.30000D+01	1 7.59426D+01	3 8.04815D+01	5 8.21877D+01	11 8.48787D+01	13 8.58987D+01	21 9.01514D+01	24 1.04857D+02
577	4.30000D+01	15 8.68865D+01	17 8.79446D+01	19 8.91361D+01	21 9.01514D+01	24 1.04857D+02		
		25 1.01929D+02						

HEATING6 02/12/83  
W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 577 TIME STEPS, TIME = 4.300000+01

18M3033/ 0  
20.58.12 11-16-89

GRASS GRID	1	1
FINE GRID	0	0
DISTANCE	0	0
1	0.0	75154
2	0.03	78121
3	0.06	80148
4	0.08	81134
5	0.10	82119
6	0.57	82165
7	1.04	83111
8	1.51	83156
9	1.98	84100
10	2.45	84144
11	2.92	84188
12	3.14	85140
13	3.35	85190
14	3.57	86139
15	3.79	86189
16	4.01	87140
17	4.23	87194
18	4.45	88153
19	4.67	89114
20	4.89	89172
21	5.10	90115
22	5.18	98161
23	5.25	104135
10 24	5.32	104186
11 25	5.35	101193

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	92.730000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 3.91357474D-02

ELAPSED CPU TIME IS 6.91 SECONDS

THE MAXIMUM TEMPERATURE IS 1.04857D+02 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES 24

THE MINIMUM TEMPERATURE IS 7.59426D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES 1

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	MODE	MAX PERCENT TEMP CHANGE			
578	4.30430D+01	1	5.92895D-06	1.055000E+00	0.0	0.0	0.0	1	5.13477D-06	25	9	29785D-01	25	9	12190D-01
578	4.30430D+01	1	5.82895D-06	1.055000E+00	0.0	0.0	0.0	2	4.56906D-07	25	9	29785D-01	25	9	12190D-01
578	4.30430D+01	1	9.95452D-07	1.055000E+00	0.0	0.0	0.0	2	4.56906D-07	25	9	29785D-01	25	9	12190D-01

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NUMBER OF TIME	MODE NUMBERS AND TEMPERATURES																																																																																																																																																		
578	<table border="1"> <tr> <td>3</td> <td>8</td> <td>04810D+01</td> <td>5</td> <td>8</td> <td>21870D+01</td> <td>11</td> <td>8</td> <td>48779D+01</td> <td>13</td> <td>8</td> <td>58983D+01</td> </tr> <tr> <td>15</td> <td>8</td> <td>68872D+01</td> <td>17</td> <td>8</td> <td>79462D+01</td> <td>19</td> <td>8</td> <td>91348D+01</td> <td>21</td> <td>9</td> <td>01369D+01</td> <td>24</td> <td>1</td> <td>03929D+02</td> </tr> <tr> <td>25</td> <td>1</td> <td>00999D+02</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>	3	8	04810D+01	5	8	21870D+01	11	8	48779D+01	13	8	58983D+01	15	8	68872D+01	17	8	79462D+01	19	8	91348D+01	21	9	01369D+01	24	1	03929D+02	25	1	00999D+02																																																																																																																				
3	8	04810D+01	5	8	21870D+01	11	8	48779D+01	13	8	58983D+01																																																																																																																																								
15	8	68872D+01	17	8	79462D+01	19	8	91348D+01	21	9	01369D+01	24	1	03929D+02																																																																																																																																					
25	1	00999D+02																																																																																																																																																	
579	<table border="1"> <tr> <td>1</td> <td>3</td> <td>1163D-06</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>1</td> <td>4</td> <td>18203D-06</td> </tr> <tr> <td>1</td> <td>3</td> <td>1163D-06</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>2</td> <td>1</td> <td>59974D-07</td> <td>25</td> <td>9</td> <td>66886D-01</td> <td>25</td> <td>9</td> <td>57321D-01</td> </tr> <tr> <td>1</td> <td>2</td> <td>73835D-07</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>11</td> <td>8</td> <td>48771D+01</td> <td>13</td> <td>8</td> <td>58979D+01</td> <td></td> <td></td> <td></td> </tr> <tr> <td>1</td> <td>7</td> <td>59422D+01</td> <td>3</td> <td>8</td> <td>01804D+01</td> <td>5</td> <td>8</td> <td>21863D+01</td> <td>11</td> <td>8</td> <td>48771D+01</td> <td>13</td> <td>8</td> <td>58979D+01</td> <td>24</td> <td>1</td> <td>02967D+02</td> </tr> <tr> <td>15</td> <td>8</td> <td>68880D+01</td> <td>17</td> <td>8</td> <td>79478D+01</td> <td>19</td> <td>8</td> <td>91333D+01</td> <td>21</td> <td>9</td> <td>01217D+01</td> <td>24</td> <td>1</td> <td>02967D+02</td> <td></td> <td></td> <td></td> </tr> <tr> <td>25</td> <td>1</td> <td>00032D+02</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>	1	3	1163D-06	1	05500E+00	0.0	0.0	0.0	1	4	18203D-06	1	3	1163D-06	1	05500E+00	0.0	0.0	0.0	2	1	59974D-07	25	9	66886D-01	25	9	57321D-01	1	2	73835D-07	1	05500E+00	0.0	0.0	0.0	11	8	48771D+01	13	8	58979D+01				1	7	59422D+01	3	8	01804D+01	5	8	21863D+01	11	8	48771D+01	13	8	58979D+01	24	1	02967D+02	15	8	68880D+01	17	8	79478D+01	19	8	91333D+01	21	9	01217D+01	24	1	02967D+02				25	1	00032D+02																																																														
1	3	1163D-06	1	05500E+00	0.0	0.0	0.0	1	4	18203D-06																																																																																																																																									
1	3	1163D-06	1	05500E+00	0.0	0.0	0.0	2	1	59974D-07	25	9	66886D-01	25	9	57321D-01																																																																																																																																			
1	2	73835D-07	1	05500E+00	0.0	0.0	0.0	11	8	48771D+01	13	8	58979D+01																																																																																																																																						
1	7	59422D+01	3	8	01804D+01	5	8	21863D+01	11	8	48771D+01	13	8	58979D+01	24	1	02967D+02																																																																																																																																		
15	8	68880D+01	17	8	79478D+01	19	8	91333D+01	21	9	01217D+01	24	1	02967D+02																																																																																																																																					
25	1	00032D+02																																																																																																																																																	
580	<table border="1"> <tr> <td>1</td> <td>2</td> <td>78782D-06</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>1</td> <td>3</td> <td>55837D-06</td> </tr> <tr> <td>1</td> <td>2</td> <td>78782D-06</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>2</td> <td>1</td> <td>79171D-07</td> <td>25</td> <td>9</td> <td>67427D-01</td> <td>25</td> <td>9</td> <td>67115D-01</td> </tr> <tr> <td>1</td> <td>1</td> <td>90715D-07</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>11</td> <td>8</td> <td>48763D+01</td> <td>13</td> <td>8</td> <td>58975D+01</td> <td></td> <td></td> <td></td> </tr> <tr> <td>1</td> <td>7</td> <td>59420D+01</td> <td>3</td> <td>8</td> <td>04798D+01</td> <td>5</td> <td>8</td> <td>21857D+01</td> <td>11</td> <td>8</td> <td>48763D+01</td> <td>13</td> <td>8</td> <td>58975D+01</td> <td>24</td> <td>1</td> <td>02007D+02</td> </tr> <tr> <td>15</td> <td>8</td> <td>68880D+01</td> <td>17</td> <td>8</td> <td>79454D+01</td> <td>19</td> <td>8</td> <td>91317D+01</td> <td>21</td> <td>9</td> <td>01063D+01</td> <td>24</td> <td>1</td> <td>02007D+02</td> <td></td> <td></td> <td></td> </tr> <tr> <td>25</td> <td>9</td> <td>80648D+01</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>	1	2	78782D-06	1	05500E+00	0.0	0.0	0.0	1	3	55837D-06	1	2	78782D-06	1	05500E+00	0.0	0.0	0.0	2	1	79171D-07	25	9	67427D-01	25	9	67115D-01	1	1	90715D-07	1	05500E+00	0.0	0.0	0.0	11	8	48763D+01	13	8	58975D+01				1	7	59420D+01	3	8	04798D+01	5	8	21857D+01	11	8	48763D+01	13	8	58975D+01	24	1	02007D+02	15	8	68880D+01	17	8	79454D+01	19	8	91317D+01	21	9	01063D+01	24	1	02007D+02				25	9	80648D+01																																																														
1	2	78782D-06	1	05500E+00	0.0	0.0	0.0	1	3	55837D-06																																																																																																																																									
1	2	78782D-06	1	05500E+00	0.0	0.0	0.0	2	1	79171D-07	25	9	67427D-01	25	9	67115D-01																																																																																																																																			
1	1	90715D-07	1	05500E+00	0.0	0.0	0.0	11	8	48763D+01	13	8	58975D+01																																																																																																																																						
1	7	59420D+01	3	8	04798D+01	5	8	21857D+01	11	8	48763D+01	13	8	58975D+01	24	1	02007D+02																																																																																																																																		
15	8	68880D+01	17	8	79454D+01	19	8	91317D+01	21	9	01063D+01	24	1	02007D+02																																																																																																																																					
25	9	80648D+01																																																																																																																																																	
581	<table border="1"> <tr> <td>1</td> <td>1</td> <td>86576D-06</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>1</td> <td>3</td> <td>00852D-06</td> </tr> <tr> <td>1</td> <td>1</td> <td>86576D-06</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>2</td> <td>1</td> <td>37275D-07</td> <td>25</td> <td>9</td> <td>67745D-01</td> <td>25</td> <td>9</td> <td>76881D-01</td> </tr> <tr> <td>1</td> <td>1</td> <td>38165D-07</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>11</td> <td>8</td> <td>48755D+01</td> <td>13</td> <td>8</td> <td>58971D+01</td> <td></td> <td></td> <td></td> </tr> <tr> <td>1</td> <td>7</td> <td>59418D+01</td> <td>3</td> <td>8</td> <td>04792D+01</td> <td>5</td> <td>8</td> <td>21850D+01</td> <td>11</td> <td>8</td> <td>48755D+01</td> <td>13</td> <td>8</td> <td>58971D+01</td> <td>24</td> <td>1</td> <td>01049D+02</td> </tr> <tr> <td>15</td> <td>8</td> <td>68896D+01</td> <td>17</td> <td>8</td> <td>78510D+01</td> <td>19</td> <td>8</td> <td>91300D+01</td> <td>21</td> <td>9</td> <td>00908D+01</td> <td>24</td> <td>1</td> <td>01049D+02</td> <td></td> <td></td> <td></td> </tr> <tr> <td>25</td> <td>9</td> <td>80971D+01</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>	1	1	86576D-06	1	05500E+00	0.0	0.0	0.0	1	3	00852D-06	1	1	86576D-06	1	05500E+00	0.0	0.0	0.0	2	1	37275D-07	25	9	67745D-01	25	9	76881D-01	1	1	38165D-07	1	05500E+00	0.0	0.0	0.0	11	8	48755D+01	13	8	58971D+01				1	7	59418D+01	3	8	04792D+01	5	8	21850D+01	11	8	48755D+01	13	8	58971D+01	24	1	01049D+02	15	8	68896D+01	17	8	78510D+01	19	8	91300D+01	21	9	00908D+01	24	1	01049D+02				25	9	80971D+01																																																														
1	1	86576D-06	1	05500E+00	0.0	0.0	0.0	1	3	00852D-06																																																																																																																																									
1	1	86576D-06	1	05500E+00	0.0	0.0	0.0	2	1	37275D-07	25	9	67745D-01	25	9	76881D-01																																																																																																																																			
1	1	38165D-07	1	05500E+00	0.0	0.0	0.0	11	8	48755D+01	13	8	58971D+01																																																																																																																																						
1	7	59418D+01	3	8	04792D+01	5	8	21850D+01	11	8	48755D+01	13	8	58971D+01	24	1	01049D+02																																																																																																																																		
15	8	68896D+01	17	8	78510D+01	19	8	91300D+01	21	9	00908D+01	24	1	01049D+02																																																																																																																																					
25	9	80971D+01																																																																																																																																																	
582	<table border="1"> <tr> <td>1</td> <td>1</td> <td>26699D-06</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>1</td> <td>2</td> <td>58553D-06</td> </tr> <tr> <td>1</td> <td>1</td> <td>26699D-06</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>2</td> <td>1</td> <td>14163D-07</td> <td>25</td> <td>9</td> <td>67966D-01</td> <td>25</td> <td>9</td> <td>86743D-01</td> </tr> <tr> <td>1</td> <td>8</td> <td>17288D-08</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>11</td> <td>8</td> <td>48748D+01</td> <td>13</td> <td>8</td> <td>58966D+01</td> <td></td> <td></td> <td></td> </tr> <tr> <td>1</td> <td>7</td> <td>53416D+01</td> <td>3</td> <td>8</td> <td>04786D+01</td> <td>5</td> <td>8</td> <td>21843D+01</td> <td>11</td> <td>8</td> <td>48748D+01</td> <td>13</td> <td>8</td> <td>58966D+01</td> <td>24</td> <td>1</td> <td>00092D+02</td> </tr> <tr> <td>15</td> <td>8</td> <td>68904D+01</td> <td>17</td> <td>8</td> <td>79525D+01</td> <td>19</td> <td>8</td> <td>91282D+01</td> <td>21</td> <td>9</td> <td>00752D+01</td> <td>24</td> <td>1</td> <td>00092D+02</td> <td></td> <td></td> <td></td> </tr> <tr> <td>25</td> <td>8</td> <td>71291D+01</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>	1	1	26699D-06	1	05500E+00	0.0	0.0	0.0	1	2	58553D-06	1	1	26699D-06	1	05500E+00	0.0	0.0	0.0	2	1	14163D-07	25	9	67966D-01	25	9	86743D-01	1	8	17288D-08	1	05500E+00	0.0	0.0	0.0	11	8	48748D+01	13	8	58966D+01				1	7	53416D+01	3	8	04786D+01	5	8	21843D+01	11	8	48748D+01	13	8	58966D+01	24	1	00092D+02	15	8	68904D+01	17	8	79525D+01	19	8	91282D+01	21	9	00752D+01	24	1	00092D+02				25	8	71291D+01																																																														
1	1	26699D-06	1	05500E+00	0.0	0.0	0.0	1	2	58553D-06																																																																																																																																									
1	1	26699D-06	1	05500E+00	0.0	0.0	0.0	2	1	14163D-07	25	9	67966D-01	25	9	86743D-01																																																																																																																																			
1	8	17288D-08	1	05500E+00	0.0	0.0	0.0	11	8	48748D+01	13	8	58966D+01																																																																																																																																						
1	7	53416D+01	3	8	04786D+01	5	8	21843D+01	11	8	48748D+01	13	8	58966D+01	24	1	00092D+02																																																																																																																																		
15	8	68904D+01	17	8	79525D+01	19	8	91282D+01	21	9	00752D+01	24	1	00092D+02																																																																																																																																					
25	8	71291D+01																																																																																																																																																	
583	<table border="1"> <tr> <td>1</td> <td>1</td> <td>54407D-05</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>1</td> <td>5</td> <td>52575D-06</td> </tr> <tr> <td>2</td> <td>1</td> <td>33710D-06</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>2</td> <td>2</td> <td>68489D-07</td> <td>25</td> <td>9</td> <td>76221D-01</td> <td>25</td> <td>1</td> <td>00508D+00</td> </tr> <tr> <td>1</td> <td>6</td> <td>56928D-07</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>11</td> <td>8</td> <td>48740D+01</td> <td>13</td> <td>8</td> <td>58964D+01</td> <td></td> <td></td> <td></td> </tr> <tr> <td>1</td> <td>3</td> <td>02069D-06</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>1</td> <td>8</td> <td>69161D-07</td> <td>25</td> <td>9</td> <td>24473D-01</td> <td>25</td> <td>9</td> <td>51798D-01</td> </tr> <tr> <td>1</td> <td>3</td> <td>02069D-06</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>2</td> <td>1</td> <td>80393D-07</td> <td>13</td> <td>8</td> <td>58964D+01</td> <td></td> <td></td> <td></td> </tr> <tr> <td>1</td> <td>4</td> <td>16367D-07</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>11</td> <td>8</td> <td>48740D+01</td> <td>13</td> <td>8</td> <td>58964D+01</td> <td>24</td> <td>9</td> <td>91881D+01</td> </tr> <tr> <td>1</td> <td>7</td> <td>59414D+01</td> <td>3</td> <td>8</td> <td>04781D+01</td> <td>5</td> <td>8</td> <td>21837D+01</td> <td>11</td> <td>8</td> <td>48740D+01</td> <td>13</td> <td>8</td> <td>58964D+01</td> <td>24</td> <td>9</td> <td>91881D+01</td> </tr> <tr> <td>15</td> <td>8</td> <td>68911D+01</td> <td>17</td> <td>8</td> <td>79539D+01</td> <td>19</td> <td>8</td> <td>91264D+01</td> <td>21</td> <td>9</td> <td>00602D+01</td> <td>24</td> <td>9</td> <td>91881D+01</td> <td></td> <td></td> <td></td> </tr> <tr> <td>25</td> <td>9</td> <td>62046D+01</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>	1	1	54407D-05	1	05500E+00	0.0	0.0	0.0	1	5	52575D-06	2	1	33710D-06	1	05500E+00	0.0	0.0	0.0	2	2	68489D-07	25	9	76221D-01	25	1	00508D+00	1	6	56928D-07	1	05500E+00	0.0	0.0	0.0	11	8	48740D+01	13	8	58964D+01				1	3	02069D-06	1	05500E+00	0.0	0.0	0.0	1	8	69161D-07	25	9	24473D-01	25	9	51798D-01	1	3	02069D-06	1	05500E+00	0.0	0.0	0.0	2	1	80393D-07	13	8	58964D+01				1	4	16367D-07	1	05500E+00	0.0	0.0	0.0	11	8	48740D+01	13	8	58964D+01	24	9	91881D+01	1	7	59414D+01	3	8	04781D+01	5	8	21837D+01	11	8	48740D+01	13	8	58964D+01	24	9	91881D+01	15	8	68911D+01	17	8	79539D+01	19	8	91264D+01	21	9	00602D+01	24	9	91881D+01				25	9	62046D+01											
1	1	54407D-05	1	05500E+00	0.0	0.0	0.0	1	5	52575D-06																																																																																																																																									
2	1	33710D-06	1	05500E+00	0.0	0.0	0.0	2	2	68489D-07	25	9	76221D-01	25	1	00508D+00																																																																																																																																			
1	6	56928D-07	1	05500E+00	0.0	0.0	0.0	11	8	48740D+01	13	8	58964D+01																																																																																																																																						
1	3	02069D-06	1	05500E+00	0.0	0.0	0.0	1	8	69161D-07	25	9	24473D-01	25	9	51798D-01																																																																																																																																			
1	3	02069D-06	1	05500E+00	0.0	0.0	0.0	2	1	80393D-07	13	8	58964D+01																																																																																																																																						
1	4	16367D-07	1	05500E+00	0.0	0.0	0.0	11	8	48740D+01	13	8	58964D+01	24	9	91881D+01																																																																																																																																			
1	7	59414D+01	3	8	04781D+01	5	8	21837D+01	11	8	48740D+01	13	8	58964D+01	24	9	91881D+01																																																																																																																																		
15	8	68911D+01	17	8	79539D+01	19	8	91264D+01	21	9	00602D+01	24	9	91881D+01																																																																																																																																					
25	9	62046D+01																																																																																																																																																	
584	<table border="1"> <tr> <td>1</td> <td>1</td> <td>60369D-05</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>1</td> <td>6</td> <td>95817D-06</td> </tr> <tr> <td>2</td> <td>1</td> <td>50950D-06</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>2</td> <td>2</td> <td>93805D-07</td> <td>25</td> <td>9</td> <td>34422D-01</td> <td>25</td> <td>9</td> <td>71285D-01</td> </tr> <tr> <td>1</td> <td>6</td> <td>79900D-07</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>11</td> <td>8</td> <td>48733D+01</td> <td>13</td> <td>8</td> <td>58961D+01</td> <td></td> <td></td> <td></td> </tr> <tr> <td>1</td> <td>7</td> <td>59412D+01</td> <td>3</td> <td>8</td> <td>04776D+01</td> <td>5</td> <td>8</td> <td>21830D+01</td> <td>11</td> <td>8</td> <td>48733D+01</td> <td>13</td> <td>8</td> <td>58961D+01</td> <td>24</td> <td>9</td> <td>82808D+01</td> </tr> <tr> <td>15</td> <td>8</td> <td>68918D+01</td> <td>17</td> <td>8</td> <td>79553D+01</td> <td>19</td> <td>8</td> <td>91245D+01</td> <td>21</td> <td>9</td> <td>00452D+01</td> <td>24</td> <td>9</td> <td>82808D+01</td> <td></td> <td></td> <td></td> </tr> <tr> <td>25</td> <td>9</td> <td>52702D+01</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>	1	1	60369D-05	1	05500E+00	0.0	0.0	0.0	1	6	95817D-06	2	1	50950D-06	1	05500E+00	0.0	0.0	0.0	2	2	93805D-07	25	9	34422D-01	25	9	71285D-01	1	6	79900D-07	1	05500E+00	0.0	0.0	0.0	11	8	48733D+01	13	8	58961D+01				1	7	59412D+01	3	8	04776D+01	5	8	21830D+01	11	8	48733D+01	13	8	58961D+01	24	9	82808D+01	15	8	68918D+01	17	8	79553D+01	19	8	91245D+01	21	9	00452D+01	24	9	82808D+01				25	9	52702D+01																																																														
1	1	60369D-05	1	05500E+00	0.0	0.0	0.0	1	6	95817D-06																																																																																																																																									
2	1	50950D-06	1	05500E+00	0.0	0.0	0.0	2	2	93805D-07	25	9	34422D-01	25	9	71285D-01																																																																																																																																			
1	6	79900D-07	1	05500E+00	0.0	0.0	0.0	11	8	48733D+01	13	8	58961D+01																																																																																																																																						
1	7	59412D+01	3	8	04776D+01	5	8	21830D+01	11	8	48733D+01	13	8	58961D+01	24	9	82808D+01																																																																																																																																		
15	8	68918D+01	17	8	79553D+01	19	8	91245D+01	21	9	00452D+01	24	9	82808D+01																																																																																																																																					
25	9	52702D+01																																																																																																																																																	
585	<table border="1"> <tr> <td>1</td> <td>1</td> <td>04210D-05</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>1</td> <td>6</td> <td>10721D-06</td> </tr> <tr> <td>2</td> <td>1</td> <td>06524D-06</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>2</td> <td>2</td> <td>16759D-07</td> <td>25</td> <td>9</td> <td>41688D-01</td> <td>25</td> <td>9</td> <td>88438D-01</td> </tr> <tr> <td>1</td> <td>5</td> <td>20316D-07</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>11</td> <td>8</td> <td>48726D+01</td> <td>13</td> <td>8</td> <td>58958D+01</td> <td></td> <td></td> <td></td> </tr> <tr> <td>1</td> <td>7</td> <td>59410D+01</td> <td>3</td> <td>8</td> <td>04770D+01</td> <td>5</td> <td>8</td> <td>21824D+01</td> <td>11</td> <td>8</td> <td>48726D+01</td> <td>13</td> <td>8</td> <td>58958D+01</td> <td>24</td> <td>9</td> <td>73691D+01</td> </tr> <tr> <td>15</td> <td>8</td> <td>68925D+01</td> <td>17</td> <td>8</td> <td>79566D+01</td> <td>19</td> <td>8</td> <td>91224D+01</td> <td>21</td> <td>9</td> <td>00300D+01</td> <td>24</td> <td>9</td> <td>73691D+01</td> <td></td> <td></td> <td></td> </tr> <tr> <td>25</td> <td>9</td> <td>43285D+01</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>	1	1	04210D-05	1	05500E+00	0.0	0.0	0.0	1	6	10721D-06	2	1	06524D-06	1	05500E+00	0.0	0.0	0.0	2	2	16759D-07	25	9	41688D-01	25	9	88438D-01	1	5	20316D-07	1	05500E+00	0.0	0.0	0.0	11	8	48726D+01	13	8	58958D+01				1	7	59410D+01	3	8	04770D+01	5	8	21824D+01	11	8	48726D+01	13	8	58958D+01	24	9	73691D+01	15	8	68925D+01	17	8	79566D+01	19	8	91224D+01	21	9	00300D+01	24	9	73691D+01				25	9	43285D+01																																																														
1	1	04210D-05	1	05500E+00	0.0	0.0	0.0	1	6	10721D-06																																																																																																																																									
2	1	06524D-06	1	05500E+00	0.0	0.0	0.0	2	2	16759D-07	25	9	41688D-01	25	9	88438D-01																																																																																																																																			
1	5	20316D-07	1	05500E+00	0.0	0.0	0.0	11	8	48726D+01	13	8	58958D+01																																																																																																																																						
1	7	59410D+01	3	8	04770D+01	5	8	21824D+01	11	8	48726D+01	13	8	58958D+01	24	9	73691D+01																																																																																																																																		
15	8	68925D+01	17	8	79566D+01	19	8	91224D+01	21	9	00300D+01	24	9	73691D+01																																																																																																																																					
25	9	43285D+01																																																																																																																																																	
586	<table border="1"> <tr> <td>1</td> <td>7</td> <td>68267D-06</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>1</td> <td>5</td> <td>40761D-06</td> </tr> <tr> <td>1</td> <td>7</td> <td>68267D-06</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>2</td> <td>6</td> <td>65446D-07</td> <td>25</td> <td>9</td> <td>47561D-01</td> <td>25</td> <td>1</td> <td>00453D+00</td> </tr> <tr> <td>1</td> <td>1</td> <td>37310D-06</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>11</td> <td>8</td> <td>48710D+01</td> <td>13</td> <td>8</td> <td>58950D+01</td> <td></td> <td></td> <td></td> </tr> <tr> <td>1</td> <td>3</td> <td>25557D-06</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>1</td> <td>1</td> <td>00807D-06</td> <td>25</td> <td>9</td> <td>98016D-01</td> <td>25</td> <td>9</td> <td>52009D-01</td> </tr> <tr> <td>1</td> <td>3</td> <td>25557D-06</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>2</td> <td>1</td> <td>95695D-07</td> <td>13</td> <td>8</td> <td>58955D+01</td> <td></td> <td></td> <td></td> </tr> <tr> <td>1</td> <td>4</td> <td>26148D-07</td> <td>1</td> <td>05500E+00</td> <td>0.0</td> <td>0.0</td> <td>0.0</td> <td>11</td> <td>8</td> <td>48700D+01</td> <td>13</td> <td>8</td> <td>58955D+01</td> <td>24</td> <td>9</td> <td>95695D+01</td> </tr> <tr> <td>1</td> <td>7</td> <td>59410D+01</td> <td>3</td> <td>8</td> <td>04765D+01</td> <td>5</td> <td>8</td> <td>21818D+01</td> <td>11</td> <td>8</td> <td>48700D+01</td> <td>13</td> <td>8</td> <td>58955D+01</td> <td>24</td> <td>9</td> <td>95695D+01</td> </tr> <tr> <td>15</td> <td>8</td> <td>68925D+01</td> <td>17</td> <td>8</td> <td>79566D+01</td> <td>19</td> <td>8</td> <td>91224D+01</td> <td>21</td> <td>9</td> <td>00300D+01</td> <td>24</td> <td>9</td> <td>73691D+01</td> <td></td> <td></td> <td></td> </tr> <tr> <td>25</td> <td>9</td> <td>43285D+01</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>	1	7	68267D-06	1	05500E+00	0.0	0.0	0.0	1	5	40761D-06	1	7	68267D-06	1	05500E+00	0.0	0.0	0.0	2	6	65446D-07	25	9	47561D-01	25	1	00453D+00	1	1	37310D-06	1	05500E+00	0.0	0.0	0.0	11	8	48710D+01	13	8	58950D+01				1	3	25557D-06	1	05500E+00	0.0	0.0	0.0	1	1	00807D-06	25	9	98016D-01	25	9	52009D-01	1	3	25557D-06	1	05500E+00	0.0	0.0	0.0	2	1	95695D-07	13	8	58955D+01				1	4	26148D-07	1	05500E+00	0.0	0.0	0.0	11	8	48700D+01	13	8	58955D+01	24	9	95695D+01	1	7	59410D+01	3	8	04765D+01	5	8	21818D+01	11	8	48700D+01	13	8	58955D+01	24	9	95695D+01	15	8	68925D+01	17	8	79566D+01	19	8	91224D+01	21	9	00300D+01	24	9	73691D+01				25	9	43285D+01											
1	7	68267D-06	1	05500E+00	0.0	0.0	0.0	1	5	40761D-06																																																																																																																																									
1	7	68267D-06	1	05500E+00	0.0	0.0	0.0	2	6	65446D-07	25	9	47561D-01	25	1	00453D+00																																																																																																																																			
1	1	37310D-06	1	05500E+00	0.0	0.0	0.0	11	8	48710D+01	13	8	58950D+01																																																																																																																																						
1	3	25557D-06	1	05500E+00	0.0	0.0	0.0	1	1	00807D-06	25	9	98016D-01	25	9	52009D-01																																																																																																																																			
1	3	25557D-06	1	05500E+00	0.0	0.0	0.0	2	1	95695D-07	13	8	58955D+01																																																																																																																																						
1	4	26148D-07	1	05500E+00	0.0	0.0	0.0	11	8	48700D+01	13	8	58955D+01	24	9	95695D+01																																																																																																																																			
1	7	59410D+01	3	8	04765D+01	5	8	21818D+01	11	8	48700D+01	13	8	58955D+01	24	9	95695D+01																																																																																																																																		
15	8	68925D+01	17	8	79566D+01	19	8	91224D+01	21	9	00300D+01	24	9	73691D+01																																																																																																																																					
25	9	43285D+01																																																																																																																																																	







GROSS GRID 1

FINE GRID 1

	DISTANCE	
1	0.0	75194
2	0.03	78120
3	0.06	80147
4	0.08	81132
5	0.10	82117
6	0.57	82163
7	1.04	83109
8	1.51	83154
9	1.98	83198
10	2.45	84143
11	2.92	84186
12	3.14	85138
13	3.35	85189
14	3.57	86140
15	3.79	86190
16	4.01	87143
17	4.23	87197
18	4.45	88153
19	4.67	89108
20	4.89	89154
21	5.10	89178
22	5.18	91133
23	5.25	90183
24	5.32	87107
25	5.35	85167

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	91.360000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 6.400215580-02

ELAPSED CPU TIME IS 7.15 SECONDS

THE MAXIMUM TEMPERATURE IS 9.13301D+01 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES 22

THE MINIMUM TEMPERATURE IS 7.59383D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES 1

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	NODE	MAX PERCENT TEMP CHANGE	
599	4.40704D+01	1	1.04797D-04	1.05500D+00	0.0	0.0	0.0	1	9.02910D-05	23	6.31937D-01	23	6.95700D-01
599	4.40704D+01	2	9.57157D-06	1.05500D+00	0.0	0.0	0.0	2	2.14914D-06				
599	4.40704D+01	1	9.39400D-06	1.05500D+00	0.0	0.0	0.0						

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
 NODE NUMBERS AND TEMPERATURES

NUMBER OF TIME STEPS	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	NODE	MAX PERCENT TEMP CHANGE	
599	4.4070D+01	1	7.59380D+01	3.804689D+01	5.821729D+01	11.848619D+01	11.848619D+01	13.858913D+01	13.858913D+01				
		15	8.69042D+01	17.879728D+01	19.890722D+01	21.897567D+01	21.897567D+01	24.86424D+01	24.86424D+01				
		25	8.52097D+01										
600	4.41478D+01	1	1.25960D-04	1.05500D+00	0.0	0.0	0.0	1	9.86289D-05				
600	4.41478D+01	3	3.7264D-06	1.05500D+00	0.0	0.0	0.0	2	2.15709D-06	23	6.33357D-01	23	7.02148D-01
600	4.41478D+01	2	1.04114D-06	1.05500D+00	0.0	0.0	0.0						
600	4.4148D+01	1	7.59377D+01	3.804681D+01	5.821720D+01	11.848609D+01	11.848609D+01	13.858909D+01	13.858909D+01				
		15	8.69053D+01	17.879738D+01	19.890651D+01	21.897268D+01	21.897268D+01	24.859001D+01	24.859001D+01				
		25	8.47496D+01										
601	4.42320D+01	1	1.45791D-04	1.05500D+00	0.0	0.0	0.0	1	1.06728D-04				
601	4.42330D+01	3	1.59640D-06	1.05500D+00	0.0	0.0	0.0	2	2.40351D-06	23	6.28368D-01	23	7.01543D-01
601	4.42330D+01	2	1.33871D-06	1.05500D+00	0.0	0.0	0.0						
601	4.4233D+01	1	7.59374D+01	3.804673D+01	5.821710D+01	11.848598D+01	11.848598D+01	13.858906D+01	13.858906D+01				
		15	8.69056D+01	17.879747D+01	19.890569D+01	21.896943D+01	21.896943D+01	24.853319D+01	24.853319D+01				
		25	8.42924D+01										
602	4.43267D+01	1	1.66335D-04	1.05500D+00	0.0	0.0	0.0	1	1.13047D-04				
602	4.43267D+01	3	1.80463D-06	1.05500D+00	0.0	0.0	0.0	2	2.68438D-06	23	6.17091D-01	23	6.93820D-01
602	4.43267D+01	2	1.72148D-06	1.05500D+00	0.0	0.0	0.0						
602	4.4327D+01	1	7.59371D+01	3.804664D+01	5.821700D+01	11.848587D+01	11.848587D+01	13.858902D+01	13.858902D+01				
		15	8.69079D+01	17.879755D+01	19.890476D+01	21.896569D+01	21.896569D+01	24.847774D+01	24.847774D+01				
		25	8.38387D+01										
603	4.44298D+01	1	1.87782D-04	1.05500D+00	0.0	0.0	0.0	1	1.17924D-04				
603	4.44298D+01	3	1.98455D-06	1.05500D+00	0.0	0.0	0.0	2	2.89551D-06	23	6.00141D-01	23	6.79477D-01
603	4.44298D+01	2	2.13092D-06	1.05500D+00	0.0	0.0	0.0						
603	4.4430D+01	1	7.59367D+01	3.804655D+01	5.821689D+01	11.848575D+01	11.848575D+01	13.858897D+01	13.858897D+01				
		15	8.69092D+01	17.879762D+01	19.890368D+01	21.896206D+01	21.896206D+01	24.842372D+01	24.842372D+01				
		25	8.33886D+01										
604	4.45432D+01	1	2.04441D-04	1.05500D+00	0.0	0.0	0.0	1	1.20424D-04				
604	4.45432D+01	3	2.50568D-06	1.05500D+00	0.0	0.0	0.0	2	3.10136D-06	23	5.78535D-01	23	6.59496D-01
604	4.45432D+01	2	2.51666D-06	1.05500D+00	0.0	0.0	0.0						
604	4.4543D+01	1	7.59364D+01	3.804645D+01	5.821677D+01	11.848562D+01	11.848562D+01	13.858893D+01	13.858893D+01				
		15	8.69107D+01	17.879766D+01	19.890244D+01	21.895795D+01	21.895795D+01	24.837106D+01	24.837106D+01				
		25	8.29479D+01										
605	4.46679D+01	1	2.17812D-04	1.05500D+00	0.0	0.0	0.0	1	1.20347D-04				
605	4.46679D+01	3	3.09032D-06	1.05500D+00	0.0	0.0	0.0	2	3.22307D-06	23	5.53732D-01	23	6.35412D-01
605	4.46679D+01	2	3.10956D-06	1.05500D+00	0.0	0.0	0.0						
605	4.4668D+01	1	7.59360D+01	3.804634D+01	5.821665D+01	11.848548D+01	11.848548D+01	13.858889D+01	13.858889D+01				
		15	8.69122D+01	17.879766D+01	19.890101D+01	21.895354D+01	21.895354D+01	24.831959D+01	24.831959D+01				
		25	8.24933D+01										
606	4.48051D+01	1	2.25992D-04	1.05500D+00	0.0	0.0	0.0	1	1.17425D-04				
606	4.48051D+01	3	3.68860D-06	1.05500D+00	0.0	0.0	0.0	2	3.24819D-06	23	5.27582D-01	23	6.09277D-01
606	4.48051D+01	2	3.57517D-06	1.05500D+00	0.0	0.0	0.0						
606	4.4805D+01	1	7.59356D+01	3.804623D+01	5.821652D+01	11.848534D+01	11.848534D+01	13.858885D+01	13.858885D+01				
		15	8.69138D+01	17.879762D+01	19.889938D+01	21.894884D+01	21.894884D+01	24.826897D+01	24.826897D+01				
		25	8.20426D+01										
607	4.49026D+01	1	5.42966D-05	1.05500D+00	0.0	0.0	0.0	1	5.75204D-05				
607	4.49026D+01	2	4.75728D-06	1.05500D+00	0.0	0.0	0.0	2	1.00971D-06	23	3.32093D-01	24	3.99429D-01
607	4.49026D+01	1	6.09736D-06	1.05500D+00	0.0	0.0	0.0						
607	4.4903D+01	1	7.59353D+01	3.804615D+01	5.821643D+01	11.848524D+01	11.848524D+01	13.858882D+01	13.858882D+01				
		15	8.69148D+01	17.879756D+01	19.889818D+01	21.894559D+01	21.894559D+01	24.823594D+01	24.823594D+01				
		25	8.17386D+01										
608	4.50000D+01	1	6.18160D-05	1.05500D+00	0.0	0.0	0.0	1	4.09919D-05				
608	4.50000D+01	2	6.08281D-06	1.05500D+00	0.0	0.0	0.0	2	1.05777D-06	24	3.12222D-01	24	3.79097D-01
608	4.5000D+01	1	6.15298D-06	1.05500D+00	0.0	0.0	0.0						
608	4.5000D+01	1	7.59350D+01	3.804607D+01	5.821634D+01	11.848515D+01	11.848515D+01	13.858879D+01	13.858879D+01				

15 8.691570+01 17 8.797480+01 19 8.896960+01 21 8.942130+01 24 8.204720+01  
25 8.145040+01

4

HEATING6 02/12/83  
W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

IBM3033/ 0  
20.58.13 11-16-89

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 608 TIME STEPS, TIME = 4.500000+01

GROSS GRID		1	
FINE GRID		1	
DISTANCE		0.0	
1	1	0.0	75193
	2	0.03	78120
2	3	0.06	80146
	4	0.08	81131
3	5	0.10	82116
	6	0.57	82162
	7	1.04	83107
	8	1.51	83152
	9	1.98	83197
	10	2.45	84141
4	11	2.92	84185
	12	3.14	85137
5	13	3.35	85189
	14	3.57	86140
6	15	3.79	86192
	16	4.01	87144
7	17	4.23	87197
	18	4.45	88150
8	19	4.67	88197
	20	4.89	89131
9	21	5.10	89142
	22	5.18	87177
	23	5.25	85143
10	24	5.32	82105
11	25	5.35	81145

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	89.500000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTAT) = 9.74431793D-02

ELAPSED CPU TIME IS 7.28 SECONDS

THE MAXIMUM TEMPERATURE IS - 8.94243D+01 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 21

THE MINIMUM TEMPERATURE IS - 7.59350D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO	MAX HEAT	BETA	L1 NORM OF	RHO	RHO	NO	L1 NORM OF	MAX TEMP	MAX PERCENT	
TIME	ITER	RESIDUAL		TEMP DIFF	{ITERATION}	{JACOBI}	ITER	TEMP DIFF	CHANGE	CHANGE	TEMP CHANGE	
609	4.51072D+01	1	3.24787D-05	1.05500D+00	0.0	0.0	1	3.58025D-05	24	3.26707D-01	24	3.98194D-01
609	4.51072D+01	2	2.76028D-06	1.05500D+00	0.0	0.0	2	5.52456D-07				
609	4.51072D+01	1	3.64440D-06	1.05500D+00	0.0	0.0						
TABLE FOR SPECIAL MONITORING OF TEMPERATURES												
***** NODE NUMBERS AND TEMPERATURES *****												
NUMBER OF	TIME											
TIME STEPS												
609	4.5107D+01	1	7.59347D+01	3.8	0.4599D+01	5	8.21625D+01	11	8.48505D+01	13	8.58877D+01	
		15	8.69167D+01	17	8.79736D+01	19	8.89558D+01	21	8.93903D+01	24	8.17205D+01	
		25	8.11416D+01									
610	4.52251D+01	1	4.12605D-05	1.05500D+00	0.0	0.0	0.0	0.0	1	3.56012D-05		
610	4.52251D+01	2	4.40036D-06	1.05500D+00	0.0	0.0	0.0	0.0	2	6.8841D-07	24	3.21438D-01
610	4.52251D+01	1	4.89019D-06	1.05500D+00	0.0	0.0	0.0	0.0				
610	4.5225D+01	1	7.59340D+01	3.8	0.4591D+01	5	8.21615D+01	11	8.48495D+01	13	8.58874D+01	
		15	8.69177D+01	17	8.79720D+01	19	8.89404D+01	21	8.93539D+01	24	8.13761D+01	
		25	8.08111D+01									
611	4.53548D+01	1	4.56066D-05	1.05500D+00	0.0	0.0	0.0	0.0	1	3.43736D-05		
611	4.53548D+01	2	5.24771D-06	1.05500D+00	0.0	0.0	0.0	0.0	2	7.06428D-07	24	3.65205D-01
611	4.53548D+01	1	5.48698D-06	1.05500D+00	0.0	0.0	0.0	0.0				
611	4.5355D+01	1	7.59340D+01	3.8	0.4582D+01	5	8.21605D+01	11	8.48484D+01	13	8.58871D+01	
		15	8.69187D+01	17	8.79698D+01	19	8.89231D+01	21	8.93150D+01	24	8.10109D+01	
		25	8.04565D+01									
612	4.54975D+01	1	4.33030D-05	1.05500D+00	0.0	0.0	0.0	0.0	1	3.20331D-05		
612	4.54975D+01	2	5.24792D-06	1.05500D+00	0.0	0.0	0.0	0.0	2	6.56546D-07	24	3.89503D-01
612	4.54975D+01	1	5.70120D-06	1.05500D+00	0.0	0.0	0.0	0.0				
612	4.5497D+01	1	7.59337D+01	3.8	0.4573D+01	5	8.21595D+01	11	8.48473D+01	13	8.58868D+01	
		15	8.69196D+01	17	8.79670D+01	19	8.89037D+01	21	8.92736D+01	24	8.06214D+01	
		25	8.00740D+01									
613	4.56544D+01	1	4.14186D-05	1.05500D+00	0.0	0.0	0.0	0.0	1	2.92888D-05		
613	4.56544D+01	2	5.32628D-06	1.05500D+00	0.0	0.0	0.0	0.0	2	5.91042D-07	24	4.17939D-01
613	4.56544D+01	1	5.50965D-06	1.05500D+00	0.0	0.0	0.0	0.0				
613	4.5654D+01	1	7.59333D+01	3.8	0.4563D+01	5	8.21584D+01	11	8.48461D+01	13	8.58855D+01	
		15	8.69204D+01	17	8.79633D+01	19	8.88821D+01	21	8.92294D+01	24	8.02035D+01	
		25	7.96595D+01									
614	4.58270D+01	1	3.98743D-05	1.05500D+00	0.0	0.0	0.0	0.0	1	2.58180D-05		
614	4.58270D+01	2	4.75972D-06	1.05500D+00	0.0	0.0	0.0	0.0	2	5.22046D-07	24	4.51082D-01
614	4.58270D+01	1	5.08376D-06	1.05500D+00	0.0	0.0	0.0	0.0				
614	4.5827D+01	1	7.59330D+01	3.8	0.4553D+01	5	8.21572D+01	11	8.48449D+01	13	8.58862D+01	
		15	8.69210D+01	17	8.79587D+01	19	8.88580D+01	21	8.91823D+01	24	7.97524D+01	
		25	7.92094D+01									
615	4.60000D+01	1	2.97413D-05	1.05500D+00	0.0	0.0	0.0	0.0	1	1.85718D-05		
615	4.60000D+01	2	1.75036D-06	1.05500D+00	0.0	0.0	0.0	0.0	2	2.43167D-07	25	4.49181D-01
615	4.60000D+01	1	2.19679D-06	1.05500D+00	0.0	0.0	0.0	0.0				
615	4.6000D+01	1	7.59326D+01	3.8	0.4544D+01	5	8.21562D+01	11	8.48438D+01	13	8.58860D+01	
		15	8.69214D+01	17	8.79533D+01	19	8.88336D+01	21	8.91366D+01	24	7.93057D+01	
		25	7.87602D+01									

IBM3033/ 0  
20.58.13 11-16-89

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 615 TIME STEPS, TIME = 4.60000D+01

HEATINGS 02/12/83  
W9XNP110

GROSS GRID	1	1	0.0
FINE GRID	1	1	0.0
DISTANCE	0.0	75193	
1	0.0	75193	
2	0.03	78119	
3	0.06	80145	
4	0.08	81131	
5	0.10	82116	
6	0.57	82161	
7	1.04	83106	
8	1.51	83151	
9	1.98	83196	
10	2.45	84140	
11	2.92	84184	
12	3.14	85137	
13	3.35	85189	
14	3.57	86140	
15	3.79	86192	
16	4.01	87144	
17	4.23	87195	
18	4.45	88143	
19	4.67	88183	
20	4.89	89109	
21	5.10	89114	
22	5.18	86134	
23	5.25	83116	
24	5.32	79131	
25	5.35	78176	

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	87.330000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 1.72983074D-01

ELAPSED CPU TIME IS 7.36 SECONDS

THE MAXIMUM TEMPERATURE IS - 8.91266D+01 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 20 21

THE MINIMUM TEMPERATURE IS - 7.59326D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	MAX PERCENT TEMP CHANGE
616	4.61903D+01	1	4.21117D-05	1.05500D+00	0.0	0.0	0.0	1	1.50592D-05	25.4.98445D-01	25.6.32863D-01
616	4.61903D+01	2	6.88284D-06	1.05500D+00	0.0	0.0	0.0	2	5.77382D-07		
616	4.61903D+01	1	4.82485D-06	1.05500D+00	0.0	0.0	0.0				

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NUMBER OF TIME STEPS	TIME	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	MAX PERCENT TEMP CHANGE
616	4.6190D+01	5.8.21551D+01	11.8.48427D+01	13.8.58856D+01	17.8.79468D+01	21.8.90878D+01	24.7.88152D+01
617	4.63996D+01	0.0	0.0	1.1.18938D-05	0.0	25.5.50508D-01	25.7.03419D-01
617	4.63996D+01	0.0	0.0	2.3.89724D-07	0.0		
617	4.63996D+01	0.0	0.0	11.8.48415D+01	13.8.58853D+01		
617	4.63996D+01	5.8.21540D+01	11.8.48415D+01	24.7.82738D+01	19.8.87767D+01	21.8.90357D+01	
617	4.6400D+01	17.8.79388D+01	19.8.87767D+01	21.8.90357D+01			
618	4.66298D+01	0.0	0.0	1.1.01579D-05	0.0	25.6.07848D-01	25.7.82187D-01
618	4.66298D+01	0.0	0.0	2.4.32470D-07	0.0		
618	4.66298D+01	0.0	0.0	11.8.48404D+01	13.8.58848D+01		
618	4.6630D+01	5.8.21529D+01	11.8.48404D+01	24.7.76761D+01	19.8.87438D+01	21.8.89800D+01	
618	4.6630D+01	17.8.79292D+01	19.8.87438D+01	21.8.89800D+01			
619	4.68149D+01	0.0	0.0	1.7.45516D-06	0.0	25.4.92426D-01	25.6.38655D-01
619	4.68149D+01	0.0	0.0	2.4.61436D-07	0.0		
619	4.68149D+01	0.0	0.0	11.8.48395D+01	13.8.58845D+01		
619	4.68149D+01	5.8.21520D+01	11.8.48395D+01	24.7.71931D+01	19.8.87173D+01	21.8.89363D+01	
619	4.6815D+01	17.8.79207D+01	19.8.87173D+01	21.8.89363D+01			
620	4.70000D+01	0.0	0.0	1.3.36798D-06	0.0	25.4.92514D-01	25.6.42876D-01
620	4.70000D+01	0.0	0.0	2.3.82641D-07	0.0		
620	4.70000D+01	0.0	0.0	11.8.48387D+01	13.8.58840D+01		
620	4.70000D+01	5.8.21513D+01	11.8.48387D+01	24.7.67085D+01	19.8.86908D+01	21.8.88935D+01	
620	4.7000D+01	17.8.79118D+01	19.8.86908D+01	21.8.88935D+01			
620	4.7000D+01	15.8.59182D+01	17.8.79118D+01	21.8.88935D+01			
620	4.7000D+01	25.7.61185D+01	15.8.59182D+01	21.8.88935D+01			



HEATING6 02/12/83  
 WOXNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
 TRANSIENT TEMPERATURE DISTRIBUTION AFTER 620 TIME STEPS, TIME = 4.700000+01

IBM3033/ 0  
 20.58.13 11-16-89

GROSS GRID	FINE GRID	DISTANCE	TEMPERATURE
1	0.0	75193	85.000000
2	0.03	78119	0.0
3	0.06	80145	73.400000
4	0.08	81130	
5	0.10	82115	
6	0.57	82160	
7	1.04	83105	
8	1.51	83150	
9	1.98	83195	
10	2.45	84140	
11	2.92	84184	
12	3.14	85136	
13	3.35	85188	
14	3.57	86140	
15	3.79	86192	
16	4.01	87143	
17	4.23	87191	
18	4.45	88135	
19	4.67	88169	
20	4.89	88189	
21	5.10	88189	
22	5.18	85128	
23	5.25	81131	
10.24	5.32	76171	
14.25	5.35	76112	

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	85.000000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 1.85084313D-01

ELAPSED CPU TIME IS 7.43 SECONDS

THE MAXIMUM TEMPERATURE IS - 8.88935D+01 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 20 21

THE MINIMUM TEMPERATURE IS - 7.59310D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

Line  
 Print

63  
 63  
 11M  
 103

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	NO	MAX TEMP CHANGE	
621	4.72036D+01	1	1.85758D-06	1.05500D+00	0.0	0.0	0.0	1	2.45046D-06	25	5.41779D-01	25	7.11758D-01
621	4.72036D+01	1	1.85758D-06	1.05500D+00	0.0	0.0	0.0	2	2.75019D-07				
621	4.72036D+01	1	3.43176D-07	1.05500D+00	0.0	0.0	0.0						

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NUMBER OF TIME STEPS	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	NO	MAX TEMP CHANGE	
621	4.7204D+01	1	7.59307D+01	3.8.04493D+01	5.8.21505D+01	11.8.48378D+01	13.8.58835D+01	13	8.48378D+01	25	5.41779D-01	25	7.11758D-01
		15	8.69164D+01	17.8.79014D+01	19.8.86617D+01	21.8.89471D+01	24.7.61751D+01	24	7.61751D+01				
		25	7.55767D+01										
622	4.74275D+01	1	6.41860D-06	1.05500D+00	0.0	0.0	0.0	1	2.77364D-06	25	5.95393D-01	25	7.87786D-01
622	4.74275D+01	1	6.41860D-06	1.05500D+00	0.0	0.0	0.0	2	4.03062D-07				
622	4.74275D+01	1	1.35379D-06	1.05500D+00	0.0	0.0	0.0						
622	4.74275D+01	1	7.55255D+01	3.8.04486D+01	5.8.21497D+01	11.8.48370D+01	13.8.58829D+01	13	8.48370D+01	25	5.95393D-01	25	7.87786D-01
		15	8.69141D+01	17.8.78634D+01	19.8.86298D+01	21.8.87971D+01	24.7.55884D+01	24	7.55884D+01				
		25	7.49813D+01										
623	4.76739D+01	1	1.25957D-05	1.05500D+00	0.0	0.0	0.0	1	4.16276D-06	25	6.53776D-01	25	8.71919D-01
623	4.76739D+01	2	2.39181D-06	1.05500D+00	0.0	0.0	0.0	2	2.32837D-07				
623	4.76739D+01	1	2.14855D-06	1.05500D+00	0.0	0.0	0.0						
623	4.76739D+01	1	1.7.59302D+01	3.8.04479D+01	5.8.21488D+01	11.8.48350D+01	13.8.58820D+01	13	8.48350D+01	25	6.53776D-01	25	8.71919D-01
		15	8.69109D+01	17.8.78755D+01	19.8.85948D+01	21.8.87430D+01	24.7.49440D+01	24	7.49440D+01				
		25	7.43276D+01										
624	4.78369D+01	1	1.50422D-05	1.05500D+00	0.0	0.0	0.0	1	3.01190D-06	25	4.34505D-01	25	5.84581D-01
624	4.78369D+01	2	2.16431D-06	1.05500D+00	0.0	0.0	0.0	2	1.94817D-07				
624	4.78369D+01	1	1.61688D-06	1.05500D+00	0.0	0.0	0.0						
624	4.78369D+01	1	1.7.59300D+01	3.8.04475D+01	5.8.21483D+01	11.8.48354D+01	13.8.58814D+01	13	8.48354D+01	25	4.34505D-01	25	5.84581D-01
		15	8.69086D+01	17.8.78659D+01	19.8.85717D+01	21.8.87077D+01	24.7.45159D+01	24	7.45159D+01				
		25	7.38931D+01										
625	4.80000D+01	1	2.59525D-05	1.05500D+00	0.0	0.0	0.0	1	3.25487D-06	25	4.31423D-01	25	5.83929D-01
625	4.80000D+01	2	3.77252D-06	1.05500D+00	0.0	0.0	0.0	2	3.32278D-07				
625	4.80000D+01	1	2.88844D-06	1.05500D+00	0.0	0.0	0.0						
625	4.80000D+01	1	1.7.59299D+01	3.8.04471D+01	5.8.21478D+01	11.8.48348D+01	13.8.58807D+01	13	8.48348D+01	25	4.31423D-01	25	5.83929D-01
		15	8.69060D+01	17.8.78560D+01	19.8.85486D+01	21.8.86727D+01	24.7.40906D+01	24	7.40906D+01				
		25	7.34616D+01										

HEATING6 02/12/83  
W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 625 TIME STEPS, TIME = 4.800000+01

18M3033/ 0  
20.58.13 11-16-83

GROSS GRID	FINE GRID	DISTANCE	O.O
1	0	0	75193
2	0	03	78119
3	0	06	80145
4	0	08	81130
5	0	10	82115
6	0	57	82160
7	1	04	83105
8	1	51	83150
9	1	98	83195
10	2	45	84139
11	2	92	84183
12	3	14	85136
13	3	35	85188
14	3	57	86140
15	3	79	86191
16	4	01	87140
17	4	23	87186
18	4	45	88125
19	4	67	88155
20	4	89	88170
21	5	10	88167
22	5	18	84126
23	5	25	79149
24	5	32	74109
25	5	35	73146

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	82.670000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 1.63054008D-01

ELAPSED CPU TIME IS 7.49 SECONDS

THE MAXIMUM TEMPERATURE IS - 8.87025D+01 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 20 21

THE MINIMUM TEMPERATURE IS - 7.34616D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 25

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	MODE	MAX PERCENT TEMP CHANGE	
626	4.81794D+01	1	8.42746D-05	1.05500D+00	0.0	0.0	0.0	1	0.3276D-05	25.4	6.5283D-01	25.6	3.3369D-01
626	4.81794D+01	2	2.08599D-06	1.05500D+00	0.0	0.0	0.0	2	5.5157D-07				
626	4.81794D+01	3	9.61452D-06	1.05500D+00	0.0	0.0	0.0						
626	4.81794D+01	1	9.61452D-06	1.05500D+00	0.0	0.0	0.0						
TABLE FOR SPECIAL MONITORING OF TEMPERATURES													
***** NODE NUMBERS AND TEMPERATURES *****													
*****													
NUMBER OF TIME STEPS													
626	4.8179D+01	1	7.59297D+01	3.8	0.466D+01	5.8	2.1473D+01	11	8.4834D+01	13	8.58799D+01		
626	4.8179D+01	2	8.59029D+01	17	8.78449D+01	19	8.85233D+01	21	8.86346D+01	24	7.36266D+01		
626	4.8179D+01	3	7.29963D+01			0.0	0.0			1	0.6899D-05	25	5.0555D-01
626	4.8179D+01	4	5.75024D-05	1.05500D+00	0.0	0.0	0.0			2	7.84524D-07	25	5.0555D-01
627	4.83767D+01	1	5.75024D-05	1.05500D+00	0.0	0.0	0.0			13	8.58788D+01		
627	4.83767D+01	2	8.25008D-06	1.05500D+00	0.0	0.0	0.0			11	8.48335D+01		
627	4.83767D+01	3	7.37186D-06	1.05500D+00	0.0	0.0	0.0			21	8.85931D+01		
627	4.83767D+01	1	7.37186D-06	1.05500D+00	0.0	0.0	0.0			24	7.31237D+01		
627	4.83767D+01	1	7.59295D+01	3.8	0.4461D+01	5.8	2.1467D+01	11	8.48335D+01	13	8.58788D+01		
627	4.83767D+01	2	8.68992D+01	17	8.78323D+01	19	8.84955D+01	21	8.85931D+01	24	7.31237D+01		
627	4.83767D+01	3	7.24907D+01			0.0	0.0			1	1.36656D-05	25	5.48747D-01
627	4.83767D+01	4	7.7046D-05	1.05500D+00	0.0	0.0	0.0			2	9.02193D-07	25	5.48747D-01
628	4.85937D+01	1	7.7046D-05	1.05500D+00	0.0	0.0	0.0			11	8.48327D+01		
628	4.85937D+01	2	2.23448D-06	1.05500D+00	0.0	0.0	0.0			13	8.58776D+01		
628	4.85937D+01	3	1.71766D-06	1.05500D+00	0.0	0.0	0.0			24	7.25778D+01		
628	4.85937D+01	1	7.59293D+01	3.8	0.4456D+01	5.8	2.1460D+01	11	8.48327D+01	13	8.58776D+01		
628	4.85937D+01	2	8.589348D+01	17	8.78180D+01	19	8.84651D+01	21	8.85479D+01	24	7.25778D+01		
628	4.85937D+01	3	7.19420D+01			0.0	0.0			1	1.15998D-05	25	5.07883D-01
628	4.85937D+01	4	5.5548D-05	1.05500D+00	0.0	0.0	0.0			2	7.51486D-07	25	5.07883D-01
629	4.87968D+01	1	8.09052D-06	1.05500D+00	0.0	0.0	0.0			13	8.58763D+01		
629	4.87968D+01	2	7.27105D-06	1.05500D+00	0.0	0.0	0.0			24	7.20738D+01		
629	4.87968D+01	1	7.59292D+01	3.8	0.4451D+01	5.8	2.1454D+01	11	8.48319D+01	13	8.58763D+01		
629	4.87968D+01	2	8.68903D+01	17	8.78944D+01	19	8.84366D+01	21	8.85061D+01	24	7.20738D+01		
629	4.87968D+01	3	7.14341D+01			0.0	0.0			1	1.22662D-05	25	5.00943D-01
629	4.87968D+01	4	7.03356D-05	1.05500D+00	0.0	0.0	0.0			2	5.86169D-07	25	5.00943D-01
630	4.90000D+01	1	9.2427D-06	1.05500D+00	0.0	0.0	0.0			13	8.58748D+01		
630	4.90000D+01	2	9.57197D-06	1.05500D+00	0.0	0.0	0.0			24	7.15759D+01		
630	4.90000D+01	1	7.59290D+01	3.8	0.4436D+01	5.8	2.1448D+01	11	8.48311D+01	13	8.58748D+01		
630	4.90000D+01	2	8.68955D+01	17	8.77904D+01	19	8.84083D+01	21	8.84646D+01	24	7.15759D+01		
630	4.90000D+01	3	7.05332D+01			0.0	0.0			1	1.22662D-05	25	5.00943D-01
630	4.90000D+01	4	5.5548D-05	1.05500D+00	0.0	0.0	0.0			2	5.86169D-07	25	5.00943D-01

HEATING6 02/12/83  
W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 634 TIME STEPS, TIME = 5.000000+01

IBM3033/ 0  
20 58 13 11-16-89

GROSS GRID	FINE GRID	O. O.
	DISTANCE	
1	0.0	75193
2	0.03	78119
3	0.06	80144
4	0.08	81129
5	0.0	82114
6	0.57	82159
7	1.04	83104
8	1.51	83149
9	1.98	83194
10	2.45	84138
11	2.92	84183
12	3.14	85135
13	3.35	85187
14	3.57	86137
15	3.79	86186
16	4.01	87131
17	4.23	87172
18	4.45	88105
19	4.67	88127
20	4.89	88135
21	5.10	88127
22	5.18	82133
23	5.25	76110
10 24	5.32	69132
11 25	5.35	68170

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	78.640000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 2.65349994D-01

ELAPSED CPU TIME IS 7.62 SECONDS

THE MAXIMUM TEMPERATURE IS -	8.83529D+01	(+0.1 PERCENT)	
MAX. TEMP. APPEARS AT NODES -	19	20	21
THE MINIMUM TEMPERATURE IS -	6.86955D+01	(+0.1 PERCENT)	
MIN. TEMP. APPEARS AT NODES -	25		

NO	TIME	NO	MAX HEAT	BETA	L1 NORM OF	RHO	RHO	NO	L1 NORM OF	MAX TEMP	NODE	MAX PERCENT	
TIME	RESIDUAL	ITER	RESIDUAL		TEMP DIFF	(ITERATION)	(JACOBI)	ITER	TEMP DIFF	CHANGE		TEMP CHANGE	
635	5.029190+01	1	8.608290-04	1.055000+00	0.0	0.0	0.0	1	8.206250-05	24	5.862560-01	24	8.456670-01
635	5.029190+01	4	2.299110-06	1.055000+00	0.0	0.0	0.0	2	9.747380-06	24	5.862560-01	24	8.456670-01
635	5.029190+01	3	5.467100-06	1.055000+00	0.0	0.0	0.0						

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NUMBER OF	TIME	NO	MAX HEAT	BETA	L1 NORM OF	RHO	RHO	NO	L1 NORM OF	MAX TEMP	NODE	MAX PERCENT	
TIME STEPS		ITER	RESIDUAL		TEMP DIFF	(ITERATION)	(JACOBI)	ITER	TEMP DIFF	CHANGE		TEMP CHANGE	
636	5.029200+01	1	7.592780+01	3.8044110+01	3.8044110+01	5.8214020+01	11.8482450+01	1	3.8586240+01	24	5.86240+01	24	8.873850+01
636	5.061300+01	1	6.114460-04	1.055000+00	0.0	0.0	0.0	1	8.513190-05	24	5.934420-01	24	8.633330-01
636	5.061300+01	4	2.366460-06	1.055000+00	0.0	0.0	0.0	2	6.883370-06	24	5.934420-01	24	8.633330-01
636	5.061300+01	3	4.660240-06	1.055000+00	0.0	0.0	0.0	11	8.482240+01	13	8.585840+01	24	8.633330-01
636	5.061300+01	1	7.592780+01	3.804400+01	3.804400+01	5.8213880+01	11.8482450+01	1	3.8586240+01	24	5.86240+01	24	8.873850+01
636	5.061300+01	15	6.683750+01	17.8767100+01	17.8767100+01	19.8819530+01	21.8814800+01	2	6.814500+01	24	5.86240+01	24	8.873850+01
636	5.061300+01	25	6.754450+01										
637	5.095610+01	1	7.886900-04	1.055000+00	0.0	0.0	0.0	1	9.188110-05	24	6.085110-01	24	8.929640-01
637	5.095610+01	4	4.376670-06	1.055000+00	0.0	0.0	0.0	2	8.569990-06	24	6.085110-01	24	8.929640-01
637	5.095610+01	3	6.697740-06	1.055000+00	0.0	0.0	0.0	11	8.481980+01	13	8.585350+01	24	8.929640-01
637	5.095610+01	1	7.592780+01	3.8043870+01	3.8043870+01	5.8213700+01	11.8482450+01	1	3.8586240+01	24	5.86240+01	24	8.873850+01
637	5.095610+01	15	6.682500+01	17.8764320+01	17.8764320+01	19.8813700+01	21.8808170+01	2	6.753650+01	24	5.86240+01	24	8.873850+01
637	5.095610+01	25	6.694600+01										
638	5.134190+01	1	1.378500-03	1.055000+00	0.0	0.0	0.0	1	1.680220-04	24	5.662680-01	24	8.384620-01
638	5.134190+01	5	1.784340-06	1.055000+00	0.0	0.0	0.0	2	2.151400-05	24	5.662680-01	24	8.384620-01
638	5.134190+01	4	2.309550-06	1.055000+00	0.0	0.0	0.0	3	3.432520-06	24	5.662680-01	24	8.384620-01
638	5.134190+01	3	2.954730-06	1.055000+00	0.0	0.0	0.0	11	8.481660+01	13	8.584780+01	24	8.384620-01
638	5.134200+01	1	7.592650+01	3.8043710+01	3.8043710+01	5.8213490+01	11.8482450+01	1	3.8586240+01	24	5.86240+01	24	8.873850+01
638	5.134200+01	15	6.681090+01	17.8761310+01	17.8761310+01	19.8808590+01	21.8801250+01	2	6.697020+01	24	5.86240+01	24	8.873850+01
638	5.134200+01	25	6.641490+01										
639	5.167090+01	1	7.911350-04	1.055000+00	0.0	0.0	0.0	1	1.172210-04	24	4.274310-01	24	6.382400-01
639	5.167090+01	4	3.300700-06	1.055000+00	0.0	0.0	0.0	2	8.850760-06	24	4.274310-01	24	6.382400-01
639	5.167090+01	3	6.140570-06	1.055000+00	0.0	0.0	0.0	11	8.481360+01	13	8.584240+01	24	6.382400-01
639	5.167100+01	1	7.592590+01	3.8043560+01	3.8043560+01	5.8213280+01	11.8482450+01	1	3.8586240+01	24	5.86240+01	24	8.873850+01
639	5.167100+01	15	6.679790+01	17.8758640+01	17.8758640+01	19.8804140+01	21.8795300+01	2	6.654280+01	24	5.86240+01	24	8.873850+01
639	5.167100+01	25	6.599840+01										
640	5.200000+01	1	9.137780-04	1.055000+00	0.0	0.0	0.0	1	1.026170-04	24	3.820740-01	24	5.741780-01
640	5.200000+01	4	3.937840-06	1.055000+00	0.0	0.0	0.0	2	9.808390-06	24	3.820740-01	24	5.741780-01
640	5.200000+01	3	6.788030-06	1.055000+00	0.0	0.0	0.0	11	8.481020+01	13	8.583650+01	24	5.741780-01
640	5.200000+01	1	7.592530+01	3.8043380+01	3.8043380+01	5.8213050+01	11.8482450+01	1	3.8586240+01	24	5.86240+01	24	8.873850+01
640	5.200000+01	15	6.678440+01	17.8755930+01	17.8755930+01	19.8799700+01	21.8789470+01	2	6.616070+01	24	5.86240+01	24	8.873850+01
640	5.200000+01	25	6.563490+01										

IBM3033/ 0  
20.58.14 11-16-89

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 640 TIME STEPS, TIME = 5.200000+01

HEATINGS 02/12/83  
WSXNP110

GROSS GRID	FINE GRID	DISTANCE	TEMPERATURE
1	1	0.0	75193
2	2	0.03	78118
3	3	0.06	80143
4	4	0.08	81128
5	5	0.10	82113
6	6	0.57	82158
7	7	1.04	83103
8	8	1.51	83148
9	9	1.98	83193
10	10	2.45	84137
11	11	2.92	84181
12	12	3.14	85133
13	13	3.35	85184
14	14	3.57	86132
15	15	3.79	86178
16	16	4.01	87120
17	17	4.23	87156
18	18	4.45	87183
19	19	4.67	88100
20	20	4.89	88103
21	21	5.10	87189
22	22	5.18	80188
23	23	5.25	73167
24	24	5.32	66116
25	25	5.35	65163

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	76.310000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 3.290606400-01

FLAPSED CPU TIME IS 7.71 SECONDS

THE MAXIMUM TEMPERATURE IS - 8.80256D+01 (+0.1 PERCENT)  
 MAX. TEMP. APPEARS AT NODES - 19 20  
 THE MINIMUM TEMPERATURE IS - 6.56349D+01 (+-0.1 PERCENT)  
 MIN. TEMP. APPEARS AT NODES - 25

END  
 P1  
 P2  
 P3  
 P4  
 P5  
 P6  
 P7  
 P8  
 P9  
 P10

NO TIME NO ITER MAX HEAT RESIDUAL BETA L1 NORM OF TEMP DIFF RHO (ITERATION) RHO (JACOBI) NO ITER L1 NORM OF TEMP DIFF MAX TEMP CHANGE MODE MAX PERCENT TEMP CHANGE  
 1 2 15813D-03 1 055000+00 0 0 0 0 1 88676D-04 24 3 28061D-01 24 4 95855D-01  
 5 1 60630D-06 1 055000+00 0 0 0 0 2 2 32641D-05  
 6 1 5 23620D+01 4 2 16532D-06 1 055000+00 0 0 0 0 3 3 59281D-06  
 6 1 5 23620D+01 3 2 89566D-06 1 055000+00 0 0 0 0  
 6 1 5 23620D+01

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	MODE	MAX PERCENT TEMP CHANGE
641	5.2362D+01	1	7.59246D+01	3.8.04317D+01	5.8.2177D+01	11.8.48061D+01	13.8.58296D+01	1	88676D-04	24.3.28061D-01	24.4.95855D-01	
		15	8.67691D+01	17.8.75292D+01	19.8.79486D+01	21.8.78319D+01	24.6.58327D+01	2	2.32641D-05			
		25	6.53521D+01		0.0	0.0		3	3.59281D-06			
642	5.27601D+01	1	5.4543D-03	1.055000+00	0.0	0.0		1	87383D-04			
		5	1.78058D-06	1.055000+00	0.0	0.0		2	1.72974D-05			
		4	2.23581D-06	1.055000+00	0.0	0.0		3	83358D-06	24.2.55283D-01	24.3.87775D-01	
		2	6.3690D-06	1.055000+00	0.0	0.0		11	48012D+01	13.8.58214D+01		
		1	7.59238D+01	3.8.04291D+01	5.8.21243D+01	11.8.78957D+01	13.8.58214D+01	21	77616D+01	24.6.55774D+01		
642	5.2760D+01	15	8.67515D+01	17.8.74956D+01	19.8.78957D+01	21.8.77616D+01		1	3.46533D-03			
		25	6.51215D+01		0.0	0.0		2	6.18057D-04			
643	5.31981D+01	1	5.98235D-02	1.055000+00	0.0	0.0		3	1.11905D-07			
		7	4.0154D-06	1.055000+00	0.0	0.0		4	2.00297D-07	25.2.42658D+00	25.3.72931D+00	
		6	3.38273D-06	1.055000+00	0.0	0.0		5	3.48247D-06			
		5	3.32902D-06	1.055000+00	0.0	0.0		1	2.8761D-14	25.6.71475D-01	25.1.03111D+00	
		4	3.61154D-06	1.055000+00	0.0	0.0		2	3.73116D-16			
		3	3.85896D-06	1.055000+00	0.0	0.0		1	1.17939D-15	25.6.25345D-01	25.9.60274D-01	
		1	5.89094D-04	1.055000+00	0.0	0.0		2	6.61283D-17	13.8.58192D+01		
		4	9.3791D-07	1.055000+00	0.0	0.0		11	8.47998D+01	24.6.57052D+01		
		2	3.02106D-06	1.055000+00	0.0	0.0		21	8.77476D+01			
		1	5.28461D-05	1.055000+00	0.0	0.0		1	2.27772D-04			
		2	6.44572D-06	1.055000+00	0.0	0.0		2	3.43763D-06	25.5.72352D-01	25.8.70540D-01	
		1	3.24982D-06	1.055000+00	0.0	0.0		11	8.7984D+01	13.8.58169D+01		
		1	7.59234D+01	3.8.04284D+01	5.8.21233D+01	11.8.78821D+01		1	2.27772D-04			
		15	8.67466D+01	17.8.74869D+01	19.8.78821D+01	21.8.77476D+01		2	3.43763D-06	25.5.72352D-01	25.8.70540D-01	
643	5.2863D+01	1	6.10481D-04	1.055000+00	0.0	0.0		1	2.27772D-04			
		1	6.10481D-04	1.055000+00	0.0	0.0		2	3.43763D-06	25.5.72352D-01	25.8.70540D-01	
		4	1.03654D-06	1.055000+00	0.0	0.0		11	8.47998D+01	13.8.58169D+01		
		2	2.48329D-06	1.055000+00	0.0	0.0		21	8.77476D+01	24.6.57052D+01		
		1	7.59231D+01	3.8.04276D+01	5.8.21224D+01	11.8.78685D+01		1	2.27772D-04			
		15	8.67421D+01	17.8.74782D+01	19.8.78685D+01	21.8.77476D+01		2	3.43763D-06	25.5.72352D-01	25.8.70540D-01	
644	5.29657D+01	1	3.45817D-04	1.055000+00	0.0	0.0		1	2.27772D-04			
		3	4.3079D-06	1.055000+00	0.0	0.0		2	4.94332D-06	25.6.46527D-01	25.9.74872D-01	
		2	2.48329D-06	1.055000+00	0.0	0.0		1	1.75861D-04			
		1	7.59228D+01	3.8.04269D+01	5.8.21214D+01	11.8.78550D+01		2	3.43763D-06	25.6.46527D-01	25.9.74872D-01	
		15	8.67274D+01	17.8.74694D+01	19.8.78550D+01	21.8.77476D+01		1	1.75861D-04			
644	5.29657D+01	1	3.45817D-04	1.055000+00	0.0	0.0		1	1.75861D-04			
		3	4.3079D-06	1.055000+00	0.0	0.0		2	4.94332D-06	25.6.46527D-01	25.9.74872D-01	
		2	2.48329D-06	1.055000+00	0.0	0.0		1	1.75861D-04			
		1	7.59228D+01	3.8.04269D+01	5.8.21214D+01	11.8.78550D+01		2	3.43763D-06	25.6.46527D-01	25.9.74872D-01	
645	5.30685D+01	1	3.50953D-04	1.055000+00	0.0	0.0		1	1.75861D-04			
		3	4.3185D-06	1.055000+00	0.0	0.0		2	4.72743D-06	25.7.17819D-01	25.1.07192D+00	
		2	3.6151D-06	1.055000+00	0.0	0.0		1	1.75861D-04			
		1	5.9578D-05	1.055000+00	0.0	0.0		2	4.72743D-06	25.7.17819D-01	25.1.07192D+00	
		2	2.00274D-06	1.055000+00	0.0	0.0		1	1.75861D-04			
		1	2.1101D-06	1.055000+00	0.0	0.0		2	4.72743D-06	25.7.17819D-01	25.1.07192D+00	
		1	1.21101D-06	1.055000+00	0.0	0.0		1	1.75861D-04			
		1	1.7.59225D+01	3.8.04262D+01	5.8.21204D+01	11.8.78431D+01		2	4.72743D-06	25.7.17819D-01	25.1.07192D+00	
		15	8.67332D+01	17.8.74617D+01	19.8.78431D+01	21.8.76997D+01		1	1.75861D-04			
		25	6.76045D+01		0.0	0.0		2	4.72743D-06	25.7.17819D-01	25.1.07192D+00	
646	5.31713D+01	1	7.5686D-04	1.055000+00	0.0	0.0		1	1.75861D-04			
		3	1.8157D-06	1.055000+00	0.0	0.0		2	2.56489D-06	25.6.82445D-01	25.1.00946D+00	
		2	1.5447D-06	1.055000+00	0.0	0.0		1	1.75861D-04			
		1	3.2603D-05	1.055000+00	0.0	0.0		2	2.56489D-06	25.6.82445D-01	25.1.00946D+00	
		2	9.71052D-07	1.055000+00	0.0	0.0		1	1.75861D-04			
		1	6.46182D-07	1.055000+00	0.0	0.0		2	2.56489D-06	25.6.82445D-01	25.1.00946D+00	
		1	7.59223D+01	3.8.04255D+01	5.8.21196D+01	11.8.78319D+01		1	1.75861D-04			
		15	8.67292D+01	17.8.74543D+01	19.8.78319D+01	21.8.76865D+01		2	2.56489D-06	25.6.82445D-01	25.1.00946D+00	
647	5.32507D+01	1	1.75686D-04	1.055000+00	0.0	0.0		1	1.75861D-04			
		3	1.8157D-06	1.055000+00	0.0	0.0		2	1.68104D-06	25.6.44057D-01	25.9.52577D-01	
		2	1.5447D-06	1.055000+00	0.0	0.0		1	1.75861D-04			
		1	3.2603D-05	1.055000+00	0.0	0.0		2	1.32687D-07	25.6.44057D-01	25.9.52577D-01	
		2	9.71052D-07	1.055000+00	0.0	0.0		1	1.75861D-04			
		1	6.46182D-07	1.055000+00	0.0	0.0		2	1.32687D-07	25.6.44057D-01	25.9.52577D-01	
		1	7.59223D+01	3.8.04255D+01	5.8.21196D+01	11.8.78319D+01		1	1.75861D-04			
		15	8.67292D+01	17.8.74543D+01	19.8.78319D+01	21.8.76865D+01		2	1.32687D-07	25.6.44057D-01	25.9.52577D-01	
647	5.32507D+01	1	1.75686D-04	1.055000+00	0.0	0.0		1	1.75861D-04			
		3	1.8157D-06	1.055000+00	0.0	0.0		2	1.32687D-07	25.6.44057D-01	25.9.52577D-01	
		2	1.5447D-06	1.055000+00	0.0	0.0		1	1.75861D-04			
		1	3.2603D-05	1.055000+00	0.0	0.0		2	1.32687D-07	25.6.44057D-01	25.9.52577D-01	
		2	9.71052D-07	1.055000+00	0.0	0.0		1	1.75861D-04			
		1	6.46182D-07	1.055000+00	0.0	0.0		2	1.32687D-07	25.6.44057D-01	25.9.52577D-01	
		1	7.59223D+01	3.8.04255D+01	5.8.21196D+01	11.8.78319D+01		1	1.75861D-04			
		15	8.67292D+01	17.8.74543D+01	19.8.78319D+01	21.8.76865D+01		2	1.32687D-07	25.6.44057D-01	25.9.52577D-01	



648	5.3331D+01	1	1	21750-04	1	055000+00	0	0	0	0	1	8	33607D-05	25	6	76566D-01	25	9	91312D-01
648	5.3331D+01	2	8	8959D-06	1	055000+00	0	0	0	0	2	2	4207D-06	25	6	76566D-01	25	9	91312D-01
648	5.3331D+01	2	9	3588D-07	1	055000+00	0	0	0	0	11	8	47937D+01	13	8	58086D+01	24	6	82321D+01
648	5.3331D+01	1	7	59221D+01	3	8	04248D+01	5	8	21187D+01	21	8	76738D+01	24	6	82321D+01	24	6	82321D+01
648	5.3331D+01	15	8	67251D+01	17	8	74470D+01	19	8	78207D+01	19	8	78207D+01	19	8	78207D+01	19	8	78207D+01
649	5.3416D+01	1	1	1068D-04	1	055000+00	0	0	0	0	1	7	9513D-05	25	6	76566D-01	25	9	91312D-01
649	5.3416D+01	2	8	4540D-06	1	055000+00	0	0	0	0	2	1	83576D-06	25	7	05682D-01	25	1	02383D+00
649	5.3416D+01	1	9	78416D-06	1	055000+00	0	0	0	0	1	3	0618D-06	25	6	76566D-01	25	9	91312D-01
649	5.3416D+01	1	1	3178D-05	1	055000+00	0	0	0	0	2	1	60910D-07	25	6	76566D-01	25	9	91312D-01
649	5.3416D+01	2	1	1987D-06	1	055000+00	0	0	0	0	11	8	47920D+01	13	8	58086D+01	24	6	82321D+01
649	5.3416D+01	1	5	7094D-07	1	055000+00	0	0	0	0	21	8	76624D+01	24	6	82321D+01	24	6	82321D+01
649	5.3416D+01	1	7	59218D+01	3	8	04242D+01	5	8	21178D+01	11	8	47920D+01	13	8	58086D+01	24	6	82321D+01
649	5.3416D+01	15	8	67214D+01	17	8	74401D+01	19	8	78104D+01	21	8	76624D+01	24	6	82321D+01	24	6	82321D+01
650	5.3490D+01	1	6	4748D-05	1	055000+00	0	0	0	0	1	5	52705D-05	25	6	76566D-01	25	9	91312D-01
650	5.3490D+01	2	5	2808D-06	1	055000+00	0	0	0	0	2	1	14450D-06	25	6	76566D-01	25	9	91312D-01
650	5.3490D+01	1	5	71725D-06	1	055000+00	0	0	0	0	11	8	47908D+01	13	8	58086D+01	24	6	82321D+01
650	5.3490D+01	1	7	59216D+01	3	8	04235D+01	5	8	21170D+01	21	8	76515D+01	24	6	82321D+01	24	6	82321D+01
650	5.3490D+01	15	8	67176D+01	17	8	74333D+01	19	8	78009D+01	21	8	76515D+01	24	6	82321D+01	24	6	82321D+01
651	5.3569D+01	1	6	32858D-04	1	055000+00	0	0	0	0	1	1	44174D-04	25	6	76566D-01	25	9	91312D-01
651	5.3569D+01	3	6	22621D-06	1	055000+00	0	0	0	0	2	7	45857D-06	25	8	22396D-01	25	1	17050D+00
651	5.3569D+01	2	3	70969D-06	1	055000+00	0	0	0	0	1	1	50757D-05	25	6	76566D-01	25	9	91312D-01
651	5.3569D+01	1	4	71965D-05	1	055000+00	0	0	0	0	2	7	52085D-07	25	6	76566D-01	25	9	91312D-01
651	5.3569D+01	2	3	68745D-06	1	055000+00	0	0	0	0	11	8	47898D+01	13	8	58086D+01	24	6	82321D+01
651	5.3569D+01	1	2	83682D-06	1	055000+00	0	0	0	0	21	8	76429D+01	24	6	82321D+01	24	6	82321D+01
651	5.3569D+01	1	7	59214D+01	3	8	04229D+01	5	8	21163D+01	11	8	47898D+01	13	8	58086D+01	24	6	82321D+01
651	5.3569D+01	15	8	67145D+01	17	8	74277D+01	19	8	77917D+01	21	8	76429D+01	24	6	82321D+01	24	6	82321D+01
652	5.3619D+01	1	7	12356D-04	1	055000+00	0	0	0	0	1	1	86951D-04	25	6	76566D-01	25	9	91312D-01
652	5.3619D+01	3	6	6897D-06	1	055000+00	0	0	0	0	2	8	61047D-06	25	8	58835D-01	25	1	21251D-20
652	5.3619D+01	2	3	1468D-06	1	055000+00	0	0	0	0	1	7	32668D-06	25	6	76566D-01	25	9	91312D-01
652	5.3619D+01	1	5	84125D-06	1	055000+00	0	0	0	0	2	4	73418D-07	25	6	76566D-01	25	9	91312D-01
652	5.3619D+01	1	5	84125D-06	1	055000+00	0	0	0	0	11	8	47898D+01	13	8	58086D+01	24	6	82321D+01
652	5.3619D+01	1	4	57612D-07	1	055000+00	0	0	0	0	21	8	76365D+01	24	7	04351D+01	24	6	82321D+01
652	5.3619D+01	1	7	59212D+01	3	8	04225D+01	5	8	21157D+01	11	8	47898D+01	13	8	58086D+01	24	6	82321D+01
652	5.3619D+01	15	8	67120D+01	17	8	74234D+01	19	8	77852D+01	21	8	76365D+01	24	7	04351D+01	24	6	82321D+01
653	5.3655D+01	1	1	6908D-04	1	055000+00	0	0	0	0	1	9	95739D-05	25	7	50638D-01	25	1	04859D+00
653	5.3655D+01	3	1	4726D-06	1	055000+00	0	0	0	0	2	2	53646D-06	25	7	50638D-01	25	1	04859D+00
653	5.3655D+01	2	8	8250D-07	1	055000+00	0	0	0	0	1	5	56219D-06	25	6	76566D-01	25	9	91312D-01
653	5.3655D+01	1	4	00790D-06	1	055000+00	0	0	0	0	2	2	37121D-07	25	6	76566D-01	25	9	91312D-01
653	5.3655D+01	1	4	00790D-06	1	055000+00	0	0	0	0	11	8	47883D+01	13	8	58086D+01	24	6	82321D+01
653	5.3655D+01	1	3	12081D-07	1	055000+00	0	0	0	0	21	8	76308D+01	24	7	05291D+01	24	6	82321D+01
653	5.3655D+01	1	7	59211D+01	3	8	04221D+01	5	8	21152D+01	11	8	47883D+01	13	8	58086D+01	24	6	82321D+01
653	5.3655D+01	15	8	67099D+01	17	8	74193D+01	19	8	77930D+01	21	8	76308D+01	24	7	05291D+01	24	6	82321D+01
654	5.3659D+01	1	8	3087D-05	1	055000+00	0	0	0	0	1	7	55544D-05	25	7	31019D-01	25	1	01156D+00
654	5.3659D+01	2	9	8593D-06	1	055000+00	0	0	0	0	2	1	80127D-06	25	7	31019D-01	25	1	01156D+00
654	5.3659D+01	1	5	0008D-06	1	055000+00	0	0	0	0	1	9	95477D-06	25	6	76566D-01	25	9	91312D-01
654	5.3659D+01	1	3	66726D-06	1	055000+00	0	0	0	0	2	2	18877D-07	25	6	76566D-01	25	9	91312D-01
654	5.3659D+01	1	3	66726D-06	1	055000+00	0	0	0	0	1	1	95477D-06	25	6	76566D-01	25	9	91312D-01
654	5.3659D+01	1	3	5101D-07	1	055000+00	0	0	0	0	2	2	18877D-07	25	6	76566D-01	25	9	91312D-01
654	5.3659D+01	1	7	59210D+01	3	8	04217D+01	5	8	21147D+01	11	8	47876D+01	13	8	58086D+01	24	6	82321D+01
654	5.3659D+01	15	8	67077D+01	17	8	74157D+01	19	8	77332D+01	21	8	76257D+01	24	7	14419D+01	24	6	82321D+01
655	5.3737D+01	1	5	16452D-05	1	055000+00	0	0	0	0	1	6	21008D-05	25	7	25138D-01	25	9	93969D-01
655	5.3737D+01	2	6	7970D-06	1	055000+00	0	0	0	0	2	1	23798D-06	25	7	25138D-01	25	9	93969D-01
655	5.3737D+01	1	3	29826D-06	1	055000+00	0	0	0	0	11	8	47869D+01	13	8	58086D+01	24	6	82321D+01
655	5.3737D+01	1	7	59208D+01	3	8	04244D+01	5	8	21142D+01	11	8	47869D+01	13	8	58086D+01	24	6	82321D+01
655	5.3737D+01	1	7	59208D+01	3	8	04244D+01	5	8	21142D+01	11	8	47869D+01	13	8	58086D+01	24	6	82321D+01
655	5.3737D+01	15	8	67056D+01	17	8	74120D+01	19	8	77683D+01	21	8	76207D+01	24	7	20340D+01	24	6	82321D+01
656	5.3780D+01	1	5	9846D-05	1	055000+00	0	0	0	0	1	5	98710D-05	25	6	76566D-01	25	9	91312D-01
656	5.3780D+01	1	5	9846D-05	1	055000+00	0	0	0	0	1	5	98710D-05	25	6	76566D-01	25	9	91312D-01

656	5.37203D+01	1 2 97471D-06	1 055000+00	0 0	0 0	0 0	2 1 10524D-06	25 7 59143D-01	25 1 24034D+00
656	5.37769D+01	3 97238D-06	1 055000+00	0 0	0 0	0 0	1 2 14001D-06		
656	5.37769D+01	3 97238D-06	1 055000+00	0 0	0 0	0 0	2 2 21018D-07	25 7 01195D-01	25 9 51691D-01
656	5.37769D+01	3 6454D-07	1 055000+00	0 0	0 0	0 0	11 8 47863D+01	13 8 57977D-01	
656	5.37770+01	1 7 59207D+01	3 8 042100+01	5 8 2138D+01	19 8 77633D+01	19 8 77633D+01	21 8 76163D+01	24 7 25606D+01	
657	5.38166D+01	15 8 67037D+01	17 8 74086D+01	0 0	0 0	0 0	1 4 70882D-05		
657	5.38166D+01	2 68504D-05	1 055000+00	0 0	0 0	0 0	3 7 35610D-07	25 7 26450D-01	25 9 1513D-01
657	5.38166D+01	2 4 9845D-06	1 055000+00	0 0	0 0	0 0	11 8 47856D+01	13 8 57967D+01	
657	5.38170+01	1 7 59207D+01	3 8 04207D+01	5 8 21133D+01	13 8 77583D+01	13 8 77583D+01	21 8 76120D+01	24 7 31538D+01	
657	5.38170+01	15 8 67037D+01	17 8 74051D+01	0 0	0 0	0 0	1 4 44849D-05		
658	5.38563D+01	2 6257D-05	1 055000+00	0 0	0 0	0 0	2 6 8235D-07	25 7 49903D-01	25 9 9883D-01
658	5.38563D+01	2 3 7389D-06	1 055000+00	0 0	0 0	0 0	11 8 47849D+01	13 8 57957D+01	
658	5.38563D+01	1 7 59207D+01	3 8 04207D+01	5 8 21128D+01	13 8 77533D+01	13 8 77533D+01	21 8 76079D+01	24 7 31733D+01	
658	5.38563D+01	15 8 6698D+01	17 8 74017D+01	0 0	0 0	0 0	1 4 18704D-05		
659	5.38950D+01	2 28631D-05	1 055000+00	0 0	0 0	0 0	2 6 23642D-07	25 7 71364D-01	25 1 6147D+00
659	5.38950D+01	2 3 3904D-06	1 055000+00	0 0	0 0	0 0	1 1 71052D-06		
659	5.38950D+01	1 7 59207D+01	3 8 04207D+01	5 8 21124D+01	13 8 77486D+01	13 8 77486D+01	21 8 76042D+01	24 7 43908D+01	
659	5.38950D+01	15 8 6698D+01	17 8 73985D+01	0 0	0 0	0 0	1 3 47164D-05		
660	5.39305D+01	1 50328D-05	1 055000+00	0 0	0 0	0 0	2 4 41471D-07	25 7 38583D-01	25 9 64479D-01
660	5.39305D+01	2 2 3522D-06	1 055000+00	0 0	0 0	0 0	11 8 47837D+01	13 8 57928D+01	
660	5.39305D+01	1 7 59207D+01	3 8 04196D+01	5 8 21119D+01	13 8 77440D+01	13 8 77440D+01	21 8 75007D+01	24 7 50267D+01	
660	5.39305D+01	15 8 6698D+01	17 8 73953D+01	0 0	0 0	0 0	1 3 05382D-05		
661	5.39652D+01	1 41357D-05	1 055000+00	0 0	0 0	0 0	2 4 12140D-07	25 7 08418D-01	25 9 16221D-01
661	5.39652D+01	2 2 1829D-06	1 055000+00	0 0	0 0	0 0	11 8 47831D+01	13 8 57929D+01	
661	5.39652D+01	1 7 59207D+01	3 8 04193D+01	5 8 21115D+01	13 8 77396D+01	13 8 77396D+01	21 8 75776D+01	24 7 56433D+01	
661	5.39652D+01	15 8 6698D+01	17 8 73923D+01	0 0	0 0	0 0	1 2 68013D-05		
662	5.40000D+01	1 62325D-05	1 055000+00	0 0	0 0	0 0	2 3 0424D-07	25 7 20648D-01	25 9 23567D-01
662	5.40000D+01	2 1 5705D-06	1 055000+00	0 0	0 0	0 0	11 8 47825D+01	13 8 57920D+01	
662	5.40000D+01	1 7 59207D+01	3 8 04190D+01	5 8 21110D+01	13 8 77353D+01	13 8 77353D+01	21 8 75946D+01	24 7 62787D+01	
662	5.40000D+01	15 8 6698D+01	17 8 73893D+01	0 0	0 0	0 0			
662	5.40000D+01	2 5 7 87461D+01							

HEATING 02/12/83  
W9KNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

18M3033/ 0  
20 58 14 11-16-89

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 562 TIME STEPS, TIME = 5.400000D+01

GROSS GRID	I	J	TEMPERATURE
1	1	1	75192
2	1	2	78117
3	1	3	80142
4	1	4	81127
5	1	5	82111
6	1	6	82156
7	1	7	83101
8	1	8	83146
9	1	9	83191
10	1	10	84135
11	1	11	84178
12	1	12	85120
13	1	13	85179
14	1	14	86126
15	1	15	86169
16	1	16	87107
17	1	17	87139
18	1	18	87162
19	1	19	87174
20	1	20	87173
21	1	21	87173
22	1	22	81194
23	1	23	77155
24	1	24	76128
25	1	25	78175

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	76.310000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 3.47628014D-02

ELAPSED CPU TIME IS 8.09 SECONDS

THE MAXIMUM TEMPERATURE IS - 8.77953D+01 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 19 20

THE MINIMUM TEMPERATURE IS - 7.59200D+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO ITER	MAX RESIDUAL	BETA	LI NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	ITER	LI NORM OF TEMP DIFF	MAX TEMP CHANGE	MODE	MAX PERCENT TEMP CHANGE			
563	5.403480+01	1	1.13730-05	1.055000+00	0.0	0.0	0.0	1	2.625940-05	25	7	336860-01	25	9	317100-01
563	5.403480+01	2	1.754350-06	1.055000+00	0.0	0.0	0.0	2	3.364270-07						
563	5.403480+01	1	1.158920-07	1.055000+00	0.0	0.0	0.0								

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NUMBER OF TIME STEPS	TIME	NO ITER	MAX RESIDUAL	BETA	LI NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	ITER	LI NORM OF TEMP DIFF	MAX TEMP CHANGE	MODE	MAX PERCENT TEMP CHANGE			
663	5.40350+01	1	1.759190+01	3.8041860+01	5.8211070+01	11.8478190+01	11.8478190+01	13	8.579110+01						
		15	8.669100+01	17.8739530+01	19.8773100+01	21.8759180+01	21.8759180+01	24	7.693030+01						
		25	7.947980+01												
664	5.407020+01	1	1.010470-05	1.055000+00	0.0	0.0	0.0	1	2.513270-05						
664	5.407020+01	2	1.553410-06	1.055000+00	0.0	0.0	0.0	2	3.014220-07	25	7	597710-01	25	9	559290-01
664	5.407020+01	1	6.582350-07	1.055000+00	0.0	0.0	0.0								
		1	7.591970+01	3.8041830+01	5.8211070+01	11.8478190+01	11.8478190+01	13	8.579020+01						
		15	8.668920+01	17.8738320+01	19.8772650+01	21.8758910+01	21.8758910+01	24	7.761150+01						
		25	8.023950+01												
665	5.410570+01	1	9.671030-06	1.055000+00	0.0	0.0	0.0	1	2.394710-05						
665	5.410570+01	1	9.671030-06	1.055000+00	0.0	0.0	0.0	2	1.014600-06	25	7	710280-01	25	9	619080-01
665	5.410570+01	2	2.89850-06	1.055000+00	0.0	0.0	0.0								
		1	7.591960+01	3.8041800+01	5.8210860+01	11.8478070+01	11.8478070+01	13	8.578920+01						
		15	8.668740+01	17.8738010+01	19.8772230+01	21.8758650+01	21.8758650+01	24	7.830820+01						
		25	8.101060+01												
666	5.41410+01	1	8.748570-06	1.055000+00	0.0	0.0	0.0	1	2.245430-05						
666	5.41410+01	1	8.748570-06	1.055000+00	0.0	0.0	0.0	2	9.403980-07	25	7	813180-01	25	9	644540-01
666	5.41410+01	1	2.072140-06	1.055000+00	0.0	0.0	0.0								
		1	7.591950+01	3.8041760+01	5.8210940+01	11.8478010+01	11.8478010+01	13	8.578830+01						
		15	8.668570+01	17.8737700+01	19.8771790+01	21.8758420+01	21.8758420+01	24	7.901920+01						
		25	8.179190+01												
667	5.417650+01	1	7.937230-06	1.055000+00	0.0	0.0	0.0	1	2.109740-05						
667	5.417650+01	1	7.937230-06	1.055000+00	0.0	0.0	0.0	2	8.666980-07	25	7	907470-01	25	9	667790-01
667	5.417650+01	1	1.882590-06	1.055000+00	0.0	0.0	0.0								
		1	7.591940+01	3.8041730+01	5.8210830+01	11.8477950+01	11.8477950+01	13	8.578740+01						
		15	8.668390+01	17.8737400+01	19.8771350+01	21.8758210+01	21.8758210+01	24	7.974330+01						
		25	8.253260+01												
668	5.421200+01	1	7.191890-06	1.055000+00	0.0	0.0	0.0	1	1.978900-07						
668	5.421200+01	1	7.191890-06	1.055000+00	0.0	0.0	0.0	2	8.053200-07	25	7	993580-01	25	9	679450-01
668	5.421200+01	1	1.731880-06	1.055000+00	0.0	0.0	0.0								
		1	7.591930+01	3.8041690+01	5.8210850+01	11.8477881+01	11.8477881+01	13	8.578640+01						
		15	8.668210+01	17.8737090+01	19.8770930+01	21.8758011+01	21.8758011+01	24	7.047980+01						
		25	8.338200+01												
669	5.424740+01	1	6.543120-06	1.055000+00	0.0	0.0	0.0	1	1.855820-05						
669	5.424740+01	1	6.543120-06	1.055000+00	0.0	0.0	0.0	2	7.09820-07	25	8	072860-01	25	9	681770-01
669	5.424740+01	1	1.51510-07	1.055000+00	0.0	0.0	0.0								
		1	7.591910+01	3.8041660+01	5.8210800+01	11.8477820+01	11.8477820+01	13	8.578550+01						
		15	8.668030+01	17.8736780+01	19.8770510+01	21.8757840+01	21.8757840+01	24	8.122760+01						
		25	8.418930+01												
670	5.428290+01	1	5.838670-06	1.055000+00	0.0	0.0	0.0	1	1.731820-05						
670	5.428290+01	1	5.838670-06	1.055000+00	0.0	0.0	0.0	2	6.709870-07	25	8	144210-01	25	9	679810-01
670	5.428290+01	1	1.389320-06	1.055000+00	0.0	0.0	0.0								
		1	7.591900+01	3.8041620+01	5.8210750+01	11.8477750+01	11.8477750+01	13	8.578450+01						
		15	8.667950+01	17.8736470+01	19.8770080+01	21.8757690+01	21.8757690+01	24	8.198580+01						
		25	8.500370+01												
671	5.431830+01	1	5.372390-06	1.055000+00	0.0	0.0	0.0	1	1.624070-05						
671	5.431830+01	1	5.372390-06	1.055000+00	0.0	0.0	0.0	2	6.292670-07	25	8	210770-01	25	9	659310-01
671	5.431830+01	1	1.280320-06	1.055000+00	0.0	0.0	0.0								
		1	7.591890+01	3.8041590+01	5.8210710+01	11.8477690+01	11.8477690+01	13	8.578350+01						
		15	8.667670+01	17.8736170+01	19.8769650+01	21.8757560+01	21.8757560+01	24	8.275380+01						
		25	8.582480+01												
672	5.435380+01	1	4.851200-06	1.055000+00	0.0	0.0	0.0	1	1.516830-05						
672	5.435380+01	1	4.851200-06	1.055000+00	0.0	0.0	0.0	2	5.814370-07	25	8	271310-01	25	9	637440-01
672	5.435380+01	1	1.167370-06	1.055000+00	0.0	0.0	0.0								
		1	7.591880+01	3.8041550+01	5.8210650+01	11.8477630+01	11.8477630+01	13	8.578260+01						
		15	8.667510+01	17.8735820+01	19.876890+01	21.8757470+01	21.8757470+01	24	8.275260+01						
		25	8.43540+01												

Table with columns for alphanumeric codes (e.g., 673, 5, 438920+01), numerical values, and alphanumeric suffixes (e.g., 21 8 757450+01). The table contains approximately 100 rows of data.

684	5.477940+01	1 4 853160-06	1 055000+00	0 0	0 0	0 0	0 0	21 8 757760+01	24 9 26351	01
		25 9 634190+01								
685	5.477940+01	1 4 853160-06	1 055000+00	0 0	0 0	0 0	0 0	1 1 263090-05		
686	5.477940+01	1 4 853160-06	1 055000+00	0 0	0 0	0 0	0 0	2 5 534060-07	25 9 431340-01	25 9 789450-01
687	5.477940+01	1 2 22630-06	1 055000+00	0 0	0 0	0 0	0 0	11 8 476820+01	13 8 577060+01	
688	5.477940+01	1 7 591720+01	3 8 041110+01	5 8 210090+01	5 8 764480+01	19 8 764480+01	19 8 764480+01	21 8 757930+01	24 9 352450+01	
689	5.481490+01	1 4 134560-06	1 055000+00	0 0	0 0	0 0	0 0			
690	5.481490+01	1 4 134560-06	1 055000+00	0 0	0 0	0 0	0 0	1 1 173960-05		
691	5.481490+01	1 4 134560-06	1 055000+00	0 0	0 0	0 0	0 0	2 4 612470-07	25 9 490430-01	25 9 755280-01
692	5.481490+01	1 1 040350-06	1 055000+00	0 0	0 0	0 0	0 0	11 8 476750+01	13 8 576960+01	
693	5.48150+01	1 7 591710+01	3 8 041070+01	5 8 210040+01	19 8 764110+01	19 8 764110+01	19 8 764110+01	21 8 758120+01	24 9 442250+01	
694	5.485040+01	1 3 667820-06	1 055000+00	0 0	0 0	0 0	0 0	1 1 095620-05		
695	5.485040+01	1 3 667820-06	1 055000+00	0 0	0 0	0 0	0 0	2 4 016620-07	25 9 543220-11	25 9 714780-01
696	5.485040+01	1 9 004150-07	1 055000+00	0 0	0 0	0 0	0 0	2 4 016620-07	25 9 543220-11	25 9 714780-01
697	5.48500+01	1 7 591690+01	3 8 041030+01	5 8 209930+01	19 8 763740+01	19 8 763740+01	19 8 763740+01	21 8 758340+01	24 9 532870+01	
698	5.48860+01	1 7 591680+01	3 8 040990+01	5 8 209940+01	19 8 763380+01	19 8 763380+01	19 8 763380+01	21 8 758570+01	24 9 542430+01	
699	5.49210+01	1 1 001470+02						1 1 020580-05		
700	5.49210+01	1 2 937240-06	1 055000+00	0 0	0 0	0 0	0 0	2 3 705730-07	25 9 590080-01	25 9 668550-01
701	5.49210+01	1 2 937240-06	1 055000+00	0 0	0 0	0 0	0 0	1 1 8 476610+01	13 8 576750+01	
702	5.49210+01	1 7 268670-07	1 055000+00	0 0	0 0	0 0	0 0	2 3 705730-07	25 9 590080-01	25 9 668550-01
703	5.49210+01	1 7 591660+01	3 8 040950+01	5 8 209880+01	19 8 763020+01	19 8 763020+01	19 8 763020+01	11 8 476540+01	13 8 576650+01	
704	5.495680+01	1 2 469750-06	1 055000+00	0 0	0 0	0 0	0 0	21 8 758830+01	24 9 716270+01	
705	5.495680+01	1 2 469750-06	1 055000+00	0 0	0 0	0 0	0 0	1 1 8 805210-06		
706	5.495680+01	1 2 469750-06	1 055000+00	0 0	0 0	0 0	0 0	2 2 960110-07	25 9 669840-01	25 9 563620-01
707	5.495680+01	1 5 9 1760-07	1 055000+00	0 0	0 0	0 0	0 0	2 3 473150-07	25 9 631170-01	25 9 519000-01
708	5.49570+01	1 7 591650+01	3 8 040910+01	5 8 209830+01	19 8 762570+01	19 8 762570+01	19 8 762570+01	11 8 476460+01	13 8 576550+01	
709	5.49920+01	1 5 8 664370+01	17 8 730650+01	19 8 730650+01	19 8 730650+01	19 8 730650+01	19 8 730650+01	21 8 759120+01	24 9 808910+01	
710	5.49920+01	25 1 020780+02						1 1 8 163500-06		
711	5.502780+01	1 2 166310-06	1 055000+00	0 0	0 0	0 0	0 0	2 2 673190-07	25 9 702370-01	25 9 504890-01
712	5.502780+01	1 2 166310-06	1 055000+00	0 0	0 0	0 0	0 0	11 8 476330+01	13 8 576440+01	
713	5.502780+01	1 5 087530-07	1 055000+00	0 0	0 0	0 0	0 0	21 8 759430+01	24 9 902100+01	
714	5.50630+01	1 7 591620+01	3 8 040870+01	5 8 209780+01	19 8 762330+01	19 8 762330+01	19 8 762330+01	11 8 476320+01	13 8 576340+01	
715	5.50630+01	1 5 8 664180+01	17 8 730350+01	19 8 730350+01	19 8 730350+01	19 8 730350+01	19 8 730350+01	21 8 759760+01	24 9 995810+01	
716	5.50630+01	25 1 030480+02						1 1 8 029770-06		
717	5.50630+01	1 2 840900-06	1 055000+00	0 0	0 0	0 0	0 0	2 3 463460-07	25 9 742220-11	24 9 463090-01
718	5.50630+01	1 2 840900-06	1 055000+00	0 0	0 0	0 0	0 0	11 8 476320+01	13 8 576340+01	
719	5.50630+01	1 6 810460-07	1 055000+00	0 0	0 0	0 0	0 0	21 8 759760+01	24 9 995810+01	
720	5.50630+01	1 7 591610+01	3 8 040790+01	5 8 209680+01	19 8 761650+01	19 8 761650+01	19 8 761650+01	11 8 476250+01	13 8 576230+01	
721	5.50630+01	1 7 591610+01	3 8 040790+01	5 8 209680+01	19 8 761650+01	19 8 761650+01	19 8 761650+01	21 8 760110+01	24 1 009040+02	
722	5.50630+01	1 7 591610+01	3 8 040790+01	5 8 209680+01	19 8 761650+01	19 8 761650+01	19 8 761650+01	1 1 7 502870-06		
723	5.50630+01	1 5 917200-07	1 055000+00	0 0	0 0	0 0	0 0	2 3 029010-07	25 9 814660-01	24 9 458900-01
724	5.50990+01	1 7 591590+01	3 8 040750+01	5 8 209620+01	19 8 761310+01	19 8 761310+01	19 8 761310+01	1 1 8 476170+01	13 8 576120+01	
725	5.50990+01	1 7 591590+01	3 8 040750+01	5 8 209620+01	19 8 761310+01	19 8 761310+01	19 8 761310+01	24 1 1 8581+02		
726	5.513510+01	1 1 448740-06	1 055000+00	0 0	0 0	0 0	0 0	1 6 915290-06		
727	5.513510+01	1 1 448740-06	1 055000+00	0 0	0 0	0 0	0 0	2 2 378300-07	25 9 884960-01	24 9 455010-01
728	5.513510+01	1 3 669060-07	1 055000+00	0 0	0 0	0 0	0 0	11 8 476170+01	13 8 576120+01	
729	5.51350+01	1 7 591580+01	3 8 040700+01	5 8 209570+01	19 8 760990+01	19 8 760990+01	19 8 760990+01	1 1 8 476100+01	13 8 576010+01	
730	5.51350+01	1 7 591580+01	3 8 040700+01	5 8 209570+01	19 8 760990+01	19 8 760990+01	19 8 760990+01	1 6 382260-06		
731	5.51350+01	1 3 669060-07	1 055000+00	0 0	0 0	0 0	0 0	2 2 041570-07	25 9 954370-01	24 9 450750-01
732	5.51350+01	1 7 591580+01	3 8 040700+01	5 8 209570+01	19 8 760990+01	19 8 760990+01	19 8 760990+01	13 8 576010+01		



706	5.558570+01	1 1 091200-05	1 055000+00	0 0	0 0	17 8 725680+01	19 8 757670+01	21 8 767200+01	24 1 140010+02
706	5.558570+01	2 1 051300-06	1 055000+00	0 0	0 0				1 5 742210-06
706	5.558570+01	1 5 013540-07	1 055000+00	0 0	0 0				2 2 131050-07
706	5.558570+01	1 7 591390+01	3 8 040160+01	3 8	040160+01				11 8 475130+01
706	5.558570+01	15 8 661010+01	17 8 725360+01	17 8	725360+01				21 8 767960+01
707	5.567550+01	1 7 408360-06	1 055000+00	0 0	0 0				24 1 150720+02
707	5.567550+01	1 7 408360-06	1 055000+00	0 0	0 0				1 5 118230-06
707	5.567550+01	1 1 254590-06	1 055000+00	0 0	0 0				2 6 650580-07
707	5.567550+01	1 1 254590-06	1 055000+00	0 0	0 0				25 1 084480+00
707	5.567550+01	1 7 591330+01	3 5 040110+01	3 5	040110+01				11 8 475040+01
707	5.567550+01	15 8 660790+01	17 8 725030+01	17 8	725030+01				21 8 768750+01
708	5.566570+01	1 5 674760-06	1 055000+00	0 0	0 0				24 1 161510+02
708	5.566570+01	1 5 674760-06	1 055000+00	0 0	0 0				1 4 658340-06
708	5.566570+01	1 1 015530-06	1 055000+00	0 0	0 0				2 5 130920-07
708	5.566570+01	1 7 591350+01	3 8 040060+01	3 8	040060+01				11 8 474950+01
708	5.566570+01	15 8 660580+01	17 8 724710+01	17 8	724710+01				21 8 769570+01
709	5.570640+01	1 4 634550-06	1 055000+00	0 0	0 0				24 1 172410+02
709	5.570640+01	1 4 634550-06	1 055000+00	0 0	0 0				1 4 278500-06
709	5.570640+01	1 8 771170-07	1 055000+00	0 0	0 0				2 4 574970-07
709	5.570640+01	1 7 591330+01	3 8 040000+01	3 8	040000+01				11 8 474850+01
709	5.570640+01	1 7 591330+01	17 8 724370+01	17 8	724370+01				21 8 770440+01
710	5.574770+01	1 4 215090-06	1 055000+00	0 0	0 0				24 1 183400+02
710	5.574770+01	1 4 215090-06	1 055000+00	0 0	0 0				1 3 952160-06
710	5.574770+01	1 8 328740-07	1 055000+00	0 0	0 0				2 4 349530-07
710	5.574770+01	1 7 591310+01	3 8 039950+01	3 8	039950+01				11 8 474760+01
710	5.574770+01	15 8 660130+01	17 8 724040+01	17 8	724040+01				21 8 771340+01
711	5.578960+01	25 1 239090+02	1 055000+00	0 0	0 0				24 1 194490+02
711	5.578960+01	1 4 221830-06	1 055000+00	0 0	0 0				1 3 726990-06
711	5.578960+01	1 4 221830-06	1 055000+00	0 0	0 0				2 4 437530-07
711	5.578960+01	1 8 842640-07	1 055000+00	0 0	0 0				2 5 1 123550+00
711	5.578960+01	1 7 591290+01	3 8 039900+01	3 8	039900+01				11 8 474660+01
711	5.578960+01	15 8 659900+01	17 8 723700+01	17 8	723700+01				21 8 772280+01
712	5.583200+01	25 1 250320+02	1 055000+00	0 0	0 0				24 1 205690+02
712	5.583200+01	1 3 801530-06	1 055000+00	0 0	0 0				1 3 644690-06
712	5.583200+01	1 3 801530-06	1 055000+00	0 0	0 0				2 4 117690-07
712	5.583200+01	1 8 134750-07	1 055000+00	0 0	0 0				2 5 1 134600+00
712	5.583200+01	1 7 591270+01	3 8 039840+01	3 8	039840+01				11 8 474570+01
712	5.583200+01	15 8 659670+01	17 8 723360+01	17 8	723360+01				21 8 773260+01
713	5.587500+01	25 1 261670+02	1 055000+00	0 0	0 0				24 1 216990+02
713	5.587500+01	1 4 172040-06	1 055000+00	0 0	0 0				1 3 711320-06
713	5.587500+01	1 4 172040-06	1 055000+00	0 0	0 0				2 4 224930-07
713	5.587500+01	1 8 479450-07	1 055000+00	0 0	0 0				2 5 1 145480+00
713	5.587500+01	1 7 591250+01	3 8 039790+01	3 8	039790+01				11 8 474470+01
713	5.587500+01	15 8 659440+01	17 8 723020+01	17 8	723020+01				21 8 774290+01
714	5.591860+01	25 1 273130+02	1 055000+00	0 0	0 0				24 1 228400+02
714	5.591860+01	1 3 985240-06	1 055000+00	0 0	0 0				1 3 658850-06
714	5.591860+01	1 3 985240-06	1 055000+00	0 0	0 0				2 2 102650-07
714	5.591860+01	1 8 337410-07	1 055000+00	0 0	0 0				2 5 1 156620+00
714	5.591860+01	1 7 591230+01	3 8 039730+01	3 8	039730+01				11 8 474360+01
714	5.591860+01	15 8 659200+01	17 8 722660+01	17 8	722660+01				13 8 573550+01
715	5.595930+01	25 1 284690+02	1 055000+00	0 0	0 0				24 1 239910+02
715	5.595930+01	1 1 347670-06	1 055000+00	0 0	0 0				1 2 106240-06
715	5.595930+01	1 1 347670-06	1 055000+00	0 0	0 0				2 1 616510-07
715	5.595930+01	1 5 26780-07	1 055000+00	0 0	0 0				2 5 1 080780+00
715	5.595930+01	1 7 591220+01	3 8 039670+01	3 8	039670+01				11 8 474270+01
715	5.595930+01	15 8 658980+01	17 8 722360+01	17 8	722360+01				21 8 776370+01
716	5.600000+01	25 1 295500+02	1 055000+00	0 0	0 0				24 1 250640+02
716	5.600000+01	1 4 218080-06	1 055000+00	0 0	0 0				1 3 030600-06
716	5.600000+01	1 4 218080-06	1 055000+00	0 0	0 0				2 3 590030-07
716	5.600000+01	1 7 452350-07	1 055000+00	0 0	0 0				2 5 1 076570+00
716	5.600000+01	1 7 591200+01	3 8 039620+01	3 8	039620+01				11 8 474170+01
716	5.600000+01	1 7 591200+01	3 8 039620+01	3 8	039620+01				13 8 573290+01



15 B 658750+01 17 B 722040+01 19 B 755110+01 21 B 777410+01 24 1 261340+02  
25 1 306270+02

HEATING6 02/12/83  
 W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

18M3033/ O  
 20 58 16 11-16-89

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 716 TIME STEPS, TIME = 5.600000+01

GROSS GRID 1

FINE GRID 1

	DISTANCE	O-O
1	0.0	75191
2	0.03	78115
3	0.06	80140
4	0.08	81124
5	0.10	82106
6	0.57	82154
7	1.04	82199
8	1.51	83143
9	1.98	83187
10	2.45	84131
11	2.92	84174
12	3.14	85125
13	3.35	85173
14	3.57	86118
15	3.79	86159
16	4.01	86194
17	4.23	87122
18	4.45	87142
19	4.67	87155
20	4.89	87164
21	5.10	87177
22	5.18	96140
23	5.25	108117
24	5.32	126113
25	5.35	130163

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	78.640000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 4.071918100-02

ELAPSED CPU TIME IS 8.62 SECONDS

THE MAXIMUM TEMPERATURE IS 1.306270+02 (+0.1 PERCENT)

MAX TEMP APPEARS AT NODES 25

THE MINIMUM TEMPERATURE IS 7.591200+01 (+0.1 PERCENT)

MIN TEMP APPEARS AT NODES 1

NO TIME	NO ITER	MAX HEAT RESIDUAL	CETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	MAX PERCENT TEMP CHANGE
717	5 60480+01	1 7 591180+01	3 8 039550+01	5 8 208100+01	11 8 474070+01	13 8 573140+01		25 1 177280+00	24 9 297210-01	
717	5 60480+01	15 8 588510+01	17 8 721690+01	19 8 754930+01	21 8 778590+01	23 8 802270+01				
718	5 609060+01	1 1 617560-06	1 055000+00	0 0	0 0	0 0				
718	5 609060+01	1 1 617560-06	1 055000+00	0 0	0 0	0 0				
718	5 609060+01	1 4 480480-07	1 055000+00	0 0	0 0	0 0				
718	5 609060+01	1 7 591150+01	3 8 039550+01	5 8 208020+01	11 8 473960+01	13 8 572990+01		25 1 200450+00	24 9 377830-01	
718	5 609060+01	15 8 588260+01	17 8 721340+01	19 8 754750+01	21 8 779820+01	23 8 802100+01				
719	5 613690+01	1 2 485170-06	1 055000+00	0 0	0 0	0 0				
719	5 613690+01	1 2 485170-06	1 055000+00	0 0	0 0	0 0				
719	5 613690+01	1 5 526140-07	1 055000+00	0 0	0 0	0 0				
719	5 613690+01	1 7 591130+01	3 8 039430+01	5 8 207940+01	11 8 473810+01	13 8 572830+01		25 1 213120+00	24 9 379540-01	
719	5 613690+01	15 8 588000+01	17 8 720920+01	19 8 754550+01	21 8 781090+01	23 8 802050+01				
720	5 618390+01	1 3 111510-06	1 055000+00	0 0	0 0	0 0				
720	5 618390+01	1 3 111510-06	1 055000+00	0 0	0 0	0 0				
720	5 618390+01	1 6 520280-07	1 055000+00	0 0	0 0	0 0				
720	5 618390+01	1 7 591110+01	3 8 039370+01	5 8 207850+01	11 8 473730+01	13 8 572670+01		25 1 225430+00	24 9 381650-01	
720	5 618390+01	15 8 587750+01	17 8 720630+01	19 8 754440+01	21 8 782400+01	23 8 802230+01				
721	5 623140+01	1 3 586430-06	1 055000+00	0 0	0 0	0 0				
721	5 623140+01	1 3 586430-06	1 055000+00	0 0	0 0	0 0				
721	5 623140+01	1 7 398130-07	1 055000+00	0 0	0 0	0 0				
721	5 623140+01	1 7 591090+01	3 8 039300+01	5 8 207770+01	11 8 473610+01	13 8 572510+01		25 1 237310+00	24 9 382560-01	
721	5 623140+01	15 8 587490+01	17 8 720270+01	19 8 754300+01	21 8 783770+01	23 8 802150+01				
722	5 627950+01	1 4 243410-06	1 055000+00	0 0	0 0	0 0				
722	5 627950+01	1 4 243410-06	1 055000+00	0 0	0 0	0 0				
722	5 627950+01	1 8 440330-07	1 055000+00	0 0	0 0	0 0				
722	5 627950+01	1 7 591060+01	3 8 039240+01	5 8 207680+01	11 8 473500+01	13 8 572350+01		25 1 248880+00	24 9 382530-01	
722	5 627950+01	15 8 587220+01	17 8 719910+01	19 8 754170+01	21 8 785170+01	23 8 802390+01				
723	5 63280+01	1 4 193610-06	1 055000+00	0 0	0 0	0 0				
723	5 63280+01	1 4 193610-06	1 055000+00	0 0	0 0	0 0				
723	5 63280+01	1 8 312030-07	1 055000+00	0 0	0 0	0 0				
723	5 63280+01	1 7 591040+01	3 8 039170+01	5 8 207600+01	11 8 473480+01	13 8 572190+01		25 1 260630+00	24 9 382360-01	
723	5 63280+01	15 8 586950+01	17 8 719550+01	19 8 754060+01	21 8 785620+01	23 8 802430+01				
724	5 63770+01	1 4 485100-06	1 055000+00	0 0	0 0	0 0				
724	5 63770+01	1 4 485100-06	1 055000+00	0 0	0 0	0 0				
724	5 63770+01	1 8 720330-07	1 055000+00	0 0	0 0	0 0				
724	5 63770+01	1 7 591010+01	3 8 039100+01	5 8 207510+01	11 8 473250+01	13 8 572020+01		25 1 272350+00	24 9 381990-01	
724	5 63770+01	15 8 586680+01	17 8 718830+01	19 8 753960+01	21 8 788120+01	23 8 802600+01				
725	5 64270+01	1 4 542890-06	1 055000+00	0 0	0 0	0 0				
725	5 64270+01	1 4 542890-06	1 055000+00	0 0	0 0	0 0				
725	5 64270+01	1 8 811160-07	1 055000+00	0 0	0 0	0 0				
725	5 64270+01	1 7 590990+01	3 8 039030+01	5 8 207420+01	11 8 473130+01	13 8 571850+01		25 1 284230+00	24 9 381620-01	
725	5 64270+01	15 8 586410+01	17 8 718830+01	19 8 753880+01	21 8 789670+01	23 8 802810+01				
726	5 64780+01	1 4 430050-06	1 055000+00	0 0	0 0	0 0				
726	5 64780+01	1 4 430050-06	1 055000+00	0 0	0 0	0 0				
726	5 64780+01	1 8 776830-07	1 055000+00	0 0	0 0	0 0				
726	5 64780+01	1 7 590960+01	3 8 038960+01	5 8 207330+01	11 8 472970+01	13 8 571670+01		25 1 296400+00	24 9 381470-01	

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NUMBER OF TIME STEPS



738	5.71930+01	15 8 552610+01	17 8 714270+01	19 8 754450+01	21 8 813730+01	24 1 532190+02
		25 1 573680+02				
738	5.719280+01	1 1 930810-05	1 055000+00	0 0	0 0	
738	5.719280+01	2 1 725600-06	1 055000+00	0 0	0 0	
738	5.719280+01	1 2 398390-06	1 055000+00	0 0	0 0	
738	5.719280+01	1 7 590580+01	3 8 037880+01	5 8 205940+01	11 8 471120+01	13 8 569140+01
		15 8 652240+01	17 8 713870+01	19 8 754680+01	21 8 816320+01	24 1 546420+02
		25 1 587740+02				
739	5.726350+01	1 1 880840-05	1 055000+00	0 0	0 0	
739	5.726350+01	2 1 635950-06	1 055000+00	0 0	0 0	
739	5.726350+01	1 2 413880-06	1 055000+00	0 0	0 0	
739	5.726350+01	1 7 590540+01	3 8 037760+01	5 8 205800+01	11 8 470930+01	13 8 568880+01
		15 8 651860+01	17 8 713470+01	19 8 754950+01	21 8 819000+01	24 1 550800+02
		25 1 602000+02				
740	5.733580+01	1 1 780530-05	1 055000+00	0 0	0 0	
740	5.733580+01	2 1 596770-06	1 055000+00	0 0	0 0	
740	5.733580+01	1 2 255670-06	1 055000+00	0 0	0 0	
740	5.733580+01	1 7 590500+01	3 8 037650+01	5 8 205650+01	11 8 470730+01	13 8 568620+01
		15 8 651470+01	17 8 713080+01	19 8 755250+01	21 8 821760+01	24 1 575330+02
		25 1 616440+02				
741	5.740950+01	1 1 742810-05	1 055000+00	0 0	0 0	
741	5.740950+01	2 1 613100-06	1 055000+00	0 0	0 0	
741	5.740950+01	1 2 252050-06	1 055000+00	0 0	0 0	
741	5.74100+01	1 7 590450+01	3 8 037530+01	5 8 205500+01	11 8 470520+01	13 8 568350+01
		15 8 651080+01	17 8 712680+01	19 8 755600+01	21 8 824600+01	24 1 590000+02
		25 1 631060+02				
742	5.748470+01	1 1 666540-05	1 055000+00	0 0	0 0	
742	5.748470+01	2 1 579650-06	1 055000+00	0 0	0 0	
742	5.748470+01	1 2 165940-06	1 055000+00	0 0	0 0	
742	5.748470+01	1 7 590420+01	3 8 037440	5 8 205350+01	11 8 470310+01	13 8 568070+01
		15 8 650680+01	17 8 712303+C	19 8 755980+01	21 8 827520+01	24 1 604830+02
		25 1 645860+02				
743	5.756130+01	1 1 217550-04	1 055000+00	0 0	0 0	
743	5.756130+01	3 1 548920-06	1 055000+00	0 0	0 0	
743	5.756130+01	2 1 435030-06	1 055000+00	0 0	0 0	
743	5.75610+01	1 7 590370+01	3 8 037240+01	5 8 205190+01	11 8 470090+01	13 8 567790+01
		15 8 650280+01	17 8 711520+01	19 8 756410+01	21 8 830510+01	24 1 619690+02
		25 1 660290+02				
744	5.763990+01	1 3 185490-04	1 055000+00	0 0	0 0	
744	5.763990+01	3 4 055180-06	1 055000+00	0 0	0 0	
744	5.763990+01	2 3 95670-06	1 055000+00	0 0	0 0	
744	5.76400+01	1 7 590330+01	3 8 037150+01	5 8 205020+01	11 8 469870+01	13 8 567490+01
		15 8 649860+01	17 8 711540+01	19 8 756890+01	21 8 833610+01	24 1 634280+02
		25 1 673440+02				
745	5.772280+01	1 1 670200-04	1 055000+00	0 0	0 0	
745	5.772280+01	3 2 189590-06	1 055000+00	0 0	0 0	
745	5.772280+01	2 2 593350-06	1 055000+00	0 0	0 0	
745	5.77230+01	1 7 590280+01	3 8 037040+01	5 8 204840+01	11 8 469630+01	13 8 567180+01
		15 8 649430+01	17 8 711170+01	19 8 757430+01	21 8 836890+01	24 1 648670+02
		25 1 686350+02				
746	5.781220+01	1 1 357320-04	1 055000+00	0 0	0 0	
746	5.781220+01	3 1 813130-06	1 055000+00	0 0	0 0	
746	5.781220+01	2 2 515620-06	1 055000+00	0 0	0 0	
746	5.78120+01	1 7 590230+01	3 8 036860+01	5 8 204650+01	11 8 469370+01	13 8 566850+01
		15 8 648970+01	17 8 710780+01	19 8 758060+01	21 8 840460+01	24 1 663170+02
		25 1 699510+02				
747	5.790610+01	1 1 150570-04	1 055000+00	0 0	0 0	
747	5.790610+01	3 1 548930-06	1 055000+00	0 0	0 0	
747	5.790610+01	2 2 339240-06	1 055000+00	0 0	0 0	
747	5.79060+01	1 7 590170+01	3 8 036710	5 8 204450+01	11 8 469090+01	13 8 566490+01
		15 8 648490+01	17 8 710710	19 8 758770+01	21 8 844220+01	24 1 677450+02
		25 1 712700+02				
748	5.800000+01	1 8 690340-05	1 055000+00	0 0	0 0	
748	5.800000+01	2 8 598820-06	1 055000+00	0 0	0 0	
748	5.800000+01	2 1 751040-06	1 055000+00	0 0	0 0	
748	5.80000+01	1 7 590120+01	3 8 036540+01	5 8 204240+01	11 8 468870+01	13 8 566140+01
		15 8 648000+01	17 8 710650+01	19 8 759120+01	21 8 845660+01	24 1 686630+02

15 8 646010+01 17 8 710030+01 19 8 759520+01 21 8 817990+01 24 1 690970+02  
25 1 725400+02

HEATING6 02/12/83  
 W9ANP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 748 TIME STEPS. TIME = 5.800000E+01

18M3037/ 0  
 20 58 18 11-16-89

GROSS GRID	FINE GRID	DISTANCE	C.O.
1	0	0	75190
2	0	0.03	78113
3	0	0.06	80137
4	0	0.08	81120
5	0	0.10	82104
6	0	0.57	82150
7	1	0.04	82195
8	1	0.51	83139
9	1	0.98	83183
10	2	0.45	84126
11	2	0.92	84169
12	3	0.14	85119
13	3	0.35	85166
14	3	0.57	86109
15	3	0.79	86148
16	4	0.01	86182
17	4	0.23	87110
18	4	0.45	87135
19	4	0.67	87160
20	4	0.89	87193
21	5	0.10	88148
22	5	0.18	112158
23	5	0.25	138188
10	24	5.32	169110
11	25	5.35	172154

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	82.670000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 9.389091600E-02

ELAPSED CPU TIME IS 8.95 SECONDS

THE MAXIMUM TEMPERATURE IS 1.775400E+02 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES 25

THE MINIMUM TEMPERATURE IS 7.590120E+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES 1

NO	TIME	NO	MAX HEAT	BETA	L1 NORM OF	RHD	RHD	ITER	L1 NORM OF	MAX TEMP	MAX PERCENT
TIME	ITER	RESIDUAL		TEMP DIFF	(ITERATION)	(JACOBI)	TEMP DIFF	CHANGE	TEMP CHANGE		
749	5.81030+01	1	1.07131D-04	1.05500D+00	0.0	0.0	1 5.89490-05	24 1.41834D+00	24 8.38769E-01		
749	5.81030+01	3	1.71544E-06	1.05500D+00	0.0	0.0	2 2.47850D-06				
749	5.81030+01	2	2.40115D-06	1.05500D+00	0.0	0.0					

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NO	TIME	NO	MAX HEAT	BETA	L1 NORM OF	RHD	RHD	ITER	L1 NORM OF	MAX TEMP	MAX PERCENT
TIME	ITER	RESIDUAL		TEMP DIFF	(ITERATION)	(JACOBI)	TEMP DIFF	CHANGE	TEMP CHANGE		
749	5.81030+01	1	1.7590050+01	3.8 03636D+01	5 8 20401D+01	11 8 46851D+01	13 8 56575D+01				
		15 8 54749D+01	17 8 70965D+01	19 8 76041D+01	21 8 85215D+01	24 1 70516D+02					
		25 1 73886D+02									
750	5.82169D+01	1	1.06764D-04	1.05500D+00	0.0	0.0	1 6.04862D-05				
750	5.82169D+01	3	1.98466D-06	1.05500D+00	0.0	0.0	2 2.45930D-06	24 1 49255D+00	24 8 75315D-01		
750	5.82169D+01	2	2.73087D-05	1.05500D+00	0.0	0.0	11 8 46817D+01	13 8 56531D+01			
750	5.82170+01	1	1.758998D+01	3.8 03616D+01	5 8 20376D+01	11 8 46817D+01	13 8 56531D+01				
		15 8 54653D+01	17 8 70927D+01	19 8 76145D+01	21 8 85671D+01	24 1 72008D+02					
		25 1 75319D+02									
751	5.83402D+01	1	1.01553D-04	1.05500D+00	0.0	0.0	1 5.91542D-05				
751	5.83402D+01	3	2.17355D-06	1.05500D+00	0.0	0.0	2 2.34934D-06	24 1 55832D+00	24 9 05955D-01		
751	5.83402D+01	2	2.92825D-05	1.05500D+00	0.0	0.0	11 8 46779D+01	13 8 56484D+01			
751	5.83400+01	1	1.758991D+01	3.8 03594D+01	5 8 20348D+01	11 8 46779D+01	13 8 56484D+01				
		15 8 54632D+01	17 8 70890D+01	19 8 76264D+01	21 8 86164D+01	24 1 73567D+02					
		25 1 76833D+02									
752	5.84695D+01	1	1.845768D-05	1.05500D+00	0.0	0.0	1 5.29616D-05				
752	5.84695D+01	3	1.97822D-06	1.05500D+00	0.0	0.0	2 1.95497D-06	24 1 58308D+00	24 9 12085D-01		
752	5.84695D+01	2	2.60234D-05	1.05500D+00	0.0	0.0	11 8 46739D+01	13 8 56435D+01			
752	5.84690+01	1	1.758983D+01	3.8 03571D+01	5 8 20319D+01	11 8 46739D+01	13 8 56435D+01				
		15 8 54570D+01	17 8 70855D+01	19 8 76398D+01	21 8 86678D+01	24 1 75150D+02					
		25 1 78389D+02									
753	5.86042D+01	1	2.66535D-04	1.05500D+00	0.0	0.0	1 6.80962D-05				
753	5.86042D+01	3	7.69169D-06	1.05500D+00	0.0	0.0	2 5.41515D-06	24 1 58883D+00	24 9 07127D-01		
753	5.86042D+01	2	7.55456D-06	1.05500D+00	0.0	0.0	11 8 46698D+01	13 8 56383D+01			
753	5.86040+01	1	1.758974D+01	3.8 03516D+01	5 8 20288D+01	11 8 46698D+01	13 8 56383D+01				
		15 8 54507D+01	17 8 70824D+01	19 8 76545D+01	21 8 87210D+01	24 1 76739D+02					
		25 1 79322D+02									
754	5.87452D+01	1	6.76728D-04	1.05500D+00	0.0	0.0	1 1.18662D-04				
754	5.87452D+01	4	1.88857D-06	1.05500D+00	0.0	0.0	2 1.35150D-05	24 1 53864D+00	24 8 70576D-01		
754	5.87452D+01	3	3.25318D-06	1.05500D+00	0.0	0.0	3 2.35351D-06				
754	5.87452D+01	2	3.48767D-06	1.05500D+00	0.0	0.0	11 8 46554D+01	13 8 56328D+01			
754	5.87450+01	1	1.758965D+01	3.8 03520D+01	5 8 20255D+01	11 8 46554D+01	13 8 56328D+01				
		15 8 54442D+01	17 8 70796D+01	19 8 76706D+01	21 8 87761D+01	24 1 78277D+02					
		25 1 81310*									
755	5.88991D+01	1	2.81681D-04	1.05500D+00	0.0	0.0	1 1.02231D-04				
755	5.88991D+01	3	7.44109D-06	1.05500D+00	0.0	0.0	2 6.77610D-06	24 1 52090D+00	24 8 53112D-01		
755	5.88991D+01	3	2.1741D-06	1.05500D+00	0.0	0.0	11 8 46605D+01	13 8 56269D+01			
755	5.88990+01	1	1.758955D+01	3.8 03492D+01	5 8 20219D+01	11 8 46605D+01	13 8 56269D+01				
		15 8 54373D+01	17 8 70772D+01	19 8 76892D+01	21 8 88357D+01	24 1 79794D+02					
		25 1 82733D+02									
756	5.90684D+01	1	3.20658D-04	1.05500D+00	0.0	0.0	1 1.02671D-04				
756	5.90684D+01	4	7.30226D-06	1.05500D+00	0.0	0.0	2 7.06459D-05	24 1 54726D+00	24 8 60552D-01		
756	5.90684D+01	3	2.09869D-06	1.05500D+00	0.0	0.0	11 8 46551D+01	13 8 56204D+01			
756	5.90680+01	1	1.758944D+01	3.8 03460D+01	5 8 20178D+01	11 8 46551D+01	13 8 56204D+01				
		15 8 54299D+01	17 8 70753D+01	19 8 77106D+01	21 8 89005D+01	24 1 81345D+02					
		25 1 84207E+02									
757	5.92546D+01	1	2.71451D-04	1.05500D+00	0.0	0.0	1 9.52216D-05				
757	5.92546D+01	4	4.78769D-07	1.05500D+00	0.0	0.0	2 6.02593D-06	24 1 59733D+00	24 8 80824D-01		
757	5.92546D+01	3	2.96782D-06	1.05500D+00	0.0	0.0	11 8 46491D+01	13 8 56132D+01			
757	5.92550+01	1	1.758932D+01	3.8 03424D+01	5 8 20133D+01	11 8 46491D+01	13 8 56132D+01				
		15 8 54222D+01	17 8 70740D+01	19 8 77351D+01	21 8 89705D+01	24 1 82943D+02					
		25 1 85757D+02									
758	5.94555D+01	1	2.19358D-04	1.05500D+00	0.0	0.0	1 8.16195D-05				
758	5.94555D+01	3	9.74818D-06	1.05500D+00	0.0	0.0	2 5.09336D-06	24 1 64347D+00	24 8 98354D-01		
758	5.94555D+01	3	2.75800D-06	1.05500D+00	0.0	0.0					



758	5.94550+01	1 7 589180+01	3 8 033850+0*	5 8 200840+01	11 8 464260+01	13 8 560540+01
		15 8 641400+01	17 8 707370+01	19 8 776280+01	21 8 904470+01	24 1 845860+02
		25 1 873770+02				
759	5.966790+01	1 2 627980-04	1 055000+00 0 0	0 0 0 0	1 7 379300-05	
		4 1 563110-07	1 055000+00 0 0	0 0 0 0	2 5 585020-06	24 1 673110+00
		3 3 519200-06	1 055000+00 0 0	0 0 0 0		24 9 064130-01
759	5.966790+01	1 7 589040+01	3 8 033440+01	5 8 200320+01	11 8 463560+01	13 8 559730+01
		15 8 640590+01	17 8 707440+01	19 8 779310+01	21 8 912150+01	24 1 862590+02
		25 1 890320+02				
760	5.983390+01	1 1 193170-04	1 055000+00 0 0	0 0 0 0		
		3 4 364030-06	1 055000+00 0 0	0 0 0 0	1 4 195670-05	
		2 4 910740-06	1 055000+00 0 0	0 0 0 0	2 2 633350-06	24 1 268270+00
760	5.983390+01	1 7 588910+01	3 8 033110+01	5 8 199900+01	11 8 467010+01	13 8 559100+01
		15 8 639980+01	17 8 707580+01	19 8 781760+01	21 8 918050+01	24 1 875280+02
		25 1 902920+02				
761	6.000000+01	1 1 340710-04	1 055000+00 0 0	0 0 0 0		
		3 5 090030-06	1 055000+00 0 0	0 0 0 0	1 3 451740-05	
		2 5 352510-06	1 055000+00 0 0	0 0 0 0	2 2 875560-06	24 1 234470+00
761	6.000000+01	1 7 588790+01	3 8 032770+01	5 8 199480+01	11 8 462460+01	13 8 558470+01
		15 8 639410+01	17 8 707780+01	19 8 784250+01	21 8 923860+01	24 1 887620+02
		25 1 915130+02				

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 761 TIME STEPS, TIME = 6.000000+01

GROSS GRID	1
FINE GRID	1
DISTANCE	0.0
1	75189
2	78111
3	80133
4	81115
5	81199
6	82185
7	82190
8	83134
9	83178
10	84121
11	84162
12	85112
13	85158
14	86101
15	86139
16	86175
17	87108
18	87142
19	87184
20	88141
21	89124
22	121111
23	154101
24	188176
25	191151

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	87.330000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 1.660747490-01

ELAPSED CPU TIME IS 9.12 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.915130+02 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 25

THE MINIMUM TEMPERATURE IS - 7.588790+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO	MAX HEAT	BETA	L1 NORM OF	RRG	RRD	THD	L1 NORM OF	MAX TEMP	NODE	MAX PERCENT
TIME	ITER	RESIDUAL	TEMP DIFF	(ITERATION)	(JACOBI)	TEMP DIFF	ITER	TEMP DIFF	CHANGE		TEMP CHANGE	
762	6.018270+01	1	1.38604D-04	1.055000+00	0.0	0.0	1	3.54469D-05	24	1.31844D+00	24	6.98469D-01
762	6.018270+01	3	5.77764D-06	1.055000+00	0.0	0.0	2	2.98868D-06				
762	6.018270+01	2	6.31654D-06	1.055000+00	0.0	0.0						

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
 \*\*\*\*\* NODE NUMBERS AND TEMPERATURES \*\*\*\*\*

NUMBER OF	TIME	MAX HEAT	BETA	L1 NORM OF	RRG	RRD	THD	L1 NORM OF	MAX TEMP	NODE	MAX PERCENT	
TIME STEPS		RESIDUAL	TEMP DIFF	(ITERATION)	(JACOBI)	TEMP DIFF	ITER	TEMP DIFF	CHANGE		TEMP CHANGE	
762	6.01830+01	1	7.58866D+01	3.8032400+01	5.819802D+01	11.846185D+01	13.855778D+01					
		15	8.63881D+01	17.870808D+01	19.878706D+01	21.893016D+01	24.190080D+02					
		25	1.92821D+02									
763	6.03836D+01	1	1.04854D-04	1.055000+00	0.0	0.0	1	2.28935D-05				
763	6.03836D+01	3	4.72991D-06	1.055000+00	0.0	0.0	2	2.35297D-06	24	1.41319D+00	24	7.43625D-01
763	6.03836D+01	2	5.61219D-06	1.055000+00	0.0	0.0						
763	5.0384D+01	1	7.58852D+01	3.803199D+01	5.819851D+01	11.846118D+01	13.855704D+01					
		15	8.63819D+01	17.870849D+01	19.879020D+01	21.893698D+01	24.191494D+02					
		25	1.94234D+02									
764	6.06047D+01	1	1.04342D-04	1.055000+00	0.0	0.0						
764	6.06047D+01	3	5.49162D-06	1.055000+00	0.0	0.0	1	3.07464D-05				
764	6.06047D+01	2	6.09323D-06	1.055000+00	0.0	0.0	2	2.28997D-06	25	1.53107D+00	24	7.96321D-01
764	6.0605D+01	1	7.58837D+01	3.803154D+01	5.819794D+01	11.846034D+01	13.855622D+01					
		15	8.63756D+01	17.870905D+01	19.879372D+01	21.894438D+01	24.193019D+02					
		25	1.95765D+02									
765	6.08478D+01	1	4.02363D-03	1.055000+00	0.0	0.0						
765	6.08478D+01	4	5.31060D-06	1.055000+00	0.0	0.0	1	3.50848D-04				
765	6.08478D+01	4	1.37326D-06	1.055000+00	0.0	0.0	2	8.51517D-05				
765	6.08478D+01	4	3.53204D-07	1.055000+00	0.0	0.0	3	2.19058D-05				
765	6.08478D+01	3	4.4549D-06	1.055000+00	0.0	0.0	4	5.50488D-06	24	1.29433D+00	23	6.91154D-01
765	6.0848D+01	1	7.58819D+01	3.803104D+01	5.819731D+01	11.845962D+01	13.855535D+01					
		15	8.63693D+01	17.870977D+01	19.879765D+01	21.895229D+01	24.194313D+02					
		25	1.96654D+02									
766	6.11153D+01	1	1.00323D-03	1.055000+00	0.0	0.0						
766	6.11153D+01	4	2.44678D-06	1.055000+00	0.0	0.0	1	2.68537D-04				
766	6.11153D+01	4	1.0110D-06	1.055000+00	0.0	0.0	2	2.55005D-05				
766	6.11153D+01	3	6.44316D-06	1.055000+00	0.0	0.0	3	6.79253D-06	23	9.41571D-01	23	5.95375D-01
766	6.1115D+01	1	7.58800D+01	3.803049D+01	5.819662D+01	11.845872D+01	13.855440D+01					
		15	8.63632D+01	17.871071D+01	19.880205D+01	21.896101D+01	24.195203D+02					
		25	1.97410D+02									
767	6.14095D+01	1	1.25689D-03	1.055000+00	0.0	0.0						
767	6.14095D+01	4	3.9601D-06	1.055000+00	0.0	0.0	1	2.41323D-04				
767	6.14095D+01	4	2.01305D-06	1.055000+00	0.0	0.0	2	2.81780D-05				
767	6.14095D+01	3	8.74077D-06	1.055000+00	0.0	0.0	3	7.89948D-06	23	7.51306D-01	23	4.72255D-01
767	6.1410D+01	1	7.58772D+01	3.802988D+01	5.819587D+01	11.845774D+01	13.855339D+01					
		15	8.63574D+01	17.871188D+01	19.880694D+01	21.897018D+01	24.195920D+02					
		25	1.98014D+02									
768	6.17048D+01	1	3.38224D-03	1.055000+00	0.0	0.0						
768	6.17048D+01	5	1.33312D-06	1.055000+00	0.0	0.0	1	3.71349D-04				
768	6.17048D+01	4	5.32534D-06	1.055000+00	0.0	0.0	2	2.38967D-05				
768	6.17048D+01	4	1.54127D-06	1.055000+00	0.0	0.0	3	2.12121D-05				
768	6.17048D+01	3	6.61797D-06	1.055000+00	0.0	0.0	4	5.96291D-06	23	5.01487D-01	23	3.13742D-01
768	6.1705D+01	1	7.58757D+01	3.802927D+01	5.819511D+01	11.845676D+01	13.855240D+01					
		15	8.63525D+01	17.871321D+01	19.881191D+01	21.897896D+01	24.196232D+02					
		25	1.98050D+02									
769	6.20000D+01	1	1.26881D-02	1.055000+00	0.0	0.0						
769	6.20000D+01	5	5.00109D-06	1.055000+00	0.0	0.0	1	1.12687D-03				
769	6.20000D+01	5	1.45885D-06	1.055000+00	0.0	0.0	2	2.77269D-04				
769	6.20000D+01	4	5.67840D-06	1.055000+00	0.0	0.0	3	7.96374D-05				
769	6.20000D+01	4	1.63480D-06	1.055000+00	0.0	0.0	4	2.27303D-05				
769	6.20000D+01	3	6.99434D-06	1.055000+00	0.0	0.0	5	6.36939D-06	25	2.11387D+00	25	1.06734D+00
769	6.19675D+01	1	1.18524D-04	1.055000+00	0.0	0.0						
769	6.19675D+01	3	9.71977D-06	1.055000+00	0.0	0.0	1	2.62787D-05				
769	6.19675D+01	2	5.51377D-06	1.055000+00	0.0	0.0	2	1.87672D-06	25	1.89627D+00	25	9.57873D-01
769	6.19675D+01	1	7.58737D+01	3.802872D+01	5.819443D+01	11.845590D+01	13.855456D+01					

770 6.200000+01 1 2.232010-05 1.055000+00 0 0 0.0 0.0 0.0  
770 6.200000+01 2 2.770930-06 1.055000+00 0 0 0.0 0.0 0.0  
770 6.200000+01 1 2.440530-06 1.055000+00 0 0 0.0 0.0 0.0  
770 6.200000+01 1 7.587310+01 3 8 028660+01 5 8 194353+01 11 8 455730+01 13 8 551460+01 25 1 521850-01  
15 8 634890+01 17 8 714510+01 19 8 8.6340+01 21 8 886340+01 23 1 953460+02  
25 1 961540+02  
15 8 634850+01 17 8 714670+01 19 8 816890+01 21 8 987220+01 24 1 951050+02  
25 1 958550+02



HEATING 02/12/83  
W9KMP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

IBM3033/ 0  
20.58 19 11-16-89

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 770 TIME STEPS, TIME = 6.200000E+01

GROSS GRID	1
FINE GRID	1
DISTANCE	0.0
1	0.0 75187
2	0.03 78108
3	0.06 80129
4	0.08 81112
5	0.10 81194
6	0.57 82140
7	1.04 82185
8	1.51 82129
9	1.98 83172
10	2.45 84114
11	2.92 84156
12	3.14 85105
13	3.35 85151
14	3.57 85194
15	3.79 86135
16	4.01 86174
17	4.23 87115
18	4.45 87160
19	4.67 88117
20	4.89 88190
21	5.10 89187
22	5.18 125107
23	5.5 160133
10 24	5.32 195110
11 25	5.35 195186

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	91.360000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 3.24589734E-02

ELAPSED CPU TIME IS 9.31 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.95855E+02 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 25

THE MINIMUM TEMPERATURE IS - 7.58734E+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO	MAX HEAT RESIDUAL	BETA	1.1 NORM OF TEMP DIFF	2ND ITERATION	RHO	ITER	1.1 NORM OF NODE TEMP DIFF	MAX TEMP CHANGE	MINI	MAX PERCENT TEMP CHANGE
771	6 203250+01	1	4 52000-06	1 055000+00	0 0	0 0	0 0	1 7 587360-06	25 2 971180-01	25 1 517030-01		
771	6 203250+01	1	4 65000-06	1 055000+00	0 0	0 0	0 0	2 3 542490-07	25 2 971180-01	25 1 517030-01		
771	6 203250+01	1	3 029210-07	1 055000+00	0 0	0 0	0 0					

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NO	TIME	NO	MAX HEAT RESIDUAL	BETA	1.1 NORM OF TEMP DIFF	2ND ITERATION	RHO	ITER	1.1 NORM OF NODE TEMP DIFF	MAX TEMP CHANGE	MINI	MAX PERCENT TEMP CHANGE
772	6 206490+01	1	2 512800-06	1 055000+00	0 0	0 0	0 0	1 6 926160-06	25 2 979870-01	25 1 523780-01		
772	6 206490+01	1	2 512800-06	1 055000+00	0 0	0 0	0 0	2 2 764190-07	25 2 979870-01	25 1 523780-01		
772	6 206490+01	1	2 160830-07	1 055000+00	0 0	0 0	0 0	11 8 455380-01	13 8 551750+01			
772	6 20650+01	1	1 7 587250+01	3 8 028520+01	5 8 194180+01	19 8 817980+01	21 8 988960+01	24 1 946100+02				
772	6 20650+01	1	15 8 634780+01	17 8 715010+01	19 8 817980+01	19 8 817980+01	21 8 988960+01	24 1 946100+02				
772	6 20650+01	1	25 1 952600+02									
773	6 209740+01	1	2 097330-05	1 055000+00	0 0	0 0	0 0	1 6 720480-06	25 3 003760-01	25 1 538340-01		
773	6 209740+01	1	2 097330-06	1 055000+00	0 0	0 0	0 0	2 2 494580-07	25 3 003760-01	25 1 538340-01		
773	6 209740+01	1	2 100290-07	1 055000+00	0 0	0 0	0 0	11 8 455470+01	13 8 551150+01			
773	6 209740+01	1	1 7 587220+01	3 8 028450+01	5 8 194100+01	19 8 818530+01	21 8 989810+01	24 1 943390+02				
773	6 209740+01	1	15 8 634750+01	17 8 715190+01	19 8 818530+01	19 8 818530+01	21 8 989810+01	24 1 943390+02				
773	6 209740+01	1	25 1 949600+02									
774	6 213310+01	1	2 428770-06	1 055000+00	0 0	0 0	0 0	1 7 100210-06	25 3 326600-01	25 1 706300-01		
774	6 213310+01	1	2 428770-06	1 055000+00	0 0	0 0	0 0	2 2 562780-07	25 3 326600-01	25 1 706300-01		
774	6 213310+01	1	2 449780-07	1 055000+00	0 0	0 0	0 0	11 8 455360+01	13 8 551040+01			
774	6 21330+01	1	1 7 587190+01	3 8 028370+01	5 8 194010+01	19 8 819130+01	21 8 990740+01	24 1 940550+02				
774	6 21330+01	1	15 8 634710+01	17 8 715380+01	19 8 819130+01	19 8 819130+01	21 8 990740+01	24 1 940550+02				
774	6 21330+01	1	25 1 946270+02									
775	6 217240+01	1	2 961340-05	1 055000+00	0 0	0 0	0 0	1 8 140100-06	25 3 694580-01	25 1 898290-01		
775	6 217240+01	1	2 961340-06	1 055000+00	0 0	0 0	0 0	2 2 127130-07	25 3 694580-01	25 1 898290-01		
775	6 217240+01	1	3 969750-07	1 055000+00	0 0	0 0	0 0	11 8 455230+01	13 8 550920+01			
775	6 21720+01	1	1 7 587160+01	3 8 028190+01	5 8 193910+01	19 8 819800+01	21 8 991740+01	24 1 937230+02				
775	6 21720+01	1	15 8 634670+01	17 8 715590+01	19 8 819800+01	19 8 819800+01	21 8 991740+01	24 1 937230+02				
775	6 21720+01	1	25 1 942570+02									
776	6 221560+01	1	3 621410-06	1 055000+00	0 0	0 0	0 0	1 9 239160-06	25 4 111220-01	25 2 116380-01		
776	6 221560+01	1	3 621410-06	1 055000+00	0 0	0 0	0 0	2 4 247480-07	25 4 111220-01	25 2 116380-01		
776	6 221560+01	1	6 509650-07	1 055000+00	0 0	0 0	0 0	11 8 455090+01	13 8 550790+01			
776	6 22160+01	1	1 7 587130+01	3 8 028200+01	5 8 193800+01	19 8 820520+01	21 8 992830+01	24 1 933500+02				
776	6 22160+01	1	15 8 634630+01	17 8 715820+01	19 8 820520+01	19 8 820520+01	21 8 992830+01	24 1 933500+02				
776	6 22160+01	1	25 1 938460+02									
777	6 226310+01	1	4 435740-06	1 055000+00	0 0	0 0	0 0	1 1 030160-05	25 4 576430-01	25 2 360860-01		
777	6 226310+01	1	4 435740-06	1 055000+00	0 0	0 0	0 0	2 5 188540-07	25 4 576430-01	25 2 360860-01		
777	6 226310+01	1	8 817860-07	1 055000+00	0 0	0 0	0 0	11 8 454940+01	13 8 550640+01			
777	6 22630+01	1	1 7 587090+01	3 8 028100+01	5 8 193680+01	19 8 821320+01	21 8 994000+01	24 1 929310+02				
777	6 22630+01	1	15 8 634590+01	17 8 716090+01	19 8 821320+01	19 8 821320+01	21 8 994000+01	24 1 929310+02				
777	6 22630+01	1	25 1 933890+02									
778	6 231540+01	1	5 425570-06	1 055000+00	0 0	0 0	0 0	1 1 142120-05	25 5 096420-01	25 2 635330-01		
778	6 231540+01	1	5 425570-06	1 055000+00	0 0	0 0	0 0	2 6 262740-07	25 5 096420-01	25 2 635330-01		
778	6 231540+01	1	1 175120-06	1 055000+00	0 0	0 0	0 0	11 8 454770+01	13 8 550490+01			
778	6 23150+01	1	1 7 587050+01	3 8 027990+01	5 8 193540+01	19 8 822200+01	21 8 995260+01	24 1 924590+02				
778	6 23150+01	1	15 8 634540+01	17 8 716380+01	19 8 822200+01	19 8 822200+01	21 8 995260+01	24 1 924590+02				
778	6 23150+01	1	25 1 928790+02									
779	6 237290+01	1	6 660160-06	1 055000+00	0 0	0 0	0 0	1 1 256380-05	25 5 676920-01	25 2 943260-01		
779	6 237290+01	1	6 660160-06	1 055000+00	0 0	0 0	0 0	2 7 455900-07	25 5 676920-01	25 2 943260-01		
779	6 237290+01	1	1 518890-06	1 055000+00	0 0	0 0	0 0	11 8 454590+01	13 8 550310+01			
779	6 23730+01	1	1 7 587010+01	3 8 027870+01	5 8 193400+01	19 8 823170+01	21 8 996600+01	24 1 919300+02				
779	6 23730+01	1	15 8 634500+01	17 8 716700+01	19 8 823170+01	19 8 823170+01	21 8 996600+01	24 1 919300+02				
779	6 23730+01	1	25 1 923110+02									
780	6 243610+01	1	8 140640-06	1 055000+00	0 0	0 0	0 0	1 1 363690-05	25 6 321360-01	25 3 287040-01		
780	6 243610+01	1	8 140640-06	1 055000+00	0 0	0 0	0 0	2 8 533010-07	25 6 321360-01	25 3 287040-01		
780	6 243610+01	1	1 839680-06	1 055000+00	0 0	0 0	0 0	11 8 454390+01	13 8 550130+01			
780	6 24360+01	1	1 7 586970+01	3 8 027740+01	5 8 193240+C1	19 8 827740+01	21 8 998430+01	24 1 945510+02				

781	6.250570+01	1 9 887530-06	1 055000+00	0 0	0 0	0 0	19 8.824230+01	21 8.998030+01	24 1.913370+02
781	6.250570+01	1 9 887530-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
781	6.250570+01	1 2 231570-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
781	6.250600+01	1 7 586920+01	3 8 027600+01	3 8 027600+01	17 8.717470+01	17 8.717470+01	19 8.825390+01	21 8.999550+01	24 1.906730+02
782	6.258220+01	1 7 579690-05	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
782	6.258220+01	2 6 174000-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
782	6.258220+01	1 9 348050-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
782	6.258220+01	1 7 586860+01	3 8 027440+01	3 8 027440+01	17 8.719200+01	17 8.719200+01	19 8.826660+01	21 9.001140+01	24 1.899200+02
783	6.266640+01	1 1 061320-04	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
783	6.266640+01	3 1 501580-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
783	6.266640+01	2 1 580500-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
783	6.266640+01	1 7 586800+01	3 8 027270+01	3 8 027270+01	17 8.718430+01	17 8.718430+01	19 8.826050+01	21 9.002810+01	24 1.890540+02
784	6.275900+01	1 7 072050-01	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
784	6.275900+01	2 7 309500-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
784	6.275900+01	2 1 391620-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
784	6.275900+01	1 7 586730+01	3 8 027080+01	3 8 027080+01	17 8.718990+01	17 8.718990+01	19 8.829570+01	21 9.003530+01	24 1.880430+02
785	6.286090+01	1 6 906680-05	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
785	6.286090+01	2 7 559500-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
785	6.286090+01	2 1 592950-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
785	6.286100+01	1 7 586560+01	3 8 026880+01	3 8 026880+01	17 8.719620+01	17 8.719620+01	19 8.831220+01	21 9.006300+01	24 1.868910+02
786	6.297300+01	1 7 504840-05	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
786	6.297300+01	2 9 002440-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
786	6.297300+01	2 1 909930-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
786	6.297300+01	1 7 586580+01	3 8 026660+01	3 8 026660+01	17 8.720330+01	17 8.720330+01	19 8.833020+01	21 9.008090+01	24 1.855660+02
787	6.309620+01	1 1 071210-04	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
787	6.309620+01	3 2 422830-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
787	6.309620+01	2 2 943990-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
787	6.309620+01	1 7 586500+01	3 8 026440+01	3 8 026440+01	17 8.721120+01	17 8.721120+01	19 8.834970+01	21 9.009880+01	24 1.840570+02
788	6.323180+01	1 1 115750-04	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
788	6.323180+01	3 2 832250-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
788	6.323180+01	2 3 466240-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
788	6.323200+01	1 7 586410+01	3 8 026150+01	3 8 026150+01	17 8.722000+01	17 8.722000+01	19 8.837080+01	21 9.011620+01	24 1.823450+02
789	6.336740+01	1 1 439480-04	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
789	6.336740+01	3 3 859600-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
789	6.336740+01	2 4 240350-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
789	6.335880+01	1 3 277630-05	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
789	6.335880+01	2 5 047090-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
789	6.335880+01	1 5 325420-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
789	6.335900+01	1 7 586310+01	3 8 025900+01	3 8 025900+01	17 8.722840+01	17 8.722840+01	19 8.839010+01	21 9.013050+01	24 1.806920+02
790	6.348570+01	1 5 032150-05	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
790	6.348570+01	2 6 015430-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
790	6.348570+01	2 1 552190-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0
790	6.348600+01	1 7 586230+01	3 8 025660+01	3 8 025660+01	17 8.723690+01	17 8.723690+01	19 8.840890+01	21 9.014280+01	24 1.789990+02
791	6.361270+01	1 4 251030-04	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0

791	6	361270+01	4	1	173130-06	1	055000+00	0	0	0	0	0	0	0	0	1	632040-05	25	1	907500+00	25	1	068460+00		
		791	6	361270+01	3	1	834370-06	1	055000+00	0	0	0	0	0	0	0	2	8	494340-06	25	1	907500+00	25	1	068460+00
		791	6	359860+01	1	2	225150-05	1	055000+00	0	0	0	0	0	0	0									
		791	6	359860+01	2	3	302800-06	1	055000+00	0	0	0	0	0	0	0									
		791	6	359860+01	1	3	103770-06	1	055000+00	0	0	0	0	0	0	0									
		791	6	359860+01	1	7	586150+01	3	8	025440+01	5	8	190420+01	11	8	450860+01	11	8	450860+01	24	1	774330+02	25	9	544060-01
		791	6	359860+01	15	8	634340+01	17	8	724450+01	19	8	842530+01	21	9	015210+01	21	9	015210+01	24	1	774330+02	25	9	544060-01
		791	6	359860+01	25	1	768240+02																		
		792	5	371150+01	1	5	153990-04	1	055000+00	0	0	0	0	0	0	0									
		792	6	371150+01	4	1	368260-06	1	055000+00	0	0	0	0	0	0	0									
		792	6	371150+01	3	1	760840-06	1	055000+00	0	0	0	0	0	0	0									
		792	6	371150+01	2	1	590010-06	1	055000+00	0	0	0	0	0	0	0									
		792	6	369780+01	1	3	080670-05	1	055000+00	0	0	0	0	0	0	0									
		792	6	369780+01	2	4	215420-06	1	055000+00	0	0	0	0	0	0	0									
		792	6	369780+01	1	3	852960-06	1	055000+00	0	0	0	0	0	0	0									
		792	6	369780+01	1	7	586070+01	3	8	025250+01	5	8	190190+01	11	8	450580+01	13	8	546810+01	25	1	691930+00	25	9	568420-01
		792	6	369780+01	15	8	634390+01	17	8	725130+01	19	8	843930+01	21	9	015910+01	21	9	015910+01	24	1	759520+02	25	9	568420-01
		792	6	369780+01	25	1	751320+02																		
		793	6	379700+01	1	1	173990-04	1	055000+00	0	0	0	0	0	0	0									
		793	6	379700+01	3	1	513480-06	1	055000+00	0	0	0	0	0	0	0									
		793	6	379700+01	2	2	614900-05	1	055000+00	0	0	0	0	0	0	0									
		793	6	379700+01	1	1	559930-05	1	055000+00	0	0	0	0	0	0	0									
		793	6	379170+01	2	1	966430-06	1	055000+00	0	0	0	0	0	0	0									
		793	6	379170+01	1	1	956560-06	1	055000+00	0	0	0	0	0	0	0									
		793	6	379170+01	1	7	586010+01	3	8	025080+01	5	8	189980+01	11	8	450320+01	13	8	546500+01	25	1	670420+00	25	9	538070-01
		793	6	379170+01	15	8	634440+01	17	8	735770+01	19	8	845230+01	21	9	016910+01	21	9	016910+01	24	1	744450+02	25	9	538070-01
		793	6	379170+01	25	1	734620+02																		
		794	6	388560+01	1	8	545220-05	1	055000+00	0	0	0	0	0	0	0									
		794	6	388560+01	2	7	811230-05	1	055000+00	0	0	0	0	0	0	0									
		794	6	388560+01	2	1	667780-06	1	055000+00	0	0	0	0	0	0	0									
		794	6	388560+01	1	7	585950+01	3	8	024940+01	5	8	189770+01	11	8	450060+01	13	8	546400+01	25	1	720310+00	25	9	917490-01
		794	6	388560+01	15	8	634510+01	17	8	726420+01	19	8	846500+01	21	9	016910+01	21	9	016910+01	24	1	728580+02	25	9	917490-01
		794	6	388560+01	25	1	717420+02																		
		795	6	394280+01	1	7	194080-05	1	055000+00	0	0	0	0	0	0	0									
		795	6	394280+01	2	6	274380-06	1	055000+00	0	0	0	0	0	0	0									
		795	6	394280+01	1	6	587640-06	1	055000+00	0	0	0	0	0	0	0									
		795	6	394280+01	1	7	565900+01	3	8	024800+01	5	8	189640+01	11	8	449300+01	13	8	546270+01	25	1	108620+00	25	6	455180-01
		795	6	394280+01	15	8	634550+01	17	8	726820+01	19	8	847260+01	21	9	017130+01	21	9	017130+01	24	1	718520+02	25	6	455180-01
		795	6	394280+01	25	1	706330+02																		
		796	6	400000+01	1	1	191940-05	1	055000+00	0	0	0	0	0	0	0									
		796	6	400000+01	2	1	500330-06	1	055000+00	0	0	0	0	0	0	0									
		796	6	400000+01	1	1	639900-07	1	055000+00	0	0	0	0	0	0	0									
		796	6	400000+01	1	7	585860+01	3	8	024690+01	5	8	189510+01	11	8	449740+01	13	8	546150+01	25	1	107450+00	25	6	490220-01
		796	6	400000+01	15	8	634600+01	17	8	727210+01	19	8	848010+01	21	9	017310+01	21	9	017310+01	24	1	708190+02	25	6	490220-01
		796	6	400000+01	25	1	695250+02																		



HEATING 02/12/83  
 W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 796 TIME STEPS, TIME = 6.400000+01

TBM0033/ 0  
 20 58 20 11-16-89

GROSS GRID	FINE GRID	DISTANCE	TEMPERATURE
1	1	0.0	75186
2	2	0.03	78105
3	3	0.06	80125
4	4	0.08	81107
5	5	0.10	81190
6	6	0.57	82135
7	7	1.04	82179
8	8	1.51	83123
9	9	1.98	83166
10	10	2.45	84108
11	11	2.92	84150
12	12	3.14	84199
13	13	3.35	85146
14	14	3.57	85191
15	15	3.79	86135
16	16	4.01	86179
17	17	4.23	87127
18	18	4.45	87182
19	19	4.67	88148
20	20	4.89	89127
21	21	5.10	90117
22	22	5.18	119142
23	23	5.25	146197
24	24	5.32	170182
25	25	5.35	169153

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	93.690000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 5.72126637D-02

ELAPSED CPU TIME IS 9.63 SECONDS

THE MAXIMUM TEMPERATURE IS 1.70819D+02 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES 24

THE MINIMUM TEMPERATURE IS 7.58586D+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES 1

NO	TIME	MD	MAX HEAT	BETA	LI NORM OF	RHO	RHO	NO	LI NORM OF	MAX TEMP	MODE	MAX PERCENT
TIME	ITER	RESIDUAL		TEMP DIFF	(1:RATIO)	(JACOBI)	ITER	TEMP DIFF	CHANGE		TEMP CHANGE	
797	6.405720+01	1	585820-06	1.055000+00	0.0	0.0	1	488620-05	25	1.117730+00	25	6.593260-01
797	6.405720+01	1	580190-06	1.055000+00	0.0	0.0	2	063700-06	25	1.117730+00	25	6.593260-01
797	6.405720+01	1	285060-06	1.055000+00	0.0	0.0	2	063700-06	25	1.117730+00	25	6.593260-01

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NUMBER OF	TIME	LI NORM OF	RHO	RHO	NO	LI NORM OF	MAX TEMP	MODE	MAX PERCENT
TIME STEPS		TEMP DIFF	(1:RATIO)	(JACOBI)	ITER	TEMP DIFF	CHANGE		TEMP CHANGE
797	6.40570+01	3.8	024590+01	5.8	189390+01	11.8	419530+01	13.8	546030+01
		17.8	727610+01	19.8	848740+01	21.9	017440+01	24.1	697660+02
798	6.412010+01	3.8	024470+01	5.8	189250+01	11.8	419420+01	13.8	545900+01
798	6.412010+01	17.8	728050+01	19.8	849530+01	21.9	017550+01	24.1	685900+02
799	6.418940+01	3.8	024250+01	5.8	189100+01	11.8	419240+01	13.8	545760+01
799	6.418940+01	17.8	728530+01	19.8	850390+01	21.9	017600+01	24.1	672780+02
800	6.426550+01	3.8	024210+01	5.8	188930+01	11.8	419040+01	13.8	545610+01
800	6.426550+01	17.8	729610+01	19.8	851310+01	21.9	017580+01	24.1	658170+02
801	6.434430+01	3.8	024070+01	5.8	188770+01	11.8	418830+01	13.8	545460+01
801	6.434430+01	17.8	729610+01	19.8	852230+01	21.9	017480+01	24.1	642860+02
802	6.442310+01	3.8	023940+01	5.8	188600+01	11.8	418630+01	13.8	545310+01
802	6.442310+01	17.8	730150+01	19.8	853140+01	21.9	017290+01	24.1	627340+02
803	6.450190+01	3.8	023810+01	5.8	188440+01	11.8	418440+01	13.8	545170+01
803	6.450190+01	17.8	730660+01	19.8	853960+01	21.9	017040+01	24.1	612620+02
804	6.457070+01	3.8	023680+01	5.8	188290+01	11.8	418290+01	13.8	545040+01
804	6.457070+01	17.8	731170+01	19.8	854750+01	21.9	016720+01	24.1	597700+02
805	6.464950+01	3.8	023560+01	5.8	188150+01	11.8	418150+01	13.8	544910+01
805	6.464950+01	17.8	731560+01	19.8	855540+01	21.9	016100+01	24.1	585200+02

806	6.471050+01	1 2 032810-05	1 055000+00	0 0	0 0	19 8 855280+01	21 9 016340+01	24 1 583360+02	
806	6.471050+01	2 1 817480-06	1 055000+00	0 0	0 0	0 0	0 0	1 1 745720-05	25 9 720110-01
806	6.471050+01	1 2 562830-06	1 055000+00	0 0	0 0	0 0	0 0	2 5 588580-07	25 9 520880+00
806	6.47110+01	1 7 585410+01	3 8 023450+01	5 8 188010+01	19 8 856190+01	11 8 447910+01	21 9 015880+01	13 8 544790+01	24 1 568810+02
807	6.478050+01	1 2 159420-05	1 055000+00	0 0	0 0	0 0	0 0	1 1 675580-05	
807	6.478050+01	2 1 840770-06	1 055000+00	0 0	0 0	0 0	0 0	2 5 619340-07	25 9 914260-01
807	6.478050+01	1 2 589670-06	1 055000+00	0 0	0 0	0 0	0 0	11 8 447740+01	13 8 544670+01
807	6.47800+01	1 7 585370+01	3 8 023330+01	5 8 187870+01	19 8 856880+01	11 8 447740+01	21 9 015380+01	13 8 544670+01	24 1 554070+02
808	6.485040+01	1 2 037720-05	1 055000+00	0 0	0 0	0 0	0 0	1 1 594430-05	
808	6.485040+01	2 1 725860-06	1 055000+00	0 0	0 0	0 0	0 0	2 5 274840-07	25 1 550370+00
808	6.485040+01	1 2 439080-06	1 055000+00	0 0	0 0	0 0	0 0	1 1 861660-06	
808	6.484620+01	1 9 061920-06	1 055000+00	0 0	0 0	0 0	0 0	2 4 839220-07	25 9 532910-01
808	6.484620+01	1 9 061920-06	1 055000+00	0 0	0 0	0 0	0 0	11 8 447580+01	13 8 544570+01
808	6.484620+01	1 1 428430-06	1 055000+00	0 0	0 0	0 0	0 0	21 9 014240+01	24 1 525880+02
808	6.48460+01	1 7 585330+01	3 8 023220+01	5 8 187740+01	19 8 857510+01	11 8 447580+01	21 9 014840+01	13 8 544570+01	24 1 540050+02
809	6.491190+01	1 1 026130-05	1 055000+00	0 0	0 0	0 0	0 0	1 1 309540-05	
809	6.491190+01	2 1 059320-06	1 055000+00	0 0	0 0	0 0	0 0	2 3 045800-07	25 1 471540+00
809	6.491190+01	1 1 340030-06	1 055000+00	0 0	0 0	0 0	0 0	11 8 447430+01	13 8 544360+01
809	6.49120+01	1 7 585290+01	3 8 023110+01	5 8 187610+01	19 8 858110+01	11 8 447430+01	21 9 014240+01	13 8 544360+01	24 1 525880+02
810	6.497770+01	1 1 371930-05	1 055000+00	0 0	0 0	0 0	0 0	1 1 280050-05	
810	6.497770+01	2 1 257560-06	1 055000+00	0 0	0 0	0 0	0 0	2 3 544220-07	25 1 481970+00
810	6.497770+01	1 1 532220-06	1 055000+00	0 0	0 0	0 0	0 0	11 8 447280+01	13 8 544360+01
810	6.49780+01	1 7 585250+01	3 8 023010+01	5 8 187480+01	19 8 858690+01	11 8 447280+01	21 9 013580+01	13 8 544360+01	24 1 515580+02
811	6.504340+01	1 1 973310-05	1 055000+00	0 0	0 0	0 0	0 0	1 1 346150-05	
811	6.504340+01	2 1 658250-06	1 055000+00	0 0	0 0	0 0	0 0	2 4 714030-07	25 1 495440+00
811	6.504340+01	1 2 006720-06	1 055000+00	0 0	0 0	0 0	0 0	1 1 532820-05	
811	6.503990+01	1 7 183670-06	1 055000+00	0 0	0 0	0 0	0 0	2 3 831740-07	25 1 419590+00
811	6.503990+01	1 7 183670-06	1 055000+00	0 0	0 0	0 0	0 0	11 8 447130+01	13 8 544260+01
811	6.503990+01	1 1 083110-06	1 055000+00	0 0	0 0	0 0	0 0	21 9 012910+01	24 1 497920+02
811	6.50400+01	1 7 585210+01	3 8 022910+01	5 8 187360+01	19 8 859230+01	11 8 447130+01	21 9 012910+01	13 8 544260+01	24 1 497920+02
812	6.510210+01	1 1 182200-05	1 055000+00	0 0	0 0	0 0	0 0	1 1 165110-05	
812	6.510210+01	2 1 146950-06	1 055000+00	0 0	0 0	0 0	0 0	2 3 190010-07	25 1 429260+00
812	6.510210+01	1 1 303200-06	1 055000+00	0 0	0 0	0 0	0 0	11 8 446990+01	13 8 544170+01
812	6.51020+01	1 7 585160+01	3 8 022810+01	5 8 187240+01	19 8 859740+01	11 8 446990+01	21 9 012180+01	13 8 544170+01	24 1 484140+02
813	6.51640+01	1 7 585160+01	3 8 022710+01	5 8 187120+01	19 8 860230+01	11 8 446850+01	21 9 011400+01	13 8 544080+01	24 1 470750+02
813	6.51640+01	1 7 585160+01	3 8 022710+01	5 8 187120+01	19 8 860230+01	11 8 446850+01	21 9 011400+01	13 8 544080+01	24 1 470750+02
813	6.51640+01	1 1 302680-05	1 055000+00	0 0	0 0	0 0	0 0	1 1 141030-05	
813	6.516430+01	2 1 211400-06	1 055000+00	0 0	0 0	0 0	0 0	2 3 401690-07	25 1 439270+00
813	6.516430+01	1 1 389140-06	1 055000+00	0 0	0 0	0 0	0 0	11 8 446850+01	13 8 544080+01
813	6.51640+01	1 7 585140+01	3 8 022710+01	5 8 187120+01	19 8 860230+01	11 8 446850+01	21 9 011400+01	13 8 544080+01	24 1 470750+02
814	6.522650+01	1 1 261470-05	1 055000+00	0 0	0 0	0 0	0 0	1 1 102930-05	
814	6.522650+01	2 1 168330-06	1 055000+00	0 0	0 0	0 0	0 0	2 3 127240-07	25 1 444880+00
814	6.522650+01	1 1 254550-06	1 055000+00	0 0	0 0	0 0	0 0	1 1 332450-06	
814	6.522330+01	1 6 030660-06	1 055000+00	0 0	0 0	0 0	0 0	2 3 277150-07	25 1 378290+00
814	6.522320+01	1 6 030660-06	1 055000+00	0 0	0 0	0 0	0 0	11 8 446720+01	13 8 543980+01
814	6.522330+01	1 9 117130-07	1 055000+00	0 0	0 0	0 0	0 0	21 9 010620+01	24 1 456960+02
814	6.52230+01	1 7 585110+01	3 8 022620+01	5 8 187010+01	19 8 860680+01	11 8 446720+01	21 9 010620+01	13 8 543980+01	24 1 456960+02
815	6.528240+01	1 6 983150-06	1 055000+00	0 0	0 0	0 0	0 0		

815	6.528240+01	1	6.983150-06	1	055000+00	0.0	0.0	0.0	1.9	023130-06	25	9.667480-01
815	6.528240+01	1	6.12460-06	1	055000+00	0.0	0.0	0.0	2.7	151220-07	25	1.394900+00
815	6.528240+01	1	7.585070+01	3	8.022530+01	5.8	186900+01	19.8	416530+01	13.8	543910+01	
815	6.528240+01	1	6.36260+01	17	8.735970+01	19.8	61110+01	19.8	009790+01	24.1	443560+02	
816	6.534140+01	1	6.264450-06	1	055000+00	0.0	0.0	0.0	1.8	902720-06	25	9.810080-01
816	6.534140+01	1	9.286450-06	1	055000+00	0.0	0.0	0.0	2.7	940910-07	25	1.392470+00
816	6.534140+01	1	7.208030-06	1	055000+00	0.0	0.0	0.0	11.8	445160+01	13.8	543830+01
816	6.534140+01	1	7.585040+01	3	8.022440+01	5.8	126800+01	19.8	008910+01	24.1	430080+02	
817	6.540040+01	1	1.405500+02	25	1.405500+02	0.0	0.0	0.0	1.9	212820-06	25	1.400350+00
817	6.540040+01	1	1.009560-05	1	055000+00	0.0	0.0	0.0	2.2	481540-07	25	1.400350+00
817	6.540040+01	2	9.540040-07	1	055000+00	0.0	0.0	0.0	11.8	445330+01	13.8	543750+01
817	6.540040+01	1	9.286300-07	1	055000+00	0.0	0.0	0.0	21.9	007990+01	24.1	416520+07
817	6.540040+01	1	7.585010+01	3	8.022350+01	5.8	186690+01	19.8	445270+01	13.8	543680+01	
818	6.545500+01	1	6.364650+01	17	8.736730+01	19.8	861920+01	19.8	007090+01	24.1	403100+02	
818	6.545500+01	1	9.881930-06	1	055000+00	0.0	0.0	0.0	1.8	583970-06	25	1.408040+00
818	6.545500+01	1	9.081930-06	1	055000+00	0.0	0.0	0.0	2.7	905570-07	25	1.408040+00
818	6.545500+01	1	1.905610-06	1	055000+00	0.0	0.0	0.0	1.1	530770-06	25	1.326040+00
818	6.545500+01	1	6.718750-06	1	055000+00	0.0	0.0	0.0	2.3	684610-07	25	1.326040+00
818	6.545500+01	1	6.718750-06	1	055000+00	0.0	0.0	0.0	11.8	445270+01	13.8	543680+01
818	6.545500+01	1	9.867740-07	1	055000+00	0.0	0.0	0.0	21.9	007090+01	24.1	403100+02
819	6.551130+01	1	4.398270-06	1	055000+00	0.0	0.0	0.0	1.7	258300-06	25	1.330780+00
819	6.551130+01	1	4.398270-06	1	055000+00	0.0	0.0	0.0	2.5	084780-07	25	1.330780+00
819	6.551130+01	1	1.113790-06	1	055000+00	0.0	0.0	0.0	11.8	445100+01	13.8	543610+01
819	6.551130+01	1	7.584950+01	3	8.022180+01	5.8	186490+01	19.8	006180+01	24.1	330800+02	
820	6.556700+01	1	6.56760+01	17	8.737780+01	19.8	862610+01	19.8	445280+01	13.8	543540+01	
820	6.556700+01	1	2.542270-05	1	055000+00	0.0	0.0	0.0	1.9	018720-06	25	1.316790+00
820	6.556700+01	2	1.991390-06	1	055000+00	0.0	0.0	0.0	2.4	644010-07	25	1.316790+00
820	6.556700+01	1	1.499780-06	1	055000+00	0.0	0.0	0.0	11.8	445280+01	13.8	543540+01
820	6.556700+01	1	7.584920+01	3	8.022100+01	5.8	186390+01	19.8	005160+01	24.1	377870+02	
821	6.562210+01	1	2.206720-05	1	055000+00	0.0	0.0	0.0	1.8	200920-06	25	1.303420+00
821	6.562210+01	2	1.763310-06	1	055000+00	0.0	0.0	0.0	2.4	425310-07	25	1.303420+00
821	6.562210+01	1	1.448730-06	1	055000+00	0.0	0.0	0.0	11.8	445870+01	13.8	543480+01
821	6.562210+01	1	7.584890+01	3	8.022020+01	5.8	186300+01	19.8	004130+01	24.1	364960+02	
822	6.567750+01	1	6.366860+01	17	8.738130+01	19.8	862420+01	19.8	445760+01	13.8	543410+01	
822	6.567750+01	1	8.396040-06	1	055000+00	0.0	0.0	0.0	1.5	872710-06	25	1.297390+00
822	6.567750+01	1	8.396040-06	1	055000+00	0.0	0.0	0.0	2.7	118490-07	25	1.297390+00
822	6.567750+01	1	1.491560-06	1	055000+00	0.0	0.0	0.0	11.8	445760+01	13.8	543410+01
822	6.567750+01	1	7.584860+01	3	8.021940+01	5.8	186200+01	19.8	003070+01	24.1	352090+02	
823	6.573300+01	1	3.746970-06	1	055000+00	0.0	0.0	0.0	1.4	451650-06	25	1.294460+00
823	6.573300+01	1	3.746970-06	1	055000+00	0.0	0.0	0.0	2.3	901110-07	25	1.294460+00
823	6.573300+01	1	7.104300-07	1	055000+00	0.0	0.0	0.0	11.8	445650+01	13.8	543350+01
823	6.573300+01	1	7.584830+01	3	8.021860+01	5.8	186110+01	19.8	001970+01	24.1	339270+02	
824	6.578800+01	1	3.044850-06	1	055000+00	0.0	0.0	0.0	1.3	286780-06	25	1.293410+00
824	6.578800+01	1	3.044850-06	1	055000+00	0.0	0.0	0.0	2.1	909440-07	25	1.293410+00
824	6.578800+01	1	2.672250-07	1	055000+00	0.0	0.0	0.0	11.8	445540+01	13.8	543290+01
824	6.578800+01	1	7.584800+01	3	8.021780+01	5.8	186030+01	19.8	000830+01	24.1	326480+02	
825	6.584380+01	1	2.211160-06	1	055000+00	0.0	0.0	0.0	1.2	345470-06	25	1.293460+00
825	6.584380+01	1	2.211160-06	1	055000+00	0.0	0.0	0.0	2.1	567440-07	25	1.293460+00
825	6.584380+01	1	2.152120-07	1	055000+00	0.0	0.0	0.0	11.8	445430+01	13.8	543230+01
825	6.584380+01	1	7.584770+01	3	8.021700+01	5.8	185920+01	19.8	445430+01	13.8	543230+01	

826	6	589920+01	15	8	637280+01	17	8	739470+01	19	8	852280+01	24	1	313740+02			
			25	1	286940+02				0	0	0						
			1	1	724700-06	1	055000+00	0	0	0	0	1	2	021360-06	25	1	005480+00
826	6	589920+01	1	1	724700-07	1	055000+00	0	0	0	0	2	1	640650-07	25	1	293990+00
826	6	589920+01	1	2	088150-07	1	055000+00	0	0	0	0	0	0	0	0	0	0
826	6	589620+01	1	5	625920-06	1	055000+00	0	0	0	0	0	0	0	0	0	0
826	6	589620+01	1	5	625920-06	1	055000+00	0	0	0	0	0	0	0	0	0	0
826	6	589620+01	1	8	650496-07	1	055000+00	0	0	0	0	0	0	0	0	0	0
826	6	589620+01	1	7	584720+01	3	8	021630+01	5	8	185840+01	11	8	445330+01	13	8	542170+01
			25	1	274680+01	17	8	739780-01	19	8	864480+01	21	8	998510+01	22	1	301660+02
			25	1	274680+02				0	0	0						
827	6	594810+01	1	3	828710-07	1	055000+00	0	0	0	0	0	0	0	0	0	0
827	6	594810+01	1	3	828710-07	1	055000+00	0	0	0	0	0	0	0	0	0	0
827	6	594810+01	1	7	989400-08	1	055000+00	0	0	0	0	0	0	0	0	0	0
827	6	594810+01	1	7	384720+01	3	8	021560+01	5	8	185750+01	11	8	445230+01	13	8	543120+01
			15	8	637480+01	17	8	740080+01	19	8	864670+01	21	8	997340+01	24	1	289700+02
			25	1	262520+02				0	0	0						
828	6	600000+01	1	1	281940-06	1	055000+00	0	0	0	0	0	0	0	0	0	0
828	6	600000+01	1	1	281940-06	1	055000+00	0	0	0	0	0	0	0	0	0	0
828	6	600000+01	1	2	075590-07	1	055000+00	0	0	0	0	0	0	0	0	0	0
828	6	600000+01	1	7	584690+01	3	8	021490+01	5	8	185670+01	11	8	445140+01	13	8	543070+01
828	6	600000+01	15	8	637590+01	17	8	740380+01	19	8	864840+01	21	8	996140+01	24	1	277750+02
			25	1	250350+02				0	0	0						

HEATING 02/12/83  
W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

IBM3033/ 11-16-89  
20 58 2.

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 828 TIME STEPS, TIME = 6.600000E+01

GROSS GRID	FINE GRID	DISTANCE	TEMP
1	1	0.0	75185
2	2	0.03	78103
3	3	0.06	80121
4	4	0.08	81104
5	5	0.10	81185
6	6	0.57	82130
7	7	1.04	82174
8	8	1.51	82118
9	9	1.98	83161
10	10	2.45	84103
11	11	2.92	84145
12	12	3.14	84195
13	13	3.55	85143
14	14	3.57	85190
15	15	3.79	85138
16	16	4.01	86187
17	17	4.23	87140
18	18	4.45	88100
19	19	4.67	88165
20	20	4.69	89133
21	21	5.10	89196
22	22	5.18	106115
23	23	5.25	119164
24	24	5.32	127177
25	25	5.35	125104

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	93.580000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 5.192100520E-02

ELAPSED CPU TIME IS 15.10.02 SECONDS

THE MAXIMUM TEMPERATURE IS 1.277750E+02 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES 24

THE MINIMUM TEMPERATURE IS 7.584690E+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES 1

NO	TIME	NO ITER	MA. HEAT RESIDUAL	P. A.	L1 NORM OF TEMP DIFF	RHO ITERATION	RHO (JACOBI)	NO ITER	L1 NORM OF NODE TEMP DIFF	MAX TEMP CHANGE	NODE TEMP CHANGE	MAX PERCENT TEMP CHANGE	
829	6.60519D+01	1	7.57410D-06	1.05500D+00	0.0	2.0	0.0	1	2.71955D-06	25	1.22148D+00	25	9.76910D-01
829	6.60519D+01	1	7.57410D-06	1.05500D+00	0.0	0.0	0.0	2	4.42762D-07	25	1.22148D+00	25	9.76910D-01
829	6.60519D+01	1	1.12354D-06	1.05500D+00	0.0	0.0	0.0	2	4.42762D-07	25	1.22148D+00	25	9.76910D-01

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NUMBER OF TIME	MA. HEAT RESIDUAL	P. A.	L1 NORM OF TEMP DIFF	RHO ITERATION	RHO (JACOBI)	NO ITER	L1 NORM OF NODE TEMP DIFF	MAX TEMP CHANGE	NODE TEMP CHANGE	MAX PERCENT TEMP CHANGE			
829	6.6052D+01	17	7.4067D+01	19	8.86500D+01	11	1504D+01	13	8.5430D+01	25	1.26178D+02	25	1.00253D+00
830	6.61038D+01	1	5.1925D-06	1.05500D+00	0.0	0.0	0.0	1	2.75013D-06	25	1.22522D+00	25	9.89564D-01
830	6.61038D+01	1	5.1925D-06	1.05500D+00	0.0	0.0	0.0	2	3.61895D-07	25	1.22522D+00	25	9.89564D-01
830	6.61038D+01	1	8.88-88D-07	1.05500D+00	0.0	0.0	0.0	11	8.4495D+01	13	8.54297D+01	25	9.89564D-01
830	6.61038D+01	1	7.5846D-06	1.05500D+00	0.0	0.0	0.0	21	8.99365D+01	24	1.25379D+02	25	9.89564D-01
831	6.61530D+01	1	7.58462D+01	17	8.74096D+01	19	8.86514D+01	11	8.18551D+01	13	8.54292D+01	25	9.89564D-01
831	6.61530D+01	1	7.58462D+01	17	8.74096D+01	19	8.86526D+01	21	8.99243D+01	24	1.24240D+02	25	9.89564D-01
831	6.61530D+01	1	2.2589D+02	17	8.74096D+01	19	8.86526D+01	21	8.99243D+01	24	1.24240D+02	25	9.89564D-01
831	6.61530D+01	1	3.3163D-06	1.05500D+00	0.0	0.0	0.0	1	2.99924D-06	25	1.22899D+00	25	1.00253D+00
831	6.61530D+01	1	5.33165D-06	1.05500D+00	0.0	0.0	0.0	2	3.71238D-07	25	1.22899D+00	25	1.00253D+00
831	6.61530D+01	1	8.7808D-07	1.05500D+00	0.0	0.0	0.0	1	1.07084D-06	25	1.16736D+00	25	9.52255D-01
831	6.61530D+01	1	4.46143D-06	1.05500D+00	0.0	0.0	0.0	2	2.54944D-07	25	1.16736D+00	25	9.52255D-01
831	6.61530D+01	1	4.46143D-06	1.05500D+00	0.0	0.0	0.0	11	8.4486D+01	13	8.54292D+01	25	9.52255D-01
831	6.61530D+01	1	6.45474D-07	1.05500D+00	0.0	0.0	0.0	21	8.99243D+01	24	1.24240D+02	25	9.52255D-01
831	6.61530D+01	1	1.7.58462D+01	17	8.74096D+01	19	8.86526D+01	21	8.99243D+01	24	1.24240D+02	25	9.52255D-01
831	6.61530D+01	1	1.7.58462D+01	17	8.74096D+01	19	8.86526D+01	21	8.99243D+01	24	1.24240D+02	25	9.52255D-01
832	6.6202D+01	1	2.25054D-06	1.05500D+00	0.0	0.0	0.0	1	2.75837D-06	25	1.16966D+00	25	9.63309D-01
832	6.6202D+01	1	2.25054D-06	1.05500D+00	0.0	0.0	0.0	2	2.37854D-07	25	1.16966D+00	25	9.63309D-01
832	6.6202D+01	1	4.84876D-07	1.05500D+00	0.0	0.0	0.0	11	8.44477D+01	13	8.54288D+01	25	9.63309D-01
832	6.6202D+01	1	7.58459D+01	17	8.74150D+01	19	8.86536D+01	21	8.99119D+01	24	1.23098D+02	25	9.63309D-01
832	6.6202D+01	1	7.58459D+01	17	8.74150D+01	19	8.86536D+01	21	8.99119D+01	24	1.23098D+02	25	9.63309D-01
833	6.62514D+01	1	3.27514D-06	1.05500D+00	0.0	0.0	0.0	1	2.95224D-06	25	1.17247D+00	25	9.75017D-01
833	6.62514D+01	1	3.27514D-06	1.05500D+00	0.0	0.0	0.0	2	2.95954D-07	25	1.17247D+00	25	9.75017D-01
833	6.62514D+01	1	6.58952D-07	1.05500D+00	0.0	0.0	0.0	11	8.4468D+01	13	8.54284D+01	25	9.75017D-01
833	6.62514D+01	1	1.7.58457D+01	17	8.74177D+01	19	8.86545D+01	21	8.99991D+01	24	1.21953D+02	25	9.75017D-01
833	6.62514D+01	1	1.7.58457D+01	17	8.74177D+01	19	8.86545D+01	21	8.99991D+01	24	1.21953D+02	25	9.75017D-01
834	6.6306D+01	1	4.25418D-06	1.05500D+00	0.0	0.0	0.0	1	3.20918D-06	25	1.17587D+00	25	9.87473D-01
834	6.6306D+01	1	4.25418D-06	1.05500D+00	0.0	0.0	0.0	2	3.35833D-07	25	1.17587D+00	25	9.87473D-01
834	6.6306D+01	1	7.41007D-07	1.05500D+00	0.0	0.0	0.0	11	8.4434D+01	13	8.54280D+01	25	9.87473D-01
834	6.6306D+01	1	7.58455D+01	17	8.74203D+01	19	8.86553D+01	21	8.9881D+01	24	1.20805D+02	25	9.87473D-01
834	6.6306D+01	1	7.58455D+01	17	8.74203D+01	19	8.86553D+01	21	8.9881D+01	24	1.20805D+02	25	9.87473D-01
835	6.63498D+01	1	4.62771D-06	1.05500D+00	0.0	0.0	0.0	1	3.41085D-06	25	1.17949D+00	25	1.00039D+00
835	6.63498D+01	1	4.62771D-06	1.05500D+00	0.0	0.0	0.0	2	3.66571D-07	25	1.17949D+00	25	1.00039D+00
835	6.63498D+01	1	8.26148D-07	1.05500D+00	0.0	0.0	0.0	11	8.4434D+01	13	8.54272D+01	25	9.87473D-01
835	6.63498D+01	1	3.74295D-06	1.05500D+00	0.0	0.0	0.0	1	9.33941D-07	25	1.12244D+00	25	9.51999D-01
835	6.63498D+01	1	3.74295D-06	1.05500D+00	0.0	0.0	0.0	2	2.14206D-07	25	1.12244D+00	25	9.51999D-01
835	6.63498D+01	1	5.21635D-07	1.05500D+00	0.0	0.0	0.0	11	8.4434D+01	13	8.54276D+01	25	9.51999D-01
835	6.63498D+01	1	7.58453D+01	17	8.74228D+01	19	8.86558D+01	21	8.98736D+01	24	1.19742D+02	25	9.51999D-01
835	6.63498D+01	1	7.58453D+01	17	8.74228D+01	19	8.86558D+01	21	8.98736D+01	24	1.19742D+02	25	9.51999D-01
835	6.63498D+01	1	1.16781D+02	17	8.74228D+01	19	8.86558D+01	21	8.98736D+01	24	1.19742D+02	25	9.51999D-01
836	6.63941D+01	1	2.22190D-06	1.05500D+00	0.0	0.0	0.0	1	3.11325D-06	25	1.12485D+00	25	9.63242D-01
836	6.63941D+01	1	2.22190D-06	1.05500D+00	0.0	0.0	0.0	2	2.54696D-07	25	1.12485D+00	25	9.63242D-01
836	6.63941D+01	1	5.25923D-07	1.05500D+00	0.0	0.0	0.0	11	8.4434D+01	13	8.54272D+01	25	9.63242D-01
836	6.63941D+01	1	7.59450D+01	17	8.74252D+01	19	8.86563D+01	21	8.98508D+01	24	1.18515D+02	25	9.63242D-01
836	6.63941D+01	1	7.59450D+01	17	8.74252D+01	19	8.86563D+01	21	8.98508D+01	24	1.18515D+02	25	9.63242D-01
836	6.63941D+01	1	15.8.63838D+01	17	8.74252D+01	19	8.86563D+01	21	8.98508D+01	24	1.18515D+02	25	9.63242D-01
836	6.63941D+01	1	15.8.63838D+01	17	8.74252D+01	19	8.86563D+01	21	8.98508D+01	24	1.18515D+02	25	9.63242D-01
837	6.64408D+01	1	3.20875D-06	1.05500D+00	0.0	0.0	0.0	1	3.27419D-06	25	1.12776D+00	25	9.75095D-01
837	6.64408D+01	1	3.20875D-06	1.05500D+00	0.0	0.0	0.0	2	2.99964D-07	25	1.12776D+00	25	9.75095D-01
837	6.64408D+01	1	6.51412D-07	1.05500D+00	0.0	0.0	0.0	11	8.44336D+01	13	8.54269D+01	25	9.75095D-01
837	6.64408D+01	1	7.58448D+01	17	8.74203D+01	19	8.86553D+01	21	8.99991D+01	24	1.21953D+02	25	9.75095D-01
837	6.64408D+01	1	7.58448D+01	17	8.74203D+01	19	8.86553D+01	21	8.99991D+01	24	1.21953D+02	25	9.75095D-01





	15	8	639550+01	17	8	745110+01	19	8	865100+01	21	8	969030+01	24	1	058270+02					
	25	1	029120+02																	
845	6	700150+01	1	2	130100-06	1	055000+00	0	0	0	0	0	0	0	0					
849	6	700150+01	1	2	130100-06	1	055000+00	0	0	0	0	0	0	0	0					
849	6	700150+01	1	5	928180-07	1	055000+00	0	0	0	0	0	0	0	0					
849	6	700150+01	1	7	584250+01	3	8	020290+01	5	8	184260+01	11	8	433520+01	13	8	542340+01	25	1	010160+00
849	6	700150+01	1	7	584250+01	3	8	020290+01	5	8	184260+01	11	8	433520+01	13	8	542340+01	25	1	010160+00
849	6	700150+01	1	15	8	639650+01	17	8	745300+01	19	8	865040+01	21	8	967480+01	24	1	048170+02		
850	6	704820+01	1	2	225570-06	1	055000+00	0	0	0	0	0	0	0	0					
850	6	704820+01	1	2	225570-06	1	055000+00	0	0	0	0	0	0	0	0					
850	6	704820+01	1	1	805500-07	1	055000+00	0	0	0	0	0	0	0	0					
850	6	704820+01	1	1	805500-07	1	055000+00	0	0	0	0	0	0	0	0					
850	6	704820+01	1	1	584230+01	3	8	020240+01	5	8	184200+01	11	8	434550+01	13	8	542320+01	25	1	009920+00
850	6	704820+01	1	15	8	639750+01	17	8	745480+01	19	8	864900+01	21	8	965910+01	24	1	038120+02		
851	6	709490+01	1	1	594210-06	1	055000+00	0	0	0	0	0	0	0	0					
851	6	709490+01	1	1	594210-06	1	055000+00	0	0	0	0	0	0	0	0					
851	6	709490+01	1	1	594210-06	1	055000+00	0	0	0	0	0	0	0	0					
851	6	709490+01	1	7	707320-08	1	055000+00	0	0	0	0	0	0	0	0					
851	6	709490+01	1	3	486750-06	1	055000+00	0	0	0	0	0	0	0	0					
851	6	709260+01	1	3	486750-06	1	055000+00	0	0	0	0	0	0	0	0					
851	6	709260+01	1	4	789820-07	1	055000+00	0	0	0	0	0	0	0	0					
851	6	709260+01	1	7	534210+01	3	8	020190+01	5	8	184140+01	11	8	433390+01	13	8	542300+01	25	9	605350-01
851	6	709260+01	1	15	8	639840+01	17	8	745650+01	19	8	864760+01	21	8	964400+01	24	1	028600+02		
852	6	713690+01	1	1	123210-06	1	055000+00	0	0	0	0	0	0	0	0					
852	6	713690+01	1	1	123210-06	1	055000+00	0	0	0	0	0	0	0	0					
852	6	713690+01	1	2	016460-07	1	055000+00	0	0	0	0	0	0	0	0					
852	6	71370+01	1	1	584230+01	3	8	020150+01	5	8	184090+01	11	8	433330+01	13	8	542280+01	25	9	598740-01
852	6	71370+01	1	15	8	639930+01	17	8	745820+01	19	8	864610+01	21	8	962880+01	24	1	019090+02		
853	6	718130+01	1	9	688050-07	1	055000+00	0	0	0	0	0	0	0	0					
853	6	718130+01	1	9	688050-07	1	055000+00	0	0	0	0	0	0	0	0					
853	6	718130+01	1	8	864740-08	1	055000+00	0	0	0	0	0	0	0	0					
853	6	718130+01	1	8	864740-08	1	055000+00	0	0	0	0	0	0	0	0					
853	6	718130+01	1	7	584180+01	3	8	020100+01	5	8	184040+01	11	8	433700+01	13	8	542260+01	25	9	591020-01
853	6	718130+01	1	15	8	640020+01	17	8	745980+01	19	8	864440+01	21	8	961340+01	24	1	009610+02		
854	6	722570+01	1	8	075670-07	1	055000+00	0	0	0	0	0	0	0	0					
854	6	722570+01	1	8	075670-07	1	055000+00	0	0	0	0	0	0	0	0					
854	6	722570+01	1	8	075670-07	1	055000+00	0	0	0	0	0	0	0	0					
854	6	722570+01	1	8	219170-08	1	055000+00	0	0	0	0	0	0	0	0					
854	6	722570+01	1	7	584160+01	3	8	020060+01	5	8	183990+01	11	8	433220+01	13	8	542240+01	25	9	588670-01
854	6	722570+01	1	15	8	640110+01	17	8	746140+01	19	8	864270+01	21	8	959790+01	24	1	000140+02		
855	6	727000+01	1	1	646250-05	1	055000+00	0	0	0	0	0	0	0	0					
855	6	727000+01	1	1	646250-05	1	055000+00	0	0	0	0	0	0	0	0					
855	6	727000+01	1	1	646250-05	1	055000+00	0	0	0	0	0	0	0	0					
855	6	727000+01	1	2	1436370-06	1	055000+00	0	0	0	0	0	0	0	0					
855	6	727000+01	1	6	872100-07	1	055000+00	0	0	0	0	0	0	0	0					
855	6	727000+01	1	7	584150+01	3	8	020020+01	5	8	183940+01	11	8	433160+01	13	8	542230+01	25	9	678040-01
855	6	727000+01	1	7	584150+01	3	8	020020+01	5	8	183940+01	11	8	433160+01	13	8	542230+01	25	9	678040-01
855	6	727000+01	1	15	8	640200+01	17	8	746300+01	19	8	864080+01	21	8	958230+01	24	9	905590+01		
856	6	731440+01	1	1	894690-05	1	055000+00	0	0	0	0	0	0	0	0					
856	6	731440+01	1	1	894690-05	1	055000+00	0	0	0	0	0	0	0	0					
856	6	731440+01	1	1	894690-05	1	055000+00	0	0	0	0	0	0	0	0					
856	6	731440+01	1	2	1740020-06	1	055000+00	0	0	0	0	0	0	0	0					
856	6	731440+01	1	8	628680-07	1	055000+00	0	0	0	0	0	0	0	0					
856	6	731440+01	1	4	021110-06	1	055000+00	0	0	0	0	0	0	0	0					
856	6	731140+01	1	4	021110-06	1	055000+00	0	0	0	0	0	0	0	0					
856	6	731140+01	1	5	418810-07	1	055000+00	0	0	0	0	0	0	0	0					
856	6	731140+01	1	5	418810-07	1	055000+00	0	0	0	0	0	0	0	0					
856	6	731140+01	1	7	584130+01	3	8	019980+01	5	8	183890+01	11	8	443110+01	13	8	542210+01	25	9	524300-01
856	6	731140+01	1	15	8	640290+01	17	8	746440+01	19	8	863890+01	21	8	956760+01	24	9	817920+01		
857	6	735280+01	1	8	011380-06	1	055000+00	0	0	0	0	0	0	0	0					
857	6	735280+01	1	8	011380-06	1	055000+00	0	0	0	0	0	0	0	0					
857	6	735280+01	1	8	011380-06	1	055000+00	0	0	0	0	0	0	0	0					
857	6	735280+01	1	1	369580-06	1	055000+00	0	0	0	0	0	0	0	0					
857	6	73530+01	1	7	584120+01	3	8	019940+01	5	8	183840+01	11	8	433060+01	13	8	542200+01	25	9	212760-01
857	6	73530+01	1	7	584120+01	3	8	019940+01	5	8	183840+01	11	8	433060+01	13	8	542200+01	25	9	212760-01
857	6	73530+01	1	15	8	640370+01	17	8	746570+01	19	8	863700+01	21	8	955270+01	24	9	728790+01		
858	6	739410+01	1	6	260320-06	1	055000+00	0	0	0	0	0	0	0	0					
858	6	739410+01	1	6	260320-06	1	055000+00	0	0	0	0	0	0	0	0					
858	6	739410+01	1	1	141410-06	1	055000+00	0	0	0	0	0	0	0	0					
858	6	739410+01	1	1	141410-06	1	055000+00	0	0	0	0	0	0	0	0					
858	6	739410+01	1	7	584100+01	3	8	019900+01	5	8	183800+01	11	8	443010+01	13	8	542180+01	25	9	829570-01
858	6	739410+01	1	7	584100+01	3	8	019900+01	5	8	183800+01	11	8	443010+01	13	8	542180+01	25	9	829570-01
858	6	739410+01	1	7	584100+01	3	8	019900+01	5	8	183800+01	11	8	443010+01	13	8	542180+01	25	9	829570-01

859	6.743550+01	15 8.640360+01	17 8.746710+01	19 8.863490+01	21 8.953780+01	24 9.639190+01	
		25 9.332310+01		0 0	0 0		
859	6.743550+01	1 5.605100-06	1.055000+00 0 0	0 0	0 0	1 4.577680-06	
		1 5.605100-06	1.055000+00 0 0	0 0	0 0	2 5.310650-07	25 9.312110-01
859	6.743550+01	1 1.046360-06	1.055000+00 0 0	0 0	0 0	11 8.442960+01	13 8.542170+01
		1 7.584090+01	3 8.019860+01	5 8.183750+01	21 8.952270+01	24 9.549120+01	
859	6.74350+01	15 8.640540+01	17 8.746830+01	19 8.863280+01			
		25 9.239190+01		0 0	0 0		
860	6.747690+01	1 1.009880-04	1.055000+00 0 0	0 0	0 0	1 2.860300-05	
		2 9.084440-06	1.055000+00 0 0	0 0	0 0	2 1.737830-06	24 8.969710-01
860	6.747690+01	1 3.861640-06	1.055000+00 0 0	0 0	0 0	11 8.442910+01	13 8.542160+01
		1 7.584070+01	3 8.019820+01	5 8.183710+01	21 8.953760+01	24 9.459420+01	
860	6.74770+01	15 8.640520+01	17 8.746980+01	19 8.863050+01			
		25 9.151750+01		0 0	0 0		
861	6.751840+01	1 2.248760-04	1.055000+00 0 0	0 0	0 0	1 7.367310-05	
		3 1.729540-06	1.055000+00 0 0	0 0	0 0	2 3.130250-06	24 8.736420-01
861	6.751840+01	2 9.454320-07	1.055000+00 0 0	0 0	0 0	11 8.442850+01	13 8.542150+01
		1 7.584060+01	3 8.019780+01	5 8.183670+01	21 8.943220+01	24 9.372060+01	
861	6.75180+01	15 8.640710+01	17 8.747080+01	19 8.862810+01			
		25 9.077170+01		0 0	0 0		
862	6.756110+01	1 1.394110-04	1.055000+00 0 0	0 0	0 0	1 6.730330-05	
		3 1.098270-06	1.055000+00 0 0	0 0	0 0	2 2.072510-06	24 8.472410-01
862	6.756110+01	1 7.551210-06	1.055000+00 0 0	0 0	0 0	11 8.442810+01	12 8.542130+01
		1 7.584050+01	3 8.019740+01	5 8.183620+01	21 8.947630+01	24 9.287330+01	
862	6.75610+01	15 8.640790+01	17 8.747200+01	19 8.862550+01			
		25 9.009550+01		0 0	0 0		
863	6.760600+01	1 1.049540-04	1.055000+00 0 0	0 0	0 0	1 6.708830-05	
		3 8.644020-07	1.055000+00 0 0	0 0	0 0	2 1.736270-06	24 8.277730-01
863	6.760600+01	1 6.682100-06	1.055000+00 0 0	0 0	0 0	11 8.442760+01	13 8.542120+01
		1 7.584030+01	3 8.019700+01	5 8.183580+01	21 8.945950+01	24 9.204560+01	
863	6.76060+01	15 8.640880+01	17 8.747330+01	19 8.862280+01			
		25 8.945750+01		0 0	0 0		
864	6.765380+01	1 9.191070-05	1.055000+00 0 0	0 0	0 0	1 7.085420-05	
		3 7.995330-07	1.055000+00 0 0	0 0	0 0	2 1.619960-06	24 8.118050-01
864	6.765380+01	1 6.666850-06	1.055000+00 0 0	0 0	0 0	11 8.442710+01	13 8.542110+01
		1 7.584020+01	3 8.019660+01	5 8.183530+01	21 8.943140+01	24 9.123380+01	
864	6.76530+01	15 8.640980+01	17 8.747450+01	19 8.861970+01			
		25 8.884190+01		0 0	0 0		
865	6.770540+01	1 9.221900-05	1.055000+00 0 0	0 0	0 0	1 7.718250-05	
		3 8.477920-07	1.055000+00 0 0	0 0	0 0	2 1.639430-06	24 7.979420-01
865	6.770540+01	1 7.277200-06	1.055000+00 0 0	0 0	0 0	11 8.442660+01	13 8.542100+01
		1 7.584000+01	3 8.019620+01	5 8.183480+01	21 8.942180+01	24 9.043580+01	
865	6.77050+01	15 8.641080+01	17 8.747580+01	19 8.861630+01			
		25 8.824030+01		0 0	0 0		
866	6.776130+01	1 1.015900-04	1.055000+00 0 0	0 0	0 0	1 8.553780-05	
		3 9.816230-07	1.055000+00 0 0	0 0	0 0	2 1.766860-06	24 7.849820-01
866	6.776130+01	1 8.521460-06	1.055000+00 0 0	0 0	0 0	11 8.442600+01	13 8.542090+01
		1 7.583980+01	3 8.019570+01	5 8.183420+01	21 8.940040+01	24 8.965080+01	
866	6.77610+01	15 8.641190+01	17 8.747720+01	19 8.861230+01			
		25 8.764860+01		0 0	0 0		
867	6.782260+01	1 1.181860-04	1.055000+00 0 0	0 0	0 0	1 9.567620-05	
		3 1.191640-06	1.055000+00 0 0	0 0	0 0	2 2.225440-06	24 7.731350-01
867	6.782260+01	2 7.762560-07	1.055000+00 0 0	0 0	0 0	11 8.442540+01	13 8.542080+01
		1 7.583960+01	3 8.019520+01	5 8.183360+01	21 8.937680+01	24 8.887770+01	
867	6.78230+01	15 8.641300+01	17 8.747850+01	19 8.860780+01			
		25 8.706430+01		0 0	0 0		
868	6.789000+01	1 1.386390-04	1.055000+00 0 0	0 0	0 0	1 1.074760-04	
		3 1.448210-06	1.055000+00 0 0	0 0	0 0	2 2.528600-06	24 7.585940-01
868	6.789000+01	2 9.867230-07	1.055000+00 0 0	0 0	0 0	11 8.442470+01	13 8.542070+01
		1 7.583940+01	3 8.019470+01	5 8.183300+01	21 8.935070+01	24 8.811910+01	
868	6.78900+01	15 8.641430+01	17 8.748000+01	19 8.860260+01			
		25 8.648710+01		0 0	0 0		
869	6.794500+01	1 5.550230-05	1.055000+00 0 0	0 0	0 0	1 7.379410-05	
		2 6.791810-06	1.055000+00 0 0	0 0	0 0	2 1.401960-06	23 5.707590-01
869	6.794500+01	1 4.857030-06	1.055000+00 0 0	0 0	0 0	11 8.442420+01	13 8.542060+01
		1 7.583930+01	3 8.019420+01	5 8.183250+01	21 8.935070+01	24 6.322610-01	
869	6.79450+01	15 8.641430+01	17 8.748000+01	19 8.860260+01			
		25 8.648710+01		0 0	0 0		

870	6	800000+01	15	8	641530+01	17	8	748100+01	19	8	859820+01	21	8	932940+01	24	8	756200+01
870	6	800000+01	25	8	605470+01												
870	6	800000+01	1	6	116050-05	1	055000+00	0	0	0	0	0	0	0	0	0	0
870	6	800000+01	2	6	668900-06	1	055000+00	0	0	0	0	0	0	0	0	0	0
870	6	800000+01	1	4	604290-06	1	055000+00	0	0	0	0	0	0	0	0	0	0
870	6	800000+01	1	7	583910+01	3	8	019380+01	5	8	183200+01	11	8	42360+01	13	8	542050+01
870	6	800000+01	15	8	641630+01	17	8	748200+01	19	8	859360+01	21	8	930800+01	24	8	705240+01
			25	8	165880+01												

HEATING6 02/12/83  
 W9XNF110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
 TRANSIENT TEMPERATURE DISTRIBUTION AFTER 870 TIME STEPS, TIME = 6.80000E+01

18M3033/ 0  
 20 58 23 11-16-89

NODES GRID	FINE GRID	DISTANCE	TEMPERATURE
1	1	0.0	91.360000
2	2	0.03	0.0
3	3	0.06	73.400000
4	4	0.08	
5	5	0.10	
6	6	0.57	
7	7	1.04	
8	8	1.51	
9	9	1.98	
10	10	2.45	
11	11	2.92	
12	12	3.14	
13	13	3.35	
14	14	3.57	
15	15	3.79	
16	16	4.01	
17	17	4.23	
18	18	4.45	
19	19	4.67	
20	20	4.89	
21	21	5.10	
22	22	5.18	
23	23	5.25	
24	24	5.32	
25	25	5.35	

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	91.360000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 5.50014486E-02

ELAPSED CPU TIME IS 10.47 SECONDS

THE MAXIMUM TEMPERATURE IS - 9.10089D+01 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 22

THE MINIMUM TEMPERATURE IS - 7.58391D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	1.1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	1.1 NORM OF TEMP DIFF	MAX TEMP CHANGE	NODE M/A PERCENT TEMP CHANGE
871	6.80605D+01	1	1.758389D+01	3.801933D+01	5.818315D+01	11.844231D+01	13.854205D+01	1	1.84231D+01	23.616994D+01	23.603298D+01
871	6.80605D+01	2	15.864174D+01	17.874831D+01	19.885884D+01	21.892845D+01	24.865408D+01	2	2.163737D+06	23.555F38D+01	23.616441D+01
871	6.80605D+01	1	25.852580D+01		0.0	0.0		1	1.742920D+05		
872	6.81271D+01	1	1.785356D+05	1.05500D+00	0.0	0.0		1	2.163737D+06		
872	6.81271D+01	2	1.752358D+05	1.05500D+00	0.0	0.0		2	2.163737D+06		
872	6.81271D+01	1	1.680960D+06	1.05500D+00	0.0	0.0		1	11.844225D+01	13.854204D+01	
872	6.8127D+01	1	1.758388D+01	3.801928D+01	5.818310D+01	11.844225D+01	13.854204D+01	1	21.892589D+01	24.860301D+01	
872	6.8127D+01	1	15.864186D+01	17.874841D+01	19.885824D+01	21.892589D+01	24.860301D+01	1	1.812599D+05		
872	6.8127D+01	1	25.848539D+01		0.0	0.0		1	2.184807D+06	23.559250D+01	23.624409D+01
873	6.82003D+01	1	1.934624D+05	1.05500D+00	0.0	0.0		1	1.878867D+05		
873	6.82003D+01	2	1.814345D+06	1.05500D+00	0.0	0.0		2	2.238719D+06	23.557988D+01	23.626914D+01
873	6.82003D+01	1	1.844927D+06	1.05500D+00	0.0	0.0		1	11.844219D+01	13.854204D+01	
873	6.8200D+01	1	1.758388D+01	3.801923D+01	5.818304D+01	11.844219D+01	13.854204D+01	1	21.892004D+01	24.850200D+01	
873	6.8200D+01	1	15.864193D+01	17.874851D+01	19.885756D+01	21.892004D+01	24.850200D+01	1	1.937438D+05		
873	6.8200D+01	1	25.840403D+01		0.0	0.0		1	2.203692D+06	23.551693D+01	23.623752D+01
874	6.82808D+01	1	1.10815D+04	1.05500D+00	0.0	0.0		1	1.878867D+05		
874	6.82808D+01	2	1.862616D+06	1.05500D+00	0.0	0.0		2	2.238719D+06	23.557988D+01	23.626914D+01
874	6.82808D+01	2	1.867276D+07	1.05500D+00	0.0	0.0		2	2.238719D+06	23.557988D+01	23.626914D+01
874	6.8281D+01	1	1.758388D+01	3.801918D+01	5.818297D+01	11.844212D+01	13.854204D+01	1	21.892004D+01	24.850200D+01	
874	6.8281D+01	1	15.864213D+01	17.874860D+01	19.885677D+01	21.892004D+01	24.850200D+01	1	1.985006D+05		
874	6.8281D+01	1	25.840403D+01		0.0	0.0		1	2.25244D+06	23.540693D+01	23.615152D+01
875	6.83694D+01	1	1.24423D+04	1.05500D+00	0.0	0.0		1	1.878867D+05		
875	6.83694D+01	3	1.37040D+06	1.05500D+00	0.0	0.0		2	2.25244D+06	23.540693D+01	23.615152D+01
875	6.83694D+01	2	1.20563D+06	1.05500D+00	0.0	0.0		2	2.25244D+06	23.540693D+01	23.615152D+01
875	6.8369D+01	1	1.758388D+01	3.801912D+01	5.818290D+01	11.844205D+01	13.854204D+01	1	21.891672D+01	24.845243D+01	
875	6.8369D+01	1	15.864228D+01	17.874868D+01	19.885588D+01	21.891672D+01	24.845243D+01	1	1.985006D+05		
875	6.8369D+01	1	25.836318D+01		0.0	0.0		1	2.25244D+06	23.540693D+01	23.615152D+01
876	6.84668D+01	1	1.43573D+04	1.05500D+00	0.0	0.0		1	1.878867D+05		
876	6.84668D+01	3	1.55253D+06	1.05500D+00	0.0	0.0		2	2.25244D+06	23.540693D+01	23.615152D+01
876	6.84668D+01	2	1.53190D+06	1.05500D+00	0.0	0.0		2	2.25244D+06	23.540693D+01	23.615152D+01
876	6.8467D+01	1	1.758379D+01	3.801905D+01	5.818283D+01	11.844197D+01	13.854204D+01	1	21.891314D+01	24.840363D+01	
876	6.8467D+01	1	15.864244D+01	17.874875D+01	19.885485D+01	21.891314D+01	24.840363D+01	1	1.985006D+05		
876	6.8467D+01	1	25.832225D+01		0.0	0.0		1	1.013100D+04		
877	6.85740D+01	1	1.58070D+04	1.05500D+00	0.0	0.0		1	2.24268D+06	23.52512D+01	23.601811D+01
877	6.85740D+01	3	1.80925D+06	1.05500D+00	0.0	0.0		2	2.24268D+06	23.52512D+01	23.601811D+01
877	6.85740D+01	2	1.89387D+06	1.05500D+00	0.0	0.0		2	2.24268D+06	23.52512D+01	23.601811D+01
877	6.8574D+01	1	1.758377D+01	3.801899D+01	5.818276D+01	11.844190D+01	13.854204D+01	1	21.890928D+01	24.835557D+01	
877	6.8574D+01	1	15.864261D+01	17.874880D+01	19.885367D+01	21.890928D+01	24.835557D+01	1	1.02265D+04		
877	6.8574D+01	1	25.828114D+01		0.0	0.0		1	2.56026D+06	23.507826D+01	23.584855D+01
878	6.86919D+01	1	1.71662D+04	1.05500D+00	0.0	0.0		1	1.02265D+04		
878	6.86919D+01	3	2.27399D+06	1.05500D+00	0.0	0.0		2	2.56026D+06	23.507826D+01	23.584855D+01
878	6.86919D+01	2	2.28649D+06	1.05500D+00	0.0	0.0		2	2.56026D+06	23.507826D+01	23.584855D+01
878	6.8692D+01	1	1.758374D+01	3.801892D+01	5.818268D+01	11.844182D+01	13.854205D+01	1	21.890514D+01	24.830812D+01	
878	6.8692D+01	1	15.864279D+01	17.874882D+01	19.885233D+01	21.890514D+01	24.830812D+01	1	1.00779D+04		
878	6.8692D+01	1	25.823970D+01		0.0	0.0		1	2.6224D+06	23.488453D+01	24.566711D+01
879	6.88216D+01	1	1.79855D+04	1.05500D+00	0.0	0.0		1	1.00779D+04		
879	6.88216D+01	3	2.7355D+06	1.05500D+00	0.0	0.0		2	2.6224D+06	23.488453D+01	24.566711D+01
879	6.88216D+01	2	2.67565D+06	1.05500D+00	0.0	0.0		2	2.6224D+06	23.488453D+01	24.566711D+01
879	6.8822D+01	1	1.758371D+01	3.801884D+01	5.818260D+01	11.844174D+01	13.854206D+01	1	21.890073D+01	24.826103D+01	
879	6.8822D+01	1	15.864297D+01	17.874880D+01	19.885079D+01	21.890073D+01	24.826103D+01	1	1.969079D+05		
879	6.8822D+01	1	25.819764D+01		0.0	0.0		1	2.6224D+06	23.488453D+01	24.566711D+01
880	6.89642D+01	1	1.83615D+04	1.05500D+00	0.0	0.0		1	1.969079D+05		
880	6.89642D+01	3	3.19496D+06	1.05500D+00	0.0	0.0		2	2.6224D+06	23.488453D+01	24.566711D+01
880	6.89642D+01	2	3.05315D+06	1.05500D+00	0.0	0.0		2	2.6224D+06	23.488453D+01	24.566711D+01
880	6.8964D+01	1	1.758369D+01	3.801877D+01	5.818254D+01	11.844165D+01	13.854207D+01	1	1.969079D+05		
880	6.8964D+01	1	15.864297D+01	17.874880D+01	19.885079D+01	21.890073D+01	24.826103D+01	1	2.6224D+06	23.488453D+01	24.566711D+01
880	6.8964D+01	1	25.819764D+01		0.0	0.0		1	2.6224D+06	23.488453D+01	24.566711D+01

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
 \*\*\*\*\* NODE NUMBERS AND TEMPERATURES \*\*\*\*\*

881	6.91212D+01	1	1	276520-04	1.055000+00	0.0	0.0	19.8.849030+01	21.8.896030+01	24.8.213940+01	
		2	2	372180-06	1.055000+00	0.0	0.0				
		3	2	496280-06	1.055000+00	0.0	0.0				
881	6.91212D+01	2	2	496280-06	1.055000+00	0.0	0.0				
		1	7	583660+01	3.8.018690+01	5.8.182430+01	11.8.441570+01	21.8.891050+01	24.8.166070+01		
881	6.91212D+01	1	7	583660+01	3.8.018690+01	5.8.182430+01	11.8.441570+01	21.8.891050+01	24.8.166070+01		
		15	8	643360+01	17.8.748590+01	19.8.847040+01					
		25	8	109380+01							
882	6.929380+01	1	1	252390-04	1.055000+00	0.0	0.0				
		2	2	793110-06	1.055000+00	0.0	0.0				
882	6.929380+01	3	2	616150-06	1.055000+00	0.0	0.0				
		1	7	583630+01	3.8.018610+01	5.8.182340+01	11.8.441430+01	21.8.885790+01	24.8.116430+01		
882	6.92940+01	1	7	583630+01	3.8.018610+01	5.8.182340+01	11.8.441430+01	21.8.885790+01	24.8.116430+01		
		15	8	643550+01	17.8.748370+01	19.8.844780+01					
		25	8	061460+01							
883	6.948370+01	1	1	260550-04	1.055000+00	0.0	0.0				
		3	3	248110-06	1.055000+00	0.0	0.0				
883	6.948370+01	3	3	248110-06	1.055000+00	0.0	0.0				
		2	2	875470-06	1.055000+00	0.0	0.0				
883	6.94840+01	1	7	583600+01	3.8.018540+01	5.8.182260+01	11.8.441410+01	21.8.880230+01	24.8.064250+01		
		15	8	643730+01	17.8.748050+01	19.8.842230+01					
		25	8	010350+01							
884	6.969250+01	1	1	016920-04	1.055000+00	0.0	0.0				
		3	2	757300-06	1.055000+00	0.0	0.0				
884	6.969250+01	3	2	757300-06	1.055000+00	0.0	0.0				
		2	2	476970-06	1.055000+00	0.0	0.0				
884	6.96930+01	1	7	583570+01	3.8.018460+01	5.8.182180+01	11.8.441340+01	21.8.874380+01	24.8.008750+01		
		15	8	643900+01	17.8.747600+01	19.8.839380+01					
		25	7	955280+01							
885	6.984630+01	1	3	362920-05	1.055000+00	0.0	0.0				
		2	5	598430-07	1.055000+00	0.0	0.0				
885	6.984630+01	2	5	598430-07	1.055000+00	0.0	0.0				
		1	1	374960-06	1.055000+00	0.0	0.0				
885	6.98460+01	1	7	583550+01	3.8.018410+01	5.8.182120+01	11.8.441290+01	21.8.870220+01	24.7.968610+01		
		15	8	644000+01	17.8.747200+01	19.8.837440+01					
		25	7	914920+01							
886	7.000000+01	1	2	573780-05	1.055000+00	0.0	0.0				
		2	3	626170-06	1.055000+00	0.0	0.0				
886	7.000000+01	2	3	626170-06	1.055000+00	0.0	0.0				
		1	2	943100-06	1.055000+00	0.0	0.0				
886	7.000000+01	1	7	583530+01	3.8.018360+01	5.8.182070+01	11.8.441250+01	21.8.866180+01	24.7.928810+01		
		15	8	644080+01	17.8.746760+01	19.8.835090+01					
		25	7	674930+01							

HEATING6 02/12/83  
W9XWP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

18M0033/ 0  
20.58.23 11-16-89

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 886 TIME STEPS, TIME = 7.000000+01

GROSS GRID 1

FINE GRID 1

	DISTANCE	
1	0.0	75184
2	0.03	78174
3	0.06	80118
4	0.08	81100
5	0.10	81182
6	0.57	82126
7	1.04	82169
8	1.51	83112
9	1.98	83156
10	2.45	83193
11	2.92	84141
12	3.14	84192
13	3.35	85142
14	3.57	85193
15	3.79	86144
16	4.01	86196
17	4.23	87147
18	4.45	87195
19	4.67	88135
20	4.89	88161
21	5.10	88166
22	5.18	86102
23	5.25	82199
10	5.32	79129
11	5.35	78175

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	87.300000
2	0.0
3	72.400000

THE CURRENT TIME STEP (DELTA) = 1.53734465D-01

ELAPSED CPU TIME IS 10.66 SECONDS

THE MAXIMUM TEMPERATURE IS 8.86618D+01 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES 20 21

THE MINIMUM TEMPERATURE IS 7.58353D+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES 1

NO	TIME	MD	MAX HEAT	BETA	L1 NORM OF	RHD	RHD	MD	L1 NORM OF	MAX TEMP	MAX PERCENT
TIME	ITER	ITER	RESIDUAL		TEMP DIFF	(ITERATION)	(JACOBI)	ITER	TEMP DIFF	CHANGE	TEMP CHANGE
887	7 01691D+01	1	3 22437D-05	1 05500D+00	0 0	0 0	0 0	1 1	19580D-05	25 4 43509D-01	25 5 63191D-01
887	7 01691D+01	2	4 94810D-06	1 05500D+00	0 0	0 0	0 0	2 4	47956D-07		
887	7 01691D+01	1	3 74622D-06	1 05500D+00	0 0	0 0	0 0				

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NUMBER OF	TIME	MD	MAX HEAT	BETA	L1 NORM OF	RHD	RHD	MD	L1 NORM OF	MAX TEMP	MAX PERCENT
TIME STEPS		ITER	RESIDUAL		TEMP DIFF	(ITERATION)	(JACOBI)	ITER	TEMP DIFF	CHANGE	TEMP CHANGE
887	7 01690+01	1	7 58351D+01	3 8 01822D+01	3 8 01822D+01	5 8 18203D+01	11 8 44121D+01	13 8 54229D+01			
		15	8 64414D+01	17 8 74622D+01	19 8 83271D+01	21 8 86185D+01	24 8 88513D+01				
		25	7 83058D+01								
888	7 03551D+01	1	42380D-05	1 05500D+00	0 0	0 0	0 0	1 9	26350D-06		
888	7 03551D+01	2	1 84959D-06	1 05500D+00	0 0	0 0	0 0	2 2	58633D-07	25 4 89353D-01	25 5 24926D-01
888	7 03551D+01	1	1 84180D-06	1 05500D+00	0 0	0 0	0 0				
888	7 03550+01	1	7 58350D+01	3 8 01828D+01	3 8 01828D+01	5 8 18198D+01	11 8 44117D+01	13 8 54233D+01			
		15	8 64417D+01	17 8 74556D+01	19 8 83080D+01	21 8 85722D+01	24 7 83697D+01				
		25	7 78164D+01								
889	7 05597D+01	1	74980D-05	1 05500D+00	0 0	0 0	0 0	1 8	42015D-06		
889	7 05597D+01	2	2 52291D-06	1 05500D+00	0 0	0 0	0 0	2 3	03609D-07	25 5 40067D-01	25 6 94027D-01
889	7 05597D+01	1	2 34034D-06	1 05500D+00	0 0	0 0	0 0				
889	7 05600+01	1	7 58348D+01	3 8 01824D+01	3 8 01824D+01	5 8 18194D+01	11 8 44114D+01	13 8 54237D+01			
		15	8 64418D+01	17 8 74476D+01	19 8 82718D+01	21 8 85225D+01	24 7 78386D+01				
		25	7 72763D+01								
890	7 07848D+01	1	1 94618D-05	1 05500D+00	0 0	0 0	0 0	1 7	52057D-06		
890	7 07848D+01	2	3 13789D-06	1 05500D+00	0 0	0 0	0 0	2 3	60315D-07	25 5 95930D-01	25 7 71167D-01
890	7 07848D+01	1	3 20073D-06	1 05500D+00	0 0	0 0	0 0				
890	7 07850+01	1	7 58347D+01	3 8 01820D+01	3 8 01820D+01	5 8 18190D+01	11 8 44112D+01	13 8 54240D+01			
		15	8 64414D+01	17 8 74380D+01	19 8 82399D+01	21 8 84632D+01	24 7 72525D+01				
		25	7 65804D+01								
891	7 10324D+01	1	2 09799D-05	1 05500D+00	0 0	0 0	0 0	1 6	78469D-06		
891	7 10324D+01	2	3 58008D-06	1 05500D+00	0 0	0 0	0 0	2 3	59485D-07	25 6 57397D-01	25 8 57321D-01
891	7 10324D+01	1	3 01511D-06	1 05500D+00	0 0	0 0	0 0				
891	7 10320+01	1	7 58345D+01	3 8 01816D+01	3 8 01816D+01	5 8 18187D+01	11 8 44110D+01	13 8 54243D+01			
		15	8 64404D+01	17 8 74266D+01	19 8 82048D+01	21 8 84121D+01	24 7 66059D+01				
		25	7 60230D+01								
892	7 13048D+01	1	5 44043D-06	1 05500D+00	0 0	0 0	0 0	1 4	82107D-06		
892	7 13048D+01	1	5 44043D-06	1 05500D+00	0 0	0 0	0 0	2 6	37437D-07	25 7 23493D-01	25 9 51676D-01
892	7 13048D+01	1	1 20156D-06	1 05500D+00	0 0	0 0	0 0				
892	7 13050+01	1	7 58344D+01	3 8 01813D+01	3 8 01813D+01	5 8 18184D+01	11 8 44109D+01	13 8 54246D+01			
		15	8 64387D+01	17 8 74130D+01	19 8 81662D+01	21 8 83508D+01	24 7 58936D+01				
		25	7 52995D+01								
893	7 15771D+01	1	9 63222D-06	1 05500D+00	0 0	0 0	0 0	1 4	14621D-06		
893	7 15771D+01	1	9 63222D-06	1 05500D+00	0 0	0 0	0 0	2 6	49413D-07	25 7 24229D-01	25 9 61797D-01
893	7 15771D+01	1	1 73975D-06	1 05500D+00	0 0	0 0	0 0				
893	7 15770+01	1	7 58343D+01	3 8 01811D+01	3 8 01811D+01	5 8 18182D+01	11 8 44108D+01	13 8 54247D+01			
		15	8 64363D+01	17 8 73985D+01	19 8 81278D+01	21 8 82908D+01	24 7 51807D+01				
		25	7 45753D+01								
894	7 17886D+01	1	7 97982D-06	1 05500D+00	0 0	0 0	0 0	1 2	80370D-06		
894	7 17886D+01	1	7 97982D-06	1 05500D+00	0 0	0 0	0 0	2 4	44176D-07	25 5 63093D-01	25 7 55066D-01
894	7 17886D+01	1	1 27450D-06	1 05500D+00	0 0	0 0	0 0				
894	7 17890+01	1	7 58342D+01	3 8 01810D+01	3 8 01810D+01	5 8 18181D+01	11 8 44107D+01	13 8 54246D+01			
		15	8 64340D+01	17 8 73867D+01	19 8 80981D+01	21 8 82450D+01	24 7 46266D+01				
		25	7 40122D+01								
895	7 20000D+01	1	3 20057D-05	1 05500D+00	0 0	0 0	0 0	1 4	79831D-06		
895	7 20000D+01	2	6 55577D-06	1 05500D+00	0 0	0 0	0 0	2 5	17778D-07	25 5 59438D-01	25 7 55873D-01
895	7 20000D+01	1	5 12345D-06	1 05500D+00	0 0	0 0	0 0				
895	7 20000+01	1	7 58342D+01	3 8 01803D+01	3 8 01803D+01	5 8 18180D+01	11 8 44107D+01	13 8 54244D+01			
		15	8 64313D+01	17 8 73744D+01	19 8 80685D+01	21 8 81998D+01	24 7 40739D+01				
		25	7 34528D+01								



HEATING6 02/12/83  
W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

18W3033/ 0  
20.58.24 11-16-89

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 895 TIME STEPS, TIME = 7.200000+01

GROSS GRID: 1

FINE GRID: 1

	DISTANCE	0.0
1	0.0	75183
2	0.03	78101
3	0.06	80118
4	0.08	81100
5	0.10	81182
6	0.57	82125
7	1.04	82168
8	1.51	83112
9	1.98	83155
10	2.45	83198
11	2.92	84141
12	3.14	84192
13	3.35	85142
14	3.57	85193
15	3.79	86143
16	4.01	86192
17	4.23	87137
18	4.45	87177
19	4.67	88107
20	4.89	88123
21	5.10	88120
22	5.18	83194
23	5.25	79132
24	5.32	74107
25	5.35	73145

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	82.670000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 2.11439664D-01

ELAPSED CPU TIME IS 10.76 SECONDS

THE MAXIMUM TEMPERATURE IS - 8.82254D+01 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 20 21

THE MINIMUM TEMPERATURE IS - 7.34528D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 25

NO	TIME	NO	MAX HEAT	BETA	L1 NORM OF	RHD	RHD	NO	L1 NORM OF	MAX TEMP	NO	MAX PERCENT	
TIME	RESIDUAL	ITER			TEMP DIFF	(ITERATION)	(JACOBI)	ITER	TEMP DIFF	CHANGE	NODE	TEMP CHANGE	
896	7.22260+01	1	1.60290-04	1.05500+00	0.0	0.0	0.0	1	1.67054D-05		25	6.01552D-01	
896	7.22260+01	3	5.45734D-06	1.05500+00	0.0	0.0	0.0	2	1.80210D-06		25	6.01552D-01	
896	7.22260+01	2	3.69810D-06	1.05500+00	0.0	0.0	0.0					25	6.01552D-01

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
 NODE NUMBERS AND TEMPERATURES

NUMBER OF	TIME	RHD	RHD	NO	L1 NORM OF	MAX TEMP	NO	MAX PERCENT				
TIME STEPS		(ITERATION)	(JACOBI)	ITER	TEMP DIFF	CHANGE	NODE	TEMP CHANGE				
896	7.22320+01	5	8.18179D+01	11	8.44106D+01	25	6.54241D+01	13	8.54241D+01			
		19	8.80360D+01	21	8.81507D+01	24	7.34736D+01					
897	7.24884D+01	1	1.12764D-04	1.05500+00	0.0	0.0	1	1.87166D-05				
897	7.24884D+01	3	3.87569D-06	1.05500+00	0.0	0.0	2	1.31360D-06	25	6.52481D-01		
897	7.24884D+01	2	3.03201D-06	1.05500+00	0.0	0.0			13	8.54236D+01		
897	7.24884D+01	1	1.758341D+01	3	8.01808D+01	5	8.18179D+01	11	8.44106D+01	13	8.54236D+01	
		15	8.64236D+01	17	8.73444D+01	19	8.80004D+01	21	8.80974D+01	24	7.28256D+01	
898	7.27590+01	1	1.45916D-04	1.05500+00	0.0	0.0	0.0	0.0	1	2.12539D-05		
898	7.27590+01	3	5.58461D-06	1.05500+00	0.0	0.0	0.0	0.0	2	1.70331D-06	25	6.80953D-01
898	7.27590+01	2	4.16861D-06	1.05500+00	0.0	0.0	0.0	0.0	11	8.18178D+01	25	6.80953D-01
898	7.27600+01	1	1.758341D+01	3	8.01807D+01	5	8.18178D+01	11	8.44103D+01	13	8.54228D+01	
		15	8.64186D+01	17	8.73268D+01	19	8.79627D+01	21	8.80416D+01	24	7.21490D+01	
899	7.30330+01	1	1.91230D-04	1.05500+00	0.0	0.0	0.0	0.0	1	2.49998D-05		
899	7.30330+01	3	7.41846D-06	1.05500+00	0.0	0.0	0.0	0.0	2	2.19766D-06	25	6.71645D-01
899	7.30330+01	2	5.38307D-06	1.05500+00	0.0	0.0	0.0	0.0	11	8.44103D+01	13	8.54218D+01
899	7.30330+01	1	1.758341D+01	3	8.01807D+01	5	8.18177D+01	11	8.44103D+01	13	8.54218D+01	
		15	8.64129D+01	17	8.73086D+01	19	8.79250D+01	21	8.79854D+01	24	7.14802D+01	
900	7.33100D+01	1	4.81604D-04	1.05500+00	0.0	0.0	0.0	0.0	1	4.86718D-05		
900	7.33100D+01	4	9.84848D-07	1.05500+00	0.0	0.0	0.0	0.0	2	5.39523D-06	24	6.52532D-01
900	7.33100D+01	3	2.92141D-05	1.05500+00	0.0	0.0	0.0	0.0	11	8.44099D+01	13	8.54205D+01
900	7.33100+01	1	1.758341D+01	3	8.01806D+01	5	8.18175D+01	11	8.44099D+01	13	8.54205D+01	
		15	8.64066D+01	17	8.72897D+01	19	8.78869D+01	21	8.79307D+01	24	7.0E277D+01	
901	7.35970+01	1	3.13802D-04	1.05500+00	0.0	0.0	0.0	0.0	1	4.72373D-05		
901	7.35970+01	4	7.57015D-07	1.05500+00	0.0	0.0	0.0	0.0	2	3.30467D-06	24	6.49872D-01
901	7.35970+01	2	9.54840D-06	1.05500+00	0.0	0.0	0.0	0.0	11	8.44095D+01	13	8.54189D+01
901	7.35980+01	1	1.758340D+01	3	8.01804D+01	5	8.18173D+01	11	8.44095D+01	13	8.54189D+01	
		15	8.63995D+01	17	8.72695D+01	19	8.78474D+01	21	8.78737D+01	24	7.01778D+01	
902	7.37980+01	1	1.16112D-04	1.05500+00	0.0	0.0	0.0	0.0	1	2.37149D-05		
902	7.37980+01	3	2.96607D-06	1.05500+00	0.0	0.0	0.0	0.0	2	1.37534D-06	24	4.41591D-01
902	7.37980+01	2	2.35887D-06	1.05500+00	0.0	0.0	0.0	0.0	11	8.44091D+01	13	8.54175D+01
902	7.37990+01	1	1.758340D+01	3	8.01803D+01	5	8.18171D+01	11	8.44091D+01	13	8.54175D+01	
		15	8.63942D+01	17	8.72552D+01	19	8.78199D+01	21	8.78343D+01	24	6.97362D+01	
903	7.40000D+01	1	1.31417D-04	1.05500+00	0.0	0.0	0.0	0.0	1	2.19186D-05		
903	7.40000D+01	3	3.46067D-06	1.05500+00	0.0	0.0	0.0	0.0	2	1.50657D-06	24	4.30781D-01
903	7.40000D+01	2	2.56895D-06	1.05500+00	0.0	0.0	0.0	0.0	11	8.44086D+01	13	8.54161D+01
903	7.40000+01	1	1.758339D+01	3	8.01801D+01	5	8.18168D+01	11	8.44086D+01	13	8.54161D+01	
		15	8.63886D+01	17	8.72406D+01	19	8.77924D+01	21	8.77953D+01	24	6.93055D+01	

HEATING6 02/12/83  
W9XNF110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 903 TIME STEPS. TIME = 7.400000+01

GROSS GRID	1
FINE GRID	1
DISTANCE	0.0
1	75183
2	78101
3	80118
4	81100
5	81182
6	82125
7	82168
8	83112
9	83155
10	83198
11	84141
12	84191
13	85142
14	85191
15	86139
16	86184
17	87124
18	87157
19	87179
20	87188
21	87180
22	82101
23	75193
24	69131
25	68168

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	78.640000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 2.01051776D-01

ELAPSED CPU TIME IS 10.87 SECONDS

THE MAXIMUM TEMPERATURE IS - 8.78784D+01 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 19 20 21

THE MINIMUM TEMPERATURE IS - 6.86832D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 25

NO	TIME	NO	MAX HEAT	BETA	L1 NORM OF	RHO	RHO	NO	L1 NORM OF	MAX TEMP	NODE	MAX PERCENT	
TIME	ITER	RESIDUAL		TEMP DIFF	(ILLRATON)	(JACOBI)	ITER	TEMP DIFF	CHANGE	TEMP	TEMP CHANGE		
904	7.422120+01	1	7.583390+01	3	8.017990+01	5	8.181650+01	11	8.440800+01	13	8.541430+01		
904	7.422120+01	1	4.263310-04	1	055000+00	0	0	0	0				
904	7.422120+01	4	9.005930-08	1	055000+00	0	0	0	0	1	4.923350-05		
904	7.422120+01	2	9.195470-06	1	055000+00	0	0	0	0	2	4.409180-06	24	4.500290-01
TABLE FOR SPECIAL MONITORING OF TEMPERATURES													
***** NODE NUMBERS AND TEMPERATURES *****													
905	7.446440+01	1	2.962340-04	1	055000+00	0	0	0	0	1	5.027820-05		
905	7.446440+01	3	9.151510-06	1	055000+00	0	0	0	0	2	3.485580-06	24	4.630070-01
905	7.446440+01	2	7.456130-06	1	055000+00	0	0	0	0	2	3.485580-06	24	4.630070-01
905	7.446440+01	1	7.583380+01	3	8.017960+01	5	8.181600+01	11	8.440720+01	13	8.541210+01	24	6.724340-01
905	7.446440+01	15	8.637480+01	17	8.720610+01	19	8.772930+01	21	8.770640+01	24	6.839240+01		
906	7.473200+01	1	3.805370-04	1	055000+00	0	0	0	0	1	5.633200-05		
906	7.473200+01	4	5.955390-07	1	055000+00	0	0	0	0	2	3.255990-06	24	4.802020-01
906	7.473200+01	3	2.143370-06	1	055000+00	0	0	0	0	1	6.514450-05		
906	7.473200+01	1	7.583360+01	3	8.017910+01	5	8.181540+01	11	8.440620+01	13	8.540940+01	24	7.021280-01
906	7.473200+01	15	8.636630+01	17	8.718580+01	19	8.769300+01	21	8.765610+01	24	6.791220+01		
907	7.502640+01	1	4.987100-04	1	055000+00	0	0	0	0	1	6.514450-05		
907	7.502640+01	4	1.346920-06	1	055000+00	0	0	0	0	2	5.557430-06	24	4.949970-01
907	7.502640+01	3	3.260020-06	1	055000+00	0	0	0	0	1	6.514450-05		
907	7.502640+01	1	7.583350+01	3	8.017860+01	5	8.181460+01	11	8.440490+01	13	8.540620+01	24	7.288780-01
907	7.502640+01	15	8.635650+01	17	8.716320+01	19	8.765330+01	21	8.760150+01	24	6.741720+01		
908	7.535020+01	1	1.373040-03	1	055000+00	0	0	0	0	1	1.286940-04		
908	7.535020+01	4	5.646430-06	1	055000+00	0	0	0	0	2	1.484550-05		
908	7.535020+01	4	9.083100-07	1	055000+00	0	0	0	0	3	2.060460-06	24	4.822280-01
908	7.535020+01	2	6.743110-06	1	055000+00	0	0	0	0	1	6.514450-05		
908	7.535020+01	1	7.583320+01	3	8.017780+01	5	8.181320+01	11	8.440310+01	13	8.540220+01	24	7.152890-01
908	7.535020+01	15	8.634510+01	17	8.713790+01	19	8.760980+01	21	8.754210+01	24	6.693350+01		
909	7.567510+01	1	7.130990-04	1	055000+00	0	0	0	0	1	1.086610-04		
909	7.567510+01	4	2.837230-06	1	055000+00	0	0	0	0	2	8.120280-06	24	4.199740-01
909	7.567510+01	3	5.540080-06	1	055000+00	0	0	0	0	1	6.514450-05		
909	7.567510+01	1	7.583290+01	3	8.017690+01	5	8.181220+01	11	8.440100+01	13	8.539780+01	24	6.274360-01
909	7.567510+01	15	8.633320+01	17	8.711220+01	19	8.756640+01	21	8.748110+01	24	6.651500+01		
910	7.600000+01	1	8.490690-04	1	055000+00	0	0	0	0	1	9.965340-05		
910	7.600000+01	4	3.492630-06	1	055000+00	0	0	0	0	2	9.103430-06	24	3.751860-01
910	7.600000+01	3	6.194060-06	1	055000+00	0	0	0	0	1	6.514450-05		
910	7.600000+01	1	7.583260+01	3	8.017580+01	5	8.181070+01	11	8.439870+01	13	8.539300+01	24	5.640630-01
910	7.600000+01	15	8.632080+01	17	8.708620+01	19	8.752320+01	21	8.742700+01	24	6.613980+01		
910	7.600000+01	25	6.562180+01										

HEATING6 02/12/83  
 W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 910 TIME STEPS, TIME = 7.600000E+01

IBM3033/ 0  
 20 58 24 11-16-89

GROSS GRID	1
FINE GRID	1
DISTANCE	0.0
1	0.0
2	0.03
3	0.06
4	0.08
5	0.10
6	0.57
7	1.04
8	1.51
9	1.98
10	2.45
11	2.92
12	3.14
13	3.35
14	3.57
15	3.79
16	4.01
17	4.23
18	4.45
19	4.67
20	4.89
21	5.10
22	5.18
23	5.25
24	5.32
25	5.35

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	76.310000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 3.24907341E-01

ELAPSED CPU TIME IS 10.97 SECONDS

THE MAXIMUM TEMPERATURE IS 8.75541E+01 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES 19 20

THE MINIMUM TEMPERATURE IS 6.56118E+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES 25

NO	TIME	NO	MAX HEAT	BETA	L1 NORM OF	RHO	RHO	NO	L1 NORM OF	MAX TEMP	MODE	MAX PERCENT
TIME	ITER	RESIDUAL		TEMP DIFF	(ITERATION)	(JACOBI)	ITER	TEMP DIFF	CHANGE		TEMP CHANGE	
911	7.635740+01	1	2.08502E-03	1.055000+00	0.0	0.0	1	1.83507D-04	24.3	2.39200-01	24.4	8.97500-01
911	7.635740+01	2	1.46090E-06	1.055000+00	0.0	0.0	2	2.26003D-05				
911	7.635740+01	3	2.01343D-06	1.055000+00	0.0	0.0	3	3.60216D-06				
911	7.635740+01	4	2.85650E-06	1.055000+00	0.0	0.0						
TABLE FOR SPECIAL MONITORING OF TEMPERATURES												
***** MODE NUMBERS AND TEMPERATURES *****												
911	7.635740+01	1	7.58221D+01	3.8	0.1743D+01	5.8	1.8087D+01	11.8	4.3957D+01	13.8	5.3872D+01	
911	7.635740+01	2	5.63365D+01	17.8	7.0572D+01	19.8	7.4759D+01	21.8	7.3656D+01	24.6	5.8159D+01	
912	7.67505D+01	1	1.37601D-03	1.055000+00	0.0	0.0	1	1.75727D-04				
912	7.67505D+01	2	1.50557D-06	1.055000+00	0.0	0.0	2	1.55434D-05				
912	7.67505D+01	3	9.3214D-06	1.055000+00	0.0	0.0	3	2.25422D-06	24.2	5.6614D-01	24.3	8.9896D-01
912	7.67505D+01	4	1.3176D-06	1.055000+00	0.0	0.0						
912	7.67505D+01	5	1.58315D+01	3.8	0.1725D+01	5.8	1.8062D+01	11.8	4.3919D+01	13.8	5.3802D+01	
912	7.67505D+01	6	1.75831D+01	17.8	7.0249D+01	19.8	7.4244D+01	21.8	7.2997D+01	24.6	5.5593D+01	
913	7.71830D+01	1	5.72347D-02	1.055000+00	0.0	0.0	1	3.34117D-03				
913	7.71830D+01	2	3.02344D-06	1.055000+00	0.0	0.0	2	5.92129D-04				
913	7.71830D+01	3	3.03337D-06	1.055000+00	0.0	0.0	3	1.06580D-04				
913	7.71830D+01	4	3.00827D-06	1.055000+00	0.0	0.0	4	1.83493D-05				
913	7.71830D+01	5	2.9626D-06	1.055000+00	0.0	0.0	5	3.30028D-06	25.2	3.3511D+00	25.3	5.8651D+00
913	7.71830D+01	6	3.59718D-06	1.055000+00	0.0	0.0						
913	7.6851D+01	1	5.02154D-04	1.055000+00	0.0	0.0	1	2.18604D-04				
913	7.6851D+01	2	4.62441D-07	1.055000+00	0.0	0.0	2	2.84701D-06	25.6	5.7768D-01	25.7	1.01027D+00
913	7.6851D+01	3	2.39525D-06	1.055000+00	0.0	0.0						
913	7.6851D+01	4	1.93042D-05	1.055000+00	0.0	0.0	1	8.88113D-06				
913	7.6851D+01	5	9.0784D-06	1.055000+00	0.0	0.0	2	5.04235D-07	25.6	2.3201D-01	25.9	5.7178D-01
913	7.6851D+01	6	6.3027D-06	1.055000+00	0.0	0.0						
913	7.6851D+01	7	1.75831D+01	3.8	0.1720D+01	5.8	1.8055D+01	11.8	4.3908D+01	13.8	5.3782D+01	
913	7.6851D+01	8	1.58315D+01	17.8	7.0160D+01	19.8	7.4103D+01	21.8	7.2820D+01	24.6	5.6893D+01	
914	7.6966D+01	1	5.67096D-04	1.055000+00	0.0	0.0	1	2.26148D-04				
914	7.6966D+01	2	4.93565D-07	1.055000+00	0.0	0.0	2	2.42411D-06	25.5	8.8081D-01	25.8	9.4677D-01
914	7.6966D+01	3	1.87394D-06	1.055000+00	0.0	0.0						
914	7.6966D+01	4	1.75831D+01	3.8	0.1714D+01	5.8	1.8047D+01	11.8	4.3896D+01	13.8	5.3762D+01	
914	7.6966D+01	5	1.58315D+01	17.8	7.0071D+01	19.8	7.3963D+01	21.8	7.2645D+01	24.6	6.0807D+01	
915	7.70737D+01	1	4.42958D-04	1.055000+00	0.0	0.0	1	1.94451D-04				
915	7.70737D+01	2	4.28299D-06	1.055000+00	0.0	0.0	2	6.03967D-06	25.6	7.5270D-01	25.9	1.01821D+00
915	7.70737D+01	3	4.57916D-06	1.055000+00	0.0	0.0						
915	7.70665D+01	1	1.11555D-05	1.055000+00	0.0	0.0	1	4.15761D-06				
915	7.70665D+01	2	1.28555D-06	1.055000+00	0.0	0.0	2	1.49689D-07	25.6	3.1440D-01	25.9	5.2119D-01
915	7.70665D+01	3	1.84364D-07	1.055000+00	0.0	0.0						
915	7.70665D+01	4	1.75831D+01	3.8	0.1708D+01	5.8	1.8040D+01	11.8	4.3885D+01	13.8	5.3742D+01	
915	7.70665D+01	5	1.58315D+01	17.8	6.9988D+01	19.8	7.3833D+01	21.8	7.2485D+01	24.6	6.5605D+01	
916	7.71670D+01	1	3.19318D-04	1.055000+00	0.0	0.0	1	1.50504D-04				
916	7.71670D+01	2	3.17768D-06	1.055000+00	0.0	0.0	2	4.37719D-06	25.6	9.8610D-01	25.9	1.04347D+00
916	7.71670D+01	3	2.02130D-06	1.055000+00	0.0	0.0						
916	7.71580D+01	1	1.59014D-05	1.055000+00	0.0	0.0	1	4.76861D-06				
916	7.71580D+01	2	1.62956D-06	1.055000+00	0.0	0.0	2	2.04474D-07	25.6	3.8501D-01	25.9	5.3690D-01
916	7.71580D+01	3	1.05610D-06	1.055000+00	0.0	0.0						
916	7.71580D+01	4	1.75831D+01	3.8	0.1703D+01	5.8	1.8033D+01	11.8	4.3875D+01	13.8	5.3724D+01	
916	7.71580D+01	5	1.58315D+01	17.8	6.9912D+01	19.8	7.3714D+01	21.8	7.2342D+01	24.6	7.0769D+01	
917	7.72495D+01	1	1.83142D-04	1.055000+00	0.0	0.0	1	1.08690D-04				
917	7.72495D+01	2	1.89071D-06	1.055000+00	0.0	0.0	2	2.66164D-06	25.6	8.2999D-01	25.9	1.01051D+00
917	7.72495D+01	3	1.61622D-06	1.055000+00	0.0	0.0						
917	7.72440D+01	1	1.10338D-05	1.055000+00	0.0	0.0	1	2.79259D-06				
917	7.72440D+01	2	1.04736D-06	1.055000+00	0.0	0.0						

917	7.724400+01	1 6 503410-07	1 055000+00	0 0 0	0 0	0 0	2 1 369270-07	25 6 440600-01	25 9 529010-01
	917	7.72440+01	1 7 583040+01	3 8 016970+01	5 8 180260+01	11 8 438650+01	11 8 438650+01	13 8 537070+01	
			15 8 626880+01	17 8 698460+01	19 8 736030+01	21 8 722110+01	21 8 722110+01	24 6 762110+01	
			25 6 823350+01		0 0	0 0			
918	7.733000+01	1 1 247480-04	1 055000+00	0 0 0	0 0	0 0	1 8 429860-05		
	918	7.733000+01	2 9 147960-06	1 055000+00	0 0 0	0 0	2 2 455830-06	25 6 771980-01	25 9 924720-01
			2 9 511830-07	1 055000+00	0 0 0	0 0	11 8 438550+01	13 8 536890+01	
			1 7 583020+01	3 8 016920+01	5 8 180190+01	11 8 438550+01	11 8 438550+01	24 6 821280+01	
			15 8 626500+01	17 8 697680+01	19 8 734930+01	21 8 720640+01	21 8 720640+01		
			25 6 891070+01		0 0	0 0			
919	7.741600+01	1 1 126610-04	1 055000+00	0 0 0	0 0	0 0	1 7 436130-05		
	919	7.741600+01	2 8 623610-06	1 055000+00	0 0 0	0 0	2 1 969910-06	25 7 067110-01	25 1 025550+00
			1 9 991410-06	1 055000+00	0 0 0	0 0			
			1 1 332710-05	1 055000+00	0 0 0	0 0	1 3 121310-06		
			2 1 217760-06	1 055000+00	0 0 0	0 0	2 1 796870-07	25 6 572370-01	25 9 537520-01
			1 8 043320-07	1 055000+00	0 0 0	0 0	11 8 438150+01	13 8 536730+01	
			1 7 583010+01	3 8 016870+01	5 8 180120+01	11 8 438150+01	11 8 438150+01	24 6 879730+01	
			15 8 626140+01	17 8 697010+01	19 8 733910+01	21 8 719710+01	21 8 719710+01		
			25 6 956790+01		0 0	0 0			
920	7.748900+01	1 6 625410-05	1 055000+00	0 0 0	0 0	0 0	1 5 579150-05		
	920	7.748900+01	2 5 377170-06	1 055000+00	0 0 0	0 0	2 1 178420-06	25 6 773660-01	25 9 736760-01
			1 5 910520-06	1 055000+00	0 0 0	0 0	11 8 438350+01	13 8 536560+01	
			1 7 582990+01	3 8 016820+01	5 8 180050+01	11 8 438350+01	11 8 438350+01	24 6 941220+01	
			15 8 625780+01	17 8 696350+01	19 8 732890+01	21 8 718630+01	21 8 718630+01		
			25 7 024530+01		0 0	0 0			
921	7.756900+01	1 6 203110-04	1 055000+00	0 0 0	0 0	0 0	1 1 422390-04		
	921	7.756900+01	3 6 117180-06	1 055000+00	0 0 0	0 0	2 7 321920-06	25 8 195640-01	25 1 166720+00
			2 3 657560-06	1 055000+00	0 0 0	0 0			
			4 773600-05	1 055000+00	0 0 0	0 0	1 1 502760-05		
			2 3 707190-06	1 055000+00	0 0 0	0 0	2 7 480790-07	25 6 531600-01	25 9 298280-01
			1 2 811270-06	1 055000+00	0 0 0	0 0	11 8 438270+01	13 8 536420+01	
			1 7 582970+01	3 8 016780+01	5 8 179990+01	11 8 438270+01	11 8 438270+01	24 6 994790+01	
			15 8 625490+01	17 8 695800+01	19 8 732060+01	21 8 717790+01	21 8 717790+01		
			25 7 089850+01		0 0	0 0			
922	7.761910+01	1 7 275650-04	1 055000+00	0 0 0	0 0	0 0	1 1 891740-04		
	922	7.761910+01	3 6 856140-06	1 055000+00	0 0 0	0 0	2 8 765540-06	25 8 626730-01	25 1 216770+00
			2 3 233110-06	1 055000+00	0 0 0	0 0			
			1 5 983390-06	1 055000+00	0 0 0	0 0	1 7 437120-06		
			1 5 983390-06	1 055000+00	0 0 0	0 0	2 4 857680-07	25 6 719220-01	25 9 477250-01
			1 4 766900-07	1 055000+00	0 0 0	0 0	11 8 438200+01	13 8 536310+01	
			1 7 582960+01	3 8 016740+01	5 8 179950+01	11 8 438200+01	11 8 438200+01	24 7 042020+01	
			15 8 625260+01	17 8 695380+01	19 8 731420+01	21 8 717150+01	21 8 717150+01		
			25 7 157040+01		0 0	0 0			
923	7.765560+01	1 1 710270-04	1 055000+00	0 0 0	0 0	0 0	1 9 999510-05		
	923	7.765560+01	2 1 485660-06	1 055000+00	0 0 0	0 0	2 2 540480-06	25 7 508730-01	25 1 049140+00
			2 8 842420-07	1 055000+00	0 0 0	0 0			
			1 3 703020-06	1 055000+00	0 0 0	0 0	1 2 504230-06		
			1 3 703020-06	1 055000+00	0 0 0	0 0	2 2 237780-07	25 6 804740-01	25 9 507760-01
			1 2 969060-07	1 055000+00	0 0 0	0 0	11 8 438140+01	13 8 536210+01	
			1 7 582950+01	3 8 016710+01	5 8 179910+01	11 8 438140+01	11 8 438140+01	24 7 090910+01	
			15 8 625050+01	17 8 694990+01	19 8 730840+01	21 8 716590+01	21 8 716590+01		
			25 7 225080+01		0 0	0 0			
924	7.769660+01	1 8 287260-05	1 055000+00	0 0 0	0 0	0 0	1 7 588300-05		
	924	7.769660+01	2 9 940170-06	1 055000+00	0 0 0	0 0	2 1 807240-06	25 7 310610-01	25 1 011840+00
			1 5 005970-06	1 055000+00	0 0 0	0 0			
			1 3 474040-06	1 055000+00	0 0 0	0 0	1 1 913390-06		
			1 3 474040-06	1 055000+00	0 0 0	0 0	2 2 165580-07	25 6 872040-01	25 9 511370-01
			1 3 330320-07	1 055000+00	0 0 0	0 0	11 8 438080+01	13 8 536110+01	
			1 7 582940+01	3 8 016680+01	5 8 179870+01	11 8 438080+01	11 8 438080+01	24 7 142130+01	
			15 8 624850+01	17 8 694630+01	19 8 730300+01	21 8 716080+01	21 8 716080+01		
			25 7 293810+01		0 0	0 0			
925	7.773690+01	1 5 206930-05	1 055000+00	0 0 0	0 0	0 0	1 5 269720-05		
	925	7.773690+01	2 6 840370-06	1 055000+00	0 0 0	0 0	2 1 246570-06	25 7 250910-01	25 9 941190-01
			1 3 322230-06	1 055000+00	0 0 0	0 0	4 380300+01	13 8 536020+01	
			1 7 582930+01	3 8 016650+01	5 8 179830+01	11 8 438030+01	11 8 438030+01	24 7 198240+01	
			15 8 624530+01	17 8 694270+01	19 8 729760+01	21 8 715590+01	21 8 715590+01		

926	7 778000+01	1 4	548750-05	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1 5 898130-05	25 7 590950-01	25 1 030500+00
926	7 778000+01	2 6	057050-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	2 1 090380-06	25 7 590950-01	25 1 030500+00
926	7 778000+01	1 2	914640-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1 2 201390-06	25 7 011300-01	25 9 518060-01
926	7 777660+01	1 4	191240-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	2 2 412540-07	25 7 011300-01	25 9 518060-01
926	7 777660+01	1 4	191340-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	11 8 437970+01	13 8 535930+01	
926	7 777660+01	1 4	218960-07	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	21 8 715160+01	24 7 253950+01	
926	7 77770+01	1 7	582920+01	3 8 016620+01	0 0	0 0	0 0	0 0	0 0	0 0	0 0	11 8 437970+01	13 8 535930+01	
		15 8	624470+01	17 8 693930+01	0 0	0 0	0 0	0 0	0 0	0 0	0 0	21 8 715160+01	24 7 253950+01	
		25 7	436430+01		0 0	0 0	0 0	0 0	0 0	0 0	0 0	1 4 717210-05	25 7 263680-01	25 9 767700-01
927	7 781630+01	1 2	676010-05	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	2 7 306830-07	25 7 263680-01	25 9 767700-01
927	7 781630+01	2 4	039880-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	11 8 437920+01	13 8 535840+01	
927	7 781630+01	1 1	840570-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	21 8 714730+01	24 7 313220+01	
927	7 78160+01	1 7	582910+01	3 8 016590+01	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1 4 463060-05	25 7 498940-01	25 9 986520-01
927	7 78160+01	15 8	624280+01	17 8 693660+01	0 0	0 0	0 0	0 0	0 0	0 0	0 0	2 6 915570-07	25 7 498940-01	25 9 986520-01
927	7 785600+01	1 2	541940-05	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	11 8 437860+01	13 8 535750+01	
928	7 785600+01	2 3	757080-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	21 8 714330+01	24 7 375750+01	
928	7 785600+01	1 1	758040-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1 4 463060-05	25 7 498940-01	25 9 986520-01
928	7 78560+01	1 7	582900+01	3 8 016560+01	0 0	0 0	0 0	0 0	0 0	0 0	0 0	2 6 915570-07	25 7 498940-01	25 9 986520-01
928	7 78560+01	15 8	624100+01	17 8 693260+01	0 0	0 0	0 0	0 0	0 0	0 0	0 0	11 8 437860+01	13 8 535750+01	
929	7 789570+01	1 2	296330-05	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	21 8 714330+01	24 7 375750+01	
929	7 789570+01	2 3	403370-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1 4 199680-05	25 7 714240-01	25 1 017170+00
929	7 789570+01	1 1	558250-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	2 6 196430-07	25 7 714240-01	25 1 017170+00
929	7 789310+01	1 3	262930-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1 1 646030-06	25 7 217670-01	25 9 516910-01
929	7 789310+01	1 3	262930-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	2 1 865710-07	25 7 217670-01	25 9 516910-01
929	7 789310+01	1 3	575550-07	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	11 8 437810+01	13 8 535670+01	
929	7 78930+01	1 7	582890+01	3 8 016540+01	0 0	0 0	0 0	0 0	0 0	0 0	0 0	21 8 713970+01	24 7 436870+01	
929	7 78930+01	15 8	623920+01	17 8 692950+01	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1 4 199680-05	25 7 714240-01	25 1 017170+00
930	7 793020+01	1 1	513990-05	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	2 6 196430-07	25 7 714240-01	25 1 017170+00
930	7 793020+01	2 2	379140-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1 3 446020-05	25 7 384240-01	25 9 644750-01
930	7 793020+01	1 1	040730-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	2 4 427830-07	25 7 384240-01	25 9 644750-01
930	7 79300+01	1 7	582880+01	3 8 016510+01	0 0	0 0	0 0	0 0	0 0	0 0	0 0	11 8 437760+01	13 8 535580+01	
930	7 79300+01	15 8	623750+01	17 8 692640+01	0 0	0 0	0 0	0 0	0 0	0 0	0 0	21 8 713620+01	24 7 500430+01	
931	7 796510+01	1 1	413380-05	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1 3 072090-05	25 7 112470-01	25 9 201040-01
931	7 796510+01	2 2	186370-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	2 4 428450-07	25 7 112470-01	25 9 201040-01
931	7 796510+01	1 8	910910-07	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	11 8 437710+01	13 8 535500+01	
931	7 79650+01	1 7	582870+01	3 8 016480+01	0 0	0 0	0 0	0 0	0 0	0 0	0 0	21 8 713310+01	24 7 562340+01	
931	7 79650+01	15 8	623590+01	17 8 692340+01	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1 2 715220-05	25 7 236740-01	25 9 276450-01
932	7 800000+01	1 1	095660-05	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	2 3 204930-07	25 7 236740-01	25 9 276450-01
932	7 800000+01	2 1	617500-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	11 8 437660+01	13 8 535420+01	
932	7 800000+01	1 7	107640-07	1 055000+00	0 0	0 0	0 0	0 0	0 0	0 0	0 0	21 8 713020+01	24 7 626100+01	
932	7 80000+01	1 7	582860+01	3 8 016460+01	0 0	0 0	0 0	0 0	0 0	0 0	0 0	1 2 715220-05	25 7 236740-01	25 9 276450-01
932	7 80000+01	15 8	623420+01	17 8 692050+01	0 0	0 0	0 0	0 0	0 0	0 0	0 0	2 3 204930-07	25 7 236740-01	25 9 276450-01
932	7 80000+01	1 7	582860+01	3 8 016460+01	0 0	0 0	0 0	0 0	0 0	0 0	0 0	11 8 437660+01	13 8 535420+01	
932	7 80000+01	15 8	623420+01	17 8 692050+01	0 0	0 0	0 0	0 0	0 0	0 0	0 0	21 8 713020+01	24 7 626100+01	
932	7 80000+01	25 7	873560+01		0 0	0 0	0 0	0 0	0 0	0 0	0 0	1 2 715220-05	25 7 236740-01	25 9 276450-01



HEATING6 02/12/83  
W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 932 TIME STEPS, TIME = 7.800000E+01

TBM4033/ 0  
20 58 26 11-16-89

GROSS GRID	1
	1
FINE GRID	1
DISTANCE	0.0
1	75183
2	0.03
3	78100
4	0.06
5	80116
6	0.08
7	80198
8	0.10
9	81180
10	0.57
11	82123
12	1.04
13	82167
14	1.51
15	83110
16	1.58
17	83153
18	2.45
19	83195
20	2.92
21	84138
22	3.14
23	84187
24	3.35
25	85135
26	3.57
27	85181
28	3.79
29	86123
30	4.01
31	86161
32	4.23
33	86192
34	4.45
35	87115
36	4.67
37	87126
38	4.89
39	87126
40	5.10
41	87113
42	5.18
43	81165
44	5.25
45	77139
46	5.32
47	76126
48	5.35
49	78174

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	76.310000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 3.49171492E-02

ELAPSED CPU TIME IS 11.38 SECONDS

THE MAXIMUM TEMPERATURE IS 8.726500E+01 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES 19 20

THE MINIMUM TEMPERATURE IS 7.582800E+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES 1

NO TIME	NO ITER	MAX HEAT RESIDUAL	BETA	I 1 ROOM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	I 1 ROOM OF TEMP DIFF	MAX TEMP CHANGE	NOISE	MAX PERCENT TEMP CHANGE
933 7.80350+01	1 7.582850+01	3 8.016430+01	5 8.179540+01	11 8.437610+01	13 8.535340+01	1 2.651290-05	25 7.368280-01	25 9.358250-01			
	15 8.623260+01	17 8.691750+01	19 8.726070+01	21 8.712740+01	24 7.691580+01	2 3.383710-07					
	25 7.947250+01										
934 7.80700+01	1 1.018870-05	1.055000+00 0.0	0.0	0.0	0.0	1 2.526390-05					
	2 1.569470-06	1.055000+00 0.0	0.0	0.0	0.0	2 3.023440-07	25 7.597710-01	25 9.560170-01			
	6.593690-07	1.055000+00 0.0	0.0	0.0	0.0	11 8.437560+01	13 8.535260+01				
	1 7.582840+01	3 8.016400+01	5 8.179500+01	11 8.437560+01	13 8.535260+01	2 3.383710-07					
	15 8.623090+01	17 8.691450+01	19 8.725640+01	21 8.712480+01	24 7.759700+01						
	25 8.023220+01										
935 7.81060+01	1 9.735270-06	1.055000+00 0.0	0.0	0.0	0.0	1 2.402720-05					
	1 9.735270-06	1.055000+00 0.0	0.0	0.0	0.0	2 1.017170-06	25 7.711440-01	25 9.611030-01			
	2.288730-06	1.055000+00 0.0	0.0	0.0	0.0	11 8.437510+01	13 8.535170+01				
	1 7.582830+01	3 8.016370+01	5 8.179470+01	11 8.437510+01	13 8.535170+01	2 3.383710-07					
	15 8.622920+01	17 8.691150+01	19 8.725210+01	21 8.712230+01	24 7.829360+01						
	25 8.100340+01										
936 7.814130+01	1 8.743680-06	1.055000+00 0.0	0.0	0.0	0.0	1 2.249870-05					
	1 8.743680-06	1.055000+00 0.0	0.0	0.0	0.0	2 9.393190-07	25 7.813970-01	25 9.646470-01			
	2.070570-06	1.055000+00 0.0	0.0	0.0	0.0	11 8.437450+01	13 8.535090+01				
	1 7.582820+01	3 8.016350+01	5 8.179430+01	11 8.437450+01	13 8.535090+01	2 3.383710-07					
	15 8.622750+01	17 8.690850+01	19 8.724780+01	21 8.712000+01	24 7.900450+01						
	25 8.178480+01										
937 7.817670+01	1 7.889090-06	1.055000+00 0.0	0.0	0.0	0.0	1 2.109500-05					
	1 7.889090-06	1.055000+00 0.0	0.0	0.0	0.0	2 8.621300-07	25 7.907630-01	25 9.668840-01			
	1.874420-06	1.055000+00 0.0	0.0	0.0	0.0	11 8.437400+01	13 8.535000+01				
	1 7.582810+01	3 8.016320+01	5 8.179390+01	11 8.437400+01	13 8.535000+01	2 3.383710-07					
	15 8.622590+01	17 8.690550+01	19 8.723650+01	21 8.711800+01	24 7.972870+01						
	25 8.257550+01										
938 7.821210+01	1 7.187930-06	1.055000+00 0.0	0.0	0.0	0.0	1 1.982150-05					
	1 7.187930-06	1.055000+00 0.0	0.0	0.0	0.0	2 8.059000-07	25 7.993720-01	25 9.680500-01			
	1.731840-06	1.055000+00 0.0	0.0	0.0	0.0	11 8.437350+01	13 8.534920+01				
	1 7.582800+01	3 8.016290+01	5 8.179360+01	11 8.437350+01	13 8.534920+01	2 3.383710-07					
	15 8.622420+01	17 8.690250+01	19 8.723940+01	21 8.711610+01	24 8.046520+01						
	25 8.337490+01										
939 7.824760+01	1 6.566600-06	1.055000+00 0.0	0.0	0.0	0.0	1 1.860410-05					
	1 6.566600-06	1.055000+00 0.0	0.0	0.0	0.0	2 7.441700-07	25 8.073290-01	25 9.683420-01			
	1.566590-06	1.055000+00 0.0	0.0	0.0	0.0	11 8.437290+01	13 8.534830+01				
	1 7.582790+01	3 8.016260+01	5 8.179320+01	11 8.437290+01	13 8.534830+01	2 3.383710-07					
	15 8.622250+01	17 8.689950+01	19 8.723520+01	21 8.711440+01	24 8.121300+01						
	25 8.418220+01										
940 7.828300+01	1 5.807750-06	1.055000+00 0.0	0.0	0.0	0.0	1 1.733130-05					
	1 5.807750-06	1.055000+00 0.0	0.0	0.0	0.0	2 6.642140-07	25 8.144430-01	25 9.674760-01			
	1.369560-06	1.055000+00 0.0	0.0	0.0	0.0	11 8.437240+01	13 8.534750+01				
	1 7.582780+01	3 8.016230+01	5 8.179280+01	11 8.437240+01	13 8.534750+01	2 3.383710-07					
	15 8.622080+01	17 8.689650+01	19 8.723100+01	21 8.711300+01	24 8.197130+01						
	25 8.499670+01										
941 7.831850+01	1 5.371630-06	1.055000+00 0.0	0.0	0.0	0.0	1 1.626830-05					
	1 5.371630-06	1.055000+00 0.0	0.0	0.0	0.0	2 6.292820-07	25 8.210880-01	25 9.660240-01			
	1.278420-06	1.055000+00 0.0	0.0	0.0	0.0	11 8.437190+01	13 8.534660+01				
	1 7.582770+01	3 8.016200+01	5 8.179240+01	11 8.437190+01	13 8.534660+01	2 3.383710-07					
	15 8.621910+01	17 8.689350+01	19 8.722690+01	21 8.711170+01	24 8.273920+01						
	25 8.581780+01										
942 7.835390+01	1 4.833150-06	1.055000+00 0.0	0.0	0.0	0.0	1 1.518290-05					
	1 4.833150-06	1.055000+00 0.0	0.0	0.0	0.0	2 5.690770-07	25 8.271420-01	25 9.638360-01			
	1.126160-06	1.055000+00 0.0	0.0	0.0	0.0	11 8.437130+01	13 8.534580+01				
	1 7.582760+01	3 8.016170+01	5 8.179210+01	11 8.437130+01	13 8.534580+01	2 3.383710-07					
	15 8.621700+01	17 8.689100+01	19 8.722470+01	21 8.710960+01	24 8.273920+01						
	25 8.581780+01										

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

\*\*\*\*\* NODE NUMBERS AND TEMPERATURES \*\*\*\*\*

NUMBER OF TIME STEPS

943	7 83894D+01	1 4 24938D-06	1 055000+00	0 0	0 0	19 8 72227D+01	21 8 71107D+01	24 8 35161D+01	25 8 32498D-01	25 8 60816D-01
943	7 83894D+01	1 4 24938D-06	1 055000+00	0 0	0 0	0 0	0 0	1 1 40968D-05	2 5 17223D-07	25 8 32498D-01
943	7 83894D+01	1 0 1419D-06	1 055000+00	0 0	0 0	0 0	0 0	2 5 17223D-07	13 8 53449D+01	24 8 43011D+01
943	7 83894D+01	1 7 58275D+01	3 8 01314D+01	0 0	0 0	5 8 17917D+01	11 8 43708D+01	21 8 71099D+01	24 8 43011D+01	24 8 43011D+01
943	7 83894D+01	1 7 58275D+01	3 8 01314D+01	0 0	0 0	19 8 72186D+01	21 8 71099D+01	24 8 43011D+01	24 8 43011D+01	24 8 43011D+01
944	7 84248D+01	1 3 96693D-06	1 055000+00	0 0	0 0	0 0	0 0	1 1 32111D-05	2 4 89287D-07	25 8 37561D-01
944	7 84248D+01	1 3 96693D-06	1 055000+00	0 0	0 0	0 0	0 0	2 4 89287D-07	25 8 37561D-01	25 8 37561D-01
944	7 84248D+01	1 9 37566D-07	1 055000+00	0 0	0 0	0 0	0 0	13 8 53440D+01	24 8 50937D+01	25 8 57460D-01
944	7 8425D+01	1 7 58274D+01	3 8 01611D+01	0 0	0 0	5 8 17913D+01	11 8 43702D+01	21 8 71093D+01	24 8 50937D+01	24 8 50937D+01
944	7 8425D+01	1 7 58274D+01	3 8 01611D+01	0 0	0 0	19 8 72146D+01	21 8 71093D+01	24 8 50937D+01	24 8 50937D+01	24 8 50937D+01
945	7 84603D+01	1 3 50754D-06	1 055000+00	0 0	0 0	0 0	0 0	1 1 22663D-05	2 4 42507D-07	25 8 42077D-01
945	7 84603D+01	1 3 50754D-06	1 055000+00	0 0	0 0	0 0	0 0	2 4 42507D-07	25 8 42077D-01	25 8 42077D-01
945	7 84603D+01	1 8 33316D-07	1 055000+00	0 0	0 0	0 0	0 0	13 8 53431D+01	24 8 58937D+01	25 8 53493D-01
945	7 84603D+01	1 7 58273D+01	3 8 01508D+01	0 0	0 0	5 8 17909D+01	11 8 43696D+01	21 8 71090D+01	24 8 58937D+01	24 8 58937D+01
945	7 84603D+01	1 7 58273D+01	3 8 01508D+01	0 0	0 0	19 8 72106D+01	21 8 71090D+01	24 8 58937D+01	24 8 58937D+01	24 8 58937D+01
946	7 8496D+01	1 7 58272D+01	3 8 01605D+01	0 0	0 0	0 0	0 0	1 1 13887D-05	2 3 99897D-07	25 8 46142D-01
946	7 8496D+01	1 7 58272D+01	3 8 01605D+01	0 0	0 0	0 0	0 0	2 3 99897D-07	25 8 46142D-01	25 8 46142D-01
946	7 8496D+01	1 7 58272D+01	3 8 01605D+01	0 0	0 0	0 0	0 0	13 8 53427D+01	24 8 66990D+01	25 8 49047D-01
946	7 8496D+01	1 7 58272D+01	3 8 01605D+01	0 0	0 0	5 8 17905D+01	11 8 43691D+01	21 8 71089D+01	24 8 66990D+01	24 8 66990D+01
946	7 8496D+01	1 7 58272D+01	3 8 01605D+01	0 0	0 0	19 8 72066D+01	21 8 71089D+01	24 8 66990D+01	24 8 66990D+01	24 8 66990D+01
947	7 85312D+01	1 5 8 62105D+01	17 8 68786D+01	0 0	0 0	0 0	0 0	1 1 48179D-05	2 3 21049D-07	25 8 58892D-01
947	7 85312D+01	1 5 8 62105D+01	17 8 68786D+01	0 0	0 0	0 0	0 0	2 3 21049D-07	25 8 58892D-01	25 8 58892D-01
947	7 85312D+01	2 1 69175D-06	1 055000+00	0 0	0 0	0 0	0 0	13 8 53414D+01	24 8 75124D+01	25 8 54291D-01
947	7 85312D+01	1 6 59370D-07	1 055000+00	0 0	0 0	0 0	0 0	2 4 78560D+01	24 8 75124D+01	25 8 54291D-01
947	7 85312D+01	1 7 58271D+01	3 8 01602D+01	0 0	0 0	5 8 17901D+01	11 8 43685D+01	21 8 71089D+01	24 8 75124D+01	24 8 75124D+01
947	7 85312D+01	1 7 58271D+01	3 8 01602D+01	0 0	0 0	19 8 72026D+01	21 8 71089D+01	24 8 75124D+01	24 8 75124D+01	24 8 75124D+01
948	7 85667D+01	1 3 08612D-05	1 055000+00	0 0	0 0	0 0	0 0	1 2 02566D-05	2 5 80977D-07	25 8 81008D-01
948	7 85667D+01	1 3 08612D-05	1 055000+00	0 0	0 0	0 0	0 0	2 5 80977D-07	25 8 81008D-01	25 8 81008D-01
948	7 85667D+01	2 3 20783D-06	1 055000+00	0 0	0 0	0 0	0 0	13 8 53405D+01	24 8 83349D+01	25 8 81008D-01
948	7 85667D+01	1 1 17244D-06	1 055000+00	0 0	0 0	0 0	0 0	2 4 8 83349D+01	24 8 83349D+01	25 8 81008D-01
948	7 85667D+01	1 7 58270D+01	3 8 01599D+01	0 0	0 0	5 8 17897D+01	11 8 43678D+01	21 8 71093D+01	24 8 83349D+01	24 8 83349D+01
948	7 85667D+01	1 7 58270D+01	3 8 01599D+01	0 0	0 0	19 8 71987D+01	21 8 71093D+01	24 8 83349D+01	24 8 83349D+01	24 8 83349D+01
949	7 8602D+01	1 1 91799D-05	1 055000+00	0 0	0 0	0 0	0 0	1 1 83273D-05	2 5 8 97208D-01	25 8 77957D-01
949	7 8602D+01	1 1 91799D-05	1 055000+00	0 0	0 0	0 0	0 0	2 4 07856D-07	25 8 97208D-01	25 8 97208D-01
949	7 8602D+01	2 2 20659D-06	1 055000+00	0 0	0 0	0 0	0 0	13 8 53396D+01	24 8 91688D+01	25 8 97208D-01
949	7 8602D+01	1 8 66632D-07	1 055000+00	0 0	0 0	0 0	0 0	2 4 8 91688D+01	24 8 91688D+01	25 8 97208D-01
949	7 8602D+01	1 7 58269D+01	3 8 01596D+01	0 0	0 0	5 8 17893D+01	11 8 43673D+01	21 8 71093D+01	24 8 91688D+01	24 8 91688D+01
949	7 8602D+01	1 7 58269D+01	3 8 01596D+01	0 0	0 0	19 8 71948D+01	21 8 71093D+01	24 8 91688D+01	24 8 91688D+01	24 8 91688D+01
950	7 86376D+01	1 1 23982D-05	1 055000+00	0 0	0 0	0 0	0 0	1 1 67980D-05	2 2 97359D-07	25 8 09696D-01
950	7 86376D+01	1 1 23982D-05	1 055000+00	0 0	0 0	0 0	0 0	2 2 97359D-07	25 8 09696D-01	25 8 09696D-01
950	7 86376D+01	2 1 59012D-06	1 055000+00	0 0	0 0	0 0	0 0	13 8 53336D+01	24 8 00146D+01	25 8 81966D-01
950	7 86376D+01	1 6 51314D-07	1 055000+00	0 0	0 0	0 0	0 0	2 4 8 00146D+01	24 8 00146D+01	25 8 81966D-01
950	7 8638D+01	1 7 58267D+01	3 8 01553D+01	0 0	0 0	5 8 17889D+01	11 8 43668D+01	21 8 71107D+01	24 8 00146D+01	24 8 00146D+01
950	7 8638D+01	1 7 58267D+01	3 8 01553D+01	0 0	0 0	19 8 71909D+01	21 8 71107D+01	24 8 00146D+01	24 8 00146D+01	24 8 00146D+01
951	7 86731D+01	1 8 92838D-06	1 055000+00	0 0	0 0	0 0	0 0	1 1 54373D-05	2 8 85945D-07	25 8 20021D-01
951	7 86731D+01	1 8 92838D-06	1 055000+00	0 0	0 0	0 0	0 0	2 8 85945D-07	25 8 20021D-01	25 8 20021D-01
951	7 86731D+01	1 9 25630D-06	1 055000+00	0 0	0 0	0 0	0 0	13 8 53377D+01	24 8 08724D+01	25 8 83454D-01
951	7 86731D+01	1 7 58266D+01	3 8 01590D+01	0 0	0 0	5 8 17884D+01	11 8 43662D+01	21 8 71117D+01	24 8 08724D+01	24 8 08724D+01
951	7 86731D+01	1 7 58266D+01	3 8 01590D+01	0 0	0 0	19 8 71871D+01	21 8 71117D+01	24 8 08724D+01	24 8 08724D+01	24 8 08724D+01
952	7 87086D+01	1 6 70619D-06	1 055000+00	0 0	0 0	0 0	0 0	1 1 43627D-05	2 7 23685D-07	25 8 28750D-01
952	7 87086D+01	1 6 70619D-06	1 055000+00	0 0	0 0	0 0	0 0	2 7 23685D-07	25 8 28750D-01	25 8 28750D-01
952	7 87086D+01	1 5 68140D-06	1 055000+00	0 0	0 0	0 0	0 0	13 8 53368D+01	24 8 17414D+01	25 8 83116D-01
952	7 87086D+01	1 7 58265D+01	3 8 01587D+01	0 0	0 0	5 8 17880D+01	11 8 43656D+01	21 8 71130D+01	24 8 17414D+01	24 8 17414D+01
952	7 87086D+01	1 7 58265D+01	3 8 01587D+01	0 0	0 0	19 8 71833D+01	21 8 71130D+01	24 8 17414D+01	24 8 17414D+01	24 8 17414D+01
953	7 87441D+01	1 5 8 62000D+01	17 8 68506D+01	0 0	0 0	0 0	0 0	1 1 34385D-05	2 6 18969D-07	25 8 36313D-01
953	7 87441D+01	1 5 8 62000D+01	17 8 68506D+01	0 0	0 0	0 0	0 0	2 6 18969D-07	25 8 36313D-01	25 8 36313D-01
953	7 87441D+01	1 5 41420D-06	1 055000+00	0 0	0 0	0 0	0 0	13 8 53153D+01	24 8 17414D+01	25 8 81473D-01
953	7 87441D+01	1 5 41420D-06	1 055000+00	0 0	0 0	0 0	0 0	2 4 8 17414D+01	24 8 17414D+01	25 8 81473D-01
953	7 87441D+01	1 3 56420D-06	1 055000+00	0 0	0 0	0 0	0 0	1 1 8 41650D+01	13 8 53153D+01	25 8 81473D-01
953	7 87441D+01	1 7 58255D+01	17 8 68506D+01	0 0	0 0	5 8 17876D+01	11 8 41650D+01	21 8 71530D+01	24 8 17414D+01	25 8 81473D-01
953	7 87441D+01	1 7 58255D+01	17 8 68506D+01	0 0	0 0	19 8 71833D+01	21 8 71530D+01	24 8 17414D+01	24 8 17414D+01	25 8 81473D-01

954	7 87796D+01	1 4 80206D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	1 1 26168D-05	25 9 83079D-01	25 9 78957D-01
954	7 87796D+01	1 4 80206D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	2 5 4480D-07	25 9 83079D-01	25 9 78957D-01
954	7 87796D+01	1 1 21124D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	11 8 43644D+01	13 8 53350D+01	24 9 35100D+01
954	7 8780D+01	1 7 58236D+01	3 8 015400+01	5 8 17872D+01	19 8 71759D+01	19 8 71759D+01	19 8 71759D+01	19 8 71759D+01	21 8 71162D+01	24 9 35100D+01	
955	7 8815D+01	1 4 13909D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	1 1 17418D-05	25 9 48981D-01	25 9 75534D-01
955	7 8815D+01	1 4 13909D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	2 4 52956D-07	25 9 48981D-01	25 9 75534D-01
955	7 8815D+01	1 1 01406D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	11 8 43638D+01	13 8 53344D+01	24 9 44080D+01
955	7 8815D+01	1 7 58262D+01	3 8 01577D+01	5 8 17868D+01	19 8 71723D+01	19 8 71723D+01	19 8 71723D+01	19 8 71723D+01	21 8 71182D+01	24 9 44080D+01	
956	7 8850D+01	1 3 74799D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	1 1 16195D-05	25 9 54382D-01	25 9 71607D-01
956	7 8850D+01	1 3 74799D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	2 4 10806D-07	25 9 54382D-01	25 9 71607D-01
956	7 8850D+01	1 9 17299D-07	1 055000+00	0 0	0 0	0 0	0 0	0 0	11 8 43632D+01	13 8 53331D+01	24 9 53142D+01
956	7 8851D+01	1 7 58261D+01	3 8 01573D+01	5 8 17863D+01	19 8 71687D+01	19 8 71687D+01	19 8 71687D+01	19 8 71687D+01	21 8 71204D+01	24 9 53142D+01	
957	7 8886D+01	1 3 23383D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	1 1 02294D-05	25 9 59105D-01	25 9 67028D-01
957	7 8886D+01	1 3 23383D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	2 3 57001D-07	25 9 59105D-01	25 9 67028D-01
957	7 8886D+01	1 7 60891D-07	1 055000+00	0 0	0 0	0 0	0 0	0 0	11 8 43625D+01	13 8 53322D+01	24 9 62278D+01
957	7 8886D+01	1 7 60891D-07	1 055000+00	0 0	0 0	0 0	0 0	0 0	21 8 71228D+01	24 9 62278D+01	
958	7 89215D+01	1 2 80827D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	1 9 49279D-06	25 9 63229D-01	25 9 61877D-01
958	7 89215D+01	1 2 80827D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	2 3 26650D-07	25 9 63229D-01	25 9 61877D-01
958	7 89215D+01	1 6 78339D-07	1 055000+00	0 0	0 0	0 0	0 0	0 0	11 8 43619D+01	13 8 53312D+01	24 9 71481D+01
958	7 8921D+01	1 7 58258D+01	3 8 01567D+01	5 8 17855D+01	19 8 71616D+01	19 8 71616D+01	19 8 71616D+01	19 8 71616D+01	21 8 71255D+01	24 9 71481D+01	
959	7 8957D+01	1 2 47562D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	1 8 81584D-06	25 9 66905D-01	25 9 56348D-01
959	7 8957D+01	1 2 47562D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	2 2 97662D-07	25 9 66905D-01	25 9 56348D-01
959	7 8957D+01	1 5 91859D-07	1 055000+00	0 0	0 0	0 0	0 0	0 0	11 8 43613D+01	13 8 53303D+01	24 9 80745D+01
959	7 8957D+01	1 7 58257D+01	3 8 01563D+01	5 8 17850D+01	19 8 71582D+01	19 8 71582D+01	19 8 71582D+01	19 8 71582D+01	21 8 71284D+01	24 9 80745D+01	
960	7 89925D+01	1 2 29211D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	1 8 25116D-06	25 9 70332D-01	25 9 50647D-01
960	7 89925D+01	1 2 29211D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	2 2 91096D-07	25 9 70332D-01	25 9 50647D-01
960	7 89925D+01	1 5 67204D-07	1 055000+00	0 0	0 0	0 0	0 0	0 0	11 8 43607D+01	13 8 53293D+01	24 9 90065D+01
960	7 8992D+01	1 7 58256D+01	3 8 01560D+01	5 8 17846D+01	19 8 71548D+01	19 8 71548D+01	19 8 71548D+01	19 8 71548D+01	21 8 71316D+01	24 9 90065D+01	
961	7 90279D+01	1 2 66022D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	1 8 00105D-06	25 9 74201D-01	24 9 46447D-01
961	7 90279D+01	1 2 66022D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	2 3 34431D-07	25 9 74201D-01	24 9 46447D-01
961	7 90279D+01	1 6 53353D-07	1 055000+00	0 0	0 0	0 0	0 0	0 0	11 8 43600D+01	13 8 53284D+01	24 9 99435D+01
961	7 9028D+01	1 7 58255D+01	3 8 01557D+01	5 8 17841D+01	19 8 71514D+01	19 8 71514D+01	19 8 71514D+01	19 8 71514D+01	21 8 71349D+01	24 9 99435D+01	
962	7 90636D+01	1 2 24201D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	1 7 50128D-06	25 9 81297D-01	24 9 45883D-01
962	7 90636D+01	1 2 24201D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	2 2 91992D-07	25 9 81297D-01	24 9 45883D-01
962	7 90636D+01	1 5 56338D-07	1 055000+00	0 0	0 0	0 0	0 0	0 0	11 8 43594D+01	13 8 53274D+01	24 1 00889D+02
962	7 9064D+01	1 7 58253D+01	3 8 01553D+01	5 8 17837D+01	19 8 71481D+01	19 8 71481D+01	19 8 71481D+01	19 8 71481D+01	21 8 71385D+01	24 1 00889D+02	
963	7 90993D+01	1 7 3866D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	1 6 89047D-06	25 9 88245D-01	24 9 45489D-01
963	7 90993D+01	1 7 3866D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	2 2 32304D-07	25 9 88245D-01	24 9 45489D-01
963	7 90993D+01	1 4 28409D-07	1 055000+00	0 0	0 0	0 0	0 0	0 0	11 8 43588D+01	13 8 53265D+01	24 1 01843D+02
963	7 9099D+01	1 7 58252D+01	3 8 01550D+01	5 8 17832D+01	19 8 71448D+01	19 8 71448D+01	19 8 71448D+01	19 8 71448D+01	21 8 71424D+01	24 1 01843D+02	
964	7 9135D+01	1 5 8 61805D+01	17 8 68279D+01	19 8 71448D+01	19 8 71448D+01	19 8 71448D+01	19 8 71448D+01	19 8 71448D+01	21 8 71424D+01	24 1 01843D+02	
964	7 9135D+01	1 5 8 61805D+01	17 8 68279D+01	19 8 71448D+01	19 8 71448D+01	19 8 71448D+01	19 8 71448D+01	19 8 71448D+01	21 8 71424D+01	24 1 01843D+02	
964	7 9135D+01	1 1 54496D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	1 6 44514D-06	25 9 95372D-01	24 9 45074D-01
964	7 9135D+01	1 1 54496D-06	1 055000+00	0 0	0 0	0 0	0 0	0 0	2 2 09573D-07	25 9 95372D-01	24 9 45074D-01
964	7 9135D+01	1 3 67163D-07	1 055000+00	0 0	0 0	0 0	0 0	0 0	11 8 43581D+01	13 8 53255D+01	24 9 45074D-01
964	7 9135D+01	1 7 58251D+01	3 8 01546D+01	5 8 17827D+01	19 8 71448D+01	19 8 71448D+01	19 8 71448D+01	19 8 71448D+01	21 8 71424D+01	24 1 01843D+02	

965	7 91714D+01	1 1 20664L-06	1 055000+00	0 0	0 0	0 0	17 8 68250L+01	19 8 71416D+01	21 8 71465D+01	24 1 02805D+02
		25 1 06980D+02	1 055000+00	0 0	0 0	0 0				
965	7 91714D+01	1 1 20664L-06	1 055000+00	0 0	0 0	0 0			1 5 92071D-06	24 9 44657D-01
		25 1 06980D+02	1 055000+00	0 0	0 0	0 0			2 1 73795D-07	25 1 00245D+00
965	7 91714D+01	1 2 85678D-07	1 055000+00	0 0	0 0	0 0			11 8 43574D+01	13 8 53245D+01
		1 7 5F250D+01	3 8 01542D+01	3 8 01542D+01	3 8 01542D+01	3 8 01542D+01			21 8 71509D+01	24 1 03776D+02
965	7 9171D+01	1 5 8 61768D+01	17 8 68220D+01	17 8 68220D+01	17 8 68220D+01	17 8 68220D+01				
		25 1 07983D+02	1 055000+00	0 0	0 0	0 0			1 5 48870D-06	
966	7 92077D+01	1 1 09283D-06	1 055000+00	0 0	0 0	0 0			2 1 61888D-07	25 1 00973D+00
		1 09283D-06	1 055000+00	0 0	0 0	0 0				
966	7 92077D+01	1 2 58318D-07	1 055000+00	0 0	0 0	0 0			11 8 43568D+01	13 8 53235D+01
		1 7 58248D+01	3 8 01539D+01	3 8 01539D+01	3 8 01539D+01	3 8 01539D+01			21 8 71556D+01	24 1 04756D+02
966	7 9208D+01	1 5 8 61750D+01	17 8 68190D+01	17 8 68190D+01	17 8 68190D+01	17 8 68190D+01				
		25 1 08992D+02	1 055000+00	0 0	0 0	0 0			1 5 03011D-06	
967	7 92443D+01	1 1 12913D-06	1 055000+00	0 0	0 0	0 0			2 1 33697D-07	25 1 01713D+00
		1 12913D-06	1 055000+00	0 0	0 0	0 0				
967	7 92443D+01	1 1 86123D-07	1 055000+00	0 0	0 0	0 0			11 8 43561D+01	13 8 53225D+01
		1 7 58247D+01	3 8 01535D+01	3 8 01535D+01	3 8 01535D+01	3 8 01535D+01			21 8 71605D+01	24 1 05745D+02
967	7 9244D+01	1 5 8 61731D+01	17 8 68160D+01	17 8 68160D+01	17 8 68160D+01	17 8 68160D+01				
		25 1 10009D+02	1 055000+00	0 0	0 0	0 0			1 4 63903D-06	
968	7 92811D+01	1 1 16041D-06	1 055000+00	0 0	0 0	0 0			2 1 18639L-07	25 1 02478D+00
		1 16041D-06	1 055000+00	0 0	0 0	0 0				
968	7 92811D+01	1 1 44816D-07	1 055000+00	0 0	0 0	0 0			11 8 43554D+01	13 8 53214D+01
		1 7 58246D+01	3 8 01531D+01	3 8 01531D+01	3 8 01531D+01	3 8 01531D+01			21 8 71657D+01	24 1 06743D+02
968	7 9281D+01	1 5 8 61713D+01	17 8 68129D+01	17 8 68129D+01	17 8 68129D+01	17 8 68129D+01				
		25 1 11034D+02	1 055000+00	0 0	0 0	0 0			1 4 24090D-06	
969	7 93181D+01	1 1 17701D-06	1 055000+00	0 0	0 0	0 0			2 1 13086D-07	25 1 03260D+00
		1 17701D-06	1 055000+00	0 0	0 0	0 0				
969	7 93181D+01	1 1 04561D-07	1 055000+00	0 0	0 0	0 0			11 8 43547D+01	13 8 53204D+01
		1 7 58244D+01	3 8 01527D+01	3 8 01527D+01	3 8 01527D+01	3 8 01527D+01			21 8 71712D+01	24 1 07750D+02
969	7 9318D+01	1 5 8 61694D+01	17 8 68099D+01	17 8 68099D+01	17 8 68099D+01	17 8 68099D+01				
		25 1 12067D+02	1 055000+00	0 0	0 0	0 0			1 3 79337D-06	
970	7 93554D+01	1 1 18981D-06	1 055000+00	0 0	0 0	0 0			2 1 04662D-07	25 1 04043D+00
		1 18981D-06	1 055000+00	0 0	0 0	0 0				
970	7 93554D+01	1 9 28660D-08	1 055000+00	0 0	0 0	0 0			11 8 43540D+01	13 8 53194D+01
		1 7 58243D+01	3 8 01524D+01	3 8 01524D+01	3 8 01524D+01	3 8 01524D+01			21 8 71769D+01	24 1 08765D+02
970	7 9355D+01	1 5 8 61675D+01	17 8 68069D+01	17 8 68069D+01	17 8 68069D+01	17 8 68069D+01				
		25 1 13107D+02	1 055000+00	0 0	0 0	0 0			1 3 48669D-06	
971	7 93930D+01	1 1 21022D-06	1 055000+00	0 0	0 0	0 0			2 1 07078D-07	25 1 01860D+00
		1 21022D-06	1 055000+00	0 0	0 0	0 0				
971	7 93930D+01	1 9 15257D-08	1 055000+00	0 0	0 0	0 0			11 8 43533D+01	13 8 53183D+01
		1 7 58242D+01	3 8 01520D+01	3 8 01520D+01	3 8 01520D+01	3 8 01520D+01			21 8 71830D+01	24 1 09791D+02
971	7 9393D+01	1 5 8 61655D+01	17 8 68038D+01	17 8 68038D+01	17 8 68038D+01	17 8 68038D+01				
		25 1 14156D+02	1 055000+00	0 0	0 0	0 0			1 3 14411D-06	
972	7 94309D+01	1 1 21467D-06	1 055000+00	0 0	0 0	0 0			2 9 73720D-08	25 1 05698D+00
		1 21467D-06	1 055000+00	0 0	0 0	0 0				
972	7 94309D+01	1 8 95417D-08	1 055000+00	0 0	0 0	0 0			11 8 43526D+01	13 8 53172D+01
		1 7 58240D+01	3 8 01516D+01	3 8 01516D+01	3 8 01516D+01	3 8 01516D+01			21 8 71893D+01	24 1 10825D+02
972	7 9431D+01	1 5 8 61635D+01	17 8 68007D+01	17 8 68007D+01	17 8 68007D+01	17 8 68007D+01				
		25 1 15213D+02	1 055000+00	0 0	0 0	0 0			1 2 95822D-06	
973	7 94691D+01	1 1 20490D-06	1 055000+00	0 0	0 0	0 0			2 1 10040D-07	25 1 06545D+00
		1 20490D-06	1 055000+00	0 0	0 0	0 0				
973	7 94691D+01	1 8 68150D-08	1 055000+00	0 0	0 0	0 0			11 8 43518D+01	13 8 53161D+01
		1 7 58239D+01	3 8 01512D+01	3 8 01512D+01	3 8 01512D+01	3 8 01512D+01			21 8 71960D+01	24 1 11859D+02
973	7 9469D+01	1 5 8 61616D+01	17 8 67976D+01	17 8 67976D+01	17 8 67976D+01	17 8 67976D+01				
		25 1 16278D+02	1 055000+00	0 0	0 0	0 0			1 2 83230D-06	
974	7 95077D+01	1 1 20132D-06	1 055000+00	0 0	0 0	0 0			2 1 24670D-07	25 1 07396D+00
		1 20132D-06	1 055000+00	0 0	0 0	0 0				
974	7 95077D+01	1 1 19478D-07	1 055000+00	0 0	0 0	0 0			11 8 43511D+01	13 8 53150D+01
		1 7 58237D+01	3 8 01507D+01	3 8 01507D+01	3 8 01507D+01	3 8 01507D+01			21 8 72030D+01	24 1 12923D+02
974	7 9507D+01	1 5 8 61597D+01	17 8 67945D+01	17 8 67945D+01	17 8 67945D+01	17 8 67945D+01				
		25 1 17352D+02	1 055000+00	0 0	0 0	0 0			1 4 97778D-06	
975	7 95465D+01	1 1 03502D-05	1 055000+00	0 0	0 0	0 0			2 1 91554D-07	25 1 07605D+00
		1 03502D-05	1 055000+00	0 0	0 0	0 0				
975	7 95465D+01	1 4 40277D-07	1 055000+00	0 0	0 0	0 0			11 8 43503D+01	13 8 53139D+01
		1 7 58236D+01	3 8 01503D+01	3 8 01503D+01	3 8 01503D+01	3 8 01503D+01				
975	7 9547D+01	1 7 58236D+01	17 8 67945D+01	17 8 67945D+01	17 8 67945D+01	17 8 67945D+01				

976	7.958580+01	15 B 615770+01	17 B 679140+01	19 B 710930+01	21 B 721030+01	24 1.139850+02
976	7.958580+01	25 1.184280+02		0.0		
976	7.958580+01	1 085700-05	1 055000+00	0.0	1 5.732130-06	24 9.391550-01
976	7.958580+01	2 1.046250-07	1 055000+00	0.0	2 2.132830-07	
976	7.958580+01	1 5.032230-07	1 055000+00	0.0	11 B 434960+01	25 1.078290+00
976	7.958580+01	1 7.582340+01	3 B 014990+01	5 B 177670+01	11 B 434960+01	13 B 531280+01
976	7.958580+01	15 B 615560+01	17 B 678830+01	19 B 710670+01	24 1.150550+02	
977	7.962550+01	25 1.195070+02		0.0		
977	7.962550+01	1 7.394010-06	1 055000+00	0.0	1 5.16270-06	24 9.380150-01
977	7.962550+01	1 7.394010-06	1 055000+00	0.0	2 6.008950-07	
977	7.962550+01	1 239670-06	1 055000+00	0.0	11 B 434880+01	13 B 531160+01
977	7.962550+01	1 7.582330+01	3 B 014950+01	5 B 177610+01	21 B 722580+01	24 1.161350+02
977	7.962550+01	15 B 615360+01	17 B 678510+01	19 B 710410+01		
978	7.966570+01	1 5.621360-06	1 055000+00	0.0	1 4.647750-06	
978	7.966570+01	1 5.621360-06	1 055000+00	0.0	2 5.107740-07	25 1.092860+00
978	7.966570+01	1 010450-06	1 055000+00	0.0	11 B 434800+01	13 B 531050+01
978	7.966570+01	1 7.582310+01	3 B 014900+01	5 B 177550+01	21 B 723420+01	24 1.172230+02
978	7.966570+01	15 B 615150+01	17 B 678190+01	19 B 710160+01		
979	7.970150+01	25 1.216840+02		0.0		
979	7.970150+01	1 4.634520-06	1 055000+00	0.0	1 4.277330-06	
979	7.970150+01	1 4.634520-06	1 055000+00	0.0	2 4.542910-07	25 1.102520+00
979	7.970150+01	1 8.646940-07	1 055000+00	0.0	11 B 434720+01	13 B 530930+01
979	7.97060+01	1 7.582300+01	3 B 014860+01	5 B 177490+01	21 B 724290+01	24 1.183220+02
979	7.97060+01	15 B 614940+01	17 B 677870+01	19 B 709920+01		
980	7.974770+01	25 1.227860+02		0.0		
980	7.974770+01	1 4.347750-06	1 055000+00	0.0	1 3.987480-06	
980	7.974770+01	1 4.347750-06	1 055000+00	0.0	2 4.498730-07	25 1.112770+00
980	7.974770+01	1 7.94360-07	1 055000+00	0.0	11 B 434630+01	13 B 530800+01
980	7.97480+01	1 7.582280+01	3 B 014810+01	5 B 177430+01	21 B 725200+01	24 1.194310+02
980	7.97480+01	15 B 614730+01	17 B 677540+01	19 B 709680+01		
981	7.978960+01	25 1.238930+02		0.0		
981	7.978960+01	1 4.138570-06	1 055000+00	0.0	1 3.711420-06	
981	7.978960+01	1 4.138570-06	1 055000+00	0.0	2 4.31140-07	25 1.123390+00
981	7.978960+01	1 8.397240-07	1 055000+00	0.0	11 B 434550+01	13 B 530680+01
981	7.97900+01	1 7.582270+01	3 B 014760+01	5 B 177370+01	21 B 726150+01	24 1.205510+02
981	7.97900+01	15 B 614510+01	17 B 677220+01	19 B 709450+01		
982	7.983200+01	25 1.250230+02		0.0		
982	7.983200+01	1 3.843210-06	1 055000+00	0.0	1 3.660790-06	
982	7.983200+01	1 3.843210-06	1 055000+00	0.0	2 4.048340-07	25 1.134360+00
982	7.983200+01	1 7.792460-07	1 055000+00	0.0	11 B 434460+01	13 B 530560+01
982	7.98320+01	1 7.582250+01	3 B 014710+01	5 B 177310+01	21 B 727140+01	24 1.216810+02
982	7.98320+01	15 B 614290+01	17 B 676890+01	19 B 709230+01		
983	7.987500+01	25 1.261570+02		0.0		
983	7.987500+01	1 4.041250-06	1 055000+00	0.0	1 3.692260-06	
983	7.987500+01	1 4.041250-06	1 055000+00	0.0	2 4.086880-07	25 1.145310+00
983	7.987500+01	1 8.003830-07	1 055000+00	0.0	11 B 434370+01	13 B 530430+01
983	7.98750+01	1 7.582230+01	3 B 014670+01	5 B 17250+01	21 B 728170+01	24 1.228220+02
983	7.98750+01	15 B 614060+01	17 B 676550+01	19 B 709010+01		
984	7.991850+01	25 1.273020+02		0.0		
984	7.991850+01	1 3.905880-06	1 055000+00	0.0	1 3.644070-06	
984	7.991850+01	1 3.905880-06	1 055000+00	0.0	2 3.982150-07	25 1.156480+00
984	7.991850+01	1 7.897670-07	1 055000+00	0.0	11 B 434220+01	13 B 530300+01
984	7.99190+01	1 7.582210+01	3 B 014510+01	5 B 177160+01	21 B 729240+01	24 1.239730+02
984	7.99190+01	15 B 613840+01	17 B 676220+01	19 B 708810+01		
985	7.995930+01	25 1.284590+02		0.0		
985	7.995930+01	1 3.49070-06	1 055000+00	0.0	1 2.117930-06	
985	7.995930+01	1 3.49070-06	1 055000+00	0.0	2 1.609050-07	25 1.081030+00
985	7.995930+01	1 5.05660-07	1 055000+00	0.0	11 B 434200+01	13 B 530170+01
985	7.995930+01	1 7.582200+01	3 B 014570+01	5 B 177120+01	21 B 730270+01	24 1.250470+02
985	7.995930+01	15 B 613630+01	17 B 675910+01	19 B 708630+01		
986	8.000000+01	25 1.295400+02		0.0		
986	8.000000+01	1 2.17540-06	1 055000+00	0.0	1 2.046000-06	
986	8.000000+01	1 2.17540-06	1 055000+00	0.0	2 3.615430-07	25 1.076790+00
986	8.000000+01	1 7.19220-07	1 055000+00	0.0	11 B 434110+01	13 B 530050+01
986	8.000000+01	1 7.582180+01	3 B 014520+01	5 B 177060+01	21 B 730500+01	24 1.250470+02
986	8.000000+01	15 B 613400+01	17 B 675400+01	19 B 708400+01		

15 8 613410+01 17 8 675600+01 19 8 708450+01 21 8 731320+01 24 1 261170+02  
25 1 306170+02

HEATING6 02/12/83  
W9XNP110

CODPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

IBM3033/ 0  
20 58 27 11-16-89

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 986 TIME STEPS, TIME = 8.000000+01

CROSS GRID 1

FINE GRID 1

DISTANCE 0.0

1	1	0.0	75182
2	2	0.03	77198
3	3	0.06	80115
4	4	0.08	80196
5	5	0.10	81177
6	6	0.57	82121
7	7	1.04	82164
8	8	1.51	83107
9	9	1.98	83150
10	10	2.45	83192
11	11	2.92	84134
12	12	3.14	84183
13	13	3.35	85130
14	14	3.57	85174
15	15	3.79	86113
16	16	4.01	86148
17	17	4.23	86176
18	18	4.45	86196
19	19	4.67	87108
20	20	4.89	87117
21	21	5.10	87121
22	22	5.18	96108
23	23	5.25	108100
24	24	5.32	126112
25	25	5.35	130162

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	78.640000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 4.072721070-02

ELAPSED CPU TIME IS 11.90 SECONDS

THE MAXIMUM TEMPERATURE IS 1.30670+02 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES 25

THE MINIMUM TEMPERATURE IS 7.582180+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES 1



NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	NODE	MAX PERCENT TEMP CHANGE	
987	8.00450+01	1	1.758216D+01	1.05500D+00	3.80170D+01	5.817699D+01	11.84340D+01	13	8.52991D+01				
			15.861318D+01	1.05500D+00	17.86746D+01	19.870828D+01	21.873250D+01	24	1.27290D+02				
			25.131794D+02	1.05500D+00	0.0	0.0	0.0						
988	8.00906D+01	1	1.80634D-06	1.05500D+00	0.0	0.0	0.0	1	3.26811D-06		24	9.37763D-01	
			1.80634D-06	1.05500D+00	0.0	0.0	0.0	2	2.77005D-07	25	1.20020D+00	24	9.37763D-01
			1.51013D-07	1.05500D+00	0.0	0.0	0.0	11	8.43392D+01	13	8.52977D+01		
			1.758214D+01	1.05500D+00	3.801441D+01	5.817692D+01	11.843392D+01	21	8.73374D+01	24	1.28483D+02		
			15.861294D+01	1.05500D+00	17.867492D+01	19.870811D+01	21.873374D+01	24	1.28483D+02				
			25.132994D+02	1.05500D+00	0.0	0.0	0.0						
989	8.01369D+01	1	2.38591D-06	1.05500D+00	0.0	0.0	0.0	1	3.32751D-06		24	9.37957D-01	
			2.38591D-06	1.05500D+00	0.0	0.0	0.0	2	2.89420D-07	25	1.21298D+00	24	9.37957D-01
			1.57837D-07	1.05500D+00	0.0	0.0	0.0	11	5.43382D+01	13	8.52963D+01		
			1.758212D+01	1.05500D+00	3.801436D+01	5.817685D+01	11.843382D+01	21	8.72502D+01	24	1.29689D+02		
			15.861270D+01	1.05500D+00	17.867457D+01	19.870796D+01	21.873502D+01	24	1.29689D+02				
			25.134207D+02	1.05500D+00	0.0	0.0	0.0						
990	8.01839D+01	1	3.10426D-06	1.05500D+00	0.0	0.0	0.0	1	3.42483D-06		24	9.36173D-01	
			3.10426D-06	1.05500D+00	0.0	0.0	0.0	2	2.26554D-07	25	1.22532D+00	24	9.36173D-01
			1.690942D-07	1.05500D+00	0.0	0.0	0.0	11	8.48372D+01	13	8.52990D+01		
			1.758210D+01	1.05500D+00	3.801430D+01	5.817678D+01	11.843372D+01	21	8.75334D+01	24	1.30150D+02		
			15.861245D+01	1.05500D+00	17.867423D+01	19.870782D+01	21.873534D+01	24	1.30150D+02				
			25.135433D+02	1.05500D+00	0.0	0.0	0.0						
991	8.02314D+01	1	3.85645D-06	1.05500D+00	0.0	0.0	0.0	1	3.57446D-06		24	9.36257D-01	
			3.85645D-06	1.05500D+00	0.0	0.0	0.0	2	3.52567D-07	25	1.23107D+00	24	9.36257D-01
			1.756004D-07	1.05500D+00	0.0	0.0	0.0	11	8.43361D+01	13	8.52934D+01		
			1.758208D+01	1.05500D+00	3.801424D+01	5.817670D+01	11.843361D+01	21	8.73771D+01	24	1.27133D+02		
			15.861220D+01	1.05500D+00	17.867388D+01	19.870769D+01	21.873771D+01	24	1.27133D+02				
			25.136670D+02	1.05500D+00	0.0	0.0	0.0						
992	8.02796D+01	1	4.11537D-06	1.05500D+00	0.0	0.0	0.0	1	3.6733D-06		24	9.38250D-01	
			4.11537D-06	1.05500D+00	0.0	0.0	0.0	2	3.71071D-07	25	1.24872D+00	24	9.38250D-01
			1.821172D-07	1.05500D+00	0.0	0.0	0.0	11	8.43351D+01	13	8.52919D+01		
			1.758206D+01	1.05500D+00	3.801418D+01	5.817662D+01	11.843351D+01	21	8.73913D+01	24	1.33373D+02		
			15.861195D+01	1.05500D+00	17.867353D+01	19.870757D+01	21.873913D+01	24	1.33373D+02				
			25.137918D+02	1.05500D+00	0.0	0.0	0.0						
993	8.03283D+01	1	4.33474D-06	1.05500D+00	0.0	0.0	0.0	1	3.76797D-06		24	9.39225D-01	
			4.33474D-06	1.05500D+00	0.0	0.0	0.0	2	3.82703D-07	25	1.26038D+00	24	9.39225D-01
			1.855619D-07	1.05500D+00	0.0	0.0	0.0	11	8.43340D+01	13	8.52904D+01		
			1.758204D+01	1.05500D+00	3.801412D+01	5.817655D+01	11.843340D+01	21	8.74059D+01	24	1.34625D+02		
			15.861170D+01	1.05500D+00	17.867318D+01	19.870747D+01	21.874059D+01	24	1.34625D+02				
			25.139179D+02	1.05500D+00	0.0	0.0	0.0						
994	8.03776D+01	1	4.32593D-06	1.05500D+00	0.0	0.0	0.0	1	3.81981D-06		24	9.38209D-01	
			4.32593D-06	1.05500D+00	0.0	0.0	0.0	2	3.79980D-07	25	1.27221D+00	24	9.38209D-01
			1.844206D-07	1.05500D+00	0.0	0.0	0.0	11	8.43329D+01	13	8.52888D+01		
			1.758202D+01	1.05500D+00	3.801406D+01	5.817647D+01	11.843329D+01	21	8.74209D+01	24	1.35898D+02		
			15.861144D+01	1.05500D+00	17.867283D+01	19.870738D+01	21.874209D+01	24	1.35898D+02				
			25.140451D+02	1.05500D+00	0.0	0.0	0.0						
995	8.04276D+01	1	4.52189D-06	1.05500D+00	0.0	0.0	0.0	1	3.50510D-06		24	9.38169D-01	
			4.52189D-06	1.05500D+00	0.0	0.0	0.0	2	3.94963D-07	25	1.28412D+00	24	9.38169D-01
			1.833948D-07	1.05500D+00	0.0	0.0	0.0	11	8.43318D+01	13	8.52872D+01		
			1.758200D+01	1.05500D+00	3.801400D+01	5.817639D+01	11.843318D+01	21	8.74365D+01	24	1.37152D+02		
			15.861118D+01	1.05500D+00	17.867248D+01	19.870731D+01	21.874365D+01	24	1.37152D+02				
			25.141735D+02	1.05500D+00	0.0	0.0	0.0						
996	8.04782D+01	1	4.67668D-06	1.05500D+00	0.0	0.0	0.0	1	3.98055D-06		24	9.38139D-01	
			4.67668D-06	1.05500D+00	0.0	0.0	0.0	2	3.99139D-07	25	1.29610D+00	24	9.38139D-01
			1.895844D-07	1.05500D+00	0.0	0.0	0.0	11	8.43300D+01	13	8.52865D+01		
			1.758197D+01	1.05500D+00	3.801393D+01	5.817630D+01	11.843300D+01	21	8.74365D+01	24	1.38169D+02		
			25.143161D+02	1.05500D+00	0.0	0.0	0.0						

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
 NODE NUMBERS AND TEMPERATURES





15 R 50315D+01 17 P 1 19 8 713250+01 21 8 802260+01 24 1 62081D+02  
25 1 725310+02

HEATING6 02/12/83  
W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

18M0033/ 0  
20 58 28 11-16-89

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 1018 TIME STEPS, TIME = 8.200000E+01

GROSS GRID	1
FINE GRID	1
DISTANCE	0.0
1	0.0
2	0.03
3	0.06
4	0.08
5	0.10
6	0.57
7	1.04
8	1.51
9	1.98
10	2.45
11	2.92
12	3.14
13	3.35
14	3.57
15	3.79
16	4.01
17	4.23
18	4.45
19	4.67
20	4.89
21	5.10
22	5.18
23	5.25
24	5.32
25	5.35

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	82.670000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 9.40772568E-02

ELAPSED CPU TIME IS 12.23 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.72531E+02 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 25

THE MINIMUM TEMPERATURE IS - 7.58121E+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (-JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	NODE MAX PERCENT TEMP CHANGE
1019 8.210250+01	1 1 079050-04	1 055000+00	0 0	0 0	0 0	11 8 428970+01	13 8 523060+01	24 1 421060+00	24 8 804600-01	
1019 8.210350+01	3 1 739200-06	1 055000+00	0 0	0 0	0 0	21 8 806440+01	24 1 705020+02			
1019 8.210250+01	2 2 403440-06	1 055000+00	0 0	0 0	0 0					

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
 \*\*\*\*\* NODE NUMBERS AND TEMPERATURES \*\*\*\*\*

NUMBER OF TIME STEPS

1019 8.21030+01	1 7 581160+01	3 8 011600+01	17 8 663670+01	5 8 173310+01	11 8 428970+01	13 8 523060+01				
	15 8 602670+01	17 8 663670+01	19 8 714160+01	19 8 714160+01	21 8 806440+01	24 1 705020+02				
	25 1 738780+02									
1020 8.22170+01	1 1 066400-04	1 055000+00	0 0	0 0	0 0	1 6 068560-05				
1020 8.22170+01	3 1 990070-06	1 055000+00	0 0	0 0	0 0	2 2 458350-06	24 1 495380+00	24 8 770430-01		
1020 8.22170+01	2 2 740470-06	1 055000+00	0 0	0 0	0 0					
1020 8.22170+01	1 7 581090+01	3 8 011410+01	17 8 663320+01	5 8 173080+01	11 8 428660+01	13 8 522650+01				
	15 8 602130+01	17 8 663320+01	19 8 715220+01	19 8 715220+01	21 8 811040+01	24 1 719970+02				
	25 1 753150+02									
1021 8.23405+01	1 1 080400-04	1 055000+00	0 0	0 0	0 0	1 5 923790-05				
1021 8.23405+01	3 2 188260-06	1 055000+00	0 0	0 0	0 0	2 2 349140-06	24 1 558270+00	24 9 058840-01		
1021 8.23405+01	2 2 930450-06	1 055000+00	0 0	0 0	0 0					
1021 8.23410+01	1 7 581030+01	3 8 011210+01	17 8 662970+01	5 8 172830+01	11 8 428310+01	13 8 522210+01				
	15 8 601560+01	17 8 662970+01	19 8 716450+01	19 8 716450+01	21 8 815990+01	24 1 735560+02				
	25 1 768300+02									
1022 8.246990+01	1 8 486890-05	1 055000+00	0 0	0 0	0 0	1 5 301830-05				
1022 8.246990+01	3 1 592410-06	1 055000+00	0 0	0 0	0 0	2 1 955590-06	24 1 583000+00	24 9 121030-01		
1022 8.246990+01	2 2 605120-06	1 055000+00	0 0	0 0	0 0					
1022 8.24700+01	1 7 580950+01	3 8 011000+01	17 8 662650+01	5 8 172560+01	11 8 427950+01	13 8 521750+01				
	15 8 600970+01	17 8 662650+01	19 8 717810+01	19 8 717810+01	21 8 821160+01	24 1 751390+02				
	25 1 783850+02									
1023 8.260450+01	1 2 584730-04	1 055000+00	0 0	0 0	0 0	1 6 836710-05				
1023 8.260450+01	3 7 768870-06	1 055000+00	0 0	0 0	0 0	2 5 474090-06	24 1 588530+00	24 9 070150-01		
1023 8.260450+01	2 7 645160-06	1 055000+00	0 0	0 0	0 0					
1023 8.26050+01	1 7 580870+01	3 8 010780+01	17 8 662370+01	5 8 172270+01	11 8 427560+01	13 8 521260+01				
	15 8 600370+01	17 8 662370+01	19 8 719300+01	19 8 719300+01	21 8 826500+01	24 1 767270+02				
	25 1 799170+02									
1024 8.274560+01	1 6 755130-04	1 055000+00	0 0	0 0	0 0	1 1 186680-04				
1024 8.274560+01	4 1 889880-06	1 055000+00	0 0	0 0	0 0	2 1 72320-05				
1024 8.274560+01	3 3 866100-06	1 055000+00	0 2	0 0	0 0	3 2 953160-06	24 1 538430+00	24 8 705120-01		
1024 8.274560+01	2 3 490640-06	1 055000+00	0 0	0 0	0 0					
1024 8.27460+01	1 7 580790+01	3 8 010540+01	17 8 662120+01	5 8 171970+01	11 8 427150+01	13 8 520750+01				
	15 8 599750+01	17 8 662120+01	19 8 720950+01	19 8 720950+01	21 8 837040+01	24 1 782660+02				
	25 1 813060+02									
1025 8.289960+01	1 2 832190-04	1 055000+00	0 0	0 0	0 0	1 1 024520-04				
1025 8.289960+01	3 7 520680-06	1 055000+00	0 0	0 0	0 0	2 6 837090-06	24 1 520800+00	24 8 531100-01		
1025 8.289960+01	3 2 243750-06	1 055000+00	0 0	0 0	0 0					
1025 8.29000+01	1 7 580700+01	3 8 010280+01	17 8 661720+01	5 8 171640+01	11 8 426700+01	13 8 520200+01				
	15 8 599090+01	17 8 661720+01	19 8 722840+01	19 8 722840+01	21 8 838030+01	24 1 797860+02				
	25 1 827280+02									
1026 8.306890+01	1 3 185360-04	1 055000+00	0 0	0 0	0 0	1 1 026000-04				
1026 8.306890+01	4 7 270130-07	1 055000+00	0 0	0 0	0 0	2 7 029180-06	24 1 547240+00	24 8 606000-01		
1026 8.306890+01	3 2 892360-06	1 055000+00	0 0	0 0	0 0					
1026 8.30690+01	1 7 580600+01	3 8 009980+01	17 8 661760+01	5 8 171270+01	11 8 426240+01	13 8 519580+01				
	15 8 598400+01	17 8 661760+01	19 8 725010+01	19 8 725010+01	21 8 844540+01	24 1 813240+02				
	25 1 842030+02									
1027 8.325510+01	1 2 725110-04	1 055000+00	0 0	0 0	0 0	1 9 534280-05				
1027 8.325510+01	4 4 814790-07	1 055000+00	0 0	0 0	0 0	2 6 018880-06	24 1 597460+00	24 8 809510-01		
1027 8.325510+01	3 2 972520-06	1 055000+00	0 0	0 0	0 0					
1027 8.32550+01	1 7 580490+01	3 8 009650+01	17 8 661680+01	5 8 170850+01	11 8 425650+01	13 8 518920+01				
	15 8 597660+01	17 8 661680+01	19 8 727500+01	19 8 727500+01	21 8 851580+01	24 1 829310+02				
	25 1 857530+02									
1028 8.345600+01	1 2 176800-04	1 055000+00	0 0	0 0	0 0	1 8 156790-05				
1028 8.345600+01	3 9 684460-06	1 055000+00	0 0	0 0	0 0	2 5 022370-06	24 1 643400+00	24 8 983690-01		
1028 8.345600+01	3 2 724920-06	1 055000+00	0 0	0 0	0 0					

1028	8 34560+01	1 7 580360+01	3 8 009300+01	5 8 170400+01	11 8 425040+01	13 8 518180+01
		15 8 596900+01	17 8 661630+01	19 8 730310+01	21 8 859030+01	24 1 845750+02
		25 1 873730+02				
1029	8 366840+01	1 2 652660-04	1 055000+00	0 0 0 0	1 7 404400-05	
1029	8 366840+01	4 1 579840-07	1 055000+00	0 0 0 0	2 5 622510-06	24 1 672800+00
1029	8 366840+01	3 3 551420-06	1 055000+00	0 0 0 0	11 8 424400+01	13 8 517430+01
1029	8 366840+01	1 7 580230+01	3 8 008910+01	5 8 169910+01	21 8 866760+01	24 1 862470+02
		15 8 596140+01	17 8 661810+01	19 8 733390+01		
		25 1 890270+02				
1030	8 383420+01	1 1 167940-04	1 055000+00	0 0 0 0	1 4 175570-05	
1030	8 383420+01	3 4 260190-06	1 055000+00	0 0 0 0	2 2 566860-06	24 1 266140+00
1030	8 383420+01	2 4 779560-06	1 055000+00	0 0 0 0	11 8 423890+01	13 8 516840+01
1030	8 383420+01	1 7 580110+01	3 8 008510+01	5 8 169530+01	21 8 872680+01	24 1 875140+02
		15 8 595570+01	17 8 661980+01	19 8 735860+01		
		25 1 902850+02				
1031	8 400000+01	1 1 332470-04	1 055000+00	0 0 0 0	1 3 437210-05	
1031	8 400000+01	3 5 069400-05	1 055000+00	0 0 0 0	2 2 872090-06	24 1 232670+00
1031	8 400000+01	2 5 340590-06	1 055000+00	0 0 0 0	11 8 423380+01	13 8 516250+01
1031	8 400000+01	1 7 580000+01	3 8 008300+01	5 8 169140+01	21 8 878510+01	24 1 867460+02
		15 8 595040+01	17 8 662220+01	19 8 738390+01		
		25 1 915050+02				

HEATING6 02/12/83  
W9XMP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

TRM0033/ 0  
20 58.29 11-16-89

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 1031 TIME STEPS. TIME = 8.400000+01

GROSS GRID 1

FINE GRID 1

	FINE GRID	DISTANCE	0.0
1	1	0.0	75180
2	2	0.03	77194
3	3	0.06	80108
4	4	0.08	80189
5	5	0.10	81169
6	6	0.57	82113
7	7	1.04	82157
8	8	1.51	82199
9	9	1.98	83141
10	10	2.45	83183
11	11	2.92	84123
12	12	3.14	84171
13	13	3.35	85116
14	14	3.57	85157
15	15	3.79	85175
16	16	4.01	86129
17	17	4.23	86162
18	18	4.45	86197
19	19	4.67	87138
20	20	4.89	87196
21	21	5.10	88179
22	22	5.18	120181
23	23	5.25	153185
24	24	5.32	188175
25	25	5.35	191151

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	87.300000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA T) = 1.65814604D-01

ELAPSED CPU TIME IS 12.41 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.91505D+02 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 25

THE MINIMUM TEMPERATURE IS - 7.58000D+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1



NO TIME	MD ITER	MAX HEAT RESIDUAL	BETA	1.1 NORM OF TEMP DIFF	RMS (ITERATION)	RMS (JACOBI)	NO ITER	1.1 NORM OF MODE TEMP DIFF	MAX TEMP CHANGE	MODE TEMP CHANGE	MAX PERCENT TEMP CHANGE
1032	8	418240+01	1 1 387670-04	1 055000+00	0 0	0 0	1 3	539530-05	24 1 316620+00	24 6 975600-01	
1032	8	418240+01	3 5 792740-06	1 055000+00	0 0	0 0	2 4	975610-06			
1032	8	418240+01	2 6 288220-06	1 055000+00	0 0	0 0	2 4	975610-06			

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NUMBER OF TIME STEPS	TIME	***** NODE NUMBERS AND TEMPERATURES	*****
1032	8	41820+01	1 7 529880+01 3 8 007960+01 5 8 168710+01 11 8 422810+01 13 8 515610+01 15 8 534480+01 17 8 562560+01 19 8 741220+01 21 8 884830+01 24 1 900630+02 25 1 928110+02
1033	8	438300+01	1 1 045100-04 1 055000+00 0 0 0 0 0 0 1 3 286530-05 1033 8 438300+01 3 4 713440-06 1 055000+00 0 0 0 0 0 0 2 5 520750-06 1 055000+00 0 0 0 0 0 0 2 2 319110-06 24 1 411440+00 24 7 426170-01 1033 8 438300+01 2 5 520750-06 1 055000+00 0 0 0 0 0 0 1 7 529750+01 3 8 007580+01 5 8 168240+01 11 8 422180+01 13 8 514910+01 15 8 533920+01 17 8 663010+01 19 8 744400+01 21 8 891690+01 24 1 514740+02 25 1 942210+02
1034	8	460370+01	1 1 046730-04 1 055000+00 0 0 0 0 0 0 1 3 081270-05 1034 8 460370+01 3 5 512260-06 1 055000+00 0 0 0 0 0 0 2 6 081050-06 1 055000+00 0 0 0 0 0 0 2 2 288970-06 25 1 528560+00 24 7 951700-01 1034 8 460370+01 2 6 081050-06 1 055000+00 0 0 0 0 0 0 1 7 529600+01 3 8 007160+01 5 8 167710+01 11 8 421490+01 13 8 514160+01 15 8 523240+01 17 8 663620+01 19 8 747960+01 21 8 892120+01 24 1 929970+02 25 1 957500+02
1035	8	484650+01	1 3 992940-03 1 055000+00 0 0 0 0 0 0 1 3 486970-04 1035 8 484650+01 4 5 179550-06 1 055000+00 0 0 0 0 0 0 4 1 338120-06 1 055000+00 0 0 0 0 0 0 3 2 450170-05 1035 8 484650+01 4 3 338120-07 1 055000+00 0 0 0 0 0 0 4 3 338120-07 1 055000+00 0 0 0 0 0 0 2 4 171620-05 1035 8 484650+01 3 4 417800-06 1 055000+00 0 0 0 0 0 0 4 5 461170-06 24 1 294240+00 23 6 912850-01 1035 8 48470+01 1 7 529440+01 3 8 006690+01 5 8 167130+01 11 8 420730+01 13 8 513340+01 15 8 522770+01 17 8 664390+01 19 8 751940+01 21 8 907160+01 24 1 942910+02 25 1 966420+02
1036	8	511350+01	1 1 012830-03 1 055000+00 0 0 0 0 0 0 1 2 685670-04 1036 8 511350+01 4 2 466800-06 1 055000+00 0 0 0 0 0 0 4 1 009700-06 1 055000+00 0 0 0 0 0 0 2 2 562720-05 1036 8 511350+01 3 6 436340-06 1 055000+00 0 0 0 0 0 0 3 6 436340-06 23 9 418280-01 23 5 961670-01 1036 8 51140+01 1 7 529270+01 3 8 006180+01 5 8 166490+01 11 8 419900+01 13 8 512460+01 15 8 522220+01 17 8 665380+01 19 8 756380+01 21 8 915820+01 24 1 951820+02 25 1 973980+02
1037	8	540730+01	1 1 253870-03 1 055000+00 0 0 0 0 0 0 1 2 414300-04 1037 8 540730+01 4 6 343530-06 1 055000+00 0 0 0 0 0 0 4 6 343530-06 1 055000+00 0 0 0 0 0 0 2 2 810340-05 1037 8 540730+01 4 1 995500-06 1 055000+00 0 0 0 0 0 0 3 8 621590-06 23 7 521330-01 23 4 732710-01 1037 8 540730+01 3 8 621590-06 1 055000+00 0 0 0 0 0 0 3 8 621590-06 1 055000+00 0 0 0 0 0 0 5 8 165780+01 13 8 511520+01 1037 8 54070+01 1 7 529070+01 3 8 005610+01 5 8 165780+01 11 8 418980+01 13 8 511520+01 15 8 591700+01 17 8 666620+01 19 8 761330+01 21 8 925040+01 24 1 959000+02 25 1 980020+02
1038	8	570360+01	1 3 320040-03 1 055000+00 0 0 0 0 0 0 1 3 671670-04 1038 8 570360+01 5 1 353040-06 1 055000+00 0 0 0 0 0 0 5 1 353040-06 1 055000+00 0 0 0 0 0 0 2 7 252950-05 1038 8 570360+01 4 5 342460-06 1 055000+00 0 0 0 0 0 0 4 1 547990-06 1 055000+00 0 0 0 0 0 0 3 2 083960-05 1038 8 570360+01 4 1 547990-06 1 055000+00 0 0 0 0 0 0 3 6 591390-06 1 055000+00 0 0 0 0 0 0 4 5 889570-06 23 5 061960-01 23 3 170170-01 1038 8 570360+01 3 6 591390-06 1 055000+00 0 0 0 0 0 0 1 7 578860+01 3 8 005040+01 5 8 165070+01 11 8 418070+01 13 8 510600+01 15 8 591260+01 17 8 668020+01 19 8 766370+01 21 8 933910+01 24 1 962210+02 25 1 980530+02
1039	8	600000+01	1 288860-02 1 055000+00 0 0 0 0 0 0 1 138490-03 1039 8 600000+01 5 5 253110-06 1 055000+00 0 0 0 0 0 0 5 5 253110-06 1 055000+00 0 0 0 0 0 0 2 2 816040-04 1039 8 600000+01 5 1 534860-06 1 055000+00 0 0 0 0 0 0 4 5 904180-06 1 055000+00 0 0 0 0 0 0 3 8 101540-05 1039 8 600000+01 4 1 701460-06 1 055000+00 0 0 0 0 0 0 4 2 31490-05 1039 8 600000+01 3 7 183690-06 1 055000+00 0 0 0 0 0 0 5 6 487830-06 25 2 123910+00 25 1 072390+00 1039 8 600000+01 3 7 183690-06 1 055000+00 0 0 0 0 0 0 1 242790-04 1 055000+00 0 0 0 0 0 0 1 2 715930-05 1039 8 596620+01 4 3 876680-07 1 055000+00 0 0 0 0 0 0 2 5 803990-06 1 055000+00 0 0 0 0 0 0 2 1 668620-06 25 1 897030+00 25 9 578370-01 1039 8 59660+01 1 7 578670+01 3 8 004540+01 5 8 154450+01 11 8 417270+01 13 8 509820+01



HEATING6 02/12/83  
W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

10M3033/ 0  
20 58.30 11-16-89

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 1040 TIME STEPS, TIME = B 600000+01

GROSS GRID 1

FINE GRID 1

	FINE GRID	DISTANCE	
1	1	0.0	75179
2	2	0.03	77192
3	3	0.06	80104
4	4	0.08	80185
5	5	0.10	81164
6	6	0.57	82108
7	7	1.04	82151
8	8	1.51	82192
9	9	1.98	83136
10	10	2.45	83177
11	11	2.92	84117
12	12	3.14	84165
13	13	3.35	85110
14	14	3.57	85151
15	15	3.79	85191
16	16	4.01	86129
17	17	4.23	86170
18	18	4.45	87115
19	19	4.67	87171
20	20	4.89	88145
21	21	5.10	89142
22	22	5.18	124177
23	23	5.25	160118
24	24	5.32	195109
25	25	5.35	195185

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	91.360000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 3.38225899D-02

ELAPSED CPU TIME IS 12.59 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.95847D+02 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 25

THE MINIMUM TEMPERATURE IS - 7.57862D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	1.1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	ITER	1.1 NORM OF TEMP DIFF	MODE CHANGE	MAX TEMP CHANGE	MODE MAX PERCENTY TEMP CHANGE
1041	8 60340+01		1 7 578590+01	3 8 004410+01	5 8 164290+01	11 8 417060+01	13 8 509620+01					
			15 8 590930+01	17 8 569740+01	19 8 772010+01	21 8 913180+01	24 1 948370+02					
			25 1 955380+02									
1042	8 606760+01		1 2 911850-06	1 055000+00	0 0	0 0	0 0					
			1 2 911850-06	1 055000+00	0 0	0 0	0 0					
			1 2 455730-07	1 055000+00	0 0	0 0	0 0					
1042	8 605760-01		1 7 578560+01	3 8 003340+01	5 8 164210+01	11 8 416960+01	13 8 505520+01					
			15 8 590960+01	17 8 569920+01	19 8 772580+01	21 8 914090+01	24 1 945730+02					
			25 1 952280+02									
1043	8 610150+01		1 2 425030-06	1 055000+00	0 0	0 0	0 0					
			1 2 425030-06	1 055000+00	0 0	0 0	0 0					
			1 2 369250-07	1 055000+00	0 0	0 0	0 0					
1043	8 610150+01		1 7 578540+01	3 8 004270+01	5 8 164130+01	11 8 416860+01	13 8 509430+01					
			15 8 590870+01	17 8 570110+01	19 8 773170+01	21 8 914980+01	24 1 943010+02					
			25 1 949150+02									
1044	8 613870+01		1 2 791860-06	1 055000+00	0 0	0 0	0 0					
			1 2 791860-06	1 055000+00	0 0	0 0	0 0					
			1 2 738100-07	1 055000+00	0 0	0 0	0 0					
1044	8 613870+01		1 7 578510+01	3 8 004200+01	5 8 164040+01	11 8 416740+01	13 8 509320+01					
			15 8 590840+01	17 8 570320+01	19 8 773800+01	21 8 915960+01	24 1 939940+02					
			25 1 945680+02									
1045	8 617960+01		1 3 387490-06	1 055000+00	0 0	0 0	0 0					
			1 3 387490-06	1 055000+00	0 0	0 0	0 0					
			1 4 881990-07	1 055000+00	0 0	0 0	0 0					
1045	8 617960+01		1 7 578460+01	3 8 004120+01	5 8 163940+01	11 8 416620+01	13 8 509200+01					
			15 8 590810+01	17 8 570550+01	19 8 774500+01	21 8 917010+01	24 1 936470+02					
			25 1 941820+02									
1046	8 622460+01		1 4 125490-06	1 055000+00	0 0	0 0	0 0					
			1 4 125490-06	1 055000+00	0 0	0 0	0 0					
			1 7 547310-07	1 055000+00	0 0	0 0	0 0					
1046	8 622460+01		1 7 578450+01	3 8 004030+01	5 8 163830+01	11 8 416400+01	13 8 509080+01					
			15 8 590780+01	17 8 570800+01	19 8 775270+01	21 8 918150+01	24 1 932570+02					
			25 1 937530+02									
1047	8 627410+01		1 5 030930-06	1 055000+00	0 0	0 0	0 0					
			1 5 030930-06	1 055000+00	0 0	0 0	0 0					
			1 1 021940-06	1 055000+00	0 0	0 0	0 0					
1047	8 627410+01		1 7 578410+01	3 8 003940+01	5 8 163720+01	11 8 416340+01	13 8 508940+01					
			15 8 590740+01	17 8 571090+01	19 8 776110+01	21 8 919370+01	24 1 928180+02					
			25 1 937750+02									
1048	8 632860+01		1 6 141470-06	1 055000+00	0 0	0 0	0 0					
			1 6 141470-06	1 055000+00	0 0	0 0	0 0					
			1 1 341100-06	1 055000+00	0 0	0 0	0 0					
1048	8 632860+01		1 7 578370+01	3 8 003830+01	5 8 163590+01	11 8 416170+01	13 8 508790+01					
			15 8 590710+01	17 8 571400+01	19 8 777040+01	21 8 950680+01	24 1 923240+02					
			25 1 927420+02									
1049	8 638850+01		1 7 495730-06	1 055000+00	0 0	0 0	0 0					
			1 7 495730-06	1 055000+00	0 0	0 0	0 0					
			1 1 686920-06	1 055000+00	0 0	0 0	0 0					
1049	8 638850+01		1 7 578330+01	3 8 003710+01	5 8 163450+01	11 8 416000+01	13 8 508620+01					
			15 8 590680+01	17 8 571760+01	19 8 778050+01	21 8 952090+01	24 1 917710+02					
			25 1 921490+02									
1050	8 645440+01		1 9 114070-06	1 055000+00	0 0	0 0	0 0					
			1 9 114070-06	1 055000+00	0 0	0 0	0 0					
			1 2 062540-06	1 055000+00	0 0	0 0	0 0					
1050	8 645440+01		1 7 578290+01	3 8 003590+01	5 8 163290+01	11 8 415800+01	13 8 508440+01					
			15 8 590580+01	17 8 571760+01	19 8 778050+01	21 8 952090+01	24 1 917710+02					
			25 1 921490+02									

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NUMBER OF TIME

TIME STEPS

1041

1042

1043

1044

1045

1046

1047

1048

1049

1050





HEATING6 02/12/83  
W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

IBM3033/ 0  
20 58 31 11 16-89

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 1065 TIME STEPS, TIME = 8.800000+01

GROSS GRID	1
FINE GRID	1
DISTANCE	O O
1	75177
2	77189
3	80101
4	80180
5	81160
6	82103
7	82146
8	82189
9	83120
10	83171
11	84112
12	84159
13	85105
14	85148
15	85191
16	86135
17	86183
18	87127
19	88103
20	88182
21	89173
22	119112
23	146182
24	170182
25	169156

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	93 690000
2	0 0
3	73 400000

THE CURRENT TIME STEP (DELTA) = 8.822122500-02

ELAPSED CPU TIME IS 12.91 SECONDS

THE MAXIMUM TEMPERATURE IS - 1.708190+02 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 24

THE MINIMUM TEMPERATURE IS - 7.577280+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RND (ITERATION)	END (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	MODE	MAX PERCENT TEMP CHANGE
1065	8 808820+01	1 7 118180-05	1 055000+00	0 0	0 0	0 0					
1066	8 808820+01	2 7 286800-06	1 055000+00	0 0	0 0	0 0	1 3 911270-05				
1066	8 808820+01	2 1 212020-05	1 055000+00	0 0	0 0	0 0	2 2 041310-06	25 1 711820+00	25 1 009540+00		
1066	8 808300+01	1 1 362620-05	1 055000+00	0 0	0 0	0 0					
1065	8 808300+01	2 1 525920-06	1 055000+00	0 0	0 0	0 0	1 2 508420-06				
1066	8 808300+01	1 1 465290-06	1 055000+00	0 0	0 0	0 0	2 2 771140-07	25 1 617450+00	25 9 538830-01		

TABLE FOR SPECIAL MONITORING OF TEMPERATURES  
 \*\*\*\*\* NODE NUMBERS AND TEMPERATURES \*\*\*\*\*

NUMBER OF TIME STEPS	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RND (ITERATION)	END (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	MODE	MAX PERCENT TEMP CHANGE
1066	8 80830+01	1 7 577230+01	3 8 000650+01	17 8 683130+01	5 8 159710+01	11 8 411350+01	11 8 411350+01	13 8 504720+01	24 1 693020+02			
		15 8 591250+01	17 8 683130+01	19 8 804040+01	19 8 804040+01	19 8 804040+01	19 8 804040+01	19 8 804040+01	19 8 804040+01			
		25 1 679470+02										
1067	8 81660+01	1 3 401510-05	1 055000+00	0 0	0 0	0 0						
1067	8 81660+01	2 2 864550-06	1 055000+00	0 0	0 0	0 0	1 3 071820-05					
1067	8 81660+01	1 5 189890-06	1 055000+00	0 0	0 0	0 0	2 9 334310-07	25 1 640600+00	25 9 768520-01			
1067	8 81660+01	1 7 577180+01	3 8 000510+01	17 8 683130+01	5 8 159540+01	11 8 411150+01	11 8 411150+01	13 8 504570+01				
		15 8 591350+01	17 8 683130+01	19 8 805100+01	19 8 805100+01	19 8 805100+01	19 8 805100+01	19 8 805100+01	19 8 805100+01			
		25 1 663070+02										
1068	8 824910+01	1 3 835410-05	1 055000+00	0 0	0 0	0 0						
1068	8 824910+01	2 3 542360-06	1 055000+00	0 0	0 0	0 0	1 2 818560-05					
1068	8 824910+01	1 5 330410-06	1 055000+00	0 0	0 0	0 0	2 9 580330-07	25 1 664200+00	25 1 000680+00			
1068	8 82490+01	1 1 055480-05	1 055000+00	0 0	0 0	0 0						
1068	8 82490+01	2 1 154380-06	1 055000+00	0 0	0 0	0 0	1 1 806240-06					
1068	8 82490+01	1 9 956460-07	1 055000+00	0 0	0 0	0 0	2 2 058170-07	25 1 585120+00	25 9 531340-01			
1068	8 82450+01	1 7 577130+01	3 8 000380+01	17 8 684290+01	5 8 159330+01	11 8 410950+01	11 8 410950+01	13 8 504430+01				
		15 8 594440+01	17 8 684290+01	19 8 806070+01	19 8 806070+01	19 8 806070+01	19 8 806070+01	19 8 806070+01	19 8 806070+01			
		25 1 647210+02										
1069	8 832370+01	1 2 216140-05	1 055000+00	0 0	0 0	0 0						
1069	8 832370+01	2 1 853690-06	1 055000+00	0 0	0 0	0 0	1 2 324310-05					
1069	8 832370+01	1 3 234880-06	1 055000+00	0 0	0 0	0 0	2 6 074890-07	25 1 601060+00	25 9 719820-01			
1069	8 83240+01	1 7 577090+01	3 8 000260+01	17 8 684550+01	5 8 159230+01	11 8 410770+01	11 8 410770+01	13 8 504300+01				
		15 8 591540+01	17 8 684550+01	19 8 807020+01	19 8 807020+01	19 8 807020+01	19 8 807020+01	19 8 807020+01	19 8 807020+01			
		25 1 631200+02										
1070	8 840250+01	1 2 607110-05	1 055000+00	0 0	0 0	0 0						
1070	8 840250+01	2 2 416330-06	1 055000+00	0 0	0 0	0 0	1 2 168270-05					
1070	8 840250+01	1 3 527620-06	1 055000+00	0 0	0 0	0 0	2 6 653080-07	25 1 617810+00	25 9 917910-01			
1070	8 84020+01	1 7 577040+01	3 8 000130+01	17 8 685420+01	5 8 159080+01	11 8 410580+01	11 8 410580+01	13 8 504160+01				
		15 8 591650+01	17 8 685420+01	19 8 807950+01	19 8 807950+01	19 8 807950+01	19 8 807950+01	19 8 807950+01	19 8 807950+01			
		25 1 615030+02										
1071	8 848130+01	1 2 584560-05	1 055000+00	0 0	0 0	0 0						
1071	8 848130+01	2 2 437150-06	1 055000+00	0 0	0 0	0 0	1 2 021120-05					
1071	8 848130+01	1 3 332040-06	1 055000+00	0 0	0 0	0 0	2 6 374220-07	25 1 633930+00	25 1 011710+00			
1071	8 847650+01	1 1 152020-05	1 055000+00	0 0	0 0	0 0						
1071	8 847650+01	2 1 173240-06	1 055000+00	0 0	0 0	0 0	1 2 137910-06					
1071	8 847650+01	1 1 148310-06	1 055000+00	0 0	0 0	0 0	2 2 435950-07	25 1 540210+00	25 9 536760-01			
1071	8 84760+01	1 7 576990+01	3 8 000010+01	17 8 685950+01	5 8 158930+01	11 8 410410+01	11 8 410410+01	13 8 504040+01				
		15 8 591750+01	17 8 685950+01	19 8 808790+01	19 8 808790+01	19 8 808790+01	19 8 808790+01	19 8 808790+01	19 8 808790+01			
		25 1 599620+02										
1072	8 855050+01	1 1 957550-05	1 055000+00	0 0	0 0	0 0						
1072	8 855050+01	2 1 657710-06	1 055000+00	0 0	0 0	0 0	1 1 749430-05					
1072	8 855050+01	1 2 506900-06	1 055000+00	0 0	0 0	0 0	2 5 068110-07	25 1 553870+00	25 9 713860-01			
1072	8 85500+01	1 7 576950+01	3 7 999890+01	17 8 686470+01	5 8 158790+01	11 8 410240+01	11 8 410240+01	13 8 503920+01				
		15 8 591860+01	17 8 686470+01	19 8 809610+01	19 8 809610+01	19 8 809610+01	19 8 809610+01	19 8 809610+01	19 8 809610+01			
		25 1 584080+02										
1073	8 862450+01	1 5 297580-05	1 055000+00	0 0	0 0	0 0						
1073	8 862450+01	2 5 035030-06	1 055000+00	0 0	0 0	0 0	1 2 244110-05					
1073	8 862450+01	1 5 718890-06	1 055000+00	0 0	0 0	0 0	2 1 190560-06	25 1 584460+00	25 1 000230+00			
1073	8 862080+01	1 8 847150-06	1 055000+00	0 0	0 0	0 0						
1073	8 862080+01	1 8 847150-06	1 055000+00	0 0	0 0	0 0	1 1 809020-06					
1073	8 862080+01	1 1 412730-06	1 055000+00	0 0	0 0	0 0	2 4 759850-07	25 1 509430+00	25 9 529130-01			
1073	8 86210+01	1 7 576910+01	3 7 999780+01	17 8 686660+01	5 8 158660+01	11 8 410080+01	11 8 410080+01	13 8 503820+01				



1074	8	869110+01	1	2	239080-05	1	055000+00	0	0	0	0	0	0	1	1	791770-05	25	9	725200-01
1074	8	869110+01	2	1	942300-06	1	055000+00	0	0	0	0	0	0	2	5	927760-07	25	9	525870+00
1074	8	869110+01	2	728960-06	1	055000+00	0	0	0	0	0	0	0	11	8	409920+01	13	8	503710+01
1074	8	869110+01	3	7	576870+01	3	7	999670+01	0	0	0	0	0	5	8	158530-01	21	8	971630+01
1074	8	869110+01	15	8	592070+01	17	8	687470+01	0	0	0	0	0	19	8	811100+01	21	8	971630+01
1074	8	869110+01	25	1	553730+01	0	0	0	0	0	0	0	0	1	1	700140-05	25	9	920330-01
1075	8	876140+01	1	2	192830-05	1	055000+00	0	0	0	0	0	0	2	5	645950-07	25	9	541350+00
1075	8	876140+01	2	1	858620-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1075	8	876140+01	2	606510-06	1	055000+00	0	0	0	0	0	0	0	11	8	409750+01	13	8	503670+01
1075	8	876140+01	1	7	576830+01	3	7	999570+01	0	0	0	0	0	5	8	158400+01	21	8	971150+01
1075	8	876140+01	15	8	592180+01	17	8	687970+01	0	0	0	0	0	19	8	811820+01	21	8	971150+01
1075	8	876140+01	25	1	538320+02	0	0	0	0	0	0	0	0	1	1	622250-05	25	9	558090+02
1076	8	883170+01	1	2	094570-05	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1076	8	883170+01	2	1	760460-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1076	8	883170+01	2	457870-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0
1076	8	883170+01	1	9	257540-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1076	8	882740+01	1	9	257540-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1076	8	882740+01	1	9	257540-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1076	8	882740+01	1	404290-06	1	055000+00	0	0	0	0	0	0	0	5	8	158280+01	11	8	409620+01
1076	8	882740+01	1	1	757670+01	3	7	999460+01	0	0	0	0	0	21	8	970630+01	24	1	544030+02
1076	8	882740+01	15	8	592290+01	17	8	688440+01	0	0	0	0	0	19	8	812460+01	21	8	970630+01
1076	8	882740+01	25	1	523650+02	0	0	0	0	0	0	0	0	1	1	327030-05	25	9	685260-01
1077	8	889340+01	1	1	030440-05	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1077	8	889340+01	2	1	054070-06	1	055000+00	0	0	0	0	0	0	2	3	155260-07	25	9	475700+00
1077	8	889340+01	1	1	407800-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1077	8	889340+01	1	1	407800-06	1	055000+00	0	0	0	0	0	0	5	8	158160+01	11	8	409340+01
1077	8	889340+01	1	7	576760+01	3	7	999370+01	0	0	0	0	0	21	8	970060+01	24	1	529820+02
1077	8	889340+01	15	8	592400+01	17	8	689900+01	0	0	0	0	0	19	8	813090+01	21	8	970060+01
1077	8	889340+01	25	1	508890+02	0	0	0	0	0	0	0	0	0	0	0	0	0	0
1078	8	895940+01	1	1	399320-05	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1078	8	895940+01	2	1	259620-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1078	8	895940+01	1	1	599250-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1078	8	895940+01	1	1	599250-06	1	055000+00	0	0	0	0	0	0	11	2	409340+01	13	8	503330+01
1078	8	895940+01	1	1	599250-06	1	055000+00	0	0	0	0	0	0	21	8	969430+01	24	1	515480+02
1078	8	895940+01	15	8	592520+01	17	8	689360+01	0	0	0	0	0	19	8	813700+01	21	8	969430+01
1078	8	895940+01	25	1	494030+02	0	0	0	0	0	0	0	0	0	0	0	0	0	0
1079	8	902550+01	1	1	769580-05	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1079	8	902550+01	2	1	510040-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1079	8	902550+01	1	1	860380-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1079	8	902550+01	1	6	988320-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1079	8	902550+01	1	6	988320-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1079	8	902550+01	1	6	988320-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1079	8	902550+01	1	1	068630-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1079	8	902550+01	1	1	068630-06	1	055000+00	0	0	0	0	0	0	5	8	157930+01	11	8	409200+01
1079	8	902550+01	15	8	592630+01	17	8	689790+01	0	0	0	0	0	19	8	814250+01	21	8	968780+01
1079	8	902550+01	25	1	479800+02	0	0	0	0	0	0	0	0	0	0	0	0	0	0
1080	8	908450+01	1	1	344650-05	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1080	8	908450+01	2	1	256880-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1080	8	908450+01	1	1	459750-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1080	8	908450+01	1	1	459750-06	1	055000+00	0	0	0	0	0	0	5	8	157820+01	11	8	409070+01
1080	8	908450+01	1	1	459750-06	1	055000+00	0	0	0	0	0	0	19	8	814790+01	21	8	968080+01
1080	8	908450+01	15	8	592740+01	17	8	690220+01	0	0	0	0	0	19	8	814790+01	21	8	968080+01
1080	8	908450+01	25	1	465460+02	0	0	0	0	0	0	0	0	0	0	0	0	0	0
1081	8	914700+01	1	1	331570-05	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1081	8	914700+01	2	1	229880-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1081	8	914700+01	1	1	343050-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1081	8	914700+01	1	1	343050-06	1	055000+00	0	0	0	0	0	0	5	8	157720+01	11	8	408950+01
1081	8	914700+01	1	1	343050-06	1	055000+00	0	0	0	0	0	0	21	8	967330+01	24	1	474010+02
1081	8	914700+01	15	8	592860+01	17	8	690650+01	0	0	0	0	0	19	8	815300+01	21	8	967330+01
1081	8	914700+01	25	1	451020+02	0	0	0	0	0	0	0	0	0	0	0	0	0	0
1082	8	920960+01	1	1	301330-05	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1082	8	920960+01	2	1	196830-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1082	8	920960+01	1	1	337530-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1082	8	920630+01	1	6	654800-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1082	8	920630+01	1	6	654800-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1082	8	920630+01	1	1	032060-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0
1082	8	920630+01	1	1	032060-06	1	055000+00	0	0	0	0	0	0	5	8	157610+01	11	8	408830+01
1082	8	920630+01	1	1	032060-06	1	055000+00	0	0	0	0	0	0	21	8	966540+01	24	1	460690+02
1082	8	920630+01	15	8	592970+01	17	8	691060+01	0	0	0	0	0	19	8	815770+01	21	8	966540+01
1082	8	920630+01	25	1	437200+02	0	0	0	0	0	0	0	0	0	0	0	0	0	0
1083	8	926560+01	1	6	817140-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0



1094	8	982500+01	15	8	594230+01	17	8	695100+01	19	8	819570+01	21	8	955800+01	24	1	316880+02	
			25	1	290230+02													
1094	8	982500+01	1	2	037990-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	
1094	8	982500+01	1	2	037990-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	
1094	8	982500+01	1	2	48530-07	1	055000+00	0	0	0	0	0	0	0	0	0	0	25
1094	8	982500+01	1	5	709830-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	25
1094	8	982500+01	1	5	709830-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	25
1094	8	982500+01	1	5	709830-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	25
1094	8	982500+01	1	8	723060-07	1	055000+00	0	0	0	0	0	0	0	0	0	0	25
1094	8	982500+01	1	7	576260+01	3	7	998010+01	5	8	156540+01	11	8	407570+01	13	8	502340+01	25
1094	8	982500+01	15	8	594340+01	17	8	695430+01	19	8	819790+01	21	8	954670+01	24	1	304790+02	
			25	1	277940+02													
1095	8	993440+01	1	8	129520-07	1	055000+00	0	0	0	0	0	0	0	0	0	0	
1095	8	993440+01	1	8	129520-07	1	055000+00	0	0	0	0	0	0	0	0	0	0	
1095	8	993440+01	1	1	151540-07	1	055000+00	0	0	0	0	0	0	0	0	0	0	
1095	8	993440+01	1	7	576230+01	3	7	997940+01	5	8	156470+01	11	8	407480+01	13	8	502300+01	25
1095	8	993440+01	15	8	594460+01	17	8	695740+01	19	8	819990+01	21	8	953510+01	24	1	292710+02	
			25	1	265650+02													
1096	8	996720+01	1	1	626630-05	1	055000+00	0	0	0	0	0	0	0	0	0	0	
1096	8	996720+01	2	1	586010-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	
1096	8	996720+01	1	6	228410-07	1	055000+00	0	0	0	0	0	0	0	0	0	0	
1096	8	996720+01	1	7	576220+01	3	7	997900+01	5	8	156420+01	11	8	407430+01	13	8	502270+01	25
1096	8	996720+01	15	8	594530+01	17	8	695940+01	19	8	820110+01	21	8	952770+01	24	1	285140+02	
			25	1	257810+02													
1097	9	000000+01	1	5	721740-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	
1097	9	000000+01	1	5	721740-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	
1097	9	000000+01	1	6	917810-07	1	055000+00	0	0	0	0	0	0	0	0	0	0	
1097	9	000000+01	1	7	576200+01	3	7	997860+01	5	8	156370+01	11	8	407370+01	13	8	502250+01	25
1097	9	000000+01	15	8	594600+01	17	8	696140+01	19	8	820220+01	21	8	952010+01	24	1	277540+02	
			25	1	250010+02													

HEATING 02/12/83  
W9XNP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

15M3033/ 0  
20 58 32 11-16-89

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 1097 TIME STEPS, TIME = 9.000000+01

GROSS GRID 1

FINE GRID 1

	DISTANCE	O. O
1	0.0	75176
2	0.03	77187
3	0.06	79198
4	0.08	80177
5	0.10	81156
6	0.57	81199
7	1.04	82142
8	1.51	82184
9	1.98	83126
10	2.45	83167
11	2.92	84107
12	3.14	84156
13	3.35	85102
14	3.57	85148
15	3.79	85195
16	4.01	86143
17	4.23	86196
18	4.45	87155
19	4.67	88170
20	4.89	88189
21	5.10	89152
22	5.18	105125
23	5.25	119148
24	5.32	127125
25	5.35	125100

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	93.690000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 3.281228300-02

ELAPSED CPU TIME IS 13.32 SECONDS

THE MAXIMUM TEMPERATURE IS 1.277540+02 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES 24

THE MINIMUM TEMPERATURE IS 7.576200+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES 1

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO ITER	L1 NORM OF NODE TEMP DIFF	MAX TEMP CHANGE	NODE TEMP CHANGE	MAX PERCENT TEMP CHANGE
1098	9 003280+01	1	1 700970-06	1 055000+00	0 0	0 0	0 0	1 1 328690-06	25 7 788160-01	25 6 230460-01	
1098	9 003280+01	1	1 700970-06	1 055000+00	0 0	0 0	0 0	2 1 140290-07			
1098	9 003280+01	1	1 648640-07	1 055000+00	0 0	0 0	0 0				

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NUMBER OF TIME STEPS	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO ITER	L1 NORM OF NODE TEMP DIFF	MAX TEMP CHANGE	NODE TEMP CHANGE	MAX PERCENT TEMP CHANGE
1098	9 00330+01	1	1 7576190+01	3 7 997820+01	5 8 156330+01	11 8 407320+01	13 8 502220+01	13 8 502220+01			
		15	8 594670+01	17 8 696330+01	19 8 820330+01	21 8 951250+01	24 1 269930+02				
		25	1 242230+02		0 0	0 0		1 1 900250-06			
1099	9 006890+01	1	3 537530-06	1 055000+00	0 0	0 0	0 0	2 2 322480-07	25 8 581170-01	25 6 875700-01	
1099	9 006890+01	1	3 537530-06	1 055000+00	0 0	0 0	0 0				
1099	9 006890+01	1	4 489850-07	1 055000+00	0 0	0 0	0 0	11 8 407260+01	13 8 502200+01		
1099	9 006890+01	1	1 7576170+01	3 7 997780+01	5 8 156270+01	11 8 407260+01	13 8 502200+01	24 1 251550+02			
		15	8 594750+01	17 8 696540+01	19 8 820440+01	21 8 950390+01	24 1 251550+02				
		25	1 233680+02		0 0	0 0		1 1 463090-06			
1100	9 010860+01	1	2 333760-06	1 055000+00	0 0	0 0	0 0	2 1 574930-07	25 9 379080-01	25 7 602500-01	
1100	9 010860+01	1	2 333760-06	1 055000+00	0 0	0 0	0 0				
1100	9 010860+01	1	3 127980-07	1 055000+00	0 0	0 0	0 0	11 8 407200+01	13 8 502170+01		
1100	9 01090+01	1	1 7576150+01	3 7 997730+01	5 8 156220+01	11 8 407200+01	13 8 502170+01	24 1 252323+02			
		15	8 594840+01	17 8 696770+01	19 8 820550+01	21 8 949430+01	24 1 252323+02				
		25	1 224300+02		0 0	0 0		1 9 194160-07			
1101	9 015230+01	1	3 792210-07	1 055000+00	0 0	0 0	0 0	2 8 891440-08	25 1 031460+00	25 8 424840-01	
1101	9 015230+01	1	3 792210-07	1 055000+00	0 0	0 0	0 0				
1101	9 015230+01	1	3 483250-08	1 055000+00	0 0	0 0	0 0	11 8 407130+01	13 8 502140+01		
1101	9 01520+01	1	1 7576140+01	3 7 997680+01	5 8 156160+01	11 8 407130+01	13 8 502140+01	24 1 242180+02			
		15	8 594940+01	17 8 697020+01	19 8 820670+01	21 8 948350+01	24 1 242180+02				
		25	1 213990+02		0 0	0 0		1 1 109380-06			
1102	9 020030+01	1	7 572560-07	1 055000+00	0 0	0 0	0 0	2 8 208560-08	25 1 135080+00	25 9 350000-01	
1102	9 020030+01	1	7 572560-07	1 055000+00	0 0	0 0	0 0				
1102	9 020030+01	1	1 083470-07	1 055000+00	0 0	0 0	0 0	11 8 407050+01	13 8 502100+01		
1102	9 02000+01	1	1 7576120+01	3 7 997620+01	5 8 156090+01	11 8 407050+01	13 8 502100+01	24 1 231020+02			
		15	8 595050+01	17 8 697300+01	19 8 820760+01	21 8 947140+01	24 1 231020+02				
		25	1 202640+02		0 0	0 0		1 2 952550-06			
1103	9 024910+01	1	8 521030-06	1 055000+00	0 0	0 0	0 0	2 5 180550-07	25 1 158640+00	25 9 634180-01	
1103	9 024910+01	1	8 521030-06	1 055000+00	0 0	0 0	0 0				
1103	9 024910+01	1	1 243450-06	1 055000+00	0 0	0 0	0 0	11 8 406980+01	13 8 502070+01		
1103	9 02490+01	1	1 7576100+01	3 7 997570+01	5 8 156030+01	11 8 406980+01	13 8 502070+01	24 1 219670+02			
		15	8 595160+01	17 8 697570+01	19 8 820880+01	21 8 945890+01	24 1 219670+02				
		25	1 191050+02		0 0	0 0		1 3 390890-06			
1104	9 029790+01	1	7 487170-06	1 055000+00	0 0	0 0	0 0	2 4 785040-07	25 1 163690+00	25 9 770290-01	
1104	9 029790+01	1	7 487170-06	1 055000+00	0 0	0 0	0 0				
1104	9 029790+01	1	1 164930-06	1 055000+00	0 0	0 0	0 0	11 8 406900+01	13 8 502040+01		
1104	9 02980+01	1	1 7576080+01	3 7 997510+01	5 8 155960+01	11 8 406900+01	13 8 502040+01	24 1 208300+02			
		15	8 595270+01	17 8 697840+01	19 8 820970+01	21 8 944610+01	24 1 208300+02				
		25	1 179420+02		0 0	0 0		1 3 370180-06			
1105	9 034680+01	1	5 862970-06	1 055000+00	0 0	0 0	0 0	2 4 216450-07	25 1 167960+00	25 9 902900-01	
1105	9 034680+01	1	5 862970-06	1 055000+00	0 0	0 0	0 0				
1105	9 034680+01	1	1 010210-06	1 055000+00	0 0	0 0	0 0	11 8 406830+01	13 8 502010+01		
1105	9 03470+01	1	1 7576060+01	3 7 997460+01	5 8 155900+01	11 8 406830+01	13 8 502010+01	24 1 196510+02			
		15	8 595380+01	17 8 698110+01	19 8 821040+01	21 8 943310+01	24 1 196510+02				
		25	1 167740+02		0 0	0 0		1 3 528490-06			
1106	9 039550+01	1	5 382860-06	1 055000+00	0 0	0 0	0 0	2 4 113830-07	25 1 172060+00	25 1 003700+00	
1106	9 039560+01	1	5 382860-06	1 055000+00	0 0	0 0	0 0				
1106	9 039560+01	1	9 396190-07	1 055000+00	0 0	0 0	0 0	1 1 093880-06			
1106	9 039300+01	1	4 267590-06	1 055000+00	0 0	0 0	0 0	2 2 485880-07	25 1 112030+00	25 9 522990-01	
1106	9 039300+01	1	4 267590-06	1 055000+00	0 0	0 0	0 0				
1106	9 039300+01	1	6 067210-07	1 055000+00	0 0	0 0	0 0	11 8 406760+01	13 8 501990+01		
1106	9 03930+01	1	1 7576040+01	3 7 997410+01	5 8 155840+01	11 8 406760+01	13 8 501990+01	24 1 186080+02			
		15	8 595480+01	17 8 698350+01	19 8 821100+01	21 8 942050+01	24 1 186080+02				
		25	1 156620+02		0 0	0 0		1 3 528490-06			
1107	9 041970+01	1	1 898960-06	1 055000+00	0 0	0 0	0 0				

1107	9.04320+01	1	948350-06	1	055000+00	0.0	0.0	1	3.083770-06	25	9.634820-01
1107	9.04320+01	1	670050-07	1	055000+00	0.0	0.0	2	398820-07	25	1.143880+00
1107	9.04320+01	1	7576020+01	3	7.997360+01	5.8	155780+01	11	8.406700+01	13	8.501960+01
		15	8.595590+01	17	8.638660+01	19	8.821140+01	21	8.940770+01	24	1.175220+02
		25	1.145470+02								
1108	9.048540+01	1	534400-06	1	055000+00	0.0	0.0	1	3.283950-06	25	9.756230-01
1108	9.048540+01	1	534400-06	1	055000+00	0.0	0.0	2	3.300730-07	25	1.117550+00
1108	9.048540+01	1	245380-07	1	055000+00	0.0	0.0	5	8.406630+01	13	8.501940+01
1108	9.048540+01	1	7576020+01	3	7.997360+01	5.8	155720+01	11	8.939470+01	24	1.164330+02
1108	9.048540+01	1	595760+01	17	8.638660+01	19	8.821170+01	21	8.940770+01	24	1.164330+02
		25	1.134300+02								
1109	9.053160+01	1	644420-06	1	055000+00	0.0	0.0	1	3.916020-06	25	9.812950-01
1109	9.053160+01	1	644420-06	1	055000+00	0.0	0.0	2	5.289120-07	25	1.113080+00
1109	9.053160+01	1	077150-06	1	055000+00	0.0	0.0	5	8.155660+01	13	8.501920+01
1109	9.053160+01	1	7576020+01	3	7.997360+01	5.8	155720+01	11	8.938150+01	24	1.153420+02
1109	9.053160+01	1	595800+01	17	8.639080+01	19	8.821190+01	21	8.938150+01	24	1.153420+02
		25	1.123170+02								
1110	9.057780+01	1	913550-05	1	055000+00	0.0	0.0	1	1.673350-05	25	9.546390-01
1110	9.057780+01	2	5.161670-06	1	055000+00	0.0	0.0	2	1.105770-06	24	1.086800+00
1110	9.057780+01	1	923310-06	1	055000+00	0.0	0.0	5	8.406500+01	13	8.501890+01
1110	9.057780+01	1	7576020+01	3	7.997360+01	5.8	155610+01	11	8.936810+01	24	1.142550+02
1110	9.057780+01	1	595910+01	17	8.639310+01	19	8.821190+01	21	8.936810+01	24	1.142550+02
		25	1.112400+02								
1111	9.062400+01	1	3.079550-05	1	055000+00	0.0	0.0	1	1.304500-05	25	9.485310-01
1111	9.062400+01	2	2.951810-06	1	055000+00	0.0	0.0	2	4.349250-07	24	1.075690+00
1111	9.062400+01	1	697260-06	1	055000+00	0.0	0.0	5	8.155550+01	13	8.501870+01
1111	9.062400+01	1	7576020+01	3	7.997360+01	5.8	155550+01	11	8.935440+01	24	1.131790+02
1111	9.062400+01	1	596020+01	17	8.639540+01	19	8.821180+01	21	8.935440+01	24	1.131790+02
		25	1.101850+02								
1112	9.067020+01	1	731460-05	1	055000+00	0.0	0.0	1	1.122060-05	25	9.461750-01
1112	9.067020+01	2	1.864680-06	1	055000+00	0.0	0.0	2	4.156520-07	24	1.064340+00
1112	9.067020+01	1	151400-06	1	055000+00	0.0	0.0	5	8.406380+01	13	8.501850+01
1112	9.067020+01	1	7576020+01	3	7.997360+01	5.8	155490+01	11	8.934060+01	24	1.121150+02
1112	9.067020+01	1	596120+01	17	8.639770+01	19	8.821160+01	21	8.934060+01	24	1.121150+02
		25	1.091420+02								
1113	9.071670+01	1	130210-05	1	055000+00	0.0	0.0	1	1.012170-05	25	9.493650-01
1113	9.071670+01	2	1.348750-06	1	055000+00	0.0	0.0	2	3.010990-07	24	1.055870+00
1113	9.071670+01	1	531950-07	1	055000+00	0.0	0.0	5	8.155440+01	13	8.501830+01
1113	9.071670+01	1	7576020+01	3	7.997360+01	5.8	155440+01	11	8.932640+01	24	1.110590+02
1113	9.071670+01	1	596230+01	17	8.639990+01	19	8.821130+01	21	8.932640+01	24	1.110590+02
		25	1.081060+02								
1114	9.076320+01	1	757320-06	1	055000+00	0.0	0.0	1	1.87733000-06	25	9.515840-01
1114	9.076320+01	1	757320-06	1	055000+00	0.0	0.0	2	9.011190-07	24	1.044770+00
1114	9.076320+01	1	810840-06	1	055000+00	0.0	0.0	5	8.406250+01	13	8.501820+01
1114	9.076320+01	1	7576020+01	3	7.997360+01	5.8	155390+01	11	8.931210+01	24	1.100140+02
1114	9.076320+01	1	596340+01	17	8.700210+01	19	8.821080+01	21	8.931210+01	24	1.100140+02
		25	1.070770+02								
1115	9.080970+01	1	62730-06	1	055000+00	0.0	0.0	1	1.8163340-06	25	9.544830-01
1115	9.080970+01	1	62730-06	1	055000+00	0.0	0.0	2	7.443500-07	24	1.034480+00
1115	9.080970+01	1	461910-06	1	055000+00	0.0	0.0	5	8.155330+01	13	8.501800+01
1115	9.080970+01	1	7576020+01	3	7.996970+01	5.8	155330+01	11	8.929750+01	24	1.089800+02
1115	9.080970+01	1	596450+01	17	8.700430+01	19	8.821020+01	21	8.929750+01	24	1.089800+02
		25	1.060550+02								
1116	9.085620+01	1	884310-06	1	055000+00	0.0	0.0	1	1.7615630-06	25	9.583680-01
1116	9.085620+01	1	884310-06	1	055000+00	0.0	0.0	2	6.215200-07	24	1.025460+00
1116	9.085620+01	1	192640-05	1	055000+00	0.0	0.0	5	8.406140+01	13	8.501780+01
1116	9.085620+01	1	7576020+01	3	7.996930+01	5.8	155280+01	11	8.928270+01	24	1.079550+02
1116	9.085620+01	1	596550+01	17	8.700640+01	19	8.820950+01	21	8.928270+01	24	1.079550+02
		25	1.050390+02								
1117	9.090260+01	1	375730-06	1	055000+00	0.0	0.0	1	1.70231000-06	25	9.633040-01
1117	9.090260+01	1	375730-06	1	055000+00	0.0	0.0	2	5.169190-07	24	1.017640+00
1117	9.090260+01	1	887600-07	1	055000+00	0.0	0.0	5	8.155230+01	13	8.501770+01
1117	9.090260+01	1	7576020+01	3	7.996880+01	5.8	155230+01	11	8.926780+01	24	1.069370+02
1117	9.090260+01	1	596660+01	17	8.700850+01	19	8.820860+01	21	8.926780+01	24	1.069370+02
		25	1.040270+02								
1119	9.094910+01	1	3034680-06	1	055000+00	0.0	0.0				



1128	9	138900+01	1	6	998050-06	1	055000+00	0	0	0	0	0	0	0	1	5	098920-06		25	9	82530-01
1128	9	138900+01	1	1	249370-06	1	055000+00	0	0	0	0	0	0	0	2	6	149160-07	25	9	27740-01	
1128	9	138900+01	1	7	575680+01	3	7	996450+01	5	8	154730+01	11	8	405540+01	21	8	910100+01	24	9	648380+01	
1129	9	143040+01	1	5	716980-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1129	9	143040+01	1	3	716980-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1129	9	143040+01	1	1	072980-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1129	9	143040+01	1	7	575670+01	3	7	996420+01	5	8	154530+01	11	8	405500+01	21	8	908650+01	24	9	558180+01	
1130	9	14720+01	1	6	816700-04	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1130	9	14720+01	1	2	608360-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1130	9	14720+01	1	2	617870-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1130	9	14720+01	1	7	575650+01	3	7	996390+01	5	8	154660+01	11	8	405480+01	21	8	908140-01	24	9	608140-01	
1130	9	14720+01	1	5	808990-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1131	9	151340+01	1	2	383120-04	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1131	9	151340+01	1	3	833510-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1131	9	151340+01	1	2	968240-07	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1131	9	151340+01	1	7	575650+01	3	7	996360+01	5	8	154620+01	11	8	405420+01	21	8	905570+01	24	9	360340+01	
1132	9	155590+01	1	1	447870-04	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1132	9	155590+01	1	1	47870-04	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1132	9	155590+01	1	1	37380-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1132	9	155590+01	1	7	728280-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1132	9	155590+01	1	7	575630+01	3	7	996320+01	5	8	154580+01	11	8	405380+01	21	8	904000+01	24	9	295360+01	
1132	9	155590+01	1	5	808150+01	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1133	9	160040+01	1	1	072870-04	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1133	9	160040+01	1	3	8794160-07	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1133	9	160040+01	1	6	678160-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1133	9	160040+01	1	7	575620+01	3	7	996290+01	5	8	154540+01	11	8	405340+01	21	8	902340+01	24	9	212400+01	
1134	9	164790+01	1	9	206060-05	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1134	9	164790+01	1	7	967800-07	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1134	9	164790+01	1	6	602320-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1134	9	16480+01	1	7	575670+01	3	7	996250+01	5	8	154500+01	11	8	405300+01	21	8	900560+01	24	9	131070+01	
1135	9	16990+01	1	5	160510-05	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1135	9	16990+01	1	3	380440-07	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1135	9	16990+01	1	7	218870-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1135	9	16990+01	1	7	575590+01	3	7	996220+01	5	8	154460+01	11	8	405250+01	21	8	898630+01	24	9	990350-01	
1136	9	175430+01	1	9	997150-05	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1136	9	175430+01	1	3	621160-07	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1136	9	175430+01	1	8	313520-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1136	9	175430+01	1	7	575580+01	3	7	996180+01	5	8	154480+01	11	8	405210+01	21	8	896520+01	24	9	772500+01	
1137	9	181490+01	1	1	156460-04	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1137	9	181490+01	1	1	162500-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1137	9	181490+01	1	2	600100-07	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1137	9	18150+01	1	7	57560+01	3	7	996130+01	5	8	154370+01	11	8	405160+01	21	8	894200+01	24	9	744530-01	
1138	9	188160+01	1	1	361350-04	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1138	9	188160+01	1	3	419040-06	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1138	9	188160+01	1	2	9605250-07	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	
1138	9	188160+01	1	7	575550+01	3	7	996090+01	5	8	154320+01	11	8	405100+01	21	8	891530+01	24	9	605690-01	
1139	9	194080+01	1	7	565140-05	1	055000+00	0	0	0	0	0	0	0	0	0	0	0	0	0	





HEATING6 02/12/83  
W9KMP110

COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-0 MODEL

IBM3033/ 0  
20 58 34 11-16-89

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 1140 TIME STEPS, TIME = 9.200000+01

GROSS GRID	FINE GRID	DISTANCE
1	1	0.0
2	2	0.03
3	3	0.06
4	4	0.08
5	5	0.10
6	6	0.57
7	7	1.04
8	8	1.51
9	9	1.98
10	10	2.45
11	11	2.92
12	12	3.14
13	13	3.35
14	14	3.57
15	15	3.79
16	16	4.01
17	17	4.23
18	18	4.45
19	19	4.67
20	20	4.89
21	21	5.10
22	22	5.18
23	23	5.25
24	24	5.32
25	25	5.35

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	91.360000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 5.921650190-02

ELAPSED CPU TIME IS 13.76 SECONDS

THE MAXIMUM TEMPERATURE IS - 9.07101D+01 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 22

THE MINIMUM TEMPERATURE IS - 7.57552D+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	(JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	MAX TEMP CHANGE	MAX PERCENT TEMP CHANGE
1141	9.20650+01	1	1.757500+01	3.7995970+01	5.8154180+01	11.8404970+01	13.8501680+01	1	1.760570-05	23.5869480-01	23.6485050-01
1141	9.20650+01	2	1.599230+01	17.8704520+01	19.8814610+01	21.8884550+01	24.8648600+01	2	1.722850-06		
1141	9.20650+01	3	25.8521950+01					3			
1142	9.213680+01	1	1.906080-05	1.055000+00	0.0	0.0	0.0	1	1.8548970-05		
1142	9.213680+01	2	8.827530-06	1.055000+00	0.0	0.0	0.0	2	1.991410-06	23.5923810-01	23.6587790-01
1142	9.213680+01	3	8.885990-06	1.055000+00	0.0	0.0	0.0	3	1.8501690+01		
1142	9.21370+01	1	1.7575490+01	3.7995930+01	5.8154130+01	11.8404920+01	13.8501690+01	1	1.722850-06		
1142	9.21370+01	2	1.599370+01	17.8704640+01	19.8813980+01	21.8881810+01	24.8594250+01	2			
1142	9.21370+01	3	25.8478880+01					3			
1143	9.221560+01	1	1.172080-04	1.055000+00	0.0	0.0	0.0	1	1.9284140-05		
1143	9.221560+01	2	9.373270-06	1.055000+00	0.0	0.0	0.0	2	2.573760-06	23.5923180-01	23.6630780-01
1143	9.221560+01	3	9.308220-07	1.055000+00	0.0	0.0	0.0	3			
1143	9.22160+01	1	1.7575470+01	3.7995880+01	5.8154080+01	11.8404870+01	13.8501700+01	1	1.8501700+01		
1143	9.22160+01	2	1.599530+01	17.8704770+01	19.8813260+01	21.8878810+01	24.8540560+01	2			
1143	9.22160+01	3	25.8435630+01					3			
1144	9.230230+01	1	1.340280-04	1.055000+00	0.0	0.0	0.0	1	1.9980230-05		
1144	9.230230+01	2	1.476070-06	1.055000+00	0.0	0.0	0.0	2	2.226210-06	23.5865920-01	23.6610500-01
1144	9.230230+01	3	1.218180-06	1.055000+00	0.0	0.0	0.0	3			
1144	9.23020+01	1	1.7575450+01	3.7995930+01	5.8154030+01	11.8404810+01	13.8501720+01	1	1.8501720+01		
1144	9.23020+01	2	1.599700+01	17.8704880+01	19.8812430+01	21.8875550+01	24.8487790+01	2			
1144	9.23020+01	3	25.8392870+01					3			
1145	9.239770+01	1	1.531910-04	1.055000+00	0.0	0.0	0.0	1	1.052450-04		
1145	9.239770+01	2	1.665200-06	1.055000+00	0.0	0.0	0.0	2	2.449710-06	23.5754390-01	23.6527980-01
1145	9.239770+01	3	1.617690-06	1.055000+00	0.0	0.0	0.0	3			
1145	9.23980+01	1	1.7575430+01	3.7995780+01	5.8153970+01	11.8404760+01	13.8501740+01	1	1.8501740+01		
1145	9.23980+01	2	1.599880+01	17.8704990+01	19.8811470+01	21.8872010+01	24.8436060+01	2			
1145	9.23980+01	3	25.8350010+01					3			
1146	9.250260+01	1	1.717060-04	1.055000+00	0.0	0.0	0.0	1	1.091430-04		
1146	9.250260+01	2	1.893270-06	1.055000+00	0.0	0.0	0.0	2	2.635510-06	23.5595170-01	23.6389050-01
1146	9.250260+01	3	1.995940-06	1.055000+00	0.0	0.0	0.0	3			
1146	9.25030+01	1	1.7575410+01	3.7995730+01	5.8153910+01	11.8404700+01	13.8501760+01	1	1.8501760+01		
1146	9.25030+01	2	1.599600+01	17.8705070+01	19.8810370+01	21.8868200+01	24.8385380+01	2			
1146	9.25030+01	3	25.8307240+01					3			
1147	9.261800+01	1	1.848450-04	1.055000+00	0.0	0.0	0.0	1	1.106450-04		
1147	9.261800+01	2	3.58660-06	1.055000+00	0.0	0.0	0.0	2	2.778110-06	23.5398680-01	23.6204330-01
1147	9.261800+01	3	2.411050-06	1.055000+00	0.0	0.0	0.0	3			
1147	9.26180+01	1	1.7575390+01	3.7995670+01	5.8153850+01	11.8404640+01	13.8501790+01	1	1.8501790+01		
1147	9.26180+01	2	1.599500+01	17.8705140+01	19.8809110+01	21.8853110+01	24.8335660+01	2			
1147	9.26180+01	3	25.8264380+01					3			
1148	9.274490+01	1	1.977820-04	1.055000+00	0.0	0.0	0.0	1	1.100550-04		
1148	9.274490+01	2	2.918350-06	1.055000+00	0.0	0.0	0.0	2	2.893090-06	23.5179270-01	23.5989330-01
1148	9.274490+01	3	2.869080-06	1.055000+00	0.0	0.0	0.0	3			
1148	9.27450+01	1	1.7575370+01	3.7995610+01	5.8153790+01	11.8404590+01	13.8501830+01	1	1.8501830+01		
1148	9.27450+01	2	1.599490+01	17.8705170+01	19.8807660+01	21.8859730+01	24.8286690+01	2			
1148	9.27450+01	3	25.8221210+01					3			
1149	9.288450+01	1	2.019050-04	1.055000+00	0.0	0.0	0.0	1	1.065030-04		
1149	9.288450+01	2	3.405310-06	1.055000+00	0.0	0.0	0.0	2	2.895840-06	23.4954610-01	23.5862870-01
1149	9.288450+01	3	3.176310-06	1.055000+00	0.0	0.0	0.0	3			
1149	9.28850+01	1	1.7575350+01	3.7995550+01	5.8153720+01	11.8404530+01	13.8501870+01	1	1.8501870+01		
1149	9.28850+01	2	1.599700+01	17.8705160+01	19.8806010+01	21.8855070+01	24.8238100+01	2			
1149	9.28850+01	3	25.8177360+01					3			
1150	9.303810+01	1	1.869520-04	1.055000+00	0.0	0.0	0.0	1	1.891440-05		
1150	9.303810+01	2	3.561330-06	1.055000+00	0.0	0.0	0.0	2	2.691120-06	24.4876140-01	24.5919000-01
1150	9.303810+01	3	3.471160-06	1.055000+00	0.0	0.0	0.0	3			
1150	9.30380+01	1	1.7575330+01	3.7995500+01	5.8153660+01	11.8404470+01	13.8501930+01	1	1.8501930+01		
1150	9.30380+01	2	1.599500+01	17.8705150+01	19.8805070+01	21.8853660+01	24.8238100+01	2			
1150	9.30380+01	3	25.8177360+01					3			

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

\*\*\*\*\* NODE NUMBERS AND TEMPERATURES \*\*\*\*\*

NUMBER OF TIME

TIME STEPS

1151	9.320710+01	15 8.600950+01	17 8.705090+01	19 8.804120+01	21 8.850130+01	24 8.189340+01
		25 8.132180+01				
1151	9.320710+01	1 1.311880-04	1.055000+00	0.0	0.0	
1151	9.320710+01	3 2.473180-06	1.055000+00	0.0	0.0	
1151	9.320710+01	2 2.626380-06	1.055000+00	0.0	0.0	
1151	9.320710+01	1 7.575360+01	3 7.995440+01	5 8.153600+01	11 8.404320+01	13 8.501980+01
		15 8.601180+01	17 8.704950+01	19 8.801980+01	21 8.844910+01	24 8.139400+01
		25 8.084360+01				
1152	9.339280+01	1 1.422980-04	1.055000+00	0.0	0.0	
1152	9.339280+01	3 3.620770-06	1.055000+00	0.0	0.0	
1152	9.339280+01	2 3.214150-06	1.055000+00	0.0	0.0	
1152	9.339330+01	1 7.575280+01	3 7.995380+01	5 8.153540+01	11 8.404380+01	13 8.502060+01
		15 8.601410+01	17 8.704710+01	19 8.799560+01	21 8.839400+01	24 8.087260+01
		25 8.033640+01				
1153	9.359740+01	1 1.208170-04	1.055000+00	0.0	0.0	
1153	9.359740+01	3 3.369370-06	1.055000+00	0.0	0.0	
1153	9.359740+01	2 3.012100-06	1.055000+00	0.0	0.0	
1153	9.35970+01	1 7.573260+01	3 7.995330+01	5 8.153490+01	11 8.404340+01	13 8.502140+01
		15 8.601640+01	17 8.704360+01	19 8.796820+01	21 8.833610+01	24 8.032170+01
		25 7.979270+01				
1154	9.379870+01	1 7.782300-05	1.055000+00	0.0	0.0	
1154	9.379870+01	2 8.656880-06	1.055000+00	0.0	0.0	
1154	9.379870+01	1 9.413510-06	1.055000+00	0.0	0.0	
1154	9.37990+01	1 7.575240+01	3 7.995260+01	5 8.153440+01	11 8.404370+01	13 8.502220+01
		15 8.601820+01	17 8.703920+01	19 8.794090+01	21 8.828130+01	24 7.579360+01
		25 7.926520+01				
1155	9.400000+01	1 5.090040-05	1.055000+00	0.0	0.0	
1155	9.400000+01	2 5.842860-06	1.055000+00	0.0	0.0	
1155	9.400000+01	1 5.637150-06	1.055000+00	0.0	0.0	
1155	9.40000+01	1 7.575230+01	3 7.995250+01	5 8.153410+01	11 8.404300+01	13 8.502310+01
		15 8.601970+01	17 8.703390+01	19 8.791320+01	21 8.822850+01	24 7.927290+01
		25 7.874190+01				

HEATING6 02/12/83  
W9XNP110

COOPER, NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL

1843033/ 0  
20 58 34 11-16-89

TRANSIENT TEMPERATURE DISTRIBUTION AFTER 1155 TIME STEPS, TIME = 9.400000+01

GROSS GRID 1

FINE GRID 1

	O O	O O
	DISTANCE	TEMP
1	0.0	75175
2	0.03	77185
3	0.06	79195
4	0.08	80174
5	0.10	81153
6	0.57	81196
7	1.04	82130
8	1.51	82179
9	1.98	83121
10	2.45	83163
11	2.92	84104
12	3.14	84153
13	3.35	85102
14	3.57	85152
15	3.79	86102
16	4.01	86153
17	4.23	87103
18	4.45	87151
19	4.67	87191
20	4.89	88118
21	5.10	88123
22	5.18	85173
23	5.25	82183
10	5.32	79127
11	5.35	78174

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	87.330000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 2.013179240-01

ELAPSED CPU TIME IS 13.96 SECONDS

THE MAXIMUM TEMPERATURE IS - 8.82285D+01 (+-0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 20 21

THE MINIMUM TEMPERATURE IS - 7.575230+01 (+-0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 1

NO	TIME	NO ITER	MAX HEAT RESIDUAL	BETA	L1 NORM OF TEMP DIFF	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	NOSE	MAX TEMP CHANGE	NOSE	MAX TEMP CHANGE	PERCENT TEMP CHANGE
1156	9.422140+01	1	6.220930-05	1.055000+00	0.0	0.0	0.0	1	1.989680-05	25 5	809720-01	25 5	809720-01	25 7.378190-01
1156	9.422140+01	3	2.226280-06	1.055000+00	0.0	0.0	0.0	2	4.849340-07	25 5	809720-01	25 5	809720-01	25 7.378190-01
1156	9.422140+01	1	7.759830-06	1.055000+00	0.0	0.0	0.0	2	4.849340-07	25 5	809720-01	25 5	809720-01	25 7.378190-01

TABLE FOR SPECIAL MONITORING OF TEMPERATURES

NUMBER OF TIME STEPS	TIME	RHO (ITERATION)	RHO (JACOBI)	NO ITER	L1 NORM OF TEMP DIFF	NOSE	MAX TEMP CHANGE	NOSE	MAX TEMP CHANGE	PERCENT TEMP CHANGE
1156	9.42210+01	5 8.153380+01	11 8.404300+01	13 8.502400+01	17 8.702710+01	19 8.788240+01	21 8.817250+01	24 7.870120+01	25 7.870120+01	
1157	9.446500+01	0.0	0.0	1 1.502200-05	0.0	0.0	0.0	2 5.298500-07	25 6.417290-01	25 8.210490-01
1157	9.446500+01	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
1157	9.446500+01	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
1157	9.446500+01	5 8.153370+01	11 8.404300+01	13 8.502600+01	17 8.701870+01	19 8.788850+01	21 8.811300+01	24 7.807010+01	25 8.210490-01	
1158	9.473300+01	0.0	0.0	1 1.895000-05	0.0	0.0	0.0	2 5.122800-07	25 7.083470-01	25 9.137700-01
1158	9.473300+01	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
1158	9.473300+01	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
1158	9.473300+01	5 8.153360+01	11 8.404320+01	13 8.502600+01	17 8.700810+01	19 8.781100+01	21 8.804960+01	24 7.737340+01	25 9.137700-01	
1159	9.501160+01	0.0	0.0	1 1.022760-05	0.0	0.0	0.0	2 6.792350-07	25 7.399490-01	25 9.633400-01
1159	9.501160+01	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
1159	9.501160+01	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
1159	9.50120+01	5 8.153360+01	11 8.404350+01	13 8.502690+01	17 8.698600+01	19 8.777210+01	21 8.798570+01	24 7.664610+01	25 9.633400-01	
1160	9.529020+01	0.0	0.0	1 6.685340-06	0.0	0.0	0.0	2 3.276560-07	25 7.414920-01	25 9.747380-01
1160	9.529020+01	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
1160	9.529020+01	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
1160	9.52900+01	5 8.153380+01	11 8.404390+01	13 8.502780+01	17 8.698250+01	19 8.773330+01	21 8.792340+01	24 7.591660+01	25 9.747380-01	
1161	9.556870+01	0.0	0.0	1 4.232050-06	0.0	0.0	0.0	2 6.518170-07	25 7.410980-01	25 9.838100-01
1161	9.556870+01	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
1161	9.556870+01	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
1161	9.55680+01	5 8.153400+01	11 8.404440+01	13 8.502840+01	17 8.696860+01	19 8.769460+01	21 8.786260+01	24 7.518660+01	25 9.838100-01	
1162	9.578440+01	0.0	0.0	1 3.478260-06	0.0	0.0	0.0	2 1.745460-07	25 5.748280-01	25 7.716670-01
1162	9.578440+01	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
1162	9.578440+01	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
1162	9.57840+01	5 8.153420+01	11 8.404480+01	13 8.502880+01	17 8.695210+01	19 8.766470+01	21 8.781630+01	24 7.462100+01	25 7.716670-01	
1163	9.600000+01	0.0	0.0	1 5.271940-06	0.0	0.0	0.0	2 5.847920-07	25 5.706480-01	25 7.710060-01
1163	9.600000+01	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
1163	9.600000+01	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	

18KJ033/ 0  
20 58 34 11-16-89

COOPER PLANT STATION CONTROL ROOM CEILING 1-D MODEL  
TRANSIENT TEMPERATURE DISTRIBUTION AFTER 1163 TIME STEPS, TIME = 9.600000+01

HEATING6 02/12/83  
MGXNP110

GROSS GRID	1	1
FINE GRID	1	1
DISTANCE	0.0	0.0
1	0.0	75175
2	0.03	77185
3	0.06	79195
4	0.08	80174
5	0.10	81153
6	0.57	81195
7	1.04	82137
8	1.51	82175
9	1.98	83121
10	2.45	83163
11	2.92	84105
12	3.14	84154
13	3.35	85103
14	3.57	85152
15	3.79	86101
16	4.01	86149
17	4.23	86194
18	4.45	87134
19	4.67	87163
20	4.89	87179
21	5.10	87177
22	5.18	83165
23	5.25	79117
24	5.32	74106
25	5.35	73144

TEMPERATURES ON NUMBERED BOUNDARIES

BOUNDARY NUMBER	TEMPERATURE
1	82.670000
2	0.0
3	73.400000

THE CURRENT TIME STEP (DELTA) = 2.1563333420-01

ELAPSED CPU TIME IS 14.05 SECONDS

THE MAXIMUM TEMPERATURE IS - 8.779300+01 (+0.1 PERCENT)

MAX. TEMP. APPEARS AT NODES - 20 21

THE MINIMUM TEMPERATURE IS - 7.344280+01 (+0.1 PERCENT)

MIN. TEMP. APPEARS AT NODES - 25

THE TRANSIENT CALCULATIONS HAVE BEEN COMPLETED

FINAL TIME IS 9.600000+01

NUMBER OF TIME STEPS COMPLETED = 1163



\*\*\*\*\* CASE NUMBER 1 \*\*\*\*\* COOPER NUCLEAR STATION CONTROL ROOM CEILING 1-D MODEL.  
\*\*\*\*\* JOB DESCRIPTION FOR THIS CASE HAVE BEEN COMPLETED  
\*\*\*\*\* THE CALCULATIONS FOR THIS CASE HAVE BEEN COMPLETED  
\*\*\*\*\* NUMBER OF ERRORS ENCOUNTERED IN THE INPUT DATA FOR THIS CASE WAS --- 0  
\*\*\*\*\* AN ATTEMPT WILL BE MADE TO READ DATA FOR A NEW CASE.  
\*\*\*\*\* THE CALCULATIONS USING THE HEATING CODE HAVE BEEN COMPLETED.  
\*\*\*\*\* NUMBER OF CASES ENCOUNTERED IN THE INPUT DATA --- 1  
\*\*\*\*\* NUMBER OF ERRORS ENCOUNTERED IN THE INPUT DATA --- 0



\*\* I B M \*\* ..... \*\* I B M \*\*  
 \*\* I B M \*\* ..... \*\* I B M \*\*  
 \*\* I B M \*\* ..... \*\* I B M \*\*

```

      RRRRRRRRRR      444      HH      HH NN      NN KK      KK      00000000      00000000      00000000
      RRRRRRRRRR      4444      HH      HH NNN      NN KK      KK      0000000000      0000000000      0000000000
      RR      RR      44 44      HH      HH NNNN      NN KK      KK      00      0000      00      0000      0000
      PR      RR      44 44      HH      HH NN NN      NN KK      KK      00      00 00      00      00 00      00 00
      RRR      RR      44 44      HH      HH NN NN      NN KK      KK      00      00 00      00      00 00      00 00
      RRRRRRRRRR      444444444444      HHHHHHHHHHHH      NN      NN      NN      KKKKKKKK      00      00      00      00      00      00
      RRRRRRRRRR      444444444444      HHHHHHHHHHHH      NN      NN      NN      KKKKKKKK      00      00      00      00      00      00
      RR      RR      44      HH      HH NN      NN NN      KK      KK      00      00      00      00      00      00
      RR      RR      44      HH      HH NN      NN NN      KK      KK      0000      00      0000      00      0000      00
      RR      RR      44      HH      HH NN      NN NN      KK      KK      000      00      000      00      000      00
      RR      RR      44      HH      HH NN      NN KK      KK      0000000000      0000000000      0000000000
      RR      RR      44      HH      HH NN      N KK      KK      00000000      00000000      00000000
  
```

```

      JJJJJJJJJ      888888888      00000000      888888888      77777777      AAAAAAAAAA
      JJJJJJJJJ      88888888888      0000000000      88888888888      77777777      AAAAAAAAAAAA
      JJ      88      88      00      0000      88      88      77      AA      AA
      JJ      88      88      00      00 00      88      88      77      AA      AA
      JJ      88      88      00      00 00      88      88      77      AA      AA
      JJ      88888888      00      00      00      88888888      77      AAAAAAAAAAAAA
      JJ      88888888      00      00      00      88888888      77      AAAAAAAAAAAAA
      JJ      88      88      00      00      00      88      88      77      AA      AA
      JJ      88      88      0000      00      88      88      77      AA      AA
      JJ      88      88      000      00      88      88      77      AA      AA
      JJJJJJJ      888888888888      0000000000      88888888888      77      AA      AA
      JJJJJ      8888888888      00000000      8888888888      77      AA      AA
  
```

```

      DDDDDDDDD      PPPPPPPPPP      LL      XX      XX      BBBB88888888      55555555555      444
      DDDDDDDDD      PPPPPPPPPP      LL      XX      XX      BBBB8888888888      55555555555      4444
      DD      DD      PP      PP      LL      XX      XX      BB      BB      55      44 44
      DD      DD      PP      PP      LL      XX      XX      BB      BB      55      44 44
      DD      DD      PP      PP      LL      XX      XX      BB      BB      55      44 44
      DD      DD      PP      PP      LL      XX      XX      BB      BB      55      44 44
      DD      DD      PPPPPPPPPP      LL      XXXX      BBBB88888888      5555555555      44444444444
      DD      DD      PPPPPPPPPP      LL      XXXX      BBBB88888888      55555555555      44444444444
      DD      DD      PP      LL      XX      XX      BB      BB      55      44
      DD      DD      PP      LL      XX      XX      BB      BB      55      44
      DD      DD      PP      LL      XX      XX      BB      BB      55      44
      DD      DD      PP      LL      XX      XX      BB      BB      55      44
      DDDDDDDDD      PP      LLLLLLLLLLLL      XX      XX      BBBB8888888888      55555555555      44
      DDDDDDDDD      PP      LLLLLLLLLLLL      XX      XX      BBBB8888888888      55555555555      44
  
```

\*\* I B M \*\*    END    JOB 8087    R4HNK000    FX2046    A12045    ROOM -B54    16.00.14 - 89.321    - PRT3    - SYSOUT = A    \*\* I B M \*\*  
 \*\* I B M \*\*    END    JOB 8087    R4HNK000    FX2046    A12045    ROOM -B54    16.00.14 - 89.321    - PRT3    - SYSOUT = A    \*\* I B M \*\*  
 \*\* I B M \*\*    END    JOB 8087    R4HNK000    FX2046    A12045    ROOM -B54    16.00.14 - 89.321    - PRT3    - SYSOUT = A    \*\* I B M \*\*

JUNE 1977

VOLUME 1

NUMBER 6


*III - 1/5*  
*NPP1 - 580 - 007*  
*27/99*

# MONTHLY SUMMARY SOLAR RADIATION DATA



*ATTACHMENT III*

*NPP1 - 580 - 007*



**noaa**

NATIONAL OCEANIC AND  
ATMOSPHERIC ADMINISTRATION

ON

ENVIRONMENTAL DATA AND  
INFORMATION SERVICE

NATIONAL CLIMATIC CENTER  
ASHEVILLE, N.C. APRIL 1979

3. Dashes (---) in place of a solar radiation value. The dashes mean the value was missing from an observed data set, or was missing, or considered faulty in the case of an edited data set.

The qualifier flag, "X", appearing in an edited data set, points to a value which fell outside limits normally prescribed for valid data but which was not judged to be faulty. Most of the flags for edited global radiation are automatically assigned as measured radiation data are compared to a clear sky radiation model. If the measurements exceed the model by ten percent or more, they are flagged as questionable. During processing, the questionable flag may be removed or the measurement may be deleted based on the meteorological conditions for that time.

#### COMPUTATIONAL PROCEDURES.

Daily totals. Daily totals are the sum of all listed hourly values for the day. The first of the following criteria to be met determines the qualifier flag assigned to a daily total:

1. If any hourly value is missing (indicated by dashes), the daily total is not computed and dashes appear in the place of the daily total.
2. If any hourly value is questionable, the daily total is considered questionable as well and assumes the questionable flag, "X".
3. If the daytime hourly series contains only modeled values, the daily total represents a modeled value and is given the qualifier flag, "#".
4. If the daytime hourly series contains any estimated and/or modeled values, the daily total is considered an estimate and assumes the qualifier flag, "\$".
5. Otherwise, the daily total appears without a qualifier flag.

Monthly means. Monthly means of hourly values are computed from all the listed values for the hour. The mean daily total for the month is computed from all listed daily totals. The first of the following criteria to be met determines the qualifier flag assigned to a mean value:

1. A monthly mean is not computed if:
  - a. Values are missing (indicated by dashes) for ten or more days during the month, or
  - b. Values are missing for seven or more days during the first fifteen days of the month, or
  - c. Values are missing for seven or more days between the sixteenth of the month and the end of the month.

The last two criteria are included to reduce the risk of computing non-representative monthly means influenced by clusters of missing data.

374 (1) III 3/5  
N.I. - SBφ-007

2. If any value contributing to the mean is questionable, the mean value is given the questionable qualifier flag, "X".
3. If all values contributing to the mean are modeled, the mean value is given the modeled qualifier flag, "M".
4. If the series contributing to the mean contains any estimated and/or modeled values, the mean assumes the estimated qualifier flag, "E".
5. Otherwise, the monthly mean appears without a qualifier flag.

GENERAL NOTES. This section contains corrections to previously published data tables; publicizes other solar radiation data and summaries available at the National Climatic Center; describes changes to the network, instrumentation, or operating procedures; and alerts the reader to new features contained in the publication.


STATION INDEX. This listing contains names of network stations for which data are normally published. It also has information on station location, observer, and data types selected (indicated by "X") for publication in the current issue.

ABBREVIATIONS. The following are the abbreviations used in the publication:

C	code (data type)
DEG	degrees
DIF	diffuse radiation
DIR	direct radiation
E	east longitude
ELEV	elevation
GBL	global radiation
IR	infrared radiation
LAT	latitude
LON	longitude
M	meters
MIN	minutes
MSL	mean sea level
N	north latitude
ORT	other radiation type
S	south latitude
SPEC SR-75	Spectrolab Model SR-75 pyranometer
STN	station
TLT	tilt (with respect to horizontal)
UV	ultraviolet radiation
W	west longitude

871/4 III-4/5

TYPICAL METEOROLOGICAL YEAR NETWORK



- OTHER U.S. STATIONS:**
- GUANTANAMO BAY, CUBA
  - KORO ISLAND, PACIFIC
  - KWAJALEIN ISLAND, PACIFIC
  - SAN JUAN, PUERTO RICO
  - WAKE ISLAND, PACIFIC

ALASKA

HAWAII

ALASKA

HAWAII

ALASKA

HAWAII

ADAK

CHAMBER, NC  
JUNE 1977


STATION 84618  
N41.22 1096.01 ELEV (M PSL) 0404  
PYRANOMETER SPEC SR-75

EDITED GLOBAL RADIATION  
RADIATION FOR EACH HOUR ENDING AT LOCAL STANDARD TIME (KILOJOULES PER SQUARE METER)

DAY C	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	TOTAL
01 0	0	0	0	0	0	86	425	684	1568	2545	3180	3427	3465	3323	2963	2455	1822	1116	457	0	0	0	0	0	20378M
02 0	0	0	0	0	0	169	603M	1577M	2254	2801	3215	3438	3424	3247	2888	2401	1742	1073	428	18	0	0	0	0	19387
03 0	0	0	0	0	0	76	823	988	1793	2418	2901	2707	2275	1148	657	1484	807	418	25	0	0	0	0	0	28308
04 0	0	0	0	0	0	155	782	1468	2117	2650	3028	3251	3305	3157	2828	2344	1721	1033	428	52	0	0	0	0	25138
05 0	0	0	0	0	0	148	713	1472	2002	2641	2808	2790	3053	2728	2338	1887	1370	884	439	54	0	0	0	0	28484
06 0	0	0	0	0	7	245	763	1462	1926	2754	3092	3420	3506	3344	2895	2462	1832	1158	490	40	0	0	0	0	28860M
07 0	0	0	0	0	4	187	898M	1595M	2257	2797	3200	3388	3456	3280	2841	2437	1800	1112	438	32	0	0	0	0	28478
08 0	0	0	0	0	4	184	873	1321	2203	2740	3107	3388	3352	3188	2804	2322	1717	1068	389	25	0	0	0	0	25192M
08 0	0	0	0	0	7	187	850M	1418	1926	2614	3085	3280	3348	3203	2905	2260	1604	1037	500	68	0	0	0	0	26581
10 0	0	0	0	0	4	7	778	1422	2088	2508	2892	3204	3244	3488	2853	2171	1582	1040	410	22	0	0	0	0	15855
11 0	0	0	0	0	4	180	789	1462	1920	1878	1922	3053	1800	482	324	317	842	1088	310	54	0	0	0	0	8881
12 0	0	0	0	0	0	40	266	688	817	446	284	335	328	468	1055	1145	1323	1159	302	25	0	0	0	0	11781
13 0	0	0	0	0	11	58	180	270	353	1307	1231	1321	1812	1030	1408	1048	817	421	364	50	0	0	0	0	25028
14 0	0	0	0	0	4	130	634	1141	1837	2642	3010	2603	2426	2380	2833	2214	1377	1015	428	54	0	0	0	0	27525
16 0	0	0	0	0	7	140	745	1418	2041	2560	2898	3183	3244	2848	2732	2328	1717	1037	450	68	0	0	0	0	17878
16 0	0	0	0	0	7	238	173	623	1246	382	547	2135	2821	3046	3028	1840	742	724	466	40	0	0	0	0	14931M
17 0	0	0	0	0	0	140	650M	1544	1577	181	310	277	202	1253	2750	2452	1782	1106	346	54	0	0	0	0	27331M
18 0	0	0	0	0	14	263	878M	1485	1840	2344	2738	3416	3482	2888	2488	2347	1586	1088	317	61	0	0	0	0	28058M
18 0	0	0	0	0	22	212	828M	884	2721	2747	3048	3233	3402	3395	2888	2495	1825	1127	400	81	0	0	0	0	26704
20 0	0	0	0	0	14	84	181	472	1534	2700	3110	3344	3373	3218	2884	2380	1771	1123	468	18	0	0	0	0	4844
21 0	0	0	0	0	0	58	79	326	144	101	155	184	284	446	317	972	1213	403	61	0	0	0	0	0	18448
22 0	0	0	0	0	0	68	266	713	1022	1840	2426	2884	2146	2124	2034	954	1112	658	367	22	0	0	0	0	15827
23 0	0	0	0	0	0	50	374	560	480	655	1732	1870	2232	1483	2088	1753	1184	877	346	83	0	0	0	0	34784M
24 0	0	0	0	0	7	258	774	1537M	2058	2707	2790	2635	2718	3186	2225	1750	1037	713	317	40	0	0	0	0	28840M
25 0	0	0	0	0	11	188	888M	1570M	2218	2768	3182	3420	3480	3301	2948	2437	1825	1141	500	65	0	0	0	0	28283M
26 0	0	0	0	0	11	184	875M	1534M	2174	2718	3150	3316	3380	3251	2884	2412	1822	1004	472	68	0	0	0	0	28784M
27 0	0	0	0	0	11	187	838M	1508	2156	2704	3100	3326	3380	3215	2859	2408	1800	1052	188	25	0	0	0	0	18312
28 0	0	0	0	0	4	83	227	398	540	220	798	1813	2082	3330	3042	2480	1828	1177	522	58	0	0	0	0	27088M
28 0	0	0	0	0	0	84	748	1528M	2174	2740	3158	3384	3452	3276	2614	2117	1339	804	438	54	0	0	0	0	---
30 0	0	0	0	0	4	173	487	662	1608	2182	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
MEAN	0	0	0	0	5	143	621M	1117M	1600	2044	24108	26828	27348	25168	23868	19278	14958	10038	4128	468	0	0	0	0	23080M

27/03 III-5/5  
NPPM-SBQ-007





ENERCON SERVICES, INC.

SHEET IV-1 OF 5

JOB NO. NP-110 DATE 12/13/89  
PROJECT CNS STATION BLACKOUT  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR E. Hancock  
REVIEWER [Signature] APPROVED \_\_\_\_\_  
CALCULATION NO. NPP1-SBQ-007

ATTACHMENT IV

CNS CONTROL ROOM ROOF INSULATION INFORMATION

EX 111 11-10  
NPP-5B0-007

10/24/89

EO HOLCOMB,

IT TURNS OUT THAT THE ENTIRE CONTROL GLOB ROOF WAS REPLACED ABOUT SIX MONTHS AGO. THE ATTACHED LETTER DETAILS THE SPECIFICATIONS FOR THE NEW CONTROL GLOB ROOF. I CALLED THE FIRESTONE TECHNICAL SERVICES DEPARTMENT (1-800-428-4511) AND ASKED THE R VALUE FOR 2 5/8" OF FIRESTONE ISO 95 ROOF INSULATION. I WAS INFORMED IT WAS R20. THE FIRESTONE ADDRESS IS BELOW.

FIRESTONE BUILDING PRODUCTS CO.  
3500 W. DEPAUW BLVD  
INDIANAPOLIS, IN 46268

IF YOU HAVE ANY QUESTIONS PLEASE CALL!!

- Bill

# INDEPENDENT ROOFING CO.

901 South 40th Street • Omaha, Nebraska 68105 • Phone (402) 348-0909

NPP1-584-007

IV-3/5

*Est JH*

April 25, 1989

6

Gary Stuchal  
Nebraska Public Power District  
Post Office Box 98  
Brownville, Nebraska

RE: AS BUILT DRAWINGS  
CONTRACT 87-30

Gary:

Listed below are the specifications used for each roof:

Rad Waste Roof:

Firestone Building Products  
Fully Adhered Roof System  
Firestone ISO 95 Roof Insulation  
2 5/8" Thickness  
Rawl Drive Mechanical Fasteners


Panhouse roof insulation was replaced per Firestone recommendations.

Control Building Roof:

Firestone Building Products  
Fully Adhered Roof System  
Firestone ISO 95 Roof Insulation  
2 5/8" Thickness  
Rawl Drive Mechanical Fasteners

Machine Shop/Water Treatment Roof:

Firestone Building Products  
Ballasted Roof System  
Firestone ISO 95 Roof Insulation  
2 5/8" Thickness  
Firestone AP Roof Fasteners



JOB NO. NF-110                      DATE 11/30/89  
PROJECT CNS STATION BLACKOUT (SBO)  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NFPD                      ORIGINATOR E. Holcomb  
REVIEWER [Signature]                      APPROVED \_\_\_\_\_  
CALCULATION NO. NFP1-SBO-007

SUMMARY OF TELEPHONE CONVERSATION

DATE:            October 23, 1989  
FROM:            John Brandon, Enercon Services  
TO:                Mark Eastwood, Firestone Building Products  
TEL. NO:        1-800-428-4511  
SUBJECT:        NFPD Control Building Roof Insulation and Waterproofing

Mr. Mark Eastwood of Firestone was contacted concerning the thermal properties of Firestone ISO 95 2-5/8" Roof Insulation. The following information was given:

Material

ISO 95 consists of a polyisocyanate (urethane) foam matrix containing Freon F-11 gas.

JOB NO. NF-110 DATE 11/30/89  
PROJECT CNS STATION BLACKOUT (SBO)  
SUBJECT CONTROL ROOM HEATUR  
CLIENT NPPD ORIGINATOR E. Holcomb  
REVIEWER [Signature] APPROVED \_\_\_\_\_  
CALCULATION NO. NPP1-SBO-007

### Thermal Properties


Density = 1.9 lb/cu ft

Thermal Conductivity = 0.131 BTU-in/hr-sq ft-F

Specific heat was not known; however, Mr. Eastwood recommended that the specific heat of Freon R-11 be used since it makes up the bulk of the volume of the insulation material.

### Waterproofing

Mr. Eastwood also stated that a layer of waterproofing material is always applied on top of the ISO 95 insulation. A thin layer, less than one inch, of rubber or asphalt is commonly used.




EMERCON SERVICES, INC.

JOB NO. NP-110 DATE 12/12/89  
PROJECT CNS STATION BLACKOUT  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR J. J. [Signature]  
REVIEWER [Signature] APPROVED \_\_\_\_\_  
CALCULATION NO. NPP1-580-007

ATTACHMENT V

SUMMARY of CONTROL ROOM ELECTRICAL LOADS



JOB NO. NP-110 DATE 12/12/89  
 PROJECT CNS STATION BLACKOUT  
 SUBJECT CONTROL ROOM HEATUP  
 CLIENT NPPD ORIGINATOR E. Holman  
 REVIEWER [Signature] APPROVED \_\_\_\_\_  
 CALCULATION NO. NPPD-588-007

SUMMARY of CONTROL ROOM  
ELECTRICAL LOADS

EMERGENCY LIGHTING 360 W  
 (30 - 12W BULBS)  
 INDICATING LIGHTS 344 W  
 (SHEETS 4 & 5 of NEDC-89-1947)

AC LOADS

COMPUTER SYSTEM (Exhibit B) 3960 W  
 NO-BREAK POWER PANEL (see calc. #1947) 4753 W  
 SECURITY SYSTEM (Exhibit C & calc. #1947) 1494 W

DC LOADS

DIV. I and DIV. II (see calc. #1947 & Exhibit A) 2721 W  
 ANNUNCIATORS (Exhibit D) 1938 W


PERSONNEL

(see Ref. 10)

879 W

TOTAL 16,449 W

NOTE: REFER TO NPPD CALC. NEDC-89-1947 FIG. A  
 DETAILED BREAKDOWN OF AC and DC LOADS.



JOB NO. NP-110 DATE 12/12/89  
 PROJECT CNS STATION BLACKOUT  
 SUBJECT CONTROL ROOM HEATUP  
 CLIENT NPPD ORIGINATOR E. J. H. Hunt  
 REVIEWER [Signature] APPROVED \_\_\_\_\_  
 CALCULATION NO. NPP1-5B6-007

EXHIBIT ALOAD SUBDIVISION BY BOARD (NBPP & DC) (a)

(CONTROL ROOM)

<u>BOARD</u>	<u>I</u>	<u>V</u>	<u>POWER</u>	
A	0.25 A ✓	125 VDC ✓	31.25 W ✓	
B	0.559 ✓ 1.1055 ✓	120-125 VDC ✓ 110-125 VDC ✓	67.393 ✓ 135.5375 ✓	
F	0.3302	125 VDC ✓	41.275 ✓	
FA	1.003 ✓ 3.029 ✓ 1.375 ✓	110-125 VDC ✓ 110-125 VDC ✓ 120 VAC ✓	122.010 ✓ 378.190 ✓ 165.0 ✓	cos φ = 1 ✓
H	1.84 ✓	120 VAC ✓	220.8 ✓	cos φ = 1 ✓
K	0.072 V	125 VDC ✓	9.0 ✓	
9-2	1.078 ✓	120 VAC ✓	129.36 ✓	cos φ = 1 ✓
9-3	0.954 ✓ 5.3515 ✓	125 VDC ✓ 125 VDC ✓	119.25 ✓ 668.9375 ✓	
9-4	14.791 ✓ 0.6875 ✓	120 VAC ✓ 125 VDC ✓	1774.920 ✓ 85.9375 ✓	cos φ = 1 ✓
9-13	0.4709 ✓	125 VDC ✓	58.8625 ✓	
9-15	3.9895 ✓	110-125 VDC ✓	498.5825 ✓	
9-17	4.0410 ✓	125 VDC ✓	505.125 ✓	
9-18	1.204 ✓	120 VAC ✓	144.48 ✓	cos φ = 1 ✓
9-27	—	—	2318.4 W ✓	cos φ = 0.8 ✓

(a) SEE NPPD CALC. NEDC-89-1947.

TOTAL

7474.2505 WATTS ✓



V-4/6  
NPP1-580-007

ERT DS

EXHIBIT B

CNS CONTROL ROOM  
COMPUTER SYSTEM LOAD SUMMARY

- Breakers #13 and #14 of No-Break Panel (120 VAC)

5 Franklin Model FT-286 Telecom  
Display Units @ 600W ea. 3000W

1 IBM 13" Monitor 120W

1 Printer 440W

4 Mega Trend CRT's @ 100W ea. 400W

TOTAL = 3960W /

10/30/89

09:28

NPPD COLUMBUS, NE. WP

002

OCT 27 '89 15:38

CALC. NPP1-5Bφ-007

759 P02

V-5/6

EA JA

EXHIBIT C

SAB CONSOLE HEAT LOAD AND STEADY STATE AMPERES

1. Uninterruptible Power Supply (UPS)

NORMAL LOAD WATTS  
1494 W

BTU/HR  
5098

NORMAL LOAD AMPERES  
12.45 A

2. NON-UPS

CONVENIENCE LOAD WATTS  
480 W

BTU/HR  
1638

CONVENIENCE LOAD AMPERES  
4 A

NOTE: The NON-UPS loads represent an estimated value during SAB Console Maintenance. Under normal conditions, no load is present on the power distribution system.

NOTED

OCT 27 1989

W.L.S.

NEBRASKA PUBLIC POWER DISTRICT

V-6/6

Date October 11, 1989  
To W. L. Swantz - Columbus General Office  
From A. M. Morisi - Columbus General Office  
Subject Annunciator System Lampbox Station Blackout Heat Loading

CALC. NPS1-580-007

FOR INTER-DISTRICT  
BUSINESS ONLY

The purpose of this memo is to provide an engineering evaluation of the Control Room heat loading during a Station Blackout condition due to the control panel Annunciator System lampboxes.

The total number of annunciator windows will be 1275, of which 307 are spares. Thus, there will be 969 active windows.

The estimated heat loading during a Station Blackout condition would therefore be 1938 watts. This value was determined based on the following assumptions:


1. The most lights to be energized under the worst case scenario is 50% of the active windows.
2. All electrical input is converted to heat.

Based on these assumptions and the wattage value for the type of bulbs being used: part No. 1829 (refer to attached Ronan Drawing 15-5311-D9, Revision 1); 2 watts each (refer to attached Rona Lamp Cabinet and Indicator catalog pages), the total wattage was calculated as follows:

	Total number of active windows	=	969
times	2 bulbs/window	=	1,938
times	2 watts/bulb	=	3,876
times	50% of the active windows ON at any one time	=	1,938 watts

*Alan M. Morisi*  
A. M. Morisi  
Engineering Consultant  
Nuclear Projects & Construction

AMM:dh96.1b



ENERCON SERVICES, INC.

SHEET VI-1 OF 6

JOB NO. NP-110 DATE 12/11/89  
PROJECT CNS STATION BLACKOUT  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR E. Holcomb  
REVIEWER J. P. [unclear] APPROVED \_\_\_\_\_  
CALCULATION NO. NPPI-588-007

ATTACHMENT VI

DETAILS of LEAKAGE COEFFICIENT CALCULATIONS

for CONTEMPT-LT/028 INPHT DECK

LEAKAGES

VI-2/6  
NPM-586-007  
EAT 04

a) SE DBL. DOORS (TO SOUTH)

$W = 6' 5''$  from DWG. 4526

• Assume  $\frac{1}{2}''$  clearance between door and floor

$$\frac{A_T}{A_{IN}} = 4.5061 E-03$$
$$A_T = 6.4167' \times \frac{1}{2}'' \times \frac{1}{2}'' = 0.2674 \text{ ft}^3$$
$$A_{IN} = A_{EXIT} = \begin{matrix} 7.4167' & \times & 8' & = & 59.3336 \text{ ft}^3 \\ \text{CORRIDOR} & & \text{DOOR} & & \\ \text{WIDTH} & & \text{HT.} & & \end{matrix}$$

b) NE DBL. DOORS (TO COMPUTER ROOM)

$W = 5.5'$  (SCALING from DWG.)

• Assume  $\frac{1}{2}''$  clearance between door and floor

$$A_{IN} = 5.5' \times 11.33' = 62.32$$

$$A_{EXIT} = \text{same} = 62.32$$

$$A_T = \frac{1}{2}'' \times \frac{1}{2}'' \times 5.5' = 0.2292 \text{ ft}^3$$

$$\frac{A_T}{A_{IN}} = \frac{A_T}{A_{EXIT}} = \frac{\frac{1}{24}}{11\frac{1}{3}} = 3.6765 E-03$$

Assume crack width = 0.1" for top and sides; 0.5" for bottom.

(ASHRAE) From p. 21.4,  $Q = C(\Delta P)^m$ , Let  $m = 1$ .

$$m = pQ = C p \Delta P$$

LT20  
 MANUAL p. 20  $m = K_L p \Delta P$

$$C \equiv \frac{\text{vol. flow / unit length / unit } \Delta P}{\text{or area}}$$

Then,  $C \cdot L = K_L$ , or  $C \cdot A = K_L$ , but  
 simpler just to equate flows.

a) The average crack width is  $(3 \times 0.1" + 0.5") / 4 = 0.2"$

b) Using Fig. 7 on ASHRAE pg. 21.7,

$$Q \approx 680 \text{ cfm @ } 0.2" \text{ and @ } \Delta P = 0.30 \text{ in. H}_2\text{O}$$

The perimeter of the elevator door in  
 Fig. 7 is  $2 \times (3.5 + 7') = 21'$ .

ENS

$$\text{SE DOOR - perimeter} = 2 \times (6.4167' + 9') = 28.83'$$

$$\text{NE DOOR - " = } 2 \times (5.5 + 8') = 27'$$

$$\Rightarrow Q_{SE} = \frac{28.83}{21} \times 680 = 934 \text{ cfm}$$

$$Q_{NE} = \frac{27}{21} \times 680 = 874 \text{ cfm}$$

Using Fig. 7,

VI-4/6  
NPP1-588-007  
ESD

$$0.30 \text{ in. } H_2O = 75 \frac{N}{m^2} + \frac{1m^2}{39.37^2 \text{ in}^2} + \frac{11 \text{ in}^2}{4.44822 N}$$

$$= 0.010878 \text{ } \frac{\text{in}^2}{\text{in}^2}$$

Adjust Q for different  $\Delta P$  according to  
 $(\Delta P / 0.30)^{0.515}$  or  $(\Delta P / 75)^{0.55}$ , see Fig. 7.

<u>inches <math>H_2O</math></u>	<u><math>\Delta P</math> <math>\frac{\text{in}^2}{\text{in}^2}</math></u>	<u><math>Q_{SE}</math></u>	<u><math>Q_{NE}</math></u>	<u><math>K_{LSE}</math></u>	<u><math>K_{LNE}</math></u>
		(CFM)			
0.0	0.0	0.	0.		
0.01	$3.626E-04$	144.	135.	$2.3828E7$	$2.2339E7$
0.1	$3.626E-03$	510.	478.	$8.4391E6$	$7.9095E6$
0.3	0.010878	934	874	$5.1517E6$	$4.8207E6$
0.6	0.021756	1367	1280	$3.7700E6$	$3.5301E6$
0.9	0.032634	1709	1599	$3.1421E6$	$2.9399E6$
1.2"	0.043512	2002	1873	$2.7606E6$	$2.5827E6$
27.578"	1.0	11227	10505	$6.7362E5$	$6.3030E5$

Use the smaller door (and flow rate) for the  
 LTSS input deck to be conservative.

VI-5/6  
NPPA-SBP-007  
EPA

SAMPLE CHECK OF TABULATED VALUES

$$m = p Q = K_L p (p_i - p_e)$$

$$\Rightarrow Q = K_L \Delta P \quad ; \quad Q \text{ from Fig. 7.}$$

$$\Rightarrow K_L = \frac{Q}{\Delta P}$$

Equate flows, then

convert Q to CFM and divide by  $\Delta P$ .

Ex.

$$Q = 934 \text{ CFM} = 56,040 \frac{\text{ft}^3}{\text{hr}}$$

$$\frac{Q}{\Delta P} = \frac{Q}{0.010878 \frac{\text{lb}}{\text{in}^2}} = 5.1517506 \frac{\text{ft}^3 - \text{in}^2}{\text{hr} - \text{lb}}$$

$$= 1.4310503 \frac{\text{ft}^3 - \text{in}^2}{\text{sec} - \text{lb}}$$

code input units




VI-6/6  
NPP1-SBφ-007

~~82~~ ~~04~~

NORMAL LEAKAGE

		$\Delta P$	$K_L$
30301	0	0.	0.
30302	0	$3.626E-04$	$2.2339E7$
30303	0	$3.626E-03$	$7.9095E6$
30304	0	0.010878	$4.8207E6$
30305	0	0.021756	$3.5301E6$
30306	0	0.032634	$2.9399E6$
30307	0	0.043512	$2.5827E6$
30308	0	1.0	$6.3030E5$



ENERCON SERVICES, INC.

SHEET \_\_\_\_\_ OF \_\_\_\_\_

JOB NO. NP-110 DATE 12/12/89  
PROJECT CNS STATION BLACKOUT  
SUBJECT CONTROL ROOM HEATUP  
CLIENT NPPD ORIGINATOR E. J. Hunt  
REVIEWER J. P. ... APPROVED \_\_\_\_\_  
CALCULATION NO. NPP1-SBφ-007

ATTACHMENT VII

CONTEMPT-LT/028 INPUT and OUTPUT  
for the  
4-HOUR SBφ SIMULATION



\*\*\*\*\*  
 \*\* POWER COMPUTING COMPANY GALIB \*\*  
 \*\* CONTEMPT NEWS BULLETIN \*\*  
 \*\*\*\*\*

ACCESS  
 \*\*\*\*\*

BEGIN, CONTEMPT, VER= 1= 0= .CM= .EC= .NEWS= .WATER=  
 PLOT= .GDFILE=  
 PLOTTER= . ( PLOTTING PARAMETERS)

THE FOLLOWING VERSION(S) ARE AVAILABLE

VER=

JUL82

CONTEMPT LT-2R FROM NESC (ARGONNE)  
 INCLUDES ENERGY INC. MODIFICATIONS  
 TO FIX THE MK I & MK II MODELS,  
 AND THE PRESSURE-FLASH MODEL  
 THIS VERSION IS THE SAME AS THE CONTEMPT  
 LT2B V-JUL82 ON NDS/BE

THE PARAMETERS AND THEIR DEFAULTS AND DESCRIPTIONS ARE

VER= VERSION (NO DEFAULT - MUST BE EQUAL TO THE  
 VALUE LISTED ABOVE)  
 NEWS=YES PRINT THE NEWS FILE (MUST = YES OR NO)  
 CM= CENTRAL MEMORY IN OCTAL WORDS (DEFAULT=360000)  
 EC= EXTENDED CORE IN THOUSAND OCTAL WORDS (DEFAULT=1)  
 I= INPUT FILE (DEFAULT=INPUT)  
 O= OUTPUT FILE (DEFAULT=OUTPUT)  
 WATER= PERMANENT FILE NAME OF WATER TABLES  
 (WATER DEFAULTS TO PCC'S GALIB WATER TABLE FILE)  
 PLOT=NO PLOT THE PCCGDF IF IT EXISTS ( MUST = YES OR NO)  
 GDFILE=PCCGDF  
 PLOTTER=CENTRAL  
 H=HANDLS  
 P1= PLOTTING PARAMETERS  
 P2= PLOTTING PARAMETERS  
 P3= PLOTTING PARAMETERS  
 P4= DRIVER  
 P5= PARAMS  
 P6= PLOTTING PARAMETERS

CONTINUED

11/1/06 MUIK

BHAK0001 2025

```

*****
** POWER COMPUTING COMPANY QALIB **
** CONTEMPT NEWS BULLETIN **
*****

```

```

ACCESS
*****

```

```

BEGIN, CONTEMPT, VER= .I= .D= .CM= .EC= .NEWS= .WATER=
PLOT= .GDFILE=
PLOTTER= . ( PLOTTING PARAMETERS)

```

THE FOLLOWING VERSION(S) ARE AVAILABLE

```

VER=
-----
-JUL82
CONTEMPT 11-28 FROM NESC (ARGONNE)
INCLUDES ENERGY INC. MODIFICATIONS
TO FIX THE MK I & MK II MODELS,
AND THE PRESSURE-FLASH MODEL.
THIS VERSION IS THE SAME AS THE CONTEMPT
LT28 V=JUL82 ON NDS/BE.

```

THE PARAMETERS AND THEIR DEFAULTS AND DESCRIPTIONS ARE  
 VER= VERSION (NO DEFAULT - MUST BE EQUAL TO THE  
 VALUE LISTED ABOVE)

```

NEWS=YES PRINT THE NEWS FILE (MUST = YES OR NO)
CM= CENTRAL MEMORY IN OCTAL WORDS (DEFAULT=360000)
EC= EXTENDED CORE IN THOUSAND OCTAL WORDS (DEFAULT=1)
I= INPUT FILE (DEFAULT=INPUT)
O= OUTPUT FILE (DEFAULT=OUTPUT)
WATER= PERMANENT FILE NAME OF WATER TABLES
SWATER DEFAULTS TO PCC'S QALIB WATER TABLE FILE)
PLOT=NO PLOT THE PCCGDF IF IT EXISTS ( MUST = YES OR NO)

```

```

PLOT=NO
GDFILE=PCCGDF
PLOTTER=CENTRAL
H=HANDLE
P1= PLOTTER
P2= PLOTTER
P3= PLOTTER
P4= DRIVER
P5= PARS
P6=
-----
STANDARD PCCPOST PLOTTING PARAMETERS

```

..... CONTINUED

DOCUMENTATION  
\*\*\*\*\*

NAME AND DATE OF MANUAL

ORDER FROM

USER'S MANUAL NUREG/CR-0255 (MAR 79)  
\*CONTEMPT-LT/28 - A COMPUTER PROGRAM FOR  
PREDICTING CONTAINMENT PRESSURE-TEMPERATURE  
RESPONSE TO A LOSS-OF-COOLANT ACCIDENT\*

PCC TECHNICAL LIBRARY

SUPPORT  
\*\*\*\*\*

FOR SUPPORT, CONTACT THE POWER COMPUTING COMPANY CYBER HELPDESK AT:  
(214) 655-8676 OR. (800) 351-1893 (US)  
(800) 442-6407 (TX)

..... CONTINUED

LISTING OF INPUT DATA FOR CASE 1

1	* COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS								
2	* SINGLE VOLUME MODEL OF CONTROL ROOM								
3	* UNIFORMLY DISTRIBUTED HEAT LOAD								
4	11000 BRITISH	6	0	91.4	14.7	0.60	90	0	0
5	11001 VOL	4	0	73.4	73.4	0.60	1	1	1
6	10011 0.2	0	0	73.4	73.4	0.40	4454	1	1
7	10031 54018	0	0	73.4	73.4	0.40	4454	1	1
8	* TIMESTEP CONTROL								
9	90000 SEC	60	0	1	100	300			
10	90001 600	0	1	600	3000				
11	90002 2400	0	1	600	3000				
12	90003 14400	0	1	3000	18000				
13	90004 14400	0	1	3000	18000				
14	* OUTSIDE AIR TEMPERATURE								
15	1001 0.0	91.4	0.2						
16	1002 1	92.8	0.2						
17	1003 2	93.7	0.2						
18	1004 3	94.0	0.2						
19	1005 4	93.7	0.2						
20	1006 24	93.7	-0.2						
21	* DECAY POWER TABLE MULTIPLIERS FOR HEAT STRUCTURES								
22	101 0	1.0							
23	102 15000	1.0							
24	* MULTIPLIERS USED FOR CONSISTENCY W/4XX CARDS								
25	201 0	0.0							
26	202 15000	0.0							
27	300 SEC LBW/SEC BTU/LBW								
28	301 0	0							
29	302 14400	0							
30	* ENERGY MULTIPLIERS FOR USE W/4XX & 2XX CARDS								
31	401 0	1.0	1.0						
32	402 15000	1.0	1.0						
33	* DISTRIBUTED HEAT RELEASE WITHIN VOLUME								
34	* INCLUDES ALL INTERNAL ENERGY IN CONTROL ROOM								
35	* TIME MOD: BTU/HR								
36	501 HR	56140	BTU/HR						
37	502 4	0	56140						
38	* CONTROL ROOM LEAKAGE **								
39	30301 0	0	0						
40	30302 0.4	2	2339E+07						
41	30303 0.3	7	9095E+06						
42	30304 0.10878	4	8207E+06						
43	30305 0.021756	3	5301E+06						
44	30306 0.032634	2	9399E+06						
45	30307 0.023512	2	5827E+06						
46	30308 1.0	6	3030E+05						
47	30309								
48	30310								
49	30311								
50	30312								
51	101000 NORTH WALL								
52	101001 14	3	0	0	0	726	3	0	3
53	101002 8	2	0	0	0	333			
54	101003 4	2	3854						
55	101004 1	2	3854						
56	101005 1	1	CONCRETE						



SAMPLE JOB SETUPS FOR CYBER NOS2 SYSTEM:

1. EXECUTE CONTEMPT, SAVE PLOT DATA PCCGDF.

```
JOB ...
USER ...
CHARGE ...
ATTACHP,CNTMPTLT28...QALIB
PFGET,PF=INFILE
BEGIN,CNTMPT,VER=JULB2,I=INFILE
PFSAVE,LF=PCCGDF,PF=PERMFILE
```

2. EXECUTE CONTEMPT, RUN THE PLOT PROGRAM, PCCPOST,  
AND PLOT THE OUTPUT AT THE CENTRAL DALLAS SITE  
(INPUT DATA IS IN THE SECOND RECORD FOLLOWING THE JCL.)

```
JOB ...
USER ...
CHARGE ...
ATTACHP,CNTMPTLT28...QALIB
PFGET,PF=URFILE
COPYBR,INPUT,HANDLE
BEGIN,CNTMPT,VER=JULB2,PLOT=YES
--- /*EOR ---
ADDRS YOUR NAME
ADDRS YOUR COMPANY
ADDRS STREET ADDRESS
ADDRS CITY-STATE-ZIP
INSTR PLS SEND PLOTS BY EXPRESS DELIVERY, ETC...
--- /*EOR ---
- DATA FOR CONTEMPT-LT28 GOES HERE -
--- /*EOR ---
```

3. RUN THE STANDARD TEST PROBLEM.

```
JOB ...
USER ...
CHARGE ...
ATTACHP,CNTMPTLT28...QALIB
ATTACHP,CNTMPTLT28...QALIB,SAMPINP
BEGIN,CNTMPT,VER=JULB2,I=TAPE5,PLOT=YES,H=INPUT
--- /*EOR ---
ADDRS YOUR NAME
ADDRS YOUR COMPANY
ADDRS STREET ADDRESS
ADDRS CITY-STATE-ZIP
INSTR PLS SEND PLOTS BY EXPRESS DELIVERY, ETC.
```



115	106201	3	*FACED PANELS	
116	106202	2	*AIR	
117	106203	1	*CONCRETE	
118	5204	2	*AIR	
119	106205	3	*FACED PANELS	
120	106300	0	0	
121	106400	50	4	50 0
122	106410	73.4		
123	**			
124	*** MATERIAL PROPERTIES ***			
125	**	K	RHO*CP	
126	410001	1.05	22.152	*CONCRETE
127	410002	0.0731	0.01752	*WALL AIR
128	410003	0.067	9.86	*FACED PANELS
129	410004	0.062	13.209	*GYPSUM
130	410005	0.035	3.22	*ACOUSTIC TILE
131	410006	0.0938	24.5	*WATERPROOFING
132	410007	31.0	54.279	*STEEL
133	410008	0.2119	0.01752	*ROOF AIR 1
134	410009	0.5509	0.01752	*ROOF AIR 2
135	***END OF DATA DECK***			

BRIEF UNITS USED FOR INPUT AND OUTPUT WHERE UNITS ARE UNSPECIFIED

PROBLEM END TIME = 4.00000E+00 HRS. NO. HEAT STRUCTURES = 6. PRESSURE SUPPRESSION OPT. = 0  
 OUTSIDE AIR TEMPERATURE = 9.14000E+01 F. PRESSURE = 1.47000E+01 PSIA. HUMIDITY = 6.00000E-01  
 CONSTANT TEMP. FOR HEAT SLABS = 9.00000E+01 F. STEP WATER TO DRY WELL = 0. LBM. WITH STEP ENERGY = 0. BTU  
 PRIMARY SYSTEM END-OF-BLOWDOWN WATER CONTENT = 0. LBM. WITH ENERGY = 0. BTU  
 PROBLEM EXECUTION STOPS WHEN TOTAL PRESSURE EXCEEDS 20.0000 PSIA

SPRAY-ECC HEAT EXCHANGER, NO. 1  
 TYPE = 0. HEAT TRANSFER AREA = 0. OVERALL H.T. COEFF. = 0. COOLANT INLET TEMP. = 0.  
 INLET MASS FLOW = 0.  
 PRESSURE FOR SPRAY ON AND OFF = 0.

SPRAY-ECC HEAT EXCHANGER, NO. 2  
 TYPE = 0. HEAT TRANSFER AREA = 0. OVERALL H.T. COEFF. = 0. COOLANT INLET TEMP. = 0.  
 INLET MASS FLOW = 0.  
 PRESSURE FOR SPRAY ON AND OFF = 0.

COMP. 1 VOL. = 2.00000E-01 LIQ. VOL. = 0. VAPOR VOL. = 2.00000E-01 HUMIDITY = 6000. TOTAL PRESSURE = 1.470000E+01  
 VAPOR TEMPERATURE = 7.340000E+01 LIQ. TEMP. = 7.340000E+01 SURF. AREA = 1.000000E+00  
 HEAT TRANS. MULT. = 1.000000E+00 MASS TRANS. MULT. = 1.000000E+00

COMP. 3 VOL. = 5.401800E+04 LIQ. VOL. = 0. VAPOR VOL. = 5.401800E+04 HUMIDITY = 4000. TOTAL PRESSURE = 1.470000E+01  
 VAPOR TEMPERATURE = 7.340000E+01 LIQ. TEMP. = 7.340000E+01 SURF. AREA = 4.454000E+03  
 HEAT TRANS. MULT. = 1.000000E+00 MASS TRANS. MULT. = 1.000000E+00  
 DRYWELL TEMPERATURE FLASH MODEL SELECTED

NORMAL COMPARTMENT LEAKAGE TABLE OF DELTA-PRESSURE AND COEFFICIENT -- FROM COMPARTMENT 3 TO 0

0.	3.626000E-04	2.233900E+07
3.626000E-03	7.909500E+06	1.087800E-02
2.175600E-02	3.530100E+06	3.263400E-02
4.351200E-02	2.582700E+06	1.000000E+00

TABLE OF TIME, POWER DECAY  
 0. 1.000000E+06 1.500000E+04 1.000000E+00

TABLE OF TIME, METAL-WATER REACTION  
 0. 1.500000E+04 0.

TABLE OF TIME, SEC. J, WATER ADDITION RATE (LBM/SEC.) AND ENTHALPY (BTU/LBM.)  
 0. 0. 0. 1.440000E+04 0. 0.

PRIMARY VESSEL ENERGY INPUT, TIME, POWER MULT., M-W MULT.  
 0. 1.000000E+00 1.000000E+00 1.500000E+04 1.000000E+00 1.000000E+00

TOP REGION DIRECT ADDITION TABLE, TIME, WATER RATE, HEAT RATE  
 0. 0. 5.614000E+04 4.000000E+00 0. 5.614000E+04

LIQUID REGION DIRECT ADDITION TABLE, TIME, WATER RATE, HEAT RATE  
 0. 0. 0. 1.000000E+06 0. 0.

SUPER HEAT ADDITION TABLE, TIME, POW. MULT., M-W MULT., FLOW RATE  
 0. 0. 0. 0. 0.  
 1.000000E+00 0. 0. 0. 0.

CONTEMPT-11/02B.30 APRIL 1978, EG&G IDAHO INC. CONTAINMENT SYSTEM PRESSURE TEMPERATURE HISTORY PROGRAM  
89/12/14  
COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS

SPRAY-ECC SYSTEM, NO 1

TIME	FLOW RATE	DR W EFF	PCT DRY	PCT WET	PCT ECC	PCT DWL	IMP DRY	IMP WET	OUT TEMP
0	0	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0
1.000000E+06	0	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0

SPRAY-ECC SYSTEM, NO 2

TIME	FLOW RATE	DR W EFF	PCT DRY	PCT WET	PCT ECC	PCT DWL	IMP DRY	IMP WET	OUT TEMP
0	0	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0
1.000000E+06	0	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0

ARBITRARY AIR ADDITION TABLE, TIME, AIR ADDED, TEMP.

0	0	0
3.600000E+09	0	0

OUTSIDE AIR CONDITIONS TABLE, TIME, TEMP., HEAT TRANSFER COEF (24 HR CYCLE)

0	9.140000E+01	2.000000E-01	1.000000E+00	9.280000E+01	2.000000E-01
2.000000E+00	9.370000E+01	2.000000E-01	3.000000E+00	9.400000E+01	2.000000E-01
4.000000E+00	9.370000E+01	2.000000E-01	2.400000E+01	9.370000E+01	2.000000E-01

TABLE OF TIME, TIME STEP (BOTH IN SEC), SLAB PRINT FREQUENCY, AND CONTAINMENT DATA PRINT FREQUENCY

6.000000E+01	100	300	6.000000E+02	1.000000E-01	600	3000
2.400000E+03	1.000000E-01	3000	1.440000E+04	1.000000E-01	3000	18000

HEAT STRUCTURE NO 1 TRANSFER BETWEEN FOLLOWING COMPARTMENTS LEFT= 0 RIGHT= 3

14 MESH POINTS 3 REGIONS RECTANGULAR GEOMETRY SOURCE FACTOR = 0. SURFACE F.FACTOR = 7.263000E+02  
 DELAY = 0.

MESH POINT COORDINATES 1\* INDICATES REGION BOUNDARY

0	2	500000E-01	5	000000E-01	7	500000E-01	1	000000E+00	1	250000E+00	1	500000E+00	
1	750000E+00	2	000000E+00	2	083325E+00	2	166650E+00	2	249975E+00	2	333300E+00	2	385400E+00

COMPOSITION OVERLAY

1 2 3

SOURCE SPATIAL DEPENDENCE

0	0	0	0	0	0	0	0	0	0	0	0	0
0	0	0	0	0	0	0	0	0	0	0	0	0

INTEGRATED SPACIAL DEPENDENCE = 0.

BOUNDARY CONDITION CONTROL OPTIONS = 1, 1.50, 4

THE INITIAL RIGHT SIDE BULK TEMPERATURE = 73.400

CONTEMP1-11/028.30 APRIL 1979. EOR&G IDAHO INC. CONTAINMENT SYSTEM PRESSURE TEMPERATURE HISTORY PROGRAM  
COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS 89/12/14

HEAT STRUCTURE NO 2 TRANSFER BETWEEN FOLLOWING COMPARTMENTS LEFT\* 3 RIGHT\* 0  
ROOF & CEILING SURFACE FACTOR = 3 235000E+03  
DELAY = 0

16 MESH POINTS 5 REGIONS RECTANGULAR GEOMETRY SOURCE FACTOR = 0

MESH POINT COORDINATES (\* INDICATES REGION BOUNDARY)  
1 20000E+01 1 206250E+01\* 1 210420E+01\* 1 229170E+01 1 237920E+01\* 1 296670E+01 1 345420E+01  
1 394170E+01 1 442920E+01 1 491670E+01\* 1 528128E+01 1 564587E+01 1 601045E+01 1 637503E+01  
1 673962E+01 1 710420E+01\*

COMPOSITION OVERLAY  
5 4 8 9 1

SOURCE SPATIAL DEPENDENCE  
0 0 0 0 0 0 0 0 0

INTEGRATED SPACIAL DEPENDENCE = 0

BOUNDARY CONDITION CONTROL OPTIONS = 6. 4. 4. 0

THE INITIAL LEFT SIDE BULK TEMPERATURE = 73.400

HEAT STRUCTURE NO 3 TRANSFER BETWEEN FOLLOWING COMPARTMENTS LEFT= 0 RIGHT= 3  
FLOOR

4 MESH POINTS 1 REGIONS RECTANGULAR GEOMETRY SOURCE FACTOR = 0. SURFACE FACTOR = 4.454000E+03  
DELAY = 0.

MESH POINT COORDINATES (\* INDICATES REGION BOUNDARY)  
0. 2.22222E-01 4.44445E-01 6.66667E-01\*

COMPOSITION OVERLAY  
1

SOURCE SPATIAL DEPENDENCE  
0. 0. 0.  
INTEGRATED SPATIAL DEPENDENCE = 0.

BOUNDARY CONDITION CONTROL OPTIONS = 6. 0. 5. 4

THE INITIAL RIGHT SIDE BULK TEMPERATURE = 73.400



CONTEMPT-11/028.30 APRIL 1978, EG&G IDIHO INC. CONTAMINANT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM  
COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS 89/12/14

HEAT STRUCTURE NO. 4 TRANSFER BETWEEN FOLLOWING COMPARTMENTS LEFT= 3 RIGHT= 0 SURFACE FACTOR = 9 132000E+02  
SOUTH WALL  
9 MESH POINTS 1 REGIONS RECTANGULAR GEOMETRY SOURCE FACTOR = 0 DELAY = 0

MESH POINT COORDINATES (\* INDICATES REGION BOUNDARY)  
7 150000E+01 7 175000E+01 7 200000E+01 7 225000E+01 7 250000E+01 7 275000E+01 7 300000E+01  
7 325000E+01 7 350000E+01\*

COMPOSITION OVERLAY

SOURCE SPATIAL DEPENDENCE 0 0 0 0 0 0 0

INTEGRATED SPACIAL DEPENDENCE = 0.

BOUNDARY CONDITION CONTROL OPTIONS = 50, 4, 50, 0

THE INITIAL LEFT SIDE BREAK TEMPERATURE = 73.400

CONEMPT-LT702B-30 APRIL 1978. EG&G IDAHO INC. CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM  
COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS 89/12/14

HEAT STRUCTURE NO. 5 TRANSFER BETWEEN FOLLOWING COMPARTMENTS LEFT= 0 RIGHT= 3  
WEST WALL

9 MESH POINTS 1 REGIONS RECTANGULAR GEOMETRY SOURCE FACTOR = 0. SURFACE FACTOR = 9.903800E+02  
DELAY = 0.

MESH POINT COORDINATES (\* INDICATES REGION BOUNDARY)  
0 2 500000E-01 5 000000E-01 7 500000E-01 1 000000E+00 1 250000E+00 1 500000E+00  
1 150000E+00 2 000000E+00\*

COMPOSITION OVERLAY

1

SOURCE SPATIAL DEPENDENCE 0 0 0 0 0 0 0 0 0

INTEGRATED SPACIAL DEPENDENCE = 0.

BOUNDARY CONDITION CONTROL OPTIONS = 50, 0, 50, 4

THE INITIAL RIGHT SIDE BULK TEMPERATURE = 73.400

HEAT STRUCTURE NO. 6 TRANSFER BETWEEN FOLLOWING COMPARTMENTS LEFT= 3 RIGHT= 0  
 EAST WALL

19 MESH POINTS 5 REGIONS RECTANGULAR GEOMETRY SOURCE FACTOR = 0 SURFACE FACTOR = 7.877000E+02  
 DELAY = 0

MESH POINT COORDINATES (\* INDICATES REGION BOUNDARY)  
 0 5.208000E-02\* 1.354100E-01 2.187400E-01 3.020700E-01 3.854000E-01\* 6.354000E-01  
 B 854000E-01 1.135400E+00 1.385400E+00 1.535400E+00 1.885400E+00 2.135400E+00 2.385400E+00\*  
 2.468725E+00 2.552050E+00 2.625375E+00 2.718700E+00\* 2.770800E+00\*

COMPOSITION OVERLAY

3 2 1 2 3

SOURCE SPATIAL DEPENDENCE  
 0 0 0 0 0 0 0  
 0 0 0 0 0 0 0  
 0 0 0 0 0 0 0

INTEGRATED SPACIAL DEPENDENCE = 0

BOUNDARY CONDITION CONTROL OPTIONS = 50, 4, 50, 0  
 THE INITIAL LEFT SIDE BULK TEMPERATURE = 73.400

TABLES COMMON TO ALL HEAT SLABS

THERMAL CONDUCTIVITY AND VOLUMETRIC HEAT CAPACITY TABLE

COMPOSITION NO.	THERMAL CONDUCTIVITY	HEAT CAPACITY
1	1.050000E+00	2.215200E+01
2	7.310000E-02	1.752000E-02
3	6.700000E-02	9.860000E+00
4	6.200000E-02	1.320900E+01
5	3.500000E-02	3.220000E+00
6	9.380000E-02	2.450000E+01
7	3.100000E+01	5.427900E+01
8	2.119000E-01	1.752000E-02
9	5.509000E-01	1.752000E-02

TABLE OF TIME, HEAT TRANS. COEFF. (TYPE 5)

0	2.100000E-01	1.440000E+04	2.100000E-01
---	--------------	--------------	--------------

TABLE OF TEMPERATURE, HEAT TRANS. COEFF. (TYPE 6)

7.000000E+01	6.138000E-01	8.000000E+01	4.828000E-01
9.000000E+01	4.785000E-01	1.000000E+02	4.742000E-01
1.100000E+02	5.920000E-01	1.200000E+02	6.716000E-01
1.500000E+02	8.250000E-01		

89/12/14

THE FOLLOWING DEFINITIONS WILL BE USED AT TIMES FOR COMPARTMENT IDENTIFICATION

- 0 = OUTSIDE ATMOSPHERE
- 1 = PRIMARY SYSTEM
- 2 = WET WELL
- 3 = DRY WELL
- 4 = ANNULAR COMPARTMENT

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -8.840826D+02 0 0 3 VAPOR 8.840826D+02 0 0  
 LEFT FILM COEF .H = 2.000000E-01 BTU/HR FT<sup>2</sup> F FIRST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 9.140000E+01 F  
 RIGHT FILM COEF .H = 3.928269E-01 BTU/HR FT<sup>2</sup> F LAST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 7.340000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.531379D+01 8.502397D+01 8.473415D+01 8.444433D+01 8.415451D+01 8.386469D+01 8.357488D+01 8.328506D+01 8.299524D+01  
 8.160773D+01 8.022022D+01 7.883272D+01 7.744521D+01 7.649867D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR 4.298599D+03 0 0 OLIGUID -4.298599D+03 0 0  
 LEFT FILM COEF .H = 5.692600E-01 BTU/HR FT<sup>2</sup> F FIRST MESH K = 3.500000E-02 BTU/HR FT BULK TEMP = 7.340000E+01 F  
 RIGHT FILM COEF .H = 1.000000E+04 BTU/HR FT<sup>2</sup> F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.573422D+01 7.810704D+01 7.900075D+01 8.017652D+01 8.135229D+01 8.252815D+01 8.370401D+01 8.487986D+01 8.605572D+01  
 8.723158D+01 8.769296D+01 8.815434D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIGUID -9.87713D+03 0 0 3 VAPOR 9.875713D+03 0 0  
 LEFT FILM COEF .H = 4.785000E-01 BTU/HR FT<sup>2</sup> F FIRST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 2.100000E-01 BTU/HR FT<sup>2</sup> F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 7.340000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.536621D+01 8.489695D+01 8.442768D+01 8.395842D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR 2.342881D+03 0 0 OLIGUID -2.342881D+03 0 0  
 LEFT FILM COEF .H = 4.285188E-01 BTU/HR FT<sup>2</sup> F FIRST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 7.340000E+01 F  
 RIGHT FILM COEF .H = 4.480471E-01 BTU/HR FT<sup>2</sup> F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.938707D+01 7.999792D+01 8.060877D+01 8.121962D+01 8.183047D+01 8.244133D+01 8.305218D+01 8.366303D+01 8.427388D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIGUID -2.540892D+03 0 0 3 VAPOR 2.540892D+03 0 0  
 LEFT FILM COEF .H = 4.480471E-01 BTU/HR FT<sup>2</sup> F FIRST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.285188E-01 BTU/HR FT<sup>2</sup> F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 7.340000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.427388D+01 8.366303D+01 8.305218D+01 8.244133D+01 8.183047D+01 8.121962D+01 8.060877D+01 7.999792D+01 7.938707D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR 7.232934D+02 0 0 OLIGUID -7.232934D+02 0 0  
 LEFT FILM COEF .H = 3.486253E-01 BTU/HR FT<sup>2</sup> F FIRST MESH K = 6.700000E-02 BTU/HR FT BULK TEMP = 7.340000E+01 F  
 RIGHT FILM COEF .H = 3.801147E-01 BTU/HR FT<sup>2</sup> F LAST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.603387D+01 7.674763D+01 7.779437D+01 7.884110D+01 7.988784D+01 8.093458D+01 8.115320D+01 8.137183D+01 8.159046D+01  
 8.180909D+01 8.202771D+01 8.224634D+01 8.246497D+01 8.268360D+01 8.273027D+01 8.277694D+01 8.282362D+01 8.287029D+01

PCC

CONTEMPT-LT/028.30 APRIL 1978. EG&G IDAHO INC. CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM  
COOPER NUCLEAR STATION CONTROL ROOM HEATER ANALYSIS 89/12/14

PAGE 14

8 7584320+01

COMP NO.	PRESSURE (PSIA)	TEMPERATURE (F)	ATMOS	ATMOS	ENERGY (BTU)	CONVERGENCE DE/E
1	1.47000+01	7.34000+01	7.34000+01	0	0	0
3	1.62860+01	7.34000+01	7.34000+01	3.916180+05	3.916180+05	0
AIR MASS (LBM) VAPOR-ATMOS-LIQUID POOL						
1	0	0	0	0	0	0
3	981820+03	2.775650+01	2.775650+01	4.000000-01	0	0
COMP. 3 LEAKAGE OUTFLOW-MASS=0 LBM/HR ENERGY BTU/HR = 0 (NORMAL=0 PENETRATION=0)						
STEP AND NET MASS LOSSES LBM STEP VAPOR=0 STEP AIR=0 NET VAPOR=0 NET AIR=0						

HEAT STRUCTURE	1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL
TO LEFT COMP	END STEP BTU/HR 1.8211540+02
TO RIGHT COMP	END STEP BTU/HR 6.5523160+02
TO VAPOR	3 VAPOR 6.5523160+02
TO FLOOR	1.050000E+00 BTU/HR FT F BULK TEMP = 9.140389E+01 F
TO CEILING	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F
TO WEST WALL	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F
TO EAST WALL	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F
TO SOUTH WALL	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F
TO NORTH WALL	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F

HEAT STRUCTURE	2 BETWEEN COMPARTMENTS 3 AND 0 RPOD & CEILING
TO LEFT COMP	END STEP BTU/HR 1.1254060+01
TO RIGHT COMP	END STEP BTU/HR -4.2985990+03
TO VAPOR	3 VAPOR -4.2985990+03
TO FLOOR	1.050000E+00 BTU/HR FT F BULK TEMP = 9.0000000+01 F
TO CEILING	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F
TO WEST WALL	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F
TO EAST WALL	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F
TO SOUTH WALL	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F
TO NORTH WALL	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F

HEAT STRUCTURE	3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR
TO LEFT COMP	END STEP BTU/HR -2.7432540+01
TO RIGHT COMP	END STEP BTU/HR 2.2314070+04
TO VAPOR	3 VAPOR 2.2314070+04
TO FLOOR	1.050000E+00 BTU/HR FT F BULK TEMP = 9.0000000+01 F
TO CEILING	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F
TO WEST WALL	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F
TO EAST WALL	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F
TO SOUTH WALL	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F
TO NORTH WALL	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F

HEAT STRUCTURE	4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL
TO LEFT COMP	END STEP BTU/HR 5.8210380+02
TO RIGHT COMP	END STEP BTU/HR -2.2138860+03
TO VAPOR	3 VAPOR -2.2138860+03
TO FLOOR	1.050000E+00 BTU/HR FT F BULK TEMP = 9.0000000+01 F
TO CEILING	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F
TO WEST WALL	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F
TO EAST WALL	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F
TO SOUTH WALL	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F
TO NORTH WALL	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F

HEAT STRUCTURE	5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL
TO LEFT COMP	END STEP BTU/HR -2.4009950+03
TO RIGHT COMP	END STEP BTU/HR 2.2720120+03
TO VAPOR	3 VAPOR 2.2720120+03
TO FLOOR	1.050000E+00 BTU/HR FT F BULK TEMP = 9.0000000+01 F
TO CEILING	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F
TO WEST WALL	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F
TO EAST WALL	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F
TO SOUTH WALL	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F
TO NORTH WALL	1.050000E+00 BTU/HR FT F BULK TEMP = 7.3655780+01 F

CONTEMP-11/028.30 APRIL 1978, EG&G IDAHO INC. CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM PAGE 06  
 COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS 89/12/14

LEFT FILM COEF, H = 4.233679E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF, H = 4.002585E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 7.365578E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 B 427374D+01 B 366303D+01 B 305218D+01 B 244133D+01 B 183047D+01 B 121962D+01 B 060877D+01 B 999792D+01 B 7.938728D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR 5.599124D+02 1.556407D-02 1.668110D+00 OL LIQUID -6.530860D-02 1.814200D-02 1.814200D+00  
 LEFT FILM COEF, H = 3.986915E-01 BTU/HR FT2 F FIRST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 7.365578E+01 F  
 RIGHT FILM COEF, H = 3.430819E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7 603555D+01 7 674764D+01 7 779437D+01 7 884110D+01 7 988784D+01 8 093453D+01 8 115370D+01 8 137183D+01 8 159046D+01  
 B 180909D+01 B 202771D+01 B 224634D+01 B 246137D+01 B 268360D+01 B 273027D+01 B 277694D+01 B 282362D+01 B 287029D+01  
 B 758336D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP.	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
0	0	-5.646366D-01	0	5.646554D+01
1	0	0	0	0
2	0	0	0	0
3	0	8.809237D-01	0	9.019771D+01
4	0	0	0	0

COMP NO	PRESSURE (PSIA)	TEMPERATURE (F)	E N E R G Y	POOL	TOTAL	CONVERSION DE/E
1	1.47000D+01	7.24000D+01	7.34000D+01	0	0	0
3	1.47000D+01	7.36555D+01	7.36555D+01	3.91616D+05	3.91616D+05	-4.40668D-07

AIR MASS (LBM)	WATER MASS (LBM)	ATMOSPHERE IS AIR (LBM)	WATER VAPOR (LBM)	ATMOSPHERE IS WATER VAPOR (LBM)	CONCENTRATION (LB/S)	TRANSFER MASS (LB)	HEAT (BTU)
0	0	0	0	0	0	0	0
3	97999D+03	2.77437D+01	0	2.77437D+01	3.96588D-01	0	0

COMP	LEAKAGE DUFFLOW MASS	ENERGY BTU/HR	PENETRATION
3	8.52122D+02	-2.458915D-02	-4.914708D+00

STEP AND NET MASS LOSSES (LBM)	STEP VAPOR	STEP AIR	NET AIR
1	1.3167D-04	1.4889D-02	1.2764D-02

TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS AIR (LBM)	TOTAL WATER VAPOR (LBM)	CONCENTRATION (LB/S)	TRANSFER MASS (LB)	HEAT (BTU)
1.83103D+00	1.83103D+00	1.276374D-02	1.276374D-02	0

\*\*\*\*\* TIME = 5.55556E-03 HR = 3.33333E-01 MIN = 2.00000E+01 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 2 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR B 852122D+02 -2.458915D-02 -4.914708D+00 J VAPOR 5.803507D+02 1.613374D-02 3.646107D+00  
 LEFT FILM COEF, H = 2.000000E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.140778E+01 F  
 RIGHT FILM COEF, H = 3.074835E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 7.390626D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 B 531375D+01 B 502397D+01 B 473415D+01 B 444330D+01 B 415250D+01 B 386469D+01 B 357488D+01 B 328506D+01 B 299524D+01  
 B 160773D+01 B 022024D+01 B 883275D+01 B 744530D+01 B 650539D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR 3.342015D+03 9.289716D-02 2.118103D+01 OL LIQUID -4.298599D+03 -1.194050D-01 -2.348111D+01  
 LEFT FILM COEF, H = 5.626280E-01 BTU/HR FT2 F FIRST MESH K = 3.500000E-02 BTU/HR FT F BULK TEMP = 7.390626E+01 F  
 RIGHT FILM COEF, H = 1.000000E-04 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 B 757424D+01 B 810706D+01 B 900075D+01 B 017652D+01 B 135229D+01 B 252815D+01 B 370404D+01 B 487986D+01 B 605572D+01  
 B 723158D+01 B 769296D+01 B 815434D+01 B 861572D+01 B 907710D+01 B 953842D+01 B 999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR



TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OIL LIQUID -9.875733D+03 -2.743254D-01 -5.486507D+01 3 VAPOR 2.157753D+04 5.994768D-01 1.238039D+02  
 LEFT FILM COEF. H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF. H = 4.822398E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 7.390626D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.536621D+01 8.489635D+01 8.442767D+01 8.395215D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR 1.973279D+03 5.482992D-02 1.164439D+01 OIL LIQUID -2.214351E+03 -6.150970D-02 -1.230116D+01  
 LEFT FILM COEF. H = 3.942165E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 7.390626E+01 F  
 RIGHT FILM COEF. H = 4.234465E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 7.938761D+01 7.999792D+01 8.060877D+01 8.121962D+01 8.183047D+01 8.244133D+01 8.305218D+01 8.366203D+01 8.427359D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OIL LIQUID -2.401499D+03 -6.670825D-02 -1.334081D+01 3 VAPOR 2.140053D+03 5.946393D-02 1.262853D+01  
 LEFT FILM COEF. H = 4.234465E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF. H = 3.942165E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 7.390626D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.427359D+01 8.366303D+01 8.305218D+01 8.244133D+01 8.183047D+01 8.121962D+01 8.060877D+01 7.999792D+01 7.938761D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR 4.834104D+02 1.343838D-02 3.116124D+00 OIL LIQUID -6.536140D+02 -1.815587D-02 -3.629232D+00  
 LEFT FILM COEF. H = 2.878471E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 7.390626E+01 F  
 RIGHT FILM COEF. H = 3.422277E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 7.602825D+01 7.674756D+01 7.779429D+01 7.884111D+01 7.988784D+01 8.093458D+01 8.145320D+01 8.137183D+01 8.159046D+01  
 8.180909D+01 8.202719D+01 8.224634D+01 8.246497D+01 8.268360D+01 8.373027D+01 8.477694D+01 8.583361D+01 8.687027D+01  
 8.758242D+01

SLURRY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP. STEP-1 VAPOR NET-VAPOR NET-LIQUID  
 0 0 -5.646939D-01 0 -1.129321D+02  
 1 0 0 0 0  
 2 0 0 0 0  
 3 0 8.362399D-01 0 1.760201D+02  
 4 0 0 0 0

COMP NO.	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	A T M O S	A T M O S	E N E R G Y (BTU)	H U M I D I T Y (LB/S)	C O N D E N S A T I O N (LB/S)	T R A N S F E R C O E F F I C I E N T S (BTU/S FT2 R)	C O N V E R G E N C E DE/E
1	1.47000D+01	0	7.34000D+01	0	0	0	0	0	0
3	1.47004D+01	1.63019D-01	7.29061D+01	3.91605D+05	0	3.91605D+05	0	-3.76653D-07	0
1	0	0	0	0	0	6.00000D-01	0	0	0
3	9.97812D+03	2.77307D+01	0	2.77307D+01	3.93266D-01	0	0	0	0
COMP	3 LEAKAGE OUTFLOW MASS	6.7186D+02 LB/HR	ENERGY BTU/HR	9.0300D+04 (NORMAL)	9.0300D+04 PENETRATION	0	0	0	0
STEP	AND NET MASS LOSSES LB/STEP	VAPOR= 1.2919D-04	STEP AIR= 1.8534D-02	NET VAPOR= 2.5805D-02	NET AIR= 3.7019D+00	0	0	0	0
TOTAL	NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 3.7019D+00	WATER VAPOR(LBM)= 2.58049D-02							

\*\*\*\*\* TIME = 8.333333E-03 HR = 5.000000E-01 MIN = 3.000000E+01 SEC \*\*\*\*\*  
 HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL

TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -8 857768D+02 -2.460483D-02 -7.374415D+00 3 VAPOR 5 096168D+02 1.416559E+02 5.459186D+00  
 LEFT FILM COEF. H = 2.000000E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 9.141167E+01 F  
 RIGHT FILM COEF. H = 2.975660E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 7.415231E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 531280D+01 8 502397D+01 8 473415D+01 8 444830D+01 8 415451D+01 8 386469D+01 8 357488D+01 8 328506D+01 8 299524D+01  
 8 160775D+01 8 022027D+01 7 883282D+01 7 744542D+01 7 651032D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR 2 895477D+03 8 049060D-02 2.983963D+01 0 LIQUID -4 298599D+03 -1.194055D-01 -3.582166D+01  
 LEFT FILM COEF. H = 5.594047E-01 BTU/HR FT2 F FIRST MESH K = 3.500000E-02 BTU/HR FT BULK TEMP = 7.415231E+01 F  
 RIGHT FILM COEF. H = 1.000000E+04 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7 575231D+01 7 810712D+01 7 900075D+01 8 017652D+01 8 135229D+01 8 370401E-01 8 487986D+01 8 605572D+01  
 8 723158D+01 8 769296D+01 8 815434D+01 8 861572D+01 8 907710D+01 8 953819D+01 8 999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 LIQUID 9 875712D+03 -2.743254D-01 -8.229761D+01 3 VAPOR 2 086085D+04 5.795664D-01 1.827416D+02  
 LEFT FILM COEF. H = 4.785000E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF. H = 4.780668E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 7.415231D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 536621D+01 8 489695D+01 8 442765D+01 8 394932D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR 1 855676D+03 5.156262D-02 1.696146D+01 0 LIQUID -2 214816D+03 -6.152261D-02 -1.845279D+01  
 LEFT FILM COEF. H = 3.88110E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 7.415231E+01 F  
 RIGHT FILM COEF. H = 4.235251E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7 948808D+01 7 999793D+01 8 060877D+01 8 121962D+01 8 183047D+01 8 244133D+01 8 305218D+01 8 366302D+01 8 427346D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 LIQUID -2 402094D+03 -6.672225D-02 -2.001234D+01 3 VAPOR 2 012513D+03 5.552049D-02 1.839498D+01  
 LEFT FILM COEF. H = 4.235251E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF. H = 3.88110E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 7.415231D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 427346D+01 8 366302D+01 8 305218D+01 8 244133D+01 8 183047D+01 8 121962D+01 8 060877D+01 7 999793D+01 7 948808D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR 4 114332D+02 1.143842D-02 4.357922D+00 0 LIQUID -6 541356D+02 -1.817036D-02 -5.445552D+00  
 LEFT FILM COEF. H = 2.764075E-01 BTU/HR FT2 F FIRST MESH K = 6.700000E-02 BTU/HR FT BULK TEMP = 7.415231E+01 F  
 RIGHT FILM COEF. H = 3.435688E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7 604206D+01 7 674776D+01 7 779443D+01 7 884113D+01 7 988785D+01 8 093458D+01 8 185320D+01 8 137183D+01 8 159346D+01  
 8 180909D+01 8 202771D+01 8 224634D+01 8 246197D+01 8 268363D+01 8 373026D+01 8 477693D+01 8 582359D+01 8 687023D+01  
 8 758150D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP. STEP LIQUID STEP VAPOR NET LIQUID NET VAPOR  
 0 0 -5.687510D+01 0 0 -1.694044D+02  
 1 0 0 0 0 0  
 2 0 0 0 0 0  
 3 0 7.931441D+01 0 0 2.574547D+02  
 4 0 0 0 0 0

COMP NO	PRESSURE (PSIA)	TEMPERATURE (F)	ENR G Y	CONVERGENCE
1	1.47000+01	7.34000+01	0	0
3	1.47000+01	7.415210+01	3.915940+05	3.915940+05
AIR MASS (LBM) W A T E R M A S S (LBM) HUMIDITY CONDENSATION (LB/S) (LB MOLS FT21BTU/S FT2 R)				
1	0	0	0	0
3	3.976280+03	2.771790+01	6.000000-01	0
COMP 3 LEAKAGE DUE TO MASS = 6.59460+02 LBM/HR ENERGY BTU/HR = 8.86720+04 (NORMAL) 8.86720+04 PENETRATION = 0				
STEP AND NET MASS LOSSES LBM STEP VAPOR = 1.26810-04 STEP AIR = 1.81920-02 NET VAPOR = 3.86030-02 NET AIR = 5.53790+00				
TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) = 5.5378500+00 WATER VAPOR(LBM) = 3.8603200-72				

\*\*\*\*\* TIME = 1.11111E-02 HR = 6.66667E-01 MIN = 4.000000E+01 SEC \*\*\*\*\*

HEAT STRUCTURE	END STEP BTU/HR	TO RIGHT COMP	END STEP BTU/HR	STEP BTU TOTAL NET BTU
1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL				
TO LEFT COMP	8.8634130+02	-2.4620510-02	9.8356900+00	1.2305020-02
TO RIGHT COMP				6.4808970+00
3 VAPOR				
LEFT FILM COEF .H = 2.000000E-01 BTU/HR FT2 F				
RIGHT FILM COEF .H = 2.871987E-01 BTU/HR FT2 F				
MESH POINT TEMPERATURES (F), LEFT TO RIGHT				
8.5313800+01	8.5023970+01	8.4734150+01	8.4444330+01	8.4154510+01
8.1607770+01	8.0220330+01	7.8832930+01	7.7445610+01	7.6516200+01

HEAT STRUCTURE	END STEP BTU/HR	TO RIGHT COMP	END STEP BTU/HR	STEP BTU TOTAL NET BTU
2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING				
TO LEFT COMP	2.4581880+03	6.8618840-02	3.7284830+01	-4.2985990+03
TO RIGHT COMP				1.1940550-01
3 VAPOR				
LEFT FILM COEF .H = 5.562374E-01 BTU/HR FT2 F				
RIGHT FILM COEF .H = 1.000000E+04 BTU/HR FT2 F				
MESH POINT TEMPERATURES (F), LEFT TO RIGHT				
8.5765740+01	7.8107210+01	7.4000750+01	8.0176520+01	8.2528150+01
8.7231580+01	8.7692960+01	8.8154340+01	8.515720+01	8.9077100+01

HEAT STRUCTURE	END STEP BTU/HR	TO RIGHT COMP	END STEP BTU/HR	STEP BTU TOTAL NET BTU
3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR				
TO LEFT COMP	9.8757730+03	-2.7432540-01	1.0973010+02	5.6018770-01
TO RIGHT COMP				2.3971520+02
3 VAPOR				
LEFT FILM COEF .H = 4.739045E-01 BTU/HR FT2 F				
RIGHT FILM COEF .H = 4.739045E-01 BTU/HR FT2 F				
MESH POINT TEMPERATURES (F), LEFT TO RIGHT				
8.5366210+01	8.4896950+01	8.4427620+01	8.3946680+01	8.6018770-01

HEAT STRUCTURE	END STEP BTU/HR	TO RIGHT COMP	END STEP BTU/HR	STEP BTU TOTAL NET BTU
4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL				
TO LEFT COMP	1.7420210+03	4.8403980-02	2.1957360+01	-2.2152800+03
TO RIGHT COMP				6.1535500-02
3 VAPOR				
LEFT FILM COEF .H = 3.819340E-01 BTU/HR FT2 F				
RIGHT FILM COEF .H = 4.236036E-01 BTU/HR FT2 F				
MESH POINT TEMPERATURES (F), LEFT TO RIGHT				
7.9388670+01	7.9997930+01	8.0608770+01	8.1219620+01	8.3052180+01

HEAT STRUCTURE	END STEP BTU/HR	TO RIGHT COMP	END STEP BTU/HR	STEP BTU TOTAL NET BTU
5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL				
TO LEFT COMP	2.4025070+03	-6.6736240-02	2.6685270+01	5.2495970-02
TO RIGHT COMP				2.3813110+01
3 VAPOR				
LEFT FILM COEF .H = 4.236036E-01 BTU/HR FT2 F				
RIGHT FILM COEF .H = 3.819340E-01 BTU/HR FT2 F				
MESH POINT TEMPERATURES (F), LEFT TO RIGHT				
8.18892490+03	8.18892490+03	8.18892490+03	8.18892490+03	8.18892490+03

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 427332D+01 8 366302D+01 8 305218D+01 8 244133D+01 8 183047D+01 8 121362D+01 8 060877D+01 7 999793D+01 7 938867D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 3 VAPOR 3 439544E+02 9 563343D+03 5 405032D+00 -6 546507D-02 -1 818467D-02 -7 263312D+00  
 LEFT FILM COEF. H = 2 642369E-01 BTU/HR FT2 F FIRST MESH K = 6 700000E-02 BTU/HR FT F BULK TEMP = 7 439409E+01 F  
 RIGHT FILM COEF. H = 3 435112E-01 BTU/HR FT2 F LAST MESH K = 5 700000E-02 BTU/HR FT F BULK TEMP = 9 000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7 604661D+01 7 674790D+01 7 779451D+01 7 881117D+01 7 988787D+01 8 093458D+01 8 115320D+01 8 137183D+01 8 159046D+01  
 8 180909D+01 8 202771D+01 8 224634D+01 8 246447D+01 8 268359D+01 8 373025D+01 8 477692D+01 8 582560D+01 8 687019D+01  
 8 758060D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0 0 -5 648078D-01 0  
 1 0 0 0 0  
 2 0 0 0 0  
 3 0 0 7 515759D-01 0  
 4 0 0 0 0

COMP. NO.	PRESSURE (PSIA)	TEMPERATURE (F)	ATMOS. POOL	ENERGY (BTU)	CONVEGENCE DE/E
1	1 70000D+01	7 34000D+01	7 34000D+01	0	0
3	1 47004D+01	7 43940D+01	7 43940D+01	3 91583D+05	0
1	0	0	0	0	0
3	3 97448D+03	2 77053D+01	2 77053D+01	3 86893D-01	0
COMP	3 LEAKAGE OUTFLOW MASS = 6 4751D+02 LBM/HR	ENERGY BTU/HR = 8 7102D+04	INORMAL = 8 7102D+04	PENETRATION = 0	
STEP AND NET MASS LOSSES LBM	STEP VAPOR = 1 2451D-04	STEP AIR = 1 7862D-02	NET VAPOR = 5 1167D-02	NET AIR = 7 3403D+00	
TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR (LBM) = 7 340254D+00	WATER MASS (LBM)	ATMOSPHERE IS 0	WATER VAPOR (LBM) = 5 116739D-02		

\*\*\*\*\* TIME = 1 388889E-02 HR = 8 333333E-01 MIN = 5 000000E+01 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 0 VAPOR -8 869057D+02 -2 463619D-02 -1 229853D+01 3 VAPOR 3 795117D+02 1 055050D-02 7 621916D+00  
 LEFT FILM COEF. H = 2 000000E-01 BTU/HR FT2 F FIRST MESH K = 1 050000E+00 BTU/HR FT F BULK TEMP = 9 141944E+01 F  
 RIGHT FILM COEF. H = 2 762917E-01 BTU/HR FT2 F LAST MESH K = 6 700000E-02 BTU/HR FT F BULK TEMP = 7 463175D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 52380D+01 8 502397D+01 8 473415D+01 8 444433D+01 8 415454D+01 8 385469D+01 8 357488D+01 8 328506D+01 8 299524D+01  
 8 160781D+01 8 022042D+01 7 883310D+01 7 744589D+01 7 652296D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 3 VAPOR 2 059127D+03 5 725357D-02 4 356867D+01 4 LIQUID -4 298553D+03 -1 194055D-01 -5 970277D+01  
 LEFT FILM COEF. H = 5 531241E-01 BTU/HR FT2 F FIRST MESH K = 3 510000E-02 BTU/HR FT F BULK TEMP = 7 463175E+01 F  
 RIGHT FILM COEF. H = 1 000000E+04 BTU/HR FT2 F LAST MESH K = 1 150000E+00 BTU/HR FT F BULK TEMP = 9 000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7 578251D+01 7 810737D+01 7 900076D+01 8 017652D+01 8 135229D+01 8 252815D+01 8 370401D+01 4 487986D+01 8 605572D+01  
 8 723158D+01 8 769296D+01 8 815434D+01 8 861572D+01 8 861572D+01 8 907700D+01 8 953849D+01 8 999967D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 LIQUID -9 875713D+03 -2 743254D-01 -1 371627D+02 3 VAPOR 1 948423D+04 5 413217D-01 2 947771D+02

CONTENPT-1.1/028.30 APRIL 1978. EGSG IDAHO INC. CONTAINMENT SYSTEM PRESSURE TEMPERATURE HISTOR  
 COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS

LEFT FILM COEF .H = 4.785000E-01 BTU/HR FT<sup>2</sup> F FIRST MESH K = 1.050000E+00 BTU/HR FT BULK ME = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.697511E-01 BTU/HR FT<sup>2</sup> F LAST MESH K = 1.050000E+00 BTU/HR FT BULK ME = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.5365210+01 8.4896950+01 8.4527580+01 8.3944220+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 NET-VAPOR NET-LIQUID  
 CUMP STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR

CONVERGENCE  
 DE/E  
 TRANSFER COEFFICIENTS  
 HEAT MASS  
 CONDENSATION (LB/S) (BTU/S FT<sup>2</sup> R)  
 HUMIDITY (LB/S)

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 7 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 0 AND 7 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 7 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 0 AND 7 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 7 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 0 AND 7 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU

LEFT FILM COEF .H = 2.00000E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 9.14233E+01 F  
 RIGHT FILM COEF .H = 2.64727E-01 BTU/HR FT2 F LAST MESH K = 6.70000E-02 BTU/HR FT F BULK TEMP = 7.48654E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.5313810+01 8.5023970+01 8.4734150+01 8.444470+01 8.3864690+01 8.3574880+01 8.3285060+01 8.2995240+01  
 8.1607880+01 8.0220560+01 7.8833330+01 7.744627 7.6530550+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR 1.6675340+03 4.6368100-02 4.8740420+01 OL LIQUID -4.2985990+03 -1.1940550-01 -7.1643320+01  
 LEFT FILM COEF .H = 5.500629E-01 BTU/HR FT2 F FIRST MESH K = 3.50000E-02 BTU/HR FT BULK TEMP = 7.48654E+01 F  
 RIGHT FILM COEF .H = 1.00000E+04 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 9.00000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.5802420+01 7.8107610+01 7.9000760+01 8.0176530+01 8.2528150+01 8.3703010+01 8.4879960+01 8.6055720+01  
 8.7231580+01 8.7692960+01 8.8154340+01 8.8645720+01 8.9077100+01 8.9538480+01 8.9998870+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OL LIQUID -9.8757130+03 -2.7422540-01 -1.6459520+02 3 VAPOR 1.8822940+04 5.2295010-01 3.4737740+02  
 LEFT FILM COEF .H = 4.785000E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF .H = 4.656045E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 7.48654E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.5366210+01 8.4896950+01 8.4427540+01 8.2941960+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 S' WITH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR 1.5260850+03 4.2405740-02 3.1028550+01 OL LIQUID -2.2162070+03 -6.1561240-02 -3.6915390+01  
 LEFT FILM COEF .H = 3.693298E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 7.48654E+01 F  
 RIGHT FILM COEF .H = 4.237695E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 9.00000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.9390210+01 7.9997940+01 8.0608770+01 8.1219620+01 8.1830470+01 8.241330+01 8.3052180+01 8.3663020+01 8.4273040+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OL LIQUID -2.4035120+03 -6.6764150-02 -4.0035330+01 3 VAPOR 1.6550640+03 4.5989700-02 3.3650960+01  
 LEFT FILM COEF .H = 4.237605E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF .H = 3.693298E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 7.48654E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.4273040+01 8.3663020+01 8.3052180+01 8.241330+01 8.1830470+01 8.1219620+01 8.0608770+01 7.9997940+01 7.9390210+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR 2.2256770+02 6.1902290-03 6.9712490+00 OL LIQUID -6.5566270+02 -1.8212750-02 -1.0903080+01  
 LEFT FILM COEF .H = 2.368785E-01 BTU/HR FT2 F FIRST MESH K = 6.70000E-02 BTU/HR FT BULK TEMP = 7.48654E+01 F  
 RIGHT FILM COEF .H = 3.437940E-01 BTU/HR FT2 F LAST MESH K = 6.70000E-02 BTU/HR FT F BULK TEMP = 9.00000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.6058250+01 7.6748390+01 7.7794810+01 7.8841340+01 8.0934580+01 8.1153200+01 8.1371830+01 8.1590460+01  
 8.1809090+01 8.2027710+01 8.2246540+01 8.2464970+01 8.2683590+01 8.3730240+01 8.4776870+01 8.5823480+01 8.6870070+01  
 8.7578850+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0 -5.6492090-01 0  
 1 0 0 0  
 2 0 0 0  
 3 0 6.7280510-01 0  
 4 0 0 0

89/12/14

COMP NO	PRESSURE (PSIA)		TEMPERATURE (F)		ENERGY (BTU)			CONVERGENCE DE/2
	TOTAL	STEAM	ATMOS	POOL	ATMOS	POOL	TOTAL	
1	1.47000D+01	0.	7.34000D+01	7.34000D+01	0.	0.	0.	-1.41983D-07
3	1.47004D+01	1.63020D-01	7.48653D+01	7.48653D+01	3.91562D+05	0.	3.91562D+05	

COMP	AIR MASS (LBM)	WATER MASS (LBM)			HUMIDITY (LB/S)	CONDENSATION (LB/S)	TRANSFER COEFFICIENTS MASS (LB MOL/S FT2)	HEAT (BTU/S FT2 R)
		VAPOR	ATMOS	LIQUID				
1	0.	0.	0.	0.	6.00000D-01	0.	0.	
3	3.97097D+03	2.76809D+01	0.	0.	3.80845D-01	0.	0.	

COMP 3 LEAKAGE OUTFLOW MASS = 6.2486D+02 LBM/HR ENFNGY BTU/HR = 127D+04 (NORMAL = 8.4127D+04 PENETRATION = )  
 STEP AND NET MASS LOSSES LBM STEP VAPOR = 1.2016D-04 STEP AIR = 1.7237D-02 NET VAPOR = 7.5627D-02 NET AIR = 1.0849D+01  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) = 1.084908D+01 WATER VAPOR(LBM) = 7.562667D-02

\*\*\*\*\* TIME = 3.33333E-02 HR = 2.00000E+00 MIN = 1.20000E+02 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -8.908534E+02 -2.474585D-02 -2.958231D+01 3 VAPOR 5.494395D+01 1.530057D-03 1.140336D+01  
 LEFT FILM COEF. H = 2.00000E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 7.619158E+01 F  
 RIGHT FILM COEF. H = 1.90000E-01 BTU/HR FT2 F LAST MESH K = 6.70000E-02 BTU/HR FT F BULK TEMP = 7.619158D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.531385D+01 8.502397D+01 8.473445D+01 8.444433D+01 8.415451D+01 8.386469D+01 8.357488D+01 8.328506D+01 8.299524D+01  
 8.160878D+01 8.022247D+01 7.883646D+01 7.745093D+01 7.658973D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -3.683982D+02 -1.019166D-02 5.886850D+01 0 LIQUID -4.298593D+03 -1.194055D-01 -1.432866D+02  
 LEFT FILM COEF. H = 5.326903E-01 BTU/HR FT2 F FIRST MESH K = 3.50000E-02 BTU/HR FT BULK TEMP = 7.619158E+01 F  
 RIGHT FILM COEF. H = 1.00000E+04 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 9.00000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.597780D+01 7.811112D+01 7.900093D+01 8.017662D+01 8.135233D+01 8.252816D+01 8.370401D+01 8.487987D+01 8.605572D+01  
 8.723158D+01 8.769296D+01 8.815434D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 LIQUID -9.875714D+03 -2.743254D-01 -3.291904D+02 3 VAPOR 1.519510D+04 4.221640D-01 6.306916D+02  
 LEFT FILM COEF. H = 4.785000E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF. H = 4.407533E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 7.619158D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.536621D+01 8.489694D+01 8.442720D+01 8.393188D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR 9.621830D+02 2.673900D-02 5.159690D+01 0 LIQUID -2.218970D+03 -6.160000D-02 -7.387523D+01  
 LEFT FILM COEF. H = 3.286681E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 7.619158E+01 F  
 RIGHT FILM COEF. H = 4.242300E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 9.00000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.939736D+01 7.999802D+01 8.060877D+01 8.121962D+01 8.183047D+01 8.244133D+01 8.305218D+01 8.366301D+01 8.427225D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 LIQUID -2.406509D+03 -6.684739D-02 -8.011887D+01 3 VAPOR 1.043503D+03 2.899887D-02 5.595767D+01  
 LEFT FILM COEF. H = 4.242300E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF. H = 3.286681E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 7.619158D+01 F

CCC

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 427225D+01 8 366301D+01 8 305218D+01 8 244133D+01 8 183047D+01 8 121962D+01 8 060877D+01 7 999802D+01 7 939736D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 3 VAPOR -1 266291D+01 -3 475489D+04 8 4C8628D+00 -6 585627D+02 -1 829334D+02 -2 185523C+01  
 LEFT FILM COEF .H = 1.90000E-01 BTU/HR.FT2 F FIRST MESH K = 6.70000E-02 BTU/HR.FT BULK TEMP = 7.619158E+01 F  
 RIGHT FILM COEF .H = 3.446271E-01 BTU/HR.FT2 F LAST MESH K = 6.70000E-02 BTU/HR.FT F BULK TEMP = 9.00000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7 610697D+01 7 675211D+01 7 779729D+01 7 982850D+01 7 988866D+01 8 093458D+01 8 115320D+01 8 137183D+01 8 159074D+01  
 8 180909D+01 8 202771D+01 8 224634D+01 8 246497D+01 8 268355D+01 8 373011D+01 8 477660D+01 8 582306D+01 8 686540D+01  
 8 757402D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP. STEP LIQUID STEP VAPOR NET LIQUID NET VAPOR  
 0 0 0 0 0 0  
 1 0 0 0 0 0  
 2 0 0 0 0 0  
 3 0 0 0 0 0  
 4 0 0 0 0 0

COMP NO.	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	E N E R G Y (BTU)	C O N V E R G E N C E (DE/E)
1	TOTAL STEAM	ATMOS POOL	ATMOS POOL	TOTAL
1	1.47000D+01	7.34000D+01	7.34000D+01	0.
3	1.47000D+01	7.61917D+01	7.61917D+01	3.91502D+05
	AIR MASS (LBM)	W A T E R M A S S (LBM)	H U M I D I T Y (LB/S)	C O N D E N S A T I O N (LB/S)
1	0.	0.	0.	5.00000D-01
3	3.96113D+03	2.76123D+01	2.76123D+01	3.64472D-01
	COMP. 3 LEAKAGE OUTFLOW MASS = 5.6612D+02 LBM/HR ENERGY B.L./HR = 7.6399D+04 (NORMAL - 7.6399D+04 PENETRATION = 0.)			
	STEP AND NET MASS LOSSES LBM STEP VAPOR = 1.0886D-04 STEP A.V. = 1.5617D-02 NET VAPOR = 1.4419D-01 NET AIR = 2.0685D+01			
	TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR (LBM) = 1.4419D+01 WATER VAPOR (LBM) = 1.441875D-01			
				TRANSFER COEFFICIENTS MASS HEAT
				{LB MOL/S FT2} {BTU/S FT2 R}
				1.76347D-07

\*\*\*\*\* TIME = 5.00000E-02 HR = 3.00000E+00 MIN = 1.80000E+02 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 0 VAPOR -8 942329D+02 -2 483973D-02 -4 445803D+01 3 VAPOR -1 027712D+02 -2 851277D-03 1 098355D+01  
 LEFT FILM COEF .H = 2.00000E-01 BTU/HR.FT2 F FIRST MESH K = 1.05000E+00 BTU/HR.FT BULK TEMP = 9.18700E+01 F  
 RIGHT FILM COEF .H = 1.90000E-01 BTU/HR.FT2 F LAST MESH K = 6.70000E-02 BTU/HR.FT F BULK TEMP = 7.140602D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 531391D+01 8 502397D+01 8 173415D+01 8 444433D+01 8 415451D+01 8 386469D+01 8 357488D+01 8 328506D+01 8 299525D+01  
 8 161085D+01 8 022672D+01 7 884313D+01 7 746040D+01 7 666128D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF AND CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 3 VAPOR -1 971930D+03 -5 474455D-02 3 885024D+01 0 LIQUID -4 298599D+03 -1 194055D-01 -2 140700D+02  
 LEFT FILM COEF .H = 5.167812E-01 BTU/HR.FT2 F FIRST MESH K = 3.50000E-02 BTU/HR.FT BULK TEMP = 7.740602E+01 F  
 RIGHT FILM COEF .H = 1.00000E+03 BTU/HR.FT2 F LAST MESH K = 1.05000E+00 BTU/HR.FT F BULK TEMP = 9.00000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7 622645D+01 7 811945D+01 7 900158D+01 8 017700D+01 8 135253D+01 8 252825D+01 8 370405D+01 8 487988D+01 8 605573D+01  
 8 723158D+01 8 769296D+01 8 815434D+01 8 861572D+01 8 907710D+01 8 953849D+01 8 999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 0 LIQUID -9 875714D+03 -2 743254D-01 -4 937857D+02 3 VAPOR 1 207133D+04 3 353819D-01 8 572720D+02



CONTEMP-11/028-30 APRIL 1979, EG&G IDAHO INC. CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM

COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS

LEFT FILM COEF .H = 4.78500E+01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.00000E+01 F
RIGHT FILM COEF .H = 4.156067E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 7.740602D+01 F
MESH POINT TEMPERATURES (F). LEFT TO RIGHT
8.489593D+01 8.442676D+01 8.392714D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU
3 VAPOR 5.12626D+02 1.42492D+02 6.37340+0+01
LEFT FILM COEF .H = 2.804592E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 7.740602E+01 F
RIGHT FILM COEF .H = 4.246977E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.00000E+01 F
MESH POINT TEMPERATURES (F). LEFT TO RIGHT
7.940763D+01 7.959821D+01 8.060878D+01 8.121962D+01 8.183047D+01 8.244133D+01 8.305218D+01 8.366298D+01 8.427149D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU
3 VAPOR 5.240918D+03 -6.692994D-02 -1.202521D+02
LEFT FILM COEF .H = 4.246977E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 7.740602E+01 F
RIGHT FILM COEF .H = 2.804592E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.00000E+01 F
MESH POINT TEMPERATURES (F). LEFT TO RIGHT
8.427149D+01 8.366298D+01 8.305218D+01 8.244133D+01 8.183047D+01 8.121962D+01 8.060878D+01 8.00000E+01 7.940763D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU
3 VAPOR 5.233195D+02 -6.471290D-03 6.503511D+00
LEFT FILM COEF .H = 2.350563E-01 BTU/HR.FT2.F FIRST MESH K = 6.70000E-02 BTU/HR.FT.F BULK TEMP = 7.740602E+01 F
RIGHT FILM COEF .H = 3.454398E-01 BTU/HR.FT2.F LAST MESH K = 6.70000E-02 BTU/HR.FT.F BULK TEMP = 9.00000E+01 F
MESH POINT TEMPERATURES (F). LEFT TO RIGHT
7.616762D+01 7.675982D+01 7.780271D+01 7.884629D+01 7.989033D+01 8.093459D+01 8.115320D+01 8.137183D+01 8.159046D+01
8.180909D+01 8.202771D+01 8.224634D+01 8.246597D+01 8.268359D+01 8.372989D+01 8.477617D+01 8.582240D+01 8.686855D+01
8.756974D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU
COMP. STEP-1 LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR
0 0. 0. 0. 0.
1 0. 0. 0. 0.
2 0. 0. 0. 0.
3 0. 3.010175D-01 0. 1.040564D+03
4 0. 0. 0. 0.

Table with columns: COMP NO, PRESSURE (PSIA), TEMPERATURE (F), POOL, ATMOS, (LBM), HUMIDITY, CONDENSATION (LB/S), TOTAL, ENR, G, Y, POOL, TOTAL, TRANSFER COEFFICIENTS, CONVERGENCE DE/E

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU
3 VAPOR 5.8976087D+02 -2.493350D-02 -5.939005D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR 3 250449D+03 9.026380D-02 -5.063276D+00 OLIIQUID -4.298599D+03 -1.194055D-01 -2.865733D+02  
 LEFT FILM COEF .H = 2.00000E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 9.149333E+01 F  
 RIGHT FILM COEF .H = 2.693785E-01 BTU/HR FT2 F LAST MESH K = 6.70000E-02 BTU/HR FT F BULK TEMP = 7.852511D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 531401D+01 8 502398D+01 8 472415D+01 8 444433D+01 8 415451D+01 8 386469D+01 8 357488D+01 8 329506D+01 8 299527D+01  
 8 161420D+01 8 023353D+01 7 885367D+01 7 747508D+01 7 674498D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQUID -9.875716D+03 -2.743254D-01 -6.583809D+02 3 VAPOR 9.376952D+03 2.605287D-01 1.035452D+03  
 LEFT FILM COEF .H = 4.785000E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF .H = 1.00000E+04 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 7.852511E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7 652405D+01 7 813366D+01 7 900310D+01 8 017797D+01 8 135309D+01 8 252854D+01 8 370419D+01 8 487995D+01 8 605575D+01  
 8 723158D+01 8 767296D+01 8 815434D+01 8 861572D+01 8 907710D+01 8 953849D+01 8 999887D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR 1.553081D+02 4.318379D-03 6.926225D+01 OLIIQUID -2.224428D+03 -6.178959D-02 -1.479332D+02  
 LEFT FILM COEF .H = 1.90000E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 7.852511E+01 F  
 RIGHT FILM COEF .H = 4.251636E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7 942022D+01 7 999853D+01 8 060878D+01 8 121962D+01 8 183047D+01 8 244132D+01 8 305217D+01 8 366295D+01 8 427077D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQUID -2.412427D+03 -6.701180D-02 -1.604347D+02 3 VAPOR 1.684341D+02 4.683351D-03 7.511602D+01  
 LEFT FILM COEF .H = 4.251636E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF .H = 1.90000E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 7.852511D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 427077D+01 8 366295D+01 8 305217D+01 8 244132D+01 8 183047D+01 8 121962D+01 8 060878D+01 7 999853D+01 7 942022D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 0 AND 0 EAST WALL  
 TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR 5.252924D+02 4.02 3.207709D-01 OLIIQUID -6.638434D+02 -1.844004D-02 -4.389707D+01  
 LEFT FILM COEF .H = 2.925372E-01 BTU/HR FT2 F FIRST MESH K = 6.70000E-02 BTU/HR FT BULK TEMP = 7.852511E+01 F  
 RIGHT FILM COEF .H = 3.462348E-01 BTU/HR FT2 F LAST MESH K = 6.70000E-02 BTU/HR FT F BULK TEMP = 9.00000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7 624551D+01 7 677226D+01 7 741160D+01 7 885202D+01 7 989314D+01 8 093461D+01 8 137183D+01 8 159046D+01  
 8 180909D+01 8 202771D+01 8 224634D+01 8 246497D+01 8 268359D+01 8 372962D+01 8 477562D+01 8 582156D+01 8 686740D+01  
 8 756592D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP STEP LIQUID STEP VAPOR NET LIQUID NET VAPOR  
 1 0 0 0 0  
 2 0 0 0 0  
 3 0 1 550136D-01 0 0  
 4 0 0 0 0

CONVERGENCE DE/E 0 6 853750-07  
 TRANSFER COEFFICIENTS HEAT  
 MASS (LB MOL/S FT2)(BTU/S FT2 R)  
 HUMIDITY CONDENSATION (LB/S) 0 0  
 (BTU) TOTAL 0 3 913990+05  
 ENER G Y POOL 0 0  
 ATMOS 0 3 913990+05  
 P RE S S U R E (PSIA) T E M P E R A T U R E (F) P O O L  
 1 1.47000+01 7.34000+01 7.34000+01 7.34000+01  
 3 1.47000+01 7.85254+01 7.85254+01 7.85254+01  
 AIR MASS W A T E R M A S S ( L B M ) H U M I D I T Y C O N D E N S A T I O N ( L B / S )  
 ( L B M ) V A P O R - A T M O S - L I Q U I D P O O L  
 1 0 0 0  
 3 9.94395+03 2.7492+01 0 0 2.74925+01 3.27380-01 0 0  
 COMP 3 LEAKAGE OUTFLOW MASS= 4.76430+02 LBM/HR ENERGY BTU/HR = 6.45630+04 (NORMAL= 5.45630+04 PENETRATION= 0 )  
 STEP AND NET MASS LOSSES LBM STEP VAPOR= 9.1614D-05 STEP AIR= 1.3143D-02 NET VAPOR= 2.6397D-01 NET AIR= 3.7869D+01  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 3.786862D+01 WATER VAPOR(LBM)= 2.639744D-01

\*\*\*\*\* TIME = 8.33333E-02 HR = 5.00000E+00 MIN = 3.00000E+02 SEC \*\*\*\*\*  
 HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 TO LEFT COMP END STEP BTU/HR -9.00980D+02 -2.50271D-02 -7.43783D+01 3 VAPOR -6.11451D+02 -1.69785D-02 -6.34841D-01  
 0 VAPOR  
 LEFT FILM COEF .H = 2.00000E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 7.956331E+01 F  
 RIGHT FILM COEF .H = 3.097547E-01 BTU/HR.FT2.F LAST MESH K = 6.70000E-02 BTU/HR.FT.F BULK TEMP = 7.956331D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.531413D+01 8.502358D+01 8.473415D+01 8.444433D+01 8.415451D+01 8.386469D+01 8.357488D+01 8.328506D+01 8.299532D+01  
 8.161899D+01 8.024332D+01 7.886859D+01 7.749568D+01 7.684545D+01  
 HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 TO LEFT COMP END STEP BTU/HR -4.28334D+03 -1.18960D-01 -6.81377D+01 OLIOUID -4.29859D+03 -1.19405D-01 -3.58216D+02  
 3 VAPOR  
 LEFT FILM COEF .H = 4.885206E-01 BTU/HR.FT2.F FIRST MESH K = 3.50000E-02 BTU/HR.FT.F BULK TEMP = 7.956331E+01 F  
 RIGHT FILM COEF .H = 1.00000E+04 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.00000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.685296D+01 7.815423D+01 7.900594D+01 8.017988D+01 8.135425D+01 8.252919D+01 8.370455D+01 8.488013D+01 8.605583D+01  
 8.723158D+01 8.769286D+01 8.815434D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.999870D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 TO LEFT COMP END STEP BTU/HR -9.87571D+03 -2.74325D-01 -8.22976D+02 3 VAPOR 7.052345D+03 1.959484D-01 1.171889D+03  
 OLIOUID  
 LEFT FILM COEF .H = 4.78500E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF .H = 3.625729E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 7.956331D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.536621D+01 8.489589D+01 8.442585D+01 8.393036D+01  
 HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 TO LEFT COMP END STEP BTU/HR -2.23957D+01 -6.181365D-04 7.035208D+01 OLIOUID -2.227123D+03 -6.186446D-02 -1.850284D+02  
 3 VAPOR  
 LEFT FILM COEF .H = 1.90000E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 7.956331E+01 F  
 RIGHT FILM COEF .H = 4.256277E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.00000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.943424D+01 7.999902D+01 8.060879D+01 8.124962D+01 8.183047D+01 8.244132D+01 8.305217D+01 8.366291D+01 8.427008D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 TO LEFT COMP END STEP BTU/HR -2.41535D+03 -6.70930D-02 -2.006663D+02 3 VAPOR -2.428859D+03 -6.703789D-04 7.629796D+01  
 OLIOUID  
 LEFT FILM COEF .H = 4.256277E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF .H = 1.90000E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 7.956331D+01 F

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.427008D+01 8.366291D+01 8.905217D+01 8.244132D+01 8.183047D+01 8.121962D+01 8.062879D+01 7.959902D+01 7.943473D+01  
 HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 3 VAPOR -8.317530D+02 -2.309713D+02 -1.038169D+01 3 VAPOR -8.784713D+02 -2.439585D+02 -1.311399D+01  
 LEFT FILM COEF. H = 3.278141E-01 BTU/HR.FT.F FIRST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 7.956331E+01 F  
 RIGHT FILM COEF. H = 3.470142E-01 BTU/HR.FT.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.631220D+01 7.679046D+01 7.782472D+01 7.886052D+01 7.989734D+01 8.093464D+01 8.115320D+01 8.137183D+01 8.159046D+01  
 8.180909D+01 8.202771D+01 8.224633D+01 8.246497D+01 8.268359D+01 8.372930D+01 8.477497D+01 8.582058D+01 8.686608D+01  
 8.756251D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0 5.662231D-01 0  
 1 0 0 0  
 2 0 3.562385D-02 0  
 3 0 1.238724D+03 0  
 4 0 0 0

COMP. NO.	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	E N E R G Y (BTU)	C O N V E R G E N C E (DE/E)
1	1.470090D+01	7.340000D+01	0	0
3	1.470030D+01	7.956370D+01	3.91353D+05	0
AIR MASS W A T E R M A S S ( L B M )				
1	0	0	0	0
3	3.93635D+03	2.74396D+01	3.26080D-01	0
COMP. 3 LEAKAGE OUTFLOW- MASS = 4.4240D+02 LBM/HR ENERGY BTU/HR = 6.0062D+04 (NORMAL = 6.0062D+04 PENETRATION = 0 )				
STEP AND NET MASS LOSSES LBM STEP VAPOR = 8.5070D-05 STEP AIR = 1.2204D-02 NET VAPOR = 3.1693D-01 NET AIR = 4.5466D+01				
TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) = 4.546576D+01 WATER VAPOR(LBM) = 3.169325D-01				

\*\*\*\*\* TIME = 1.000000E-01 HR = 6.000000E+00 MIN = 3.600000E+02 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS C AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 0 VAPOR -9.043492D+02 -2.512073D+02 -8.942273D+01 3 VAPOR -8.784713D+02 -2.439585D+02 -1.311399D+01  
 LEFT FILM COEF. H = 2.000000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT BULK TEMP = 9.154000E+01 F  
 RIGHT FILM COEF. H = 3.987952E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 8.053265D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.531427D+01 8.502398D+01 8.473415D+01 8.444333D+01 8.415451D+01 8.386469D+01 8.357488D+01 8.328506D+01 8.295539D+01  
 8.262544D+01 8.225622D+01 8.188847D+01 8.152298D+01 8.115298D+01 7.952608D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 3 VAPOR -5.200298D+03 -1.44319D-01 -1.471303D+02 3 VAPOR -4.298599D+03 -1.194055D-01 -1.298599D+02  
 LEFT FILM COEF. H = 4.825710E-01 BTU/HR.FT2.F FIRST MESH K = 3.050000E-02 BTU/HR.FT BULK TEMP = 8.053265E+01 F  
 RIGHT FILM COEF. H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.720151D+01 7.818131D+01 7.901050D+01 8.018305D+01 8.135628D+01 8.253041D+01 8.370525D+01 8.488050D+01 8.605599D+01  
 8.723158D+01 8.769296D+01 8.815433D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 OLIQUID -9.875724D+03 -2.743257D-01 -9.875716D+02 3 VAPOR 5.053160D+03 1.403082D-01 1.272334D+03

CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM

89/12/14

CONTEMP-LI/028,30 APRIL 1978, EG&G IDAHO INC. CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM

COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS

LEFT FILM COEF .H = 4.785000E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 3.332615E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 8.053265E+01 F  
 WASH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.536621D+01 8.489686D+01 8.442552D+01 8.399695D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.252519D+02 -6.251100D-03 6.853262D+01  
 LEFT FILM COEF .H = 2.276336E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.260901E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 8.053265E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.944906D+01 7.993967D+01 8.060881D+01 8.121962D+01 8.183047D+01 8.244132D+01 8.305217D+01 8.365286D+01 8.426943D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 LIQUID -2.418250D+03 -6.717355D-02 -2.409463D+02  
 LEFT FILM COEF .H = 4.260901E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 2.276336E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 8.053265E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.426943D+01 8.365286D+01 8.305217D+01 8.244132D+01 8.183047D+01 8.121962D+01 8.060881D+01 7.993967D+01 7.944906D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.136765D+03 -3.156985D-02 -2.739533D+01  
 LEFT FILM COEF .H = 3.540938E-01 BTU/HR FT2 F FIRST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 8.053265E+01 F  
 RIGHT FILM COEF .H = 2.477798E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.645742D+01 7.581535D+01 7.784279D+01 7.882200D+01 7.990317D+01 8.093471D+01 8.115121D+01 8.137183D+01 8.159046D+01  
 7.180909D+01 2.02771D+01 8.224634D+01 8.246437D+01 8.268358D+01 8.372893D+01 8.477425D+01 8.581949D+01 8.686462D+01

8.755845D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP.	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
0	0	665358D-01	0	-2.036075D+03
1	0	0	0	0
2	0	0	0	0
3	0	-7.31192D-02	0	1.227551D+03
4	0	0	0	0

COMP NO	PRESSURE (PSIA)	TEMPERATURE (F)	ENRGY (BTU)	CONVERGENCE DE/E
1	1.47000D+01	7.34000E+01	0	0
3	1.47003D+01	8.05332D+01	3.91311D+05	1.03856D-06
AIR MASS (LBM)				
VAPOR--ATMOS--LIQUID				
1	0	0	0	0
3	3.92929D+03	2.73903D+01	3.15899D-01	0
COMP. 3 LEAKAGE OUTFLOW MASS = 4.1152D+02 LBM/HR ENERGY BTU/HR = 5.5966D+04 (NORMAL = 5.5967E+04 PENETRATION = 0)				
STEP AND NET MASS LOSSES LBM STEP VAPOR = 7.9133D-05 STEP AIR = 1.1352D-02 NET VAPOR = 3.6619D-01 NET AIR = 5.2533D+01				
TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) = 5.253264D+01 WATER VAPOR(LBM) = 3.661943D-01				

\*\*\*\*\* TIME = 1.166667E-01 HR = 7.000000E+00 MIN = 4.200000E+02 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -9.077142D+02 -2.521421D-02 -1.045233D+02

LEFT FILM COEF .H = 2.00000E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.156333E+01 F  
 RIGHT FILM COEF .H = 3.611826E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 8.143676E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.531444E+01 8.502395E+01 8.473415E+01 8.444434E+01 8.415451E+01 8.386469E+01 8.357488E+01 8.328506E+01 8.299550E+01  
 8.163371E+01 8.027285E+01 7.891384E+01 7.755764E+01 7.620150E+01 7.484534E+01 7.348918E+01 7.213302E+01 7.077686E+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -6.038837E+03 -1.677274E+01 -2.409534E+02 OLIIQUID -4.298599E+03 -1.194055E+01 -5.015032E+02  
 LEFT FILM COEF .H = 4.821822E-01 BTU/HR FT2 F FIRST MESH K = 3.500000E-02 BTU/HR FT F BULK TEMP = 8.143676E+01 F  
 RIGHT FILM COEF .H = 1.000000E+04 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.75653E+01 7.21486E+01 7.901716E+01 8.018782E+01 8.135946E+01 8.253240E+01 8.370645E+01 8.488118E+01 8.605629E+01  
 8.723158E+01 8.768296E+01 8.815434E+01 8.861572E+01 8.907710E+01 8.953849E+01 8.999987E+01 9.046125E+01 9.092263E+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQUID -9.875730E+03 -2.743258E-01 -1.152167E+03 3 VAPOR 3.360587E+03 9.338542E-02 1.342035E+03  
 LEFT FILM COEF .H = 4.785600E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 3.006831E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 8.143676E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.536620E+01 8.409683E+01 8.442522E+01 8.394608E+01 8.346694E+01 8.298780E+01 8.250866E+01 8.202952E+01 8.155038E+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -4.997498E+02 -1.387525E-02 8.253746E+01 OLIIQUID -2.232450E+03 -6.207243E-02 -2.593548E+02  
 LEFT FILM COEF .H = 2.775666E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 8.143676E+01 F  
 RIGHT FILM COEF .H = 4.265508E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.946516E+01 7.900506E+01 8.060033E+01 8.121962E+01 8.183047E+01 8.244132E+01 8.305217E+01 8.366280E+01 8.426881E+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQUID -2.421427E+03 -6.790347E-02 -2.812745E+02 3 VAPOR -5.419866E+02 -1.504793E-02 6.782288E+01  
 LEFT FILM COEF .H = 4.265508E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 2.775666E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 8.143676E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.206881E+01 8.296280E+01 8.305217E+01 8.244132E+01 8.183047E+01 8.121962E+01 8.060883E+01 8.000050E+01 7.946516E+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.431004E+03 -3.974347E-02 -4.881227E+01 OLIIQUID -6.707954E+02 -1.863288E-02 -7.726693E+01  
 LEFT FILM COEF .H = 3.747357E-01 BTU/HR FT2 F FIRST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 8.143676E+01 F  
 RIGHT FILM COEF .H = 3.485331E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.658865E+01 7.68477E+01 7.786640E+01 7.888776E+01 7.991085E+01 8.093480E+01 8.115321E+01 8.137183E+01 8.159046E+01  
 8.180908E+01 8.20277E+01 8.224634E+01 8.246497E+01 8.268357E+01 8.290220E+01 8.312083E+01 8.333946E+01 8.355809E+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0 -5.668444E-01 0 -2.376090E+03  
 1 0 0 0  
 2 0 0 0  
 3 0 -1.763680E-01 0 1.152691E+03  
 4 0 0 0



MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 B 425822D+01 B 366274D+01 B 305217D+01 B 244132D+01 B 183047D+01 B 121963D+01 B 06087D+01 B 000152D+01 7 928275D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 3 VAPOR -1 710173D+03 -4 749852D+02 -7 501727D+01 0 LIQUID -6 729037D+02 -1 869164D+02 -8 846433D+01  
 LEFT FILM COEF .H = 3 914784E-04 BTU/HR FT2 F FIRST MESH K = 6 700000E-02 BTU/HR FT BULK TEMP = 8 228151E+01 F  
 RIGHT FILM COEF .H = 3 492754E-01 BTU/HR FT2 F LAST MESH K = 6 700000E-02 BTU/HR FT F BULK TEMP = 9 000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7 673562D+01 7 688808D+01 7 789601D+01 7 850719D+01 7 992053D+01 8 093449D+01 8 115321D+01 8 137183D+01 8 159046D+01  
 B 180909D+01 B 202771D+01 B 224634D+01 B 246497D+01 B 268356D+01 B 372814D+01 B 477267D+01 B 587712D+01 B 686145D+01  
 B 755419D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP STEP LIQUID STEP VAPOR NET LIQUID NET VAPOR  
 0 0 -5 671492D-01 0 -2 716208D+03  
 1 0 0 0  
 2 0 0 0  
 3 0 -2 657010D-01 0 1 020X06D+03  
 4 0 0 0

COMP NO.	PRESSURE (PSIA)	TEMPERATURE (F)	ENERGY POOL	ATMOSPHERIC	RELATIVE HUMIDITY	CONDENSATION (LB/S)	TRANSFER COEFFICIENTS	CONVERGENCE DE/E
1	1 470000D+01	0	7 34000D+01	0	0	0	1 32534D-06	0
3	1 47000D+01	1 63029D-01	8 22822D+01	3 91235D+05	0	3 91235D+05	1 32534D-06	0
1	0	0	0	0	6 00000D-01	0	0	0
3	3 91660D+03	2 73019D+01	0	2 73019D+01	2 98413D-01	0	0	0
COMP	3 LEAKAGE OUTFLOW - MASS =	3 5702D+02 LBM/HR	ENERGY BTU/HR =	4 8704D+04 (NORMAL =	4 8704D+04 PENETRATION =	0	0	0
STEP	AND NET MASS LOSSES LBM STEP VAPOR =	6 8653D-05 STEP AIR =	9 8486D-03 NET VAPOR =	4 5463D-01 NET AIR =	6 5219D+01	0	0	0
TOTAL	NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) =	6 521869D+01 WATER VAPOR(LBM) =	4 546262D-01					

\*\*\*\*\* TIME = 1 500000E-01 HR = 9 000000E+00 MIN = 5 400000E+02 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 0 VAPOR -9 144740D+02 -2 540087D-02 -1 348924D+02 3 VAPOR -1 622518D+03 -4 506467D-04 -7 611401D+01  
 LEFT FILM COEF .H = 2 000000E-04 BTU/HR FT2 F FIRST MESH K = 1 050000E+00 BTU/HR FT BULK TEMP = 9 161010E+01 F  
 RIGHT FILM COEF .H = 3 939567E-01 BTU/HR FT2 F LAST MESH K = 6 700000E-02 BTU/HR FT F BULK TEMP = 8 317314D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 B 531485D+01 B 502401D+01 B 473415D+01 B 444433D+01 B 415451D+01 B 386469D+01 B 357488D+01 B 328507D+01 B 299586D+01  
 B 165628D+01 B 031803D+01 7 898245D+01 7 765092D+01 7 740259D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 3 VAPOR -7 409351D+03 -2 058 81D-01 -4 661020D+02 0 LIQUID -4 298599D+03 -1 194055D+01 -6 447899D+02  
 LEFT FILM COEF .H = 5 814786E-04 BTU/HR FT2 F FIRST MESH K = 3 500000E-02 BTU/HR FT BULK TEMP = 8 407314E+01 F  
 RIGHT FILM COEF .H = 1 000000E+04 BTU/HR FT2 F LAST MESH K = 1 050000E+00 BTU/HR FT F BULK TEMP = 9 000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7 83158D+01 7 830075D+01 7 903808D+01 B 020330D+01 B 137625D+01 B 253952D+01 B 371096D+01 B 488382D+01 B 605751D+01  
 B 723159D+01 B 769296D+01 B 815434D+01 B 861572D+01 B 907710D+01 B 953849D+01 B 999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 0 LIQUID -9 875750D+03 -2 743264D-01 -1 481358D+03 3 VAPOR 7 589254D+02 2 109601D-02 1 408706D+03



LEFT FILM COEF .H = 4.785000E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 1.900000E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 8.307314D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.536619D+01 8.489676D+01 8.442543D+01 8.396994D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR 1.101069D+03 -3.057818D-02 3.594710D+01 0 LIQUID -2.237695D+03 -6.215814D-02 -3.238575D+02  
 LEFT FILM COEF .H = 3.376208E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 8.307314E+01 F  
 RIGHT FILM COEF .H = 4.274674E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.95019E+01 8.000275D+01 8.060892D+01 8.121963D+01 8.183047D+01 8.244132D+01 8.305216D+01 8.366267D+01 8.426766D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.426816D+03 -6.741350D-02 -3.620730D+02 3 VAPOR -1.194127D+03 -3.316253D-02 -3.898521D+01  
 LEFT FILM COEF .H = 4.274674E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 3.376208E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 8.307314D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.426766D+01 8.366267D+01 8.305216D+01 8.244132D+01 8.183047D+01 8.121963D+01 8.060892D+01 8.000275D+01 7.950190D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.972601D+03 -5.478860D-02 -1.057252D+02 0 LIQUID -6.749356D+02 -1.874816D-02 -9.969631D+01  
 LEFT FILM COEF .H = 4.053812E-01 BTU/HR FT2 F FIRST MESH K = 6.700000E-02 BTU/HR FT BULK TEMP = 8.307314E+01 F  
 RIGHT FILM COEF .H = 3.500078E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.689561D+01 7.636887D+01 7.793190D+01 7.893083D+01 7.992233D+01 8.093513D+01 8.115322D+01 8.137183D+01 8.159046D+01  
 8.180905D+01 8.203771D+01 8.224634D+01 8.246497D+01 8.268355D+01 8.372772D+01 8.477184D+01 8.581588D+01 8.685980D+01  
 8.755193D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0 -5.674506D-01 0 -3.056668D+03  
 1 0 0 0  
 2 0 0 0  
 3 0 -3.483161D-01 0 1.356970D+02  
 4 0 0 0

COMP NO.	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	A T M O S P O O L	E N E R G Y (BTU)	T O T A L	C O N V E R G E N C E (DE/E)
1	1.47000D+01	7.34000D+01	7.34000D+01	0	0	0
3	1.47003D+01	1.63029D-01	8.30739D+01	3.91200D+05	3.91200D+05	1.44482D-06

AIR MASS (LBM)	W A T E R V A P O R - A T M O S - L I Q U I D	M A S S P O O L	H U M I D I T Y (LB/AOL/S)	C O N D E N S A T I O N (LB/S)	M A S S F L O W (BTU/S FT2 R)	H E A T T R A N S F E R C O E F F I C I E N T S
1	0	0	6.00000D-01	0	0	0
3	3.91088D+03	2.72620D+01	2.72620D+01	2.90859D-01	0	0

COMP. 3 LEAKAGE OUTFLOW - MASS = 3.3372D+02 LBM/HR ENERGY BTU/HR = 4.5589D+04 (NORMAL) 4.5589D+04 PENETRATION = 0.  
 STEP AND NET MASS LOSSES LBM STEP VAPOR = 6.4172D-05 STEP AIR = 9.2059D-03 NET VAPOR = 4.9447D-01 NET AIR = 7.09334D+01  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR (LBM) = 7.0933423D+01 WATER VAPOR (LBM) = 4.944681D-01

\*\*\*\*\* TIME = 1.666667E-01 HR = 1.000000E+01 MIN = 6.000000E+02 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -9.177890D+02 -2.549406D-02 -1.501610D+02 3 VAPOR -1.843804D+03 -5.121180D-02 -1.05017E+02

CONTINMENT SYSTEM PRESSURE - TEMPERATURE HISTORY PROGRAM  
89/12/14

COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS  
LEFT FILM COEF .H = 2.00000E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 9.163333E+01 F  
RIGHT FILM COEF .H = 4.06448E-01 BTU/HR FT2 F LAST MESH K = 6.70000E-02 BTU/HR FT BULK TEMP = 8.381948E+01 F  
MESH POINT TEMPERATURES (F) LEFT TO RIGHT  
8.531508E+01 8.502402E+01 8.473150E+01 8.444.33E+01 8.415451E+01 8.386469E+01 8.357488E+01 8.328508E+01 8.299613E+01  
8.167073E+01 8.036888E+01 7.902613E+01 7.771005E+01 7.657361E+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR 7.978860E+03 -2.216235E+01 -5.84254E+02 0.10010 1.389028E+03 3 VAPOR 1.389028E+03 3.273770E-03 1.476141E+03  
LEFT FILM COEF .H = 4.811576E-01 BTU/HR FT2 F FIRST MESH K = 3.50000E-02 BTU/HR FT BULK TEMP = 8.381948E+01 F  
RIGHT FILM COEF .H = 1.00000E+04 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 9.000000E+01 F  
MESH POINT TEMPERATURES (F) LEFT TO RIGHT  
7.869348E+01 7.835257E+01 7.805287E+01 8.021450E+01 8.137830E+01 8.254502E+01 8.371457E+01 8.488598E+01 8.605852E+01  
8.723167E+01 8.765296E+01 8.815434E+01 8.861572E+01 8.907710E+01 8.953849E+01 8.999987E+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
0 LIQUID 9.875762E+03 -2.742670E-01 -6.45954E+03 0.1 LIQUID 1.389028E+03 3 VAPOR 1.389028E+03 3.273770E-03 1.476141E+03  
LEFT FILM COEF .H = 4.785000E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 9.00000E+01 F  
RIGHT FILM COEF .H = 1.90000E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 8.381948E+01 F  
MESH POINT TEMPERATURES (F) LEFT TO RIGHT  
8.546619E+01 8.485673E+01 8.442579E+01 8.398362E+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR 1.407674E+03 -3.909496E-02 1.504239E+01 0.1 LIQUID -2.240289E+03 -6.223019E-02 -3.711740E+02  
LEFT FILM COEF .H = 3.587406E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 8.381948E+01 F  
RIGHT FILM COEF .H = 4.279232E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 9.00000E+01 F  
MESH POINT TEMPERATURES (F) LEFT TO RIGHT  
7.952258E+01 8.000419E+01 8.060899E+01 8.121963E+01 8.183047E+01 8.244132E+01 8.305216E+01 8.366260E+01 8.426713E+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
0 LIQUID -2.429629E+03 -6.748963E-02 -4.025442E+02 3 VAPOR -1.526645E+03 -4.239911E-02 -1.631371E+01  
LEFT FILM COEF .H = 4.279232E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 9.00000E+01 F  
RIGHT FILM COEF .H = 3.587409E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 8.381948E+01 F  
MESH POINT TEMPERATURES (F) LEFT TO RIGHT  
8.426713E+01 8.366260E+01 8.305216E+01 8.244132E+01 8.183047E+01 8.121963E+01 8.060899E+01 8.000419E+01 7.952258E+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -2.218849E+03 -6.162915E-02 -1.406743E+02 0.1 LIQUID -6.768987E+03 -1.880270E-02 -1.109619E+02  
LEFT FILM COEF .H = 4.171682E-01 BTU/HR FT2 F FIRST MESH K = 6.70000E-02 BTU/HR FT BULK TEMP = 8.381948E+01 F  
RIGHT FILM COEF .H = 3.507311E-01 BTU/HR FT2 F LAST MESH K = 6.70000E-02 BTU/HR FT BULK TEMP = 9.000000E+01 F  
MESH POINT TEMPERATURES (F) LEFT TO RIGHT  
7.706712E+01 7.659425E+01 7.797424E+01 7.895878E+01 7.994632E+01 8.093538E+01 8.115323E+01 8.137183E+01 8.159046E+01  
8.180639E+01 8.202771E+01 8.224634E+01 8.246497E+01 8.268354E+01 8.272290E+01 8.277100E+01 8.281463E+01 8.285813E+01  
8.294987E+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
COMP. STEP-1 LIQUID STEP-VAPOR NET-1 LIQUID NET-VAPOR  
0 0 0 -5.677488E+01 0  
1 0 0 0  
2 0 0 0  
3 0 0 -4.120852E+01 0  
4 0 0 0

COMP NO	PRESSURE (PSIA)		TEMPERATURE (F)		ENERGY (BTU)		CONVERGENCE DE/E
	TOTAL	STEAM	ATMOS	POOL	ATMOS	POOL	
1	1.470000E+01	0	7.340000E+01	7.340000E+01	0	0	1.53559D-06
3	1.470030E+01	1.630300E-01	8.382030E+01	8.382030E+01	3.911680E+05	0	TRANSFER COEFFICIENTS
AIR MASS (LBM)		WATER MASS (LBM)		HUMIDITY		CONDENSATION MASS (LB M/L/S FT2)	
VAPOR--ATMOS--LIQUID		POOL		TOTAL		PENETRATION	
1	0	0	0	0	0	0	0
3	3.905510E+03	2.722460E+01	0	0	2.722460E+01	2.839340E-01	0
LEAKAGE OUTFLOW MASS = 3.15720E+02 LBM/HR		ENERGY BTU/HR = 4.31870E+04 (NORMAL = 4.31870E+04)		NET VAPOR = 5.31920E-01		NET AIR = 7.63070E+01	
TOTAL NET MASS LOSSES LBM STEP VAPOR = 6.07100E-05		STEP AIR = 0.01 WATER VAPOR(LBM) = 5.319217D-01		TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) = 7.63071			

\*\*\*\*\* TIME = 1.833333E-01 HR = 1.100000E+01 MIN = 6.600000E+02 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -9.211408D+02 -2.558717D-02 -1.654857E+02 3 VAPOR -2.052220D+03 -5.700143D-02 -1.375025D+02  
 LEFT FILM COEF .H = 2.000000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.165667E+01 F  
 RIGHT FILM COEF .H = 4.171812E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 8.452745D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.531534D+01 8.502404D+01 8.473416D+01 8.444433D+01 8.415451D+01 8.386469D+01 8.357488D+01 8.328509D+01 8.299647D+01  
 8.168735D+01 8.037999D+01 7.907615D+01 7.777620D+01 7.775442D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -8.491072D+03 -2.358519D-01 -7.317491D+02 0 LIQUID -4.298599D+03 -1.194055D-01 -7.880765D+02  
 LEFT FILM COEF .H = 4.808532E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT. BULK TEMP = 8.452745E+01 F  
 RIGHT FILM COEF .H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.906892D+01 7.840986D+01 7.907081D+01 8.022827D+01 8.128836D+01 8.255203D+01 8.371924D+01 8.488883D+01 8.605988D+01  
 8.723162D+01 8.769296D+01 8.815434D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 LIQUID -9.875775D+03 -2.743271D-01 -1.810550D+03 3 VAPOR -4.482326D+02 -1.243768D-02 -1.413519D+03  
 LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 1.900000E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 8.452745D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.536618D+01 8.485671D+01 8.442635D+01 8.399779D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.713324D+03 -4.758530D-02 -1.096978D+01 0 LIQUID -2.242864D+03 -6.230171D-02 -4.085337D+02  
 LEFT FILM COEF .H = 3.765407E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 8.452745E+01 F  
 RIGHT FILM COEF .H = 4.283775E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.954479D+01 8.000586D+01 8.060907D+01 8.121963D+01 8.183047D+01 8.244132D+01 8.305215D+01 8.366252D+01 8.426663D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 LIQUID 72422D+03 -6.756720D-02 -4.430613D+02 3 VAPOR -1.858127D+03 -5.160702D-02 -1.189690D+01  
 LEFT FILM COEF .H = 4.283775E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 3.765407E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 8.452745D+01 F

PCC



CONTEMP-LV/028.30 APRIL 1978, EG&G IDAHO INC. CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM PAGE 37  
COOPER NO. EAR STATION CONTROL ROOM #1 ATUP ANALYSIS 89/12/14

LEFT FILM COEF .H = 4.785000E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT F BULK T.M.P = 9.000000E+01 F  
RIGHT FILM COEF .H = 2.330381E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK T.M.P = 8.519808E+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
B. 536617D+01 8.489670D+01 8.442713D+01 8.401247D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -2.014405D+03 -5.594884D-02 -4.204330D+01 0 LIQUID -2.245420D+03 -6.237273D-02 -4.459361D+02  
LEFT FILM COEF .H = 3.918337E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT F BULK T.M.P = 8.519808E+01 F  
RIGHT FILM COEF .H = 4.288302E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK T.M.P = 9.000000E+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
7.956846D+01 8.000779D+01 8.060917D+01 8.121964D+01 8.183047D+01 8.244132D+01 8.305215D+01 8.366244D+01 8.426515D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -2.435194D+03 -6.764422D-02 -4.836248D+02 3 VAPOR -2.184654E+03 -6.067738D-02 -4.355977D+01  
LEFT FILM COEF .H = 4.288302E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT F BULK T.M.P = 9.000000E+01 F  
RIGHT FILM COEF .H = 3.918337E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK T.M.P = 8.519808E+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.425645D+01 8.356244D+01 8.305215D+01 8.244132D+01 8.183047D+01 8.121964D+01 8.060517D+01 8.000779D+01 7.956846D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -2.665606D+03 -7.403982D-02 -2.222582D+02 0 LIQUID -6.806378D+02 -1.890656D-02 -1.335881D+03  
LEFT FILM COEF .H = 4.361427E-01 BTU/HR FT2 F FIRST MESH K = 6.700000E-02 BTU/HR FT F BULK T.M.P = 8.519808E+01 F  
RIGHT FILM COEF .H = 3.521535E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT F BULK T.M.P = 9.000000E+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
7.743907D+01 7.713484E+01 7.807842D+01 7.902775D+01 7.998095D+01 8.093610D+01 8.115325D+01 8.137183D+01 8.159046D+01  
8.180909D+01 8.202771D+01 8.224634D+01 8.246496D+01 8.268351D+01 8.286430D+01 8.305215D+01 8.326430D+01 8.348000D+01  
8.374629D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR

0	0	-5.683367D-01	0	0	0	0
1	0	0	0	0	0	0
2	0	0	0	0	0	0
3	0	-5.358786D-01	0	4.007991D+01	0	0
4	0	0	0	0	0	0

COMP. NO.	PRESSURE (PSIA)	TEMPERATURE (F)	ATMOS. POOL	ENERGY (BTU)	ATMOS. HUMIDITY (LB/S)	CONDENSATION (LB/S)	CONVEGENCE DE/E
1	1.47000D+01	0	7.34000D+01	7.34000D+01	0	0	0
3	1.470030D+01	1.63031D-01	8.51990D+01	8.51990D+01	3.91109D+05	3.91109D+05	1.7794D-06

AIR MASS (LB)	VAPOR--ATMOS--LIQUID	MASS (LB)	HUMIDITY (LB/S)	CONVEGENCE DE/E
0	0	0	0	0
1	0	0	6.00000D-01	0
3	8.9563D+03	2.71557D+01	2.71630D-01	0

COMP. 3 LEAKAGE OUTFLOW MASS = 2.8096D+02 LBM/HR ENERGY BTU/HR = 3.8525D+04 (NORMAL = 3.8525D+04 PENETRATION = 0)  
STEP AND NET MASS LOSSES LBM STEP VAPOR = 5.4026D-05 STEP AIR = 7.4D-03 NET VAPOR = 6.0084D-01 NET AIR = 8.613D+01  
TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR (LBM) = 8.613333E+01 AFTER VAPOR (LBM) = 6.008363D-01

\*\*\*\*\* TIME = 2.166667E-01 HR = 1.300000E+01 MIN = 7.800000E+02 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
0 VAPOR -9.278452D+02 -2.577312D-02 -1.963017D+02 3 VAPOR -2.425586D+03 -6.737344D-02 -2.123093D+02

LEFT FILM COEF .H = 2.00000E+00 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT BULK TEMP = 9.170333E+01 F  
 RIGHT FILM COEF .H = 4.34417E-01 BTU/HR.FT2.F LAST MESH K = 6.70000E-02 BTU/HR.FT.F BULK TEMP = 8.582807D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.521592D+01 8.502408D+01 8.473416D+01 8.444433D+01 8.415451D+01 8.386464D+01 8.357488D+01 8.328513D+01 8.299742D+01  
 8.122705D+01 8.045887D+01 7.919504D+01 7.793777D+01 7.614042D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR 9.357645D+03 -2.589258D-01 -1.029825D+03 OIL LIQID -4.258599D-03 -1.194055D-01 -9.313632D+02  
 LEFT FILM COEF .H = 4.802939E-01 BTU/HR.FT2.F FIRST MESH K = 3.50000E-02 BTU/HR.FT BULK TEMP = 8.582807E+01 F  
 RIGHT FILM COEF .H = 1.00000E+04 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.00000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.860546D+01 7.853947D+01 7.914151D+01 8.026408D+01 8.141508D+01 8.257108D+01 8.373221D+01 8.489687D+01 8.606374D+01  
 8.722167D+01 8.769294D+01 8.815434D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OIL LIQID -9.875803D+03 -2.743279D-01 -2.139743D+03 3 VAPOR -2.145530D+03 -5.957649D-02 -1.372462D+03  
 LEFT FILM COEF .H = 4.785060E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF .H = 2.676156E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 8.582807D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.536617D+01 8.489671D+01 8.442811D+01 8.402806D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.306155D+03 -6.405324D-02 -7.806348D+01 OIL LIQID -2.247959D+03 -6.244325D-02 -4.833809D+02  
 LEFT FILM COEF .H = 4.050586E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT BULK TEMP = 8.582807E+01 F  
 RIGHT FILM COEF .H = 4.292815E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.00000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.959353D+01 8.000960D+01 8.060930D+01 8.121964D+01 8.183047D+01 8.244132D+01 8.305214D+01 8.366236D+01 8.426570D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OIL LIQID -2.437947D+03 -6.772670D-02 -5.242343D+02 3 VAPOR -2.501062D+03 -6.946676D-02 -8.466109D+01  
 LEFT FILM COEF .H = 4.292815E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF .H = 4.050586E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 8.582807D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.426570D+01 8.366236D+01 8.305214D+01 8.244132D+01 8.183047D+01 8.121964D+01 8.060930D+01 8.000960D+01 7.959353D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.863007D+03 -7.952361D-02 -2.683520D+02 OIL LIQID -6.824252D+02 -1.895621D-02 -1.449471D+02  
 LEFT FILM COEF .H = 4.437219E-01 BTU/HR.FT2.F FIRST MESH K = 6.70000E-02 BTU/HR.FT BULK TEMP = 8.582807E+01 F  
 RIGHT FILM COEF .H = 3.528537E-01 BTU/HR.FT2.F LAST MESH K = 6.70000E-02 BTU/HR.FT.F BULK TEMP = 9.00000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.763682D+01 7.721802D+01 7.814012D+01 7.906868D+01 8.000156D+01 8.093660D+01 8.115327D+01 8.137183D+01 8.159046D+01  
 8.180909D+01 8.202771D+01 8.224634D+01 8.246496D+01 8.268349D+01 8.272601D+01 8.476845D+01 8.581089D+01 8.685316D+01  
 8.754473D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP. STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0 -5.586267D-01 0 -4.419971D+03  
 1 0 0 0 0  
 2 0 0 0 0  
 3 0 -5.999193D-01 0 -3.007521D+02  
 4 0 0 0 0

COMP NO	PRESSURE (PSIA)	TEMPERATURE (F)	ATMOS	POOL	ENERGY (BTU)	TOTAL	CONVERGENCE DE/E
1	1.47000+01	7.34000+01	0	0	0	0	0
3	1.47000+01	8.58290+01	3.91082D+05	0	3.91082D+05	1.79497D-06	

AIR MASS (LBM)	WATER MASS (LBM)	HUMIDITY (LB/S)	CONDENSATION (LB/S)	TRANSFER COEFFICIENTS (BTU/S FT <sup>2</sup> R)	HEAT MASS (LB MOL/S FT <sup>2</sup> )
0	0	0	0	0	0
3.89116+03	2.71243D+01	6.00000D-01	0	0	0
3	2.6308D+02	3.6114D+04	3.6114D+04	3.6114D+04	3.6114D+04

STEP AND NET MASS LOSSES LBM STEP VAPOR= 5.0589D-05 STEP AIR= 7.2572D-03 NET VAPOR= 6.3222D-01 NET AIR= 9.0695D+01  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 9.069482D+01 WATER VAPOR(LBM)= 6.322153D-01

\*\*\*\*\* TIME = 2.33333E-01 HR = 1.40000E+01 MIN = 8.40000E+02 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -9.31177D+02 -2.58659D+02 -2.17935D+02 3 VAPOR -2.58809D+03 -7.18878D-02 -2.54124D+02  
 LEFT FILM COEF. H = 2.00000E-01 BTU/HR FT<sup>2</sup> F FIRST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 9.172667E+01 F  
 RIGHT FILM COEF. H = 4.41255E-01 BTU/HR FT<sup>2</sup> F LAST MESH K = 6.70000E-02 BTU/HR FT F BULK TEMP = 8.641856E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.531625D+01 8.502411D+01 8.473416D+01 8.14333D+01 8.45451D+01 8.386468D+01 8.357488D+01 8.328516D+01 8.299803D+01  
 8.175005D+01 8.050447D+01 7.926363D+01 7.802995D+01 7.834293D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -9.71420D+03 -2.69831D+01 -1.188823E+03 0 LIQUID -4.298599D+03 -1.194055D-01 -1.00306D+03  
 LEFT FILM COEF. H = 4.800400E-01 BTU/HR FT<sup>2</sup> F FIRST MESH K = 3.50000E-02 BTU/HR FT F BULK TEMP = 8.641856E+01 F  
 RIGHT FILM COEF. H = 1.00000E+04 BTU/HR FT<sup>2</sup> F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 9.00000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.016315D+01 7.861108D+01 7.914482D+01 8.042007D+01 8.143194D+01 8.258332D+01 8.374068D+01 8.490219D+01 8.606631D+01  
 8.723171D+01 8.769296D+01 8.815433D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 LIQUID -9.875815D+03 -2.74328D-01 -2.304340E+03 3 VAPOR -3.100718D+03 -8.610876D-02 -1.32871D+03  
 LEFT FILM COEF. H = 4.78500E-01 BTU/HR FT<sup>2</sup> F FIRST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF. H = 2.932518E-01 BTU/HR FT<sup>2</sup> F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 8.641856D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.536616D+01 8.489673D+01 8.442932D+01 8.404461D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.586490D+03 -7.18406D-02 -1.188526D+02 0 LIQUID -2.250480D+03 -6.251328D-02 -5.208679D+02  
 LEFT FILM COEF. H = 4.166018E-01 BTU/HR FT<sup>2</sup> F FIRST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 8.641856E+01 F  
 RIGHT FILM COEF. H = 4.297312E-01 BTU/HR FT<sup>2</sup> F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 9.00000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.961989D+01 8.001241D+01 8.060945D+01 8.121965D+01 8.183048D+01 8.244132D+01 8.305213D+01 8.366227D+01 8.426528D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 LIQUID -2.44082D+03 -6.77966D-02 -5.648896D+02 3 VAPOR -2.80509D+03 -7.791229D-02 -1.288975D+02  
 LEFT FILM COEF. H = 4.297312E-01 BTU/HR FT<sup>2</sup> F FIRST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF. H = 4.166018E-01 BTU/HR FT<sup>2</sup> F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 8.641856D+01 F

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.426528D+01 8.366227D+01 8.305213D+01 8.244132D+01 8.183048D+01 8.121965D+01 8.060945D+01 8.001241D+01 7.961989D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 3 VAPOR -3.042223D+03 8.450224D-02 -3.175907D+02 0. LIQUID -6.841638D+02 -1.900451D-02 -1.563754D+02

RIGHT FILM COEF. H = 4.502417E-01 BTU/HR FT2 F FIRST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 8.641856E+01 F  
 LAST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 9.000000D+01 F

RIGHT FILM COEF. H = 3.525473E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 9.000000D+01 F

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.784059D+01 7.730930D+01 7.810802D+01 7.911381D+01 8.002431D+01 8.093719D+01 8.115230D+01 8.137183D+01 8.159046D+01  
 8.180909D+01 8.202771D+01 8.224634D+01 8.246496D+01 8.268347D+01 8.372559D+01 8.476768D+01 8.580968D+01 8.685156D+01

8.754330D+01  
 SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0 0 0  
 1 0 0 0  
 2 0 -6.620931D-01 0  
 3 0 -6.620931D-01 0  
 4 0 0 0

CONVERGENCE DE/E

COMP NO	PRESSURE (PSIA)	TEMPERATURE (F)	ATMOS	POOL	ENERGY (BTU)	TOTAL	CONDENSATION (LB/S)	TRANSFER COEFFICIENTS
1	1.47000D+01	7.34000D+01	7.34000D+01	0	0	0	0	7.87800D-06
3	1.47002D+01	8.64195D+01	8.64195D+01	3.91056D+05	0	3.91056D+05	0	HEAT

WATER MASS (LB) TOTAL 6.00000D-01 0  
 VAPOR--ATMOS--LIQUID 0 0  
 2.70949D+01 2.61241D-01 0  
 3.88691D+03 2.4578D+02 LBM/HR ENERGY BTU/HR = 3.3773D+04 (NORMAL= 3.3773D+04 PENETRATION= 0)  
 3 LEAKAGE OUTFLOW- MASS= 2.4578D+02 LBM/HR ENERGY BTU/HR = 3.3773D+04 (NORMAL= 3.3773D+04 PENETRATION= 0)  
 STEP AND NET MASS LOSSES LBM STEP VAPOR= 4.7261D-05 STEP AIR= 6.7799D-03 NET VAPOR= 6.6156D-01 NET AIR= 9.4905D+01  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 9.490473D+01 WATER VAPOR(LBM)= 6.615617D-01

\*\*\*\*\* TIME = 2.500000E-01 HR = 1.500000E+01 MIN = 9.000000E+02 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 0 VAPOR -9.345176D+02 -2.595874D-02 -2.273409D+02 3 VAPOR -2.734565D+03 -7.595694D-02 -2.984899D+02

LEFT FILM COEF. H = 2.00000E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.175000E+01 F  
 LAST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 8.697091D+01 F

RIGHT FILM COEF. H = 4.871225E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 8.697091D+01 F

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.531659D+01 8.502414D+01 8.473416D+01 8.444433D+01 8.415451D+01 8.386463D+01 8.357488D+01 8.328520D+01 8.299876D+01  
 8.177508D+01 8.055399D+01 7.933804D+01 7.812980D+01 7.855026D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 3 VAPOR -1.002532D+04 -2.784743D-01 -1.353379D+03 0. LIQUID -4.298599D+03 -1.194052D-01 -1.074650D+03

LEFT FILM COEF. H = 4.798025E-01 BTU/HR FT2 F FIRST MESH K = 3.500000E-02 BTU/HR FT F BULK TEMP = 8.697091E+01 F  
 LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000D+01 F

RIGHT FILM COEF. H = 1.000000E+04 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000D+01 F

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.051197D+01 7.868675D+01 7.917644D+01 8.031151D+01 8.145122D+01 8.259746D+01 8.375054D+01 8.490843D+01 8.606935D+01  
 8.723177D+01 8.769296D+01 8.815434D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.991987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 0. LIQUID -9.875874D+03 -2.743285D-01 -2.468937D+03 3 VAPOR -4.062613D+03 -1.128282D-01 -1.269069D+03





LEFT FILM COEF .H = 2.00000E-01BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT BULK TEMP = 9.177333E+01 F  
 RIGHT FILM COEF .H = 4.521472E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 8.748694E+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.531695+01 8.502417+01 8.473416+01 8.444433+01 8.415451+01 8.386469+01 8.357488+01 8.328524+01 8.299959+01  
 8.180203+01 8.060726+01 7.941798+01 7.823695+01 7.706111+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.029538D+04 -2.859769D-01 -1.522772D+03 OLIIQUID -4.298599D+03 -1.194055D-01 -1.146293D+03  
 LEFT FILM COEF .H = 4.795806E-01BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT BULK TEMP = 8.748694E+01 F  
 RIGHT FILM COEF .H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.085094+01 7.756111D+01 7.921156D+01 8.033967D+01 8.147296D+01 8.261354D+01 8.376185D+01 8.491562D+01 8.607287D+01  
 8.723183D+01 8.769296D+01 8.815434D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQUID -9.875830D+03 -2.743286D-01 -2.633534D+03 3 VAPOR -5.011351D+03 -1.391825D-01 -1.193425D+03  
 LEFT FILM COEF .H = 4.785000E-01BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 3.302998E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 8.748694D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.536616D+01 8.485684D+01 8.432444D+01 8.408054D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -3.107926D+03 -8.632557D-02 -2.139104D+02 OLIIQUID -2.255472D+03 -6.265194D-02 -5.959673D+02  
 LEFT FILM COEF .H = 4.357176E-01BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT BULK TEMP = 8.748694E+01 F  
 RIGHT FILM COEF .H = 4.306264E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 7.967607D+01 8.001815D+01 8.060985D+01 8.121967D+01 8.183048D+01 8.244132D+01 8.305211D+01 8.366208D+01 8.426450D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQUID -2.446095D+03 -6.794703D-02 -6.463361D+02 3 VAPOR -3.370596D+03 -9.362146D-02 -2.319892D+02  
 LEFT FILM COEF .H = 4.306264E-01BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.357176E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 8.748694D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.426450D+01 8.366208D+01 8.305211D+01 8.244132D+01 8.183048D+01 8.121967D+01 8.060985D+01 8.001815D+01 7.967607D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -3.347514D+03 -9.298336D-02 -4.242784D+02 OLIIQUID -6.875096D+02 -1.909745D-02 -1.791971D+02  
 LEFT FILM COEF .H = 4.606405E-01BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT BULK TEMP = 8.748694E+01 F  
 RIGHT FILM COEF .H = 3.549159E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 7.825124D+01 7.751050D+01 7.836138D+01 7.921591D+01 8.007592D+01 8.093870D+01 8.115336D+01 8.137184D+01 8.159046D+01  
 8.180909D+01 8.202771D+01 8.224634D+01 8.246496D+01 8.268362D+01 8.372478D+01 8.476611D+01 8.580735D+01 8.684848D+01  
 8.754081D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP. STEP-LIQUID NET-LIQUID NET-VAPOR  
 0 C -5.694820D-01 0  
 1 0 0  
 2 0 0  
 3 0 -7.776847D-01 0  
 4 0 -1.544704D+03 0

COMP NO	PRESSURE (PSIA)	TEMPERATURE (F)	ATMOS	POOL	ENR	GR	Y	(BTU) TOTAL	CONVERGENCE DE/F
1	1.470000+01	0	7.340000+01	7.340000+01	0	0	0	0	0
3	1.470020+01	1.630340-01	8.748800+01	8.748800+01	3.910110+05	0	3.910110+05	0	2.028930-06
<p>TRANSFER COEFFICIENTS                  HEAT MASS (BTU/S FT2 R)                  AIR MASS (LBM) VAPOR-ATMOS -LIQUID W A T E R M A S S (LBM) HUMIDITY CONDENSATION (LB/S) O O O                  1 0 3.879320+03 2.704200+01 0 2.704200+01 2.525170-01 0 6.000000-01 0 0                  3 3.879320+03 2.137100+02 LBM/HR ENERGY BTU/HR 2.942100+04 (NORMAL) 2.942100+04 PENETRATION= 0                  LEAKAGE OUTFLOW MASS= 2.137100+02 LBM/HR 2.942100+04 (NORMAL) 2.942100+04 PENETRATION= 0                  STEP AND NET MASS LOSSES LBM STEP VAPOR= 4.109400-05 STEP AIR= 5.895200-03 NET VAPOR= 7.145000-01 NET AIR= 1.025000+02                  TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.02499200+02 WATER VAPOR(LBM)= 7.14500090-01</p>									
<p>***** TIME = 2.833333E-01 HR = 1.71 JOE+01 MIN = 1.020000E+03 SEC *****</p>									
<p>HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL</p>									
TO LEFT COMP	END STEP BTU/HR	STEP BTU TOTAL NET BTU	TO RIGHT COMP	END STEP BTU/HR	STEP BTU TOTAL NET BTU				
0 VAPOR	-9.4118870-02	-2.6144050-02	3 VAPOR	-2.9816730+03	-8.2821720-02				
LEFT FILM COEF	H = 2.000000E-01 BTU/HR FT2 F	FIRST MESH K = 1.050000E+00 BTU/HR FT F	RIGHT FILM COEF	H = 6.700000E-02 BTU/HR FT F	BULK TEMP = 9.179667E+01 F				
RIGHT FILM COEF	H = 4.564397E-01 BTU/HR FT2 F	LAST MESH K = 6.700000E-02 BTU/HR FT F							
<p>MESH POINT TEMPERATURES (F), LEFT TO RIGHT</p>									
8.531730+01	8.5024210+01	8.4734160+01	8.4444330+01	8.4154510+01	8.3864690+01	8.3574880+01	8.3285300+01	8.3000550+01	
8.1830820+01	8.0664060+01	7.9503130+01	7.8350950+01	7.8974510+01					
<p>HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF &amp; CEILING</p>									
TO LEFT COMP	END STEP BTU/HR	STEP BTU TOTAL NET BTU	TO RIGHT COMP	END STEP BTU/HR	STEP BTU TOTAL NET BTU				
3 VAPOR	-1.7528690+04	-2.9245870-01	0 LIQUID	-4.2985990+03	-1.1940550-01				
LEFT FILM COEF	H = 4.793735E-01 BTU/HR FT2 F	FIRST MESH K = 3.500000E-02 BTU/HR FT F	RIGHT FILM COEF	H = 1.050000E+00 BTU/HR FT F	BULK TEMP = 8.796867E+01 F				
RIGHT FILM COEF	H = 1.000000E+04 BTU/HR FT2 F	LAST MESH K = 1.050000E+00 BTU/HR FT F							
<p>MESH POINT TEMPERATURES (F), LEFT TO RIGHT</p>									
8.1179250+01	7.6481830+01	7.9250140+01	8.0370800+01	8.1451600+01	8.2631570+01	8.3774620+01	8.4923790+01	8.6076890+01	
8.7231920+01	8.7692970+01	8.8154340+01	8.8615720+01	8.9077100+01	8.9538490+01	8.9999870+01			
<p>HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR</p>									
TO LEFT COMP	END STEP BTU/HR	STEP BTU TOTAL NET BTU	TO RIGHT COMP	END STEP BTU/HR	STEP BTU TOTAL NET BTU				
0 LIQUID	-9.8758330+03	-2.7432860-01	3 VAPOR	-5.9345960+03	-1.6482890-01				
LEFT FILM COEF	H = 3.785000E-01 BTU/HR FT2 F	FIRST MESH K = 1.050000E+00 BTU/HR FT F	RIGHT FILM COEF	H = 1.050000E+00 BTU/HR FT F	BULK TEMP = 9.000000E+01 F				
RIGHT FILM COEF	H = 3.442993E-01 BTU/HR FT2 F	LAST MESH K = 1.050000E+00 BTU/HR FT F							
<p>MESH POINT TEMPERATURES (F), LEFT TO RIGHT</p>									
8.5366160+01	8.4896930+01	8.4434360+01	8.4099850+01	8.3700000+01	8.3300000+01	8.2900000+01	8.2500000+01	8.2100000+01	
<p>HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL</p>									
TO LEFT COMP	END STEP BTU/HR	STEP BTU TOTAL NET BTU	TO RIGHT COMP	END STEP BTU/HR	STEP BTU TOTAL NET BTU				
3 VAPOR	-3.3479630+03	-9.2993580-02	0 LIQUID	-2.2579430+03	-6.2720590-02				
LEFT FILM COEF	H = 4.436874E-01 BTU/HR FT2 F	FIRST MESH K = 1.050000E+00 BTU/HR FT F	RIGHT FILM COEF	H = 1.050000E+00 BTU/HR FT F	BULK TEMP = 8.796867E+01 F				
RIGHT FILM COEF	H = 4.310718E-01 BTU/HR FT2 F	LAST MESH K = 1.050000E+00 BTU/HR FT F							
<p>MESH POINT TEMPERATURES (F), LEFT TO RIGHT</p>									
7.9703670+01	8.0021450+01	8.0610090+01	8.1119680+01	8.2441320+01	8.3052100+01	8.3661990+01	8.4264150+01		
<p>HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL</p>									
TO LEFT COMP	END STEP BTU/HR	STEP BTU TOTAL NET BTU	TO RIGHT COMP	END STEP BTU/HR	STEP BTU TOTAL NET BTU				
0 LIQUID	-2.4487760+03	-6.8021490-02	3 VAPOR	-3.6309200+03	-1.0085300-01				
LEFT FILM COEF	H = 4.436874E-01 BTU/HR FT2 F	FIRST MESH K = 1.050000E+00 BTU/HR FT F	RIGHT FILM COEF	H = 1.050000E+00 BTU/HR FT F	BULK TEMP = 9.000000E+01 F				
RIGHT FILM COEF	H = 4.436874E-01 BTU/HR FT2 F	LAST MESH K = 1.050000E+00 BTU/HR FT F							





LEFT FILM COEF .H = 2.00000E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT. BULK TEMP = 9.184333E+01 F  
 RIGHT FILM COEF .H = 4.631697E-01 BTU/HR FT2 F LAST MESH K = 6.70000E-02 BTU/HR FT F BULK TEMP = 8.883762D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.531814D+01 8.502129D+01 8.473117D+01 8.444330D+01 8.415451D+01 8.386470D+01 8.357489D+01 8.328545D+01 8.300286D+01  
 8.189346D+01 8.078734D+01 7.968768D+01 7.859767D+01 7.750547D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.090096D+04 -3.028607D-01 -2.053837D+03 OL LIQUID -4.258599D+03 -1.194055D-01 -1.361223D+03  
 LEFT FILM COEF .H = 4.789998E-01 BTU/HR FT2 F FIRST MESH K = 3.50000E-02 BTU/HR FT. BULK TEMP = 8.883762E+01 F  
 RIGHT FILM COEF .H = 1.00000E+04 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.180276D+01 7.902304D+01 7.933745D+01 8.044182D+01 8.155289D+01 8.267354D+01 8.380358D+01 8.494309D+01 8.608642D+01  
 8.723214D+01 8.769297D+01 8.815434D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 3 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OL LIQUID -9.875807D+03 -2.743280D-01 -3.127326D+03 3 VAPOR -7.677040D+03 -2.132318D-01 -8.748875D+02  
 LEFT FILM COEF .H = 4.785000E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 3.669807E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 8.883762D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.836617D+01 8.489721D+01 8.443897D+01 8.414083D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -3.786714D+03 -1.051817D-01 -3.867812D+02 OL LIQUID -2.262839D+03 -6.285659D-02 -7.089257D+02  
 LEFT FILM COEF .H = 4.571694E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 3.319585E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 8.883762E+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 7.976736D+01 8.002894D+01 8.061070D+01 8.121972D+01 8.183048D+01 8.244132D+01 8.305208D+01 8.366179D+01 8.426352D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OL LIQUID -2.454085D+03 -6.816897D-02 -7.688412D+02 3 VAPOR -4.106752D+03 -1.140713D-01 -4.194812D+02  
 LEFT FILM COEF .H = 4.319885E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.571694E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 8.883762D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.426352D+01 8.366179D+01 8.305208D+01 8.244132D+01 8.183048D+01 8.121972D+01 8.061070D+01 8.002894D+01 7.976736D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -3.684944D+03 -1.023574D-01 -6.006490D+02 OL LIQUID -6.522407D+02 -1.922887D-02 -136922L+02  
 LEFT FILM COEF .H = 4.71190E-01 BTU/HR FT2 F FIRST MESH K = 6.70000E-02 BTU/HR FT. BULK TEMP = 8.883762E+01 F  
 RIGHT FILM COEF .H = 3.569274E-01 BTU/HR FT2 F LAST MESH K = 6.70000E-02 BTU/HR FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 7.890937D+01 7.787502D+01 7.863046D+01 7.939554D+01 8.016707D+01 8.054188D+01 8.115357D+01 8.137185D+01 8.159046D+01  
 8.180909D+01 8.202771D+01 8.224634D+01 8.246495D+01 8.268335D+01 8.372366D+01 8.476393D+01 8.580414D+01 8.684425D+01  
 8.793784D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES UNITS ARE BTU  
 COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0 -5.703170D-01 0 -6.470094D+03  
 1 0 0 0 0  
 2 0 0 0 0  
 3 0 -9.257831D-01 0 -3.082520D+01  
 4 0 0 0 0

COMP NO	PRESSURE (PSIA)		TEMPERATURE (F)		ENERGY (BTU)			CONVERGENCE DE/E
	TOTAL	STEAM	ATMOS	POOL	ATMOS	POOL	TOTAL	
1	1.47000D+01	0.	7.34000D+01	7.34000D+01	0.	0.	0.	0.
3	1.47002D+01	1.63035D-01	8.88388D+01	8.88388D+01	3.90953D+05	0.	3.90953D+05	2.21240D-06

COMP NO	AIR MASS (LBM)	WATER MASS (LBM)		TOTAL (LBM)	HUMIDITY (LB/S)	CONDENSATION (LB/S)	TRANSFER COEFFICIENTS (BTU/S FT2 R)	
	VAPOR	ATMOS	LIQUID				MASS	HEAT
1	0.	0.	0.	0.	6.00000D-01	0.	0.	0.
3	3.86976D+03	2.69754D+01	0.	2.69754D+01	1.41957D-01	0.	0.	0.

COMP 3 LEAKAGE OUTFLOW MASS = 1.7280D+02 LBM/HR ENERGY BTU/HR = 2.3846D+04 (NORMAL = 2.3846D+04 PENETRATION = 0.)  
 STEP AND NET MASS LOSSES LBM STEP VAPOR = 3.3229D-05 STEP AIR = 4.7609D-03 NET VAPOR = 7.8114D-01 NET AIR = 1.1206D+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) = 1.120584D+02 WATER VAPOR(LBM) = 7.811363D-01

\*\*\*\*\* TIME = 3.33333E-01 HR = 2.00000E+01 MIN = 1.20000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
0 VAPOR	-9.51175D+02	-2.642145D-02	-3.059119D+02	3 VAPOR	-3.250286D+03	-9.028407D-02	-5.501935D+02

LEFT FILM COEF .H = 2.00000E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 9.186667E+01 F  
 RIGHT FILM COEF .H = 4.657963E-01 BTU/HR FT2 F LAST MESH K = 6.70000E-02 BTU/HR FT F BULK TEMP = 8.922903D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.531858D+01 8.502434D+01 8.473418D+01 8.444433D+01 8.415451D+01 8.386470D+01 8.357490D+01 8.328554D+01 8.300421D+01  
 8.192706D+01 8.085334D+01 7.978633D+01 7.872937D+01 7.762155D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
3 VAPOR	-1.104704D+04	-3.068592D-01	-2.236770D+03	0 LIQUID	-4.298599D+03	-1.194055D-01	-1.432866D+03

LEFT FILM COEF .H = 4.788315E-01 BTU/HR FT2 F FIRST MESH K = 3.50000E-02 BTU/HR FT BULK TEMP = 8.922903E+01 F  
 RIGHT FILM COEF .H = 1.00000E+04 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 9.00000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.209739D+01 7.911391D+01 7.938601D+01 8.048159D+01 8.158434D+01 8.269742D+01 8.382176D+01 8.495422D+01 8.609194D+01  
 8.773229D+01 8.769297D+01 8.815434D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.99987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
0 LIQUID	-9.87578D+03	-2.743272D-01	-3.291922D+03	3 VAPOR	-8.489206D+03	-2.357930D-01	7.401120D+02

LEFT FILM COEF .H = 4.785000E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF .H = 3.761795E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 8.922903D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.536618D+01 8.483740D+01 8.444166D+01 8.416237D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
3 VAPOR	-3.986112D+03	-1.107209D-01	-4.515827D+02	0 LIQUID	-2.265264D+03	-6.292395D-02	-7.466599D+02

LEFT FILM COEF .H = 4.628947E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 8.922903E+01 F  
 RIGHT FILM COEF .H = 4.323998E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 9.00000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.979925D+01 8.003314D+01 8.061107D+01 8.121974D+01 8.183048D+01 8.244132D+01 8.305206D+01 8.366169D+01 8.426323D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
0 LIQUID	-2.456715D+03	-6.824203D-02	-8.097646D+02	3 VAPOR	-4.323003D+03	-1.200786D-01	-4.897486D+02

LEFT FILM COEF .H = 4.323998E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF .H = 4.628947E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 8.922903D+01 F

PCC

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.426323D+01 8.366169D+01 8.305206D+01 8.244132D+01 8.183048D+01 8.121974D+01 8.061107D+01 8.003314D+01 7.979925D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -3.769384D+03 -1.047033D+01 -6.627681D+02  
 LEFT FILM COEF .H = 4.736806E-01 BTU/HR.FT<sup>2</sup>.F FIRST MESH K = 6.700000E-02 BTU/HR.FT BULK TEMP = 8.922903E+01 F  
 RIGHT FILM COEF .H = 3.575878E-01 BTU/HR.FT<sup>2</sup>.F LAST MESH K = 6.700000E-02 BTU/HR.FT F BULK TEMP = 8.922903E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.912664D+01 7.800672D+01 7.872908D+01 7.946151D+01 8.020065D+01 8.094321D+01 8.115366D+01 8.137185D+01 8.159J46D+01  
 8.180909D+01 8.202771D+01 8.224634D+01 8.246435D+01 8.268332D+01 8.272333D+01 8.276325D+01 8.280316D+01 8.284295D+01  
 8.753703D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0. -5.705910D-01 0. -6.812367D+03  
 1 0. 0. 0. 0.  
 2 0. 0. 0. 0.  
 3 0. -9.684390D-01 0. -3.650969D+03  
 4 0. 0. 0. 0.

COMP. NO.	PRESSURE (PSIA)	TEMPERATURE (F)	ATMOS	E N E R G Y	HUMIDITY	CONDENSATION	TRANSFER COEFFICIENTS	CON. ERGENCE
	TOTAL	ATMOS	POOL	ATMOS	POOL	(LB/S)	(BTU/S FT <sup>2</sup> )	DE/E
1	1.47000D+01	7.34000D+01	7.34000D+01	0	0	0	0	0
3	1.47002D+01	1.63035D-01	8.92302D+01	3.90936D+05	0	3.90936D+05	2.26343D-06	0
1	AIR MASS (LB)	W A T E R M A S S ( L B M )	P O O L	T O T A L	H U M I D I T Y	C O N D E N S A T I O N	M A S S	H E A T
3	3.86700D+03	2.69561D+01	0	2.69561D+01	6.00000D-01	0	0	0
COMP.	3 LEAKAGE OUTFLOW- MASS= 1.6106D+02 LBM/HR	ENERGY BTU/HR = 2.2241D+04 (NORMAL= 2.2241D+04 PENETRATION= 0)						
	STEP AND NET MASS LOSSES LBM STEP VAPOR= 3.0970D-05	STEP AIR= 4.428D-03 NET VAPOR= 8.0029D-01 NET AIR= 1.1482D+02						
	TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.148198D-02 WATER VAPOR(LBM)= 8.003861D-01							

\*\*\*\*\* TIME = 3.50000E-01 HR = 2.10000E+01 MIN = 1.26000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -9.544986D+02 -2.651377D-02 -3.217925D+02  
 LEFT FILM COEF .H = 2.000000E-01 BTU/HR.FT<sup>2</sup>.F FIRST MESH K = 1.050000E+00 BTU/HR.FT BULK TEMP = 9.189000E+01 F  
 RIGHT FILM COEF .H = 4.679729E-01 BTU/HR.FT<sup>2</sup>.F LAST MESH K = 6.700000E-02 BTU/HR.FT F BULK TEMP = 8.959443D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.531903D+01 8.502440D+01 8.473418D+01 8.444433D+01 8.415451D+01 8.386470D+01 8.357490D+01 8.328565D+01 8.300571D+01  
 8.198202D+01 8.092190D+01 7.988873D+01 7.886597D+01 7.983720D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.117062D+04 -3.102925D-01 -2.421947D+03  
 LEFT FILM COEF .H = 4.786744E-01 BTU/HR.FT<sup>2</sup>.F FIRST MESH K = 3.500000E-02 BTU/HR.FT BULK TEMP = 8.959443E+01 F  
 RIGHT FILM COEF .H = 1.000000E+04 BTU/HR.FT<sup>2</sup>.F LAST MESH K = 1.050000E+00 BTU/HR.FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.238065D+01 7.920692D+01 7.943770D+01 8.052409D+01 8.10182D+01 8.272319D+01 8.384037D+01 8.496632D+01 8.605797D+01  
 8.723246D+01 8.769298D+01 8.815434D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 LIQUID -9.875740D+03 -2.743261D-01 -3.456518D+03  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -9.260190D+03 -2.572101D-01 -5.921729D+02





LEFT FILM COEF .H = 2.00000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.191333E+01 F  
 RIGHT FILM COEF .H = 4.697708E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 8.993573D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.531950D+01 8.502446D+01 8.473418D+01 8.444434D+01 8.415451D+01 8.386470D+01 8.357491D+01 8.328578D+01 8.300734D+01  
 8.199822D+01 8.099277D+01 7.999450D+01 7.900695D+01 8.005192D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.127443D+04 -3.131765D+03 -2.609015D+03 OL LIQUID -4.298599D+03 -1.194055D+01 -1.576153D+03  
 LEFT FILM COEF .H = 4.785276E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT. BULK TEMP = 8.993573E+01 F  
 RIGHT FILM COEF .H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.765266D+01 7.930180D+01 7.912240D+01 8.056923D+01 8.165415D+01 8.275081D+01 8.386039D+01 8.497937D+01 8.611448D+01  
 8.723265D+01 8.769298D+01 8.815434D+01 8.861572D+01 8.953849D+01 8.999870D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OL LIQUID -9.875684D+03 -2.743246D+01 -3.621130D+03 3 VAPOR -9.990029D+03 -2.774844D+01 -4.316677D+02  
 LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 3.915342E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 8.993573D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.536622D+01 8.489790D+01 8.448783D+01 8.420715D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -4.347581D+03 -1.207622D+01 -5.906113D+02 OL LIQUID -2.270070D+03 -6.205745D+02 -8.222490D+02  
 LEFT FILM COEF .H = 4.727219E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 8.993573E+01 F  
 RIGHT FILM COEF .H = 4.332785E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.986465D+01 8.004244D+01 8.061194D+01 8.121981D+01 8.183048D+01 8.244132D+01 8.305203D+01 8.366148D+01 8.426272D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OL LIQUID -2.461927D+03 -6.838681D+02 -8.917421D+02 3 VAPOR -4.745022D+03 -1.309688D+01 -6.405274D+02  
 LEFT FILM COEF .H = 4.332785E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.727219E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 8.993573D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.426272D+01 8.366148D+01 8.305203D+01 8.244132D+01 8.183048D+01 8.121981D+01 8.061194D+01 8.004244D+01 7.986465D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -3.902621D+03 -1.084048D+01 -7.907772D+02 OL LIQUID -6.966751D+02 -1.935205D+02 -2.484162D+02  
 LEFT FILM COEF .H = 4.774656E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 8.993573E+01 F  
 RIGHT FILM COEF .H = 3.588945E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.955926D+01 7.828456D+01 7.893743D+01 7.960103D+01 8.027182D+01 8.094629D+01 8.115389D+01 8.137186D+01 8.159046D+01  
 8.180909D+01 8.202771D+01 8.224634D+01 8.246494D+01 8.268326D+01 8.372265D+01 8.476201D+01 8.580132D+01 8.684053D+01  
 8.753565D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP. STEP LIQUID STEP VAPOR NET LIQUID NET VAPOR  
 0 0. -5.711224D-01 0. -7.497402D+03  
 1 0. 0. 0.  
 2 0. 0. 0.  
 3 0. -1.044470D+00 0. -4.859946D+03  
 4 0. 0. 0.

89/12/14

COMP NO.	PRESSURE (PSIA)		TEMPERATURE (F)			ENERGY (BTU)			CONVERGENCE DE/E
	TOTAL	STEAM	ATMOS	POOL	ATMOS	POOL	TOTAL		
1	1.47000D+01	0.	7.34000D+01	7.34000D+01	0.	0.	0.	0.	
3	1.47002D+01	1.63036D-01	8.99370D+01	8.99370D+01	3.90906D+05	0.	3.90906D+05	2.35190D-06	

COMP.	AIR MASS (LBM)	WATER MASS (LB)			HUMIDITY	CONDENSATION (LB/S)	TRANSFER COEFFICIENTS	
	VAPOR-ATMOS-LIQUID	POOL	TOTAL	MASS			HEAT	
1	0.	0.	0.	0.	6.00000D-01	0.	0.	0.
3	3.96202D+03	2.69214D+01	0.	2.69214D+01	2.33738D-01	0.	0.	0.

COMP. 3 LEAKAGE OUTFLOW MASS = 1.4016D+02 LBM/HR ENERGY BTU/HR = 1.9379D+04 (NORMAL = 1.9379D+04 PENETRATION = 0.)  
 STEP AND NET MASS LOSSES LBM STEP VAPOR = 2.6952D-05 STEP AIR = 3.8664D-03 NET VAPOR = 8.3507D-01 NET AIR = 1.1980D+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR (LBM) = 1.197959D+02 WATER VAPOR (LBM) = 8.350734D-01

\*\*\*\*\* TIME = 3.833333E-01 HR = 2.30000E+01 MIN = 1.38000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -9.611383D+02 -2.669821D-02 -3.537198D+02 3 VAPOR -3.418971D+03 -9.497042D-02 -7.172890D+02  
 LEFT FILM COEF. H = 2.00000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT BULK TEMP = 9.193667E+01 F  
 RIGHT FILM COEF. H = 4.712348E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.025474D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.531999D+01 8.502452D+01 8.473419D+01 8.444434D+01 8.415451D+01 8.386470D+01 8.357492D+01 8.328592D+01 8.300913D+01  
 8.203553D+01 8.106571D+01 8.010327D+01 7.915182D+01 0.026528D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.136090D+04 -3.155787D-01 -2.797665D+03 0 LIQUID -4.298599D+03 -1.194055D-01 -1.647796D+03  
 LEFT FILM COEF. H = 4.783905E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT BULK TEMP = 9.025474E+01 F  
 RIGHT FILM COEF. H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.291373D+01 7.939830D+01 7.954998D+01 8.061690D+01 8.169235D+01 8.278020D+01 8.388178D+01 8.499335D+01 8.61148D+01  
 8.723288D+01 8.769299D+01 8.815434D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 LIQUID -9.875611D+03 -2.743225D-01 -3.785708D+03 3 VAPOR -1.067947D+04 -2.966366D-01 -2.593665D+02  
 LEFT FILM COEF. H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF. H = 3.979971E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.025474D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.536626D+01 8.489821D+01 8.445132D+01 8.423026D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -4.510900D+03 -1.252991D-01 -6.644474D+02 0 LIQUID -2.272452D+03 -6.312360D-02 -8.601033D+02  
 LEFT FILM COEF. H = 4.769509E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT BULK TEMP = 9.025474E+01 F  
 RIGHT FILM COEF. H = 4.337158E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.989799D+01 8.004754D+01 8.061245D+01 8.121984D+01 8.183048D+01 8.244131D+01 8.305202D+01 8.366138D+01 8.426249D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 LIQUID -2.464510D+03 -6.845856D-02 -9.327958D+02 3 VAPOR -4.892143D+03 -1.358889D-01 -7.206038D+02  
 LEFT FILM COEF. H = 4.337158E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF. H = 4.769509E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.025474D+01 F

PCC

COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS  
89/12/14

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.426249D+01 8.366138D+01 8.305202D+01 8.244131D+01 8.183048D+01 8.121984D+01 8.061245D+01 8.004754D+01 7.983795D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
3 VAPOR -3.95345D+03 -1.098170D-01 -8.562579D+02 OL LIQUID -6.980941D+02 -1.939147D-02 -2.600393D+02  
LEFT FILM COEF .H = 4.788614E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.025474E+01 F  
RIGHT FILM COEF .H = 3.595311E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.000000D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
7.977366D+01 7.842967D+01 7.904636D+01 7.967407D+01 8.030917D+01 8.094805D+01 8.115403D+01 8.137187D+01 8.159045D+01  
8.180909D+01 8.202771D+01 8.224634D+01 8.246494D+01 8.268323D+01 8.289170D+01 8.310000D+01 8.328608D+01 8.347187D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP NO.	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
0	0	0	-7.840162D+03	0
1	0	0	0	0
2	0	0	0	0
3	0	0	0	0
4	0	0	0	0

COMP NO.	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	A T M O S P O O L	E N E R G Y P O O L	H U M I D I T Y (LB/S)	C O N D E N S A T I O N (LB/S)	M A S S M O L / S F T 2	H E A T T R A N S F E R (BTU/HR)	C O N V E R G E N C E (DE/E)
1	1.47000D+01	7.34000D+01	7.34000D+01	0	0	0	0	0	0
3	1.47002D+01	1.63036D-01	9.02560D+01	9.02560D+01	3.90893D+05	3.90893D+05	3.90893D+05	2.39002D-06	0
1	0	0	0	0	0	0	0	0	0
3	3.85978D+03	2.69058D+01	0	2.69058D+01	2.31410D-01	0	0	0	0
COMP	3 LEAKAGE OUTFLOW MASS = 1.30910D+02 LBM/HR	ENERGY BTU/HR = 1.8110D+03 (NORMAL = 1.8110D+04 PENETRATION = 0)							
STEP AND NET MASS LOSSES LBM	STEP VAPOR = 2.5173D-05	STEP AIR = 3.6112D-03	NET VAPOR = 3.5070D-01	NET AIR = 1.2204D+02					
TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) = 1.220380D+02	WATER MASS (LBM)	ATMOSPHERE IS 0 WATER VAPOR(LBM) = 8.507026D-01							

TIME = 4.00000E-01 HR = 2.40000E+01 MIN = 1.44000E+03 SEC

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
0 VAPOR -9.644545D+02 -2.675033D-02 -3.697665D+02 3 VAPOR -3.457223D+03 -9.603319D-02 -7.746017D+02  
LEFT FILM COEF .H = 2.00000E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.196000E+01 F  
RIGHT FILM COEF .H = 4.724037E-01 BTU/HR.FT2.F LAST MESH K = 6.70000E-02 BTU/HR.FT. BULK TEMP = 9.055316D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.532050D+01 8.502459D+01 8.473420D+01 8.444340D+01 8.415451D+01 8.386470D+01 8.357493D+01 8.328608D+01 8.301105D+01  
8.207383D+01 8.114048D+01 8.021467D+01 7.930011D+01 8.047693D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
3 VAPOR -1.143218D+04 -3.175590D-01 -2.987627D+03 OL LIQUID -4.298599D+03 -1.194055D-01 -1.719440D+03  
LEFT FILM COEF .H = 4.782621E-01 BTU/HR.FT2.F FIRST MESH K = 3.50000E-02 BTU/HR.FT. BULK TEMP = 9.055316E+01 F  
RIGHT FILM COEF .H = 1.00000E+04 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.000000D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.316411D+01 7.949622D+01 7.961030D+01 8.066699D+01 8.173263D+01 8.281131D+01 8.390448D+01 8.500824D+01 8.611894D+01  
8.723313D+01 8.769300D+01 8.815434D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
OL LIQUID -9.875518D+03 -2.743200D-01 -3.950300D+03 3 VAPOR -1.132977D+04 -3.147011D-01 -7.590277D+01

LEFT FILM COEF .H = 4.785000E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.038043E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.055316E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.536630D+01 8.489858D+01 8.445506D+01 8.425375D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -4.663484D+03 -1.295378D-01 -7.409150D+02 OLIQUID -2.274819D+03 -6.318938D-02 -8.979973D+02  
 LEFT FILM COEF .H = 4.807933E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 9.055316E+01 F  
 RIGHT FILM COEF .H = 4.341519E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.993165D+01 8.005294D+01 8.061201D+01 8.121989D+01 8.183049D+01 8.244131D+01 8.305200D+01 8.366127D+01 8.426228D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIQUID -2.467078D+03 -6.852989D-02 -9.738924D+02 3 VAPOR -5.057623D+03 -1.404858D-01 -8.035342D+02  
 LEFT FILM COEF .H = 4.341519E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.807933E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.055316E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.426228D+01 8.366127D+01 8.305200D+01 8.244131D+01 8.183049D+01 8.121989D+01 8.061301D+01 8.005294D+01 7.993165D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -3.995029D+03 -1.109722D-01 -9.225075D+02 OLIQUID -6.994854D+02 -1.943012D-02 -2.716859D+02  
 LEFT FILM COEF .H = 4.793695E-01 BTU/HR FT2 F FIRST MESH K = 6.700000E-02 BTU/HR FT BULK TEMP = 9.055316E+01 F  
 RIGHT FILM COEF .H = 3.601834E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.998631D+01 7.857827D+01 7.915799D+01 7.974898D+01 8.034753D+01 8.094996D+01 8.115419D+01 8.137188D+01 8.159046D+01  
 8.180908D+01 8.202771D+01 8.224634D+01 8.246493D+01 8.268320D+01 8.372205D+01 8.476088D+01 8.579965D+01 8.683835D+01  
 8.753456D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
0	0.	-5.716652D-01	0.	-8.183082D+03
1	0.	0.	0.	0.
2	0.	0.	0.	0.
3	0.	-1.109289D+00	0.	-6.153283D+03
4	0.	0.	0.	0.

COMP NO.	PRESSURE (PSIA)		TEMPERATURE (F)			ENERGY (BTU)		CONVERGENCE DE/E
	TOTAL	STEAM	ATMOS	POOL	ATMOS	POOL	TOTAL	
1	1.47000D+01	0.	7.34000D+01	7.34000D+01	0.	0.	0.	0.
3	1.47002D+01	1.63036D-01	9.05545D+01	9.05545D+01	3.90880D+05	0.	3.90880D+05	2.42452D-06

COMP	AIR MASS (LBM)	WATER MASS (LBM)			HUMIDITY	CONDENSATION (LB/S)	TRAK. MASS (LB MOL/S FT2)	EFFICIENTS HEAT (BTU/S FT2 R)
		VAPOR	ATMOS	LIQUID				
1	0.	0.	0.	0.	0.	0.	0.	0.
3	3.85769D+03	2.68912D+01	0.	0.	2.68912D+01	2.29255D-01	0.	0.

COMP. 3 LEAKAGE OUTFLOW MASS = 1.2238D+02 LBM/HR ENERGY BTU/HR = 1.6939D+04 (NORMAL = 1.6939D+04 PENETRATION = 0.)  
 STEP AND NET MASS LOSSES LBM STEP VAPOR = 2.3534D-05 STEP AIR = 3.3760D-03 NET VAPOR = 8.6531D-01 NET AIR = 1.2413D+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) = 1.241331D+02 WATER VAPOR(LBM) = 8.653070D-01

\*\*\*\*\* TIME = 4.16667E-01 HR = 2.50000E+01 MIN = 1.50000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -9.677683D+02 -2.688238D-02 -3.858683D+02 3 VAPOR -3.487856D+03 -9.688426D-02 -8.324875D+02

PCC

CONTEMP-1T/028.30 APRIL 1978, EG&G IDAHO INC. CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM  
COOL-2R NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS 89/12/14

LEFT FILM COEF. H = 2.00000E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.198333E+01 F  
RIGHT FILM COEF. H = 4.733116E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.083258D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.532102D+01 8.502466D+01 8.473420D+01 8.444434D+01 8.415451D+01 8.386470D+01 8.357494D+01 8.328627D+01 8.301313D+01  
8.211301D+01 8.121684D+01 8.032836D+01 7.945134D+01 8.068657D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -1.149016D+04 -3.191698D-01 -3.178664D+03 OL1001D -4.298559D+03 -1.194055D-01 -1.791083D+03  
LEFT FILM COEF. H = 4.781420E-01 BTU/HR.FT2.F FIRST MESH K = 3.50000E-02 BTU/HR.FT. BULK TEMP = 9.083258E+01 F  
RIGHT FILM COEF. H = 1.00000E+04 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.340419D+01 7.959535D+01 7.967321D+01 8.071939D+01 8.177491D+01 8.284407D+01 8.392845D+01 8.502399D+01 8.612686D+01  
8.723342D+01 8.769301D+01 8.815434D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
OL1001D -9.875402D+03 -2.743167D-01 -4.114891D+03 3 VAPOR -1.194247D+04 -3.317245D-01 -1.180836D+02  
LEFT FILM COEF. H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
RIGHT FILM COEF. H = 4.090445E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.083258D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.536636D+01 8.489899D+01 8.445906D+01 8.427757D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -4.805997D+03 -1.334967D-01 -8.198409D+02 OL1001D -2.277174D+03 -6.325477D-02 -9.359306D+02  
LEFT FILM COEF. H = 4.842924E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.083258E+01 F  
RIGHT FILM COEF. H = 4.345868E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
7.996558D+01 8.005863D+01 8.061363D+01 8.121994D+01 8.183049D+01 8.244131D+01 8.305198D+01 8.366117D+01 8.426209D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
OL1001D -2.469631D+05 -6.860081D-02 -1.015032D+03 3 VAPOR -5.212180D+03 -1.447793D-01 -8.891306D+02  
LEFT FILM COEF. H = 4.345868E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
RIGHT FILM COEF. H = 4.842924E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.083258D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.426209D+01 8.366117D+01 8.305198D+01 8.244131D+01 8.183049D+01 8.121994D+01 8.061363D+01 8.005863D+01 7.996558D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -4.028235D+03 -1.118947D-01 -9.893791D+02 OL1001D -7.008571D+02 -1.946803D-02 -2.83353D+02  
LEFT FILM COEF. H = 4.808265E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.083258E+01 F  
RIGHT FILM COEF. H = 3.608216E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.019689D+01 7.872986D+01 7.927194D+01 7.982550D+01 8.038678D+01 8.095202D+01 8.115137D+01 8.137190D+01 8.159046D+01  
8.180909D+01 8.202771D+01 8.223634D+01 8.246493D+01 8.268316D+01 8.283160D+01 8.302177D+01 8.321770D+01 8.347636D+01 8.379889D+01 8.416373D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
0 0 0 0  
1 0 0 0  
2 0 0 0  
3 0 -1.137846D+00 0 -6.827585D+03  
4 0 0 0

CONTEMP-1-T/028.30 APRIL 1978, EG&G IDAHO INC. CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM  
COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS 89/12/14

COMP NO.	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	A T M O S	E N E R G Y	(BTU) TOTAL	CONVERGENCE DE/E
1	1.47000D+01	7.34000D+01	0	0	0	0
3	1.47002D+01	9.08339D+01	3.90868D+05	0	3.90868D+05	2.45572D-06

AIR MASS (LBM)      W A T E R M A S S (LBM)      H U M I D I T Y (LB/S)      C O N D E N S A T I O N (LB/S)      M A S S H E A T T R A N S F E R C O E F F I C I E N T S (BTU/S FT<sup>2</sup>(BTU/S FT<sup>2</sup> R))  
 0      V A P O R - A T M O S - L I Q U I D P O O L T O T A L      5.00000D-01      0      0  
 3.85573D+03      2.68775D+01      0      2.68775D+01      0  
 3 LEAKAGE OUTFLOW-MASS= 1.1454D+02 LBM/HR      E N E R G Y B T U / H R      1.5861D+04 P E N E T R A T I O N - 0  
 STEP AND NET MASS LOSSES LBM STEP VAPOR= 2.2024D+05 STEP AIR= 3.1595D+03 NET VAPOR= 8.7897D-01 NET AIR= 1.2605D+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.260928D+02 WATER VAPOR(LBM)= 8.789674D-01

\* \* \* \* \* T I M E = 4.33333E-01 HR = 2.60000E+01 MIN = 1.56000E+03 SEC \* \* \* \* \*  
 HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL      E N D S T E P B T U / H R      S T E P B T U T O T A L N E T B T U  
 TO LEFT COMP.      E N D S T E P B T U / H R      S T E P B T U T O T A L N E T B T U  
 0 VAPOR      -9.110798D+02      -2.697436D-02      -4.020254D+02      3 VAPOR      -3.511609D+03      -9.754423D-02      -8.908254D+02  
 LEFT FILM COEF. H = 2.00000E-01 BTU/HR FT<sup>2</sup> F      F I R S T M E S H K = 1.050000E+00 BTU/HR FT      B U L K T E M P = 9.200667E+01 F  
 RIGHT FILM COEF. H = 4.739884E-01 BTU/HR FT<sup>2</sup> F      L A S T M E S H K = 6.700000E-02 BTU/HR FT      F      B U L K T E M P = 9.109443D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.532155D+01      8.502473D+01      8.473421D+01      8.444434D+01      8.415451D+01      8.386470D+01      8.357496D+01      8.328648D+01      8.301536D-01  
 8.215295D+01      8.129457D+01      8.044402D+01      7.960509D+01      7.883396D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING      E N D S T E P B T U / H R      S T E P B T U T O T A L N E T B T U  
 TO LEFT COMP.      E N D S T E P B T U / H R      S T E P B T U T O T A L N E T B T U  
 3 VAPOR      -1.153651D+04      -3.204576D-01      -3.370568D+03      O I L I Q U I D      -4.198595D+03      -1.194055D-01      -1.862726D+03  
 LEFT FILM COEF. H = 4.780294E-01 BTU/HR FT<sup>2</sup> F      F I R S T M E S H K = 3.500000E-02 BTU/HR FT      B U L K T E M P = 9.109449E+01 F  
 RIGHT FILM COEF. H = 1.000000E+04 BTU/HR FT<sup>2</sup> F      L A S T M E S H K = 1.050000E+00 BTU/HR FT      F      B U L K T E M P = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.363437D+01      7.969550D+01      7.973857D+01      8.077397D+01      8.181907D+01      8.287840D+01      8.395364D+01      8.504057D+01      8.613521D+01  
 8.723374D+01      8.769302D+01      8.815434D+01      8.861572D+01      8.907710D+01      8.953845D+01      8.999870D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR      E N D S T E P B T U / H R      S T E P B T U T O T A L N E T B T U  
 TO LEFT COMP.      E N D S T E P B T U / H R      S T E P B T U T O T A L N E T B T U  
 O I L I Q U I D      -9.875261D+03      -2.743128D-01      -4.279480D+03      3 VAPOR      -1.251935D+04      -3.477469D-01      -3.219806D+02  
 LEFT FILM COEF. H = 4.785000E-01 BTU/HR FT<sup>2</sup> F      F I R S T M E S H K = 1.050000E+00 BTU/HR FT      B U L K T E M P = 9.000000E+01 F  
 RIGHT FILM COEF. H = 4.137912E-01 BTU/HR FT<sup>2</sup> F      L A S T M E S H K = 1.050000E+00 BTU/HR FT      F      B U L K T E M P = 9.109449D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.536642D+01      8.489945D+01      8.446333D+01      8.430166D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL      E N D S T E P B T U / H R      S T E P B T U T O T A L N E T B T U  
 TO LEFT COMP.      E N D S T E P B T U / H R      S T E P B T U T O T A L N E T B T U  
 3 VAPOR      -4.939092D+03      -1.371940D-01      -9.010526D+02      O I L I Q U I D      -2.279515D+03      -6.331980D-02      -9.739030D+02  
 LEFT FILM COEF. H = 4.874858E-01 BTU/HR FT<sup>2</sup> F      F I R S T M E S H K = 1.050000E+00 BTU/HR FT      B U L K T E M P = 9.109449E+01 F  
 RIGHT FILM COEF. H = 4.350204E-01 BTU/HR FT<sup>2</sup> F      L A S T M E S H K = 1.050000E+00 BTU/HR FT      F      B U L K T E M P = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 7.999969D+01      8.006462D+01      8.061431D+01      8.12.999D+01      8.183049D+01      8.244131D+01      8.305196D+01      8.366106D+01      8.426192D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL      E N D S T E P B T U / H R      S T E P B T U T O T A L N E T B T U  
 TO LEFT COMP.      E N D S T E P B T U / H R      S T E P B T U T O T A L N E T B T U  
 O I L I Q U I D      -2.472170D+03      -6.867130D-02      -1.056213D+03      3 VAPOR      -5.356524D+03      -1.487891D-01      -9.772168D+02  
 LEFT FILM COEF. H = 4.350204E-01 BTU/HR FT<sup>2</sup> F      F I R S T M E S H K = 1.050000E+00 BTU/HR FT      B U L K T E M P = 9.000000E+01 F  
 RIGHT FILM COEF. H = 4.874858E-01 BTU/HR FT<sup>2</sup> F      L A S T M E S H K = 1.050000E+00 BTU/HR FT      F      B U L K T E M P = 9.109449D+01 F

MESH POINT TEMPERATURES (F), LEFT TO RIGHT 8.426192D+01 8.366106D+01 8.305196D+01 8.244131D+01 8.183049D+01 8.121999D+01 8.061431D+01 8.006462D+01 7.999968D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 3 VAPOR -4.053888D+03 -1.126075D+01 -1.056740D+03 OL LIQUID -7.021890D+02 -1.950522D+02 -2.950474D+02  
 LEFT FILM COEF .H = 4.814611E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.107449E+01 F  
 RIGHT FILM COEF .H = 3.614556E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.040518D+01 7.888401D+01 7.938788D+01 7.990347D+01 8.042681D+01 8.095422D+01 8.115457D+01 8.137191D+01 8.159016D+01  
 8.180909D+01 8.202771D+01 8.224634D+01 8.246492D+01 8.268313D+01 8.372151D+01 8.475987D+01 8.579817D+01 8.683644D+01  
 8.753374D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0 0 -5.721890D+01 0  
 1 0 0 0 0  
 2 0 0 -1.164339D+00 0  
 3 0 0 -1.164339D+00 0

COMP NO	PRESSURE (PSIA)	TEMPERATURE (F)	WATER MASS (LBM)	ATMOS. POOL	ENERGY BTU/HR	ATMOS. POOL	CONDENSATION (LB/S)	HUMIDITY (LB/S)	CONVEGENCE DE/E
1	0	0	0	0	0	0	0	0	0
3	853890+03	2.68647D+01	0	2.68647D+01	0	2.25403D+01	0	0	0
3	LEAKAGE OUTFLOW- MASS = 1.0731D+02 LBM/HR	ENERGY BTU/HR = 1.4867D+04	(NORMAL = 1.4867D+04 PENETRATION = 0)						
COMP	3	LEAKAGE OUTFLOW- MASS = 1.0731D+02 LBM/HR	ENERGY BTU/HR = 1.4867D+04	(NORMAL = 1.4867D+04 PENETRATION = 0)					
STEP AND NET MASS LOSSES LBM	STEP VAPOR = 2.0636D+05	STEP AIR = 2.9603D+03	NET VAPOR = 8.9176D+01	NET AIR = 1.2793D+02					
TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) = 1.279278D+02	WATER MASS (LBM)	ATMOS. POOL	ENERGY BTU/HR	ATMOS. POOL	CONDENSATION (LB/S)	HUMIDITY (LB/S)	CONVEGENCE DE/E	TRANSFER COEFFICIENTS MASS HEAT	
1	0	0	0	0	0	0	0	0	0
3	1.47000D+01	7.34000D+01	7.34000D+01	0	0	0	0	0	0
3	1.47002D+01	1.63037D+01	9.10958D+01	9.10958D+01	3.90857D+05	3.90857D+05	3.90857D+05	3.90857D+05	2.48391D+06

\*\*\*\*\* TIME = 4.50000E-01 HR = 2.70000E+01 MIN = 1.62000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 0 VAPOR -9.743891D+02 -2.706629D+02 -4.182376D+02 3 VAPOR -3.529170D+03 -9.803215D+02 -9.495067D+02  
 LEFT FILM COEF .H = 2.000000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.203000E+01 F  
 RIGHT FILM COEF .H = 4.744602E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.134025D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.532210D+01 8.502482D+01 8.473422D+01 8.444344D+01 8.415451D+01 8.386470D+01 8.357497D+01 8.328671D+01 8.301773D+01  
 8.219256D+01 8.137347D+01 8.056132D+01 7.976094D+01 8.109891D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 3 VAPOR -1.157268D+04 -3.214627D+01 -3.563157D+03 OL LIQUID -4.298599D+03 -1.194053D+01 -1.934370D+03  
 LEFT FILM COEF .H = 4.779237E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT.F BULK TEMP = 9.134025E+01 F  
 RIGHT FILM COEF .H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.38509D+01 7.979650D+01 7.990624D+01 8.083051D+01 8.186503D+01 8.291422D+01 8.397999D+01 8.505796D+01 8.614399D+01  
 8.723409D+01 8.768303D+01 8.815434D+01 8.861512D+01 8.907710D+01 8.953849D+01 8.999587D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 OL LIQUID -9.875051D+03 -2.743281D+01 -4.444067D+03 3 VAPOR -1.306230D+04 -3.628295D+01 -5.352068D+02



LEFT FILM COEF .H = 4.78500E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 9.00000E+01 F  
RIGHT FILM COEF .H = 4.181059E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 9.134025D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.536650D+01 8.489998D+01 8.446784D+01 8.432597D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -5.063402D+03 -1.406473D-01 -9.842285D+02 -2.281842D+03 -6.338446D-02 -1.011914D+03  
LEFT FILM COEF .H = 4.904064E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 9.134025E+01 F  
RIGHT FILM COEF .H = 4.354528E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 9.000000D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.003395D+01 8.007089D+01 8.061505D+01 8.122006D+01 8.244131D+01 8.305194D+01 8.366096D+01 8.4261176D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -2.474469D+03 -6.874146D-02 -1.097437D+03 -5.491341D+03 -1.525342D-01 -1.067628D+03  
LEFT FILM COEF .H = 4.354528E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT BULK TEMP = 9.00000E+01 F  
RIGHT FILM COEF .H = 4.904064E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT F BULK TEMP = 9.134025D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.426176D+01 8.366096D+01 8.305194D+01 8.244131D+01 8.122006D+01 8.061505D+01 8.007089D+01 8.003395D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -4.072746D+03 -1.131315D-01 -1.124471D+03 -7.035028D+02 -1.954171D-02 -3.067615D+02  
LEFT FILM COEF .H = 4.818985E-01 BTU/HR FT2 F FIRST MESH K = 6.70000E-02 BTU/HR FT BULK TEMP = 9.134025E+01 F  
RIGHT FILM COEF .H = 3.620858E-01 BTU/HR FT2 F LAST MESH K = 6.70000E-02 BTU/HR FT F BULK TEMP = 9.000000D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.061096D+01 7.904029D+01 7.950550D+01 7.998252D+01 8.046750D+01 8.095658D+01 8.115480D+01 8.137193D+01 8.159046D+01  
8.180909D+01 8.202771D+01 8.224634D+01 8.246492D+01 8.268310D+01 8.372126D+01 8.475840D+01 8.579750D+01 8.683553D+01  
8.753343D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
0 0 -5.724475D-01 0 -9.212787D+03  
1 0 0 0  
2 0 0 0  
3 0 -1.188637D+00 0 -8.224399D+03  
4 0 0 0

COMP NO.	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	A T M O S	E N E R G Y	C O N D E N S A T I O N	H U M I D I T Y	C O N V E R G E N C E
	TOTAL	STEAM	ATMOS	POOL	(LB/S)	(LB/S)	DE/E
1	1.47000D+01	0	7.34000D+01	0	0	0	0
3	1.47002D+01	1.63037D-01	9.13416D+01	3.90847D+05	3.90847D+05	0	2.50936D-06
AIR MASS (LBM)							
1	0	0	0	0	0	0	0
3	3.85217D+03	2.68527D+01	0	0	6.00000D-01	0	0
COMP. 3 LEAKAGE OUTFLOW - MASS = 1.0067D+02 LBM/HR ENERGY BTU/HR = 1.3953D+04 (NORMAL = 1.3953D+04 PENETRATION = 0)							
STEP AND NET MASS LOSSES LBM STEP VAPOR = 1.9356D-05 STEP AIR = 2.7770D-03 NET VAPOR = 9.0375D-01 NET AIR = 1.2965D+02							
TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) = 1.296481D+02 WATER VAPOR(LBM) = 9.037512D-01							

\*\*\*\*\* TIME = 4.666667E-01 HR = 2.80000E+01 MIN = 1.68000E+03 SEC \*\*\*\*\*  
HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
0 VAPOR -9.776961D+02 -2.715815D-02 -4.345050D+02 -3.541170D+03 -9.836561D-02 -1.008434D+03

LEFT FILM COEF .H = 2.00000E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.205333E+01 F  
 RIGHT FILM COEF .H = 4.747504E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.157114D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 B 532267D+01 B 502490D+01 B 473423D+01 B 444434D+01 B 415454D+01 B 384470D+01 B 357499D+01 B 328697D+01 B 302025D+01  
 B 223473D+01 B 145334D+01 B 067996D+01 B 7.991849D+01 B 130126D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.159997D+04 -3.22207D-01 -3.756274D+03 OLIIQID -4.298599D+03 -1.194055D-01 -2.006013D+03  
 LEFT FILM COEF .H = 4.778244E-01 BTU/HR.FT2.F FIRST MESH K = 3.50000E-02 BTU/HR.FT. BULK TEMP = 9.157114E+01 F  
 RIGHT FILM COEF .H = 1.00000E+04 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 B 406677D+01 B 7.989821D+01 B 7.987607D+01 B 8.089180D+01 B 191268D-01 B 400744D+01 B 507611D+01 B 615317D+01  
 B 723448D+01 B 769305D+01 B 815434D+01 B 861572D+01 B 907710D+01 B 953849D+01 B 999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQID -9.874891D+03 -2.743025D-01 -4.608650D+03 3 VAPOR -1.357323D+04 -3.770228D-01 -7.572127D+02  
 LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF .H = 4.220405E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.157114D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 B 536660D+01 B 490056D+01 B 447261D+01 B 435045D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -5.179538D+03 -1.438735D-01 -1.069797D+03 OLIIQID -2.284158D+03 -6.344877D-02 -1.049964D+03  
 LEFT FILM COEF .H = 4.930829E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.157114E+01 F  
 RIGHT FILM COEF .H = 4.358839E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 B 006830D+01 B 007744D+01 B 061585D+01 B 122013D+01 B 183050D+01 B 244130D+01 B 305192D+01 B 366086D+01 B 426162D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQID -2.477205D+03 -6.881120D-02 -1.138703D+03 3 VAPOR -5.617292D+03 -1.560331D-01 -1.160242D+03  
 LEFT FILM COEF .H = 4.358839E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF .H = 4.930829E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.157114D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 B 26162D+01 B 366086D+01 B 305192D+01 B 244130D+01 B 183050D+01 B 122013D+01 B 305192D+01 B 061585D+01 B 007744D+01 B 006830D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -4.085507D+03 -1.134861D-01 -1.192464D+03 OLIIQID -7.047923D+02 -1.957753D-02 -3.184973D+02  
 LEFT FILM COEF .H = 4.821611E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.157114E+01 F  
 RIGHT FILM COEF .H = 3.627120E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 B 081410D+01 B 7.919830D+01 B 7.962448D+01 B 006261D+01 B 050877D+01 B 095908D+01 B 115505D+01 B 137195D+01 B 159046D+01  
 B 180909D+01 B 202771D+01 B 224634D+01 B 246491D+01 B 268306D+01 B 372103D+01 B 475897D+01 B 579687D+01 B 683471D+01  
 B 753317D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 3 0 0 -5.727037D-01 0  
 1 0 0 0  
 2 0 0 0  
 3 0 -1.211002D+00 0  
 4 0 0 -8.944395D+03



MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 4261500+01 8 3660750+01 8 3051900+01 8 2441300+01 8 1830510+01 8 1220210+01 8 0616720+01 8 00844270+01 8 0102680+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -4.092811D+03 -1.136891D-01 -1.260624D+03 OLIGUID -7.060582D+02 -1.961270D-02 -3.302545D+02  
 LEFT FILM COEF .H = 4.822686E-01 BTU/HR FT2 F FIRST MESH K = 6.700000E-02 BTU/HR FT BULK TEMP = 9.178834E+01 F  
 RIGHT FILM COEF .H = 3.633345E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT

8 1014460+01 7.935767D+01 7.974456D+01 8 0143480+01 8 055051D+01 8 096173D+01 8 115533D+01 8 1371970+01 8 1590470+01  
 8 1809050+01 8 202771D+01 8 224634D+01 8 246491D+01 8 268303D+01 8 372081D+01 8 475856D+01 8 579628D+01 8 683394D+01  
 8 753298D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP.	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
0	0	0	-5.729575D-01	0
1	0	0	0	0
2	0	0	0	0
3	0	-1.231585D+00	0	-9.677266D+03
4	0	0	0	0

COMP NO	PRESSURE (PSIA)	TEMPERATURE (F)	ATMOS	POOL	ENERGY (BTU)	CONVERGENCE DE/E
1	1.47000D+01	0	7.34000D+01	7.34000D+01	0	0
3	1.47002D+01	1.63037D-01	9.17897D+01	9.17897D+01	3.90828D+05	0

AIR MASS (LBM)	WATER	LIQUID	MASS	POOL	HUMIDITY (LB/S)	CONDENSATION (LB/S)	TRANSFER MASS (LB MOL/S FT2)	COEFFICIENTS HEAT (BTU/S FT2 R)
0	0	0	0	0	6.00000D-01	0	0	0
3	8.84904D+03	2.68309D+01	0	2.68309D+01	2.20572D-01	0	0	0

COMP. 3 LEAKAGE OUTFLOW MASS = 8.85390D+01 LBM/HR ENERGY BTU/HR = 1.2337D+04 (NORMAL = 1.2337D+04 PENETRATION = 0)  
 STEP AND NET MASS LOSSES LBM STEP VAPOR = 1.7102D-05 STEP AIR = 2.4534D-03 NET VAPOR = 9.2559D-01 NET AIR = 1.3278D+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) = 1.327808D+02 WATER VAPOR(LBM) = 9.255888D-01

\*\*\*\*\* TIME = 5.000000E-01 HR = 3.000000E+01 MIN = 1.800000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -9.843035D+02 -2.734169D-02 -4.672050D+02 3 VAPOR -3.550762D+03 -9.863227D-02 -1.126682D+03  
 LEFT FILM COEF .H = 2.000000E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 9.210000E+01 F  
 RIGHT FILM COEF .H = 4.748650E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 9.199292D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 532385D+01 8 502509D+01 8 473425D+01 8 444344D+01 8 415451D+01 8 386470D+01 8 357504D+01 8 328756D+01 8 302573D+01  
 8 231837D+01 8 161523D+01 8 092022D+01 8 023278D+01 8 169770D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.163217D+04 -3.231157D-01 -4.133552D+03 OLIGUID -4.298599D+03 -1.194055D-01 -2.149300D+03  
 LEFT FILM COEF .H = 4.776430E-01 BTU/HR FT2 F FIRST MESH K = 3.500000E-02 BTU/HR FT BULK TEMP = 9.199292E+01 F  
 RIGHT FILM COEF .H = 1.000000E+04 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 446486D+01 8 010318D+01 8 002162D+01 8 101165D+01 8 201264D+01 8 302985D+01 8 406540D+01 8 511452D+01 8 617265D+01  
 8 723537D+01 8 769309D+01 8 815434D+01 8 861572D+01 8 907710D+01 8 953849D+01 8 999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIGUID -9.874385D+03 -2.742885D-01 -4.937805D+03 3 VAPOR -1.450678D+04 -8.029580D-01 -1.225526D+03

LEFT FILM COEF .H = 4.78500E-01BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT. BULK TEMP = 9.00000E+01 F  
RIGHT FILM COEF .H = 4.289403E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT. F BULK TEMP = 9.199292D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
B 536683D+01 B 490190D+01 B 418288D+01 B 439573D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
3 VAPOR -5.389576D+03 -1.497062D-01 -1.246027D+03 OL LIQUID -2.288751D+03 -6.357635D-02 -1.126180D+03  
LEFT FILM COEF .H = 4.978013E-01BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT. BULK TEMP = 9.199292E+01 F  
RIGHT FILM COEF .H = 4.367427E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT. F BULK TEMP = 9.00000D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
B 013707D+01 B 009136D+01 B 061765D+01 B 122030D+01 B 183957D+01 B 244130D+01 B 305188D+01 B 366065D+01 B 426139D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
OL LIQUID -2.482187D+03 -6.894957D-02 -1.221360D+03 3 VAPOR -5.845082D+03 -1.623609D-01 -1.351337D+03  
LEFT FILM COEF .H = 4.367427E-01BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT. BULK TEMP = 9.00000E+01 F  
RIGHT FILM COEF .H = 4.978013E-01 BTU/HR FT2 F LAST MESH K = 1.05000E+00 BTU/HR FT. F BULK TEMP = 9.199292D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
B 426139D+01 B 366065D+01 B 305188D+01 B 244130D+01 B 183957D+01 B 122030D+01 B 061765D+01 B 009136D+01 B 013707D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
3 VAPOR -4.095244D+03 -1.137560D-01 -1.328864D+03 OL LIQUID -7.073031D+02 -1.964722D-02 -3.420325D+02  
LEFT FILM COEF .H = 4.822383E-01BTU/HR FT2 F FIRST MESH K = 6.70000E-02 BTU/HR FT. BULK TEMP = 9.199292E+01 F  
RIGHT FILM COEF .H = 3.639533E-01 BTU/HR FT2 F LAST MESH K = 6.70000E-02 BTU/HR FT. F BULK TEMP = 9.00000D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
B 121196D+01 7.951805D+01 7.986546D+01 B 022496D+01 B 059263D+01 B 096452D+01 B 115563D+01 B 137199D+01 B 159047D+01  
B 180909D+01 B 202771D+01 B 224634D+01 B 246490D+01 B 268300D+01 B 372060D+01 B 475819D+01 B 579574D+01 B 683323D+01  
B 753284D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
0	0	-5.752088D-01	0	-1.024388D+04
1	0	0	0	0
2	0	0	0	0
3	0	-1.250530D+00	0	-1.042199D+04
4	0	0	0	0

COMP NO	PRESSURE (PSIA)	TEMPERATURE (F)	ATMOS	POOL	ENERGY	REG	Y	ATMOS	POOL	CONCENTRATION (LB/S)	HUMIDITY	CONDENSATION (LB/S)	CONCENTRATION (LB MOL/S FT2)	HEAT TRANSFER COEFFICIENTS
1	1.47000D+01	0	7.34000D+01	7.34000D+01	0	0	0	0	0	0	0	0	0	0
3	1.47002D+01	1.63038D-01	9.19983D+01	9.19983D+01	5.19943D+01	3.90819D+05	0	0	0	0	0	0	0	0
1	0	0	0	0	0	0	0	0	0	0	0	0	0	0
3	8.4731D+03	2.68209D+01	0	0	2.68209D+01	2.19169D-01	0	0	0	0	0	0	0	0

COMP 3 LEAKAGE OUTFLOW MASS= 8.3769D+01 LBM/HR ENERGY BTU/HR = 1.1624D+04 (NORMAL) 1.1624D+04 PENETRATION= 0  
STEP AND NET MASS LOSSES LBM STEP VAPOR= 1.6108D-05 STEP AIR= 2.3108D-03 NET VAPOR= 9.3555D-01 NET AIR= 1.3421D+02  
TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.342095D+02 WATER VAPOR(LBM)= 9.355473D-01

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
0 VAPOR -9.876040D+02 -2.743337D-02 -4.836376D+02 TO RIGHT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU  
0 VAPOR -3.549371D+03 -9.859372D-02 -1.185855D+03

\*\*\*\*\* TIME = 5.166667E-01 HR = 3.100000E+01 MIN = 1.860000E+03 SEC \*\*\*\*\*

LEFT FILM COEF .H = 2.00000E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT BULK TEMP = 9.212333E+01 F  
 RIGHT FILM COEF .H = 4.747237E-01 BTU/HR.FT2.F LAST MESH K = 6.70000E-02 BTU/HR.FT.F BULK TEMP = 9.218588E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 532446E+01 8 502520E+01 8 473426E+01 8 444434E+01 8 415453E+01 8 386471E+01 8 357507E+01 8 328790E+01 8 302868E+01  
 8 236068E+01 8 169692E+01 8 104133E+01 8 039786E+01 8 189164E+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.163892E+04 -3.233032E-01 -4.337486E+03 OLIGUID -4.298599E+03 -1.194055E-01 -2.220943E+03  
 LEFT FILM COEF .H = 4.775601E-01 BTU/HR.FT2.F FIRST MESH K = 3.50000E-02 BTU/HR.FT BULK TEMP = 9.218588E+01 F  
 RIGHT FILM COEF .H = 1.00000E+04 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 461214E+01 8 020624E+01 8 009707E+01 8 107530E+01 8 206475E+01 8 307085E+01 8 409579E+01 8 513471E+01 8 618292E+01  
 8 721587E+01 8 769311E+01 8 815435E+01 8 861572E+01 8 907710E+01 8 953849E+01 8 999987E+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIGUID -9.874073E+03 -2.742798E-01 -5.102375E+03 3 VAPOR -1.493312E+04 -4.147994E-01 -1.470894E+03  
 LEFT FILM COEF .H = 4.988852E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.319762E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.218588E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 536698E+01 8 490267E+01 8 448837E+01 8 442447E+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -5.483547E+03 -1.523464E-01 -1.336654E+03 OLIGUID -2.291029E+03 -6.363964E-02 -1.164344E+03  
 LEFT FILM COEF .H = 4.988852E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT BULK TEMP = 9.218588E+01 F  
 RIGHT FILM COEF .H = 4.37103E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 017141E+01 8 009872E+01 8 061865E+01 8 122040E+01 8 183052E+01 8 244130E+01 8 305185E+01 8 366055E+01 8 426129E+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIGUID -2.484657E+03 -6.901824E-02 -1.262750E+03 3 VAPOR -5.948078E+03 -1.652221E-01 -1.449622E+03  
 LEFT FILM COEF .H = 4.37103E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.988852E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.218588E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 426123E+01 8 366055E+01 8 305185E+01 8 244130E+01 8 183052E+01 8 122040E+01 8 061865E+01 8 009872E+01 8 017141E+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -4.093339E+03 -1.137039E-01 -1.397108E+03 OLIGUID -7.085215E+02 -1.968112E-02 -3.538300E+02  
 LEFT FILM COEF .H = 4.820860E-01 BTU/HR.FT2.F FIRST MESH K = 6.70000E-02 BTU/HR.FT BULK TEMP = 9.218588E+01 F  
 RIGHT FILM COEF .H = 3.645685E-01 BTU/HR.FT2.F LAST MESH K = 6.70000E-02 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 140653E+01 7.962913E+01 7.998694E+01 8.030690E+01 8.063505E+01 8.096746E+01 8.115597E+01 8.137202E+01 8.159047E+01  
 8 180909E+01 8.202771E+01 8.224633E+01 8.246490E+01 8.268296E+01 8.272041E+01 8.275784E+01 8.279523E+01 8.283258E+01  
 8 753275E+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0 0 0  
 1 0 0 0  
 2 0 0 0  
 3 0 0 -1.267969E+00 0  
 4 0 0 -1.117762E+00 0

COMP NO.	PRESSURE (PSIA)		TEMPERATURE (F)		ENERGY (BTU)			CONVERGENCE DE/E
	TOTAL	STEAM	ATMOS	POOL	ATMOS	POOL	TOTAL	
1	1.47000D+01	0.	7.34000D+01	7.34000D+01	0.	0.	0.	0.
3	1.47002D+01	1.63038D-01	9.21873D+01	9.21873D+01	3.90811D+05	0.	3.90811D+05	2.58875D-06

COMP NO.	AIR MASS (LBM)	WATER MASS (LBM)		TOTAL	HUMIDITY (LB/S)	CONDENSATION (LB/S)	TRANSFER COEFFICIENTS	
		VAPOR--	ATMOS--				LIQUID	MASS (LB MOL/S FT2)
1	0.	0.	0.	0.	6.00000D-01	0.	0.	0.
3	3.84626D+03	2.68116D+01	0.	2.68116D+01	2.17856D-01	0.	0.	0.

COMP 3 LEAKAGE OUTFLOW- MASS= 7.9013D+01 LBM/HR ENERGY BTU/HR = 1.0967D+04 (NORMAL= 1.0967D+04 PENETRATION= 0.)  
 STEP AND NET MASS LOSSES LBM STEP VAPOR= 1.5194D-05 STEP AIR= 2.1796D-03 NET VAPOR= 9.4493D-01 NET AIR= 1.3556D+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.35556D+02 WATER VAPOR(LBM)= 9.449336D-01

\*\*\*\*\* TIME = 5.33333E-01 HR = 3.20000E+01 MIN = 1.92000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -9.909025D+02 -2.752499D-02 -5.001252D+02 3 VAPOR -3.544459D+03 -9.845734D-02 -1.244975D+03  
 LEFT FILM COEF .H = 2.00000E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.214667E+01 F  
 RIGHT FILM COEF .H = 4.744697E-01 BTU/HR.FT2.F LAST MESH K = 6.70000E-02 BTU/HR.FT.F BULK TEMP = 9.236814D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.532509D+01 8.502530D+01 8.473428D+01 8.444434D+01 8.415452D+01 8.386471D+01 8.357511D+01 8.328827D+01 8.303178D+01  
 8.240322D+01 8.177891D+01 8.116280D+01 8.055883D+01 8.208264D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.164045D+04 -3.233458D-01 -4.531487D+03 0 LIQUID -4.298599D+03 -1.194055D-01 -2.292586D+03  
 LEFT FILM COEF .H = 4.774817E-01 BTU/HR.FT2.F FIRST MESH K = 3.50000E-02 BTU/HR.FT. BULK TEMP = 9.236814E+01 F  
 RIGHT FILM COEF .H = 1.00000E+04 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.483218D+01 8.030946D+01 8.017411D+01 8.114040D+01 8.211815D+01 8.311293D+01 8.412704D+01 8.515550D+01 8.619352D+01  
 8.723641D+01 8.769313D+01 8.815435D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 LIQUID -9.873719D+03 -2.742700D-01 -5.266940D+03 3 VAPOR -1.533491D+04 -4.259606D-01 -1.723160D+03  
 LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.347754E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.236814D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.536715D+01 8.490350D+01 8.449409D+01 8.444922D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -5.573476D+03 -1.548168D-01 -1.428812D+03 0 LIQUID -2.293295D+03 -6.370260D-02 -1.202547D+03  
 LEFT FILM COEF .H = 5.018095E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.236814E+01 F  
 RIGHT FILM COEF .H = 4.375968E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.020560D+01 8.010634D+01 8.061972D+01 8.122052D+01 8.183053D+01 8.244129D+01 8.305183D+01 8.366045D+01 8.426121D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 LIQUID -2.487116D+03 -6.908649D-02 -1.304182D+03 3 VAPOR -6.044524D+03 -1.679013D-01 -1.549570D+03  
 LEFT FILM COEF .H = 4.375968E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.018095E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.236814D+01 F

PCC

CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM  
89/12/14

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.426124D+01 8.366045D+01 8.305183D+01 8.244129D+01 8.183053D+01 8.122052D+01 8.061972D+01 8.010634D+01 8.020568D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -4.087581D+03 -1.135441D+01 -1.465288D+03  
LEFT FILM COEF. H = 4.818253E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.236814E+01 F  
RIGHT FILM COEF. H = 3.651802E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.159813D+01 7.984061D+01 8.010878D+01 8.038913D+01 8.067770D+01 8.097054D+01 8.115633D+01 8.137205D+01 8.159047D+01  
8.180909D+01 8.202771D+01 8.224633D+01 8.246488D+01 8.268293D+01 8.290148D+01 8.312003D+01 8.333858D+01 8.355713D+01  
8.377568D+01 8.399423D+01 8.421278D+01 8.443093D+01 8.464908D+01 8.486723D+01 8.508538D+01 8.530373D+01 8.552208D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP NO.	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
0	0	0	-5.737040D-01	-1.093203D+04
1	0	0	0	0
2	0	0	0	0
3	0	-1.284026D+00	0	-1.194329D+04
4	0	0	0	0

COMP NO.	PRESSURE (PSIA)	TEMPERATURE (F)	ATMOS POOL	ENERGY (BTU)	ATMOS POOL	HUMIDITY (LB/S)	CONDENSATION (LB/S)	TRANSFER COEFFICIENTS (BTU/S FT2 R)	CONVERGENCE DE/E
1	1.47000D+01	7.34000D+01	7.34000D+01	0	0	0	0	0	0
3	1.47000D+01	1.63038D-01	9.23696D+01	9.23696D+01	3.90804D+05	0	3.90804D+05	2.60402D-06	0
1	0	0	0	0	0	6.00000D-01	0	0	0
3	3.84499D+03	2.68027D+01	0	2.68027D+01	0	2.16524D-01	0	0	0
COMP.	3 LEAKAGE DUTIFLOW- MASS=	7.4636D+01 LBM/HR	ENERGY BTU/HR =	1.0363D+04	(NORMAL=	1.0363D+04	PENETRATION=	0	0
STEP AND NET MASS LOSSES	LBM STEP VAPOR=	1.4352D-05	STEP AIR=	2.0589D-03	NET VAPOR=	9.5379D-01	NET AIR=	1.3663D+02	0
TOTAL NET CONTAINMENT LOSS	TO ATMOSPHERE IS	0 AIR(LBM)=	1.368270D+02	WATER VAPOR(LBM)=	9.537934D-01				

\*\*\*\*\* TIME = 5.500000E-01 HR = 3.300000E+01 MIN = 1.980000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
0 VAPOR -5.941988D+02 -2.761656D-02 -5.166677D+02  
LEFT FILM COEF. H = 2.000000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.217000E+01 F  
RIGHT FILM COEF. H = 4.741157E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.254054D+01 F

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.532573D+01 8.502542D+01 8.473428D+01 8.444434D+01 8.415452D+01 8.386471D+01 8.357544D+01 8.328867D+01 8.303501D+01  
8.244590D+01 8.186106D+01 8.128442D+01 8.071993D+01 8.015584D+01 7.959175D+01 7.902766D+01 7.846357D+01 7.789948D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -1.163741D+04 -3.232516D-01 -4.725475D+03  
LEFT FILM COEF. H = 4.774076E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT. BULK TEMP = 9.254054E+01 F  
RIGHT FILM COEF. H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.500538D+01 8.041285D+01 8.025253D+01 8.025253D+01 8.120683D+01 8.212740D+01 8.315603D+01 8.415909D+01 8.517685D+01 8.620442D+01  
8.723700D+01 8.769316D+01 8.815435D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
OLIQUID -9.873319D+03 -2.742589D-01 -5.431499D+03  
TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
OLIQUID -1.571381D+04 -4.364862D-01 -1.981930D+03



LEFT FILM COEF .H = 4.785000E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.373628E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT.F BULK TEMP = 9.254054D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.536733D+01 8.490440D+01 8.450003D+01 8.447396D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -5.656818D+03 -1.571320D-01 -1.522405D+03 OLIQUID -2.295550D+03 -6.376524D-02 -1.240788D+03  
 LEFT FILM COEF .H = 5.035897E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT. BULK TEMP = 9.254054E+01 F  
 RIGHT FILM COEF .H = 4.380221E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.023985D+01 8.011421D+01 8.062086D+01 8.122064D+01 8.183054D+01 8.244129D+01 8.305181D+01 8.366035D+01 8.426115D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIQUID -2.489561D+03 -6.915442D-02 -1.345654D+03 3 VAPOR -6.134909D+03 -1.704121D-01 -1.651073D+03  
 LEFT FILM COEF .H = 4.380221E-01 BTU/HR FT2.F FIRST MESH K = 1.050000E+00 BTU/HR FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.035897E-01 BTU/HR FT2.F LAST MESH K = 1.050000E+00 BTU/HR FT.F BULK TEMP = 9.254054D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.426115D+01 8.366035D+01 8.305181D+01 8.244129D+01 8.183054D+01 8.122064D+01 8.062086D+01 8.011421D+01 8.023985D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -4.078413D+03 -1.132895D-01 -1.533342D+03 OLIQUID -7.108972D+02 -1.974712D-02 -3.774882D+02  
 LEFT FILM COEF .H = 4.814685E-01 BTU/HR FT2.F FIRST MESH K = 6.700000E-02 BTU/HR FT. BULK TEMP = 9.254054E+01 F  
 RIGHT FILM COEF .H = 3.657884E-01 BTU/HR FT2.F LAST MESH K = 6.700000E-02 BTU/HR FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.178673D+01 8.000221D+01 8.023077D+01 8.047152D+01 8.072050D+01 8.097376D+01 8.115673D+01 8.137209D+01 8.159047D+01  
 8.180909D+01 8.202771D+01 8.224633D+01 8.246488D+01 8.268289D+01 8.372007D+01 8.475722D+01 8.579435D+01 8.683144D+01  
 8.753273D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
0	0.	-5.739477D-01	0.	-1.127633D+04
1	0.	0.	0.	0.
2	0.	0.	0.	0.
3	0.	-1.298816D+00	0.	-1.271821D+04
4	0.	0.	0.	0.

COMP NO.	P R E S S U R E (PSIA)			T E M P E R A T U R E (F)			E N E R G Y (BTU)			CONVERGENCE DE/E
	TOTAL	STEAM		ATMOS	POOL		ATMOS	POOL	TOTAL	
1	1.47000D+01	0.		7.34000D+01	7.34000D+01		0.	0.	0.	0.
3	1.47001D+01	1.63038D-01		9.25420D+01	9.25420D+01		3.90796D+05	0.	3.90796D+05	2.61781D-06

COMP	AIR MASS (LBM)	W A T E R M A S S (LBM)		TOTAL	HUMIDITY	CONDENSATION (LB/S)	TRANSFER COEFFICIENTS	
		VAPOR--ATMOS	--LIQUID				MASS	HEAT
1	0.	0.	0.	0.	6.00000D-01	0.	0.	0.
3	3.84379D+03	2.67943D+01	0.	2.67943D+01	2.15465D-01	0.	0.	0.

COMP. 3 LEAKAGE OUTFLOW- MASS= 7.0606D+01 LBM/HR ENERGY BTU/HR = 9.8064D+03 (NORMAL= 9.8064D+03 PENETRATION= 0.)  
 STEP AND NET MASS LOSSES LBM STEP VAPOR= 1.3577D-05 STEP AIR= 1.9477D-03 NET VAPOR= 9.6217D-01 NET AIR= 1.3803D+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.380284D+02 WATER VAPOR(LBM)= 9.621685D-01

\*\*\*\*\* TIME = 5.666667E-01 HR = 3.400000E+01 MIN = 2.040000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -9.974932D+02 -2.770807D-02 -5.332651D+02 3 VAPOR -3.525638D+03 -9.793468D-02 -1.362840D+03

PCC

89/12/14.

LEFT FILM COEF .H = 2.000000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.219333E+01 F  
 RIGHT FILM COEF .H = 4.736731E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.270386E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.532638D+01 8.502554D+01 8.473431E+01 8.444435D+01 8.415452D+01 8.386471D+01 8.357518D+01 8.328910D+01 8.303838D+01  
 8.248867D+01 8.194324D+01 8.140601D+01 8.088091D+01 8.245577D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.163037D+04 -3.230660D-01 -4.919379D+03 OLIIQUID -4.298599D+03 -1.194055D-01 -2.435873D+03  
 LEFT FILM COEF .H = 4.773373E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT. BULK TEMP = 9.270386E+01 F  
 RIGHT FILM COEF .H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.517215D+01 8.051630D+01 8.033248D+01 8.127450D+01 8.222843D+01 8.320007D+01 8.419188D+01 8.519873D+01 8.621561D+01  
 8.723763E+01 8.769319D+01 8.815435D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQUID -9.872870D+03 -2.742464D-01 -5.596051D+03 3 VAPOR -1.607144D+04 -4.464207D-01 -2.222222D+03  
 LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.397600E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.270386D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.536754D+01 8.490537D+01 8.450619D+01 8.449867D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -5.734994D+03 -1.593036D-01 -1.617344D+03 OLIIQUID -2.297794D+03 -6.382756D-02 -1.279065D+03  
 LEFT FILM COEF .H = 5.052395E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.270386E+01 F  
 RIGHT FILM COEF .H = 4.384463E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.027390D+01 8.012232D+01 8.062207D+01 8.122077D+01 8.183055D+01 8.244129D+01 8.305178D+01 8.366025D+01 8.426110D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQUID -2.491994D+03 -6.922201D-02 -1.387167D+03 3 VAPOR -6.219693D+03 -1.727674D-01 -1.754035D+03  
 LEFT FILM COEF .H = 4.384463E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.052395E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.270386D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.426110D+01 8.366025D+01 8.305178D+01 8.244129D+01 8.183055D+01 8.122077D+01 8.062207D+01 8.012232D+01 8.027390D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -4.066233D+03 -1.129512D-01 -1.601218D+03 OLIIQUID -7.120534D+02 -1.977924D-02 -3.893462D+02  
 LEFT FILM COEF .H = 4.810268E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.270386E+01 F  
 RIGHT FILM COEF .H = 3.663932E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.197232D+01 8.016369D+01 8.035273D+01 8.055395D+01 8.076339D+01 8.097711D+01 8.115715D+01 8.137213D+01 8.159048D+01  
 8.180909D+01 8.202771D+01 8.224633D+01 8.246488D+01 8.268286D+01 8.371991D+01 8.475696D+01 8.579397D+01 8.683095D+01  
 8.753280D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP.	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
0	0.	-5.741888D-01	0.	-1.162077D+04
1	0.	0.	0.	0.
2	0.	0.	0.	0.
3	0.	-1.312444D+00	0.	-1.350165D+04
4	0.	0.	0.	0.

COMP NO.	P R E S S U R E (PSIA)		T E M P E R A T U R E (F)			E N E R G Y (BTU)			CONVERGENCE DE/E
	TOTAL	STEAM	ATMOS	POOL	ATMOS	POOL	TOTAL		
1	1.47000D+01	0.	7.34000D+01	7.34000D+01	0.	0.	0.	0.	
3	1.47001D+01	1.63038D-01	9.27053D+01	9.27053D+01	3.90789D+05	0.	3.90789D+05	2.63028D-06	

COMP NO.	AIR MASS (LBM)	W A T E R M A S S (LBM)		HUMIDITY (LB/S)	CONDENSATION (LB/S)	TRANSFER COEFFICIENTS MASS HEAT (BTU/S FT2 R)
	VAPOR--ATMOS--LIQUID	POOL	TOTAL			
1	0.	0.	0.	0.	0.	0.
3	3.84265D+03	2.67864D+01	0.	2.67864D+01	2.14375D-01	0.

COMP. 3 LEAKAGE OUTFLOW MASS= 6.6894D+01 LBM/HR ENERGY BTU/HR = 9.2935D+03 (NORMAL= 9.2935D+03 PENETRATION= 0.)  
 STEP AND NET MASS LOSSES LBM STEP VAPOR= 1.2863D-05 STEP AIR= 1.8453D-03 NET VAPOR= 9.7010D-01 NET AIR= 1.3917D+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.391659D+02 WATER VAPOR(LBM)= 9.700974D-01

\*\*\*\*\* TIME = 5.83333E-01 HR = 3.50000E+01 MIN = 2.10000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
0 VAPOR	-1.000786D+03	-2.779952D-02	-5.499174D+02	3 VAPOR	-3.512424D+03	-9.756767D-02	-1.421494D+03

LEFT FILM COEF. H = 2.00000E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.221667E+01 F  
 RIGHT FILM COEF. H = 4.731521E-01 BTU/HR.FT2.F LAST MESH K = 6.70000E-02 BTU/HR.FT.F BULK TEMP = 9.285879D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.532705D+01 8.502566D+01 8.473432D+01 8.444435D+01 8.415452D+01 8.386472D+01 8.357523D+01 8.328956D+01 8.304188D+01  
 8.253147D+01 8.202534D+01 8.152740D+01 8.104156D+01 8.263787D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
3 VAPOR	-1.161981D+04	-3.227727D-01	-5.113135D+03	OLIQUID	-4.298599D+03	-1.194055D-01	-2.507516D+03

LEFT FILM COEF. H = 4.772707E-01 BTU/HR.FT2.F FIRST MESH K = 3.50000E-02 BTU/HR.FT. BULK TEMP = 9.285879E+01 F  
 RIGHT FILM COEF. H = 1.00000E+01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.533287D+01 8.061973D+01 8.041356D+01 8.134330D+01 8.228513D+01 8.324497D+01 8.422537D+01 8.522109D+01 8.622707D+01  
 8.723830D+01 8.769323D+01 8.815435D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
OLIQUID	-9.872369D+03	-2.742325D-01	-5.760594D+03	3 VAPOR	-1.640929D+04	-4.558059D-01	-2.517535D+03

LEFT FILM COEF. H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF. H = 4.419861E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.285879D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.536778D+01 8.490642D+01 8.451256D+01 8.452331D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
3 VAPOR	-5.808399D+03	-1.613428D-01	-1.713545D+03	OLIQUID	-2.300026D+03	-6.388957D-02	-1.317381D+03

LEFT FILM COEF. H = 5.067713E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.285879E+01 F  
 RIGHT FILM COEF. H = 4.388694E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.030779D+01 8.613067D+01 8.062336D+01 8.122092D+01 8.183057D+01 8.244128D+01 8.305175D+01 8.366016D+01 8.426106D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
OLIQUID	-2.494415D+03	-6.928926D-02	-1.428720D+03	3 VAPOR	-6.299302D+03	-1.749788D-01	-1.858367D+03

LEFT FILM COEF. H = 4.388694E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF. H = 5.067713E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.285879D+01 F

PCC

MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 B. 426106D+01 8. 366016D+01 8. 305175D+01 8. 244128D+01 8. 183057D+01 8. 122092D+01 8. 062336D+01 8. 013067D+01 8. 030779D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 3 VAPOR -4.05140D+03 -1.12539D-01 -1.668668D+03 OL LIQUID -7.131892D+02 -1.981075D-02 -4.012233D+02  
 LEFT FILM COEF. H = 4.805099E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.285879E+01 F  
 RIGHT FILM COEF. H = 3.669947E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8. 215489D+01 8. 032482D+01 8. 047448D+01 8. 163628D+01 8. 080630D+01 8. 098060D+01 8. 115761D+01 8. 137217D+01 8. 159048D+01  
 8. 180909D+01 8. 202771D+01 8. 224633D+01 8. 246487D+01 8. 268282D+01 8. 371978D+01 8. 475671D+01 8. 579363D+01 8. 683052D+01  
 8. 753291D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0. -5.744272D-01 0. -1.196535D+04  
 1 0. 0. 0. 0.  
 2 0. 0. 0. -1.429294D+04  
 3 0. -1.325007D+00 0. 0.  
 4 0. 0. 0. 0.

COMP NO	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	A T M O S	E N E R G Y P O O L	(BTU) TOTAL	C O N V E R G E N C E D E / E
1	1.4700D+01	7.3400D+01	0.	0.	0.	0.
3	1.4700D+01	9.2860D+01	3.9078D+05	0.	3.9078D+05	2.64154D-06
AIR MASS W A T E R M A S S H U M I D I T Y C O N D E N S A T I O N M A S S T R A N S F E R C O E F F I C I E N T S						
1	0.	0.	0.	6.00000D-01	0.	0.
3	3.84157D+03	2.67789D+01	2.67789D+01	2.13346D-01	0.	0.
3 LEAKAGE OUTFLOW- MASS= 6.3474D+01 LBM/HR ENERGY BTU/HR = 8.827D+03 PENETRATION= 0. )						
STEP AND NET MASS LOSSES LBM STEP VAPOR= 1.2208D-05 STEP AIR= 1.7510D-03 NET VAPOR= 9.7762D-01 NET AIR= 1.4024D+02						
TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.402443D+02 WATER VAPOR(LBM)= 9.776150D-01						

\*\*\*\*\* TIME = 6.000000E-01 HR = 3.600000E+01 MIN = 2.160000E+03 SFC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 0 VAPOR -1.004076D+03 -2.789092D-02 -5.666246D+02 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 LEFT FILM COEF. H = 2.000000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.224000F+01 F  
 RIGHT FILM COEF. H = 4.725618E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.306000D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8. 532773D+01 8. 502579D+01 8. 473434D+01 8. 444435D+01 8. 415452D+01 8. 386472D+01 8. 357528D+01 8. 329006D+01 8. 304551D+01  
 8. 257425D+01 8. 210725D+01 8. 164843D+01 8. 120166D+01 8. 828170D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 3 VAPOR -1.160615D+04 -3.223935D-01 -5.306688D+03 OL LIQUID -4.298599D+03 -1.194055D-01 -2.579159D+03  
 LEFT FILM COEF. H = 4.772074E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT. BULK TEMP = 9.300600E+01 F  
 RIGHT FILM COEF. H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8. 548792D+01 8. 072307D+01 8. 049574D+01 8. 141311D+01 8. 234275D+01 8. 329067D+01 8. 425949D+01 8. 524391D+01 8. 623878D+01  
 8. 723901D+01 8. 769327D+01 8. 815435D+01 8. 861572D+01 8. 907710D+01 8. 953849D+01 8. 995987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 OL LIQUID -9.871814D+03 -2.742171D-01 -5.925129D+03 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.672877D+04 -4.646809D-01 -2.793710D+03

LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.440579E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.300600E+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.536804D+01 8.490753D+01 8.451913D+01 8.454787D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -5.877395D+03 -1.632594D-01 -1.810933D+03 OIL LIQUID -2.302248D+03 -6.395128D-02 -1.355733D+03  
 LEFT FILM COEF .H = 5.081960E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.300600E+01 F  
 RIGHT FILM COEF .H = 4.392914E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F P,K TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.034451D+01 8.013925D+01 8.062412D+01 8.122108D+01 8.244128D+01 8.305175D+01 8.366006D+01 8.426104D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OIL LIQUID -2.496825D+03 -6.935618D-02 -1.470314D+03 3 VAPOR -6.374129D+03 -1.770575D-01 -1.963986D+03  
 LEFT FILM COEF .H = 4.392914E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.081960E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.300600D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.426104D+01 8.366006D+01 8.305173D+01 8.244128E+01 8.183058D+01 8.122108D+01 8.062472D+01 8.013925D+01 8.034151D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -4.034254D+03 -1.120630D-01 -1.736252D+03 OIL LIQUID -7.143051D+02 -1.984178D-02 -4.131191D+02  
 LEFT FILM COEF .H = 4.759266E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.300600E+01 F  
 RIGHT FILM COEF .H = 3.675930E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.23345D+01 8.048541D+01 8.059587D+01 8.071843D+01 8.084919D+01 8.098422D+01 8.115810D+01 8.137222D+01 8.159039D+01  
 8.180809D+01 8.202771D+01 8.224633D+01 8.246486D+01 8.268279D+01 8.371965D+01 8.475650D+01 8.579333D+01 8.683013D+01  
 8.753308D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP. STEP LIQUID STEP VAPOR NET LIQUID NET VAPOR  
 0 0 -5.746628D-01 0 -1.231008D+04  
 1 0 0 0 0  
 2 0 0 0 0  
 3 0 -1.336596D+00 0 -1.509148D+04  
 4 0 0 0 0

COMP. NO.	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	A T M O S P H E R E (LB/S)	H U M I D I T Y (LB/S)	C O N D E N S A T I O N (LB/S)	M A S S T R A N S F E R C O E F F I C I E N T S (BTU/S FT2 R)	C O N V E R G E N C E (DE/E)
1	1.47000D+01	0	7.34000D+01	0	0	0	0
3	1.47001D+01	1.63038D-01	9.30075D+01	3.90777D+05	3.90777D+05	2.65173D-06	0
1	0	0	0	6.00000D-01	0	0	0
3	3.84055D+03	2.67717D+01	0	2.12373D-01	0	0	0
COMP	3 LEAKAGE OUTFLOW MASS = 6.0320D+01 LB/HR	ENERGY BTU/HR = 8.3846D+03 (NORMAL = 8.3846D+03)	PENETRATION = 0				
STEP	AND NET MASS LOSSES LB/HR	STEP AIR = 1.1599D-05	NET VAPOR = 9.8475D-01	NET AIR = 1.4127D+02			
TOTAL	NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR (LB/HR) = 1.412684D+02	WATER VAPOR (LB/HR) = 9.847537D-01					

\*\*\*\*\* TIME = 6.166667E-01 HR = 3.700000E+01 MIN = 2.220000E+03 SEC \*\*\*\*\*  
 HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -1.007365D+03 -2.798227D-02 -5.833866D+02 3 VAPOR -3.479882D+03 -9.666380D-02 -1.538053D+03

89/12/14

LEFT FILM COEF .H = 2.000000E-01 BTU/HR.FT<sup>2</sup>.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.226333E+01 F  
 RIGHT FILM COEF .H = 4.719103E-01 BTU/HR.FT<sup>2</sup>.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.314607E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.532813D+01 8.502593D+01 8.473436D+01 8.444435D+01 8.415452D+01 8.386473D+01 8.357534D+01 8.329059D+01 8.304926D+01  
 8.261695D+01 8.218889D+01 8.176896D+01 8.136104D+01 8.299320D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.158978D+04 -3.219387D-01 -5.499991D+03 OLIIQUID -4.298599D+03 -1.194055D-01 -2.650803D+03  
 LEFT FILM COEF .H = 4.771472E-01 BTU/HR.FT<sup>2</sup>.F FIRST MESH K = 3.500000E-02 BTU/HR.FT. BULK TEMP = 9.314607E+01 F  
 RIGHT FILM COEF .H = 1.000000E+04 BTU/HR.FT<sup>2</sup>.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.563765D+01 8.082628D+01 8.057893D+01 8.148386D+01 8.240120D+01 8.333709D+01 8.429419D+01 8.526714D+01 8.625072D+01  
 8.723976D+01 8.769331D+01 8.815435D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQUID -9.871199D+03 -2.742000D-01 -6.089655D+03 3 VAPOR -1.703122D+04 -4.730826D-01 -3.075066D+03  
 LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT<sup>2</sup>.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.459903E-01 BTU/HR.FT<sup>2</sup>.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.314607D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.536833D+01 8.490872D+01 8.452580D+01 8.457233D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -5.942320D+03 -1.650630D-01 -1.909436D+03 OLIIQUID -2.304459D+03 -6.401269D-02 -1.394122D+03  
 LEFT FILM COEF .H = 5.095235E-01 BTU/HR.FT<sup>2</sup>.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.314607E+01 F  
 RIGHT FILM COEF .H = 4.397123E-01 BTU/HR.FT<sup>2</sup>.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.037504D+01 8.014806D+01 8.062616D+01 8.122125D+01 8.183060D+01 8.244128D+01 8.305170D+01 8.365997D+01 8.426102D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQUID -2.499222D+03 -6.942278D-02 -1.511948D+03 3 VAPOR -6.444541D+03 -1.790135D-01 -2.070814D+03  
 LEFT FILM COEF .H = 4.397123E-01 BTU/HR.FT<sup>2</sup>.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.095235E-01 BTU/HR.FT<sup>2</sup>.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.314607D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.426102D+01 8.365997D+01 8.305170D+01 8.244128D+01 8.183060D+01 8.122125D+01 8.062616D+01 8.014806D+01 8.037504D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -4.015078D+03 -1.115304D-01 -1.803332D+03 OLIIQUID -7.154014D+02 -1.987223D-02 -4.250333D+02  
 LEFT FILM COEF .H = 4.792849E-01 BTU/HR.FT<sup>2</sup>.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.314607E+01 F  
 RIGHT FILM COEF .H = 3.681880E-01 BTU/HR.FT<sup>2</sup>.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.251102D+01 8.064526D+01 8.071676D+01 8.080030D+01 8.089200D+01 8.098796D+01 8.115863D+01 8.137228D+01 8.159049D+01  
 8.180909D+01 8.202771D+01 8.224633D+01 8.246485D+01 8.268275D+01 8.371954D+01 8.475631D+01 8.579306D+01 8.682979D+01  
 8.759328D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP.	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
0	0.	-5.748955D-01	0.	-1.265495D+04
1	0.	0.	0.	0.
2	0.	0.	0.	0.
3	0.	-1.347292D+00	0.	-1.589669D+04
4	0.	0.	0.	0.

COMP NO	PRESSURE (PSIA)	TEMPERATURE (F)	ENERGY (BTU)	CONVERGENCE DE/E
1	1.47000+01	7.34000+01	0	0
3	1.47001+01	9.31475+01	3.90771D+05	2.66095D-06

AIR MASS (LBM)	WATER MASS (LBM)	HUMIDITY (LB/S)	CONDENSATION MASS (LB MOL/S FT2)	HEAT TRANSFER COEFFICIENTS
0	0	6.00000-01	0	0
3	2.67650+01	2.11452D-01	0	0

COMP 3 LEAKAGE OUTFLOW MASS = 5.7410E+01 LBM/HR ENERGY BTU/HR = 7.9821D+03 (NORMAL = 7.9821D+03 PENETRATION = 0)  
 STEP AND NET MASS LOSSES LBM STEP VAPOR = 1.10400-05 STEP AIR = 1.5837D-03 NET VAPOR = 9.9154D-01 NET AIR = 1.4224D+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) = 1.422423D+02 WATER VAPOR(LBM) = 9.915428D-01

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -1.01065D+03 -2.807357E-02 -6.002034D+02 3 VAPOR -3.461066D+03 -9.614118D-02 -1.595896D+03  
 LEFT FILM COEF .H = 2.00000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.228667E+01 F  
 RIGHT FILM COEF .H = 4.712050E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.327955D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.532913D+01 8.502607D+01 8.473438D+01 8.444335D+01 8.415452D+01 8.386473D+01 8.357540D+01 8.329115D+01 8.305314D+01  
 8.265953D+01 8.227016D+01 8.188888D+01 8.151954D+01 8.115452D+01 8.077100D+01 8.038649D+01 7.999987D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.15710D+04 -3.214173D-01 -5.693001D+03 0 LIQUID -4.298599D+03 -1.194055D-01 -2.722446D+03  
 LEFT FILM COEF .H = 4.770898E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT.F BULK TEMP = 9.327955E+01 F  
 RIGHT FILM COEF .H = 1.000000E+01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.578239D+01 8.092930D+01 8.066300D+01 8.155534D+01 8.246042D+01 8.338417D+01 8.432942D+01 8.529075D+01 8.626288D+01  
 8.724056D+01 8.769336D+01 8.815436D+01 8.851572D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 LIQUID -9.870524D+03 -2.741812D-01 -6.254169D+03 3 VAPOR -1.731785D+04 -4.810450D-01 -3.561329D+03  
 LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.477965E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.327955D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.536864D+01 8.490999D+01 8.453287D+01 8.459668D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -6.003485D+03 -1.667621D-01 -2.008989D+03 0 LIQUID -2.306659D+03 -6.407380D-02 -1.432548D+03  
 LEFT FILM COEF .H = 5.107625E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.327955E+01 F  
 RIGHT FILM COEF .H = 4.401322E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.040837D+01 8.015708D+01 8.062768D+01 8.12.144D+01 8.193061D+01 8.244127D+01 8.305167D+01 8.365986D+01 8.426103D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 LIQUID -2.501608D+03 -6.948906D-02 -1.553621D+03 3 VAPOR -6.510875D+03 -1.608562D-01 -2.178781D+03  
 LEFT FILM COEF .H = 4.401322E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.107625E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.327955D+01 F

MESH POINT TEMPERATURES (F), LEFT TO RIGHT

8.426103D+01 8.365988D+01 8.305167D+01 8.244127D+01 8.183061D+01 8.122144D+01 8.062768D+01 8.015708D+01 8.040837D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL

TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -3.994142D+03 -1.109489D-01 -1.870078D+03 OLIQUID -7.164785D+02 -1.990276D-02 -4.369657D+02  
 LEFT FILM COEF .H = 4.785917E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.327955E+01 F  
 RIGHT FILM COEF .H = 3.687800E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.258464D+01 8.080421D+01 8.083701D+01 8.088179D+01 8.093468D+01 8.099183D+01 8.115919D+01 8.137234D+01 8.159050D+01  
 8.180909D+01 8.202771D+01 8.224633D+01 8.246485D+01 8.268272D+01 8.371944D+01 8.475614D+01 8.579283D+01 8.682950D+01  
 8.753353D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0. 0. -5.751254D-01 0. -1.299995D+04  
 1 0. 0. 0. 0.  
 2 0. 0. -1.357171D+00 0. -1.670808D+04  
 3 0. 0. 0. 0.  
 4 0. 0. 0. 0.

COMP NO	P R E S S U R E (P S I A)	T E M P E R A T U R E ( F )	A T M O S P H E R E ( L B M )	E N E R G Y ( B T U )	H U M I D I T Y ( L B M )	C O N D E N S A T I O N ( L B / S )	T R A N S F E R C O E F F I C I E N T S ( B T U / S F T 2 R )	C O N V E R G E N C E D E / E
1	1.47000D+01	7.34000D+01	7.34000D+01	0.	0.	0.	0.	0.
3	1.47001D+01	1.63039D-01	9.32810D+01	9.32810D+01	3.90765D+05	3.90765D+05	2.66930D-06	2.66930D-06
3	3.83865D+03	2.67585D+01	0.	2.67585D+01	6.000E-20	0.	0.	0.
CUMP	3 LEAKAGE OUTFLOW - MASS = 5.4724D+01 LBM/HR	ENERGY BTU/HR	7.34000D+01	7.34000D+01	0.	0.	0.	0.
	STEP AND NET MASS LOSSES LBM STEP VAPOR = 1.0523D-05 STEP AIR = 1.5096D-03 NET VAPOR = 9.9801D-01 NET AIR = 1.4317D+02	(NORMAL = 7.6103D+03 PENETRATION = 0.)	9.32810D+01	9.32810D+01	0.	0.	0.	0.
	TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) = 1.431700D+02 WATER VAPOR(LBM) = 9.980093D-01		0.	0.	0.	0.	0.	0.

\*\*\*\*\* TIME = 6.500000E-01 HR = 7.900000E+01 MIN = 2.340000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL

TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -1.0139336D+03 -2.816481D-02 -6.170750D+02 3 VAPOR -3.440855D+03 -9.557979D-02 -1.653414D+03  
 LEFT FILM COEF .H = 2.000000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.231000E+01 F  
 RIGHT FILM COEF .H = 4.704525E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.340694D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.532985D+01 8.502621D+01 8.473449D+01 8.444436D+01 8.415452D+01 8.386474D+01 8.357546D+01 8.329176D+01 8.305714D+01  
 8.270195D+01 8.235098D+01 8.200806D+01 8.167700D+01 8.133682D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING

TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.155012D+04 -3.208373D-01 -5.885680D+03 OLIQUID -4.298599D+03 -1.194055D-01 -2.794089D+03  
 LEFT FILM COEF .H = 4.770350E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT.F BULK TEMP = 9.340694E+01 F  
 RIGHT FILM COEF .H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.592245D+01 8.103208D+01 8.074788D+01 8.162776D+01 8.252032D+01 8.343185D+01 8.436513D+01 8.531471D+01 8.627524D+01  
 8.724141D+01 8.769341D+01 8.815436D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR

TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIQUID -9.869785D+03 -2.741607D-01 -6.418672D+03 3 VAPOR -1.758982D+04 -4.886000D-01 -3.652246D+03



LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.494882E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.340694D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 B 536899D+01 B 491133D+01 B 454001D+01 B 462091D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -6.061176D+03 -1.683647D-01 -2.109533D+03 OLIIQUID -2.308848D+03 -6.413462D-02 -1.471011D+03  
 LEFT FILM COEF .H = 5.119209E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.340694E+01 F  
 RIGHT FILM COEF .H = 4.405509E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 B 044147D+01 B 016630D+01 B 062928D+01 B 122164D+01 B 183063D+01 B 244127D+01 B 305165D+01 B 365979D+01 B 426104D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQUID -2.503983D+03 -6.955502D-02 -1.595335D+03 3 VAPOR -6.573443D+03 -1.825942D-01 -2.287822D+03  
 LEFT FILM COEF .H = 4.405509E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.119209E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.340694D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 B 426104D+01 B 365979D+01 B 305165D+01 B 244127D+01 B 183063D+01 B 122164D+01 B 062928D+01 B 016630D+01 B 044147D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -3.971688D+03 -1.103252D-01 -1.936462D+03 OLIIQUID -7.175369D+02 -1.993156D-02 -4.489158D+02  
 LEFT FILM COEF .H = 4.778536E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.340694E+01 F  
 RIGHT FILM COEF .H = 3.693688E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 B 285531D+01 B 096211D+01 B 095653D+01 B 096283D+01 B 097721D+01 B 099582D+01 B 115978D+01 B 137241D+01 B 159050D+01  
 B 180909D+01 B 202771D+01 B 224633D+01 B 246484D+01 B 268269D+01 B 371935D+01 B 475600D+01 B 579264D+01 B 682926D+01  
 B 753383D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
0	0.	-5.753523D-01	0.	-1.334510D+04
1	0.	0.	0.	0.
2	0.	0.	0.	0.
3	0.	-1.366301D+00	0.	-1.757516D+04
4	0.	0.	0.	0.

COMP NO	PRESSURE (PSIA)		TEMPERATURE (F)		ENERGY (BTU)			CONVERGENCE DE/E
	TOTAL	STEAM	ATMOS	POOL	ATMOS	POOL	TOTAL	
1	1.47000D+01	0.	7.34000D+01	7.34000D+01	0.	0.	0.	0.
3	1.47001D+01	1.63039D-01	9.34084D+01	9.34084D+01	3.90760D+05	0.	3.90760D+05	2.67686D-06

COMP	AIR MASS (LBM)	WATER VAPOR--ATMOS--LIQUID		MASS POOL	TOTAL	HUMIDITY (LB/S)	CONDENSATION (LB/S)	TRANSFER COEFFICIENTS MASS HEAT (LB MCL/S FT2)(BTU/S FT2 R)	
1	0.	0.	0.	0.	0.	6.00000D-01	0.	0.	0.
3	3.83776D+03	2.67523D+01	0.	0.	2.67523D+01	2.09750D-01	0.	0.	0.

COMP 3 LEAKAGE OUTFLOW- MASS= 5.2241D+01 LBM/HR ENERGY BTU/HR = 7.2666D+03 (NORMAL= 7.2666D+03 PENETRATION= 0.)  
 STEP AND NET MASS LOSSES LBM STEP VAPOR= 1.0046D-05 STEP AIR= 1.4411D-03 NET VAPOR= 1.0042D+00 NET AIR= 1.4405D+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.440549D+02 WATER VAPOR(LBM)= 1.004178D+00

\*\*\*\*\* TIME = 6.6666E-01 HR = 4.000000E+01 MIN = 2.400000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -1.017219D+03 -2.825600D-02 -6.340013D+02 3 VAPOR -3.419446D+03 -9.498512D-02 -1.710585D+03

CC

LEFT FILM COEF  $h = 2.000000E-01$  BTU/HR.FT<sup>2</sup>.F FIRST MESH  $K = 1.050000E+00$  BTU/HR.FT. BULK TEMP =  $9.233333E+01$  F  
 RIGHT FILM COEF  $h = 4.696587E-01$  BTU/HR.FT<sup>2</sup>.F LAST MESH  $K = 6.700000E-02$  BTU/HR.FT.F BULK TEMP =  $9.352870E+01$  F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.5330599+01 8.502637D+01 8.473442D+01 8.444436D+01 8.415452D+01 8.386475D+01 8.357554D+01 8.329240D+01 8.306125D+01  
 8.274417D+01 8.243130D+01 8.212641D+01 8.183330D+01 8.350432D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.152737D+04 -3.202054D-01 -6.077995D+03 0 LIQUID -4.298599D+03 -1.194055D-01 -2.865733D+03  
 LEFT FILM COEF  $h = 4.769827E-01$  BTU/HR.FT<sup>2</sup>.F FIRST MESH  $K = 3.050000E+00$  BTU/HR.FT. BULK TEMP =  $9.352870E+01$  F  
 RIGHT FILM COEF  $h = 1.000000E+04$  BTU/HR.FT<sup>2</sup>.F LAST MESH  $K = 1.050000E+00$  BTU/HR.FT.F BULK TEMP =  $9.000000D+01$  F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.605813D+01 8.113459D+01 8.083345D+01 8.170075D+01 8.258084D+01 8.348007D+01 8.440129D+01 8.533900D+01 8.628778D+01  
 8.724229D+01 8.769346D+01 8.815436D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 LIQUID -9.868979D+03 -2.741383D-01 -6.583161D+03 3 VAPOR -1.784818D+04 -4.957771D-01 -3.947581D+03  
 LEFT FILM COEF  $h = 4.785000E-01$  BTU/HR.FT<sup>2</sup>.F FIRST MESH  $K = 1.050000E+00$  BTU/HR.FT. BULK TEMP =  $9.000000E+01$  F  
 RIGHT FILM COEF  $h = 4.510759E-01$  BTU/HR.FT<sup>2</sup>.F LAST MESH  $K = 1.050000E+00$  BTU/HR.FT.F BULK TEMP =  $9.352870D+01$  F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.536937D+01 8.491275D+01 8.454733D+01 8.464499D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -6.115660D+03 -1.698782D-01 -2.211011D+03 0 LIQUID -2.311028D+03 -6.419516D-02 -1.509510D+03  
 LEFT FILM COEF  $h = 5.130059E-01$  BTU/HR.FT<sup>2</sup>.F FIRST MESH  $K = 1.050000E+00$  BTU/HR.FT. BULK TEMP =  $9.352870E+01$  F  
 RIGHT FILM COEF  $h = 4.409687E-01$  BTU/HR.FT<sup>2</sup>.F LAST MESH  $K = 1.050000E+00$  BTU/HR.FT.F BULK TEMP =  $9.000000D+01$  F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.047435D+01 8.017573D+01 8.063095D+01 8.122186D+01 8.183066D+01 8.244127D+01 8.305162D+01 8.365971D+01 8.426106D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 LIQUID -2.506346E+03 -6.962068D-02 -1.637087D+03 3 VAPOR -6.632531D+03 -1.842356D-01 -2.397876D+03  
 LEFT FILM COEF  $h = 4.409687E-01$  BTU/HR.FT<sup>2</sup>.F FIRST MESH  $K = 1.050000E+00$  BTU/HR.FT. BULK TEMP =  $9.000000E+01$  F  
 RIGHT FILM COEF  $h = 5.130059E-01$  BTU/HR.FT<sup>2</sup>.F LAST MESH  $K = 1.050000E+00$  BTU/HR.FT.F BULK TEMP =  $9.352870D+01$  F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.426106D+01 8.365971D+01 8.305162D+01 8.244127D+01 8.183066D+01 8.122186D+01 8.063095D+01 8.017573D+01 8.047435D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -3.947932D+03 -1.096653D-01 -2.002460D+03 0 LIQUID -7.185769D+02 -1.996044D-02 -4.608835D+02  
 LEFT FILM COEF  $h = 4.770761E-01$  BTU/HR.FT<sup>2</sup>.F FIRST MESH  $K = 6.700000E-02$  BTU/HR.FT. BULK TEMP =  $9.352870E+01$  F  
 RIGHT FILM COEF  $h = 3.699546E-01$  BTU/HR.FT<sup>2</sup>.F LAST MESH  $K = 6.700000E-02$  BTU/HR.FT.F BULK TEMP =  $9.000000D+01$  F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.302309D+01 8.111884D+01 8.107519D+01 8.104336D+01 8.101953D+01 8.099992D+01 8.116042D+01 8.137248D+01 8.159051D+01  
 8.180909D+01 8.202771D+01 8.224632D+01 8.246483D+01 8.268265D+01 8.371927D+01 8.475588D+01 8.579248D+01 8.682907D+01  
 8.753417D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP.	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
0	0.	-5.755762D-01	0.	-1.369038D+04
1	0.	0.	0.	0.
2	0.	0.	0.	0.
3	0.	-1.374747D+00	0.	-1.834751D+04
4	0.	0.	0.	0.

CC

89/12/14.

COMP NO	PRESSURE (PSIA)		TEMPERATURE (F)		ENERGY (BTU)			CONVERGENCE DE/E
	TOTAL	STEAM	ATMOS	POOL	ATMOS	POOL	TOTAL	
1	1.47000D+01	0.	7.34000D+01	7.34000D+01	0.	0.	0.	0.
3	1.47001D+01	1.63039D-01	9.35302D+01	9.35302D+01	3.755D+05	0.	3.90755D+0F	2.68372D-06

COMP NO	AIR MASS (LBM)	WATER MASS (LBM)		HUMIDITY	CONDENSATION (LB/S)	TRANSFER COEF. MASS (LB MOL/S FT2)	EFFICIENTS HEAT (BTU/S FT2 R)
	VAPOR	ATMOS	LIQUID				
1	0.	0.	0.	0.	0.	0.	0.
3	3.83692D+03	2.67464D+01	0.	0.	2.57464D+C1	2.08960D-01	0.

COMP. 3 LEAKAGE OUTFLOW- MASS= 4.9946D+01 LBM/HR ENERGY BTU/HR = 6.9488D+03 (NORMAL= 6.94E ) FRACTION= 0. )  
 STEP AND NET MASS LOSSES LBM STEP VAPOR= 9.6042D-06 STEP AIR= 1.3778D-03 NET VAPOR= 1.0101D+00 NE  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.449003D+02 WATER VAPOR(LBM)= 1.010071D+00

\*\*\*\*\* TIME = 7.50000E-01 HR = 4.50000E+01 MIN 2.70000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
0 VAPOR	-1.033607D+03	-2.871123D-02	-7.194526D+02	3 VAPOR	-3.300052D+03	-9.166869D-02	-1.990678D+03

LEFT FILM COEF .H = 2.00000E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.24500E+01 F  
 RIGHT FILM COEF .H = 4.652386E-01 BTU/HR.FT2.F LAST MESH K = 6.70000E-02 BTU/HR.FT.F BULK TEMP = 9.406649D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.533444D+01 8.502721D+01 8.473456D+01 8.444438D+01 8.415452D+01 8.386479D+01 8.3.7601D+01 8.329616D+01 8.308341D+01  
 8.295133D+01 8.282331D+01 8.270293D+01 8.259379D+01 8.430021D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
3 VAPOR	-1.139231D+04	-3.164538D-01	-7.033195D+03	0 LIQUID	-4.298600D+C3	-1.194056D-01	-3.223949D+03

LEFT FILM COEF .H = 4.767514E-01 BTU/HR.FT2.F FIRST MESH K = 3.50000E-02 BTU/HR.FT. BULK TEMP = 9.406649E+01 F  
 RIGHT FILM COEF .H = 1.00000E+04 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.00000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.667987D+01 8.164192D+01 8.126901D+01 8.207312D+01 8.289038D+01 8.372740D+01 8.458722D+01 8.546421D+01 8.635279D+01  
 8.724740D+01 8.769381D+01 8.815438D+01 8.861572D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
0 LIQUID	-9.863845D+03	-2.739957D-01	-7.405376D+03	3 VAPOR	-1.896798D+04	-5.268837D-01	-5.483411D+03

LEFT FILM COEF .H = 4.78500E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF .H = 4.577489E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.406649D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.537178D+01 8.492104D+01 8.458637D+01 8.476305D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
3 VAPOR	-6.347844D+03	-1.763281D-01	-2.730748D+03	0 LIQUID	-2.321777D+03	-6.449374D-C2	-1.702545D+03

LEFT FILM COEF .H = 5.175326E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.406649E+01 F  
 RIGHT FILM COEF .H = 4.430419E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.00000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.063505D+01 8.022567D+01 8.064054D+01 8.122321D+01 8.183080D+01 8.244125D+01 8.305147D+01 8.365931D+01 8.426135D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
0 LIQUID	-2.518004D+03	-6.994450D-02	-1.846437D+03	3 VAPOR	-6.884339D+03	-1.912306D-01	-2.961540D+03

LEFT FILM COEF .H = 4.430419E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF .H = 5.175326E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.406649D+01 F

PGC

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.426135D+01 8.365931D+01 8.305147D+01 8.244125D+01 8.183080D+01 8.122321D+01 8.064054D+01 8.022567D+01 8.063505D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -3.81577D+03 -1.059945D-01 -2.326072D+03 OLIIQUID -1.235139D+02 -2.009759D-02 -5.209736D+02  
 LEFT FILM COEF. H = 4.727626E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.406649E+01 F  
 RIGHT FILM COEF. H = 3.72804E-01 BTU/HR.FT2.F LAST MESH K = 5.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.381591D+01 8.188114D+01 8.165308D+01 8.143627D+01 8.122712D+01 8.102205D+01 8.116415D+01 8.137294D+01 8.159055D+01  
 8.180909D+01 8.202771D+01 8.224632D+01 8.246478D+01 8.268250D+01 8.371906D+01 8.475563D+01 8.579220D+01 8.682877D+01  
 8.753644D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0. -5.766483D-01 0. 1.541873D+04  
 1 0. 0. 0. 0.  
 2 0. 0. -1.08559D+00 0. -2.252564D+04  
 4 0. 0. 0. 0.

COMP NO.	PRESSURE (PSIA)	TEMPERATURE (F)	ATMOS	POOL	ENERGY	TOTAL	CONVERGENCE DE/E
1	1.47000D+01	7.34000D+01	0.	0.	0.	0.	0.
3	1.47000D+01	9.40680D+01	3.90732D+05	0.	3.90732D+05	2.70969D-06	
AIR MASS (LBM) VAPOR--ATMOS--LIQUID M A S S (LBM) HUMIDITY (LB/S) CONDENSATION (LB/S) MASS TRANSFER COEFFICIENTS (LB MOL/S FT2) (BTU/S FT2 R) HEAT							
1	0.	0.	0.	0.	6.00000D-01	0.	0.
3	3.83319D+03	2.67204D+01	2.67204D+01	0.	2.05514D-01	0.	0.

COMP. 3 LEAKAGE OUTFLOW MASS = 4.0761D+01 LBM/HR ENERGY BTU/HR = 5.6763D+03 (NORMAL = 5.6763D+03 PENETRATION) = 0.  
 STEP AND NET MASS LOSSES LBM STEP VAPOR = 7.8381D-06 STEP AIR = 1.1244D-03 NET VAPOR = 1.0361D+00 NET AIR = 1.4863D+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) = 1.486297D+02 WATER VAPOR(LBM) = 1.036068D+00

\*\*\*\*\* TIME = 8.33333E-01 HR = 5.00000E+01 MIN = 3.00000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -1.049953D+03 -2.916528D-02 -8.062679D+02 2 VAPOR -3.170857D+03 -8.807996D-02 -2.260328D+03  
 LEFT FILM COEF. H = 3.00000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.25667E+01 F  
 RIGHT FILM COEF. H = 4.603966E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.451340D+01 F

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.533857D+01 8.502821D+01 8.473474D+01 8.444440D+01 8.415453D+01 8.386487D+01 8.357668D+01 8.330089D+01 8.310789D+01  
 8.314959D+01 8.319595D+01 8.324914D+01 8.331291D+01 8.331291D+01 8.503078D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.123383D+04 -3.120515D-01 -7.976071D+03 OLIIQUID -4.298601D+03 -1.194056D-01 -3.582166D+03  
 LEFT FILM COEF. H = 4.765592E-01 BTU/HR.FT2.F FIRST MESH K = 3.506300E-02 BTU/HR.FT. BULK TEMP = 9.451340E+01 F  
 RIGHT FILM COEF. H = 1.00000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.722661D+01 8.743870D+01 8.171113D+01 8.245225D+01 8.320664D+01 8.398103D+01 8.477858D+01 8.559361D+01 8.642050D+01  
 8.725361D+01 8.769431D+01 8.815441D+01 8.861573D+01 8.907710D+01 8.938490D+01 8.999587D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQUID -9.55628D+03 -2.73795D-01 -8.227078D+03 3 VAPOR -1.98676D+04 -5.51873D-01 -7.102825D+03

LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.628793E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.451340E+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 B.537517D+01 B.493133D+01 B.462889D+01 B.487672D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -6.529162D+03 -1.813649D+01 -3.267579D+03 3 VAPOR -2.332292D+03 -6.478585D+02 -1.896466D+03  
 LEFT FILM COEF .H = 5.209591E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.451340E+01 F  
 RIGHT FILM COEF .H = 4.450903E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 B.078918D+01 B.027965D+01 B.065217D+01 B.122503D+01 B.244124D+01 B.305132D+01 B.365898D+01 B.426189D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 LIQUID -2.529408D+03 -7.026129D+02 -2.056748D+03 3 VAPOR -7.080980D+03 -1.966931D+01 -3.542742D+03  
 LEFT FILM COEF .H = 4.450903E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.209591E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.451340E+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 B.426189D+01 B.365898D+01 B.305132D+01 B.244124D+01 B.183102D+01 B.122503D+01 B.065217D+01 B.027965D+01 B.078918D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -3.673137D+03 -1.020322D+01 -2.638139D+03 3 VAPOR -7.280434D+02 -2.022341D+02 -5.814578D+02  
 LEFT FILM COEF .H = 4.680572E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.451340E+01 F  
 RIGHT FILM COEF .H = 3.756582E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 B.180910D+01 B.202771D+01 B.224631D+01 B.246473D+01 B.268235D+01 B.271912D+01 B.279268D+01 B.282948D+01  
 B.180910D+01 B.202771D+01 B.224631D+01 B.246473D+01 B.268235D+01 B.271912D+01 B.279268D+01 B.282948D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP. STEP-1 LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0 -5.776367D-01 0 -1.715018D+04  
 1 0 0 0  
 2 0 0 0  
 3 0 -1.432095D+00 0 -2.678868D+04  
 4 0 0 0

COMP NO	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	E N E R G Y (BTU)	C O N V E R G E N C E (DE/E)
1	TOTAL	ATMOS	POOL	TOTAL
1	1.47000D+01	7.34000D+01	7.34000D+01	0.
3	1.47001D+01	9.45149D+01	9.45149D+01	3.90714D+05
AIR MASS (LBM) W A T E R M A S S (LBM) H U M I D I T Y C O N D E N S A T I O N (LB M O L / S F T 2 ) (BTU / S F T 2 R)				
1	0.	0.	0.	0.
3	3.83010D+03	2.66890D+01	2.66890D+01	6.00000D-01
COMP 3 LEAKAGE OUTFLOW MASS = 3.4374D+01 LBM/HR ENERGY BTU/HR = 4.7905D+03 (NORMAL = 4.7905D+03 PENETRATION = 0.)				
STEP AND NET MASS LOSSES LBM STEP VAPOR = 6.6093D-06 STEP AIR = 9.4822D-04 NET VAPOR = 1.0576D+00 NET AIR = 1.5172D+02				
TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) = 1.517232D+02 WATER VAPOR(LBM) = 1.057632D+00				

\*\*\*\*\* TIME = 9.166667E-01 HR = 5.500000E+01 MIN = 3.300000E+03 SEC \*\*\*\*\*  
 HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -1.066258D+03 -2.961824D-02 -2.944437D+02 3 VAPOR -3.041373D+03 -8.448170D-02 -2.519150D+03

CONTEMP-L1/O2B.30 APRIL 1978. EG&G IDAHO INC. CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM  
COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS 89/12/14.

LEFT FILM COEF .H = 2.00000E+00 BTU/HR.FT. BULK TEMP = 9.26833E+01 F  
RIGHT FILM COEF .H = 4.55435E-01 BTU/HR.FT2.F LAST MESH K = 6.70000E-02 BTU/HR.FT.F BULK TEMP = 9.489618D+01 F  
MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
8.534298D+01 8.502935D+01 8.473496D+01 8.444440+01 8.415455D+01 8.386498E+01 8.357759D+01 8.330662D+01 8.313425D+01  
8.333865D+01 8.354670D+01 8.376153D+01 8.398624D+01 8.570170D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -1.106216D+04 -3.072829D-01 -8.905137D+03 0 LIQUID -4.298601D+03 -1.194056D-01 -3.930383D+03  
LEFT FILM COEF .H = 4.763946E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT.F BULK TEMP = 9.489618E+01 F  
RIGHT FILM COEF .H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
8.771826D+01 8.262277D+01 8.215339D+01 8.283234D+01 8.352452D+01 8.423667D+01 8.497201D+01 8.572491D+01 8.648974D+01  
8.726090D+01 8.769497D+01 8.815445D+01 8.861513D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
0 LIQUID -9.847032D+03 -2.73287D-01 -9.04801D+03 3 VAPOR -2.061308D+04 -5.725825D-01 -8.790416D+03  
LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
RIGHT FILM COEF .H = 4.669858E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.489618D+01 F  
MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
8.537967D+01 8.494365D+01 8.467418D+01 8.498583D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -6.675473D+03 -1.854292D-01 -3.817974D+03 0 LIQUID -2.342591D+03 -6.507193D-02 -2.091254D+03  
LEFT FILM COEF .H = 5.236549E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.489618E+01 F  
RIGHT FILM COEF .H = 4.471150E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
8.093665D+01 8.033692D+01 8.066586D+01 8.122741D+01 8.183134D+01 8.244124D+01 8.305117D+01 8.365871D+01 8.422265D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
0 LIQUID -2.540577D+03 -7.057154D-02 -2.267999D+03 3 VAPOR -7.239657D+03 -2.011005D-01 -4.140654D+03  
LEFT FILM COEF .H = 4.471150E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
RIGHT FILM COEF .H = 5.236549E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.489618D+01 F  
MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
8.426265D+01 8.365871D+01 8.305117D+01 8.244124D+01 8.183134D+01 8.122741D+01 8.066586D+01 8.033692D+01 8.093665D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -3.530399D+03 -9.806729D-02 -2.938262D+03 0 LIQUID -7.322034D+02 -2.033893D-02 -6.423039D+02  
LEFT FILM COEF .H = 4.632515E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.489618E+01 F  
RIGHT FILM COEF .H = 3.784134E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
8.522129D+01 8.327563D+01 8.271321D+01 8.216068D+01 8.161494D+01 8.107236D+01 8.117457D+01 8.137454D+01 8.159074D+01  
8.180911D+01 8.202771D+01 8.224630D+01 8.246468D+01 8.268223D+01 8.371942D+01 8.475662D+01 8.579384D+01 8.683109D+01  
8.754357D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
0 0 0 -5.785350D-01 0  
1 0 0 0  
2 0 0 -3.111159D+04  
3 0 0 -1.448946D+00 0  
4 0 0 0

COMP NO	PRESSURE (PSIA)	TEMPERATURE (F)	ATMOS POOL	ENR G Y	(BTU) TOTAL	CONVERGENCE DE/E
1	1.47000+01	7.34000+01	7.34000+01	0	0	0
3	1.47001+01	9.48977+01	9.48977+01	3.90698+05	3.90698+05	2.73473D-05
<p>AIR MASS (LBM)      W A T E R M A S S ( L E M )      HUMIDITY      CONDENSATION (LB/S)      (LB MOL/5 FT2) (BTU/5 FT2 R)      TRANSFER COEFFICIENTS MASS HEAT</p>						
1	0	0	0	0	0	0
3	3.82745D+03	2.66804D+01	2.66804D+01	6.00000D-01	6.00000D-01	0
<p>COMP 3 LEAKAGE OUTFLOW MASS = 2.9804D+01 LBM/HR      ENERGY BTU/HR = 4.1563D+03 PENETRATION = 0</p>						
<p>STEP AND NET MASS LOSSES LBM STEP VAPOR = 5.7310D-06 STEP AIR = 8.2215D-04 NET VAPOR = 1.0761D+00 NET AIR = 1.5437D+02</p>						
<p>TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) = 1.54368E+02 WATER VAPOR(LBM) = 1.076073D+00</p>						
<p>***** TIME = 1.00000E+00 HR = 6.00000E+01 MIN = 3.60000E+03 SEC *****</p>						
<p>HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL</p>						
<p>TO LEFT COMP.      END STEP BTU/HR      STEP BTU      TOTAL NET BTU      TO RIGHT COMP.      END STEP BTU/HR      STEP BTU      TOTAL NET BTU</p>						
<p>0 VAPOR      -1.082529D+03      -3.007017D-02      -9.819566D+02      3 VAPOR      -2.91183D+03      -8.102363D-02      -2.767363D+03</p>						
<p>RIGHT FILM COEF. H = 4.505357E-01 BTU/HR.FT2.F      FIRST MESH K = 1.050000E+00 BTU/HR.FT      BULK TEMP = 9.280000E+01 F</p>						
<p>MESH POINT TEMPERATURES (F), LEFT TO RIGHT</p>						
<p>8.534765D+01      8.503064D+01      8.473523D+01      8.444448D+01      8.415458D+01      8.386515D+01      8.357877D+01      8.331335D+01      8.316212D+01</p>						
<p>8.351676D+01      8.387485D+01      8.423927D+01      8.461288D+01      8.500904D+01</p>						
<p>HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF &amp; CEILING</p>						
<p>TO LEFT COMP.      END STEP BTU/HR      STEP BTU      TOTAL NET BTU      TO RIGHT COMP.      END STEP BTU/HR      STEP BTU      TOTAL NET BTU</p>						
<p>3 VAPOR      -1.08838D+04      -3.023087D-01      -9.819566D+03      0 LIQUID      -4.298601D+03      -1.194056D-01      -4.298600D+03</p>						
<p>RIGHT FILM COEF. H = 4.762501E-01 BTU/HR.FT2.F      FIRST MESH K = 3.500000E-02 BTU/HR.FT      BULK TEMP = 9.523235E+01 F</p>						
<p>MESH POINT TEMPERATURES (F), LEFT TO RIGHT</p>						
<p>8.816848D+01      8.309377D+01      8.259137D+01      8.220539D+01      8.184047D+01      8.144128D+01      8.107710D+01      8.999987D+01</p>						
<p>8.726921D+01      8.769583D+01      8.815452D+01      8.861573D+01      8.907710D+01      8.953843D+01      8.999987D+01</p>						
<p>HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR</p>						
<p>TO LEFT COMP.      END STEP BTU/HR      STEP BTU      TOTAL NET BTU      TO RIGHT COMP.      END STEP BTU/HR      STEP BTU      TOTAL NET BTU</p>						
<p>0 LIQUID      -9.834814D+03      -2.31893D-01      -9.868177D+03      3 VAPOR      -2.124821D+04      -5.902253D-01      -1.053529D+04</p>						
<p>RIGHT FILM COEF. H = 4.785000E-01 BTU/HR.FT2.F      FIRST MESH K = 1.050000E+00 BTU/HR.FT      BULK TEMP = 9.523235E+01 F</p>						
<p>MESH POINT TEMPERATURES (F), LEFT TO RIGHT</p>						
<p>8.538540D+01      8.495796D+01      8.472167D+01      8.509049D+01</p>						
<p>HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL</p>						
<p>TO LEFT COMP.      END STEP BTU/HR      STEP BTU      TOTAL NET BTU      TO RIGHT COMP.      END STEP BTU/HR      STEP BTU      TOTAL NET BTU</p>						
<p>3 VAPOR      -6.797148D+03      -1.688092D-01      -4.378477D+03      0 LIQUID      -2.352687D+03      -6.535236D-02      -2.286892D+03</p>						
<p>RIGHT FILM COEF. H = 5.258496E-01 BTU/HR.FT2.F      FIRST MESH K = 1.050000E+00 BTU/HR.FT      BULK TEMP = 9.523235E+01 F</p>						
<p>MESH POINT TEMPERATURES (F), LEFT TO RIGHT</p>						
<p>8.107769D+01      8.035683D+01      8.068156D+01      8.123041D+01      8.183179D+01      8.244125D+01      8.305102D+01      8.365852D+01      8.426361D+01</p>						
<p>HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL</p>						
<p>TO LEFT COMP.      END STEP BTU/HR      STEP BTU      TOTAL NET BTU      TO RIGHT COMP.      END STEP BTU/HR      STEP BTU      TOTAL NET BTU</p>						
<p>0 LIQUID      -2.551526D+03      -7.087568D-02      -2.480171D+03      3 VAPOR      -7.371616D+03      -2.047655D-01      -4.749613D+03</p>						
<p>RIGHT FILM COEF. H = 4.491170E-01 BTU/HR.FT2.F      FIRST MESH K = 1.050000E+00 BTU/HR.FT      BULK TEMP = 9.523235E+01 F</p>						
<p>MESH POINT TEMPERATURES (F), LEFT TO RIGHT</p>						
<p>8.525849E-01 BTU/HR.FT2.F      LAST MESH K = 1.050000E+00 BTU/HR.FT      BULK TEMP = 9.523235D+01 F</p>						

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.426361D+01 8.365852D+01 8.305102D+01 8.244125D+01 8.183179D+01 8.123041D+01 8.06156D+01 8.039683D+01 8.107769D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -3.393278D+03 -3.425833D+02 -3.226697D+03 OLIQUID -7.360280D+02 -2.044521D+02 -7.034824D+02  
 LEFT FILM COEF. H = 4.585197E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.523235E+01 F  
 RIGHT FILM COEF. H = 3.811109E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.583726D+01 8.390252D+01 8.319114D+01 8.248896D+01 8.179310D+01 8.110070D+01 8.118127D+01 8.137568D+01 8.159090D+01  
 8.180913D+01 8.202771D+01 8.224628D+01 8.246463D+01 8.268213D+01 8.371994D+01 8.475776D+01 8.579561D+01 8.683230D+01  
 8.754822D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP. NO.	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
0	-5.793383D-01	0.	-2.062130D+04	0.
1	0.	0.	0.	0.
2	0.	0.	0.	0.
3	-1.461392D+00	0.	-3.547800D+04	0.
4	0.	0.	0.	0.

COMP. NO.	P R E S S U R E (P S I A)	T E M P E R A T U R E ( F )	A T M O S	E N E R G Y	T O T A L	C O N V E R G E N C E
1	1.47000D+01	7.34000D+01	7.34000D+01	0.	0.	0.
3	1.47000D+01	9.52339D+01	9.52339D+01	3.90684D+05	3.90684D+05	2.74388D-06

AIR MASS (LB)	W A T E R M A S S ( L B M )	H U M I D I T Y ( L B M / S F T 2 )	T R A N S F E R C O E F F I C I E N T S
0.	0.	6.00000D-01	0.
3.82513D+03	2.66642D+01	1.98262D-01	0.
3 LEAKAGE DUTFLOW- MASS= 2.64300+01 LBM/HR	ENERGY BTU/HR = 3.6879D+03	(NORMAL= 3.6879D+03	PENETRATION= 0.
STEP AND NET MASS LOSSES LBM STEP VAPOR= 5.0823D-06	STEP AIR= 7.2908D-04	NET VAPOR= 1.0922D+00	NET AIR= 1.5669D+02
TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.566888D+02	WATER VAPOR(LBM)= 1.092246D+00		

\*\*\*\*\* TIME = 1.083333E+00 HR = 6.500000E+01 MIN = 3.900000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -1.092728D+03 -3.035352D-02 -1.074613D+03 3 VAPOR -2.799902D+03 -7.777559D-02 -3.005501D+03  
 LEFT FILM COEF. H = 2.000000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.287500E+01 F  
 RIGHT FILM COEF. H = 4.458056E-01 BTU/HR.FT2.F LAST MESH K = 5.700000E-02 BTU/HR.FT.F BULK TEMP = 9.553353D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.535243D+01 8.503208D+01 8.473555D+01 8.444454D+01 8.415461D+01 8.386537D+01 8.358025D+01 8.332104D+01 8.319110D+01  
 8.368431D+01 8.418076D+01 8.468311D+01 8.519399D+01 8.688522D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.070010D+04 -2.972259D-01 -1.071888D+04 OLIQUID -4.298601D+03 -1.194056D-01 -4.656816D+03  
 LEFT FILM COEF. H = 4.761206E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT.F BULK TEMP = 9.553353E+01 F  
 RIGHT FILM COEF. H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.858654D+01 8.355190D+01 8.302214D+01 8.358071D+01 8.415212D+01 8.474296D+01 8.535644D+01 8.598715D+01 8.652964D+01  
 8.727848D+01 8.765689D+01 8.815460D+01 8.861574D+01 8.907710D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIQUID -9.819783D+03 -2.727718D-01 -1.068714D+04 3 VAPOR -2.180204D+04 -6.056098D-01 -1.232953D+04



LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.732816E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT F BULK TEMP = 9.553353E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.539245D+01 8.497421D+01 8.477084D+01 8.519099D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 3 VAPOR -6.901001D+03 -1.916940D-01 -4.950339D+03 -2.358891D+03 -6.552471D-02 -2.483208D+03  
 LEFT FILM COEF .H = 5.276890E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT F BULK TEMP = 9.553353E+01 F  
 RIGHT FILM COEF .H = 4.503860E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.121271D+01 8.045880D+01 8.069222D+01 8.123407D+01 8.244128D+01 8.305088D+01 8.365841D+01 8.426469D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 3 VAPOR -2.558250D+03 -7.106260D-02 -2.693079D+03 -7.484246D+03 -2.078952D-01 -5.368722D+03  
 LEFT FILM COEF .H = 4.503860E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT F BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.276890E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT F BULK TEMP = 9.553353E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.426469D+01 8.365841D+01 8.305088D+01 8.244128D+01 8.183237D+01 8.123407D+01 8.069222D+01 8.045880D+01 8.121271D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 3 VAPOR -3.264674D+03 -9.068595D-02 -3.504047D+03 -7.377653D+02 -2.049347D-02 -7.648906D+02  
 LEFT FILM COEF .H = 4.539641E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT F BULK TEMP = 9.553353E+01 F  
 RIGHT FILM COEF .H = 3.827777E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.640381D+01 8.446344D+01 8.363484D+01 8.279478D+01 8.112966D+01 8.118894D+01 8.137745D+01 8.153112D+01  
 8.180916D+01 8.202771D+01 8.224627D+01 8.246458D+01 8.268205D+01 8.372064D+01 8.475925D+01 8.579789D+01 8.683657D+01  
 8.755313D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
0	0	0	-5.796117D-01	0
1	0	0	0	0
2	0	0	0	0
3	0	-1.470886D+00	0	-3.987702D+04
4	0	0	0	0

COMP	P R E S S U R E (P S I A)	T E M P E R A T U R E (F)	E N E R G Y P O O L	A T M O S	T O T A L	H U M I D I T Y	C O N D E N S A T I O N	M A S S T R A N S F E R C O E F F I C I E N T S	C O N V E R G E N C E
1	1.470000D+01	7.340000D+01	7.340000D+01	0	0	0	0	0	0
3	1.470010D+01	9.553510D+01	9.553510D+01	3.906710D+05	3.906710D+05	0	0	0	2.74886D-06
1	0	0	0	0	0	6.00000D-01	0	0	0
3	8.23050D+03	2.66498D+01	0	2.66498D+01	1.96436D-01	0	0	0	0
COMP	3 LEAKAGE OUTFLOW-MASS=	2.3857D+01 LBM/HR	ENERGY BTU/HR =	3.3306D+03 (NORMAL=	3.3306D+03 PENETRATION=	0	0	0	0
STEP	AND NET MASS LOSSES LBM STEP VAPOR=	4.5875D-06 STEP AIR=	6.5810D-04 NET VAPOR=	1.1067D+00 NET AIR=	1.5876D+02	0	0	0	0
TOTAL	NET CONTAINMENT LOSS TO ATMOSPHERE IS	0 AIR(LBM)=	1.587550D+02 WATER VAPOR(LBM)=	1.106719D+00	0	0	0	0	0

\*\*\*\*\* TIME = 1.166667E+00 HR = 7.000000E+01 MIN = 4.200000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 0 VAPOR -1.102927D+03 -3.063681D-02 -1.166698D+03 3 VAPOR -2.691755D+03 -7.477145D-02 -3.234258D+03

COMTEMP-LT/028.30 APRIL 1978. EG&G IDAHO INC. CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM PAGE 82  
COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS 89/12/14

LEFT FILM COEF .H = 2.00000E-01 BTU/HR.FT2 F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.29500E+01 F  
RIGHT FILM COEF .H = 4.413058E-01 BTU/HR.FT2 F LAST MESH K = 6.70000E-02 BTU/HR.FT.F BULK TEMP = 9.580761D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.53572D+01 8.50336D+01 8.47359D+01 8.44446D+01 8.41546D+01 8.38656D+01 8.35820D+01 8.32296D+01 8.32209D+01  
8.38416D+01 8.44654D+01 8.50946D+01 8.57318D+01 8.64095D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -1.05155D+04 -2.92098D-01 -1.16028D+04 OL LIQUID -4.29860D+03 -1.19405D-01 -5.01503D+03  
LEFT FILM COEF .H = 4.760027E-01 BTU/HR.FT2 F FIRST MESH K = 3.50000E-02 BTU/HR.FT. BULK TEMP = 9.580761E+01 F  
RIGHT FILM COEF .H = 1.00000E+04 BTU/HR.FT2 F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.00000D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.89787D+01 8.39949D+01 8.34438D+01 8.39445D+01 8.44578D+01 8.49902D+01 8.55447D+01 8.61162D+01 8.66992D+01  
8.72886D+01 8.76981D+01 8.81547D+01 8.86157D+01 8.90771D+01 8.95384D+01 8.99998D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
OL LIQUID -9.80180D+03 -2.72272D-01 -1.15047D+04 3 VAPOR -2.22940D+04 -6.56951D-02 -2.68003D+03  
LEFT FILM COEF .H = 4.78500E-01 BTU/HR.FT2 F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.00000E+01 F  
RIGHT FILM COEF .H = 4.758010E-01 BTU/HR.FT2 F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.580761D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.54008D+01 8.49923D+01 8.48212D+01 8.52876D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -6.99155D+03 -1.94209D-01 -5.52927D+03 OL LIQUID -2.36502D+03 -2.10623D-02 -2.68003D+03  
LEFT FILM COEF .H = 5.292674E-01 BTU/HR.FT2 F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.580761E+01 F  
RIGHT FILM COEF .H = 4.516465E-01 BTU/HR.FT2 F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.00000D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.134214D+01 8.05223D+01 8.071874D+01 8.123844D+01 8.183313D+01 8.244134D+01 8.305076D+01 8.365836D+01 8.426582D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
OL LIQUID -2.56490D+03 -7.12414D-02 -2.90658D+03 3 VAPOR -7.58245D+03 -2.10623D-02 -2.10623D-01 -5.99588D+03  
LEFT FILM COEF .H = 4.516465E-01 BTU/HR.FT2 F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.00000E+01 F  
RIGHT FILM COEF .H = 5.292674E-01 BTU/HR.FT2 F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.580761D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.426582D+01 8.365836D+01 8.305076D+01 8.244134D+01 8.183313D+01 8.123844D+01 8.071874D+01 8.05223D+01 8.134214D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -3.14584D+03 -8.73850D-02 -3.77108D+03 OL LIQUID -7.39449D+02 -2.05402D-02 -8.26441D+02  
LEFT FILM COEF .H = 4.496419E-01 BTU/HR.FT2 F FIRST MESH K = 6.70000E-02 BTU/HR.FT. BULK TEMP = 9.580761E+01 F  
RIGHT FILM COEF .H = 3.844287E-01 BTU/HR.FT2 F LAST MESH K = 6.70000E-02 BTU/HR.FT.F BULK TEMP = 9.00000D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.69256D+01 8.50207D+01 8.40459D+01 8.307914D+01 8.211778D+01 8.115945D+01 8.119755D+01 8.137894D+01 8.159142D+01  
8.18092D+01 8.20277D+01 8.22462D+01 8.24645D+01 8.26819D+01 8.37214D+01 8.47609D+01 8.58004D+01 8.68400D+01  
8.75580D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
0 0 0 0  
1 0 0 0  
2 0 0 0  
3 0 -1.478365D+00 0  
4 0 -4.430132D+04 0

89/12/14.

COMP NO.	PRESSURE (PSIA)		TEMPERATURE (F)		ENERGY (BTU)		CONVERGENCE DE/E
	TOTAL	STEAM	ATMOS	POOL	ATMOS	POOL	
1	1.47000D+01	0.	7.34000D+01	7.34000D+01	0.	0.	0.
3	1.47001D+01	1.63041D-01	9.58092D+01	9.58092D+01	3.90660D+05	0.	3.90660D+05
AIR MASS (LBM)      W A T E R M A S S (LBM)      HUMIDITY      CONDENSATION MASS (LB/S)      TRANSFER COEFFICIENTS HEAT (BTU/S FT2 R)							
	(LBM)	VAPOR--ATMOS--LIQUID	POOL	TOTAL			
1	0.	0.	0.	0.	6.00000D-01	0.	0.
3	3.82117D+03	2.66366D+01	0.	2.66366D+01	1.94791D-01	0.	0.
COMP. 3 LEAKAGE OUTFLOW- MASS= 2.1831D+01 LBM/HR      ENERGY BTU/HR = 3.0492D+03 (NORMAL= 3.0492D+03 PENETRATION= 0. )							
STEP AND NET MASS LOSSES LBM STEP VAPOR= 4.1979D-06 STEP AIR= 6.0221D-04 NET VAPOR= 1.1199D+00 NET AIR= 1.6065D+02							
TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.606523D+02 WATER VAPOR(LBM)= 1.119875D+00							

\*\*\*\*\* TIME = 1.25000E+00 HR = 7.50000E+01 MIN = 4.50000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
0 VAPOR	-1.11312D+03	-3.092001D-02	-1.258434D+03	3 VAPOR	-2.592679D+03	-7.201931D-02	-3.454380D+03
LEFT FILM COEF. H = 2.00000E-01 BTU/HR.FT2.F				FIRST MESH K = 1.050000E+00 BTU/HR.FT.			BULK TEMP = 9.302500E+01 F
RIGHT FILM COEF. H = 4.370682E-01 BTU/HR.FT2.F				LAST MESH K = 6.700000E-02 BTU/HR.FT.F			BULK TEMP = 9.606003D+01 F
MESH POINT TEMPERATURES (F), LEFT TO RIGHT							
8.536204D+01	8.503534D+01	8.473636D+01	8.444471D+01	8.415474D+01	8.386606D+01	8.358420D+01	8.333918D+01
8.398926D+01	8.473010D+01	8.547603D+01	8.622929D+01	8.785263D+01			

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
3 VAPOR	-1.033086D+04	-2.869691D-01	-1.247146D+04	0 LIQUID	-4.298601D+03	-1.194056D-01	-5.373250D+03
LEFT FILM COEF. H = 4.758942E-01 BTU/HR.FT2.F				FIRST MESH K = 3.500000E-02 BTU/HR.FT.			BULK TEMP = 9.606003E+01 F
RIGHT FILM COEF. H = 1.000000E+04 BTU/HR.FT2.F				LAST MESH K = 1.050000E+00 BTU/HR.FT.F			BULK TEMP = 9.000000D+01 F
MESH POINT TEMPERATURES (F), LEFT TO RIGHT							
8.934958D+01	8.442507D+01	8.385522D+01	8.429988D+01	8.475678D+01	8.523224D+01	8.572941D+01	8.624313D+01
8.729962D+01	8.763968D+01	8.815487D+01	8.861576D+01	8.907711D+01	8.953849D+01	8.999987D+01	

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
0 LIQUID	-9.780778D+03	-2.716884D-01	-1.232069D+04	3 VAPOR	-2.273756D+04	-6.315969D-01	-1.604387D+04
LEFT FILM COEF. H = 4.785000E-01 BTU/HR.FT2.F				FIRST MESH K = 1.050000E+00 BTU/HR.FT.			BULK TEMP = 9.000000E+01 F
RIGHT FILM COEF. H = 4.780308E-01 BTU/HR.FT2.F				LAST MESH K = 1.050000E+00 BTU/HR.FT.F			BULK TEMP = 9.606003D+01 F
MESH POINT TEMPERATURES (F), LEFT TO RIGHT							
8.541076D+01	8.501218D+01	8.487271D+01	8.538085D+01				

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
3 VAPOR	-7.071853D+03	-1.964400D-01	-6.115314D+03	0 LIQUID	-2.371092D+03	-6.586365D-02	-2.877377D+03
LEFT FILM COEF. H = 5.306474E-01 BTU/HR.FT2.F				FIRST MESH K = 1.050000E+00 BTU/HR.FT.			BULK TEMP = 9.606003E+01 F
RIGHT FILM COEF. H = 4.528986E-01 BTU/HR.FT2.F				LAST MESH K = 1.050000E+00 BTU/HR.FT.F			BULK TEMP = 9.000000D+01 F
MESH POINT TEMPERATURES (F), LEFT TO RIGHT							
8.146647D+01	8.058712D+01	8.074005D+01	8.124356D+01	8.183409D+01	8.244143D+01	8.305065D+01	8.365839D+01
				8.426701D+01			

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
0 LIQUID	-2.571487D+03	-7.143018D-02	-3.120562D+03	3 VAPOR	-7.669537D+03	-2.130423D-01	-6.632156D+03
LEFT FILM COEF. H = 4.528986E-01 BTU/HR.FT2.F				FIRST MESH K = 1.050000E+00 BTU/HR.FT.			BULK TEMP = 9.000000E+01 F
RIGHT FILM COEF. H = 5.306474E-01 BTU/HR.FT2.F				LAST MESH K = 1.050000E+00 BTU/HR.FT.F			BULK TEMP = 9.606003D+01 F

PCC



RIGHT FILM COEF .H = 4.785000E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000E+01 F  
 LEFT FILM COEF .H = 4.800300E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.629463E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 542207D+01 8 503373D+01 8 492482D+01 8 547089D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -7.143991D+03 -1.984439D-01 -6.707692D+03 0 LIQUID -2.377091D+03 -5.603029D-02 -3.075219D+03  
 LEFT FILM COEF .H = 5.318713E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.629463E+01 F  
 RIGHT FILM COEF .H = 4.541426E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 1586130+01 8 0652749+01 8 076302D+01 8 128945D+01 8 183527D+01 8 244158D+01 8 305057D+01 8 365847D+01 8 426824D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 LIQUID -2.577994D+03 -7.161090D-02 -3.335124D+03 3 VAPOR -7.747773D+03 -2.152156D-01 -7.274599D+03  
 LEFT FILM COEF .H = 4.541426E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.318713E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.629463D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 426824D+01 8 365847D+01 8 305057D+01 8 244158D+01 8 183527D+01 8 124945D+01 8 076302D+01 8 065274D+01 8 158613D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.938147D+03 -8.161563D-02 -4.277535D+03 0 LIQUID -7.425677D+02 -2.062687D-02 -9.499481D+02  
 LEFT FILM COEF .H = 4.477963E-01 BTU/HR FT2 F FIRST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 9.629463E+01 F  
 RIGHT FILM COEF .H = 3.876786E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8 785475D+01 8 597614D+01 8 477912D+01 8 358887D+01 8 240335D+01 8 122051D+01 8 121735D+01 8 138258D+01 8 159227D+01  
 8 180932D+01 8 202772D+01 8 224622D+01 8 246443D+01 8 268195D+01 8 372339D+01 8 476484D+01 8 580634D+01 8 684789D+01  
 8 756824D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS kcal BTU  
 COMP. STEP LIQUID STEP VAPOR NET LIQUID NET VAPOR  
 0 0 -5.798954D-01 0 -2.757815D+04  
 1 0 0 0  
 2 0 0 0  
 3 0 -1.489484D+00 0 -5.320690D+04  
 4 0 0 0

COMP NO	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	A T M O S P H E R E (LBM)	E N E R G Y (BTU)	H U M I D I T Y (LB M O L / S F T 2 R)	C O N D E N S A T I O N (LB / S)	M A S S T R A N S F E R C O E F F I C I E N T S (BTU / S F T 2 R)	C O N V E R G E N C E (DE / E)	
1	1.47000D+01	0	7.34000D+01	7.34000D+01	0	0	0	2.75712D-06	
3	1.47001D+01	1.63041D-01	9.62962D+01	9.62962D+01	3.90640D+05	3.90640D+05	0	0	
1	0	0	0	0	0	0	0	0	
3	3.61782D+03	2.56133D+01	0	2.65133D+01	1.91907D-01	0	0	0	
COMP	3 LEAKAGE OUTFLOW - MASS =	1.8820D+01 LBM/HR	ENERGY BTU/HR =	2.6309D+03 (NORMAL =	2.6309D+03 PENETRATION =	0	0	0	
STEP	AND NET MASS LOSSES LBM	STEP VAPOR =	3.6189D-06	STEP AIR =	5.1915D-04	NET VAPOR =	1.1432D+00	NET AIR =	1.6400D+02
TOTAL	NET CONTAINMENT LOSS TO ATMOSPHERE IS	0 AIR (LBM) =	1.640012D+02	WATER VAPOR (LBM) =	1.143220D+00				

\*\*\*\*\* TIME = 1.416667E+00 HR = 8.500000E+01 MIN = 5.100000E+03 SEC \*\*\*\*\*  
 HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -1.133497D+03 -3.148597D-02 -1.445652D+03 3 VAPOR -2.420683D+03 -6.724156D-02 -3.871693D+03

CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM  
89/12/14  
CONTEMP1-L1/028.30 APRIL 1978, EG&G IDAHO INC. CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM  
COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS

LEFT FILM COEF. H = 2.00000E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.317500E+01 F  
 RIGHT FILM COEF. H = 4.294210E-01 BTU/HR.FT2.F LAST MESH K = 6.70000E-02 BTU/HR.FT.F BULK TEMP = 9.651423D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.537177D+01 8.503906D+01 8.473741D+01 8.444497D+01 8.415495D+01 8.386713D+01 8.358959D+01 8.336010D+01 8.331293D+01  
 8.425779D+01 8.520516D+01 8.615694D+01 8.711502D+01 8.875285D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 -9.965836D+03 -2.768296D-01 -1.416274D+04 3 LIQUID -4.298601D+03 -1.194056D-01 -6.089683D+03  
 3 VAPOR -9.965836D+03 -2.768296D-01 -1.416274D+04 3 VAPOR -2.351316D+04 -6.619508D-02 -3.273558D+03  
 LEFT FILM COEF. H = 4.756989E-01 BTU/HR.FT2.F FIRST MESH K = 3.50000E-02 BTU/HR.FT.F BULK TEMP = 9.651423E+01 F  
 RIGHT FILM COEF. H = 1.00000E+04 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 9.003822D+01 8.524524D+01 8.464474D+01 8.498248D+01 8.533178D+01 8.569866D+01 8.608614D+01 8.648940D+01 8.690357D+01  
 8.732379D+01 8.770346D+01 8.815530D+01 8.861579D+01 8.907711D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 -9.729459D+03 -2.702629D-01 -1.394671D+04 3 VAPOR -2.351316D+04 -6.619508D-02 -3.273558D+03  
 OLIIQUID -9.729459D+03 -2.702629D-01 -1.394671D+04 3 VAPOR -2.351316D+04 -6.619508D-02 -3.273558D+03  
 LEFT FILM COEF. H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.651423E+01 F  
 RIGHT FILM COEF. H = 4.818402E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.651423D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.543483D+01 8.505685D+01 8.497743D+01 8.555808D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 -7.209442D+03 -2.002620D-01 -7.305794D+03 3 VAPOR -2.383024D+03 -6.619508D-02 -3.273558D+03  
 OLIIQUID -7.209442D+03 -2.002620D-01 -7.305794D+03 3 VAPOR -2.383024D+03 -6.619508D-02 -3.273558D+03  
 LEFT FILM COEF. H = 5.329688E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.651423E+01 F  
 RIGHT FILM COEF. H = 4.553785E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.170154D+01 8.071896D+01 8.078756D+01 8.125613D+01 8.183669D+01 8.244178D+01 8.305052D+01 8.365862D+01 8.426953D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 -2.584428D+03 -7.178963D-02 -3.550225D+03 3 VAPOR -7.818755D+03 -2.171873D-01 -7.923250D+03  
 OLIIQUID -2.584428D+03 -7.178963D-02 -3.550225D+03 3 VAPOR -7.818755D+03 -2.171873D-01 -7.923250D+03  
 LEFT FILM COEF. H = 4.553785E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.651423E+01 F  
 RIGHT FILM COEF. H = 5.329688E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.651423D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.426953D+01 8.365862D+01 8.305052D+01 8.244178D+01 8.183669D+01 8.125613D+01 8.078756D+01 8.071896D+01 8.170154D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 -2.848525D+03 -7.912608D-02 -4.518584D+03 3 VAPOR -7.439980D+02 -2.066660D-02 -1.011883D+03  
 OLIIQUID -2.848525D+03 -7.912608D-02 -4.518584D+03 3 VAPOR -7.439980D+02 -2.066660D-02 -1.011883D+03  
 LEFT FILM COEF. H = 4.382841E-01 BTU/HR.FT2.F FIRST MESH K = 6.70000E-02 BTU/HR.FT.F BULK TEMP = 9.651423E+01 F  
 RIGHT FILM COEF. H = 3.892779E-01 BTU/HR.FT2.F LAST MESH K = 6.70000E-02 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.826329D+01 8.640044D+01 8.510565D+01 8.381713D+01 8.253301D+01 8.125139D+01 8.122843D+01 8.138645D+01 8.159286D+01  
 8.180942D+01 8.202773D+01 8.224620D+01 8.246439D+01 8.268196D+01 8.372444D+01 8.476695D+01 8.580949D+01 8.685210D+01  
 8.757366D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0 0 -2.931772D+04  
 1 0 0 0  
 2 0 0 0  
 3 0 -1.493788D+00 0  
 4 0 0 -5.768197D+04

COMP NO.	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	A T M O S	E N E R G Y	(BTU)	C O N V E R G E N C E		
	TOTAL	POOL		POOL	TOTAL	DE/E		
1	1.470000+01	7.340000+01	0.	0.	0.	0.		
3	1.470010+01	9.651580+01	3.906310+05	0.	3.906310+05	2.758680-06		
AIR MASS (LBM)      VAPOR--ATMOS--LIQUID      M A S S      H U M I D I T Y      C O N D E N S A T I O N      M A S S      H E A T (LBM)      (LBM)      (LBM)      (LB/S)      (LB/S)      (LB MDL/S FT2)      (BTU/S FT2 R)								
3	3.816310+03	2.660280+01	0.	6.000000-01	0.	0.		
3	3.816310+03	2.660280+01	2.660280+01	1.905220-01	0.	0.		
3 LEAKAGE DUTFLOW- MASS = 1.765500+01 LBM/HR      ENERGY BTU/HR = 2.46890+03 PENETRATION= 0. STEP AND NET MASS LOSSES LBM STEP VAPOR= 3.39490-06 STEP AIR= 4.87010-04 NET VAPOR= 1.15370+00 NET AIR= 1.65510+02 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.6550920+02 WATER VAPOR(LBM)= 1.1537320+00								
***** TIME = 1.500000E+00 HR = 9.000000E+01 MIN = 5.400000E+03 SEC *****								
HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL TO LEFT COMP.      END STEP BTU/HR      STEP BTU TOTAL NET BTU      TO RIGHT COMP.      END STEP BTU/HR      STEP BTU TOTAL NET BTU								
0	VAPOR	-1.1436740+03	-3.1768670-02	-1.5405340+03	3 VAPOR	-2.3467140+03	-6.5186820-02	-4.0702820+03
RIGHT FILM COEF. H = 2.000000E-01 BTU/HR.FT2.F	FIRST MESH K = 1.050000E+00 BTU/HR.FT.F	BULK TEMP = 9.325000E+01 F					BULK TEMP = 9.325000E+01 F	
MESH POINT TEMPERATURES (F), LEFT TO RIGHT							BULK TEMP = 9.6720920+01 F	
8.5376710+01	8.5041070+01	8.4738020+01	8.4445140+01	8.4155110+01	8.3592850+01	8.3372410+01	8.3343900+01	
8.4379950+01	8.5418360+01	8.5460880+01	8.7509250+01	8.9136410+01				
HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING TO LEFT COMP.      END STEP BTU/HR      STEP BTU TOTAL NET BTU      TO RIGHT COMP.      END STEP BTU/HR      STEP BTU TOTAL NET BTU								
3	VAPOR	-9.7870210+03	-2.7186250-01	-1.4985750+04	OL LIQUID	-4.2985980+03	-1.1940550-01	-6.4479000+03
LEFT FILM COEF. H = 4.756100E-01 BTU/HR.FT2.F	FIRST MESH K = 3.500000E-02 BTU/HR.FT.F	BULK TEMP = 9.672092E+01 F					BULK TEMP = 9.672092E+01 F	
RIGHT FILM COEF. H = 1.000000E+04 BTU/HR.FT2.F	LAST MESH K = 1.050000E+00 BTU/HR.FT.F	BULK TEMP = 9.000000E+01 F					BULK TEMP = 9.000000E+01 F	
MESH POINT TEMPERATURES (F), LEFT TO RIGHT							BULK TEMP = 9.6720920+01 F	
9.0359920+01	8.5635780+01	8.5622350+01	8.5309250+01	8.5222580+01	8.6257810+01	8.6608400+01	8.6963650+01	
8.7336850+01	8.7705740+01	8.8155580+01	8.8645820+01	8.9077110+01	8.9538490+01	8.9999870+01		
HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR TO LEFT COMP.      END STEP BTU/HR      STEP BTU TOTAL NET BTU      TO RIGHT COMP.      END STEP BTU/HR      STEP BTU TOTAL NET BTU								
OL LIQUID	-9.6991760+03	-2.6942170-01	-1.4756260+04	3 VAPOR	-2.3856640+04	-6.6268290-01	-2.1873840+04	
LEFT FILM COEF. H = 4.785000E-01 BTU/HR.FT2.F	FIRST MESH K = 1.050000E+00 BTU/HR.FT.F	BULK TEMP = 9.000000E+01 F					BULK TEMP = 9.000000E+01 F	
RIGHT FILM COEF. H = 4.834916E-01 BTU/HR.FT2.F	LAST MESH K = 1.050000E+00 BTU/HR.FT.F	BULK TEMP = 9.6720920+01 F					BULK TEMP = 9.6720920+01 F	
MESH POINT TEMPERATURES (F), LEFT TO RIGHT							BULK TEMP = 9.6720920+01 F	
8.5449040+01	8.5081460+01	8.5030370+01	8.5642690+01					
HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL TO LEFT COMP.      END STEP BTU/HR      STEP BTU TOTAL NET BTU      TO RIGHT COMP.      END STEP BTU/HR      STEP BTU TOTAL NET BTU								
3	VAPOR	-7.2692680+03	-2.0192380-01	-7.9091090+03	OL LIQUID	-2.3888910+03	-6.6358060-02	-3.4723880+03
LEFT FILM COEF. H = 5.339611E-01 BTU/HR.FT2.F	FIRST MESH K = 1.050000E+00 BTU/HR.FT.F	BULK TEMP = 9.572092E+01 F					BULK TEMP = 9.572092E+01 F	
RIGHT FILM COEF. H = 4.566065E-01 BTU/HR.FT2.F	LAST MESH K = 1.050000E+00 BTU/HR.FT.F	BULK TEMP = 9.000000E+01 F					BULK TEMP = 9.000000E+01 F	
MESH POINT TEMPERATURES (F), LEFT TO RIGHT							BULK TEMP = 9.000000E+01 F	
8.1813060+01	8.0785550+01	8.0813540+01	8.1253610+01	8.1838370+01	8.2442040+01	8.3050490+01	8.3658830+01	
HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL TO LEFT COMP.      END STEP BTU/HR      STEP BTU TOTAL NET BTU      TO RIGHT COMP.      END STEP BTU/HR      STEP BTU TOTAL NET BTU								
OL LIQUID	-2.5907910+03	-7.1966380-02	-3.7658600+03	3 VAPOR	-7.8836370+03	-2.1899960-01	-8.5775560+03	
LEFT FILM COEF. H = 4.566065E-01 BTU/HR.FT2.F	FIRST MESH K = 1.050000E+00 BTU/HR.FT.F	BULK TEMP = 9.000000E+01 F					BULK TEMP = 9.000000E+01 F	
RIGHT FILM COEF. H = 5.339611E-01 BTU/HR.FT2.F	LAST MESH K = 1.050000E+00 BTU/HR.FT.F	BULK TEMP = 9.6720920+01 F					BULK TEMP = 9.6720920+01 F	

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.427087D+01 8.365883D+01 8.305049D+01 8.244204D+01 8.183837D+01 8.126361D+01 8.081354D+01 8.078555D+01 8.181306D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TO:AL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.767553D+03 -7.687682D-02 -4.752529D+03 OLIIQUID -7.453488D+02 -2.070115E-02 -1.073946D+03  
 LEFT FILM COEF .H = 4.350388E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT BULK TEMP = 4.672092E+01 F  
 RIGHT FILM COEF .H = 3.908610E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.864472D+01 8.679312D+01 8.540841D+01 8.402953D+01 8.265475D+01 8.128231D+01 8.124021D+01 8.138970D+01 8.159356D+01  
 8.180955D+01 8.202774D+01 8.224618D+01 8.246435D+01 8.268199D+01 8.372556D+01 8.476914D+01 8.584277D+01 8.685646D+01  
 8.757910D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0 -5.796244D-01 0 -3.105689D+04  
 1 0 0 0  
 2 0 0 0  
 3 0 -1.497523D+00 0 -6.216907D+04  
 4 0 0 0

COMP. P R E S S U R E (PSIA) T E M P E R A T U R E (F) E N E R G Y (BTU) C O N V E R G E N C E  
 NO. TOTAL STEAM ATMOS POOL TOTAL DE/E  
 1 1.47000D+01 0. 7.34000D+01 0. 0. 0.  
 3 1.47001D+01 1.63042D-01 9.67225D+01 3.90622D+05 0. 3.90622D+05 2.75994D-06

AIR MASS W A T E R M A S S ( L B M ) H U M I D I T Y C O N D E N S A T I O N ( L B / S ) T R A N S F E R C O E F F I C I E N T S  
 ( L B M ) V A P O R -- A T M O S -- L I Q U I D P O O L P O O L P O O L M A S S H E A T  
 1 0. 0. 0. 0. 6.00000D-01 0. 0.  
 3 3.81489D+03 2.65929D+01 0. 2.65929D+01 1.89422D-01 0. 0.  
 COMP. 3 LEAKAGE OUTFLOW MASS = 1.6644D+01 LBM/HR ENERGY BTU/HR = 2.3284D+03 (NORMAL) 2.3284D+03 PENETRATION = 0.  
 STEP AND NET MASS LOSSES LBM STEP VAPOR = 3.2005D-06 STEP AIR = 4.5914D-04 NET VAPOR = 1.1634D+00 NET AIR = 1.6693D+02 )  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR (LBM) = 1.669274D+02 WATER VAPOR (LBM) = 1.163418D+00

\*\*\*\*\* TIME = 1.583333E+00 HR = 9.50000E+01 MIN = 5.70000E+03 SEC \*\*\*\*\*  
 HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -1.153843D+03 -3.205115D-02 -1.636264D+03 3 VAPOR -2.279936D+03 -6.333184D-02 -4.263011D+03  
 LEFT FILM COEF .H = 2.000000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT BULK TEMP = 9.332500E+01 F  
 RIGHT FILM COEF .H = 4.228550E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT F BULK TEMP = 9.691632D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.538171D+01 8.504318D+01 8.473869D+01 8.444533D+01 8.415530D+01 8.386868D+01 8.359649D+01 8.338485D+01 8.337480D+01  
 8.449484D+01 8.561711D+01 8.674321E+01 8.787475D+01 8.949271D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -9.611428D+03 -2.669849D-01 -1.579400D+04 OLIIQUID -4.298598D+03 -1.194055D-01 -6.806116D+03  
 LEFT FILM COEF .H = 4.755260E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT BULK TEMP = 9.691632E+01 F  
 RIGHT FILM COEF .H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.066834D+01 8.601366D+01 8.538848D+01 8.562527D+01 8.587495D+01 8.614020D+01 8.642490D+01 8.672454D+01 8.703458D+01  
 8.735047D+01 8.770827D+01 8.815591D+01 8.861586D+01 8.907711D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQUID -9.665867D+03 -2.684965D-01 -1.556316D+04 3 VAPOR -2.417581D+04 -6.715488D-01 -2.387535D+04



LEFT FILM COEF .H = 4.78500E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF .H = 4.85007E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.691632D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.546467D+01 8.510745D+01 8.508352D+01 8.572496D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -7.324262D+03 -2.034515D-01 -8.517204D+03 OL LIQUID -2.394694D+03 -6.651924D-02 -3.671704D+03  
 LEFT FILM COEF .H = 5.348640E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.691632E+01 F  
 RIGHT FILM COEF .H = 4.578266E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.192104D+01 8.085232D+01 8.084087D+01 8.127189D+01 8.184035D+01 8.244239D+01 8.305050D+01 8.365909D+01 8.427226D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OL LIQUID -2.597084D+03 -7.214118D-02 -3.982022D+03 3 VAPOR -7.943279D+03 -2.205364D-01 -9.237048D+03  
 LEFT FILM COEF .H = 4.578266E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF .H = 5.348640E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.691632E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.427226D+01 8.365909D+01 8.305050D+01 8.244239D+01 8.184035D+01 8.127189D+01 8.084087D+01 8.085232D+01 8.192104D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.694526D+03 -7.484827D-02 -4.980063D+03 OL LIQUID -7.466265D+02 -2.073962D-02 -1.136112D+03  
 LEFT FILM COEF .H = 4.320494E-01 BTU/HR.FT2.F FIRST MESH K = 6.70000E-02 BTU/HR.FT.F BULK TEMP = 9.691632E+01 F  
 RIGHT FILM COEF .H = 3.924287E-01 BTU/HR.FT2.F LAST MESH K = 6.70000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.899882D+01 8.715693D+01 8.568947D+01 8.422742D+01 8.276918D+01 8.131316D+01 8.125263D+01 8.139332D+01 8.159339D+01  
 8.180970D+01 8.202776D+01 8.224616D+01 8.246432D+01 8.268205D+01 8.372671D+01 8.477144D+01 8.581614D+01 8.686095D+01  
 8.758464D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP STEP LIQUID STEP VAPOR NET LIQUID NET VAPOR  
 0 0 -5.793532D-01 0 -3.279538D+04  
 1 0 0 0 0  
 2 0 0 0 0  
 3 0 -1.500812D+00 0 -5.666667D+04  
 4 0 0 0 0

COMP NO	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	E N E R G Y (BTU)	C O N V E R G E N C E (DE/E)
1	1.47000D+01	7.34000D+01	7.34000D+01	0
3	1.63047D-01	9.69179D+01	9.69179D+01	2.76088D-06
AIR MASS (LBM) VAPOR--ATMOS--LIQUID POOL TOTAL (LBM) IRIDIUMITY COMPENSATION MASS (LB MOL/S FT2) HEAT TRANSFER COEFFICIENTS				
1	0	0	0	0
3	3.81355D+03	2.65835D+01	2.65835D+01	0
COMP 3 LEAKAGE OUTFLOW MASS= 1.5754D+01 LBM/HR ENERGY BTU/HR = 2.2047D+03 (NORMAL= 2.2047D+03 PENETRATION= 0 )				
STEP AND NET MASS LOSSES LBM STEP VAPOR= 3.0294D-06 STEP AIR= 4.3459D-04 NET VAPOR= 1.1730D+00 NET AIR= 1.6827D+02				
TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.682673D+02 WATER VAPOR(LBM)= 1.172958D+00				

\*\*\*\*\* TIME = 1.666667E+00 HR = 1.000000E+02 MIN = 6.000000E+03 SEC \*\*\*\*\*  
 HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -1.164004D+03 -3.23339D-02 -1.732844D+03 3 VAPOR -2.219719D+03 -6.165911D-02 -4.450454D+03

89/12/14.

LEFT FILM COEF.  $h = 2.000000E-01$  BTU/HR.FT<sup>2</sup>.F FIRST MESH  $k = 1.050000E+00$  BTU/HR.FT. BULK TEMP =  $9.340000E+01$  F  
 RIGHT FILM COEF.  $h = 4.199513E-01$  BTU/HR.FT<sup>2</sup>.F LAST MESH  $k = 6.700000E-02$  BTU/HR.FT.F BULK TEMP =  $9.710170E+01$  F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.538676D+01 8.504537D+01 8.473943D+01 8.444556D+01 8.415554D+01 8.386967D+01 8.360050D+01 8.339787D+01 8.340554D+01  
 8.460304D+01 8.580263D+01 8.700580D+01 8.821404D+01 8.982420D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -9.439469D+03 -2.622083D-01 -1.658776D+04 OLIQUID -4.298595D+03 -1.194054D-01 -7.164333D+03  
 LEFT FILM COEF.  $h = 4.754463E-01$  BTU/HR.FT<sup>2</sup>.F FIRST MESH  $k = 3.500000E-02$  BTU/HR.FT. BULK TEMP =  $9.710172E+01$  F  
 RIGHT FILM COEF.  $h = 1.000000E+04$  BTU/HR.FT<sup>2</sup>.F LAST MESH  $k = 1.050000E+00$  BTU/HR.FT.F BULK TEMP =  $9.000000D+01$  F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.096449D+01 8.637921D+01 8.574324D+01 8.593361D+01 8.613453D+01 8.635152D+01 8.658739D+01 8.683779D+01 8.709833D+01  
 8.736460D+01 8.771108D+01 8.815631D+01 8.861590D+01 8.907712D+01 8.953849D+01 8.999870D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIQUID -9.629601D+03 -2.674891D-01 -1.636716D+04 3 VAPOR -2.447349D+04 -6.798177D-01 -2.590254D+04  
 LEFT FILM COEF.  $h = 4.785000E-01$  BTU/HR.FT<sup>2</sup>.F FIRST MESH  $k = 1.050000E+00$  BTU/HR.FT. BULK TEMP =  $9.000000E+01$  F  
 RIGHT FILM COEF.  $h = 4.864041E-01$  BTU/HR.FT<sup>2</sup>.F LAST MESH  $k = 1.050000E+00$  BTU/HR.FT.F BULK TEMP =  $9.710172D+01$  F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.548169D+01 8.513474D+01 8.513678D+01 8.580510D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -7.375031D+03 -2.048617D-01 -9.129702D+03 OLIQUID -2.400433D+03 -6.667867D-02 -3.871502D+03  
 LEFT FILM COEF.  $h = 5.356894E-01$  BTU/HR.FT<sup>2</sup>.F FIRST MESH  $k = 1.050000E+00$  BTU/HR.FT. BULK TEMP =  $9.710172E+01$  F  
 RIGHT FILM COEF.  $h = 4.590391E-01$  BTU/HR.FT<sup>2</sup>.F LAST MESH  $k = 1.050000E+00$  BTU/HR.FT.F BULK TEMP =  $9.000000D+01$  F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.202576D+01 8.091910D+01 8.086944D+01 8.128098D+01 8.184263D+01 8.244281D+01 8.305055D+01 8.365941D+01 8.427370D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIQUID -2.603308D+03 -7.231408D-02 -4.198705D+03 3 VAPOR -7.958339D+03 -2.221758D-01 -9.901308D+03  
 LEFT FILM COEF.  $h = 4.596291E-01$  BTU/HR.FT<sup>2</sup>.F FIRST MESH  $k = 1.050000E+00$  BTU/HR.FT. BULK TEMP =  $9.000000E+01$  F  
 RIGHT FILM COEF.  $h = 5.355894E-01$  BTU/HR.FT<sup>2</sup>.F LAST MESH  $k = 1.050000E+00$  BTU/HR.FT.F BULK TEMP =  $9.710172D+01$  F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.427370D+01 8.365941D+01 8.305055D+01 8.244281D+01 8.184263D+01 8.128098D+01 8.086944D+01 8.091914D+01 8.202576D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.628742D+03 -7.302089D-02 -5.201818D+03 OLIQUID -7.478371D+02 -2.077325D-02 -1.198381D+03  
 LEFT FILM COEF.  $h = 4.293026E-01$  BTU/HR.FT<sup>2</sup>.F FIRST MESH  $k = 6.700000E-02$  BTU/HR.FT. BULK TEMP =  $9.710172E+01$  F  
 RIGHT FILM COEF.  $h = 3.939815E-01$  BTU/HR.FT<sup>2</sup>.F LAST MESH  $k = 6.700000E-02$  BTU/HR.FT.F BULK TEMP =  $9.000000D+01$  F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.932809D+01 8.749446D+01 8.595073D+01 8.441203D+01 8.287689D+01 8.134385D+01 8.126562D+01 8.139733D+01 8.159536D+01  
 8.180989D+01 8.202778D+01 8.224615D+01 8.246430D+01 8.268212D+01 8.372792D+01 8.477374D+01 8.581961D+01 8.686555D+01  
 8.759026D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP.	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
0	0.	-5.789939D-01	0.	-3.453292D+04
1	0.	0.	0.	0.
2	0.	0.	0.	0.
3	0.	-1.503744D+00	0.	-7.117358D+04
4	0.	0.	0.	0.

COMP NO.	PRESSURE (PSIA)		TEMPERATURE (F)		ENERGY (BTU)			CONVERGENCE DE/E
	TOTAL	STEAM	ATMOS	POOL	ATMOS	POOL	TOTAL	
1	1.270000+01	0.	7.340000+01	7.340000+01	0.	0.	0.	0.
3	1.470010+01	1.630420-01	9.710330+01	9.710330+01	3.906060+05	0.	3.906060+05	2.761660-06

COMP NO.	ATR MASS (LBM)		WATER MASS (LBM)		TOTAL (LBM)	HUMIDITY	CONDENSATION (LB/S)	TRANSFER COEFFICIENTS MASS HEAT	
	VAPOR	ATMOS	LIQUID	POOL				(LB MOL/S FT2)	(BTU/S FT2 R)
1	0.	0.	0.	0.	0.	6.000000-01	0.	0.	0.
3	3.812280+03	2.657470+01	0.	0.	2.657470+01	1.872320-01	0.	0.	0.

COMP 3 LEAKAGE OUTFLOW MASS = 1.49610+01 LBM/HR ENERGY BTU/HR = 2.09440+03 (NORMAL = 2.09440+03 PENETRATION = 0.)  
 STEP AND NET MASS LBSSES LBM STEP VAPOR = 2.87700-06 STEP AIR = 4.12720-04 NET VAPOR = 1.18180+00 NET AIR = 1.69540+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) = 1.6953760+02 WATER VAPOR(LBM) = 1.1818130+00

\*\*\*\*\* TIME = 1.750000E+00 HR = 1.050000E+02 MIN = 6.300000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
3 VAPOR	-1.1741560+03	-3.2615390-02	-1.8302650+03	3 VAPOR	-2.1654570+03	-6.0151820-02	-4.6331300+03

LEFT FILM COEF .H = 2.000000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.347500E+01 F  
 RIGHT FILM COEF .H = 4.172822E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.7278150+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.5391870+01 8.5047660+01 8.4740220+01 8.4445820+01 8.4155830+01 8.3870800+01 8.3604890+01 8.3411410+01 8.3436050+01  
 8.4705060+01 8.5976050+01 8.7250390+01 8.8529440+01 9.0133130+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
3 VAPOR	-9.2714620+03	-2.5754140-01	-1.7367350+04	OLIQUID	-4.2985910+03	-1.1940530-01	-7.5225490+03

LEFT FILM COEF .H = 4.753704E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT. BULK TEMP = 9.727815E+01 F  
 RIGHT FILM COEF .H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.0000000+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.1249200+01 8.6732770+01 8.6086810+01 8.6231400+01 8.6386220+01 8.6556610+01 8.6745320+01 8.6948150+01 8.7160860+01  
 8.7379180+01 8.7714140+01 8.8156770+01 8.8615950+01 8.9077120+01 8.9538490+01 8.9999870+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
OLIQUID	-9.5904640+03	-2.6640200-01	-1.7168010+04	3 VAPOR	-2.4751930+04	-6.0755240-01	-2.7953730+04

LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.876966E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.7278150+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.5500050+01 8.5163250+01 8.5190080+01 8.5883290+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
3 VAPOR	-7.4220560+03	-2.0616800-01	-9.7462720+03	OLIQUID	-2.4061100+03	-6.6836360-02	-4.0717750+03

LEFT FILM COEF .H = 5.364469E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.727815E+01 F  
 RIGHT FILM COEF .H = 4.602440E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.0000000+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.2127490+01 8.0985880+01 8.0899140+01 8.1290860+01 8.1845220+01 8.2443340+01 8.3050650+01 8.3659780+01 8.4275190+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
OLIQUID	-2.6094650+03	-7.2485100-02	-4.4159050+03	3 VAPOR	-8.0493380+03	-2.2359250-01	-1.0569990+04

LEFT FILM COEF .H = 4.602440E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.364469E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.7278150+01 F

PCC

CONTEMP-LT/02B,30 APRIL 1978, EG&G IDAHO INC CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM  
 COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS  
 89/12/74

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.427519D+01 8.365978D+01 8.305065D+01 8.244334D+01 8.184522D+01 8.129086D+01 8.089914D+01 8.098588D+01 8.312719D+01  
 HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.569526D+03 -7.137600D-02 -5.418369D+03 OL LIQUID -7.489863D+02 -2.080517D-02 -1.260748D+03  
 LEFT FILM COEF .H = 4.267837E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT BULK TEMP = 9.727815E+01 F  
 RIGHT FILM COEF .H = 3.95201E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.963479D+01 8.780803D+01 8.619392D+01 8.458450D+01 8.297842D+01 8.137430D+01 8.127914D+01 8.140171D+01 8.159648D+01  
 8.181013D+01 8.202782D+01 8.224614D+01 8.246428D+01 8.269220D+01 8.372915D+01 8.477613D+01 8.582315D+01 8.687025D+01  
 8.759594D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0 -5.785493D-01 0 3.626825D+04  
 1 0 0 0 0  
 2 0 0 0 0  
 3 0 -1.506382D+00 0 -7.568884D+04  
 4 0 0 0 0

COMP NO	P R E S S U R E (P S I A)	T E M P E R A T U R E (F)	E N E R G Y (BTU)	C O N V E R G E N C E (DE/E)
1	1.470000+01	7.340000+01	0.000000-01	0.000000-01
3	1.470010+01	9.727970+01	3.905990+05	3.905990+05
1	0.000000-01	0.000000-01	0.000000-01	0.000000-01
3	3.811070+03	2.656630+01	2.656630+01	1.862280-01

COMP 3 LEAKAGE OUTFLOW- MASS= 1.4248D+01 LBM/HR ENERGY BTU/HR = 1.9952D+03 (NORMAL= 1.9952D+03 PENETRATION= 0)  
 STEP AND NET MASS LOSSES LBM STEP VAPOR= 2.7398D-06 STEP AIR= 3.9304D-04 NET VAPOR= 1.1902D+00 NET AIR= 1.7075D+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.707458D+02 WATER VAPOR(LBM)= 1.190235D+00

\*\*\*\*\* TIME = 1.833333E+00 HR = 1.100000E+02 MIN = 6.600000E+03 SEC \*\*\*\*\*  
 HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR 1.842980+03 -3.289712D-02 -1.928534D+03 3 VAPOR -2.116585D+03 -5.879425D-02 -4.811513D+03  
 LEFT FILM COEF .H = 2.000000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT BULK TEMP = 9.355000E+01 F  
 RIGHT FILM COEF .H = 4.148331E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT F BULK TEMP = 9.744648D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.539705D+01 8.570020D+01 8.474107D+01 8.444612D+01 8.415617D+01 8.387209D+01 8.360966D+01 8.342542D+01 8.346628D+01  
 8.480441D+01 8.614841D+01 8.747854D+01 8.882307D+01 9.042148D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -9.107646D+03 -2.529909D-01 -1.813312D+04 OL LIQUID -4.298586D+03 -1.194052D-01 -7.880765D+03  
 LEFT FILM COEF .H = 4.752980E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT BULK TEMP = 9.744648E+01 F  
 RIGHT FILM COEF .H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.152315D+01 8.707465D+01 8.641939D+01 8.651982D+01 8.663015D+01 8.675557D+01 8.689875D+01 8.705565D+01 8.722216D+01  
 8.739418D+01 8.771748D+01 8.815730D+01 8.861602D+01 8.907713D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OL LIQUID -9.548553D+03 -2.652378D-01 -1.796549D+04 3 VAPOR -2.501299D+04 -6.948042D-01 -3.002738D+04

CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM  
89/12/14

CONTEMP-LT/02B.30 APRIL 1978. EG&G IDAHO INC.

COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS

LEFT FILM COEF .H = 4.765000E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 9.000000E+01 F  
RIGHT FILM COEF .H = 4.888962E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 9.744648E+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8 551972D+01 8 519289D+01 8 524337D+01 8 595569D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
-7.465726D+03 -2.073811D-01 -1.036662D+04 OLIGUID -2.411725D+03 -6.699235D-02 -4.272518D+03  
3 VAPOR -7.465726D+03 -2.073811D-01 -1.036662D+04  
LEFT FILM COEF .H = 5.371440E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 9.744648E+01 F  
RIGHT FILM COEF .H = 4.514415E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 9.000000E+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8 222646D+01 8 105244D+01 8 092988D+01 8 130153D+01 8 184816D+01 8 244398D+01 8 305079D+01 8 366020D+01 8 427672D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
-2.615557D+03 -7.265427D-02 -4.633614D+03 3 VAPOR -8.096699D+03 -2.249081D-01 -1.124216D+04  
OLIGUID -2.615557D+03 -7.265427D-02 -4.633614D+03  
LEFT FILM COEF .H = 4.614415E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 9.744648E+01 F  
RIGHT FILM COEF .H = 5.371440E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT BULK TEMP = 9.744648E+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8 427672D+01 8 366020D+01 8 305079D+01 8 244398D+01 8 184816D+01 8 130153D+01 8 092988D+01 8 105244D+01 8 222646D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
-2.516252D+03 -6.989611D-02 -5.630237D+03 3 VAPOR -7.500794D+02 -2.083554D-02 -1.323211D+04  
OLIGUID -2.516252D+03 -6.989611D-02 -5.630237D+03  
LEFT FILM COEF .H = 4.244779E-01 BTU/HR FT2 F FIRST MESH K = 6.700000E-02 BTU/HR FT BULK TEMP = 9.744648E+01 F  
RIGHT FILM COEF .H = 3.970452E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT BULK TEMP = 9.000000E+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8 992094D+01 8 809380D+01 8 642066D+01 8 474589D+01 8 307425D+01 8 140446D+01 8 129313D+01 8 140645D+01 8 159775D+01  
8 181041D+01 8 202786D+01 2 224613D+01 8 246427D+01 8 268231D+01 8 373042D+01 8 477856D+01 8 582676D+01 8 687502D+01  
8 760168D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP	STEP	LIQUID	VAPOR	NET LIQUID	NET VAPOR
0	0	0	0	-3.800413D+04	0
1	0	0	0	0	0
2	0	0	0	-8.021163D+04	0
3	0	0	0	0	0
4	0	0	0	0	0

COMP	NO	PRESSURE (PSIA)	TEMPERATURE (F)	ATMOS	POOL	ENERGY (BTU)	TOTAL
1	1	47000+01	734000+01	734000+01	0	0	0
3	1	47001D+01	974481D+01	974481D+01	3.90592D+05	0	3.90592D+05
AIR MASS (LBM)		WATER MASS (LBM)		HUMIDITY (LB/S)		CONDENSATION (LB/S)	
1	0	0	0	0	6.00000D-01	0	0
3	3	80992D+03	2.65582D+01	0	2.65582D+01	1.85275D-01	0
COMP		3 LEAKAGE OUTFLOW MASS		ENERGY BTU/HR		NORMAL - 1.9052D+03 PENETRATION = 0	
STEP AND NET MASS LOSSES		LBM STEP VAPOR = 2.6155D-06		STEP AIR = 3.7520D-04		NET VAPOR = 1.1983D+00	
TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE		15.0 AIR (LBM) = 1.718977D+02		WATER VAPOR (LBM) = 1.198265D+00			

\*\*\*\*\* TIME = 1.916667E+00 HR = 1.150000E+02 MIN = 6.900000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
0 VAPOR -1.194431D+03 -3.317860D-02 -2.027647D+03 3 VAPOR -2.072582D+03 -5.757192D-07 -4.966029D+03

LEFT FILM COEF .H = 2.00000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.362500E+01 F  
 RIGHT FILM COEF .H = 4.125893E-01 BTU/HR.FT2.F LAST MESH K = 2.300000E-02 BTU/HR.FT.F BULK TEMP = 9.760744E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.540229E+01 8.505247E+01 8.474199E+01 8.446450E+01 8.415657E+01 8.387354E+01 8.361478E+01 8.343985E+01 8.345620E+01  
 8.489253E+01 8.629064E+01 8.769169E+01 8.909685E+01 9.063108E+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -8.948198E+03 -2.495618E+01 -1.885420E+04 OLIGUID -4.298579E+03 -1.194050E+01 -8.238980E+03  
 LEFT FILM COEF .H = 4.752288E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT. BULK TEMP = 9.760744E+01 F  
 RIGHT FILM COEF .H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.178697E+01 8.740521E+01 8.674125E+01 8.679908E+01 8.686648E+01 8.704774E+01 8.716030E+01 8.728223E+01  
 8.740954E+01 8.772107E+01 8.815769E+01 8.861610E+01 8.907714E+01 8.953849E+01 8.999987E+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIGUID -9.503976E+03 -2.639995E-01 -1.875936E+04 3 VAPOR -2.525823E+04 -7.016165E-01 -3.212212E+04  
 LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.900121E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.760744E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.554063E+01 8.522359E+01 8.529659E+01 8.603444E+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -7.506367E+03 -2.085100E-01 -1.099048E+04 OLIGUID -2.417281E+03 -6.714666E-02 -4.473727E+03  
 LEFT FILM COEF .H = 5.377872E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.760744E+01 F  
 RIGHT FILM COEF .H = 4.626317E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.232287E+01 8.111876E+01 8.096158E+01 8.131297E+01 8.185145E+01 8.244473E+01 8.305098E+01 8.366067E+01 8.427823E+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIGUID -2.621579E+03 -7.282162E-02 -4.851829E+03 3 VAPOR -8.140775E+03 -2.261324E-01 -1.191935E+04  
 LEFT FILM COEF .H = 4.626317E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.377872E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.760744E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.427829E+01 8.366067E+01 8.305098E+01 8.244473E+01 8.185145E+01 8.131297E+01 8.096158E+01 8.111876E+01 8.232287E+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.468338E+03 -6.856516E-02 -5.837893E+03 OLIGUID -7.511214E+02 -2.086448E-02 -1.385761E+03  
 LEFT FILM COEF .H = 4.223703E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.760744E+01 F  
 RIGHT FILM COEF .H = 3.985572E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.018836E+01 8.837170E+01 8.663238E+01 8.489715E+01 8.316484E+01 8.143429E+01 8.130752E+01 8.141156E+01 8.159918E+01  
 8.181074E+01 8.202792E+01 8.224612E+01 8.246427E+01 8.268243E+01 8.273172E+01 8.478104E+01 8.583041E+01 8.687985E+01  
 8.760746E+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP STEP - LIQUID STEP - VAPOR NET - LIQUID NET - VAPOR  
 0 0 -5.774159E-01 0 -3.973731E+04  
 1 0 0 0  
 2 0 0 0  
 3 0 -1.510958E+03 0 -8.474128E+04  
 4 0 0 0

89/12/14.

COMP NO.	PRESSURE (PSIA)		TEMPERATURE (F)		ENERGY (BTU)		CONVERGENCE DE/E
	TOTAL	STEAM	ATMOS	POOL	ATMOS	POOL	
1	1.470000+01	0.	7.340000+01	7.340000+01	0.	0.	0.
3	1.470010+01	1.630430-01	9.780900+01	9.760900+01	3.905860+05	0.	2.763130-06

COMP NO.	AIR MASS (LBM)	WATER MASS (LBM)		TOTAL	HUMIDITY	CONDENSATION (LB/S)	TRANSFER COEFFICIENTS	
	VAPOR--ATMOS--LIQUID	POOL	ATMOS				HEAT (BTU/S FT2 R)	MASS (LB MOL/S FT2)
1	0.	0.	0.	0.	6.00000E-01	0.	0.	0.
3	3.808820+03	2.655060+01	0.	2.655060+01	1.843690-01	0.	0.	0.

COMP. 3 LEAKAGE OUTFLOW- MASS= 1.30120+01 LBM/HR ENERGY BTU/HR = 1.82310+03 (NORMAL= 1.82310+03 PENETRATION= 0.)  
 STEP AND NET MASS LOSSES LBM STEP VAPOR= 2.50210-06 STEP AIR= 3.58930-04 NET VAPOR= 1.10590+00 NET AIR= 1.73000+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.7299850+02 WATER VAPOR(LBM)= .2059390+00

\*\*\*\*\* TIME = 2.000000E+00 HR = 1.200000E+02 MIN = 7.20000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -1.2045540+03 -3.3459800-02 -2.1276050+03 3 VAPOR -2.0129710+03 -5.6471600-02 -5.1570650+03  
 LEFT FILM COEF. H = 2.000000E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT. BULK TEMP = 9.370000E+01 F  
 RIGHT FILM COEF. H = 4.105365E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT. F BULK TEMP = 9.7761660+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.5407600+01 8.5054990+01 8.4742960+01 8.4446830+01 8.4157040+01 8.3875160+01 8.3620250+01 8.3454640+01 8.3525750+01  
 8.4978840+01 8.6433610+01 8.7891140+01 8.9352530+01 9.0943560+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -8.7932420+03 -2.4425740-01 -1.9524610+04 OLIIQUID 4.2985690+03 -1.1940470-01 -8.5971940+03  
 LEFT FILM COEF. H = 4.751625E-01 BTU/HR FT2 F FIRST MESH K = 3.500000E-02 BTU/HR FT. BULK TEMP = 9.776166E+01 F  
 RIGHT FILM COEF. H = 1.000000E+04 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT. F BULK TEMP = 9.0000000+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.2041180+01 8.7724800+01 8.7052660+01 8.7069390+01 8.7095390+01 8.7135540+01 8.7192390+01 8.7262170+01 8.7341060+01  
 8.7425230+01 8.7724920+01 8.8158570+01 8.8616190+01 8.9077150+01 8.9538490+01 8.9999870+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQUID -9.4568430+03 -2.6269030-01 -1.9549410+04 3 VAPOR -2.5488990+04 -7.0802620-01 -3.4236680+04  
 LEFT FILM COEF. H = 4.785000E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF. H = 4.910525E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT. F BULK TEMP = 9.7761660+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.5562750+01 8.5255270+01 8.5349720+01 8.6107680+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -7.5442530+03 -2.0956240-01 -1.1617600+04 OLIIQUID -2.4227760+03 -6.7299320-02 -4.6753970+03  
 LEFT FILM COEF. H = 5.383816E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT. BULK TEMP = 9.776166E+01 F  
 RIGHT FILM COEF. H = 4.638147E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT. F BULK TEMP = 9.0000000+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.2416900+01 8.1184760+01 8.0994140+01 8.1325170+01 8.1855090+01 8.2445620+01 8.3051220+01 8.3661200+01 8.4279910+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQUID -2.6275400+03 -7.2987190-02 -5.0705420+03 3 VAPOR -8.1818640+03 -2.2727380-01 -1.2599480+04  
 LEFT FILM COEF. H = 4.638147E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF. H = 5.383816E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT. F BULK TEMP = 9.7761660+01 F

PCC

CONTEMPT-LI/028.30 APRIL 1978. EG&G IDAHO INC. CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM 89/12/14

MESH POINT TEMPERATURES (F). LEFT TO RIGHT 8 427991D+01 8 366120D+01 8 305122D+01 8 244562D+01 8 185509D+01 8 132517D+01 8 099414D+01 8 118476D+01 8 241690D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU 3 VAPOR -2.425257D+03 -6.736845D-02 -6.041764D+03 OIL LIQUID -7.521164D+02 -2.089212D-02 -1.448396D+03 LEFT FILM COEF .H = 4.204844E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.776166E+01 F RIGHT FILM COEF .H = 4.000566E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F

MESH POINT TEMPERATURES (F). LEFT TO RIGHT 9 043871D+01 8 862550D+01 8 683041D+01 8 503914D+01 8 325062D+01 8 146376D+01 8 132228D+01 8 141701D+01 8 160078D+01 8 181112D+01 8 202799D+01 8 224612D+01 8 246427D+01 8 268256D+01 8 373304D+01 8 478355D+01 8 583411D+01 8 688474D+01 8 761327D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR 0 0 0 0 -5.767334D-01 0 -4.146855D+04 1 0 0 0 0 0 2 0 0 0 -1.512960D+00 0 -8.927720D+04 3 0 0 0 0 0 4 0 0 0 0 0

Table with columns: COMP NO., PRESSURE (PSIA), TEMPERATURE (F), ATMOSPHERE, ENERGY (BTU), HUMIDITY, CONDENSATION, MASS TRANSFER COEFFICIENTS, CONVERGENCE DE/E. Rows include data for steam, air, and water vapor.

\*\*\*\*\* TIME = 2.083333E+00 HR = 1.250000E+02 MIN = 7.500000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU 0 VAPOR -1.207426D+03 -3.353959D-02 -2.228104D+03 3 VAPOR -1.997321D+03 -5.548179D-02 -5.324968D+03 LEFT FILM COEF .H = 2.000000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.372500E+01 F RIGHT FILM COEF .H = 4.086606E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.790868D+01 F

MESH POINT TEMPERATURES (F). LEFT TO RIGHT 8 541283D+01 8 505759D+01 8 474400D+01 8 344726D+01 8 415757D+01 8 387695D+01 8 362606D+01 8 346975D+01 8 355493D+01 8 506071D+01 8 656810D+01 8 807808D+01 8 959168D+01 9.118039D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU 3 VAPOR -8.642856D+03 -2.400800D-01 -2.035108D+04 OIL LIQUID -4.298559D+03 -1.194044D-01 -8.955408D+03 LEFT FILM COEF .H = 4.750988E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT.F BULK TEMP = 9.790968E+01 F RIGHT FILM COEF .H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F

MESH POINT TEMPERATURES (F). LEFT TO RIGHT 9 228628D+01 8 803375D+01 8 735390D+01 8 733100D+01 8 731707D+01 8 731684D+01 8 733279D+01 8 736129D+01 8 739866D+01 8 744120D+01 8 772903D+01 8 815932D+01 8 861630D+01 8 907716D+01 8 953819D+01 8 999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU OIL LIQUID -9.407271D+03 -2.613133D-01 -2.033544D+04 3 VAPOR -2.570638D+04 -7.140652D-01 -3.636991D+04





LEFT FILM COEF .H = 2.000000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.375000E+01 F  
 RIGHT FILM COEF .H = 4.069486E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.805197D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.541787D+01 8.506025D+01 8.474509D+01 8.444773D+01 8.415818D+01 8.387892D+01 8.363220D+01 8.348515D+01 8.358371D+01  
 8.513851D+01 8.669481D+01 8.825358D+01 8.981574D+01 9.140291D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -8.497083D+03 -2.360308D-01 -2.106521D+04 OLIIQUID -4.298545D+03 -1.194040D-01 -9.313621D+03  
 LEFT FILM COEF .H = 4.750377E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT. BULK TEMP = 9.805197E+01 F  
 RIGHT FILM COEF .H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.252270D+01 8.833240D+01 8.764526D+01 8.758415D+01 8.753171D+01 8.749254D+01 8.746905D+01 8.745773D+01 8.745504D+01  
 8.745741D+01 8.773339D+01 8.816015D+01 8.861642D+01 8.907718D+01 8.953849D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQUID -9.355377D+03 -2.598718D-01 -2.111723D+04 3 VAPOR -2.591146D+04 -7.197618D-01 -3.852074D+04  
 LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.929320E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.805197D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.561036D+01 8.532132D+01 8.545560D+01 8.625002D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -7.612687D+03 -2.114634D-01 -1.288081D+04 OLIIQUID -2.425380D+03 -6.737166D-02 -5.079408D+03  
 LEFT FILM COEF .H = 5.394419E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.805197E+01 F  
 RIGHT FILM COEF .H = 4.645659E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.259845D+01 8.131562D+01 8.106155D+01 8.135176D+01 8.186350D+01 8.244782D+01 8.305190D+01 8.366240D+01 8.428302D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQUID -2.630363D+03 -7.306564D-02 -5.508699D+03 3 VAPOR -8.256081D+03 -2.293354D-01 -1.396944D+04  
 LEFT FILM COEF .H = 4.645659E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.394419E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.805197D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.428302D+01 8.366240D+01 8.305190D+01 8.244782D+01 8.186350D+01 8.135176D+01 8.106155D+01 8.131562D+01 8.259845D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.351727D+03 -6.532590D-02 -6.439625D+03 OLIIQUID -7.504129D+02 -2.084481D-02 -1.573597D+03  
 LEFT FILM COEF .H = 4.170947E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.805197E+01 F  
 RIGHT FILM COEF .H = 4.009047E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.089397D+01 8.908505D+01 8.719005D+01 8.529842D+01 8.340923D+01 8.152154D+01 8.135272D+01 8.142893D+01 8.160448D+01  
 8.181207D+01 8.202819D+01 8.224614D+01 8.246431D+01 8.268282D+01 8.373568D+01 8.478851D+01 8.584139D+01 8.689434D+01  
 8.762372D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP.	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
0	0.	-5.741781D-01	0.	-4.492140D+04
1	0.	0.	0.	0.
2	0.	0.	0.	0.
3	0.	-1.516507D+00	0.	-9.836588D+04
4	0.	0.	0.	0.

COMP NO	PRESSURE (PSIA)		TEMPERATURE (F)		ENERGY (BTU)		CONVERGENCE DE/E
	TOTAL	STEAM	ATMOS	POOL	ATMOS	POOL	
1	1.470000+01	0.	7.340000+01	7.340000+01	0.	0.	0.
3	1.470010+01	1.630430-01	9.805360+01	9.805360+01	3.905670+05	0.	2.763770-06

COMP NO	AIR MASS (LBM)	WATER MASS (LBM)		HUMIDITY		CONDENSATION MASS		TRANSFER COEFFICIENTS HEAT
		VAPOR--ATMOS	LIQUID	POOL	TOTAL	(LB/S)	(LB MOL/S FT2)(BTU/S FT2 R)	
1	0.	0.	0.	0.	0.	6.000000-01	0.	0.
3	3.805780+03	2.652840+01	0.	0.	2.652940+01	1.818930-01	0.	0.

COMP. 3 LEAKAGE OUTFLOW- MASS= 1.151300+01 LBM/HR ENERGY BTU/HR = 1.614300+03 (NORMAL= 1.614300+03 PENETRATION= 0.)  
 STEP AND NET MASS LOSSES LBM STEP VAPOR= 2.213900-06 STEP AIR= 3.175900-04 NET VAPOR= 1.227100+00 NET AIR= 1.760400+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.7603540+02 WATER VAPOR(LBM)= 1.2271080+00

\*\*\*\*\* TIME = 2.250000E+00 HR = 1.350000E+02 MIN = 8.100000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
0 VAPOR	-1.2132500+03	-3.3701370-02	-2.4298260+03	3 VAPOR	-1.9363800+03	-5.3788470-02	-5.6525970+03

LEFT FILM COEF .H = 2.000000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.377500E+01 F  
 RIGHT FILM COEF .H = 4.053877E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.8188970+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.5422740+01 8.5062960+01 8.4746250+01 8.4448250+01 8.4158870+01 8.3881060+01 8.3638650+01 8.3500790+01 8.3612090+01  
 8.5212530+01 8.6814410+01 8.8418610+01 9.0026010+01 9.1612330+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
3 VAPOR	-8.3559370+03	-2.3211000-01	-2.1767390+04	OLIQUID	-4.2985250+03	-1.1940350-01	-9.6718320+03

LEFT FILM COEF .H = 4.749787E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT.F BULK TEMP = 9.818897E+01 F  
 RIGHT FILM COEF .H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.2750870+01 8.8621100+01 8.7927040+01 8.7829080+01 8.7739520+01 8.7662790+01 8.7601260+01 8.7551550+01 8.7510220+01  
 8.7473840+01 8.7737990+01 8.8161070+01 8.8616560+01 8.9077190+01 8.9538490+01 8.9999870+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
OLIQUID	-9.3012780+03	-2.5836910-01	-2.1894600+04	3 VAPOR	-2.6105110+04	-7.2514090-01	-4.0688170+04

LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.937844E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.8188970+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.5635740+01 8.5355570+01 8.5508330+01 8.6319320+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
3 VAPOR	-7.6436260+03	-2.1232280-01	-1.3516500+04	OLIQUID	-2.4267270+03	-6.7409080-02	-5.2815790+03

LEFT FILM COEF .H = 5.399152E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.818897E+01 F  
 RIGHT FILM COEF .H = 4.649422E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.2686240+01 8.1380420+01 8.1096260+01 8.1366100+01 8.1868280+01 8.2449150+01 8.3052340+01 8.3663060+01 8.4284480+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
OLIQUID	-2.6318240+03	-7.3106230-02	-0.7279570+03	3 VAPOR	-8.2896350+03	-2.3026750-01	-1.4658860+04

LEFT FILM COEF .H = 4.649422E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.399152E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.8188970+01 F

PCC

MESH POINT TEMPERATURES (F), LEFT TO RIGHT

8.428448D+01 8.366306D+01 8.305234D+01 8.244915D+01 8.186828D+01 8.136610D+01 8.109626D+01 8.138042D+01 8.268624D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU

3 VAPOR -2.320455D+03 -6.445723D-02 -6.634274E+03

LEFT FILM COEF .H = 4.156412E-01 BTU/HR.FT2.F FIRST MESH K = 5.700000E-02 BTU/HR.FT.F BULK TEMP = 9.818897E+01 F

RIGHT FILM COEF .H = 2.013409E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.110145D+01 8.929353D+01 8.735372D+01 8.541708D+01 8.348274D+01 8.154983D+01 8.136832D+01 8.123536D+01 8.163659D+01

8.181264D+01 8.202834D+01 8.224615D+01 8.246433D+01 8.268305D+01 8.373694D+01 8.479084D+01 8.584480D+01 8.689842D+01

8.762832D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT SURFACES - UNITS ARE BTU

COMP STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR

0 0 -5.728163D-01 0 -4.561190D+04

1 0 0 0

2 0 0 0

3 0 -1.518087D+00 0 -1.021178D+05

4 0 0 0

COMP P R E S S U R E (PSIA) T E M P E R A T U R E (F) A T M O S P H E R E (LB/S) H U M I D I T Y C O M P E N S A T I O N M A S S (LB/S) T R A N S F E R C O E F F I C I E N T S

1 1.47000D+01 7.34000D+01 7.34000D+01 0.00000D+00 0.00000D+00 0.00000D+00 0.00000D+00 2.76386D-06

3 1.47001D+01 1.63043D-01 9.81906D+01 9.81906D+01 3.90562D+05 0.00000D+00 3.90562D+05 0.00000D+00 2.76386D-06

1 0.00000D+00 0.00000D+00 0.00000D+00 0.00000D+00 0.00000D+00 0.00000D+00 0.00000D+00 0.00000D+00 0.00000D+00

3 3.80485D+03 2.65229D+01 1.1087D+01 1.1087D+01 2.65229D+01 1.81137D-01 1.81137D-01 0.00000D+00 0.00000D+00

COMP 3 LEAKAGE OUTFLOW MASS= 1.1087D+01 LBM/HR ENERGY BTU/HR = 1.5549D+03 (NORMAL = 1.5549D+03 PENETRATION= 0.0)

STEP AND NET MASS LOSSES LBM STEP VAPOR= 2.1319D-06 STEP AIR= 3.0584D-04 NET VAPOR= 1.2336D+00 NET AIR= 1.7697D+02

TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.7697D+02 WATER VAPOR(LBM)= 1.2336D+00

AIR MASS (LBM) VAPOR-ATMOS--LIQUID M A S S P O O L (LB/S) H U M I D I T Y C O M P E N S A T I O N M A S S (LB/S) T R A N S F E R C O E F F I C I E N T S

1 0.00000D+00 0.00000D+00 0.00000D+00 0.00000D+00 0.00000D+00 0.00000D+00 0.00000D+00 0.00000D+00 0.00000D+00

3 3.80485D+03 2.65229D+01 1.1087D+01 1.1087D+01 2.65229D+01 1.81137D-01 1.81137D-01 0.00000D+00 0.00000D+00

1 0.00000D+00 0.00000D+00 0.00000D+00 0.00000D+00 0.00000D+00 0.00000D+00 0.00000D+00 0.00000D+00 0.00000D+00

3 3.80485D+03 2.65229D+01 1.1087D+01 1.1087D+01 2.65229D+01 1.81137D-01 1.81137D-01 0.00000D+00 0.00000D+00

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -1.216194D+03 -3.378316D-02 -2.511052D+03  
 LEFT FILM COEF .H = 2.000000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.380000E+01 F  
 RIGHT FILM COEF .H = 4.039661E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.832104D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.542747D+01 8.506569D+01 8.474746D+01 8.448882D+01 8.415955D+01 8.388339D+01 8.364541D+01 8.351663D+01 8.364007D+01  
 8.528308D+01 8.692747D+01 8.857405D+01 9.022365D+01 9.180973D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -8.219404D+03 -2.283174D-01 -2.245800D+04  
 LEFT FILM COEF .H = 4.749220E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT.F BULK TEMP = 9.832104E+01 F  
 RIGHT FILM COEF .H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.030000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.297117D+01 8.890037D+01 8.819954D+01 8.806605D+01 8.794070D+01 8.782776D+01 8.772955D+01 8.764280D+01 8.756421D+01  
 8.749046D+01 8.774283D+01 8.816208D+01 8.861673D+01 8.907722D+01 8.953850D+01 8.999870D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 LIQUID -9.245091D+03 -2.568083D-01 -2.266734D+04  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.628813D+04 -7.302249D-01 -4.287129D+04



CONTEMP-LT/028.30 APRIL 1978. EG&G IDAHO INC. CONTAINMENT SYSTEM PRESSURE - TEMPERATURE HISTORY PROGRAM  
COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS 89/12/14.

LEFT FILM COEF .H = 2.00000E-01 BTU/HR FT2 F FIRST MESH K = 1.05000E+00 BTU/HR FT. BULK TEMP = 9.302500E+01 F  
RIGHT FILM COEF .H = 4.026727E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT. F BULK TEMP = 9.844854D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.543208D+01 8.506844D+01 8.474872D+01 8.444944D+01 8.416051D+01 8.388390D+01 8.365245D+01 8.353266D+01 8.366763D+01  
8.535042D+01 8.703452D+01 8.872070D+01 9.040973D+01 9.199612D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -8.087449D+03 -2.246520D-01 -2.313742D+04 OLIIQID -4.298476D+03 -1.194021D-01 -1.038825D+04  
LEFT FILM COEF .H = 4.748671E-01 BTU/HR FT2 F FIRST MESH K = 3.500000E-02 BTU/HR FT. BULK TEMP = 9.844854E+01 F  
RIGHT FILM COEF .H = 1.000000E+04 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT. F BULK TEMP = 9.000000E+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
9.318394D+01 8.916994D+01 8.846305D+01 8.829532D+01 8.813545D+01 8.798760D+01 8.785401D+01 8.773155D+01 8.761703D+01  
8.750724D+01 8.774791D+01 8.816218D+01 8.861691D+01 8.907724D+01 8.953850D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -9.186929D+03 -2.551327D-01 -1.479522D+04 OLIIQID -2.646124D+04 -7.350337D-01 -4.506925D+04  
LEFT FILM COEF .H = 4.750000E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT. BULK TEMP = 9.000000E+01 F  
RIGHT FILM COEF .H = 4.953325E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT. F BULK TEMP = 9.844854D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.568940D+01 8.542624D+01 8.561331D+01 8.645456D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -7.659776D+03 -2.138825D-01 -1.479522D+04 OLIIQID -2.429480D+03 -6.748556D-02 -5.686262D+03  
LEFT FILM COEF .H = 5.407636E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT. BULK TEMP = 9.844854E+01 F  
RIGHT FILM COEF .H = 4.656952E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT. F BULK TEMP = 9.000000E+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.285643D+01 8.150861D+01 8.116738D+01 8.138678D+01 8.187901D+01 8.245231D+01 8.305344D+01 8.366448D+01 8.428724D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
OLIIQID -2.634810D+03 -7.318917D-02 -6.166842D+03 3 VAPOR -8.350530D+03 -2.319590D-01 -1.604565D+04  
LEFT FILM COEF .H = 4.656952E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT. BULK TEMP = 9.000000E+01 F  
RIGHT FILM COEF .H = 5.407636E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT. F BULK TEMP = 9.844854D+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
8.428724D+01 8.366448D+01 8.305344D+01 8.245231D+01 8.187901D+01 8.138678D+01 8.116738D+01 8.150861D+01 8.285643D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -2.267144D+03 -6.297635D-02 -7.016417D+03 OLIIQID -7.487721D+02 -2.079923D-02 -1.760979D+03  
LEFT FILM COEF .H = 4.131205E-01 BTU/HR FT2 F FIRST MESH K = 6.700000E-02 BTU/HR FT. BULK TEMP = 9.844854E+01 F  
RIGHT FILM COEF .H = 4.022282E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT. F BULK TEMP = 9.000000E+01 F  
MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
9.148161D+01 8.967386D+01 8.765321D+01 8.563539D+01 8.361962D+01 8.160516D+01 8.140011D+01 8.144911D+01 8.161135D+01  
8.181400D+01 8.201863D+01 8.224621D+01 8.246442D+01 8.268343D+01 8.373928D+01 8.479515D+01 8.585106D+01 8.690703D+01  
8.763671D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
0 0 -5.699342D-01 0  
1 0 0 0  
2 0 0 0  
3 0 -1.520923D+00 0  
4 0 -1.120350D+05 0

COMP NO. P R E S S U R E (PSIA) T E M P E R A T U R E (F) A T M O S P O O L E N E R G Y (BTU) T O T A L C O N V E R G E N C E D E / E

1 1.47000D+01 0. 7.34000D+01 7.34000D+01 0. 0. 0. 0. 2.76390D-06

3 1.47001D+01 1.63044D-01 9.84501D+01 9.84501D+01 3.90551D+05 0. 3.90551D+05

AIR MASS (LBM) W A T E R M A S S (LBM) H U M I D I T Y C O N D E N S A T I O N (LB/S) T R A N S F E R C O E F F I C I E N T S M A S S H E A T

1 0. 0. 0. 0. 6.00000D-01 0. 0.

3 3.80308D+03 2.65105D+01 0. 2.65105D+01 1.79715D-01 0. 0.

COMP 3 LEAKAGE DUTIFLOW MASS = 1.0322D+01 LBM/HR ENERGY BTU/HR = 1.4482D+03 NORMAL = 1.4482D+03 PENETRATION = 0.

STEP AND NET MASS LOSSES LBM STEP VAPOR = 1.9848D-06 STEP AIR = 2.8472D-04 NET VAPOR = 1.2460D+00 NET AIR = 1.7874D+02

TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) = 1.7874D+02 WATER VAPOR(LBM) = 1.245964D+00

\*\*\*\*\* TIME = 2.50000E+00 HR = 1.50000E+02 MIN = 9.00000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL

TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU

0 VAPOR -1.22213D+03 -3.39481D-02 -2.734245D+03 3 VAPOR -1.856107D+03 -5.183639D-02 -6.127441D+03

LEFT FILM COEF .H = 2.00000E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.38500E+01 F

RIGHT FILM COEF .H = 4.014972E-01 BTU/HR.FT2.F LAST MESH K = 6.70000E-02 BTU/HR.FT.F BULK TEMP = 9.857176D+01 F

MESH POINT TEMPERATURES (F), LEFT TO RIGHT

8.543658D+01 8.507124D+01 8.475004D+01 8.445013D+01 8.416146D+01 8.388859D+01 8.365977D+01 8.354883D+01 8.369479D+01

8.544479D+01 8.713605D+01 8.885928D+01 9.058521D+01 9.217239D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 DOOF & CEILING

TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU

3 VAPOR -7.960027D+03 -2.21124D-01 -2.380603D+04 0 LIQUID -4.258442D+03 -1.194012D-01 -1.074645D+04

LEFT FILM COEF .H = 4.748141E-01 BTU/HR.FT2.F FIRST MESH K = 3.50000E-02 BTU/HR.FT. BULK TEMP = 9.857176E+01 F

RIGHT FILM COEF .H = 1.00000E+04 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.00000E+01 F

MESH POINT TEMPERATURES (F), LEFT TO RIGHT

9.338954D+01 8.943074D+01 8.871787D+01 8.851711D+01 8.832397D+01 8.814246D+01 8.797477D+01 8.781787D+01 8.766869D+01

8.752415D+01 8.775321D+01 8.816437D+01 8.861712D+01 8.907727D+01 8.953850D+01 8.99987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 3 AND 0 FLOOR

TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU

0 LIQUID -9.126902D+03 -2.53253D-01 -2.419849D+04 3 VAPOR -2.662511D+04 -7.395856D-01 -4.728124D+04

LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.00000E+01 F

RIGHT FILM COEF .H = 4.960370E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.857176D+01 F

MESH POINT TEMPERATURES (F), LEFT TO RIGHT

8.571756D+01 8.546257D+01 8.566555D+01 8.652065D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL

TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU

3 VAPOR -7.725268D+03 -2.145907D-01 -1.543794D+04 0 LIQUID -2.430876D+03 -6.752434D-02 -5.888777D+03

LEFT FILM COEF .H = 5.411439E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.857176E+01 F

RIGHT FILM COEF .H = 4.660716E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.00000E+01 F

MESH POINT TEMPERATURES (F), LEFT TO RIGHT

8.293903D+01 8.157198D+01 8.120367D+01 8.141307D+01 8.188496D+01 8.245416D+01 8.305411D+01 8.366523D+01 8.428858D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL

TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU

0 LIQUID -2.636324D+03 -7.323122D-02 -6.386472D+03 3 VAPOR -8.378176D+03 -2.327270D-01 -1.674270D+04

LEFT FILM COEF .H = 4.660716E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.00000E+01 F

RIGHT FILM COEF .H = 5.411439E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.857176D+01 F





LEFT FILM COEF.  $h = 4.785000E-01$  BTU/HR.FT<sup>2</sup>.F FIRST MESH  $K = 1.050000E+00$  BTU/HR.FT. BULK TEMP =  $9.000000E+01$  F  
 RIGHT FILM COEF.  $h = 4.966996E-01$  BTU/HR.FT<sup>2</sup>.F LAST MESH  $K = 1.050000E+00$  BTU/HR.FT.F BULK TEMP =  $9.869100D+01$  F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 $8.574635D+01$   $8.549949D+01$   $8.571763D+01$   $8.658580D+01$

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -7.749204D+03 -2.152556D-01 -1.608272D+04 OLIQUID -2.432280D+03 -6.756332D-02 -6.091408D+03  
 LEFT FILM COEF.  $h = 5.414979E-01$  BTU/HR.FT<sup>2</sup>.F FIRST MESH  $K = 1.050000E+00$  BTU/HR.FT. BULK TEMP =  $9.869100E+01$  F  
 RIGHT FILM COEF.  $h = 4.664477E-01$  BTU/HR.FT<sup>2</sup>.F LAST MESH  $K = 1.050000E+00$  BTU/HR.FT.F BULK TEMP =  $9.000000D+01$  F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 $8.302008D+01$   $8.163485D+01$   $8.124038D+01$   $8.142995D+01$   $8.109131D+01$   $8.245620D+01$   $8.305486D+01$   $8.366602D+01$   $8.428989D+01$

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIQUID -2.637846D+03 -7.327351D-02 -6.606229D+03 3 VAPOR -8.404136D+03 -2.334481D-01 -1.744197D+04  
 LEFT FILM COEF.  $h = 4.664477E-01$  BTU/HR.FT<sup>2</sup>.F FIRST MESH  $K = 1.050000E+00$  BTU/HR.FT. BULK TEMP =  $9.000000E+01$  F  
 RIGHT FILM COEF.  $h = 5.414979E-01$  BTU/HR.FT<sup>2</sup>.F LAST MESH  $K = 1.050000E+00$  BTU/HR.FT.F BULK TEMP =  $9.869100D+01$  F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 $8.428989D+01$   $8.366602D+01$   $8.305486D+01$   $8.245620D+01$   $8.189131D+01$   $8.142995D+01$   $8.124038D+01$   $8.163485D+01$   $8.302008D+01$

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.224206D+03 -6.178358D-02 -7.390567D+03 OLIQUID -7.480586D+02 -2.077941D-02 -1.885711D+03  
 LEFT FILM COEF.  $h = 4.110462E-01$  BTU/HR.FT<sup>2</sup>.F FIRST MESH  $K = 6.700000E-02$  BTU/HR.FT. BULK TEMP =  $9.869100E+01$  F  
 RIGHT FILM COEF.  $h = 4.031302E-01$  BTU/HR.FT<sup>2</sup>.F LAST MESH  $K = 6.700000E-02$  BTU/HR.FT.F BULK TEMP =  $9.000000D+01$  F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 $9.182152D+01$   $9.001196D+01$   $8.792056D+01$   $8.583169D+01$   $8.374468D+01$   $8.165886D+01$   $8.143248D+01$   $8.146395D+01$   $8.161681D+01$   
 $8.181568D+01$   $8.202906D+01$   $8.224631D+01$   $8.246454D+01$   $8.268382D+01$   $8.374141D+01$   $8.479902D+01$   $8.585666D+01$   $8.691436D+01$   
 $8.7E4425D+01$

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP.	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
0	0.	-5.668566D-01	0.	-5.348072D+04
1	0.	0.	0.	0.
2	0.	0.	0.	0.
3	0.	-1.523394D+00	0.	-1.211682D+05
4	0.	0.	0.	0.

COMP. NO.	PRESSURE (PSIA)		TEMPERATURE (F)			ENERGY (BTU)		CONVERGENCE DE/E
	TOTAL	STEAM	ATMOS	POOL	ATMOS	POOL	TOTAL	
1	1.47000D+01	0.	7.34000D+01	7.34000D+01	0.	0.	0.	2.76379D-06
3	1.47001D+01	1.63044D-01	9.86926D+01	9.86926D+01	3.90541D+05	0.	3.90541D+05	TRANSFER COEFFICIENTS
	AIR MASS (LBM)	WATER VAPOR--ATMOS--LIQUID	MASS (LBM)		HUMIDITY	CONDENSATION (LB/S)	MASS HEAT (LB MOL/S FT2)(BTU/S FT2 R)	
1	0.	0.	0.	0.	0.	0.	0.	0.
3	3.80143D+03	2.64990D+01	0.	0.	2.64990D+01	1.78398D-01	0.	0.

COMP. 3 LEAKAGE OUTFLOW- MASS= 9.6550D+00 LBM/HR ENERGY BTU/HR = 1.3553D+03 (NORMAL= 1.3553D+03 PENETRATION= 0.)  
 STEP AND NET MASS LOSSES LBM STEP VAPOR= 1.8566D-06 STEP AIR= 2.6634D-04 NET VAPOR= 1.2575D+00 NET AIR= 1.8039D+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.803924D+02 WATER VAPOR(LBM)= 1.257480D+00

\*\*\*\*\* TIME = 2.666667E+00 HR = 1.600000E+02 MIN = 9.600000E+03 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -1.228123D+03 -3.411451D-02 -2.938433D+03 3 VAPOR -1.830350D+03 -5.084312D-02 -6.435372D+03

PCC

LEFT FILM COEF. H = 2.000000E-01 BTU/HR.FT<sup>2</sup>.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.390000E+01 F  
 RIGHT FILM COEF. H = 3.994621E-01 BTU/HR.FT<sup>2</sup>.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.880649D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.544350+01 8.507684+01 8.475283+01 8.445167+01 8.416365+01 8.389452+01 8.367517+01 8.358151+01 8.374790+01  
 8.853551+01 8.732427+01 8.911482+01 9.090780+01 9.249775+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -7.718507D+03 -2.144035D-01 -2.511233D+04 OLIIQUID -4.298355D+03 -1.193988D-01 -1.146285D+04  
 LEFT FILM COEF. H = 4.747132E-01 BTU/HR.FT<sup>2</sup>.F FIRST MESH K = 3.500000E-02 BTU/HR.FT. BULK TEMP = 9.860649E+01 F  
 RIGHT FILM COEF. H = 1.000000E+04 BTU/HR.FT<sup>2</sup>.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.378043D+01 8.992663D+01 8.920256D+01 8.893929D+01 8.868314D+01 8.843788D+01 8.820560D+01 8.798348D+01 8.776866D+01  
 8.755827D+01 8.776446D+01 8.816703D+01 8.861761D+01 8.907735D+01 8.953851D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQUID -9.001682D+03 -2.500470E-01 -2.570929D+04 3 VAPOR -2.652742D+04 -7.479934D-01 -5.174441D+04  
 LEFT FILM COEF. H = 4.785000E-01 BTU/HR.FT<sup>2</sup>.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF. H = 4.973233E-01 BTU/HR.FT<sup>2</sup>.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.880649D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.577632D+01 8.553697D+01 8.576954D+01 8.665007D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -7.771695D+03 -2.158803D-01 -1.672944D+04 OLIIQUID -2.433688D+03 -6.760243D-02 -6.294157D+03  
 LEFT FILM COEF. H = 5.418278E-01 BTU/HR.FT<sup>2</sup>.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.880649E+01 F  
 RIGHT FILM COEF. H = 4.668235E-01 BTU/HR.FT<sup>2</sup>.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.309966D+01 8.169721D+01 8.127748D+01 8.144741D+01 8.189805D+01 8.245843D+01 8.305569D+01 8.366684D+01 8.429118D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQUID -2.639373D+03 -7.331592D-02 -6.826114D+03 3 VAPOR -8.428528D+03 -2.341257D-01 -1.814334D+04  
 LEFT FILM COEF. H = 4.668235E-01 BTU/HR.FT<sup>2</sup>.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF. H = 5.418278E-01 BTU/HR.FT<sup>2</sup>.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.880649D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.429118D+01 8.366684D+01 8.305569D+01 8.245843D+01 8.189805D+01 8.144741D+01 8.127748D+01 8.169721D+01 8.309966D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.206007D+03 -6.127805D-02 -7.575145D+03 OLIIQUID -7.477895D+02 -2.077194D-02 -1.948038D+03  
 LEFT FILM COEF. H = 4.101535E-01 BTU/HR.FT<sup>2</sup>.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.880649E+01 F  
 RIGHT FILM COEF. H = 4.035854E-01 BTU/HR.FT<sup>2</sup>.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.197839D+01 9.016732D+01 8.804379D+01 8.592267D+01 8.380331D+01 8.168511D+01 8.144882D+01 8.147174D+01 8.161981D+01  
 8.181664D+01 8.202932D+01 8.224638D+01 8.246461D+01 8.268403D+01 8.374241D+01 8.480082D+01 8.585923D+01 8.691774D+01  
 8.764775D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0 0 -5.652506D-01 0  
 1 0 0 0 0  
 2 0 0 -1.524514D+00 0  
 3 0 0 -1.257400D+05 0  
 4 0 0 0 0

COMP NO	PRESSURE (PSIA)	TEMPERATURE (F)	ATMOS	ENRUY	CONVERGENCE
1	1.47000+01	7.34000+01	0.0	0.0	0.0
3	1.47001+01	7.34000+01	0.0	0.0	0.0
	1.63044D-01	9.88081D+01	3.90537D+05	3.90537D+05	2.76370D-06

AIR MASS (LBM) VAPOR--ATMOS--LIQUID M A S S (LBM) HUMIDITY CONDENSATION (LB/S) TRANSFER COEFFICIENTS MASS HEAT  
 1 0 0 0 0 0 0 0 0 0 0 0  
 3 80064D+03 2.64935D+01 0.0 2.64935D+01 1.77774D-01 0.0  
 COMP 3 LEAKAGE OUTFLOW MASS= 9.3532D+00 LBM/HR ENERGY BTU/HR = 1.3132D+03 PENETRATION= 0.0  
 STEP AND NET MASS LOSSES LBM STEP VAPOR= 1.7986D-06 STEP AIR= 2.5801D-04 NET VAPOR= 1.2630D+00 NET AIR= 1.8118D+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.811788D+02 WATER VAPOR(LBM)= 1.262961D+00

\*\*\* TIME = 2.75000E+00 HR = 1.65000E+02 MIN = 9.90000E+03 SEC \*\*\*  
 HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -1.231133D+03 -3.419812D-02 -3.040902D+03 3 VAPOR -1.815177D+03 -5.042166D-02 -6.587258D+03  
 LEFT FILM COEF. H = 2.00000E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.392500E+01 F  
 RIGHT FILM COEF. H = 3.985852E-01 BTU/HR.FT2.F LAST MESH K = 6.70000E-02 BTU/HR.FT.F BULK TEMP = 9.891848D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.544963D+01 8.507966D+01 8.475430D+01 8.445253D+01 8.416489D+01 8.39775D+01 8.368323D+01 8.359798E+01 8.377386D+01  
 8.559224D+01 8.741173D+01 8.923292D+01 9.105641D+01 9.264827D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -7.604249D+03 -2.112297D-01 -2.575375D+04 OL LIQUID -4.298298D+03 -1.193972D-01 -1.182105D+04  
 LEFT FILM COEF. H = 4.746651E-01 BTU/HR.FT2.F FIRST MESH K = 3.50000E-02 BTU/HR.FT.F BULK TEMP = 9.891848E+01 F  
 RIGHT FILM COEF. H = 1.00000E+04 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.00000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.396632D+01 9.016234D+01 8.943301D+01 8.914014D+01 8.885417D+01 8.857874D+01 8.831589D+01 8.806290D+01 8.781700D+01  
 8.757544D+01 8.777040D+01 8.816850D+01 8.861790D+01 8.907739D+01 8.953852D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OL LIQUID -8.936691D+03 -2.482417D-01 -2.645674D+04 3 VAPOR -2.706691D+04 -7.518579D-01 -5.399422D+04  
 LEFT FILM COEF. H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF. H = 4.97917E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.891848D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.580681D+01 8.557497D+01 8.582129D+01 8.671350D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -7.792842D+03 -2.164677D-01 -1.737797D+04 OL LIQUID -2.425097D+03 -6.764158D-02 -6.497023D+03  
 LEFT FILM COEF. H = 5.421951E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.891848E+01 F  
 RIGHT FILM COEF. H = 4.671988E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.00000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.317784D+01 8.175906D+01 8.131490D+01 8.146542D+01 8.190518D+01 8.246085D+01 8.305661D+01 8.366769D+01 8.429246D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OL LIQUID -2.640902D+03 -7.335837D-02 -7.046125D+03 3 VAPOR -8.451462D+03 -2.347627D-01 -1.884668D+04  
 LEFT FILM COEF. H = 4.671988E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF. H = 5.421951E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.891848D+01 F

CONTEMT-LT/02B.30 APRIL 1978. EG&G IDAHO INC. CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM 89/12/14.

MESH POINT TEMPERATURES (°C). LEFT TO RIGHT 8.429246D+01 8.366769D+01 8.305661D+01 8.246086D+01 8.190518D+01 8.146542D+01 8.131490D+01 8.175906D+01 8.317784D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU 3 VAPOR -2.189708D+03 -6.082530D-02 -7.758287D+03 LEFT FILM COEF .H = 4.093461E-01 BTU/HR FT2 F FIRST MESH K = 6.700000E-02 BTU/HR FT2 F BULK TEMP = 9.891848E+01 F RIGHT FILM COEF .H = 4.040428E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT2 F BULK TEMP = 9.000000D+01 F MESH POINT TEMPERATURES (°F). LEFT TO RIGHT 9.212746D+01 9.031453D+01 8.816081D+01 8.600936D+01 8.385961D+01 8.171056D+01 8.146523D+01 8.147976D+01 8.162297D+01 8.181768D+01 8.202962D+01 8.224646D+01 8.246469D+01 8.268424D+01 8.374338D+01 8.480253D+01 8.586172D+01 8.692096D+01 8.765110D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR 0 0 -5.636028D-01 0 -5.687218D+04 1 0 0 0 0 0 2 0 0 -1.525565D+00 0 -1.303152D+05 3 0 0 0 0 0 4 0 0 0 0 0

Table with columns: COMP NO, PRESSURE (PSIA), TEMPERATURE (°F), ATMOSPHERE (LBM), MASS (LBM), HUMIDITY (LB M/L S FT2), CONDENSATION (LB/S), TRANSFER COEFFICIENTS, CONVERGENCE DE/E. Rows include data for compartments 1, 2, and 3.

\*\*\*\*\* TIME = 2.833333E+00 HR = 1.700000E+02 MIN = 1.020000E+04 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU 3 VAPOR -1.234151D+03 -3.428195D-02 -3.143622D+03 LEFT FILM COEF .H = 2.000000E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT2 F BULK TEMP = 9.395000E+01 F RIGHT FILM COEF .H = 3.977918E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT2 F BULK TEMP = 9.902717D+01 F MESH POINT TEMPERATURES (°F). LEFT TO RIGHT 8.545385D+01 8.508248D+01 8.475581D+01 8.445345D+01 8.416624D+01 8.380117D+01 8.369151D+01 8.361451D+01 8.379944D+01 8.564679D+01 8.749520D+01 8.934525D+01 9.115748D+01 9.279152D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU 3 VAPOR -7.494207D+03 -2.081729D-01 -2.637983D+04 LEFT FILM COEF .H = 4.746183E-01 BTU/HR FT2 F FIRST MESH K = 3.500000E-02 BTU/HR FT2 F BULK TEMP = 9.902717E+01 F RIGHT FILM COEF .H = 1.000000E+04 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT2 F BULK TEMP = 9.000000D+01 F MESH POINT TEMPERATURES (°F). LEFT TO RIGHT 9.414619D+01 9.039027D+01 8.965588D+01 8.933449D+01 8.901976D+01 8.871525D+01 8.842291D+01 8.814015D+01 8.786429D+01 8.759267D+01 8.777653D+01 8.817008D+01 8.861821D+01 8.907744D+01 8.953853D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU 3 VAPOR -8.870241D+03 -2.463959D-01 -2.719870D+04 OLIQUID TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU 3 VAPOR -2.719923D+04 -7.555350D-01 -5.625536D+04

LEFT FILM COEF .H = 4.785000E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.984643E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.902717D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.583799D+01 8.561345D+01 8.587287D+01 8.677614D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 3 VAPOR -7.812737D+03 -2.170204D-01 -1.802821D+03 -2.436505D+03 -6.768063D-02 -6.700006D+03  
 LEFT FILM COEF .H = 5.424217E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.902717E+01 F  
 RIGHT FILM COEF .H = 4.675725E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.325468D+01 8.182040D+01 8.135263D+01 8.148396D+01 8.191270D+01 8.246350D+01 8.305763D+01 8.366857D+01 8.429374D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 OLIGUID -2.642429D+03 -7.340079D-02 -7.266264D+03 -8.473039D+03 -2.353621D-01 -1.955188D+04  
 LEFT FILM COEF .H = 4.675735E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.424217E-01 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT F BULK TEMP = 9.902717D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.429374D+01 8.366857D+01 8.305763D+01 8.246350D+01 8.191270D+01 8.148396D+01 8.135263D+01 8.182040D+01 8.325468D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 3 VAPOR -2.175126D+03 -6.042023D-02 -7.940444D+03 -7.473986D+02 -2.076107D-02 -2.072634D+03  
 LEFT FILM COEF .H = 4.086168E-01 BTU/HR FT2 F FIRST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 9.902717E+01 F  
 RIGHT FILM COEF .H = 4.045021E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.226934D+01 9.035426D+01 8.827240D+01 8.609211D+01 8.391374D+01 8.179643D+01 8.148171D+01 8.148800D+01 8.162631D+01  
 8.181881D+01 8.202995D+01 8.224656D+01 8.246478D+01 8.268446D+01 8.374431D+01 8.480417D+01 8.586408D+01 8.692402D+01  
 8.765431D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP. STEP LIQUID STEP VAPOR NET LIQUID  
 0 0.0 -5.619157D-01 0.0  
 1 0.0 0.0 0.0  
 2 0.0 0.0 0.0  
 3 0.0 -1.526553D+00 0.0  
 4 0.0 0.0 -1.348934D+05 0.0

COMP NO	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	A T M O S P H E R E (LBM)	E N E R G Y (BTU)	H U M I D I T Y (LB/S)	C O N D E N S A T I O N (LB/S)	T R A N S F E R C O E F F I C I E N T S (BTU/S FT2 R)	C O N V E R G E N C E (DE/E)
1	1.47000D+01	7.34000D+01	7.34000D+01	0	0	0	2.76345D-06	0
3	1.47001D+01	9.90288D+01	9.90288D+01	3.90528D+05	0	3.90528D+05	HEAT	0
1	0	0	0	0	6.00000D-01	0	0	0
3	3.79914D+03	2.64831D+01	2.64831D+01	2.64831D+01	1.76589D-01	0	0	0
COMP	3 LEAKAGE OUTFLOW MASS = 8.6037D+00 LBM/HR	ENERGY BTU/HR = 1.2365D+03 (NORMAL = 1.2365D+03 PENETRATION = 0)						
	STEP AND NET MASS LOSSES LBM STEP VAPOR = 1.6929D-06 STEP AIR = 2.4285D-04 NET VAPOR = 1.2734D+00 NET AIR = 1.8268D+02							
	TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) = 1.8268D+02 WATER VAPOR(LBM) = 1.273429D+00							

\*\*\*\*\* TIME = 2.916667E+00 HR = 1.750000E+02 MIN = 1.050000E+04 SEC \*\*\*\*\*  
 HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 0 VAPOR -1.237176D+03 -3.436598D-02 -3.246594D+03 10 RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 -1.789409D+03 -4.970586D-02 -6.887561D+03

89/12/14

LEFT FILM COEF .H = 2.000000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.397500E+01 F  
 RIGHT FILM COEF .H = 3.970747E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.913276D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.545802D+01 8.508531D+01 8.475737D+01 8.445444D+01 8.416769D+01 8.390476D+01 8.370000D+01 8.363109D+01 8.382465D+01  
 8.569931D+01 8.757500D+01 8.945225D+01 9.133158D+01 9.292805D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -7.388283D+03 -2.052306D-01 -2.699990D+04 OLIQUID -4.298156D+03 -1.193932D-01 -1.253742D+04  
 LEFT FILM COEF .H = 4.745729E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT. BULK TEMP = 9.913276E+01 F  
 RIGHT FILM COEF .H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.41110D+01 9.061071D+01 8.987145D+01 8.952255D+01 8.918010D+01 8.884753D+01 8.852677D+01 8.821529D+01 8.791053D+01  
 8.751133D+01 8.778285D+01 8.817175D+01 8.861856D+01 8.907750D+01 8.953853D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIQUID -8.802423D+03 -2.445121D-01 -2.793507D+04 3 VAPOR -2.732480D+03 -7.590217D-01 -5.852724D+04  
 LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.989862E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.913276D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.586981D+01 8.565238D+01 8.592429D+01 8.683205D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -7.831466D+03 -2.175406D-01 -1.868006D+04 OLIQUID -2.437909D+03 -6.771970D-02 -6.903107D+03  
 LEFT FILM COEF .H = 5.426891E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.913276E+01 F  
 RIGHT FILM COEF .H = 4.679476E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.333025D+01 8.188123D+01 8.139062D+01 8.150301D+01 8.192061D+01 8.246634D+01 8.305874D+01 8.366949D+01 8.429502D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIQUID -2.643952D+03 -7.344310D-02 -7.486530D+03 3 VAPOR -8.493350D+03 -2.359263D-01 -2.025882D+04  
 LEFT FILM COEF .H = 4.679476E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.426891E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.913276D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.429502D+01 8.366949D+01 8.305874D+01 8.246634D+01 8.192061D+01 8.150301D+01 8.139062D+01 8.188123D+01 8.333025D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.162095D+03 -6.005824D-02 -8.120851D+03 OLIQUID -7.472661D+02 -2.075739D-02 -2.134912D+03  
 LEFT FILM COEF .H = 4.079587E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.913276E+01 F  
 RIGHT FILM COEF .H = 4.049631E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.240458D+01 9.058710D+01 8.837812D+01 8.617122D+01 8.396586D+01 8.176152D+01 8.149822D+01 8.149645D+01 8.162982D+01  
 8.182004D+01 8.203031D+01 8.224667D+01 8.246487D+01 8.268467D+01 8.374520D+01 8.480575D+01 8.586633D+01 8.692695D+01  
 8.765740D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP.	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
0	0.	-5.601915D-01	0.	-6.024363D+04
1	0.	0.	0.	0.
2	0.	0.	0.	0.
3	0.	-1.527483D+00	0.	-1.394741D+05
4	0.	0.	0.	0.

CC

COMP NO	PRESSURE (PSIA)		TEMPERATURE (F)		ENERGY (BTU)			CONVERGENCE DE/E
	TOTAL	STEAM	ATMOS	POOL	ATMOS	POOL	TOTAL	
1	1.47000D+01	0.	7.34000D+01	7.34000D+01	0.	0.	0.	0.
3	1.47001D+01	1.63044D-01	9.91344D+01	9.91344D+01	3.90523D+05	0.	3.90523D+05	2.76329D-06

COMP NO	AIR MASS (LBM)	WATER MASS (LBM)		HUMIDITY	CONDENSATION (LB/S)	TRANSFER COEFFICIENTS MASS HEAT (BTU/S FT2 R)	
	VAPOR	ATMOS	LIQUID			POOL	(LB MOL/S FT2)
1	0.	0.	0.	0.	0.	0.	0.
3	3.79842D+03	2.64781D+01	0.	0.	2.64781D+01	1.76025D-01	0.

COMP 3 LEAKAGE OUTFLOW MASS = 5.531D+00 LBM/HR ENERGY BTU/HR = 1.2015D+03 (NORMAL = 1.2015D+03 PENETRATION = 0.)  
 STEP AND NET MASS LOSSES LBM STEP VAPOR = 1.6447D-06 STEP AIR = 2.3594D-04 NET VAPOR = 1.2784D+00 NET AIR = 1.8340D-02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) = 1.833985D+02 WATER VAPOR(LBM) = 1.278435D+00

\*\*\*\*\* TIME = 3.00000E+00 HR = 1.80000E+02 MIN = 1.08000E+04 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU

0 VAPOR	-1.240207D+03	-3.445018D-02	-3.349818D+03	3 VAPOR	-1.778528D+03	-4.940361D-02	-7.036216D+03
---------	---------------	---------------	---------------	---------	---------------	---------------	---------------

LEFT FILM COEF .H = 2.00000E-01 BTU/HR FT2.F FIRST MESH K = 1.05000E+00 BTU/HR FT. BULK TEMP = 9.40000E+01 F  
 RIGHT FILM COEF .H = 3.964276E-01 BTU/HR FT2.F LAST MESH K = 6.70000E-02 BTU/HR FT.F BULK TEMP = 9.23542D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.546216D+01 8.508814D+01 8.475897D+01 8.445550D+01 8.416925D+01 8.390852D+01 8.370868D+01 8.364769D+01 8.384949D+01  
 8.574994D+01 8.765139D+01 8.955433D+01 9.145926D+01 1.305838D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU

3 VAPOR	-7.286375D+03	-2.023998D-01	-2.761132D+04	0 LIQUID	-4.298066D+03	-1.193907D-01	-1.289560D+04
---------	---------------	---------------	---------------	----------	---------------	---------------	---------------

LEFT FILM COEF .H = 4.745288E-01 BTU/HR FT2.F FIRST MESH K = 3.50000E-02 BTU/HR FT. BULK TEMP = 9.923542E+01 F  
 RIGHT FILM COEF .H = 1.00000E+04 BTU/HR FT2.F LAST MESH K = 1.05000E+00 BTU/HR FT.F BULK TEMP = 9.00000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.448891D+01 9.082394D+01 9.007998D+01 8.970455D+01 8.933536D+01 8.897574D+01 8.862757D+01 8.828840D+01 8.795577D+01  
 8.762720D+01 8.778936D+01 8.817352D+01 8.861893D+01 8.907757D+01 8.953854D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU

0 LIQUID	-8.733323D+03	-2.425926D-01	-2.866574D+04	3 VAPOR	-2.744401D+04	-7.623332D-01	-6.080932D+04
----------	---------------	---------------	---------------	---------	---------------	---------------	---------------

LEFT FILM COEF .H = 4.78500E-01 BTU/HR FT2.F FIRST MESH K = 1.05000E+00 BTU/HR FT. BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF .H = 4.994786E-01 BTU/HR FT2.F LAST MESH K = 1.05000E+00 BTU/HR FT.F BULK TEMP = 9.923542D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.590223D+01 8.569172D+01 8.597555D+01 8.689925D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU

3 VAPOR	-7.849105D+03	-2.180306D-01	-1.933342D+04	0 LIQUID	-2.439308D+03	-6.775855D-02	-7.106324D+03
---------	---------------	---------------	---------------	----------	---------------	---------------	---------------

LEFT FILM COEF .H = 5.429385E-01 BTU/HR FT2.F FIRST MESH K = 1.05000E+00 BTU/HR FT. BULK TEMP = 9.923542E+01 F  
 RIGHT FILM COEF .H = 4.683211E-01 BTU/HR FT2.F LAST MESH K = 1.05000E+00 BTU/HR FT.F BULK TEMP = 9.00000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.340459D+01 8.194154D+01 8.142884D+01 8.152253D+01 8.192890D+01 8.246940D+01 8.305995D+01 8.367044D+01 8.429625D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU

0 LIQUID	-2.645469D+03	-7.348523D-02	-7.706922D+03	3 VAPOR	-8.512480D+03	-2.364577D-01	-2.096741D+04
----------	---------------	---------------	---------------	---------	---------------	---------------	---------------

LEFT FILM COEF .H = 4.683211E-01 BTU/HR FT2.F FIRST MESH K = 1.05000E+00 BTU/HR FT. BULK TEMP = 9.00000E+01 F  
 RIGHT FILM COEF .H = 5.429385E-01 BTU/HR FT2.F LAST MESH K = 1.05000E+00 BTU/HR FT.F BULK TEMP = 9.923542D+01 F

PCC

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.429629D+01 8.367044D+01 8.305995D+01 8.246940D+01 8.192890D+01 8.152253D+01 8.142884D+01 8.194754D+01 8.340459D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.150466D+03 -5.973522D-02 -8.300532D+03  
 LEFT FILM COEF. H = 4.073658E-01 BTU/HR FT2 F FIRST MESH K = 6.700000E-02 BTU/HR FT. BULK TEMP = 9.923542E+01 F  
 RIGHT FILM COEF. H = 4.054254E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT. F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.253369D+01 9.071356D+01 8.847928D+01 8.624696D+01 8.401611D+01 8.178625D+01 8.151476D+01 8.150508D+01 8.163350D+01  
 8.182135D+01 8.203271D-01 8.224579D+01 8.246498D+01 8.268489D+01 8.374607D+01 8.480727D+01 8.586849D+01 8.692976D+01  
 8.766037D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0 -5.584320D-01 0 -6.192158D+04  
 1 0 0 0  
 2 0 0 0  
 3 0 -1.528360D+00 0 -1.440582D+05  
 4 0 0 0

COMP NO.	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	A T M O S P O O L	E N E R G Y (BTU)	T O T A L	C O N V E R G E N C E (DE/E)
1	1.47000D+01	7.34000D+01	7.34000D+01	0	0	0
3	1.47001D+01	9.92370D+01	9.92370D+01	3.90519D+05	3.90519D+05	2.763130-06

AIR MASS (LBM)	W A T E R V A P O R - A T M O S - L I Q U I D	M A S S P O O L	H U M I D I T Y	C O N D E N S A T I O N (LB/S)	T R A N S F E R C O E F F I C I E N T S (BTU/S FT2 R)
1	0	0	0	0	0
3	3.79772D+03	2.64732D+01	2.64732D+01	6.00000D-01	0

COMP.	3 LEAKAGE OUTFLOW - MASS	8.3165D+00 LBM/HR	E N E R G Y B T U / H R	(N O R M A L = 1.1685D+03 PENETRATION = 0)
STEP AND NET MASS LOSSES LBM STEP VAPOR =	1.5993D-06	STEP AIR =	2.2942D-04	NET VAPOR = 1.2833D+00
TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) =	1.840965D+02	W A T E R V A P O R (LBM) =	1.283300D+00	

\*\*\*\*\* TIME = 3.083333E+00 HR = 1.850000E+02 MIN = 1.110000E+04 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -1.23600D+03 -3.437339D-02 -3.452993D+03  
 LEFT FILM COEF. H = 2.00000E-01 BTU/HR FT2 F FIRST MESH K = 1.050000E+00 BTU/HR FT. BULK TEMP = 9.397500E+01 F  
 RIGHT FILM COEF. H = 3.95844E-01 BTU/HR FT2 F LAST MESH K = 6.700000E-02 BTU/HR FT. F BULK TEMP = 9.933533D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.546611D+01 8.509097D+01 8.476062D+01 8.445662D+01 8.417092D+01 8.391246D+01 8.371754D+01 8.366430D+01 8.327398D+01  
 8.579882D+01 8.772463D+01 8.965187D+01 9.158102D+01 9.318296D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -7.188380D+03 -1.996777D-01 -2.821441D+04  
 RIGHT FILM COEF. H = 4.744858E-01 BTU/HR FT2 F FIRST MESH K = 3.500000E-02 BTU/HR FT. BULK TEMP = 9.933533E+01 F  
 LEFT FILM COEF. H = 1.00000E+04 BTU/HR FT2 F LAST MESH K = 1.050000E+00 BTU/HR FT. F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.465223D+01 9.103021D+01 9.028171D+01 8.988070D+01 8.948572D+01 8.910001D+01 8.872540D+01 8.835953D+01 8.800002D+01  
 8.764448D+01 8.779605D+01 8.817539D+01 8.861934D+01 8.907764D+01 8.953855D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 LIQUID -8.663023D+03 -2.406399D-01 -2.939059D+04  
 TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.755722D+04 -7.654779D-01 -6.310107D+04



LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 4.999432E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.933533E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 B 593522D+01 B 573145D+01 B 602665D+01 B 695978D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -7.865729D+03 -2.484924D-01 -1.998821D+04 OLIIQUID -2.436628D+03 -6.768411D-02 -7.309488D+03  
 LEFT FILM COEF .H = 5.431713E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.933533E+01 F  
 RIGHT FILM COEF .H = 4.679065E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 B 347778D+01 B 200135D+01 B 146726D+01 B 154252D+01 B 193756D+01 B 247267D+01 B 306126D+01 B 367143D+01 B 429752D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQUID -2.642562D+03 -7.340450D-02 -7.927256D+03 3 VAPOR -8.530509D+03 -2.070253D-02 -2.369585D+01 -2.167754D+04  
 LEFT FILM COEF .H = 4.679065E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.431713E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.933533D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 B 429752D+01 B 367143D+01 B 306126D+01 B 247267D+01 B 193756D+01 B 154252D+01 B 146726D+01 B 100135D+01 B 347778D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.140106D+03 -5.944745D-02 -8.479298D+03 OLIIQUID -7.452907D+02 -2.070253D-02 -2.259364D+03  
 LEFT FILM COEF .H = 4.068323E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.933533E+01 F  
 RIGHT FILM COEF .H = 4.048439E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 B 265714D+01 B 083421D+01 B 857595D+01 B 631957D+01 B 406462D+01 B 181062D+01 B 153134D+01 B 151390D+01 B 163733D+01  
 B 182276D+01 B 203116D+01 B 224693D+01 B 246509D+01 B 268511D+01 B 374690D+01 B 480874D+01 B 587055D+01 B 693242D+01  
 B 766290D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP.	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
0	0	-5.561522D-01	0	-6.359346D+04
1	0	0	0	0
2	0	0	0	0
3	0	-1.529188D+00	0	-1.486445D+05
4	0	0	0	0

COMP NO.	P R E S S U R E (P S I A)	T E M P E R A T U R E (F)	E N E R G Y (B T U)	C O N V E R G E N C E (D E / E)
1	1.47000D+01	7.34000D+01	7.34000D+01	0
3	1.47000D+01	9.93369D+01	9.93369D+01	3.90515D+05

AIR MASS (LBM)	W A T E R M A S S (L B M)	H U M I D I T Y (L B / S)	C O N D E N S A T I O N (L B / S)	T R A N S F E R C O E F F I C I E N T S (L B M O L / S F T 2)(B T U / S F T 2 R)
1	0	0	0	0
3	3.79704D+03	2.64685D+01	6.00000D-01	0

COMP	LEAKAGE OUTFLOW MASS	ENERGY BTU/HR	NET VAPOR	NET AIR	PENETRATION
3	8.0940D+00	8.0940D+00	1.1374D+03	1.1374D+03	0

TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.847754D+02 WATER VAPOR(LBM)= 1.2880D+00 NET AIR= 1.8478D+02

\*\*\* TIME = 3.166667E+00 HR = 1.900000E+02 MIN = 1.140000E+04 SEC \*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -1.231839D+03 -3.421776D-02 -3.555819D+03 3 VAPOR -1.760164D+03 -4.889349D-02 -7.331048D+03

LEFT FILM COEF .H = 2.000000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.395000E+01 F  
 RIGHT FILM COEF .H = 3.953197E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.943264E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.546977D+01 8.509380D+01 8.476230D+01 8.445781D+01 8.417270D+01 8.391656D+01 8.372658D+01 8.368091D+01 8.385312D+01  
 8.584607D+01 8.779496D+01 8.974522D+01 9.169730D+01 9.330224D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -7.094190D+03 -1.970613D-01 -2.880949D+04 OLIQUID -4.297846D+03 -1.193846D-01 -1.361192D+04  
 LEFT FILM COEF .H = 4.744440E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT. BULK TEMP = 9.943264E+01 F  
 RIGHT FILM COEF .H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.481035D+01 9.122978D+01 9.047690D+01 9.005120D+01 8.963136D+01 8.922049D+01 8.882037D+01 8.842875D+01 8.804331D+01  
 8.766176D+01 8.780290D+01 8.817736D+01 8.861979D+01 8.907772D+01 8.953857D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIQUID -8.591602D+03 -2.386559D-01 -3.010954D+04 3 VAPOR -2.766476D+04 -7.684650D-01 -6.540203E+04  
 LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.003818E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.943264E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.596873D+01 8.577154D+01 8.607760D+01 8.701968D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -7.881402D+03 -2.189278D-01 -2.064435D+04 OLIQUID -2.493999D+03 -6.761100D-02 -7.512430D+03  
 LEFT FILM COEF .H = 5.433886E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.943264E+01 F  
 RIGHT FILM COEF .H = 4.674930E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.354984D+01 8.206066D+01 8.150585D+01 8.156295D+01 8.194660D+01 8.247616D+01 8.306268D+01 8.367245D+01 8.429863D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIQUID -2.639711D+03 -7.332531D-02 -8.147351D+03 3 VAPOR -8.547507D+03 -2.374307D-01 -2.238913D+04  
 LEFT FILM COEF .H = 4.674930E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.433886E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.943264E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.429863D+01 8.367245D+01 8.306268D+01 8.247616D+01 8.194660D+01 8.156295D+01 8.150585D+01 8.206066D+01 8.354984D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.130895D+03 -5.919158D-02 -8.657248D+03 OLIQUID -7.436254D+02 -2.065627D-02 -2.321401D+03  
 LEFT FILM COEF .H = 4.063531E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.943264E+01 F  
 RIGHT FILM COEF .H = 4.042737E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.277534D+01 9.094943D+01 8.866846D+01 8.638930D+01 8.411151D+01 8.183464D+01 8.154786D+01 8.152288D+01 8.164133D+01  
 8.182426D+01 8.203165D+01 8.224703D+01 8.246521D+01 8.268534D+01 8.374767D+01 8.481001D+01 8.587238D+01 8.693479D+01  
 8.766483D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0 -5.538510D-01 0 -6.525847D+04  
 1 0 0 0  
 2 0 0 0  
 3 0 -1.529970D+00 0 -1.532333D+05  
 4 0 0 0

CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM  
89/12/14.

CONTEMP1-11/028.30 APRIL 1978, EG&G IDAHO INC. CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM  
COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS

COMP NO.	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	A T M O S P O O L	E N E R G Y (BTU)	C O N D E N S A T I O N (LB/S)	H U M I D I T Y (LB/S)	M A S S (LBM)	T O T A L (LB/S)	C O N V E R G E N C E (DE/E)
1	1.47000+01	7.34000+01	7.34000+01	0.	0.	0.	0.	0.	0
3	1.47000+01	9.94342+01	9.94342+01	3.90511D+05	3.90511D+05	3.90511D+05	3.90511D+05	3.90511D+05	2.76275D-06
<p>TRANSFER COEFFICIENTS HEAT</p>									
1	0.	0.	0.	0.	0.	0.	0.	0.	0.
3	3.75638D+03	2.64639D+01	2.64639D+01	1.74435D-01	1.74435D-01	1.74435D-01	1.74435D-01	1.74435D-01	0.
<p>COMP. 3 LEAKAGE OUTFLOW- MASS= 1.10800D+03 (NORMAL= 1.10800D+03 PENETRATION= 0.)</p>									
<p>STEP AND NET MASS LOSSES LBM STEP VAPOR= 1.5159D-06 STEP AIR= 2.1747D-04 NET VAPOR= 1.2926D+00 NET AIR= 1.8544D+02</p>									
<p>TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 A/R(LBM)= 1.854365D+02 WATER VAPOR(LBM)= 1.292644D+00</p>									

\*\*\*\*\* TIME = 3.25000E+00 HR = 1.95000E+02 MIN = 1.17000E+04 SEC \*\*\*\*\*

HEAT STRUCTURE	1 BETWEEN COMPARTMENTS	0 AND 3 NORTH WALL	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
TO LEFT COMP.	-1.227714D+03	-3.410319D-02	-3.658301D+03	3 VAPOR	-1.752873D+03	-4.867983D-02	-7.477402D+03	3 VAPOR	-1.752873D+03
0 VAPOR	2.00000E-01	BTU/HR	FT2.F	FIRST MESH	K = 1.050000E+00	BTU/HR	FT.F	BULK TEMP = 9.392500E+01	F
LEFT FILM COEF.	H = 3.948485E-01	BTU/HR	FT2.F	LAST MESH	K = 6.700000E-02	BTU/HR	FT.F	BULK TEMP = 9.952748D+01	F
RIGHT FILM COEF.	H = 3.948485E-01	BTU/HR	FT2.F	LAST MESH	K = 6.700000E-02	BTU/HR	FT.F	BULK TEMP = 9.952748D+01	F
MESH POINT TEMPERATURES (F), LEFT TO RIGHT	8.547316D+01	8.509659D+01	8.475403D+01	8.445907D+01	8.41748D+01	8.392082D+01	8.373578D+01	8.369752D+01	8.392192D+01
8.589175D+01	8.786257D+01	8.983467D+01	9.180852D+01	9.341659D+01					

HEAT STRUCTURE	2 BETWEEN COMPARTMENTS	3 AND 0 ROOF & CEILING	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
TO LEFT COMP.	-7.003697D+03	-1.945476D-01	-2.539687D+04	OLIOUID	-4.297711D+03	-1.193809D-01	-1.397007D+04	OLIOUID	-4.297711D+03
3 VAPOR	4.744032E-01	BTU/HR	FT2.F	FIRST MESH	K = 3.500000E-02	BTU/HR	FT.F	BULK TEMP = 9.952748E+01	F
LEFT FILM COEF.	H = 1.000000E+04	BTU/HR	FT2.F	LAST MESH	K = 1.050000E+00	BTU/HR	FT.F	BULK TEMP = 9.000000D+01	F
RIGHT FILM COEF.	H = 1.000000E+04	BTU/HR	FT2.F	LAST MESH	K = 1.050000E+00	BTU/HR	FT.F	BULK TEMP = 9.000000D+01	F
MESH POINT TEMPERATURES (F), LEFT TO RIGHT	9.496390D+01	9.142290D+01	9.066578D+01	9.021628D+01	8.933730D+01	8.891258D+01	8.849611D+01	8.808566D+01	
8.767902D+01	8.780991D+01	8.817943D+01	8.862026D+01	8.907781D+01	8.953858D+01	8.999987D+01			

HEAT STRUCTURE	3 BETWEEN COMPARTMENTS	0 AND 3 FLOOR	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
TO LEFT COMP.	-8.519133D+03	-2.306429D-01	-3.082250D+04	OLIOUID	-2.77669D+04	-7.713030D-01	-6.771172D+04	OLIOUID	-2.77669D+04
3 VAPOR	4.785000E-01	BTU/HR	FT2.F	FIRST MESH	K = 1.050000E+00	BTU/HR	FT.F	BULK TEMP = 9.000000E+01	F
LEFT FILM COEF.	H = 5.007958E-01	BTU/HR	FT2.F	LAST MESH	K = 1.050000E+00	BTU/HR	FT.F	BULK TEMP = 9.952748D+01	F
RIGHT FILM COEF.	H = 5.007958E-01	BTU/HR	FT2.F	LAST MESH	K = 1.050000E+00	BTU/HR	FT.F	BULK TEMP = 9.952748D+01	F
MESH POINT TEMPERATURES (F), LEFT TO RIGHT	8.600273D+01	8.581195D+01	8.612840D+01	8.707899D+01					

HEAT STRUCTURE	4 BETWEEN COMPARTMENTS	3 AND 0 SOUTH WALL	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
TO LEFT COMP.	-7.896188D+03	-2.193385D-01	-2.130176D+04	OLIOUID	-2.431413D+03	-6.753927D-02	-7.715756D+03	OLIOUID	-2.431413D+03
3 VAPOR	5.435916E-01	BTU/HR	FT2.F	FIRST MESH	K = 1.050000E+00	BTU/HR	FT.F	BULK TEMP = 9.952748E+01	F
LEFT FILM COEF.	H = 4.670802E-01	BTU/HR	FT2.F	LAST MESH	K = 1.050000E+00	BTU/HR	FT.F	BULK TEMP = 9.000000D+01	F
RIGHT FILM COEF.	H = 4.670802E-01	BTU/HR	FT2.F	LAST MESH	K = 1.050000E+00	BTU/HR	FT.F	BULK TEMP = 9.000000D+01	F
MESH POINT TEMPERATURES (F), LEFT TO RIGHT	8.362083D+01	8.211946D+01	8.154459D+01	8.158379D+01	8.195600D+01	8.247987D+01	8.306420D+01	8.367350D+01	8.429965D+01

HEAT STRUCTURE	5 BETWEEN COMPARTMENTS	0 AND 3 WEST WALL	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
TO LEFT COMP.	-2.636907D+03	-7.324742D-02	-8.367209D+03	OLIOUID	-8.563542D+03	-2.378761D-01	-2.310210D+04	OLIOUID	-8.563542D+03
3 VAPOR	4.670802E-01	BTU/HR	FT2.F	FIRST MESH	K = 1.050000E+00	BTU/HR	FT.F	BULK TEMP = 9.000000E+01	F
LEFT FILM COEF.	H = 5.435916E-01	BTU/HR	FT2.F	LAST MESH	K = 1.050000E+00	BTU/HR	FT.F	BULK TEMP = 9.952748D+01	F
RIGHT FILM COEF.	H = 5.435916E-01	BTU/HR	FT2.F	LAST MESH	K = 1.050000E+00	BTU/HR	FT.F	BULK TEMP = 9.952748D+01	F



LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.011868E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.961999D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.603719D+01 8.585267D+01 8.617905D+01 8.713772D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -7.910142D+03 -2.197261D-01 -2.196036D+04 OLIQUID -2.428862D+03 -6.746841D-02 -7.917667D+03

LEFT FILM COEF .H = 5.437810E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.961999E+01 F  
 RIGHT FILM COEF .H = 4.666679E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.369078D+01 8.217777D+01 8.158346D+01 8.160503D+01 8.196577D+01 8.248380D+01 8.306583D+01 8.367453D+01 8.430060D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIQUID -2.634140D+03 -7.317057D-02 -8.586836D+03 3 VAPOR -8.578675D+03 -2.382965D-01 -2.381636D+04

LEFT FILM COEF .H = 4.666679E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.437810E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.961999D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.430060D+01 8.367458D+01 8.306583D+01 8.248380D+01 8.196577D+01 8.160503D+01 8.158346D+01 8.217777D+01 8.369078D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.115197D+03 -5.876383D-02 -9.011062D+03 OLIQUID -7.407397D+02 -2.057611E-02 -2.445090D+03

LEFT FILM COEF .H = 4.055387E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.961999E+01 F  
 RIGHT FILM COEF .H = 4.031557E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.299754D+01 9.116522D+01 8.884224D+01 8.652093D+01 8.420088D+01 8.188169D+01 8.158092D+01 8.154131D+01 8.164979D+01  
 8.182754D+01 8.203275D+01 8.224747D+01 8.246548D+01 8.268578D+01 8.374894D+01 8.481210D+01 8.587529D+01 8.693849D+01  
 8.766744D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
0	0.	-5.491840D-01	0.	-6.856761D+04
1	0.	0.	0.	0.
2	0.	0.	0.	0.
3	0.	-1.531410D+00	0.	-1.624175D+05
4	0.	0.	0.	0.

COMP NO	PRESSURE (PSIA)		TEMPERATURE (F)			ENERGY (BTU)		CONVERGENCE DE/E
	TOTAL	STEAM	ATMOS	POOL	ATMOS	POOL	TOTAL	
1	1.47000D+01	0.	7.34000D+01	7.34000D+01	0.	0.	0.	0.
3	1.47001D+01	1.63045D-01	9.96216D+01	9.96216D+01	3.90503D+05	0.	3.90503D+05	2.76234D-06

COMP	AIR MASS (LBM)	WATER		MASS (LBM)		HUMIDITY	CONDENSATION (LB/S)	TRANSFER COEFFICIENTS	
		VAPOR	ATMOS-LIQUID	POOL	TOTAL			MASS	HEAT
1	0.	0.	0.	0.	0.	6.00000D-01	0.	0.	0.
3	3.79511D+03	2.64550D+01	0.	0.	2.64550D+01	1.73450D-01	0.	0.	0.

COMP 3 LEAKAGE OUTFLOW- MASS= 7.4956D+00 LBM/HR ENERGY BTU/HR = 1.0538D+03 (NORMAL= 1.0538D+03 PENETRATION= 0.)  
 STEP AND NET MASS LOSSES LBM STEP VAPOR= 1.4413D-06 STEP AIR= 2.0677D-04 NET VAPOR= 1.3015D+00 NET AIR= 1.8671D+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.867086D+02 WATER VAPOR(LBM)= 1.301509D+00

\*\*\*\*\* TIME = 3.416667E+00 HR = 2.050000E+02 MIN = 1.230000E+04 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -1.219563D+03 -3.387677D-02 -3.862239D+03 3 VAPOR -1.739624D+03 -4.832291D-02 -7.68366D+03

CONTEMP-LI/02B.30 APRIL 1978, EG&G IDAHO INC. CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM  
 COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS 89/12/14.

LEFT FILM COEF. H = 2.00000E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.387500E+01 F  
 RIGHT FILM COEF. H = 3.940487E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.9710300+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.5479280+01 8.5102080+01 8.4767590+01 8.4461800+01 8.4178690+01 8.3929820+01 8.3754620+01 8.3730670+01 8.3968560+01  
 8.5979070+01 8.7950420+01 9.0003010+01 9.2017210+01 9.3631900+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -6.8333720+03 -1.8981630-01 -3.0549770+04 OLIIQID -4.2973860+03 -1.1937180-01 -1.4686330+04  
 LEFT FILM COEF. H = 4.743246E-01 BTU/HR.FT2.F FIRST MESH K = 3.50000E-02 BTU/HR.FT. BULK TEMP = 9.971030E+01 F  
 RIGHT FILM COEF. H = 1.00000E+04 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.0000000+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.5256970+01 9.1790750+01 9.1025520+01 9.0530890+01 9.0041590+01 8.9560430+01 8.9089090+01 8.8625510+01 8.8167660+01  
 8.7713440+01 8.7824390+01 8.6183870+01 8.8621330+01 8.9078020+01 8.9538620+01 8.9999870+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQID -8.3743280+03 -2.3253720-01 -3.2230090+04 3 VAPOR -2.7956270+04 -7.7656270-01 -7.2355590+04  
 LEFT FILM COEF. H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF. H = 5.015561E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.9710300+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.607080+01 8.5893670+01 8.6229550+01 8.7195910+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -7.9233170+03 -2.2009210-01 -2.2620090+04 OLIIQID -2.4262400+03 -6.7398340-02 -8.1199670+03  
 LEFT FILM COEF. H = 5.439580E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.971030E+01 F  
 RIGHT FILM COEF. H = 4.662558E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.0000000+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.3759740+01 8.2235590+01 8.1622430+01 8.1975880+01 8.2487960+01 8.3067580+01 8.3675680+01 8.4301490+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQID -2.6314040+03 -7.3094580-02 -8.9062340+03 3 VAPOR -8.5929640+03 -2.3869340-01 -2.4531850+04  
 LEFT FILM COEF. H = 4.662558E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF. H = 5.439580E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.9710300+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.4301490+01 8.3675680+01 8.3067580+01 8.2487960+01 8.1975880+01 8.1622430+01 8.2235590+01 8.3759740+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.1091240+03 -5.8586790-02 -9.1670820+03 OLIIQID -7.3947110+02 -2.0540870-02 -2.5067650+03  
 LEFT FILM COEF. H = 4.051954E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.971030E+01 F  
 RIGHT FILM COEF. H = 4.026051E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.0000000+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 5.3102200+01 5.1266520+01 8.8924050+01 8.6583190+01 8.4243540+01 8.1904740+01 8.1597410+01 8.1550740+01 8.1654240+01  
 8.1829320+01 8.2033380+01 8.2247690+01 8.2465630+01 8.2686010+01 8.3749450+01 8.4812900+01 8.5876370+01 8.6939850+01  
 8.7668250+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0. -5.4681960-01 0. -7.0211620+04  
 1 0. 0. 0.  
 2 0. 0. 0.  
 3 0. -1.5320740+00 0. -1.6701270+05  
 4 0. 0. 0.

COMP NO.	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	A T M O S P O O L	E N E R G Y (BTU)	T O T A L	C O N V E R G E N C E (DE/E)
1	1.47000+01	7.34000+01	7.34000+01	0.	0.	0.
3	1.47001D+01	9.97119D+01	9.97119L+01	3.90500+05	3.90500+05	2.76213D-06

AIR MASS (LBM)	W A T E R M A S S (LBM)	H U M I D I T Y (LB/S)	C O N D E N S A T I O N (LB/S)	T R A N S F E R C O E F F I C I E N T S (BTU/S FT2 R)
1	0.	0.	0.	0.
3	3.79450D+03	2.64507D+01	6.00000D-01	0.

COMP. 3 LEAKAGE OUTFLOW MASS= 7.3168D+00 LBM/HR ENERGY BTU/HR = 1.0289D+03 PENETRATION= 0.  
 STEP AND NET MASS LOSSES LBM STEP VAPOR= 1.4070D-06 STEP AIR= 2.0184D-04 NET VAPOR= 1.3058D+00 NET AIR= 1.8732D+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.873214D+02 WATER VAPOR(LBM)= 1.305781D+00

\*\*\*\*\* TIME = 3.50000E+00 HR = 2.10000E+02 MIN = 1.26000E+04 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU TOTAL NET BTU
0 VAPOR	-1.215530D+03	-3.376473D-02	3 VAPOR	-1.734313D+03	-4.817539D-02
LEFT FILM COEF. H =	2.00000E-01 BTU/HR.FT2.F	FIRST MESH K =	1.050000E+00 BTU/HR.FT. F	BULK TEMP =	9.385000E+01 F
RIGHT FILM COEF. H =	3.937120E-01 BTU/HR.FT2.F	LAST MESH K =	6.700000E-02 BTU/HR.FT. F	BULK TEMP =	9.979851D+01 F
MESH POINT TEMPERATURES (F), LEFT TO RIGHT					
8.54R204D+01	8.510475D+01	8.476942D+01	8.418091D+01	8.376425D+01	8.374720D+01
8.602080D+01	8.805101D+01	9.008240D+01	9.211535D+01	9.373348D+01	8.399141D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING

TO LEFT COMP.	END STEP BTU/HR	STEP BTU TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU TOTAL NET BTU
3 VAPOR	-6.753322D+03	-1.875926D-01	0 LIQUID	-4.297193D+03	-1.193665D-01
LEFT FILM COEF. H =	4.742866E-01 BTU/HR.FT2.F	FIRST MESH K =	3.500000E-02 BTU/HR.FT. F	BULK TEMP =	9.979851E+01 F
RIGHT FILM COEF. H =	1.00000E+04 BTU/HR.FT2.F	LAST MESH K =	1.050000E+00 BTU/HR.FT. F	BULK TEMP =	9.000000D+01 F
MESH POINT TEMPERATURES (F), LEFT TO RIGHT					
9.539699D+01	9.196594D+01	9.119682D+01	9.068082D+01	8.966700D+01	8.868767D+01
8.773058D+01	8.783185D+01	8.818623D+01	8.852192D+01	8.953864D+01	8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR

TO LEFT COMP.	END STEP BTU/HR	STEP BTU TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU TOTAL NET BTU
0 LIQUID	-8.296121D+03	-2.304481D-01	3 VAPOR	-2.804397D+04	-7.789988D-01
LEFT FILM COEF. H =	4.785000E-01 BTU/HR.FT2.F	FIRST MESH K =	1.050000E+00 BTU/HR.FT. F	BULK TEMP =	9.000000E+01 F
RIGHT FILM COEF. H =	5.019046E-01 BTU/HR.FT2.F	LAST MESH K =	1.050000E+00 BTU/HR.FT. F	BULK TEMP =	9.979851D+01 F
MESH POINT TEMPERATURES (F), LEFT TO RIGHT					
8.610737D+01	8.593494D+01	8.627991D+01	8.725359D+01	8.827350D+01	8.820735D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU TOTAL NET BTU
3 VAPOR	-7.935764D+03	-2.204378D-01	0 LIQUID	-2.422839D+03	-6.732889D-02
LEFT FILM COEF. H =	5.441233E-01 BTU/HR.FT2.F	FIRST MESH K =	1.050000E+00 BTU/HR.FT. F	BULK TEMP =	9.979851E+01 F
RIGHT FILM COEF. H =	4.658437E-01 BTU/HR.FT2.F	LAST MESH K =	1.050000E+00 BTU/HR.FT. F	BULK TEMP =	9.000000D+01 F
MESH POINT TEMPERATURES (F), LEFT TO RIGHT					
8.382775D+01	8.229292D+01	8.166149D+01	8.198635D+01	8.249234D+01	8.367682D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU TOTAL NET BTU
0 LIQUID	-2.628693D+03	-7.301925D-02	3 VAPOR	-8.606463D+03	-2.390683D-01
LEFT FILM COEF. H =	4.658437E-01 BTU/HR.FT2.F	FIRST MESH K =	1.050000E+00 BTU/HR.FT. F	BULK TEMP =	9.000000E+01 F
RIGHT FILM COEF. H =	5.441233E-01 BTU/HR.FT2.F	LAST MESH K =	1.050000E+00 BTU/HR.FT. F	BULK TEMP =	9.979851D+01 F
MESH POINT TEMPERATURES (F), LEFT TO RIGHT					
8.382775D+01	8.229292D+01	8.166149D+01	8.198635D+01	8.249234D+01	8.367682D+01

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.430232D+01 8.367682D+01 8.306943D+01 8.249234D+01 8.198635D+01 8.164864D+01 8.166149D+01 8.229292D+01 8.382775D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.103526D+03 -5.8129D-02 -9.362604D+03 OLIIQUID -7.382990D+02 -2.050831D-02 -2.568338D+03  
 LEFT FILM COEF. H = 4.048896E-01B1 R.FT2 F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 9.979851E+01 F  
 RIGHT FILM COEF. H = 4.020590E-01 R.FT2 F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT

9.320297D+01 9.136383D+01 8.900279D+01 8.664230D+01 8.428498D+01 8.192748D+01 8.161386D+01 8.156029D+01 8.165883D+01  
 8.183120D+01 8.203405D+01 8.224793D+01 8.246579D+01 8.268623D+01 8.374988D+01 8.481355D+01 8.587723D+01 8.694092D+01  
 8.766879D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS 3 AND 0 EAST WALL - UNITS ARE BTU  
 COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
 0 0. -5.444358D-01 0. -7.184851D+04  
 1 0. 0. 0. 0.  
 2 0. -1.532704D+00 0. -1.716099D+05  
 3 0. 0. 0. 0.  
 4 0. 0. 0. 0.

CONVERGENCE DE/E

COMP NO.	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	A T M O S P O O L	E N E R G Y	(BTU) TOTAL	CONVERGENCE DE/E
1	1.4700D+01	7.3400D+01	7.3400D+01	0.	0.	0.
2	1.4700D+01	9.9800D+01	9.9800D+01	3.90496D+05	3.90496D+05	2.7619D-06

TRANSFER COEFFICIENTS

COMP NO.	A I R M A S S (LBM)	W A T E R M A S S (LBM)	H U M I D I T Y	C O N D E N S A T I O N (LB/S)	M A S S (LB M O L / S F T 2 )	H E A T
1	0.	0.	6.0000D-01	0.	0.	0.
3	7.9390D+03	2.64465D+01	1.72517D-01	0.	0.	0.

COMP. 3 LEAKAGE OUTFLOW- MASS= 7.1472D+00 LBM/HR ENERGY BTU/HR = 1.0052D+03 (NORMAL = 1.0052D+03 PENETRATION= 0.)  
 STEP AIR NET MASS LOSSES LBM STEP VAPOR= 1.3744D-06 STEP AIR= 1.9716D-04 NET VAPOR= 1.3100D+00 NET AIR= 1.8792D+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.879198D+02 WATER VAPOR(LBM)= 1.309952D+00

\*\*\*\*\* TIME = 3.583333E+00 HR = 2.150000E+02 MIN = 1.290000E+04 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -1.211521D+03 -3.365338D-02 -4.064828D+03 3 VAPOR -1.729656D+03 -4.804602D-02 -8.057436D+03  
 LEFT FILM COEF. H = 2.000000E-01BTU/HR.FT2 F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.382500E+01 F  
 RIGHT FILM COEF. H = 3.934126E-01 BTU/HR.FT2 F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.988473D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.548464D+01 8.510738D+01 8.477128D+01 8.446481D+01 8.418324D+01 8.393943D+01 8.377399D+01 8.376369D+01 8.401397D+01  
 8.606137D+01 8.810956D+01 9.015890D+01 5.220974D+01 9.283138D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -6.676537D+03 -1.854597D-01 -3.167541D+04 OLIIQUID -4.296978D+03 -1.193605D-01 -1.540253D+04  
 LEFT FILM COEF. H = 4.742496E-01BTU/HR.FT2 F FIRST MESH K = 3.500000E-02 BTU/HR.FT. BULK TEMP = 9.988473E+01 F  
 RIGHT FILM COEF. H = 1.000000E+04 BTU/HR.FT2 F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.553292D+01 9.213559D+01 9.136269D+01 9.082605D+01 9.029440D+01 8.977039D+01 8.925563D+01 8.874820D+01 8.824619D+01  
 8.774767D+01 8.7839943D+01 8.818870D+01 8.862255D+01 8.907828D+01 8.953866D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQUID -8.220124D+03 -2.283371D-01 -3.36275D+04 3 VAPOR -2.812723D+04 -7.813143D-01 -7.702946D+04



CONTEMP-11/02B.30 APRIL 1978. EGG IDAHO INC. CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM 89/12/14 PAGE

COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS
LEFT FILM COEF .H = 4.78500E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.00000E+01 F
RIGHT FILM COEF .H = 5.022342E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.988473D+01 F
MESH POINT TEMPERATURES (F). LEFT TO RIGHT
8.614303D+01 8.597644D+01 8.633013D+01 8.731077D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU
3 VAPOR -7.947527D+03 -2.207646D-01 -2.394270D+04 OL LIQUID -2.421355D+03 -6.725994D-02 -8.523940D+03
LEFT FILM COEF .H = 5.442777E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.988473E+01 F
RIGHT FILM COEF .H = 4.654316E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F
MESH POINT TEMPERATURES (F). LEFT TO RIGHT
8.389484D+01 8.234978D+01 8.170062D+01 8.167096D+01 8.199715D+01 8.249625D+01 8.307141D+01 8.367798D+01 8.430312D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU
OL LIQUID -2.626000D+03 -7.294445D-02 -9.244350D+03 3 VAPOR -8.519222D+03 -2.394227D-01 -2.596624D+04
LEFT FILM COEF .H = 4.654316E-01 BTU/HR.FT2.F FIRST MESH K = 1.05000E+00 BTU/HR.FT. BULK TEMP = 9.00000E+01 F
RIGHT FILM COEF .H = 5.442777E-01 BTU/HR.FT2.F LAST MESH K = 1.05000E+00 BTU/HR.FT.F BULK TEMP = 9.988473D+01 F
MESH POINT TEMPERATURES (F). LEFT TO RIGHT
8.430312D+01 8.367798D+01 8.307141D+01 8.249625D+01 8.199715D+01 8.170062D+01 8.167096D+01 8.234978D+01 8.389484D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU
3 VAPOR -2.098631D+03 -5.829534D-02 -9.537689D+03 OL LIQUID -7.372126D+02 -2.047813D-02 -2.629817D+03
LEFT FILM COEF .H = 4.046181E-01 BTU/HR.FT2.F FIRST MESH K = 6.70000E-02 BTU/HR.FT. BULK TEMP = 9.988473E+01 F
RIGHT FILM COEF .H = 4.015168E-01 BTU/HR.FT2.F LAST MESH K = 6.70000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F
MESH POINT TEMPERATURES (F). LEFT TO RIGHT
9.330012D+01 9.145745D+01 8.907868D+01 8.670141D+01 8.432527D+01 8.194993D+01 8.163028D+01 8.156996D+01 8.166357D+01
8.183317D+01 8.203477D+01 8.224819D+01 8.246596D+01 8.268645D+01 8.375025D+01 8.481406D+01 8.587789D+01 8.694172D+01
8.766908D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU
COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR
0 0. -5.420335D-01 0. -7.347821D+04
1 0. 0. 0. 0.
2 0. 0. 0. 0.
3 0. -1.533303D+00 0. -1.762089D+05
4 0. 0. 0. 0.

Table with columns: COMP NO., P R E S S U R E (PSIA), S T E A M, T E M P E R A T U R E (F), A T M O S, P O O L, E N E R G Y (BTU), C O N D E N S A T I O N (LB/S), H U M I D I T Y, M A S S, T R A N S F E R C O E F F I C I E N T S, C O N V E R G E N C E D E / E. Rows include data for compartments 1, 3, and totals for air mass, vapor, and heat transfer.

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU
0 VAPOR -1.207535D+03 -3.354266D-02 -4.165621D+03

CONTEMP-LT/O28.30 APRIL 1978, EG&G IDAHO INC. CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM  
COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS 89/12/14.

RIGHT FILM COEF .H = 2.00000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.380000E+01 F  
LEFT FILM COEF .H = 3.931473E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.996906E+01 F  
MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
8.548708D+01 8.510995D+01 8.477316D+01 8.446641D+01 8.418568D+01 8.3944446D+01 8.378014D+01 8.4036225D+01  
8.610084D+01 8.816622D+01 9.023271D+01 9.230064D+01 9.392586D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING STEP BTU TOTAL NET BTU  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -6.602912D+03 -1.834146D-01 -3.222870D+04 OL LIQUID -4.296736D+03 -1.193538D-01 -1.576060D+04  
LEFT FILM COEF .H = 4.742133E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT.F BULK TEMP = 9.996906E+01 F  
RIGHT FILM COEF .H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
9.566491D+01 9.229991D+01 9.152334D+01 9.096678D+01 8.987073D+01 8.933538D+01 8.880717D+01 8.828423D+01  
8.776470D+01 8.784715D+01 8.819126D+01 8.862322D+01 8.907842D+01 8.953869D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR STEP BTU TOTAL NET BTU  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -8.143393D+03 -2.262057D-01 -3.429457D+04 OL LIQUID -2.418886D+03 -6.719130D-02 -8.725617D+03  
LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.996906E+01 F  
RIGHT FILM COEF .H = 5.025453E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.996906D+01 F  
MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
8.617903D+01 8.601816D+01 8.638021D+01 8.736749D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL STEP BTU TOTAL NET BTU  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -7.958648D+03 -2.210735D-01 -2.460546D+04 OL LIQUID -2.418886D+03 -6.719130D-02 -8.725617D+03  
LEFT FILM COEF .H = 5.444218E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.996906E+01 F  
RIGHT FILM COEF .H = 4.650192E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
8.396103D+01 8.240616D+01 8.173979D+01 8.169361D+01 8.200829D+01 8.250178D+01 8.307349D+01 8.367916D+01 8.430389D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL STEP BTU TOTAL NET BTU  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -2.623321D+03 -7.287004D-02 -9.463071D+03 OL LIQUID -8.631281D+03 -2.397578D-01 -2.568502D+04  
LEFT FILM COEF .H = 4.650192E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.996906E+01 F  
RIGHT FILM COEF .H = 5.444218E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.996906D+01 F  
MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
8.430389D+01 8.367916D+01 8.307349D+01 8.250178D+01 8.200829D+01 8.169361D+01 8.173979D+01 8.240616D+01 8.396103D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL STEP BTU TOTAL NET BTU  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -2.094376D+03 -5.817713D-02 -9.712394D+03 OL LIQUID -7.362026D+02 -2.045008D-02 -2.691209D+03  
LEFT FILM COEF .H = 4.043779E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.996906E+01 F  
RIGHT FILM COEF .H = 4.009780E-01 BTU/HR.FT2.F LAST MESH K = 5.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
9.339390D+01 9.154763D+01 8.915192D+01 8.675765D+01 8.436448D+01 8.197209D+01 8.164664D+01 8.157974D+01 8.166844D+01  
8.183524D+01 8.203555D+01 8.224848D+01 8.246614D+01 8.269666D+01 8.375056D+01 8.481446D+01 8.587836D+01 8.694228D+01  
8.766914D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR  
0 0 0 -5.396136D-01 0 0  
1 0 0 0 0 0  
2 0 0 -1.533871D+00 0 0  
3 0 0 -1.533871D+00 0 0  
4 0 0 0 0 -1.808097D+05

COMP NO.	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	E N E R G Y (BTU)	C O N V E R G E N C E (DE/E)
1	1.47000D+01	7.34000D+01	0.	0
3	1.47001D+01	9.99707D+01	3.90489D+05	2.76146D-05

AIR MASS (LBM)	W A T E R M A S S (LBM)	H U M I D I T Y (LB MDL/S FT2)	C O N D E N S A T I O N (LB/S)	M A S S H E A T T R A N S F E R C O E F F I C I E N T S (BTU/S FT2 R)
0.	0.	0.	0.	0.
3.79274D+03	2.64385D+01	6.00000D-01	0.	0.
3	6.8332D+00	9.6128D+02	9.6128D+02	9.6128D+02

COMP. 3 LEAKAGE OUTFLOW- MASS= 6.8332D+00 LBM/HR ENERGY BTU/HR = 9.6128D+02 (NORMAL= 9.6128D+02 PENETRATION= 0.)  
 STEP AND NET MASS LOSSES LBM STEP VAPOR= 1.3140D-06 STEP AIR= 1.8850D-04 NET VAPOR= 1.3180D+00 NET AIR= 1.8908D+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.890764D+02 WATER VAPOR(LBM)= 1.318014D+00

\*\*\* TIME = 3.750000E+00 HR = 2.250000E+02 MIN = 1.350000E+04 SEC \*\*\*  
 HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. 3 VAPOR -1.203570D+03 -3.34251D-02 -4.266084D+03 -4.783317D-02 -6.745048D+03  
 LEFT FILM COEF. H = 2.000000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.377500E+01 F  
 RIGHT FILM COEF. H = 3.929091E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 1.000514D+02 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.548938D+01 8.511248D+01 8.477507D+01 8.446809D+01 8.418823D+01 8.394962D+01 8.379538D+01 8.379538D+01 8.405824D+01  
 8.613930D+01 8.82211D+01 9.030400D+01 9.238830D+01 9.401714D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. 0 LIQUID -4.296470D+03 -1.193464D-01 -1.611865D+04 -1.193464D-01 -1.611865D+04  
 LEFT FILM COEF. H = 4.748054E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT.F BULK TEMP = 1.000514E+02 F  
 RIGHT FILM COEF. H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.579370D+01 9.245913D+01 9.167896D+01 9.110316D+01 9.053205D+01 8.996812D+01 8.941290D+01 8.885461D+01 8.832147D+01  
 8.778167D+01 8.783498D+01 8.819392D+01 8.862333D+01 8.907858D+01 8.953871D+01 8.999870D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. 3 VAPOR -2.828129D+04 -7.855309D-01 -8.173043D+04 -7.855309D-01 -8.173043D+04  
 LEFT FILM COEF. H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF. H = 5.028364E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 1.000514D+02 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.621536D+01 8.606000D+01 8.643015D+01 8.742375D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. 0 LIQUID -2.416425D+03 -6.712293D-02 -8.927088D+03 -6.712293D-02 -8.927088D+03  
 LEFT FILM COEF. H = 5.445543E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 1.000514E+02 F  
 RIGHT FILM COEF. H = 4.646064E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.402637D+01 8.246208D+01 8.177900D+01 8.171657D+01 8.201975D+01 8.250683D+01 8.307570D+01 8.368038D+01 8.430463D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 TO RIGHT COMP. 3 VAPOR -8.642546D+03 -2.400707D-01 -2.740477D+04 -2.400707D-01 -2.740477D+04  
 LEFT FILM COEF. H = 4.646064E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF. H = 5.445543E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 1.000514D+02 F

CONTEMPT-LT/O28.30 APRIL 1978. EG&G IDAHO INC. CONTAINMENT SYSTEM PRESSURE-TEMPERATURE HISTORY PROGRAM  
COOPER NUCLEAR STATION CONTROL ROOM HEATUP ANALYSIS  
89/12/14

MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
8.430463D+01 8.368038D+01 8.307570D+01 8.250683D+01 8.201975D+01 8.171657D+01 8.177900D+01 8.246208D+01 8.402637D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -2.090618D+03 -5.807273D-02 -9.886767D+03 OLIIQUID -7.352610D+02 -2.042392D-02 -2.752520D+03  
LEFT FILM COEF. H = 4.041623E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 1.000514E+02 F  
RIGHT FILM COEF. H = 4.004421E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
9.348453D+01 9.163462D+01 8.922269D+01 8.681215D+01 8.440268D+01 8.199397D+01 8.156295D+01 8.158963D+01 8.167344D+01  
8.183741D+01 8.203637D+01 8.224879D+01 8.246632D+01 8.268688D+01 8.375080D+01 8.481474D+01 8.587868D+01 8.694262D+01  
8.766901D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
COMP. STEP-VAPOR NET-LIQUID NET-VAPOR  
0 0 -5.371770D-01 0.0  
1 0 0.0 0.0  
2 0 -1.534591D+00 0.0  
3 0 -1.854123D+05 0.0  
4 0 0.0 0.0

COMP NO.	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	A T M O S	P O O L	E N E R G Y	P O O L	T O T A L	C O N D E N S A T I O N (LB/S)	H U M I D I T Y	M A S S (LB)	T O T A L	T R A N S F E R C O E F F I C I E N T S
1	1.47000D+01	7.34000D+01	7.34000D+01	0.0	0.0	0.0	0.0	0.0	6.00000D-01	0.0	0.0	0.0
3	1.47001D+01	1.63045D-01	1.00053D+02	1.00053D+02	1.00053D+02	1.00053D+02	3.90486D+05	3.90486D+05	0.0	0.0	3.90486D+05	2.76114D-06
1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3	3.79218D+03	2.64346D+01	0.0	0.0	2.64346D+01	1.71204D-01	0.0	0.0	0.0	0.0	0.0	0.0
COMP	3 LEAKAGE OUTFLOW - MASS = 6.6404D+00 LB/HR	ENERGY BTU/HR = 9.3429D+02 (NOMINAL) = 9.3429D+02	PENETRATION = 0.0									
STEP	AND NET MASS LOSSES LB/HR	STEP VAPOR = 1.2769D-06	STEP AIR = 1.8318D-04	NET VAPOR = 1.3219D+00	NET AIR = 1.8963D+02							
TOTAL	NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM) = 1.896344D+02	WATER VAPOR(LBM) = 1.896344D+02	WATER VAPOR(LBM) = 1.896344D+02	WATER VAPOR(LBM) = 1.896344D+02	WATER VAPOR(LBM) = 1.896344D+02	WATER VAPOR(LBM) = 1.896344D+02	WATER VAPOR(LBM) = 1.896344D+02	WATER VAPOR(LBM) = 1.896344D+02	WATER VAPOR(LBM) = 1.896344D+02	WATER VAPOR(LBM) = 1.896344D+02	WATER VAPOR(LBM) = 1.896344D+02	WATER VAPOR(LBM) = 1.896344D+02

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
0 VAPOR -1.199623D+03 -3.33289D-02 -4.366217D+03 3 VAPOR -1.718682D+03 -4.774118D-02 -P.488407D+03  
LEFT FILM COEF. H = 2.00000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.375000E+01 F  
RIGHT FILM COEF. H = 3.926879E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 1.001314D+02 F  
MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
8.549154D+01 8.511495D+01 8.477701D+01 8.446984D+01 8.419089D+01 8.395492D+01 8.380389D+01 8.381287D+01 8.407997D+01  
8.617679D+01 8.827435D+01 9.031295D+01 9.247291D+01 9.410536D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
3 VAPOR -6.480574D+03 -1.800162D-01 -3.331870D+04 OLIIQUID -4.296174D+03 -1.193382D-01 -1.647668D+04  
LEFT FILM COEF. H = 4.757479E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT.F BULK TEMP = 1.001314E+02 F  
RIGHT FILM COEF. H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
9.592062D+01 9.261357D+01 9.182976D+01 9.123538D+01 9.064554D+01 9.006266D+01 8.948827D+01 8.892060D+01 8.835794D+01  
8.779856D+01 8.786293D+01 8.819657D+01 8.862469D+01 8.907875D+01 8.953875D+01 8.999987D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
OLIIQUID -7.987938D+03 -2.218875D-01 -3.563888D+04 3 VAPOR -2.835050D+04 -7.875137D-01 -8.409013D+04

LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.031036E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 1.001314D+02 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.625197D+01 8.610220D+01 8.647996D+01 8.747957D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -7.978465D+03 -2.216240D-01 -2.597361D+04 OLIIQID -2.413969D+03 -6.705471D-02 -9.128355D+03  
 LEFT FILM COEF .H = 5.446715E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 1.001314E+02 F  
 RIGHT FILM COEF .H = 4.641932E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.409086D+01 8.251755D+01 8.181824D+01 8.173982D+01 8.203153D+01 8.251211D+01 8.307802D+01 8.368164D+01 8.430535D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIIQID -2.617988D+03 -7.272190D-02 -9.899847D+03 3 VAPOR -8.652773D+03 -2.403548D-01 -2.812541D+04  
 LEFT FILM COEF .H = 4.641932E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF .H = 5.446715E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 1.001314D+02 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.430535D+01 8.368164D+01 8.307802D+01 8.251211D+01 8.173982D+01 8.181824D+01 8.251755D+01 8.409086D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.087160D+03 -5.797669D-02 -1.006084D+04 OLIIQID -7.343805D+02 -2.039946D-02 -2.813754D+03  
 LEFT FILM COEF .H = 4.039621E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 1.001314E+02 F  
 RIGHT FILM COEF .H = 3.999087E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.357215D+01 9.171861D+01 8.929114D+01 8.686502D+01 8.443993D+01 8.201558D+01 8.167921D+01 8.159967D+01 8.167857D+01  
 8.183967D+01 8.203725D+01 8.224913D+01 8.246652D+01 8.268709D+01 8.375100D+01 8.481492D+01 8.587884D+01 8.694276D+01  
 8.766869D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP.	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
0	0	0	0	0
1	0	0	0	0
2	0	0	0	0
3	0	0	0	0
4	0	0	0	0

COMP NO.	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	E N E R G Y (BTU)	C O N V E R G E N C E (DE/E)
1	TOTAL	ATMOS	POOL	TOTAL
1	1.470000D+01	7.340000D+01	7.340000D+01	0
3	1.470010D+01	1.001330D+02	1.001330D+02	3.904830D+05
A I R M A S S ( L B M )				
W A T E R M A S S ( L B M )		H U M I D I T Y ( L B / S )		C O N D E N S A T I O N ( L B / S )
1	0	0	0	0
3	3.79164D+03	2.64308D+01	6.00000D-01	0
C O M P 3 L E A K A G E O U T F L O W M A S S = 6.4693D+00 L B M / H R E N E R G Y B T U / H R = 9.1035D+02 ( N O R M A L = 9.1035D+02 P E N E T R A T I O N = 0 )				
S T E P A N D N E T M A S S L O S S E S L B M S T E P V A P O R = 1.2440D-06 S T E P A I R = 1.7846D-04 N E T V A P O R = 1.3257D+00 N E T A I R = 1.9018D+02				
T O T A L N E T C O N T A I N M E N T L O S S T O A T M O S P H E R E I S 0 A I R ( L B M ) = 1.901766D+02 W A T E R V A P O R ( L B M ) = 1.325684D+00				

\*\*\*\*\* TIME = 3.916667E+00 HR = 2.350000E+02 MIN = 1.410000E+04 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 0 VAPOR -1.195694D+03 -3.321375D-02 -4.466022D+03 3 VAPOR -1.715768D+03 -4.766024D-02 -8.631507D+03

LEFT FILM COEF. H = 2.00000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.372500E+01 F  
 RIGHT FILM COEF. H = 3.924900E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 1.002095D+02 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.549359D+01 8.511736D+01 8.477896D+01 8.447166D+01 8.396035D+01 8.381404D+01 8.382916D+01 8.410143D+01  
 8.621336D+01 8.832602D+01 9.043969D+01 9.255467D+01 9.419069D+01

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -6.422163D+03 -1.783937D-01 -3.385631D+04 OLIQUID -4.295847D+03 -1.193291D-01 -1.683468D+04  
 LEFT FILM COEF. H = 4.766684E-01 BTU/HR.FT2.F FIRST MESH K = 3.500000E-02 BTU/HR.FT. BULK TEMP = 1.002095E+02 F  
 RIGHT FILM COEF. H = 1.000000E+04 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 9.604478D+01 9.276350D+01 9.197600D+01 9.136365D+01 9.075571D+01 9.015454D+01 8.956158D+01 8.897518D+01 8.839367D+01  
 8.781537D+01 8.787099D+01 8.819952D+01 8.862548D+01 8.907893D+01 8.953878D+01 8.999987D+01

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIQUID -7.909310D+03 -2.197034D-01 -3.630127D+04 3 VAPOR -2.841554D+04 -7.893204D-01 -8.645540D+04  
 LEFT FILM COEF. H = 4.785000E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF. H = 5.033526E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 1.002095D+02 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.628887D+01 8.614447D+01 8.652963D+01 8.753497D+01

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -7.987226D+03 -2.218673D-01 -2.659885D+04 OLIQUID -2.411515D+03 -6.698655D-02 -9.329417D+03  
 LEFT FILM COEF. H = 5.447781E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 1.002095E+02 F  
 RIGHT FILM COEF. H = 4.637794E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.415454D+01 8.257256D+01 8.185748D+01 8.176335D+01 8.204362D+01 8.251762D+01 8.308046D+01 8.368293D+01 8.430606D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 OLIQUID -2.615327D+03 -7.264798D-02 -1.011790D+04 3 VAPOR -8.662274D+03 -2.406187D-01 -2.884688D+04  
 LEFT FILM COEF. H = 4.637794E-01 BTU/HR.FT2.F FIRST MESH K = 1.050000E+00 BTU/HR.FT. BULK TEMP = 9.000000E+01 F  
 RIGHT FILM COEF. H = 5.447781E-01 BTU/HR.FT2.F LAST MESH K = 1.050000E+00 BTU/HR.FT.F BULK TEMP = 1.002095D+02 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 8.430606D+01 8.368293D+01 8.308046D+01 8.251762D+01 8.204362D+01 8.176335D+01 8.185748D+01 8.257256D+01 8.415454D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU TO RIGHT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU  
 3 VAPOR -2.084128D+03 -5.789247D-02 -1.023464D+04 OLIQUID -7.335547D+02 -2.037652D-02 -2.874918D+03  
 LEFT FILM COEF. H = 4.037830E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 1.002095E+02 F  
 RIGHT FILM COEF. H = 3.993774E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F). LEFT TO RIGHT  
 9.365692D+01 9.179978D+01 8.935741D+01 8.691634D+01 8.447628D+01 8.203693D+01 8.169541D+01 8.160967D+01 8.168387D+01  
 8.184202D+01 8.203818D+01 8.224949D+01 8.246672D+01 8.268729D+01 8.375115D+01 8.481501D+01 8.587887D+01 8.694273D+01  
 8.766822D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU  
 COMP. STEP-LIQUID STEP-VAPOR NET-LIQUID NET-VAPOR NET  
 0 0 0 -5.322573D-01 0 -7.992421D+04  
 1 0 0 0 0 0  
 2 0 0 -1.535753D+00 0 -1.946236D+05  
 3 0 0 0 0 0  
 4 0 0 0 0 0

COMP NO.	P R E S S U R E (PSIA)	T E M P E R A T U R E (F)	A T M O S	E N E R G Y P O O L	(BTU) T O T A L	C O N V E R G E N C E D E / E
1	1.470000+01	7.340000+01	0.	0.	0.	0
3	1.470010+01	1.002110+02	3.904790+05	0.	3.904790+05	2.76058D-05
AIR MASS (LBM) W A T E R M A S S (LBM) H U M I D I T Y C O N D E N S A T I O N (LB MOL/S FT2)(BTU/S FT2 R) VAPOR--ATMOS--LIQUID POOL 0. 0. 0. 6.000000-01 0. 0. 3. 7.91110D+03 2.64271D+01 0. 2.64271D+01 1.70389D-01 0.						
COMP. 3 LEAKAGE OUTFLOW- MASS= 6.3278D+00 LBM/HR ENE .Y BTU/HR = 8.9054D+02 PENETRATION= 0. STEP AND NET MASS LOSSES LBM STEP VAPOR= 1.2169D-06 STEP .R= 1.7455D-04 NET VAPOR= 1.3294D+00 NET AIR= 1.9071D+02 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 .A.R.(LBM)= 1.907060D+02 WATER VAPOR(LBM)= 1.329374D+00						

\*\*\*\*\* TIME = 4.00000E+00 HR = 2.40000E+02 MIN = 1.44000E+04 SEC \*\*\*\*\*

HEAT STRUCTURE 1 BETWEEN COMPARTMENTS 0 AND 3 NORTH WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
0 VAPOR	-1.191782D+03	-3.310507D-02	-4.565500D+03	3 VAPOR	-1.7132274D+03	-4.759095D-02	-8.774380D+03
LEFT FILM COEF .H = 2.00000E-01 BTU/HR.FT2.F	FIRST MESH K = 1.050000E+00 BTU/HR.FT.F	BULK TEMP = 9.370000E+01 F		RIGHT FILM COEF .H = 3.923166E-01 BTU/HR.FT2.F	LAST MESH K = 6.700000E-02 BTU/HR.FT.F	BULK TEMP = 1.002861D+02 F	
MESH POINT TEMPERATURES (F). LEFT TO RIGHT							
8.549553D+01	8.511973D+01	8.478094D+01	8.447355D+01	8.396592D+01	8.382429D+01	8.384538D+01	8.412265D+01
8.624908D+01	8.837621D+01	9.050434D+01	9.263373D+01	9.427332D+01			

HEAT STRUCTURE 2 BETWEEN COMPARTMENTS 3 AND 0 ROOF & CEILING

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
3 VAPOR	-6.365509D+03	-1.768200D-01	-3.438911D+04	OLIGUID	-4.295489D+03	-1.193191D-01	-1.719265D+04
LEFT FILM COEF .H = 4.775701E-01 BTU/HR.FT2.F	FIRST MESH K = 3.500000E-02 BTU/HR.FT.F	BULK TEMP = 1.002861E+02 F		RIGHT FILM COEF .H = 1.000000E+04 BTU/HR.FT2.F	LAST MESH K = 1.050000E+00 BTU/HR.FT.F	BULK TEMP = 9.000000D+01 F	
MESH POINT TEMPERATURES (F). LEFT TO RIGHT							
9.616585D+01	9.290909D+01	9.211788D+01	9.148815D+01	9.086270D+01	8.963293D+01	8.902843D+01	8.842869D+01
8.783210D+01	8.787915D+01	8.820246D+01	8.862632D+01	8.907913D+01	8.953882D+01	8.999987D+01	

HEAT STRUCTURE 3 BETWEEN COMPARTMENTS 0 AND 3 FLOOR

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
OLIGUID	-7.830142D+03	-2.175043D-01	-3.695708D+04	3 VAPOR	-2.847709D+04	-7.910301D-01	-8.882595D+04
LEFT FILM COEF .H = 4.785000E-01 BTU/HR.FT2.F	FIRST MESH K = 1.050000E+00 BTU/HR.FT.F	BULK TEMP = 1.002861D+02 F		RIGHT FILM COEF .H = 5.035864E-01 BTU/HR.FT2.F	LAST MESH K = 1.050000E+00 BTU/HR.FT.F	BULK TEMP = 1.002861D+02 F	
MESH POINT TEMPERATURES (F). LEFT TO RIGHT							
8.632601D+01	8.618691D+01	8.657917D+01	8.758995D+01				

HEAT STRUCTURE 4 BETWEEN COMPARTMENTS 3 AND 0 SOUTH WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
3 VAPOR	-7.995463D+03	-2.220962D-01	-2.726480D+04	OLIGUID	-2.409061D+03	-6.691896D-02	-9.530274D+03
LEFT FILM COEF .H = 5.448765E-01 BTU/HR.FT2.F	FIRST MESH K = 1.050000E+00 BTU/HR.FT.F	BULK TEMP = 1.002861E+02 F		RIGHT FILM COEF .H = 4.633648E-01 BTU/HR.FT2.F	LAST MESH K = 1.050000E+00 BTU/HR.FT.F	BULK TEMP = 9.000000D+01 F	
MESH POINT TEMPERATURES (F). LEFT TO RIGHT							
8.421742D+01	8.262713D+01	8.189672D+01	8.178714D+01	8.205601D+01	8.308303D+01	8.368425D+01	8.430677D+01

HEAT STRUCTURE 5 BETWEEN COMPARTMENTS 0 AND 3 WEST WALL

TO LEFT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU	TO RIGHT COMP.	END STEP BTU/HR	STEP BTU	TOTAL NET BTU
OLIGUID	-2.612665D+03	-7.257403D-02	-1.033573D+04	3 VAPOR	-8.671207D+03	-2.408668D-01	-2.956911D+04
LEFT FILM COEF .H = 4.633648E-01 BTU/HR.FT2.F	FIRST MESH K = 1.050000E+00 BTU/HR.FT.F	BULK TEMP = 1.002861E+02 F		RIGHT FILM COEF .H = 5.448765E-01 BTU/HR.FT2.F	LAST MESH K = 1.050000E+00 BTU/HR.FT.F	BULK TEMP = 1.002861D+02 F	

89/12/14.

MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 8.430677D+01 8.368425D+01 8.308303D+01 8.252334D+01 8.205601D+01 8.178714D+01 8.189672D+01 8.262713D+01 8.421742D+01

HEAT STRUCTURE 6 BETWEEN COMPARTMENTS 3 AND 0 EAST WALL  
 TO LEFT COMP. END STEP BTU/HR STEP BTU TOTAL NET BTU STEP BTU TOTAL NET BTU  
 3 VAPOR -2.081547D+C3 -5.782076D-02 -1.040821D+04 OIL/OIL -7.327779D+02 -2.035494D-02 -2.936015D+03  
 LEFT FILM COEF. H = 4.036264E-01 BTU/HR.FT2.F FIRST MESH K = 6.700000E-02 BTU/HR.FT. BULK TEMP = 1.002861E+02 F  
 RIGHT FILM COEF. H = 3.988480E-01 BTU/HR.FT2.F LAST MESH K = 6.700000E-02 BTU/HR.FT.F BULK TEMP = 9.000000D+01 F  
 MESH POINT TEMPERATURES (F), LEFT TO RIGHT  
 9.373903D+01 9.187831D+01 8.942163D+01 8.696221D+01 8.451177D+01 8.205803D+01 8.171154D+01 8.161981D+01 8.168919D+01  
 8.184446D+01 8.203916D+01 8.224287D+01 8.246694D+01 8.268750D+01 8.375126D+01 8.481502D+01 8.587879D+01 8.694254D+01  
 8.766759D+01

SUMMARY OF HEAT TRANSFER TO COMPARTMENTS BY HEAT STRUCTURES - UNITS ARE BTU

COMP.	STEP-LIQUID	STEP-VAPOR	NET-LIQUID	NET-VAPOR
1	0.	-5.297758D-01	0.	-8.151725D+04
2	0.	0.	0.	0.
3	0.	-1.536225D+00	0.	-1.992316D+05
4	0.	0.	0.	0.

COMP NO.	P R E S S U R E (PSIA)			T E M P E R A T U R E (F)			E N E R G Y (BTU)			CONVERGENCE DE/E
	TOTAL	STEAM	ATMOS	ATMOS	POOL	TOTAL	ATMOS	POOL	TOTAL	
1	1.47000D+01	0.	7.34000D+01	0.	0.	0.	0.	0.	0.	0.
3	1.47001D+01	1.63045D-01	1.00288D+02	1.00288D+02	1.00288D+02	3.90476D+05	3.90476D+05	0.	3.90476D+05	2.76033D-06

AIR MASS (LBM)	W A T E R M A S S (LBM)		H U M I D I T Y (LB/S)		T R A N S F E R C O E F F I C I E N T S (BTU/S FT2 R)	
	VAPOR	ATMOS	LIQUID	POOL	CONDENSATION	HEAT
1	0.	0.	0.	0.	0.	0.
3	3.79059D+03	2.64235D+01	0.	0.	2.64235D+01	1.69996D-01

COMP. 3 LEAKAGE DUTIFLOW- MASS= 6.2008D+00 LBM/HR ENERGY BTU/HR = 8.7279D+02 (NORMAL= 8.7279D+02 PENETRATION= 0.)  
 STEP AND NET MASS LOSSES LBM STEP VAPOR= 1.1924D-06 STEP AIR= 1.7105D-04 NET VAPOR= 1.3300D+00 NET AIR= 1.9422D+02  
 TOTAL NET CONTAINMENT LOSS TO ATMOSPHERE IS 0 AIR(LBM)= 1.912243D+02 WATER VAPOR(LBM)= 1.332987D+00

\*\*\*\*\* COMPUTER TIME FOR THIS CASE WAS 15.7214 MIN.  
 \*\*\*\*\* COMPUTER TIME FOR ALL JOBS WAS 15.7217 MIN.



LOCAL FILE INFORMATION

FILENAME	LENGTH/PRUS	TYPE	STATUS	FS	LEVEL
INPUT	10	IN *	EOR	NAD	
PROC1	1	LO	EOR		
OUTPUT	039	LO	EOR WRITE		
Z7ZINFO	1	LO	BOI		
CNTMPT	15	LO	EOR		
DOUNGUZ	1	LO	BOI		
OFXTGJM	1	LO	BOI		
UBOF26Z	1	LO	BOI		
LY28ABS	1171	PM *	EOR		
MU39BCT	1	LO	BOI		

TOTAL = 10



```

18.15.03. * GET THE APPLICATION INPUT FILE
18.15.03. * GET THE NONE TABLE
18.15.03. IFE, $NONE$.EQ. $NONE$.GETUSERS.
18.15.03. RETURN, TAPE15.
18.15.03. ATTACHP, CTMPTBLT28, JUL82, O, QALIB.
18.15.07. STOP
18.15.07. 035200 MAXIMUM EXECUTION FL.
18.15.07. 0.114 CP SECONDS EXECUTION TIME.
18.15.07. ELSE, GETUSERS.
18.15.07. ENDIF, GETUSERS.
18.15.07. * *****
18.15.07. * GET THE APPLICATION PROGRAM
18.15.07. * ATTACHP, CNTMPTLT28, JUL82, O, QALIB.
18.15.07. * *****
18.15.07. ATTACHP, CNTMPTLT28, JUL82, O, QALIB.
18.15.09. STOP
18.15.09. 035200 MAXIMUM EXECUTION FL.
18.15.09. 0.085 CP SECONDS EXECUTION TIME.
18.15.09. REWIND, TAPE15.
18.15.09. REDUCE, -
18.15.09. RFL, CM=360000, EC=1.
18.15.09. DF, ON.
18.15.09. * *****
18.15.09. * JOB DAYFILE ON *
18.15.09. * *****
18.15.09. LT28ABS(INPUT, OUTPUT, PL=9999999)
18.15.10. * *****
18.15.10. * CONTEMPT LT-28 FROM NESC (ARGONNE). *
18.15.10. * INCLUDES ENERGY INC. MODIFICATIONS *
18.15.10. * TO FIX THE MK I & MK II MODELS, *
18.15.10. * AND THE PRESSURE-FLASH MODEL *
18.15.10. * (E.I. IDENTS 'PSFIX'+ 'PFLFIX', AS *
18.15.10. * IDENT 'PSPFL-FIX' IN THIS SOURCE). *
18.15.10. * INCLUDES PLOTTING CAPABILITY VIA *
18.15.10. * CALCOMP-PCCPOST ('IDENT 'UCCPLOT'). *
18.15.10. * UCC INSTALLATION DATE- 14 JULY 82. *
18.15.10. * PCC RE-INSTALLATION ON NDS2- 18AUG89*
18.15.10. * *****
18.32.49. STOP
18.32.49. 360000 FINAL EXECUTION FL.
18.32.49. 943.318 CP SECONDS EXECUTION TIME.
18.32.49. DF, OFF.
18.32.49. * *****
18.32.49. * JOB DAYFILE OFF *
18.32.49. * *****
18.32.50. DF, ON.
18.32.50. * *****
18.32.50. * JOB DAYFILE ON *
18.32.50. * *****
18.32.50. * *
18.32.50. * *****
18.32.50. * *
18.32.50. * * CONTEMPT-LT28 NORMAL TERMINATION *
18.32.50. * *
18.32.50. * *****
18.32.50. *
18.32.50. REVERT.
18.32.50. RFL( EC=277)
18.32.50. ENQUIRE, F.
18.32.50. ENQUIRY COMPLETE.
18.32.50. UEPF, 0.155KUN$.
18.32.50. UEMS, 6.607KUN$.
18.32.50. UECF, 944.044SECS.
18.32.50. SRU, 2004.747UNTS.
18.32.50. $OUT(* /OP=E)

```

FCC

11 32 50 10 FILES PROCESSED.  
16 77 50 \$DAYFILEFD, (PUT, JT=0)  
18 32 50 IARG. 10108 SDBS FN-OUTPUT  
18 31 50 POWER COMPUTING/990 - MDS 2 7 1 10  
18 32 50 DATE: 89/12/14.  
18 32 50 JSN: MOFK



• INFO

NP1104F 0021004713

BHHP0001 ZC2025

LINE 06 MULT K