

Duke Power Company
Nuclear Production Department
P.O. Box 1007
Charlotte, NC 28201-1007

(704)373-4011



DUKE POWER

January 31, 1991

Subject: Catawba Nuclear Station, Units 1 & 2
Selected Licensee Commitments Manual
Revision 2

Please find attached a copy of Revision 2 to the subject manual.

Update your manual as follows:

Remove these pages

Insert these pages

LOEP1,2,3
16.2-1

LOEP1,2,3
16.2-1

If you have any questions, please contact me at 373-7567.

R.L. Gill, Jr. Technical System Manager
Regulatory Compliance

Jerel Reavis
Jerel Reavis
Regulatory Compliance

*Aool
1/1*

9102110257 910131
PDR ADOCK 05000413
PDR

DUKE POWER COMPANY
CATAWBA NUCLEAR STATION
SELECTED LICENSEE COMMITMENTS
MANUAL
LIST OF EFFECTIVE PAGES

<u>Page</u>	<u>Revision Date</u>
LOEP 1	1/91
LOEP 2	12/90
LOEP 3	7/90
<u>Tab 16.0</u>	
16.0-1	12/90
<u>Tab 16.1</u>	
16.1-1	
<u>Tab 16.2</u>	
16.2-1	
16.2-2	1/91
16.2-3	
<u>Tab 16.3</u>	
<u>Tab 16.4</u>	
<u>Tab 16.5</u>	
<u>Tab 16.6</u>	
<u>Tab 16.7</u>	
<u>Tab 16.8</u>	
<u>Tab 16.9</u>	
16.9-0	12/90
16.9-1	12/90
16.9-2	12/90
16.9-3	12/90
16.9-4	12/90

<u>Page</u>	<u>Revision Date</u>
16.9-5	12/90
16.9-6	12/90
16.9-7	12/90
16.9-8	12/90
16.9-9	12/90
16.9-10	12/90
16.9-11	12/90
16.9-12	12/90
16.9-13	12/90
16.9-14	12/90
16.9-15	12/90
16.9-16	12/90
16.9-17	12/90
Table 16.9-3 1 of 5	12/90
Table 16.9-3 2 of 5	12/90
Table 16.9-3 3 of 5	12/90
Table 16.9-3 4 of 5	12/90
Table 16.9-3 5 of 5	12/90
<u>Tab 16.10</u>	
<u>Tab 16.11</u>	
<u>Tab 16.12</u>	
<u>Tab 16.13</u>	
16.13-0	12/90
16.13-1	12/90

Page

Revision Date

Tab 16.14

Tab 16.15

Appendix

Directive 3.1.5 1 of 7

Directive 3.1.5 2 of 7

Directive 3.1.5 3 of 7

Directive 3.1.5 4 of 7

Directive 3.1.5 5 of 7

Directive 3.1.5 6 of 7

Directive 3.1.5 7 of 7

Directive 3.1.5 Attachment 1 1 of 1

Directive 3.1.5 Attachment 2 1 of 1

Directive 3.1.5 Attachment 3 1 of 1

Directive 3.1.5 Attachment 4 1 of 1

Directive 3.1.5 Attachment 5 1 of 1

16.2 APPLICABILITY

This section provides the general requirements applicable to each of the commitments and Testing Requirements within Section 16.0, Selected Licensee Commitments (SLCs).

16.2.1 Compliance with the SLCs is required as specified. When a Commitment is not met, the associated Remedial Action(s) shall be met.

16.2.2 Noncompliance with a Commitment exists when the requirements of both the Commitment and the specified Remedial Action are not met within the specified time. If compliance with a Commitment is restored prior to expiration of the specified time interval completion of the Remedial Action(s) is not required.

16.2.3 Where corrective measures are completed that permit operation under the Remedial Actions, the action may be taken within the specified time limits, as measured from the time of failure to meet the Commitment.

16.2.4 Entry into an OPERATIONAL MODE or other specified condition shall not be made when the conditions for the Commitment are not met and the associated Remedial Action requires a shutdown if they are not met within a specified time interval. Entry into an OPERATIONAL MODE or specified condition may be made in accordance with the Remedial Action requirements when conformance to them permits continued operation of the facility for an unlimited period of time. This provision shall not prevent passage through or to OPERATIONAL MODES as required to comply with Remedial Action requirements. Exceptions to these requirements are stated in the individual commitments.

16.2.5 Commitments including the associated Remedial Actions shall apply to each unit individually unless otherwise indicated as follows:

- a. Whenever the Commitment refers to systems or components which are shared by both units, the Remedial Actions will apply to both units simultaneously. This will be indicated in the Remedial Actions;
- b. Whenever the Commitment applies to only one unit, this will be identified in the APPLICABILITY section of the Commitment; and
- c. Whenever certain portions of a Commitment contain operating parameters, setpoints etc., which are different for each unit, this will be identified in parentheses or footnotes. (for example, "...flow rate of 54,000 cfm (Unit 1) or 43,000 cfm (Unit 2)...").

16.2.6 Testing Procedures shall be performed during the OPERATIONAL MODES or other conditions specified for an individual commitment unless otherwise stated in an individual Testing Procedure or Reference.

16.2.7 Each Testing Procedure shall be performed on its specified frequency with a maximum allowable extension not to exceed 25% of the test frequency. The phrase "at least" associated with a testing frequency does not negate this tolerance value, and permits the performance of more frequent surveillance