

BOSTON EDISON COMPANY
GENERAL OFFICES 800 BOYLSTON STREET
BOSTON, MASSACHUSETTS 02199

A. V. MORISI
MANAGER
NUCLEAR OPERATIONS SUPPORT DEPARTMENT

December 6, 1982

BECO. Ltr. #82-304

Mr. Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

License No. DF-35
Docket No. 50-293

Response to Information Survey
on PNPS Emergency Operations Facility

Dear Sir:

The following information is offered in response to a verbal request from Mr. K. Eccleston of your staff concerning the Primary and Backup Emergency Operations Facility (EOF) at Pilgrim Station.

Permanent Primary EOF

<u>Location</u>	- On-site, approximately 1/4 mile from the reactor building
<u>Structure Type</u>	- Prefabricated aluminum and wood frame permanently installed mobile office structures
<u>Protection Factor</u>	- 1.0
<u>Date Started</u>	- Structures were first moved on-site in June 1980
<u>Construction Status</u>	- Complete and operational in March 1981
<u>HEPA Filters</u>	- No

Permanent Backup EOF

<u>Location</u>	- 19 miles from site
<u>Structure Type</u>	- Brick and concrete

A045

BOSTON EDISON COMPANY

Mr. Domenic B. Vassallo, Chief
December 6, 1982
Page 2

Date Started - Existing structure (Massachusetts
State Emergency Operations Facility)
Construction Status - Complete

For further information on this subject please refer to BECo Letter #81-121,
dated June 1, 1981 "Response to NRC Generic Letter #81-10".

Very truly yours,

