



PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4502

December 6, 1982

JOHN S. KEMPER
VICE-PRESIDENT
ENGINEERING AND RESEARCH

Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Docket Nos. 50-352
50-353

Subject: Limerick Generating Station Units 1 and 2
Request for Information on Emergency
Operations Facility

Dear Mr. Schwencer:

In accordance with Dr. Harvey Abelson's verbal request of December 3, 1982 for information on the Limerick Emergency Operations Facility (EOF), we are pleased to provide you with the answers to the following questions:

1. On what date did Philadelphia Electric Company respond to generic letter 81-10, dated 2-18-81, on EOF's?

Answer: March 20, 1981 via letter from J. S. Kemper to D. G. Eisenhut.

2. From the emergency plan, what is the permanent EOF location?

Answer: As stated in section 7.1.2 of the Emergency Plan, the EOF is located at Philadelphia Electric Company's Plymouth Service Building, 17 miles from the site.

3. What type of structure is the EOF?

Answer: The EOF will be located in the windowless basement of an existing concrete and steel framed masonry building.

4. What is the protection factor of the EOF?

Answer: Because of the EOF's distance from the site, no protection factor is being identified. This is in accordance with NUREG-0696.

8212100090 821206
PDR ADOCK 05000352
F PDR

3029

5. When was construction started?

Answer: The structure is complete. All construction will be complete by September, 1983.

6. What is the status of construction of the structure only?

Answer: The structure is complete.

7. Are HEPA filters installed at the EOF?

Answer: No, because of the distance from the site HEPA filters are not required by NUREG-0696.

8. Where is the permanent back-up EOF?

Answer: There is no back-up EOF.

9. Where is the interim primary EOF located?


Answer: As the plant is not operating, there is no interim primary EOF.

10. Where is the interim back-up EOF located?

Answer: There is no interim back-up EOF.

We trust these responses satisfy your need for this information.

Very truly yours,



J. S. Kemper

JTR/pb/C-12

cc: See attached service list

cc: Judge Lawrence Brenner
Judge Richard F. Cole
Judge Peter A. Morris
Troy B. Conner, Jr., Esq.
Ann P. Hodgdon
Mr. Frank R. Romano
Mr. Robert L. Anthony
Mr. Marvin I. Lewis
Judith A. Dorsey, Esq.
Charles W. Elliott, Esq.
Mr. Alan J. Noguee
Robert W. Adler, Esq.
Mr. Thomas Gerusky
Director, Pennsylvania Emergency Management Agency
Mr. Steven P. Hershey
James M. Neill, Esq.
Donald S. Bronstein, Esq.
Mr. Joseph H. White, III
Dr. Judith H. Johnsrud
Walter W. Cohen, Esq.
Robert J. Sugarman, Esq.
Mr. W. Wilson Goode
Atomic Safety and Licensing Appeal Board
Atomic Safety and Licensing Board Panel
Docket and Service Section