

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

February 6, 1991

United States Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555

Serial No. 91-013  
NO/ETS  
Docket No. 50-281  
License No. DPR-37

Gentlemen:

**VIRGINIA ELECTRIC AND POWER COMPANY**  
**SURRY POWER STATION UNIT 2**  
**PROPOSED TECHNICAL SPECIFICATION FOR THE**  
**MAIN CONTROL ROOM AND EMERGENCY SWITCHGEAR**  
**ROOM AIR HANDLING UNITS**

Pursuant to 10 CFR 50.90, the Virginia Electric and Power Company requests an amendment, in the form of a change to the Technical Specifications, for Surry Power Station Unit 2. As part of our effort to upgrade the Main Control Room (MCR) and Emergency Switchgear Room (ESGR) air conditioning system, the Unit 2 air handling units (AHU) are scheduled to be replaced during the upcoming refueling outage. Installation of new Unit 2 air handling units will return the system to the original AHU design configuration. The proposed Technical Specification change eliminates the present interim operating restrictions for the Unit 2 ESGR air handling units and provides technical specifications consistent with the permanent AHU design configuration. This change is consistent with our previous Technical Specification change request for Unit 1, dated June 26, 1990 (Serial No. 90-271) and the corresponding previous Technical Specification amendment No. 145, issued October 11, 1990. The proposed change for Unit 2 is included in Attachment 1. We are requesting that the Technical Specification become effective when the Unit 2 AHUs are installed and operational at the end of the Unit 2 refueling outage.

In addition, preparatory work to support the installation of additional chiller capacity will also be performed during the Unit 2 refueling outage. Installation of the additional safety-related chiller capacity will occur as non-outage work following Unit 2 refueling. The schedule for installation of this additional chiller capacity has not yet been finalized, although it is our intention to initiate this activity late in 1991 or early 1992.

*A001*  
*1/11*

This request has been reviewed and approved by the Station Nuclear Safety and Operating Committee and the Management Safety Review Committee. It has been determined that the proposed changes do not involve an unreviewed safety question as defined in 10 CFR 50.59 or a significant hazards consideration as defined in 10 CFR 50.92. The basis for our no significant hazards consideration determination is included in Attachment 2.

Very truly yours,



W. L. Stewart  
Senior Vice President - Nuclear

Attachments

cc: U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, N. W.  
Suite 2900  
Atlanta, Georgia 30323

Mr. W. E. Holland  
NRC Senior Resident Inspector  
Surry Power Station

Commissioner  
Department of Health  
Room 400  
109 Governor Street  
Richmond, Virginia 23219

COMMONWEALTH OF VIRGINIA )  
 )  
COUNTY OF HENRICO )

The foregoing document was acknowledged before me, in and for the County and Commonwealth aforesaid, today by W. L. Stewart who is Senior Vice President - Nuclear, of Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 6<sup>TH</sup> day of February, 1991.

My Commission Expires: May 31, 1994.

Vicki L. Hull  
Notary Public

(SEAL)