

Appendix

NOTICE OF VIOLATION

Wisconsin Public Service
Corporation

Docket No. 50-305

As a result of the inspection conducted on September 1-October 31, 1982, and in accordance with the NRC Enforcement Policy, 47 PR 9987 (March 9, 1982), the following violation was identified:

Technical Specification 4.1.a states, "Calibration, testing, and checking of protective instrumentation channels and testing of logic channels shall be performed as specified in Table 4.1-1." Technical Specification Table 4.1-1, item 19, requires a monthly test of all Radiation Monitoring System Channels. Technical Specification 4.1.c states, in part, "Specified time intervals may be adjusted plus or minus 25% to accommodate normal test procedures."


Contrary to the above, the monthly Surveillance Test for Radiation Monitoring Channels R-11 and 12 was performed on September 2, 1982, and subsequently performed on October 23, 1982. This time interval exceeds the requirements of your Technical Specifications 4.1.a and 4.1.c.

This is a Severity Level IV violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice a written statement or explanation in reply, including for each item of noncompliance: (1) corrective action taken and the results achieved; (2) corrective action to be taken to avoid further noncompliance; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

NOV 23 1982

Dated _____



R. L. Spessard, Director
Division of Project and
Resident Programs