

DCS

JAN 30 1991

Docket No. 50-353

Philadelphia Electric Company
ATTN: Mr. D. M. Smith
Senior Vice President-Nuclear
Correspondence Control Desk
P. O. Box 195
Wayne, Pennsylvania 19087-0195

Gentlemen:

Subject: Inspection No. 50-353/50-26

Enclosed is the report of the team inspection conducted by Mr. L. S. Cheung and other NRC inspectors from November 26 to November 30, 1990, and subsequent staff review through December 12, 1990 at the Philadelphia Electric Company Corporate Office and Limerick Generating Station Unit 2.

The team's findings were discussed with members of your staff at the conclusion of the inspection on November 30, 1990, and on December 12, 1990, following the completion of the staff review of the qualification documents for the containment high range radiation monitors. The inspection reviewed your program for establishing and maintaining the qualification of electric equipment within the scope of 10 CFR 50.49. Within these areas the inspection consisted of reviews of selected procedures and environmental qualification packages, interviews with personnel, observations and a physical walkdown verification of specific electrical equipment.

The inspection determined that you have implemented a program to meet the requirements of 10 CFR 50.49. An uncited violation was identified regarding the completeness of an environmental qualification file. The finding is not being cited because of its isolated nature and subsequent determination that the equipment was qualified. Within the scope of this inspection, no violations were observed.

No reply to this letter is required. Your cooperation with us in this matter is appreciated.

Sincerely,

Original Signed By:
Marvin W. Hodges

Marvin W. Hodges, Director
Division of Reactor Safety

Enclosure: NRC Region I Inspection Report Number 50-353/90-26

OFFICIAL RECORD COPY

IR LIM2 90-26 - 0001.0.0
01/22/91

9102120126 910130
PDR ADOCK 05000353
PDR

IE:01

JAN 30 1991

Philadelphia Electric Company 2

cc w/encl:

R. Lees, Chairman, Nuclear Review Board
G. Leitch, Vice President - Limerick Generating Station
D. Helwig, Vice President of Nuclear Engineering and Services
J. Durham, Sr., Vice President and General Council
M. McCormick, Jr., Manager - Limerick Generating Station
G. Hunger, Jr., Director - Licensing Section
J. Doering, Project Manager - Limerick Generating Station
J. O'Rourke, Manager - Limerick Quality Division
G. Madsen, Regulatory Engineer - Limerick Generating Station
Secretary, Nuclear Committee of the Board
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
K. Abraham, PAO (24) SALP Reports and (2) All Inspection Reports
NRC Resident Inspector
Commonwealth of Pennsylvania

bcc w/encl:

Region I Docket Room (with concurrences)
Management Assistant, DRMA (w/o encl)
R. Bellamy, DRSS
R. Blough, DRP
P. Kaufman, DRP
L. Doerflein, DRP
M. Miller, SLO
J. Caldwell, EDO
R. Clark, NRR
R. McBrearty, DRS
C. McCracken, DRS
U. Potapovs, DRS

RI:DRS
Cheung/vhd
LC
1/25/91

RI:DRS
Anderson
JA
1/27/91

ad
RI:DRS
Durr

1/28/91

RI:DRS
Hodges
Murf

1/30/91

OFFICIAL RECORD COPY

IR LIM2 90-26 - 0002.0.0
01/22/91