

Appendix

NOTICE OF VIOLATION

Union Electric Company

Docket No. 50-483

As a result of the inspection conducted on October 1-31, 1982, and in accordance with the NRC Enforcement Policy, 47 FR 9987 (March 9, 1982), the following violation was identified:

10 CFR 50, Appendix B,, Criterion III, Design Control, states, "Measures shall be established to assure that applicable regulatory requirements are correctly translated into specifications, drawings, procedures and instructions. These measures shall include provisions to assure that appropriate quality standards are specified and included in design documents and that deviations from such standards are controlled."

Bechtel Drawing E-OR8900, Raceway Notes, Symbols and Details, paragraph 3.31, states, "The support systems for Class IE raceways are designed seismic and the design and installation are "Q" classification as to seismic support and separation criteria."

Contrary to the above, the inspector found two conduits marked as being Class IE (safety related) that are attached to nonseismic Category 1 platforms in each of the diesel generator rooms in the control building.

This is a Severity Level IV violation (Supplement II).

Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice a written statement or explanation in reply, including for each item of noncompliance: (1) corrective action taken and the results achieved; (2) corrective action to be taken to avoid further noncompliance; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Dated _____

R. L. Spessard, Director
Division of Project and
Resident Programs

8212100238 821126
PDR ADOCK 05000483
Q PDR