



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Bx 220
Marseilles, Illinois 61341
Telephone 815/357-6761

November 15, 1982

U.S. Environmental Protection Agency
Region V, Enforcement Division
ATTN: Chief, Compliance Unit
230 South Dearborn Street
Chicago, IL 60604

Illinois Environmental Protection Agency
Division of Water Pollution Control
Compliance Management Unit
2200 Churchill Road
Springfield, IL 62706

Dear Sir:

Subject: NPDES Noncompliances for LaSalle County Nuclear
Generating Station - Permit No. IL0048151

In accordance with Standard Condition 12, we wish to submit the following notice of noncompliances, which are listed chronologically in the attached table.

If there are any questions, please contact Joe Williams of my staff at (815) 357-6761, extension 201.

C E Sargent

G. J. Diederich
Superintendent
LaSalle County Station

GRL JDW
GJD/FRL/JDW/lrw

cc: Director of Water Quality, Environmental Affairs
Manager, Nuclear Stations Division

LASALLE COUNTY NUCLEAR GENERATING STATION
N.P.D.E.S. PERMIT NO: IL0048151
NONCOMPLIANCE REPORT

DISCHARGE NUMBER AND DESCRIPTION: Outfall 6J1c Low Volume Waste
Regen. Wastes Soln. Disch. Tank

PARAMETER AND PERMIT LIMIT: Total Iron, 1.0 mg/l

NONCOMPLIANCE, DATE, AND DURATION: 4.7 mg/l, 5 November 1982, 110,827 gallons

CAUSE OF NONCOMPLIANCE:

The temporary hydrogen peroxide system was not injecting hydrogen peroxide.

CORRECTIVE ACTION:

A work request was written to repair the malfunctioning pump. Repairs to the other injection pump in the system had been completed. This pump was put in service, and verification made that it was injecting hydrogen peroxide.

DATE RECOGNIZED AS A VIOLATION:

12 November 1982

DATE INVESTIGATED:

13 November 1982