NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

UPDATE REPORT - PREVIOUS REPORT DATE 11/4/80

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 LICENSEE CODE (2)	G A E I H 2
LICENSE NUMBER (3)	0 0 - 0 0 0 0 0 - 0 0
LICENSE TYPE (4)	4 1 1 1 1
CAT (5)	
CON'T 0 1 REPORT SOURCE (6)	L
DOCKET NUMBER (7)	0 5 0 0 0 3 6 6
EVENT DATE (8)	1 0 1 4 8 0
REPORT DATE (9)	1 1 3 0 8 2

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While making power changes from 2180 to 1980 MWt, during the performance
0 3 of the "HPCI STEAM LINE DELTA P INSTRUMENT F.T. AND C." procedure, the
0 4 N004 HPCI Steam Line dp switch was found to actuate at 198" H2O. Tech.
0 5 Specs. Table 3.3.2-2, item 5.a. requires actuation at </= 300 percent of
0 6 rated flow (= a dp of </= 196" H2O). Plant operation and the health and
0 7 safety of the public were not affected by this repetitive event(as last
0 8 reported on LER 50-366/1980-112).

0 9	SYSTEM CODE (11)	CAUSE CODE (12)	CAUSE SUBCODE (13)	COMPONENT CODE (14)	COMP. SUBCODE (15)	VALVE SUBCODE (16)
	S F	E	E	I N S T R U	S	Z

LER/RO REPORT NUMBER (17)	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 0	—	1 4 1	/	0 3	X	—	1

ACTION TAKEN (18)	FUTURE ACTION (19)	EFFECT ON PLANT (20)	SHUTDOWN METHOD (21)	HOURS (22)	ATTACHMENT SUBMITTED (23)	NPRD-4 FORM SUB. (24)	PRIME COMP. SUPPLIER (25)	COMPONENT MANUFACTURER (26)
E	F	Z	Z	0 0 0 0	N	N	N	B 0 8 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause of this event has been attributed to setpoint drift. The
1 1 switch, a Barton Model 288A, was recalibrated, successfully functionally
1 2 tested, and returned to service. An engineering study to find a means
1 3 of preventing or reducing the frequency of recurrence has recommended a
1 4 Design Change. Recommended corrective measures are being evaluated.

1 5	FACILITY STATUS (28)	% POWER (29)	OTHER STATUS (30)	METHOD OF DISCOVERY (31)	DISCOVERY DESCRIPTION (32)
	F	0 8 9	NA	B	Surveillance Testing

1 6	ACTIVITY RELEASED (33)	CONTENT OF RELEASE (34)	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
	Z	Z	NA	NA

PERSONNEL EXPOSURES

1 7	NUMBER (37)	TYPE (38)	DESCRIPTION (39)
	0 0 0	Z	NA

PERSONNEL INJURIES

1 8	NUMBER (40)	DESCRIPTION (41)
	0 0 0	NA

LOSS OF OR DAMAGE TO FACILITY (43)

1 9	TYPE (42)	DESCRIPTION
	Z	NA

PUBLICITY

2 0	ISSUED (44)	DESCRIPTION (45)	NRC USE ONLY
	N	NA	

8212100279 821130
PDR ADOCK 05000366
S PDR

NAME OF PREPARER S. B. Tipps PHONE: (912) 367-7851

GPO 917-926