

ATTACHMENT B  
REPLACEMENT TECHNICAL SPECIFICATION PAGE  
(One Page)

9102120276 910206  
PDR ADDCK 05000293  
PDR

6.9.A Routine Reports (Continued)

3. Occupational Exposure Tabulation

A tabulation of the number of station, utility and other personnel (including contractors) receiving exposures greater than 100 mrem/yr and their associated man-rem exposure according to work and job functions, e.g. reactor operations and surveillance inservice inspection, routine maintenance, special maintenance (including a description), waste processing, and refueling shall be submitted on an annual basis. This tabulation supplements the requirements of 20.407 of 10 CFR 20. The dose assignment to various duty functions may be estimates based on pocket dosimeter, TLD, or film badge measurements. Small exposures totalling less than 20% of the individual total dose need not be accounted for. In the aggregate, at least 80% of the total whole body dose received from external sources shall be assigned to specific major work functions.

4. Core Operating Limits Report

- a) Core operating limits shall be established and documented in the CORE OPERATING LIMITS REPORT before each reload cycle or any remaining part of a reload cycle.
- b) The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC in NEDE-24011-P-A, "General Electric Standard Application for Reactor Fuel," (the approved version at the time the reload analyses are performed shall be identified in the CORE OPERATING LIMITS REPORT), and in NEDC-31852P, "Pilgrim Nuclear Power Station SAFER/GESTR-LOCA Loss of Coolant Accident Analysis", dated September, 1990 (the approved version at the time the reload analyses are performed shall be identified in the CORE OPERATING LIMITS REPORT).
- c) The core operating limits shall be determined so that all applicable limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and accident analysis limits) are met.
- d) The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance, for each reload cycle, to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.

6.9.B Deleted

ATTACHMENT C

MARK-UP TECHNICAL SPECIFICATION PAGE  
(One Page)

6.9.A Routine Reports (Continued)

3. Occupational Exposure Tabulation

A tabulation of the number of station, utility and other personnel (including contractors) receiving exposures greater than 100 mrem/yr and their associated man-rem exposure according to work and job functions, e.g. reactor operations and surveillance in service inspection, routine maintenance, special maintenance (including a description), waste processing, and refueling shall be submitted on an annual basis. This tabulation supplements the requirements of 20.407 of 10 CFR 20. The dose assignment to various duty functions may be estimates based on pocket dosimeter, TLD, or film badge measurements. Small exposures totalling less than 20% of the individual total dose need not be accounted for. In the aggregate, at least 80% of the total whole body dose received from external sources shall be assigned to specific major work functions.

4. Core Operating Limits Report

- a) Core operating limits shall be established and documented in the CORE OPERATING LIMITS REPORT before each reload cycle or any remaining part of a reload cycle.
- b) The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC in NEDE-2401-P-A, "General Electric Standard Application for Reactor Fuel," (the approved version at the time the reload analyses are performed shall be identified in the CORE OPERATING LIMITS REPORT) and in NEDO-21696, "Loss of Coolant Analysis Report for Pilgrim Nuclear Power Station," dated August 1977, (the approved version at the time the reload analyses are performed shall be identified in the CORE OPERATING LIMITS REPORT).
- c) The core operating limits shall be determined so that all applicable limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and accident analysis limits) are met.
- d) The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance, for each reload cycle, to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.

6.9.B Deleted

*SUBSTITUTE*

*NEPC-31952P, "PILGRIM NUCLEAR POWER STATION SAFER/GESTR-LOCA LOSS OF COOLANT ACCIDENT ANALYSIS," DATED SEPTEMBER 1990*