

IOW-20-004

Attachment 3

STRESS CORROSION CRACKING
EVALUATION PROGRAM

DUANE ARNOLD ENERGY CENTER

Prepared for:
Iowa Electric Light & Power Company

Prepared by:
NUTECH
San Jose, California

Prepared by:

Jeffrey D. Martin
J. B. Martin, P.E.

Reviewed and Approved by:

P. C. Riccardella
P. C. Riccardella, P.E.

M. D. Sullivan

Issued by:

James W. Axline
J. W. Axline, P.E.

Date: April 27 1980

ABSTRACT

An intergranular stress corrosion cracking (IGSCC) survey of the austenitic stainless steel piping in the recirculation system and RHR system of the Duane Arnold Energy Center has been completed. The primary objective of the survey was to assist Iowa Electric Light & Power in its inservice inspection program by identifying the weld joints which are most susceptible to IGSCC. In the survey, material properties and fabrication data from the plant records were compiled for each joint. The Stress Rule Index (SRI), a method of evaluating the sustained stress level at the inside surface weld HAZ, was calculated for each joint. The materials data and SRI were then used to rank each weld joint according to its relative susceptibility to IGSCC. An IGSCC Susceptibility Matrix was developed as a means of ranking the weld joints. Through this matrix each weld joint is categorized into one of three regions. Region I represents combinations of SRI and material chemistry which have thus far proven to be immune to IGSCC. Regions II and III represent combinations more susceptible to IGSCC.

In addition to the ranking, all weld joints were categorized as conforming, nonconforming, or service-sensitive according to the guidelines given in NUREG-0313, Revision 0, the Nuclear Regulatory Commission document related to IGSCC of BWR piping.

The following summary highlights the results of the survey.

1. Of a total of 117 welds ≥ 10 inches in diameter, 19 welds were found to meet the requirements for conforming material as defined in NUREG-0313. Of the remaining 98 nonconforming welds, 4 were identified as having a high resistance to IGSCC because the base materials contained a carbon content between 0.035%

- and 0.050% or because they are believed to have been fabricated using an inside surface water spray cooling technique.
2. None of the large diameter pipes (>10 inches diameter) were in service-sensitive lines.
 3. All of the 26, 4 inch diameter welds were found to contain base material defined as nonconforming by NUREG-0313, and 18 of these were located in service-sensitive lines. Two of these 18 welds have high resistance to IGSCC because the carbon content of base material was between 0.035% and 0.050%.
 4. Forty-seven weld joints (33% of the total welds) were categorized in Region I of the IGSCC Susceptibility Matrix, representing the least susceptible welds. The remainder of the weld joints were evenly divided between Regions II and III.

TABLE OF CONTENTS

	<u>Page</u>
ABSTRACT.....	i
TABLE OF CONTENTS.....	iii
1.0 INTRODUCTION AND PROGRAM OBJECTIVE.....	1
2.0 REVIEW OF PLANT RECORDS.....	2
3.0 REVIEW OF METALLURGICAL VARIABLES.....	3
Figure 3-1 Carbon Content Versus Time to..... Failure in Type-304 Stainless Steel Pipe Tests	8
Table 3-2 Summary of Metallurgical Evaluation Results	9
4.0 STRESS RULE EVALUATION.....	10
5.0 IDENTIFICATION OF LOW FAILURE PROBABILITY JOINTS.....	11
Figure 5-1 IGS SCC Susceptibility Matrix.....	13
APPENDIX A SCC Evaluation Tables	
APPENDIX B Stress Rule Index Evaluation Summary	
APPENDIX C ISI Isometric Drawings	

1.0 INTRODUCTION AND PROGRAM OBJECTIVE

As a result of the stress corrosion cracking incidents in welded austenitic stainless steel primary coolant piping in Boiling Water Reactors (BWRs) in recent years, Iowa Electric Light and Power instituted a program with NUTECH to evaluate the stress corrosion cracking propensity of stainless steel welds in the recirculation and residual heat removal (RHR) systems at the Duane Arnold Energy Center (DAEC). The objective of the program is to perform a review of plant fabrication records, a metallurgical review of these records to evaluate factors important to intergranular stress corrosion cracking (IGSCC) in the BWR environment, and a Stress Rule evaluation to assist in identifying those joints which are potentially susceptible to IGSCC. The ultimate program aim is to provide input to the DAEC Inservice Inspection Program so that the proper attention can be focused on those joints which are most susceptible to IGSCC. The identification of potentially susceptible pipe locations will also enable Iowa Electric to prepare for potential incidents by providing a repair or replacement plan to address the problem where it may exist. Additionally, this program will assist in addressing, in a more meaningful way, the concerns of the Nuclear Regulatory Commission published in NUREG-0313 and NUREG-0531 regarding materials selection and processing guidelines for BWRs.

The program is divided into the following four major tasks:

- Task 1. Review of Plant Records
- Task 2. Review of Metallurgical Variables
- Task 3. Stress Rule Evaluation
- Task 4. Identification of Low Failure Probability Joints

The following sections provide a brief description of the work performed under each of the above mentioned tasks.

2.0 REVIEW OF PLANT RECORDS

The objective of this task activity was to obtain and review all plant records required to complete the detailed evaluations described in Tasks 2 and 3. These records included piping fabrication and isometric drawings, stress reports, material certifications, fabrication procedures, and records regarding repairs and replacements.

An extremely complete and well-compiled set of fabrication records for the entire recirculation system were supplied to NUTECH by Mr. K. V. Harrington of Iowa Electric, greatly facilitating this task activity.

3.0 REVIEW OF METALLURGICAL VARIABLES

The objective of this task was to identify, for each stainless steel joint in the recirculation and RHR systems, the material chemistry, significant fabrication practices that may have an effect on the joint's susceptibility to IGSCC, and determine the NUREG-0313 status. A detailed compilation of this information is presented in the Stress Corrosion Cracking Evaluation Tables included as Appendix A to this report.

3.1 Material Chemistry

Certified material test reports were located for each component of the subject piping systems. The material specification and the associated carbon content are identified in SCC Evaluation Tables, Appendix A.

Unstabilized wrought austenitic stainless steel with a carbon content less than 0.035% has been demonstrated to be highly resistant to stress corrosion cracking and is acceptable to the NRC for installation in BWR piping systems, as stated in NUREG-0313. Welds between materials with a carbon content in the 0.035% to 0.050% range are identified in the SCC Evaluation Tables as having high resistance to IGSCC. While no NRC credit can be taken for these welds relative to NUREG-0313 guidelines, we feel it is appropriate, based on field failure data and the EPRI sponsored pipe test and laboratory test data, to identify these joints as highly resistant to IGSCC. The General Electric test data presented in Figure 3-1 illustrates that at these carbon levels Type 304 stainless steel is highly resistant to IGSCC.

Ferritic steels and cast stainless steels have also been demonstrated to be highly resistant to IGSCC and are acceptable materials for installation in BWR piping systems. Inconel (Alloy 600), not addressed specifically in NUREG-0313, is considered as

a conforming material in this evaluation. In the uncreviced condition this material has provided satisfactory performance in the BWR environment.

3.2 Significant Fabrication Practices

A review of the fabrication procedures revealed that the large diameter shop welds may have been fabricated using an inside surface water spray cooling technique. The pipe fabricator, Southwest Fabricating and Welding Co., commonly uses the spray cool technique to maintain interpass temperature when welding stainless steel pipe having a wall thickness greater than 0.75 in.⁽¹⁾ The main purpose for employing this technique was to control interpass temperature, however, the technique is similar to that currently being studied as a fabrication remedy for stress corrosion cracking mitigation.

This technique, also called heat sink welding (HSW), is used to produce axial compressive residual stress on the inside pipe surface in the weld heat affected zone. The first two layers are deposited by the gas tungsten arc process in the normal manner. The remainder of the weld is made while the inside surface is being cooled by either a water spray or by filling the pipe with flowing water.

It has been documented in General Electric Company's pipe tests on small diameter piping that as much as an order of magnitude performance improvement may be possible for heat sink welded joints.⁽²⁾ A separate program, supported by the Electric Power

(1) Robert Pearson, Southwest Fabricating and Welding Co.,
Private Communication

(2) R. Hughes, Qualification of Solution Heat Treatment,
Corrosion Resistant Cladding and Heat Sink Welding.
Seminar on Countermeasures for BWR Pipe Cracking,
January 22-24, 1980.

Research Institute, is currently underway to evaluate the residual stress benefit for large diameter piping fabricated using this process.

Although no NRC credit can currently be taken for heat sink welded joints in relation to the augmented ISI requirements of NUREG-0313, these welds are specifically highlighted in the SCC Evaluation Tables because of their potentially high resistance to IGSCC. It should also be noted that, although the shop welding procedure used in fabricating the Duane Arnold spools requires interpass temperature control, and allows water spray cooling, specific documentation describing the detailed process and verifying its use on each of the shop welds has not been located. Follow-up discussions with the pipe fabricator will be necessary to provide adequate assurance that the water spray cooling technique was, in fact, employed for each shop weld.

3.3 NUREG-0313 Evaluation

An evaluation of the metallurgical data compiled for each joint was conducted with respect to the NRC technical positions established in NUREG-0313, "Technical Report on Material Selection and Processing Guidelines for BWR Coolant Pressure Boundary Piping," published in July 1977.

The SCC Evaluation Tables identify the NUREG-0313 status of each joint based on the following criteria.

Conforming - joints for which each of the adjoining parent materials are one of the following highly resistant materials; ferritic steels, "Nuclear Grade" or L-Grade Type 304 or 316 austenitic stainless steel (<0.035% Carbon), or cast stainless steels. Regular grades of 304 or 316 stainless steel are not

considered conforming unless the as-installed piping, including the weld, is in the solution annealed condition.

Nonconforming - all joints not meeting the above criteria. These joints are subject to augmented inservice inspection requirements as identified in NUREG-0313.

Service Sensitive - nonconforming joints in lines designated by the NRC as having experienced cracking of a generic nature, or that are considered to be particularly susceptible to cracking because of a combination of high local stress material condition, and high oxygen content in lines which have relatively stagnant, intermittent, or low flow coolant. Included in this category of piping runs are: core spray lines, recirculation bypass lines, CRD hydraulic return lines, isolation condenser lines, and shutdown heat exchanger lines. A higher degree of augmented inspection is required for these lines.

A revision of NUREG-0313, currently issued for review and comment, proposes to add recirculation riser piping and internal attachment welds to the service sensitive category.

3.4 Summary

The overall metallurgical review consisted of an examination of 136 joints in the recirculation system and 7 joints in the residual heat removal system. Of the 143 total joints, 19 were evaluated as conforming, 106 were nonconforming, and 18 were both nonconforming and in service sensitive lines.


Of a total of 117 welds greater than or equal to 10 inches in diameter, 19 welds were found to meet the requirements for conforming material as defined in NUREG-0313. Of the remaining 98 nonconforming welds, 34 were identified as having a high resistance to IGSCC because the base materials contained a carbon content between 0.035% and 0.050% or because they are believed to

have been fabricated using an inside surface water cooling technique.

All of the 26, 4-inch diameter welds were found to contain base material defined as nonconforming by NUREG-0313, and 18 of these were located in service sensitive lines. Two of these 18 welds were designated as having a high resistance to IGSCC because the carbon content of the base material was between 0.035% and 0.050%.

Table 3-2 provides a tabular summary of the metallurgical evaluation results.

FIGURE 3-1



CARBON CONTENT VERSUS TIME TO FAILURE
IN TYPE-304 STAINLESS STEEL PIPE TESTS
(REF: NEDC 23750-2, EPRI CONTRACT RP968)

TABLE 3-2
SUMMARY OF METALLURGICAL EVALUATION RESULTS

SYSTEM	DIA	TOTAL WELDS	TOTAL CONFORMING WELDS	NON-CONF. WELDS SHOP WATER SPRAY COOLED*	NON-CONF. WELDS WITH .035 < %C < .050	TOTAL NON-CONFORMING WELDS	TOTAL NON-CONFORMING & SERVICE SENSITIVE
RECIRCULATION SUCTION	22	23	2	10	15	21	0
RECIRCULATION DISCHARGE	22	16	0	6	1	16	0
RECIRCULATION RING HEADER	16	8	0	8	0	8	0
RECIRCULATION RISERS	10	64	16	0	0	48	0
RECIRCULATION BYPASS	4	18	0	0	2	0	18
RECIRCULATION BRANCH CONNECTIONS	4	7	0	0	0	7	0
RESIDUAL HEAT REMOVAL	20 18 4	4 2 1	0 1 0	0 0 0	0 0 0	4 1 1	0 0 0
TOTAL		143	19	24**	18**	106	18

*The use of water spray cooling not yet fully verified.

**Each column includes six joints that satisfy both criteria (i.e., .035 < %C < .050 and shop water spray cooled.)

4.0 STRESS RULE EVALUATION

To provide a further means of determining a joint's susceptibility to IGSCC, a Stress Rule Index (SRI) evaluation was performed for each joint being studied. The Stress Rule Index is determined in the following manner. The axial stress components resulting from sustained loading conditions (i.e. pressure, deadweight, and steady state thermal expansion) are derived from the elemental force and moment tables of the original Duane Arnold piping stress analysis. These are combined with residual stress estimates and input to the General Electric Company developed Stress Rule Index equation shown below.

$$\frac{P_m + P_b}{S_y} + \frac{Q + F \text{ (Resid)}}{S_y + .002E} = \text{SRI}$$

Where	P_m	= Primary Membrane Stress
	P_b	= Primary Bending Stress
	S_y	= Code Yield Strength
	Q	= Sustained Secondary Stress
	F	= Sustained Peak Stress
	E	= Elastic Modulus
	Resid	= Weld Residual Stress

For non-creviced welds, General Electric Company has determined that if the index is less than unity, susceptibility to stress corrosion cracking is mitigated; for crevices, a value somewhat lower than unity may be more suitable. To this date, IGSCC events have not been observed in joints exhibiting a SRI less than 1.2.

The SRI evaluation was facilitated by the use of a NUTECH computer program (SCORE) which calculates the SRI given the appropriate forces and moments from the piping stress report. The SRI for each joint is given in the SCC Evaluation Tables. Detailed results of the SRI evaluation are included in Appendix B.

5.0 IDENTIFICATION OF LOW FAILURE PROBABILITY JOINTS

Three main considerations must be taken into account in determining the susceptibility of a joint to intergranular stress corrosion; material properties, stress, and environment. In this report, we have quantitatively addressed two of these three factors. For both material properties and stress, there exists sufficient analysis, laboratory data, and field experience to provide a basis for determining relative susceptibility. The environmental factor has only been addressed in that stagnant, low flow lines (service sensitive) are considered more susceptible to IGSCC. The degree to which one of these three ingredients must be present for IGSCC to occur is variable, making it extremely difficult to combine what is known about each of these factors to define an absolute scale of susceptibility. There are also other known variables that effect the susceptibility of sensitized austentic stainless steel to IGSCC. These other variables, which must be factored into a final determination of susceptibility, include such effects as cold work, counterbore grinding crevices, temperature, pH, etc. EPRI is currently sponsoring research that may lead to more refined techniques for quantifying the susceptibility of various piping joints.

To provide a rudimentary means of ranking each weld, the IGSCC Susceptibility Matrix was developed. It displays the relative susceptibility of each weld based on the information that has been compiled in this study regarding material properties and stress conditions. Figure 5-1 shows the placement of the recirculation and RHR system welds in the matrix based on the stress rule index calculated for that joint and the highest carbon content of the base material on either side of the weld.

The IGSCC Susceptibility Matrix is divided into three regions labeled I, II, and III. Region I contains welds that are either

conforming from a material standpoint (less than 0.035% carbon as defined in NUREG-0313) or have a stress rule index less than 1.2. (IGSCC events have not been observed in weld joints with a SRI < 1.2.) Welds in this region are considered to be the least susceptible to IGSCC.

Region II defines an intermediate zone encompassing welds which exhibit considerable margin to failure, relative to Region III welds, but are somewhat more susceptible than Region I welds. Finally, Region III represents the most susceptible welds, those having the smallest margin to failure.

Other variables, as discussed earlier, can enter in to increase or decrease the susceptibility to IGSCC. Two of the more important factors to be considered for Duane Arnold are the effects of shop water spray cooling and whether specific welds are in service sensitive piping. Welds that are believed to have been shop water spray cooled are underlined in the matrix. These welds are potentially highly resistant to IGSCC because of favorable residual stress distribution. If this is verified and actual measurements determine the extent to which these stresses are reduced, the stress rule index may be significantly lowered, thus shifting the position of the underlined welds to the left. The other important factor to consider is whether welds are in service sensitive piping. Welds which are both nonconforming and in service sensitive piping are identified in the matrix with an asterisk. These welds are potentially more susceptible to IGSCC than other welds of the same matrix position.

STRESS RULE INDEX

	0 - 1.20	1.21 - 1.50	1.51 - 2.00	2.01 +	
CARBON CONTENT (%)	RRA-J7 RRD-J7 RRE-J7 RRF-J7 RRH-J7	RCA-J18 RMA-J10 RRG-J7 RCB-J21 RRB-J7 RRC-J7	RMA-J4 RMA-J2 RMB-J11 RMB-J2	RMA-J8 RMB-J5 RMB-J9	
.070 +					
.069 + .060	RCA-J17 RBA-J7* RCB-J30 RHC-F2 RHD-F2	RCA-J34 RBA-J3* RRE-J4 RRF-J4 RRC-J4 RRD-J4 RCB-J37	RBB-J1* RBB-J7* RBB-J12* RHC-J1 RHD-J1	RRA/H-J5 (8 welds) RBA-J6* REA-J8* RRG-J4 RRH-J4 RRA-J4 RRB-J4	
REGION III (HIGH SUSCEPTIBILITY)					
.059 + .050	RCA-J7 RCA-J15 RCA-J24 RCA-J28 RCA-J38 RMA-J1 RMA-J11 RRA/H-J4A (8 welds)	RCB-J27 RCB-J31 RCB-J41 RMB-J1 RMB-JT2 RHB-J1	RCA-J12 RCA-J13 RCA-J21 RCA-J30 RCA-J32 RCA-J41 RCA-J43 RMA-J6 RRA/H-J3 (8 welds)	RMA-J5 RMA-J7 RBA-J2* RBA-J3* RCB-J6 RCB-J7 RCB-J33 RCB-J35	RCB-J24 RMB-J7 RMB-J6 RMB-J8 RBB-J2* RBB-J3* RBA-J9* RBB-J9*
.049 + .040	RCA-J3 RCA-J6 RCB-J3 RCB-J9 RCB-JT8		RCA-J8 RCA-J5 RCA-J12* RCB-J4 RCB-J5 RCB-J15 RCB-J16	RCB-J24 RCB-J46	RCA-J22 RBA-J10* RCB-J25 RBB-J10*
REGION II (MODERATE SUSCEPTIBILITY)					
.035 + .030	RHB-F5 RCA-F2 RCB-F2 RRA/H-F2A (8 welds)				
< .035					
REGION I (LOW SUSCEPTIBILITY)					

* IN SERVICE SENSITIVE LINES
xxx SHOP WATER SPRAY COOLED

FIGURE 5-1
IGSCC SUSCEPTIBILITY MATRIX

APPENDIX A
SCC EVALUATION TABLES

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
utech

Line No. RCA				System RECIRCULATION SUCTION - LOOP A							Revision - Date 0 4/11/80		Page A1
Weld Number	Dia. (in)	Weld Type	Shop or Field Weld	Component	Material Type & Specification	Heat Treatment	Heat Number	Carbon Content (%)	NUREG 0313 Status			Stress Rule Index	Comments
									S E R V S	S C O M F	C O N F		
				RECIRC. SUCTION NOZZLE (N1A)	FORGED SA-508 CL.2 LOW ALLOY STEEL	---	NA	---					
RCA-F2	22	NOZ-SE	SW								X	1.01	
				SAFE-END (N1A)	FORGED SA-336 GR F8	7	M57S	0.023					
RCA-J3	22	SE-P	FW							+		1.03	LOWER %C HIGH RESISTANCE TO IGSCC
				PIPE (5-1)	R&W A358 CL.1 FROM A240 T304	1	2P2470-4A	0.045					
RCA-J4	22	P-E	SW							+		1.30	LOWER %C & SHOP WATER SPRAY COOLED HIGH RESISTANCE TO IGSCC
				ELBOW(90°LR)	R&W A403-WP304W FROM A240	2	300223	0.049					
RCA-J5	22	E-P	SW							+		1.32	LOWER %C & SHOP WATER SPRAY COOLED HIGH RESISTANCE TO IGSCC
				PIPE (5-2)	R&W A358 CL.1 FROM A240 T304	1	2P2470-4A	0.045					
RCA-J6	22	P-P	FW							+		0.90	LOWER %C HIGH RESISTANCE TO IGSCC
				PIPE (6-1)	R&W A358 CL.1 FROM A240 T304	1	2P2470-1A	0.045					
RCA-J7	22	P-P	SW							+		0.87	SHOP WATER SPRAY COOLED
				PIPE (6-2)	R&W A358 CL.1 FROM A240 T304	1	300069-1B	0.050					
RCA-J12	22	P-E	SW							+		1.30	SHOP WATER SPRAY COOLED
				ELBOW(90°LR)	R&W A403-WP304W FROM A240	2	300223	0.049					
RCA-J13	22	E-V	FW							+		1.33	LOWER %C TO CASTING HIGH RESISTANCE TO IGSCC
				VALVE (MO-F023A)	CAST A351-65 GR CF-8	7	40298	0.05					9% FERRITE

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
nutech

LINE NO.	RCA		SYSTEM RECIRCULATION SUCTION - LOOP A (CoNT)							REVISION - DATE	PAGE		
WELD NUMBER	DIA. (IN)	WELD TYPE	SHOP OR FIELD WELD	COMPONENT	MATERIAL TYPE & SPECIFICATION	HEAT TREATMENT	HEAT NUMBER	CARBON CONTENT (%)	NUREG 0313 STATUS			STRESS RULE INDEX	COMMENTS
									S	S E R N V S	N C O O N F		
RCA-J15	22	V-P	FW	PIPE (4-1)	R&W A358 CL.1 FROM A240 T304	1	300069-1B	0.050		X		0.96	
RCA-J21	22	P-E	SW	ELBOW(90°SR)	R&W A403-WP304W-1967 FROM A240	2	K51142-3	0.048		B+		1.43	SHOP WATER SPRAY COOLED
RCA-J22	22	E-Pp	FW	PUMP	CAST A351 GR. CF8M	7	51510 or 50448	0.06 0.05		B+		1.63	LOWER %C TO CASTING HIGH RESISTANCE TO IGSCC 14% FERRITE
				PIPE (5-2)	R&W A358 CL.1 FROM A240 T304	1	2P2470-4A	0.045					SPOOL 5-2 ALSO SHOWN ON PG. A1
RCA-J5A	4	BPC	SW	WEISDOLET 22" X 4"	FORGED A182-F304	6	812680 (496E)	0.060		X			
				PIPE (4-1)	R&W A358 CL.1 FROM A240 T304	1	300069-1B	0.050					SPOOL ALSO SHOWN ON PG. A2
RCA-J18	4	BPC	SW	4" WN FLANGE (900# LONG)	FORGED A182-69 F-304	4	41167	0.070		X		1.32	DECONTAMINATION FLANGE
				BLIND FLANGE	FORGED A182-69 F-304	4	41167	0.0/0					

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
nutech

LINE NO.		SYSTEM		REVISION - DATE							PAGE		
RCA		RECIRCULATION DISCHARGE - LOOP A							0 4/11/80		A3		
WELD NUMBER	DIA (IN)	WELD TYPE	SHOP OR FIELD WELD	COMPONENT	MATERIAL TYPE & SPECIFICATION	HEAT TREATMENT	HEAT NUMBER	CARBON CONTENT (%)	NUREG 0313 STATUS			STRESS RULE INDEX	COMMENTS
									S E R V S	N C O O N H F	C O M P R		
				PUMP	CAST A351 CF8M	7	51510 or 50448	0.06 0.05					14% FERRITE
RCA-J24	22	P-P	FW							X		0.98	
				PIPE (7-1)	R&W A358 CL.1 FROM A240 T304	1	300075-1B	0.058					
RCA-J28	22	P-V	FW							X		0.97	
				VALVE (MD-F031A)	CAST A351-65 GR. CF8	7	44266	0.04					18% FERRITE
RCA-J30	22	V-E	FW							X		1.27	
				ELBOW(90°LR)	R&W A403-WP304W FROM A240	2	600324-1A	0.055					
RCA-J32	22	E-P	SW							θ+		1.26	SHOP WATER SPRAY COOLED
				PIPE (9-1)	R&W A358 CL.1 FROM A240 T304	1	300075-1B	0.058					
RCA-J38	22	P-P	SW							X		0.89	
				PIPE (9-1)	R&W A358 CL.1 FROM A240 T304	1	300075-1B	0.058					FLOW RESTRICTER WELDED TO PIPE I.D.
RCA-J41	22	P-T	SW							θ+		1.25	SHOP WATER SPRAY COOLED
				REDUCING TEE 22"X22"X20"	R&W A403-WP304W FROM A240	2	6003241	0.055					20" OUTLET EXTRUDED PRIOR TO HEAT TREATMENT
RCA-J43	22	T-Cr	FW							X		1.33	
				REDUCING CROSS 22X22X16X16	R&W A403-WP304W FROM A240-69	2	582533-1	0.040					16" OUTLETS EXTRUDED PRIOR TO HEAT TREATMENT
RCA-J6	22	Cr-Cp	SW							θ+		1.22	SHOP WATER SPRAY COOLED
				WELD CAP	R&W A403-WP-304-67 FROM A240	3	600225-1A	0.058					

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
utech

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
nutech

LINE NO.		RRE		SYSTEM RECIRCULATION RISERS - LOOP A (N2E)						REVISION - DATE		PAGE
WELD NUMBER	DIA (IN)	WELD TYPE	SHOP OR FIELD WELD	COMPONENT	MATERIAL TYPE & SPECIFICATION	HEAT TREATMENT	HEAT NUMBER	CARBON CONTENT (%)	NUREG 0313 STATUS		STRESS RULE INDEX	COMMENTS
									S E R V S	N C O O N F	C O N F	
				16" RING HEADER (24-2)	R&W A358 CL.1 FROM A240 T304	1	600120-1B	0.059				ALSO SHOWN ON PG. A5
RRE-J10	10	Hdr-A	SW	ADAPTER	FORGED A182-F304	6	52624	0.070		X	1.40	
RRE-J7	10	A-P	FW	PIPE (12-2)	SMLS A376-TP304	5	2P3687	0.051		X	1.11	
RRE-J5	10	P-E	SW	ELBOW(90°LR)	R&W A403-WP304W-67 FROM A240	3	37845-1A	0.061		X	1.56	
RRE-J4	10	E-P	SW	PIPE (12-1)	SMLS A376-TP304	5	2P3399	0.055		X	1.39	
RRE-J4A	10	P-P	FW	PIPE (12-1)	SMLS A376-TP304	5	2P3399	0.055		X	0.98	PORTION OF SPOOL 12-1 WAS CUT OUT AND REWELDED IN 1978
RRE-J3	10	P-P	FW	SAFE-END EXTENSION	FORGED SA-336 GR. F8	7	M53S	0.030		X	1.23	
RRE-F2A	10	P-SE	FW	SAFE-END (N2E)	SMLS SB-166 INCONEL	7	NX8927	0.07		X	1.02	SAFE-END REPLACED IN 1978
RRE-F2	10	SE-N02	FW	RECIRC INLET NOZZLE	FORGED SA-508 CL. 2 LOW ALLOY STEEL	---	NA	---		X	1.03	

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
nutech

LINE NO.		SYSTEM RECIRCULATION RISERS - LOOP A							REVISION - DATE		PAGE	
RRF		(N2F)							0 4/11/80		A7	
WELD NUMBER	DIA (IN)	WELD TYPE	SHOP OR FIELD WELD	COMPONENT	MATERIAL TYPE & SPECIFICATION	HEAT TREATMENT	HEAT NUMBER	CARBON CONTENT (%)	NUREG 0313 STATUS		STRESS RULE INDEX	COMMENTS
				16" RING HEADER (24-2)	R&W A358 CL.1 FROM A240 T304	1	600120-1B	0.059	S E R N V S	N C O N F F		ALSO SHOWN ON PG. A5
RRF-J8	10	Hdr-A	SW	ADAPTER	FORGED A182-F304	6	52624	0.070		X	2.05	
RRF-J7	10	A-P	FW	PIPE (13-2)	SMLS A376-TP304	5	2P3271	0.061		X	1.20	
RRF-J5	10	P-E	SW	ELBOW(90°LR)	R&W A403-WP304W-67 FROM A240	3	37845-1A	0.061		X	1.70	
RRF-J4	10	E-P	SW	PIPE (13-1)	SMLS A376 TP304	5	2P3687	0.051		X	1.41	
RRF-J4A	10	P-P	FW	PIPE (13-1)	SMLS A376 TP304	5	2P3687	0.051		X	0.98	PORTION OF SPOOL 13-1 WAS CUT OUT AND REWELDED IN 1978
RRF-J3	10	P-P	FW	SAFE-END EXTENSION	FORGED SA-336 GR. F8	7	M53S	0.030		X	1.23	
RRF-F2A	10	P-SE	FW	SAFE-END (N2F)	SMLS SB-166 INCONEL	7	NX8927	0.07		X	1.02	SAFE-END REPLACED IN 1978
RRF-F2	10	SE-NOZ	FW	RECIRC INLET NOZZLE	FORGED SA-508 CL.2 LOW ALLOY STEEL	---	NA	---		X	1.03	

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
nutech

LINE NO.		SYSTEM RECIRCULATION RISERS - LOOP A (N2G)							REVISION - DATE	PAGE	
WELD NUMBER	DIA (IN)	WELD TYPE	SHOP OR FIELD WELD	COMPONENT	MATERIAL TYPE & SPECIFICATION	HEAT TREATMENT	HEAT NUMBER	CARBON CONTENT (%)	NUREG 0313 STATUS	STRESS RULE INDEX	COMMENTS
									S E N C O O N F E E R V S		
				16" RING HEADER (24-1)	R&W A358 CL.2 FROM A240 T304	1	600120-1B	0.059			ALSO SHOWN ON AS
RMA-J4	10	Hdr-A	SW	ADAPTER	FORGED A182-F304	6	52624	0.070		X	1.51
RRG-J7	10	A-P	FW	PIPE (14-2)	SMLS A376-TP304	5	2P3271	0.061		X	1.22
RRG-J5	10	P-E	SW							X	1.68
				ELBOW(90°LR)	R&W A403-WP304W-67 FROM A240	3	37845-1A	0.061			
RRG-J4	10	E-P	SW	PIPE (14-1)	SMLS A376-TP304	5	2P3637	0.051		X	1.53
RRG-J4A	10	P-P	FW	PIPE (14-1)	SMLS A376-TP304	5	2P3687	0.051		X	0.98
RRG-J3	10	P-P	FW	SAFE-END EXTENSION	FORGED SA-336 GR. F8	7	M53S	0.030			PORTION OF SPOOL 14-1 WAS CUT OUT AND REWELDED IN 1978
RRG-F2A	10	P-SE	FW							X	1.02
				SAFE-END (N2G)	SMLS SB-166 INCONEL	7	NX9923	0.06			SAFE-END REPLACED IN 1978
RRG-F2	10	SE-NOZ	FW	RECIRC INLET NOZZLE	FORGED SA-508 CL.2 LOW ALLOY STEEL	---	NA	----		X	1.03

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
nutech

LINE NO.		SYSTEM		RECIRCULATION RISERS - LOOP A (N2H)						REVISION - DATE			
WELD NUMBER	DIA. (IN)	WELD TYPE	SHOP OR FIELD WELD	COMPONENT	MATERIAL TYPE & SPECIFICATION	HEAT TREATMENT	HEAT NUMBER	CARBON CONTENT (%)	NUREG 0313 STATUS			STRESS RULE INDEX	COMMENTS
									S E E R V S	M C O O N F	C O N F		
				16" RING HEADER (24-1)	R&W A358 CL. 1 FROM A240 T304	1	600120-1B	0.059					ALSO SHOWN ON PG. A5
RRI-J2	10	Hdr-A	SW	ADAPTER	FORGED A182-F304	6	S2624	0.070		X		1.90	
RRI-J7	10	A-P	FW	PIPE (15-2)	SMLS A376-TP304	5	2P3687	0.051		X		1.14	
RRH-J5	10	P-E	SW	ELBOW	R&W A403-WP304W-67 FROM A240	3	37845-1A	0.061		X		1.55	
RRI-J4	10	E-P	SW	PIPE (15-1)	SMLS A376-TP304	5	2P3687	0.051		X		1.57	
RRI-J4A	10	P-P	FW	PIPE (15-1)	SMLS A376-TP304	5	2P3687	0.051		X		0.98	
RRH-J3	10	P-P	FW	SAFE-END EXTENSION	FORGED SA-336 GR. F8	7	M53S	0.030		X		1.23	PORTION OF SPOOL 15-1 WAS CUTOUT AND REWELDED IN 1978
RRI-F2A	10	P-SF	FW	SAFE-END (N2H)	SMLS SB-166 INCONEL	7	NX9923	0.06		X		1.02	SAFE-END REPLACED IN 1978
RRI-F2	10	SE-NOZ	FW	RECIRC INLET NOZZLE	FORGED SA-508 CL. 2 LOW ALLOY STEEL	---	NA	---		X		1.03	

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
nutech

LINE NO.		SYSTEM RECIRCULATION BYPASS LINE - LOOP A							REVISION - DATE		PAGE	
RBA									0 4/11/80		A10	
WELD NUMBER	DIA. (IN)	YIELD TYPE	SHOP OR FIELD WELD	COMPONENT	MATERIAL TYPE & SPECIFICATION	HEAT TREATMENT	HEAT NUMBER	CARBON CONTENT (%)	NUREG 0313 STATUS			STRESS RULE INDEX
				WELDOLET	FORGED A182-F304	6	812680 (496E)	0.060	S E R N S	N C O O N F	C O N F	
RBA-J1	4	WOL-P	FW	PIPE	SMLS A376-TP304	5	2P3535	0.053		X	X	1.22
RBA-J2	4	P-E	SW	ELBOW(90°LR)	SMLS A403-WP304-67 FROM A376	3	20257 CFRQ	0.047		X	X	1.40
RBA-J3	4	E-P	SW	PIPE	SMLS A376-TP304	5	2P3371	0.057		X	X	1.50
RBA-J6	4	P-T	FW	TEE	SMLS A403-WP304W-67 FROM A312	3	37368 CFRP	0.060		X	X	1.83
RBA-J7	4	T-FL	SW	WN FLANGE (900 #LONG)	FORGED A182-F316	4	E1460	0.060		X	X	1.16
				BLIND FLANGE	FORGED A182-F316	4	E1460	0.060				
				TEE	SMLS A403-WP304W-67 FROM A312	3	37368 CFRP	0.060				ALSO SHOWN ON PG. A4
RBA-J8	4	T-P	FW	PIPE	SMLS A376-TP304	5	2P3371	0.057		X	X	1.94
RBA-J9	4	P-E	SW							X	X	1.72

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by

nutech

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
nutech

LINE NO.		SYSTEM							REVISION - DATE		PAGE	
RCB		RECIRCULATION SUCTION - LOOP B							0 4/11/80		A12	
WELD NUMBER	DIA. (IN)	WELD TYPE	SHOP OR FIELD WELD	COMPONENT	MATERIAL TYPE & SPECIFICATION	HEAT TREATMENT	HEAT NUMBER	CARBON CONTENT (%)	NUREG 0313 STATUS		STRESS RULE INDEX	COMMENTS
				RECIRC. SUCTION NOZZLE (NIB)	FORGED SA-508 CL.2 LOW ALLOY STEEL	---	NA	---	S E R V S	N C O O N F		
RCB-F2	22	NOZ-SE	SW								X	0.97
				SAFE-END (NIB)	FORGED SA-336 GR. F8	7	557S	0.023				
RCB-J3	22	SE-P	FW							8+	1.01	LOWER 1C HIGH RESISTANCE TO IGSCC
				PIPE (1-1)	R&W A358 CL.1 FROM A240 T304	1	2P2470-4A	0.045				
RCB-J4	22	P-E	SW							8+	1.35	LOWER 1C & SHOP WATER SPRAY COOLED HIGH RESISTANCE TO IGSCC
				ELBOW(90°LR)	R&W A403-WP304W FROM A240	2	300223	0.049				
RCB-J5	22	E-P	SW							8+	1.24	LOWER 1C & SHOP WATER SPRAY COOLED HIGH RESISTANCE TO IGSCC
				PIPE (1-2)	R&W A358 CL.1 FROM A240 T304	1	2P2470-1A	0.045				
RCB-J6	22	P-T	FW							X	1.24	
				REDUCING TEE 22"X22"X18"	R&W A403-WP304W FROM A240-69	2	6003241	0.055				18" OUTLET EXTRUDED PRIOR TO HEAT TREATMENT
RCB-J7	22	T-P	SW							8+	1.32	SHOP WATER SPRAY COOLED
				PIPE (1-2)	R&W A358 CL.1 FROM A240 T304	1	2P2470-1A	0.045				
RCB-J9	22	P-P	SW							8+	0.89	LOWER 1C & SHOP WATER SPRAY COOLED HIGH RESISTANCE TO IGSCC
				PIPE (2-1)	R&W A358 CL. 1 FROM A240 T304	1	2P2431-1A	0.040				
RCB-J15	22	P-E	FW							8+	1.33	LOWER 1C HIGH RESISTANCE TO IGSCC
				ELBOW(90°LR)	R&W A403-WP304W FROM A240	2	300223	0.049				
RCB-J16	22	E-V	FW							8+	1.32	LOWER 1C HIGH RESISTANCE TO IGSCC

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
motech

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
nutech

LINE NO.		SYSTEM		REIRCULATION DISCHARGE - LOOP B							REVISION - DATE	PAGE	
WELD NUMBER	DIA (IN)	WELD TYPE	SHOP OR FIELD WELD	COMPONENT	MATERIAL TYPE & SPECIFICATION	HEAT TREATMENT	HEAT NUMBER	CARBON CONTENT (%)	NUREG 0313 STATUS			STRESS RULE INDEX	COMMENTS
									S E R V S	N C O O N F	C O N F		
				PUMP	CAST A351 CF8M	7	51E10 or 50448	0.06 0.05					14% FERRITE
RCB-J27	22	P-P	FW							X		0.97	
				PIPE(8-1)	RGW A358 CL.1 FROM A240 T304	1	300075-1C	0.058					
RCB-J31	22	P-V	FW							X		0.96	
				VALVE (MO-F031B)	CAST A351-65 GR. CF8	7	44691	0.04					15% FERRITE
RCB-J33	22	V-E	FW							X		1.24	
				ELBOW(90°LR)	RGW A403-WP304W FROM A240	2	600324-1A	0.055					
RCB-J35	22	E-P	SW							+		1.22	SHOP WATER SPRAY COOLED
				PIPE (10-1)	RGW A358 CL. 1 FROM A240 T304	1	300075-1C	0.058					
RCB-J41	22	P-P	SW							X		0.90	
				PIPE (10-1)	RGW A358 CL.1 FROM A240 T304	1	300075-1C	0.058					FLOW RESTRICTER WELDED TO PIPE I.D.
RCB-J44	22	P-T	SW							+		1.43	SHOP WATER SPRAY COOLED
				REDUCING TEE 22X22X20	RGW A403-WP304W FROM A240-69	2	6825331	0.040					20" OUTLET EXTRUDED PRIOR TO HEAT TREATMENT
RCB-J46	22	T-Cr	FW							+		1.33	LOWER %C CONTENT - HIGH RESISTANCE TO IGSCC
				REDUCING CROSS 22X22X16X16	RGW A403-WP304W FROM A240-69	2	6825331	0.040					16" OUTLETS EXTRUDED PRIOR TO HEAT TREATMENT
RMB-J7	22	Cr-Cp	SW							+		1.22	SHOP WATER SPRAY COOLED
				WELD CAP	RGW A403-67 FROM A240 T304	3	600225-1A	0.058					

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
nutech

LINE NO.		SYSTEM		RECIRCULATION DISCHARGE - LOOP B (Con't)						REVISION - DATE	PAGE		
WELD NUMBER	DIA. (IN)	WELD TYPE	SHOP OR FIELD WELD	COMPONENT	MATERIAL TYPE & SPECIFICATION	HEAT TREATMENT	HEAT NUMBER	CARBON CONTENT (%)	NUREG 0313 STATUS			STRESS RULE INDEX	COMMENTS
				22" PIPE (8-1)	R&W A358 CL. 1 FROM A240 T304	1	300075-1C	0.058	S E E R V S	S E E R N F	N O N F O N F		ALSO SHOWN ON PG. A14
RCB-J30	4	BPC	SW	WELDOLET 22"X4"	FORGED A182-F304	6	812680 (496E)	0.060			X	1.08	BRANCH CONNECTION FOR 4" RECIRC. DISCHARGE VALVE BYPASS LINE
				22" PIPE (10-1)	R&W A358 CL. 2 FROM A240 T304	1	300075-1C	0.058			X	1.25	ALSO SHOWN ON PG. A14
RCB-J37	4	BPC	SW	WELDOLET 22"X4"	FORGED A182-F304	6	812680 (496E)	0.060			X	1.25	BRANCH CONNECTION FOR 4" RECIRC. DISCHARGE VALVE BYPASS LINE

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
eutech

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
nutech

LINE NO.		SYSTEM RECIRCULATION RISERS - LOOP B (N2A)							REVISION - DATE		PAGE	
WELD NUMBER	DIA. (IN)	WELD TYPE	SHOP OR FIELD WELD	COMPONENT	MATERIAL TYPE & SPECIFICATION	HEAT TREATMENT	HEAT NUMBER	CARBON CONTENT (%)	NUREG 0313 STATUS		STRESS RULE INDEX	COMMENTS
				16" RING HEADER (11-2)	R&W A358 CL.1 FROM A240-67 T304	1	600120-1B	0.059	S E R V S	M C O O F	C O M F	
RMB-J11	10	Hdr-A	SW	ADAPTER	FORGED A182-F304	6	52624	0.070		X	1.95	SPOOL 11-2 ALSO SHOWN ON PG. A16
RRA-J7	10	A-P	FW	PIPE (16-2)	SMLS A376 - TP304	5	2P3687	0.051		X	1.16	
RRA-J5	10	P-E	SW	ELBOW(90°LR)	R&W A403-WP304W-67 FROM A240	3	37845-1A	0.061		X	1.57	
RRA-J4	10	E-P	SW	PIPE (16-1)	SMLS A376-TP304	5	2P3399	0.055		X	1.63	
RRA-J4A	10	P-P	FW	PIPE (16-1)	SMLS A376-TP304	5	2P3399	0.055		X	0.98	PORTION OF SPOOL 16-1 WAS CUT OUT AND REPLACED IN 1978
RRA-J3	10	P-P	FW	SAFE-END EXTENSION	FORGED SA-336 GR. F8	7	M53S	0.030		X	1.23	
RRA-F2A	10	P-SE	FW	SAFE-END (N2A)	SMLS SB-166 INCONEL	7	NX9923	0.06		X	1.02	
RRA-F2	10	SE-N02	FW	RECIRC. INLET NOZZLE	FORGED SA-508 CL. 2 LOW ALLOY STEEL	---	NA	---		X	1.03	SAFE-END REPLACED IN 1978

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
nutech

LINE NO.		SYSTEM RECIRCULATION RISERS - LOOP B (N2B)							REVISION - DATE		PAGE		
WELD NUMBER	DIA. (IN)	WELD TYPE	SHOP OR FIELD WELD	COMPONENT	MATERIAL TYPE & SPECIFICATION	HEAT TREATMENT	HEAT NUMBER	CARBON CONTENT (%)	NUREG 0313 STATUS			STRESS RULE INDEX	COMMENTS
									S E R V S	N C O O N F	C D M F		
				16" RING HEADER (11-2)	R&W A358 CL.1 FROM A240-67 T304	1	600120-1B	0.059					SPOOL 11-2 ALSO SHOWN ON PG. A16
RRB-J9	10	Hdr-A	SW	ADAPTER	FORGED A182-F304	6	52624	0.070			X	2.19	
RRB-J7	10	A-P	FW	PIPE (17-2)	SMLS A376 - TP304	5	2P3687	0.051			X	1.25	
RRB-J5	10	P-E	SW	ELBOW(90°LR)	R&W A403-WP304W-67 FROM A240	3	37845-1A	0.061			X	1.75	
RRB-J4	10	E-P	SW	PIPE (17-1)	SMLS A376 - TP304	5	2P3399	0.055			X	1.59	
RRB-J4A	10	P-P	FW	PIPE (17-1)	SMLS A376 - TP304	5	2P3399	0.055			X	0.98	PORTION OF SPOOL 17-1 WAS CUT OUT AND REPLACED IN 1978
RRB-J3	10	P-P	FW	SAFE-END EXTENSION	FORGED SA-336 GR. F8	7	M53S	0.030			X	1.23	
RRB-F2A	10	P-SE	FW	SAFE-END (N2B)	SMLS SB-166 INCONEL	7	NX9923	0.06			X	1.02	SAFE-END REPLACED IN 1978
RRB-F2	10	SE-NOZ	FW	RECIRC. INLET NOZZLE	FORGED SA-508 CL.2 LOW ALLOY STEEL	---	NA	---			X	1.03	

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
nutech

LINE NO.		SYSTEM		RECIRCULATION RISERS - LOOP B (N2C)						REVISION - DATE	PAGE		
WELD NUMBER	DIA (IN)	WELD TYPE	SHOP OR FIELD WELD	COMPONENT	MATERIAL TYPE & SPECIFICATION	HEAT TREATMENT	HEAT NUMBER	CARBON CONTENT (%)	NUREG 0313 STATUS			STRESS RULE INDEX	COMMENTS
									S E R N V S	N C O N F F	C O N F		
				16" RING HEADER (11-1)	R&W A358 CL.1 FROM A240-67 T304	1	600120-1B	0.059					SPOOL 11-1 ALSO SHOWN ON PG. A16
RRC-J5	10	Hdr-A	SW	ADAPTER	FORGED A182-F304	6	52624	0.070			X	2.10	
RRC-J7	10	A-P	FW	PIPE (18-2)	SMLS A376 TP304	5	2P3687	0.051			X	1.24	
RRC-J5	10	P-E	SW	ELBOW(90°LR)	R&W A403-WP304W-67 FROM A240	3	37845-1A	0.061			X	1.73	
RRC-J4	10	E-P	SW	PIPE (18-1)	SMLS A376-TP304	5	2P3399	0.055			X	1.40	
RRC-J4A	10	P-P	FW	PIPE (18-1)	SMLS A376-TP304	5	2P3399	0.055			X	0.98	PORTION OF SPOOL 18-1 WAS CUT OUT AND REPLACED IN 1978
RRC-J3	10	P-P	FW	SAFE-END EXTENSION	FORGED SA-336 GR. F8	7	M53S	0.030			X	1.23	
RRC-F2A	10	P-SE	FW	SAFE-END (N2C)	SMLS SB-166 INCONEL	7	NX9923	0.06			X	1.02	SAFE-END REPLACED IN 1978
RRC-F2	10	SL-NO2	FW	RECIRC. INLET NOZZLE	FORGED SA-508 CL.2 LOW ALLOY STEEL	---	NA	---			X	1.03	

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
utech

LINE NO. RRD				SYSTEM RECIRCULATION RISERS - LOOP B (N2D)							REVISION - DATE 0 4/11/80		PAGE A20
WELD NUMBER	DIA (IN)	WELD TYPE	SHOP OR FIELD WELD	COMPONENT	MATERIAL TYPE & SPECIFICATION	HEAT TREATMENT	HEAT NUMBER	CARBON CONTENT (%)	MIREG 9013 STATUS			STRESS RATE INDEX	COMMENTS
									S E R V S	N C O N F	C O N F		
				16" RING HEADER (11-1)	R&W A358 CL.1 FROM A240-67 T304	1	600120-1B	0.059					SPOOL 11-1 ALSO SHOWN ON PG. A16
RMB-J2	10	Hdr-A	SW							X		1.83	
				ADAPTER	FORGED A182-F304	6	52624	0.070					
RRD-J7	10	A-P	FW							X		1.13	
				PIPE (19-2)	SMLS A376-TP304	5	2P3687	0.051					
RRD-J5	10	P-E	SW							X		1.58	
				ELBOW(90°LR)	R&W A403-WP304W-67 FROM A240	3	37845-1A	0.061					
RRD-J4	10	E-P	SW							X		1.44	
				PIPF (19-1)	SMLS A376-TP304	5	2P3399	0.055					
RRD-J4A	10	P-P	FW							X		0.98	
				PIPE (19-1)	SMLS A376-TP304	5	2P3399	0.055					PORTION OF SPOOL 17-1 WAS CUT OUT AND REWELDED IN 1978
RRD-J3	10	P-P	FW							X		1.23	
				SAFE-END EXTENSION	FORGED SA-336 GR. F8	7	M53S	0.030					
RRD-F2A	10	P-SE	FW								X	1.02	
				SAFE-END (N2D)	SMLS SB-166 INCONEL	7	NX9923	0.06					SAFE-END REPLACED IN 1978
RRD-F2	10	SE-NOZ	FW								X	1.03	
				RECIRC. INLET NOZZLE	FORGED SA-508 CL.2 LOW ALLOY STEEL	---	NA	---					

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
nutech

LINE NO.				SYSTEM							REVISION - DATE		PAGE
RBB				RECIRCULATION BYPASS LINE - LOOP B							0 4/11/80		A21
WELD NUMBER	DIA. (IN.)	WELD TYPE	SHOP OR FIELD WELD	COMPONENT	MATERIAL TYPE & SPECIFICATION	HEAT TREATMENT	HEAT NUMBER	CARBON CONTENT (%)	NUREG 0313 STATUS			STRESS RULE INDEX	COMMENTS
				WELDOLET 22"X4"	FORGED A182-F304	6	812680 (496E)	0.060	S E R H V S	S E R H V S	N C O O N F	C O N F	
RBB-J1	4	WOL-P	FW						X	X		1.23	ALSO SHOWN ON PG. A15
				PIPE	SMLS A376-TP304	5	2P3371	0.057					
RBB-J2	4	P-E	SW						X	X		1.39	
				ELBOW(90°LR)	SMLS A403-WP304W-67 FROM A312	3	20257 CFR0	0.047					
RBB-J3	4	E-P	SW						X	X		1.50	
				PIPE	SMLS A376-TP304	5	2P3371	0.057					
RBB-J6	4	P-T	FW						X	X		1.86	
				TEE	SMLS A403-WP304W-67 FROM A312	3	37368 CFRP	0.060					
RBB-J7	4	T-FL	SW						X	X		1.29	
				WN FLANGE (900#-LONG)	FORGED A182-F316	4	E1460	0.060					
				BLIND FLANGE	FORGED A182-F316	8	E1460	0.060					
				TEE	SMLS A403-WP304W-67 FROM A312	3	37368 CFRP	0.060					ALSO SHOWN ON PG. A14
RBB-J8	4	T-P	FW						X	X		1.99	
				PIPE	SMLS A376-TP304	5	2P3371	0.057					
RBB-J9	4	P-E	SW						X	X		1.73	

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
nutech

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
utech

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
nutech

Prepared for
IOWA ELECTRIC
LIGHT & POWER
COMPANY

STRESS CORROSION CRACKING EVALUATION

DUANE ARNOLD ENERGY CENTER

Prepared by
utech

APPENDIX B

STRESS RULE INDEX EVALUATION SUMMARY

S C O R E
-- VERSION 1.0.0 --

KEY FOR STRESS RULE INDEX EVALUATION - SUMMARY

ISI WELD ID	ISI Weld Number Pipe Fabricator's Weld Number
WELD TYPE	Components Adjoining Weld
PIPE SIZE	Pipe Diameter (in.)
NODE NO	NSC Stress Analysis Mode Number
COMP TYPE	Component Type Used in Determining NB-3600 Piping Stress Indices

B1 / B2	NB-3600 Piping Stress Indices
C1 / C2	
K1 / K2	

SI(PRES)	Pressure Stress Intensity (psi)
SI(DW)	Dead Weight Stress Intensity (psi)
SI(THER)	Thermal Stress Intensity (psi)
PM + PB	Primary Stress Intensity (psi)
PM+PB+D+F	Primary plus Secondary plus Peak Stress Intensity (psi)
Q + F	Secondary plus Peak Stress Intensity (psi)
RESI ST	Weld Residual Stress (psi)
YIELD ST	Code Minimum Yield Strength of Piping Material at 550°F (psi)
MOD. ELA.	Young's Modulus of Piping Material (psi)

SRI,PRI	Stress Rule Index - Primary Stress Component
SRI,SEC	Stress Rule Index - Secondary Stress Component

SRI TOTAL	Overall Stress Rule Index
-----------	---------------------------

S C O R E

-- VERSION 1.0.0 --

PAGE 29 *

DUANE ARNOLD RECIRCULATION PIPING,LOOP A E B

04/01/80 *

STRESS RULE INDEX EVALUATION - SUMMARY

ISI WELD ID	RCA-J3 A1	RCA-J4 RS-N-A1-A	RCA-J5 RS-L-A1-B	RCA-J6 A2	RCA-J7 RS-N-A2-C
WELD TYPE	SE-P	P-E	E-P	P-P	P-P
PIPE SIZE	22.00	22.00	22.00	22.00	22.00
NOTE NO	10A	15A	20A	A2	SNAZC
COMP TYPE	TRANS	ELBOWLR	ELBOWLR	PIPE	PIPE
B1 / B2	.50/1.00	1.00/3.52	1.00/3.52	.50/1.00	.50/1.00
C1 / C2	1.37/1.50	1.23/4.70	1.23/4.70	1.10/1.00	1.10/1.00
K1 / K2	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
SII(PRES)	12388.70	12388.70	12388.70	12388.70	12388.70
SI (DW)	716.42	140.12	344.64	215.70	0.00
SI(THRE)	1145.68	1038.97	699.63	543.29	0.00
PM + PB	6910.78	12892.15	13602.37	6410.06	6194.35
PM+PB+Q+F	25432.10	28324.31	27184.80	17719.27	16353.09
Q + F	18521.33	15442.16	13582.43	11309.22	10158.74
RESI ST	28000.00	28000.00	28000.00	28000.00	28000.00
YIELD ST	18800.00	18800.00	18800.00	18800.00	18800.00
MOD. ELA.	25666000.00	25666000.00	25666000.00	25666000.00	25666000.00
SRI,PRI	.3676	.6852	.7235	.3410	.3295
SRI,SEC	.6533	.6194	.5929	.5605	.5441
SRI TOTAL	.0309	1.3047	1.3164	.9015	.8736

S C O R E

-- VERSION 1.0.0 --

PAGE 30 *

DUANE ARNOLD RECIRCULATION PIPING,LOOP A & B

04/01/80 *

STRESS RULE INDEX EVALUATION - SUMMARY

1ST WELD ID	RCA-J12 RS-N-A2-B	RCA-J13 A3	RCA-J15 A4	RCA-J18 RS-N-A3-A	RCA-J21 RS-N-A3-D
WELD TYPE	P-E	E-V	V-P	BPC	P-E
PIPE SIZE	22.00	22.00	22.00	22.00	22.00
NODE NO	35A	40A	55A	60A	65A
COMP TYPE	ELBOWLR	ELBOWLR	TRANS	BRANRUR	ELBOWSR
B1 / B2	1.00/3.52	1.00/3.52	.50/1.00	1.00/1.00	1.00/4.62
C1 / C2	1.23/4.70	1.23/4.70	1.37/1.50	2.00/1.00	1.46/6.15
K1 / K2	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
SI(PRES)	12388.70	12388.70	12388.70	12388.70	12388.70
SI (DW)	412.59	481.50	176.64	63.29	504.37
SI(ETHER)	402.18	507.15	450.15	440.38	31.85
PM + PB	13841.66	14084.37	6371.00	12452.00	14716.48
PM+PB+Q+F	25245.06	26714.77	22102.43	30639.51	32083.63
Q + F	11403.39	12630.40	15731.44	18187.51	17367.16
RESI ST	28000.00	28000.00	28000.00	28000.00	28000.00
YIELD ST	18800.00	18800.00	18800.00	18800.00	18800.00
MOD. ELA.	25666000.00	25666000.00	25666000.00	25666000.00	25666000.00
SRI,PRI	.7363	.7492	.3389	.6623	.7828
SRI,SEC	.5618	.5793	.6236	.6586	.6469
SRI TOTAL	1.2981	1.3285	.9624	1.3209	1.4297

S C O R E

-- VERSION 1.0.0 --

PAGE 31

04/01/80

DUANE ARNOLD RECIRCULATION PIPING,LOOP A E B

STRESS RULE INDEX EVALUATION - SUMMARY

ISI WELD ID	RCA-J22 A5	RCA-J24 A6	RCA-J27 RD-A-A1-A	RCA-J28 A7	RCA-J30 A8
WELD TYPE	E-PP	PP-P	BPC	P-V	V-E
PIPE SIZE	22.00	22.00	6.00	22.00	22.00
NODE NO	70A	90A	95A	100A	115A
CUMP TYPE	ELBOWSR	TRANS	TEE	TRANS	ELBOWLR
B1 / B2	1.00/4.62	.50/1.00	1.00/2.35	.50/1.00	1.00/3.18
C1 / C2	1.46/6.15	1.36/1.48	1.50/3.13	1.36/1.48	1.23/4.24
K1 / K2	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
SI(PRES)	12388.70	12748.55	3987.40	12748.55	12748.55
SI(DW)	1061.17	294.64	179.63	94.27	227.62
SI(THRE)	526.47	436.32	2766.79	365.14	505.85
PM + PB	17280.24	6668.91	4409.40	6468.55	13472.78
PM+PB+Q+F	39299.10	22814.02	23790.24	22088.29	24459.25
Q + F	22012.85	16145.10	19380.84	15619.74	10986.46
RESI ST	28000.00	28000.00	39000.00	28000.00	28000.00
YIELD ST	18800.00	18800.00	18800.00	18800.00	18800.00
MOD. ELA.	25666000.00	25666000.00	25666000.00	25666000.00	25666000.00
SRI,PRI	.9195	.3547	.2345	.3441	.7166
SRI,SEC	.7131	.5295	.8324	.6220	.5559
SRI TOTAL	1.6326	.9842	1.0670	.9660	1.2725

S C O R E

-- VERSION 1.0.0 --

PAGE 32

04/01/80

DUANE ARNOLD RFCIRCULATION PIPING,LOOP A E 8

STRESS RULE INDEX EVALUATION - SUMMARY

1ST WELD ID	RCA-J32 RD-N-A2-A	RCA-J34 RD-N-A2-B	RBA-J1 A18	RBA-J2 RD-N-A8-A	RBA-J3 RD-N-A8-B
WELD TYPE	E-P	BPC	WGL-P	P-E	E-P
PIPE SIZE	22.00	6.00	4.00	4.00	4.00
NODE NO	120A	125A	A18	130A	135A
COMP TYPE	ELBOWLR	TEE	PIPE	ELBOWLR	ELBOWLR
B1 / B2	1.00/3.18	1.00/2.35	.50/1.00	1.00/2.43	1.00/2.43
C1 / C2	1.23/4.24	1.50/3.13	1.10/1.00	1.27/3.24	1.27/3.24
K1 / K2	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
SIEPRESS	12748.55	3987.40	8031.90	8031.90	8031.90
SI (DW)	208.79	1115.00	591.19	76.24	155.46
SIEITHER	444.87	2860.58	9106.68	3049.46	4088.63
PM + PB	13412.87	6606.90	4607.14	8217.26	8409.89
PM+PB+Q+F	23849.85	29593.08	28058.27	30437.64	36963.89
Q + F	10436.99	22986.19	23451.13	22220.38	28554.00
REST ST	28000.00	39000.00	45000.00	45000.00	45000.00
YIELD ST	18800.00	18800.00	18800.00	18800.00	18800.00
MOD. ELA.	25666000.00	25666000.00	25666000.00	25666000.00	25666000.00
SRI,PRI	.7135	.3514	.2451	.4371	.4473
SRI,SFC	.5441	.4839	.9760	.9585	1.0488
SRI TOTAL	1.2615	1.2353	1.2211	1.3956	1.4961

* NUTECH
 *
 * DUANE ARNOLD RECIRCULATION PIPING, LOOP A E B
 *
 * STRESS RULE INDEX EVALUATION - SUMMARY
 *
 * PAGE 33 *
 * 04/01/80 *

ESI WELD ID	RBA-J6 A19	RBA-J8 A20	RBA-J7 RD-N-A9-A	RBA-J9 RD-N-A10-A	RBA-J10 A21
WELD TYPE	P-T	T-P	T-FL	P-E	E-V
PIPE SIZE	4.00	4.00	4.00	4.00	4.00
NODE NO	140A	140A	140A	150A	155A
COMP TYPE	TEE	TEE	TEE	ELBOWLR	ELBOWLR
B1 / B2	1.00/1.69	1.00/1.69	1.00/1.69	1.00/2.43	1.00/2.43
C1 / C2	1.50/2.26	1.50/2.26	1.50/2.26	1.27/3.24	1.27/3.24
K1 / K2	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
SII(PRES)	8031.90	8031.90	8031.90	8031.90	8031.90
SII(ON)	459.35	1446.17	0.00	740.30	405.85
SII(OTHER)	10590.04	10406.92	0.00	5588.41	3889.88
PM + PB	8809.42	10479.74	8031.90	9831.86	9018.69
PM+PB+Q+F	59343.71	62608.58	14457.42	49128.28	37265.23
Q + F	50534.30	52128.83	6425.52	39296.42	28246.54
RESI ST	45000.00	45000.00	45000.00	45000.00	45000.00
YIELD ST	18800.00	18800.00	18800.00	18800.00	18800.00
MOD. ELA.	25666000.00	25666000.00	25666000.00	25666000.00	25666000.00
SRI,PRI	.4686	.5574	.4272	.5230	.4797
SRI,SEC	1.3622	1.3849	.7333	1.2020	1.0444
SRI TOTAL	1.8308	1.9424	1.1605	1.7249	1.5241

* SCORE
 * NUTECH PAGE 34 *
 * -- VERSION 1.0.0 -- 04/01/80 *
 * DUANE ARNOLD RECIRCULATION PIPING,LOOP A & B *
 * STRESS RULE INDEX EVALUATION - SUMMARY *

ISI WELD ID	RBA-J12 A22	RCA-J38 RD-N-A2-E	RCA-J41 RD-N-A2-C	RCA-J43 A9	RMA-J6 RD-N-A3-E
WELD TYPE	V-WOL	P-P	P-T	T-CR	CR-CP
PIPE SIZE	4.00	22.00	22.00	22.00	22.00
NODE NO	167A	173A	175A	180A	185A
COMP TYPE	TRANS	PIPE	TEE	TEE	TEE
B1 / B2	.50/1.00	.50/1.00	1.00/2.35	1.00/2.35	1.00/2.35
C1 / C2	1.34/1.45	1.10/1.00	1.50/3.13	1.50/3.13	1.50/3.13
K1 / K2	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
SIE(PRES)	8031.90	12748.55	12748.55	12748.55	12748.55
SI (DW)	1623.18	5.23	98.48	398.75	0.00
SI(ETHER)	5460.72	195.91	219.90	511.41	0.00
PM + PB	5639.13	6379.51	12979.91	13685.35	12748.55
PM+PB+Q+F	31448.36	17190.16	24742.49	28079.18	22947.40
Q + F	25809.23	10810.65	11762.59	14393.84	10198.84
REST ST	45000.00	28000.00	28000.00	28000.00	28000.00
YIELD ST	18800.00	18800.00	18800.00	18800.00	18800.00
MOD. ELA.	25666000.00	25666000.00	25666000.00	25666000.00	25666000.00
SRI,PRI	.3000	.3393	.6904	.7279	.6781
SRI,SEC	1.0097	.5534	.5670	.6045	.5447
SRI TOTAL	1.3096	.8927	1.2574	1.3324	1.2228

S C O R E

-- VERSION 1.0.0 --

PAGE 35

04/01/80

DUANE ARNOLD RECIRCULATION PIPING,LOOP A & B

STRESS RULE INDEX EVALUATION - SUMMARY

ISI WELD ID	RMA-J5 RD-N-A3-D	RMA-J4 RD-N-A3-C	RRG-J7 A12	RRG-J5 RD-N-A6-B	RRG-J4 RD-N-A6-C
WELD TYPE	HDR-CR	HDR-A	A-P	P-E	E-P
PIPE SIZE	16.00	10.00	10.00	10.00	10.00
NODE NO	.1874	190A	ADATR	195A	200A
COMP TYPE	TEE	TEE	PIPE	ELBOWLR	ELBOWLR
B1 / B2	1.00/2.35	1.00/2.31	.50/1.00	1.00/3.18	1.00/3.18
C1 / C2	1.50/3.13	1.50/3.09	1.10/1.00	1.26/4.24	1.26/4.24
K1 / K2	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
SI(PRES)	12482.49	11930.12	11930.12	11930.12	11930.12
SI EDW	167.25	870.40	870.40	567.81	227.12
SI(ETHER)	1941.48	9150.02	9150.02	3204.63	2603.61
PM + PB	12875.42	13944.97	6835.46	13735.73	12652.34
PM+PB+Q+F	34358.26	77144.38	33784.50	46798.68	39611.68
Q + F	21482.84	63199.40	26949.04	33062.95	26959.33
RESI ST	30000.00	33500.00	33500.00	33500.00	33500.00
YIELD ST	18800.00	18800.00	1d800.00	18800.00	18800.00
MOD. ELA.	25666000.00	25666000.00	25666000.00	25666000.00	25666000.00
SRI,PRI	.6849	.7418	.3636	.7306	.6730
SRI,SEC	.7341	1.3788	.8619	.9491	.8621
SRI TOTAL	1.4189	2.1206	1.2255	1.6797	1.5351

*
 * NUTECH
 *
 * S C O R E
 * -- VERSION 1.0.0 --
 * DUANE ARNOLD RECIRCULATION PIPING, LOOP A & B
 *
 * STRESS RULE INDEX EVALUATION - SUMMARY
 *

PAGE 36

04/01/80

ISI WELD ID	RMA-J2 RD-N-A3-B	RRH-J7 A13	RMA-J1 RD-N-A3-A	RRH-J5 RD-N-A7-B	RRH-J4 RD-N-A7-C
WELD TYPE	HDR-A	A-P	CP-HDR	P-E	E-P
PIPE SIZE	10.00	10.00	16.00	10.00	10.00
NODE NO	215A	ADATR	220A	225A	230A
COMP TYPE	TEE	PIPE	TRANS	ELBOWLR	ELBOWLR
SI / B2	1.00/2.31	.50/1.00	.50/1.00	1.00/3.18	1.00/3.18
CI / C2	1.50/3.09	1.10/1.00	1.36/1.48	1.26/4.24	1.26/4.24
K1 / K2	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
SI(PRES)	11930.12	11930.12	12482.49	11930.12	11930.12
SI (DW)	135.20	133.65	0.00	158.63	132.51
SI(THRE)	7874.17	7874.17	0.00	2840.50	3098.50
PM + PB	12243.10	6098.71	6241.25	12434.55	12351.48
PM+PB+Q+F	65971.68	30161.83	20405.23	40896.90	42666.56
Q + F	53728.58	24063.12	14163.98	28462.35	30315.08
RESI ST	33500.00	33500.00	30000.00	33500.00	33500.00
YIELD ST	18800.00	18800.00	18800.00	18800.00	18800.00
MOD. ELA.	25666000.00	25666000.00	25666000.00	25666000.00	25666000.00
SRI,PRI	.6512	.3244	.3320	.6614	.6570
SRI,SEC	1.2438	.8208	.6297	.8835	.9099
SRI TOTAL	1.8950	1.1452	.9617	1.5449	1.5669

S C O R E

-- VERSION 1.0.0 --

PAGE 37

04/01/80

DUANE ARNOLD RECIRCULATION PIPING,LOOP A & B

STRESS RULE INDEX EVALUATION - SUMMARY

ISE WELD ID	RMA-J7 RD-N-A3-F	RMA-J8 RD-N-A3-G	RRF-J7 A11	RRF-J5 RD-N-A5-B	RRF-J4 RD-N-A5-C
WELD TYPE	CR-HDR	HDR-A	A-P	P-E	E-P
PIPE SIZE	16.00	10.00	10.00	10.00	10.00
NODE NO	237A	240A	ADATR	245A	250A
COMP T/PE	TEE	TEE	PIPE	ELBOWLR	ELBOWLR
B1 / B2	1.00/2.35	1.00/2.31	.50/1.00	1.00/3.18	1.00/3.18
C1 / C2	1.50/3.13	1.50/3.09	1.10/1.00	1.26/4.24	1.26/4.24
K1 / K2	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
SI(PRES)	12482.49	11930.12	11930.12	11930.12	11930.12
SI (DW)	145.50	882.20	882.20	612.61	218.54
SI(ETHER)	1380.76	8263.53	8263.53	3276.00	1492.08
PM + PB	12824.32	13972.29	6847.26	13878.17	12625.06
PM+PB+Q+F	31074.07	72284.89	32210.06	47685.28	31063.16
Q + F	18249.76	58312.60	25362.80	33807.11	18438.10
REST ST	30000.00	33500.00	33500.00	33500.00	33500.00
YIELD ST	18800.00	18800.00	18800.00	18800.00	18800.00
MOD. ELA.	25666000.00	25666000.00	25666000.00	25666000.00	25666000.00
SRI,PRI	.6821	.7432	.3642	.7382	.6715
SRI,SEC	.6880	1.3091	.8393	.9597	.7406
SRI TOTAL	1.3701	2.0523	1.2035	1.6979	1.4121

*
 * NUTECH
 *
 * SCORE
 * -- VERSION 1.0.0 --
 * DUANE ARNOLD RECIRCULATION PIPING,LOOP A E B
 *
 * STRESS RULE INDEX EVALUATION - SUMMARY
 *

PAGE 38
04/01/80

ISI WELD ID	RMA-J10 RD-N-A3-H	RRE-J7 A10	RMA-J11 RD-N-A3-J	RRE-J5 RD-N-A4-B	RRE-J4 RD-N-A4-C
WELD TYPE	HDR-A	A-P	HDR-CP	P-E	E-P
PIPE SIZE	10.00	10.00	16.00	10.00	10.00
NUDE NO	265A	ADATR	270A	275A	280A
COMP TYPE	TEF	P.PE	TRANS	ELBOWLR	ELBOWLR
81 / 82	1.00/2.31	.50/1.00	.50/1.00	1.00/3.18	1.00/3.18
C1 / C2	1.50/3.09	1.10/1.00	1.36/1.48	1.26/4.24	1.26/4.24
K1 / K2	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
SIE(PRES)	11930.12	11930.12	12482.49	11930.12	11930.12
SI (DW)	169.86	169.86	0.00	122.30	27.31
SIE(THRS)	6357.08	6357.08	0.00	3020.30	1726.56
PM + PB	12323.31	6134.91	6241.25	12319.01	12016.96
PM+PB+Q+F	57735.75	27496.24	20405.23	41991.79	31393.27
Q + F	45412.44	21361.33	14163.98	29672.78	19376.30
RESI ST	33500.00	33500.00	30000.00	33500.00	33500.00
YIELD ST	18800.00	18800.00	18800.00	18800.00	18800.00
MOD. ELA.	25666000.00	25666000.00	25666000.00	25666000.00	25666000.00
SRI,PRI	.6555	.3263	.3320	.6553	.6392
SRI,SEC	1.1252	.7823	.6297	.9008	.7540
SRI TOTAL	1.7807	1.1056	.9617	1.5560	1.3932

* NUTECH

S C O R E

-- VERSION 1.0.0 --

DUANE ARNOLD RECIRCULATION PIPING,LOOP A E B

PAGE 39

04/01/80

STRESS RULE INDEX EVALUATION - SUMMARY

1ST WELD ID	RCB-J3 B1	RCB-J4 RS-N-B1-A	RCB-J5 RS-N-B1-B	RCB-J6 B2	RCB-J7 RS-N-B2-A
WELD TYPE	SE-P	P-E	E-P	P-T	T-P
PIPE SIZE	22.00	22.00	22.00	22.00	22.00
NODE NO	108	158	208	238	238
COMP TYPE	TRANS	ELBOWLR	ELBOWLR	TEE	TEE
B1 / B2	.50/1.00	1.00/3.52	1.00/3.52	1.00/2.59	1.00/2.59
C1 / C2	1.37/1.50	1.23/4.70	1.23/4.70	1.50/3.45	1.50/3.45
K1 / K2	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
SIEPRESS	12388.70	12388.70	12388.70	12388.70	12388.70
SI EDWT	628.10	390.10	59.94	0.00	377.71
SIEETHER	843.00	866.06	680.35	400.09	577.96
PM + PB	6822.45	13762.48	12599.78	12388.70	13366.67
PM+PB+Q+F	24378.17	28975.73	24615.61	24785.84	28238.21
Q + F	17555.72	15213.25	12015.83	12397.14	14871.54
REST ST	28000.00	28000.00	28000.00	28000.00	28000.00
YIELD ST	18800.00	18800.00	18800.00	18800.00	18800.00
MUD. ELA.	25666000.00	25666000.00	25666000.00	25666000.00	25666000.00

SRI,PRI	.3629	.7320	.6702	.6590	.7110
SRI,SEC	.6496	.5162	.5706	.5760	.6113

SRI TOTAL	1.0125	1.1452	1.2408	1.2350	1.3223

S C O R E

-- VERSION 1.0.0 --

PAGE 40

04/01/80

DUANE ARNOLD RECIRCULATION PIPING,LOOP A & B

STRESS RULE INDEX EVALUATION - SUMMARY

ISI WELD ID	RCB-J4 RS-N-B2-A1	RCB-J15 RS-N-B2-E	RCB-J16 B3	RCB-J18 B4	RCB-J21 RS-N-B3-A
WELD TYPE	P-P	P-E	E-V	V-P	BPC
PIPE SIZE	22.00	22.00	22.00	22.00	22.00
NODE NO	N82A1	358	408	558	608
COMP TYPE	PIPE	ELBOWLR	ELBOWLR	TRANS	BRANRUN
B1 / B2	.50/1.00	1.00/3.52	1.00/3.52	.50/1.00	1.00/1.00
C1 / C2	1.10/1.00	1.23/4.70	1.23/4.70	1.37/1.50	2.00/1.00
K1 / K2	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
SI(PRES)	12368.70	12388.70	12388.70	12388.70	12388.70
SI (DW)	110.77	352.63	465.27	211.92	103.13
SI(ETHER)	386.75	610.02	506.64	379.84	345.30
PM + PB	6305.13	13630.52	14027.21	6406.27	12491.83
PM+PB+Q+F	17248.63	26495.02	26573.34	22007.99	30540.06
Q + F	10943.51	12864.50	12546.12	15601.72	18048.23
RESI ST	28000.00	28000.00	28000.00	28000.00	28000.00
YIELD ST	18800.00	18800.00	18800.00	18800.00	18800.00
MOD. ELA.	25666000.00	25666000.00	25666000.00	25666000.00	25666000.00
SRI,PRI	.3354	.7250	.7461	.3408	.6645
SRI,SEC	.5553	.5827	.5781	.6217	.6566
SRI TOTAL	.6907	1.3077	1.3243	.9625	1.3211

* NUTECH

S C O R E

-- VERSION 1.0.0 --

DUANE ARNOLD RECIRCULATION PIPING, LOOP A & B

PAGE 41

04/01/80

STRESS RULE INDEX EVALUATION - SUMMARY

ISI WELD ID	RCB-J24 RS-N-B3-D	RCB-J25 85	RCB-J27 B6	RCB-J30 RD-N-B1-A	RCB-J31 B7
WELD TYPE	P-E	E-PP	PP-P	BPC	P-V
PIPE SIZE	22.00	22.00	22.00	6.00	22.00
NODE NO	658	708	908	958	1008
COMP TYPE	ELBOWSR	ELBOWSR	TRANS	TEE	TRANS
SI / S2	1.00/4.62	1.00/4.62	.50/1.00	1.00/2.35	.50/1.00
C1 / C2	1.46/6.15	1.46/6.15	1.36/1.48	1.50/3.13	1.36/1.48
K1 / K2	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
SI(PRES)	12388.70	12388.70	12748.55	3987.40	12748.55
SI (DW)	445.10	975.82	253.73	199.77	48.20
SI(ETHER)	277.13	335.77	226.75	2873.99	231.29
PM + PB	14442.93	16892.31	6628.00	4456.73	6422.48
PM+PB+Q+F	29713.34	36241.40	22144.58	24508.27	21607.42
Q + F	15270.41	19349.09	15516.58	20051.54	15184.95
RESI ST	28000.00	28000.00	28000.00	39000.00	28000.00
YIELD ST	18800.00	18400.00	18800.00	18800.00	18800.00
MOD. ELA.	25666000.00	25666000.00	25666000.00	25666000.00	25666000.00
SRI,PRI	.7682	.8485	.3526	.2371	.3416
SRI,SEC	.6170	.6751	.6205	.8420	.6158
SRI TOTAL	1.3852	1.5737	.9730	1.0791	.9574

S C O R E

-- VERSION 1.0.0 --

PAGE 42

04/01/80

DUANE ARNOLD RECIRCULATION PIPING,LOOP A & B

STRESS RULE INDEX EVALUATION - SUMMARY

ISI WELD ID	RCB-J33 B8	RCB-J35 RD-N-B2-A	RCB-J37 RD-N-B2-B	RBB-J1 B18	RBB-J2 RD-N-B8-A
WELD TYPE	V-E	E-P	BPC	WOL-P	P-E
PIPE SIZE	22.00	22.00	6.00	4.00	4.00
NODE NO	1158	1208	1258	818	1308
COMP TYPE	ELBOWLR	ELBOWLR	TEE	PIPE	ELBOWLR
B1 / B2	1.00/3.18	1.00/3.18	1.00/2.35	.50/1.00	1.00/2.43
C1 / C2	1.23/4.24	1.23/4.24	1.50/3.13	1.10/1.00	1.27/3.24
K1 / K2	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
SIEPPRES	12748.55	12748.55	3987.40	8031.90	8031.90
SI (DWI)	223.04	172.81	1124.39	657.56	73.86
SEITHER	246.12	170.00	2993.71	9459.36	3011.41
PM + PB	13458.21	13298.39	6628.94	4673.50	8211.47
PM+PB+Q+F	22440.95	21514.32	30396.60	28812.56	30201.72
Q + F	8982.74	8215.93	23757.66	24139.05	21990.24
REST ST	26000.00	28000.00	39000.00	45000.00	45000.00
YIELD ST	18800.00	18800.00	1d800.00	18800.00	18800.00
MUD. ELA.	25666000.00	25666000.00	25666000.00	25666000.00	25666000.00
SRI,PRI	.7159	.7074	.3526	.2486	.4368
SRI,SEC	.5273	.5164	.8950	.9d58	.9552
SxI TOTAL	1.2432	1.2238	1.2476	1.2344	1.3920

S C U R E

-- VERSION 1.0.0 --

DUANE ARNOLD RECIRCULATION PIPING,LOOP A E B

PAGE 43

04/01/80

STRESS RULE INDEX EVALUATION - SUMMARY

ISI WELD ID	RBB-J3 RD-N-B8-B	RBB-J6 B19	RBB-J8 B20	RBB-J7 RD-N-B9-A	RBB-J9 RD-N-B10-A
WELD TYPE	E-P	P-T	T-P	T-FL	P-E
PIPE SIZE	4.00	4.00	4.00	4.00	4.00
NODE NO	1358	1408	1408	1458	1508
COMP TYPE	ELBOWLR	TEE	TEE	TEE	ELBOWLR
B1 / B2	1.00/2.43	1.00/1.69	1.00/1.69	1.00/1.69	1.00/2.43
C1 / C2	1.27/3.24	1.50/2.26	1.50/2.26	1.50/2.26	1.27/3.24
K1 / K2	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
STIFFNESS	8031.90	8031.90	8031.90	8031.90	8031.70
SI (DWI)	173.68	477.39	1562.36	1029.63	746.35
SI (THER)	4147.79	11066.86	10910.63	0.00	5674.30
PM + PB	8454.18	8839.95	10676.40	9774.68	9846.56
PM+PB+Q+F	37415.41	61353.99	65126.83	18640.10	49664.76
Q + F	28961.22	52514.04	54450.43	8865.41	39818.20
RESI ST	45000.00	45000.00	45000.00	45000.00	45000.00
YIELD ST	18800.00	18800.00	18800.00	18800.00	18800.00
MOD. ELA.	25666000.00	25666000.00	25666000.00	25666000.00	25666000.00
SRI,PKI	.4497	.4702	.5679	.5199	.5238
SRI,SEC	1.0546	1.3904	1.4180	.7681	1.2094
SRI TOTAL	1.5043	1.8605	1.9859	1.2880	1.7332

*
* NUTECH S C O R E PAGE 44
* -- VERSION 1.0.0 -- 04/01/80
* DUANE ARNOLD RECIRCULATION PIPING,LOOP A & B
*
* STRESS RULE INDEX EVALUATION - SUMMARY

WELD ID	R88-J10 B21	R88-J12 B22	RCB-J41 RD-N-B2-E	RCB-J44 RD-N-B2-C	RCB-J46 B9
WELD TYPE	E-V	V-WOL	P-P	P-T	T-CR
PIPE SIZE	4.00	4.00	22.00	22.00	22.00
NODE NO	1528	1678	1738	1758	1808
COMP TYPE	ELBOWLK	TRANS	PIPE	TEE	TEE
B1 / B2	1.00/2.43	.50/1.00	.50/1.00	1.00/2.35	1.00/2.35
C1 / C2	1.27/3.24	1.34/1.45	1.10/1.00	1.50/3.13	1.50/3.13
K1 / K2	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
SIE(PRES)	8031.90	8031.90	12748.55	12748.55	12748.55
SI (DWI)	413.40	1652.74	57.24	431.51	381.12
WEATHER	3793.97	3769.66	492.65	1649.72	517.30
PM + PB	9037.03	5668.69	6431.52	13762.30	13643.93
PM+PB+Q+F	36749.58	27101.63	17817.40	34682.07	28013.04
Q + F	27712.55	21432.94	11386.38	20919.77	14369.11
RESET	45000.00	45000.00	28000.00	28000.00	28000.00
YIELD ST	18800.00	18800.00	18800.00	18800.00	18800.00
MOD. ELA.	25666000.00	25666000.00	25666000.00	25666000.00	25666000.00
SKI,PHI	.4807	.3015	.3421	.7320	.7257
SKI,SEC	1.0364	.9473	.5616	.6975	.6041
SKI TOTAL	1.5175	1.2488	.9037	1.4296	1.3299

S C O R E

-- VERSION 1.0.0 --

DUANE ARNOLD RECIRCULATION PIPING, LOOP A & B

PAGE 45

04/01/80

STRESS RULE INDEX EVALUATION - SUMMARY

ISI WELD ID	RMB-J7 RD-N-B3-E	RMB-J6 RD-N-B3-D	RMB-J5 RD-N-B3-C	RRC-J7 B12	RRC-J5 RD-N-B6-B
WELD TYPE	CR-CP	HDR-CR	HDR-A	A-P	P-E
PIPE SIZE	22.00	16.00	10.00	10.00	10.00
NODE NO	1658	1878	1908	ADATR	1958
COMP TYPE	TEE	TEE	TEE	PIPE	ELBOWLR
B1 / B2	1.00/2.59	1.00/2.59	1.00/2.31	.50/1.00	1.00/3.18
C1 / C2	1.50/3.45	1.50/3.45	1.50/3.09	1.10/1.00	1.26/4.24
K1 / K2	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
S11PRES1	12748.55	12482.49	11930.12	11930.12	11930.12
S11 (DW)	0.00	292.96	886.40	886.40	613.22
S11(THRE)	0.00	1775.68	8875.73	9479.33	3591.54
PH + PB	12748.55	12241.01	13982.00	6851.45	13880.13
PH+PH+Q+F	22947.40	35323.04	75709.42	34406.06	50098.12
Q + F	10198.84	22082.03	61727.41	27554.61	36217.98
RESI ST	28000.00	30000.00	33500.00	33500.00	33500.00
YIELD ST	18800.00	18800.00	18800.00	18800.00	18800.00
MOD. ELA.	25666000.00	25666000.00	25666000.00	25666000.00	25666000.00
SRI,PRE	.67d1	.7043	.7437	.3644	.7383
SRI,SEC	.5447	.7426	1.3578	.8706	.9941
SRI TOTAL	1.2223	1.4469	2.1016	1.2350	1.7324

* NUTCH
 * SCORE
 * -- VERSION 1.0.0 --
 * DUANE ARNOLD RECIRCULATION PIPING,LOOP A E.B
 * STRESS RULE INDEX EVALUATION - SUMMARY
 * PAGE 46
 * 04/01/80

ISI WELD ID	RRC-J4 RD-N-B6-C	RMB-J2 RD-N-d3-B	RRD-J7 B13	RMB-J1 RD-N-B3-A	RRD-J5 RD-N-B7-B
WELD TYPE	E-P	HDR-A	A-P	CP-HDR	P-E
PIPE SIZE	10.00	10.00	10.00	16.00	10.00
NODE NO	2008	2158	ADATR	2208	2258
CUMP TYPE	ELBOWLK	TEE	PIPE	TRANS	ELBOWLR
SL / S2	1.00/3.18	1.00/2.31	.50/1.00	.50/1.00	1.00/3.18
CL / C2	1.26/4.24	1.50/3.09	1.10/1.00	1.36/1.48	1.26/4.24
K1 / K2	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
STIPRESF	11930.12	11930.12	11930.12	12482.49	11930.12
SI (DM)	296.90	338.07	338.07	0.00	232.12
SI(THRE)	1247.51	6603.35	6603.35	0.00	2974.12
PM + PB	12874.25	12712.71	6303.13	6241.25	12668.26
PK+PB+Q+F	29794.74	60038.48	28242.31	20405.23	42477.59
Q + F	16920.49	47325.77	21939.18	14163.98	29809.33
RESI ST	33500.00	33500.00	33500.00	30000.00	33500.00
YIELD ST	18800.00	18800.00	18800.00	18800.00	18800.00
MOD. ELA.	25666000.00	25666000.00	25666000.00	25666000.00	25666000.00
SRI,PRI	.6848	.6762	.3353	.3320	.6738
SRI,SEC	.71d9	1.1525	.7905	.6297	.9027
SRI TOTAL	1.4037	1.6287	1.1258	.9617	1.5766

* NUTECH
 * SCORE
 * -- VERSION 1.0.0 --
 * DUANE ARNOLD RECIRCULATION PIPING,LOOP A & B
 * STRESS RULE INDEX EVALUATION - SUMMARY
 * PAGE 47
 * 04/01/80

EST WELD ID	RRB-J4 RD-N-B7-C	RMB-J8 RD-N-B3-F	RMB-J9 RD-N-B3-G	RRB-J7 B11	RRB-J5 RD-N-B5-B
WELD TYPE	E-P	CR-HDR	HDR-A	A-P	P-E
PIPE SIZE	10.00	16.00	10.00	10.00	10.00
NODE NO	2308	2378	2408	ADATR	2458
COMP TYPE	ELBOWLR	TEE	TEE	PIPE	ELBOWLR
B1 / B2	1.00/3.18	1.00/2.35	1.00/2.31	.50/1.00	1.00/3.18
C1 / C2	1.26/4.24	1.50/3.13	1.50/3.09	1.10/1.00	1.26/4.24
K1 / K2	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
SIE(PRES)	11930.12	12482.49	11930.12	11930.12	11930.12
SI (DW)	82.51	52.84	827.30	827.28	659.52
SIE(THRS)	2013.67	1314.65	10130.23	10130.23	3617.92
PM + PB	12192.50	12606.63	13845.21	6792.34	14027.54
PM+PB+Q+F	34005.74	30178.88	82350.72	35471.28	50653.21
Q + F	21813.24	17572.25	68505.51	28678.94	36625.67
RESE ST	33500.00	30000.00	33500.00	33500.00	33500.00
YIELD ST	18800.00	18800.00	18800.00	18800.00	18800.00
MOD. ELA.	25666000.00	25666000.00	25666000.00	25666000.00	25666000.00
SRI,PRI	.6485	.6706	.7364	.3713	.7461
SRI,SEC	.7847	.6783	1.4545	.8866	.9999
SRI TOTAL	1.4372	1.3489	2.1909	1.2479	1.7461

S C O R E

-- VERSION 1.0.0 --

PAGE 48

04/01/80

DUANE ARNOLD RECIRCULATION PIPING,LOOP A & B

STRESS RULE INDEX EVALUATION - SUMMARY

ISE WELD ID	RKB-J4 RD-N-B5-C	RMB-J11 RD-N-B3-H	RRA-J7 B10	RMB-J12 RD-N-B3-J	RRA-J5 RD-N-B4-B
WELD TYPE	E-P	HDR-A	A-P	HDR-CP	P-E
PIPE SIZE	10.00	10.00	10.00	16.00	10.00
NODE NO	2503	2658	ADATR	2708	2758
COMP TYPE	ELBOWLR	TEE	PIPE	TRANS	ELBOWLR
B1 / B2	1.00/3.18	1.00/2.31	.50/1.00	.50/1.00	1.00/3.18
C1 / C2	1.26/4.24	1.50/3.09	1.10/1.00	1.36/1.48	1.26/4.24
K1 / K2	1.20/1.60	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
S1(PRES)	11930.12	11930.12	11930.12	12482.49	11930.12
SI (DWI)	474.77	61.87	61.87	0.00	163.19
SI(OTHER)	2605.35	8729.46	8729.46	0.00	3099.86
PM + PB	13439.87	12073.34	6026.93	6241.25	12449.07
PM+PB+Q+F	41515.03	70315.97	31572.15	20405.23	42911.14
Q + F	28075.17	58242.63	25545.22	14163.98	30462.07
RESI ST	33500.00	33500.00	33500.00	30000.00	33500.00
YIELD ST	18800.00	18800.00	18800.00	18800.00	18800.00
MOD. ELA.	25666000.00	25666000.00	25666000.00	25666000.00	25666000.00
SRI,PRE	.7149	.6422	.3206	.3320	.6622
SRI,SEC	.8760	1.3081	.8419	.6297	.9120
SRI TOTAL	1.5929	1.9503	1.1625	.9617	1.5742

S C O R E

-- VERSION 1.0.0 --

PAGE 49

04/01/80

JOAINE ARNOLD RE-CIRCULATION PIPING, LOOP A L R

STRESS RULE INDEX EVALUATION - SUMMARY

ISI KRA-34
WELD ID KU-N-54-C

WELD TYPE E-P

PIPE SIZE 10.00

NODE NO 280n

COMP TYPE ELBOWLK

BL / B2 1.00/3.1d

CL / C2 1.26/4.2d

KL / K2 1.20/1.80

SI(PRES) 11930.12

SI (DWI) 198.7d

SI(THRE) 3512.6d

PM + PR 12562.23

PM+PR+J+F 46333.02

Q + F 33770.80

REST ST 33500.00

YIELD ST 15800.00

MOD. ELA. 25666000.00

SKI,PKI .6642

SKI,SEC .9542

SKI TOTAL 1.6274

*
 * NUTECH
 *
 * SCORER
 * -- VERSION 1.0.0 --
 * DUANE ARNOLD RECIRCULATION INLET & OUTLET NOZZLE
 *
 * STRESS RULE INDEX EVALUATION - SUMMARY
 *

PAGE 10
04/01/80

ISE WELD ID	RRA/H-J4A	RRA/H-J3	RRA/H-F2A	RRA/H-F2A	RRA/H-F2
WELD TYPE	P-P	P-SEX	P-SE	P-SE	SE-NZ
PIPE SIZE	10.00	10.00	10.00	10.00	12.00
NODE NO	WELD5	WELD6	WELD4	WELD4	WELD2
COMP TYPE	PIPE	PIPE	TRANS	TRANS	TRANS
B1 / B2	.50/1.00	.50/1.00	.50/1.00	.50/1.00	.50/1.00
C1 / C2	1.10/1.00	1.10/1.00	1.36/1.48	1.35/1.46	1.34/1.45
K1 / K2	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
SI(PRES)	9916.97	9916.97	9916.97	7757.14	6833.33
SI (DWI)	673.30	3014.93	3251.25	2574.37	5185.24
SI(OTHER)	3283.88	7026.02	7442.46	5893.48	3431.22
PM + PB	5631.79	7973.41	8209.74	6452.94	8601.91
PM+PB+Q+F	20213.34	31164.11	44653.84	34819.26	33557.56
Q + F	14581.55	23190.69	36444.10	28366.32	24955.65
RESI ST	33500.00	33500.00	33500.00	40000.00	38000.00
YIELD ST	18800.00	18800.00	18800.00	28130.00	28130.00
MOD. ELA.	25778000.00	25778000.00	25778000.00	29416000.00	29416000.00
SRI,PRI	.2996	.4241	.4367	.2294	.3058
SRI,SEC	.6834	.8058	.9941	.7862	.7239
SRI TOTAL	.9830	1.2299	1.4308	1.0156	1.0297



*
* NUTECH
*
* SC O R E
* -- VERSION 1.0.0 --
* DUANE ARNOLD RECIRCULATION INLET & OUTLET NOZZLE
*
* STRESS RULE INDEX EVALUATION - SUMMARY

PAGE 11
04/01/80

1ST WELD ID	RCA-F2	RCB-F2
WELD TYPE	SE-NZ	SE-NZ
PIPE SIZE	12.00	12.00
NODE NO	N1A	N1B
COMP TYPE	TRANS	TRANS
<hr/>		
B1 / B2	.50/1.00	.50/1.00
C1 / C2	1.34/1.45	1.34/1.45
K1 / K2	1.20/1.80	1.20/1.80
SI(PRES)	6833.33	6833.33
SI(EDW)	2085.38	1832.14
SI(THRE)	2996.39	2292.12
PM + PB	5502.05	5248.81
PM+PB+Q+F	24302.30	21795.16
Q + F	18800.25	16546.35
RESI ST	32000.00	32000.00
YIELD ST	18800.00	18800.00
MOD. ELA.	25778000.00	25778000.00
<hr/>		
SRI,PRI	.2927	.2792
SRI,SEC	.7220	.6900
<hr/>		
SRI TOTAL	1.0147	.9692


ISI WELD ID	RHC-J1	RHC-F2	RHB-J1	RHB-J2	RHB-F3
WELD TYPE	T-P	P-P	T-P	BPI(P-WOL)	P-P
PIPE SIZE	20.00	20.00	18.00	18.00	18.00
NODE NO	175A	290A	238	410B	415B
COMP TYPE	TEE	PIPE	TEE	BRANRUN	PIPE
BL / BZ	1.00/2.59	.50/1.00	1.00/2.59	1.00/1.00	.50/1.00
CL / CZ	1.50/3.45	1.10/1.00	1.50/3.45	2.00/1.00	1.10/1.00
K1 / K2	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80	1.20/1.80
S1(PRES)	9699.32	9699.32	9605.12	9605.12	9605.12
SI (DW)	854.61	546.02	431.29	230.50	441.72
S1(ETHER)	1004.44	1054.68	769.18	517.63	461.25
PM + PB	11912.05	5395.68	10721.80	9835.62	5244.28
PM+PB+Q+F	29010.94	15702.35	24748.92	24398.92	14304.11
Q + F	17098.89	10306.67	14027.13	14563.30	9059.83
RESI ST	28500.00	28500.00	29000.00	29000.00	29000.00
YIELD ST	18800.00	18800.00	18800.00	18800.30	18800.00
MOD. ELA.	25946000.00	25946000.00	25946000.00	25946000.00	25946000.00
SRI,PRI	.6336	.2870	.5703	.5232	.2790
SRI,SEC	.6450	.5490	.6087	.6162	.5384
SRI TOTAL	1.2787	.8360	1.1790	1.1394	.8173

* NUTECH
* SCORE
* -- VERSION 1.0.0 --
* DUANE ARNOLD RESIDUAL HEAT REMOVAL PIPING
* STRESS RULE INDEX EVALUATION - SUMMARY



PAGE 10
04/01/80


ISI WELD ID	RHD-J1	RHD-F2
WELD TYPE	T-P	P-P
PIPE SIZE	20.00	20.00
NODE NO	1758	2908
COMP TYPE	TEE	PIPE
<hr/>		
B1 / B2	1.00/2.59	.50/1.00
C1 / C2	1.50/3.45	1.10/1.00
K1 / K2	1.20/1.80	1.20/1.80
SI(PRES)	9699.32	9699.32
SI(DW)	882.68	538.56
SI(THRE)	1077.82	1128.25
PM + PB	11984.72	5388.22
PM+PB+Q+F	29641.28	15803.35
Q + F	17656.57	10415.14
RESI ST	28500.00	28500.00
YIELD ST	18800.00	18800.00
MOD. ELA.	25946000.00	25946000.00
<hr/>		
SRI,PRI	.6375	.2866
SRI,SEC	.6529	.5505
<hr/>		
SRI TOTAL	1.2904	.8371


APPENDIX C
ISI ISOMETRIC DRAWINGS



CIRCULATION PUMP "A" &
DISCHARGE VALUE BY-PASS
CA-, RBA-
SS, 22", A"
I.S.D. No. 19








RECIRCULATION MANIFOLD "B" & RISERS A,B,C,D


RMB-, RRA-, RRB- RRC-, RRD-,



SS, 16", 10"

I.S.D. NO. 22



RESIDUAL HEAT REMOVAL - 1SB
 RHB-
 SS, CS, 18"
 ISO. No. 14





ATTACHMENT 4

Summary of Recirculation System UT Results, 1981-1982

1981 - A total of 48 welds were examined with the following results:

- A) 17 welds - no indications
- B) 21 welds - geometry < 50% DAC
- C) 5 welds - geometry 50% to 75% DAC
- D) 4 welds - geometry > 75% DAC
- E) *1 weld - Linear Indication

*Weld RRC-BJ4 had a linear indication ~ 3 1/4" long = 50% DAC. A decision was made to periodically monitor this weld.

1982 - A Total of 21 Welds Were Examined With The Following Results:

- A) 8 Welds - Geometry < 50% DAC
- B) 3 Welds - Geometry 50% to 75% DAC
- C) 9 Welds - Geometry > 75% DAC
- D) *1 Weld - Linear Indication

*Weld RRC-BJ4 was examined with identical results in 1981 and 1982.