

BIG ROCK POINT PLANT

NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK:  1 6

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T
REPORT SOURCE L J 6 | 0 | 5 | 0 - 1 0 | 1 5 | 5 | 7 | 1 | 1 | 0 | 5 | 8 | 2 | 8 | 1 | 2 0 | 2 | 8 | 1 | 2 | 9
7 8
60 61 DOCKET NUMBER 65 69 EVENT DATE 74 75 76 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During a non-routine inspection, the audible alarm unit for the fire
0 3 | detection equipment in zone 1 and zone 2 of the electrical equipment room
0 4 | was found to be inoperative. The visual alarm was still operable and the
0 5 | audible alarm was restored to operable status in two hours. No hazard to
0 6 | the public occurred. A prior identical failure occurred during a plant
0 7 | shutdown when reportability was not required. Reportability based on Tech
0 8 | Spec 6.9.2.b (2)

0 9 7 8	SYSTEM CODE [A B] 11 9 10	CAUSE CODE B 12 11	CAUSE SUBCODE B 13 12	COMPONENT CODE A N N U N C 14 13 18	COMP. SUBCODE Z 15 19	VALVE SUBCODE Z 16 20	80	
(17) LER/RO REPORT NUMBER [] [] 21 22	EVENT YEAR [] [] 8 2 23	SEQUENTIAL REPORT NO. [] [] [] 0 3 0 24 26	OCCURRENCE CODE [] [] 0 3 27 29	REPORT TYPE L 30	REVISION NO. 0 32			
ACTION TAKEN TAKEN ACTION B 16 33	FUTURE ACTION X 19 34	EFFECT ON PLANT [] [] 8 20 35	SHUTDOWN METHOD [] [] 5 21 36	HOURS [] [] [] [] 0 0 0 0 37 40	ATTACHMENT SUBMITTED N 23 41	NPRD4 FORM SUB. N 24 42	PRIME COMP. SUPPLIER A 25 43	COMPONENT MANUFACTURER P 4 3 5 4 6 44 47
CAUSE DESCRIPTION AND CAUSING CONDITIONS								

10 Flexing of stiff wiring on the door panel pulled the solder connection loose
11 at a panel termination on Pyrotronics Model FI U-6. The problem is deemed
12 to be related to connector design since the wiring is too large to make a
13 high integrity joint at the small socket pin. The wire was reconnected and
14 evaluation to improve the design is in progress.

FACILITY STATUS		% POWER	OTHER STATUS		METHOD OF DISCOVERY	DISCOVERY DESCRIPTION
1	5	E (26)	10	6	5 (29) NA	B (31) Non-routine inspection
ACTIVITY	CONTENT	10	12	13		
RELEASED. OF RELEASE		AMOUNT OF ACTIVITY			LOCATION OF RELEASE	
1	6	Z (33)	Z (34) NA		NA	(36)
8	9	10	11			

PERSONNEL EXPOSURES
NUMBER TYPE DESCRIPTION (39)

8 9 11 12 13
PERSONNEL INJURIES
NUMBER DESCRIPTION 41

1 8
8 9 11 12
LOSS OF OR DAMAGE TO FACILITY 80

1	9	TYPE	DESCRIPTION
Z	42	NA	
8	9	10	

PUBLICITY
ISSUED **DESCRIPTION** 45
20 N 44 NA
NRC USE ONLY

8 9 10
8212100309 821202
058 AD054 25000455

8313100308 87

NRC USE ONLY

0212100307 021202
PDR ADOCK 05000155
S PDR