## LICENSEE EVENT REPORT

	시키는 Barrier 19 : 10 : 10 : 10 : 10 : 10 : 10 : 10 :
	CONTROL BLOCK: [ ] [ ] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1	M     P A L   1 2 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
O 1	REPORT L 6 05 0 0 0 2 5 5 7 1 1 0 2 8 2 8 1 2 0 2 8 2 9 SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 60
0 2	[During normal power operation, T-82D (D Safety Injection Tank) level dropped
0 3	[below the T/S limit of 186 inches. The level indicating system and the
0 4	[associated alarms failed to respond to the level change. Tank level was
0 5	promptly restored to the normal operating range; therefore, no threat to
06	public health or safety. Condition reportable per TS 3.3.1.b and
0 7	[6.9.2.δ(2).
08	80
[ <u>0</u> 9	SYSTEM CAUSE CAUSE COMPONENT CUDE SUBCODE SUBC
	TAKEN ACTION ON PLANT METHOD HOURS 22 ATTACHMENT FORM SUB- SUBMITTED FORM SUB- SUPPLIER MANUFACTURER    X   B   X   19   Z   20   Z   21   22   23   24   26   27   28   29   29   30   31   32   31   32   32   33   34   35   36   37   37   37   37   37   37   37
10	Level decrease due to leakage past fill and drain valve CV-3003. Valve will
11	(be inspected during next refueling outage. Level indication problem cleared)
1 2	prior to troubleshooting and has not recurred. Level indication will be
1 3	closely monitored and additional troubleshooting and repairs conducted as
14	necessary.
15	STATUS POWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32  E 28 1 0 0 29 NA Alarm annunciation
	CTIVITY CONTENT FLEASED OF RELEASE AMOUNT OF ACTIVITY 35 NA LOCATION OF RELEASE 36  NA N
17	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39 NA  PERSONNEL INJURIES 13 80
1 a	O O O O O O DESCRIPTION (41) NA
1 9	TYPE DESCRIPTION NA NA NA NA
20	PUBLICITY SSUED DESCRIPTION 45  NAC USE ONLY  NA
821 PDR S	2100317 821202 ADDCK 05000255 PDR