

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | M I D C C 1 | 2 | 0 0 - 0 0 0 0 0 - 0 0 | 3 | 4 1 1 1 1 | 4 | _____ | 5

CON'T
0 1 | L | 6 | 0 5 0 0 0 3 1 5 | 7 | 1 1 0 5 8 2 | 8 | 1 2 0 3 8 2 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 | DURING NORMAL OPERATION, AN AEO ON TOUR REPORTED FIRE DOOR 437, BETWEEN THE UNIT 1
0 3 | AND UNIT 2 CONTROL ROOM AIR CONDITIONING EQUIPMENT ROOMS, AS BEING INOPERABLE.
0 4 | THIS CONSTITUTED AN INOPERABLE PENETRATION FIRE BARRIER, CONTRARY TO T.S. 3.7.10.
0 5 | THE FIRE DETECTION SYSTEM REMAINED OPERABLE AND ACTION REQUIREMENTS WERE MET.
0 6 | PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED.

0 9 | SYSTEM CODE: A B (11) CAUSE CODE: X (12) CAUSE SUBCODE: Z (13) COMPONENT CODE: X X X X X X (14) COMP SUBCODE: Z (15) VALVE SUBCODE: Z (16)

17 | LER NO REPORT NUMBER: 8 2 (21) SEQUENTIAL REPORT NO.: 1 0 0 (24) OCCURRENCE CODE: 0 3 (28) REPORT TYPE: L (30) REVISION NO.: 0 (32)
ACTION TAKEN: E (18) FUTURE ACTION: Z (19) EFFECT ON PLANT: Z (20) SHUTDOWN METHOD: Z (21) HOURS: 0 0 0 0 (22) ATTACHMENT SUBMITTED: N (23) NPD-4 FORM SUB.: N (24) PRIME COMP. SUPPLIER: A (25) COMPONENT MANUFACTURER: Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 | THOUGH THE CONDITIONS COULD NOT BE DUPLICATED, THE FAILURE APPEARED TO HAVE BEEN DUE
1 1 | TO THE DOOR SCRAPING ON A STAIR STEP. THE CLEARANCE BETWEEN THE DOOR AND STEP WAS
1 2 | IMPROVED. THE DOOR TESTED SATISFACTORILY.

1 5 | FACILITY STATUS: E (28) % POWER: 1 0 0 (29) OTHER STATUS: NA (30) METHOD OF DISCOVERY: B (31) DISCOVERY DESCRIPTION: OPERATOR OBSERVATION (32)

1 6 | ACTIVITY CONTENT: Z (33) Z (34) AMOUNT OF ACTIVITY: NA (35) LOCATION OF RELEASE: NA (36)

1 7 | PERSONNEL EXPOSURES: NUMBER: 0 0 0 (37) TYPE: Z (38) DESCRIPTION: NA (39)

1 8 | PERSONNEL INJURIES: NUMBER: 0 0 0 (40) DESCRIPTION: NA (41)

1 9 | LOSS OF OR DAMAGE TO FACILITY: TYPE: Z (42) DESCRIPTION: NA (43)

2 0 | PUBLICITY ISSUED: N (44) DESCRIPTION: NA (45) 8212100327 821203 PDR ADDCK 05000315 S PDR

NAME OF PREPARER: R. H. PIEHL PHONE: 616-465-5901