

LICENSEE EVENT REPORT

*CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | 1 | L | 0 | A | D | 2 | 2 | 0 | 0 | 0 | - | 0 | 0 | 0 | - | 0 | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | _____ | 5
7 8 9 14 15 25 26 30 57 58
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T
0 1 | L | 6 | 0 | 5 | 0 | 0 | 0 | 2 | 6 | 5 | 7 | 1 | 0 | 0 | 6 | 3 | 2 | 8 | 1 | 2 | 0 | 1 | 8 | 2 | 9
7 8 60 61 68 69 74 75 80
REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 | On October 6, 1982, following monthly preventative maintenance, the Unit Two
0 3 | Emergency Diesel Generator tripped on high temperature, 10 minutes after loading.
0 4 | Technical Specification 3.9.E.1 required surveillances were successfully performed.
0 5 | All four 345 KV lines were available and the 1/2 Diesel Generator and associated
0 6 | ECCS systems were found operable. Therefore, there was no significant affect on
0 7 | safe plant operation as a result of this occurrence.

0 9 | SYSTEM CODE: EE (11) CAUSE CODE: E (12) CAUSE SUBCODE: X (13) COMPONENT CODE: ITEXCH (14) COMP SUBCODE: C (15) VALVE SUBCODE: Z (16)
17 | LER/RO REPORT NUMBER: 82 (21) SEQUENTIAL REPORT NO.: 018 (24) OCCURRENCE CODE: 03 (28) REPORT TYPE: L (30) REVISION NO.: 1 (32)
ACTION TAKEN: A (18) FUTURE ACTION: Z (19) EFFECT ON PLANT: Z (20) SHUTDOWN METHOD: Z (21) HOURS: 0000 (22) ATTACHMENT SUBMITTED: Y (23) NPRD-4 FORM SUB.: Y (24) PRIME COMP. SUPPLIER: A (25) COMPONENT MANUFACTURER: W097 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 | The apparent cause of this occurrence was determined to be fouling of the Diesel
1 1 | Generator Cooling Water System heat exchangers. Upon the Vendor's recommendations,
1 2 | both heat exchangers were replaced with spare heat exchangers. On October 8, 1982,
1 3 | the Unit Two Diesel Generator was tested and found to be operable. Diesel Cooling
1 4 | Water heat exchangers will be placed on a preventative maintenance schedule for
cleaning.

FACILITY STATUS: E (28) % POWER: 096 (29) OTHER STATUS: NA (30) METHOD OF DISCOVERY: B (31) DISCOVERY DESCRIPTION: Post-Maintenance Surveillance (32)

ACTIVITY CONTENT: Z (33) AMOUNT OF ACTIVITY: NA (35) LOCATION OF RELEASE: NA (36)

PERSONNEL EXPOSURES: 000 (37) TYPE: Z (38) DESCRIPTION: NA (39)

PERSONNEL INJURIES: 000 (40) DESCRIPTION: NA (41)

LOSS OF OR DAMAGE TO FACILITY: Z (42) DESCRIPTION: NA (43)

PUBLICITY: NA (44) DESCRIPTION: NA (45)

ISSUED: NA (44) DESCRIPTION: NA (45) 8212100335 821201 PDR ADOCK 05000265 PDR

U.P.O. 917-926