

T-1164  
ORIGINAL

# OFFICIAL TRANSCRIPT PROCEEDINGS BEFORE

NUCLEAR REGULATORY COMMISSION  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

DKT/CASE NO.

TITLE 272ND GENERAL MEETING

PLACE WASHINGTON, D. C.

DATE DECEMBER 9, 1982

PAGES 1 - 285

*TR 04  
delete B. White*

8212130040 821209  
PBR ACRS  
T-1164 PBR



ALDERSON REPORTING

(202) 628-9300  
440 FIRST STREET, N.W.  
WASHINGTON, D.C. 20001

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
272ND GENERAL MEETING

Room 1046  
1717 H Street, N.W.  
Washington, D.C.

Thursday, December 9, 1982

The Committee met, pursuant to notice, at  
8:35 a.m., Paul G. Shewmon, Chairman of the Committee,  
presiding.

ACRS MEMBERS PRESENT:

- PAUL G. SHEWMON
- CHESTER P. SIESS
- ROBERT C. AXTMANN
- J. CARSON MARK
- FORREST J. REMICK
- JESSE C. EBERSOLE
- DAVID A. WARD
- DAVID OKRENT
- MYER BENDER
- DADE W. MOELLER
- JEREMIAH J. RAY
- HAROLD ETHERINGTON

DESIGNATED FEDERAL EMPLOYEE:

RAYMOND FRALEY

PROFESSIONAL SECRETARY:

M. NORMAN SCHWARTZ



## 1           ALSO PRESENT:

2           BILL RUSSELL  
3           CHRIS GRIMES  
4           S. POWERS  
5           T. RAUSCH  
6           B. RYBAK  
7           N. SMITH  
8           M. ERNST  
9           MR. SPULAK  
10          MR. BERRY  
11          MR. KACICH  
12          MR. AMICO  
13          M. BAIN  
14          MR. MILLS  
15          T. NOVAK  
16          C. STAHL  
17          R. WARNICK  
18          D. HUNTER  
19          C. TINKLER  
20          MR. BUTLER

21

22

23

24

25

26

27

28

29

30

31

32

33

34

P R O C E E D I N G S

1  
2 MR. SHEWMON: Good morning.

3 This is the first day of the 272nd meeting of  
4 the ACRS. During today's meeting the Committee will  
5 hear reports and discussions on the SEP evaluation of  
6 Dresden and Millstone Station Unit 2 and Millstone 1.  
7 We will have a brief report on the Zimmer plant QA  
8 problems and the Sequoyah Nuclear Power Plants 1 and 2  
9 regarding control of combustible gases following a  
10 serious accident.

11 The meeting is being conducted -- needless to  
12 say, there's an agenda in the back of the room. My  
13 prompter seems to have forgotten that today.

14 The meeting is being conducted in accordance  
15 with the provisions of the Federal Advisory Committee  
16 Act and the Government in the Sunshine Act, and Mr.  
17 Raymond Fraley is the Designated Federal Employee for  
18 this portion of the meeting.

19 A transcript of portions of the meeting is  
20 being kept. It's requested that each speaker use one of  
21 the microphones, identify himself or herself, and speak  
22 with sufficient clarity and volume that he or she can be  
23 readily heard.

24 We have received no written statements or  
25 requests to make oral statements from members of the

1 public regarding today's meeting.

2 (Whereupon, the Committee went into executive  
3 session. )

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

OPEN SESSION

1 MR. SHEWMON: Without further ado, I will turn  
2 it over to Chet, who will handle Dresden and Millstone.

3 MR. SIESS: I'm just trying to see what's in  
4 the folder under tab 2 that you can look at. I haven't  
5 seen it yet myself.

6 MR. SHEWMON: But you're sure it's there?

7 MR. SIESS: Yes. It has a schedule.

8 What we will be doing today is looking at the  
9 SEP review for the fourth and fifth plants in the  
10 program. This will conclude the five plants that are  
11 what I call relatively of recent vintage. We start off  
12 with Palisades, then Ginna. The past month we did  
13 Oyster Creek, which was the first boiler. And today we  
14 will be doing Millstone Unit 1 and Dresden Unit 2, both  
15 of which are boiling water reactors.

16 They are somewhat similar to Oyster Creek, in  
17 that they are Mark I type containments, but they are a  
18 different type of reactor systems. These are both jet  
19 pump plants. They are very similar in the NSSS,  
20 although they're not all that similar in balance of  
21 plant, and of course they are at different sites. One  
22 of them is on Long Island Sound and the other is on a  
23 small river in Illinois, that probably is a lot larger  
24 today than it was last week.

25 We are proposing to look at the two almost

1 simultaneously because of their similarity in the issues  
2 or the topics, and even to some extent in the resolution  
3 of the topics. Not only are Dresden and Millstone quite  
4 similar in the whole presentation, in the whole process;  
5 they were reviewed together and they are also similar in  
6 many respects to Oyster Creek, which I hope you have  
7 some recollection of from last month.

8           The Subcommittee in a meeting last week did go  
9 through its review in this essentially simultaneous  
10 manner and it seemed to work and it seemed to expedite  
11 our review and expedite our understanding of the issues  
12 and how they were related to Oyster Creek. So the Staff  
13 will be making its presentation in essentially that  
14 fashion today.

15           As you will recall, we start off with 137  
16 issues in phase two, which were reduced from several  
17 hundred in phase one. Phase one was to boil it down. A  
18 number of those issues get put to one side, either  
19 because they are obviously not applicable to the plant  
20 because of its type -- it might be a PWR issue and it's  
21 a BWR plant -- or they're not relevant because of the  
22 site. Another set gets put aside because they're being  
23 treated generically on all plants, the USI and TMI  
24 items, the resolution of which will be handled in a  
25 different fashion and presumably will be reviewed by us

1 when we review these plants for the provisional  
2 operating license or full-term operating license.

3 All these five plants will be coming up later  
4 for full-term operating licenses. I might mention in  
5 that respect that Dresden 2 will have to convert its  
6 license. Dresden 3 started out with a full-term  
7 license.

8 MR. SHEWMON: Chet, would you tell me the  
9 difference between the SEP and the full-term? I kind of  
10 thought that's why we were doing this.

11 MR. SIESS: No. The SEP is the systematic  
12 evaluation of the older reactors to see how they compare  
13 with current criteria. The idea originally was to start  
14 back at the beginning with Yankee Rowe and Dresden 1,  
15 Big Rock --

16 MR. SHEWMON: It's not just a comparison. The  
17 utilities are committing to change?

18 MR. SIESS: Yes. Let me finish.

19 We started with the old plants that we knew  
20 didn't meet current criteria, see where they didn't and  
21 decide what to do about it; obviously, not to backfit  
22 them to current criteria, but to make judgments. Added  
23 to that first list of the very old plants were a number  
24 of plants that were not all that old but were still  
25 operating under provisional operating licenses, under

1 the theory that by reviewing them as part of the SEP  
2 that review would make it easier to do the review for  
3 the full-term license conversions.

4           These were put into the program because they  
5 did have provisional licenses, because it would  
6 contribute to the full-term license review. This does  
7 not replace it, simply because the SEP does not cover  
8 all of the outstanding issues.

9           The Committee decided with the Palisades plant  
10 that we would not try to sign off on a full-term  
11 license. The Staff was not ready to sign off on a  
12 full-term license and the Staff will issue an SER for a  
13 full-term license when they have completed evaluating  
14 the status of the USI and TMI fixes.

15           The Staff does not intend that all those fixes  
16 must be made to these plants to get a full-term license  
17 -- that would not make sense, since there are 40 or 50  
18 plants out there with full-term licenses that are still  
19 in the process of making them -- but that they would  
20 determine the status and acceptability of operating  
21 without that.

22           The full-term license reviews are still to  
23 come and just how the Committee will handle those we  
24 will have to decide. I have some research going on how  
25 we have handled them in the past, but these six plants



1 are obviously older.

2           Many of the plants that got provisional  
3 licenses will be converted to full-term in a couple of  
4 years. That was the general idea originally. We gave  
5 them a provisional license and if they haven't blown up  
6 in two years we give them a full license. Obviously,  
7 that's not the way it was done.

8           Then the Commission sort of backed off on  
9 full-term licenses and all of these plants that applied  
10 for their full-term within a year or two -- I guess the  
11 law says that as long as you have applied for it and the  
12 Commission hasn't denied it, you can keep operating  
13 under your provisional license until the Commission  
14 decides what to do about it.

15           So here we have plants 12 years old that are  
16 still provisional. Now, these plants, then, are very  
17 similar to Oyster Creek in the nature and type of  
18 review. As I said, the Staff starts with 137. You  
19 eliminate the USI and TMI items and you end up with some  
20 number which they will explain to us, and then those are  
21 compared against current criteria.

22           They either meet the criteria or meet them on  
23 some defined basis where the criteria allow for an  
24 alternate, or they do not meet it. Those that do not  
25 meet current criteria were then subjected to what is

1 called the integrated assessment, integrated plant  
2 safety assessment.

3           The results of that were reported in the two  
4 yellow volumes which I assume you have received, but I  
5 will not assume you have read. The main thrust of the  
6 reviews on the other three, and I think it probably  
7 should be here, should be on those items that did not  
8 meet current criteria, where the Staff had to make a  
9 decision as to what to do about it, and those decisions  
10 were of various kinds.

11           In some cases they decided nothing was needed,  
12 they were satisfactory even though they didn't meet  
13 current criteria. In other cases they decided that some  
14 procedural change or some tech spec change would bring  
15 them up to the appropriate level of safety.

16           In other cases hardware backfits are  
17 required. I say required; most of the Staff has said,  
18 this would resolve our concern, and the applicant has  
19 agreed to it. When it gets to the point of requiring,  
20 then the Staff would have to invoke the backfit rule or  
21 something else. So far I don't think they've had to  
22 invoke the backfit rule in that the changes they have  
23 proposed have been agreed to by the licensee.

24           In both plants, as in the case of the earlier  
25 plants, other plants we looked at, there are number of

1 items that have not been resolved because they require  
2 further rather extensive studies by the licensee,  
3 evaluations, analyses, et cetera. Much of this relates  
4 to seismic resistance item by item.

5           Because of some codes that have been changed,  
6 in the case of Millstone all of the structural problems  
7 are being looked at in an integrated fashion. Whether  
8 it's the change in code or the change in earthquake or  
9 the change in tornado or something else, they try to do  
10 an integrated review and correction of structural  
11 problems. But the pattern is the same.

12           I have asked the Staff to go through it rather  
13 quickly on the items that were deleted, because those  
14 are relatively straightforward. The Subcommittee has  
15 looked at them. These are USI-TMI items and not  
16 applicable items.

17           The next list the Staff will present are those  
18 that in the Staff reviewer's opinion the plant either  
19 meets current criteria or meets it on some acceptable or  
20 defined basis. There again, I have asked the Staff to  
21 give us a list and if you have questions or want further  
22 details on any item in the list as to how it meets  
23 current criteria or what any other defined basis is,  
24 they will provide the details.

25           But I've asked them to give you a list and let

1 you pick from them. Then they will go into the items  
2 that -- I forget what comes next, whether it's those  
3 requiring further evaluation or those requiring  
4 backfits. But we will go through those in a little more  
5 detail.

6           Again, the Staff is prepared to present  
7 detailed discussions, the Staff or the Licensee or both,  
8 detailed discussions on any item you wish. Those they  
9 did not meet and those that are resolved are discussed  
10 in considerable detail in chapter 4 that you have or we  
11 can provide you with copies of. I think that should  
12 give you the picture.

13           We have asked the Licensees to take a few  
14 minutes to give a brief description of the plant, just  
15 to bring you up to speed on that. Oh, one other item.  
16 In its integrated assessment, the Staff has used in a  
17 somewhat limited way a PRA. On the other plants we  
18 looked at, they got a PRA for the nearest plant to that  
19 if they didn't have a plant-specific one and, by a  
20 procedure which was described to us at a couple of other  
21 meetings, they got some measure of the affect of  
22 possible changes on reliability and used that as a guide  
23 to deciding whether something needed to be done.

24           For Millstone Unit 1 there is a plant-specific  
25 PRA as a result of the IREP program. That was used,

1 shall I say, directly for Millstone Unit 1. It was used  
2 indirectly for Dresden in much the same fashion that the  
3 Millstone 1 IREP was used for Oyster Creek,

4           It was our impression that the plant-specific  
5 PRA wasn't a real tremendous improvement over using one  
6 for a similar plant. The Staff couldn't use the PRA  
7 exactly for anything. It didn't cover earthquakes, for  
8 example, so it wasn't much help on seismic flooding or  
9 any extreme external event problems, and they were using  
10 it as a sole basis for decisionmaking, but the Staff  
11 didn't use it that way. If some things were rated low  
12 by the PRA, they thought it should be fixed anyway, and  
13 I'm not sure whether it was vice versa, but they'll tell  
14 us that.

15           So we did have a Millstone plant-specific  
16 PRA. I don't know where Dave went. We have been  
17 provided with volume one of that, which is really the  
18 summary, isn't it, Bill?

19           MR. RUSSELL: (Nods affirmatively.)

20           MR. SIESS: It had more in it than I was  
21 interested in and probably less in it than somebody else  
22 might be interested in. It will all be available some  
23 day.

24           Are there any questions at this stage?

25           MR. MOELLER: Yes. We have of course the

1 comments on the SEP's by the four consultants.

2 MR. SIESS: Yes. Each plant -- let me just  
3 mention this. The Staff has had, I guess, consultants  
4 or a peer review panel or what have you. They started  
5 off with five. Spence Bush, Herb Isben, Joe Hendrie,  
6 Bob Budnitz, and Zenon Zudans are the names that are  
7 quite familiar to us, and those consultants have  
8 reviewed, usually a draft of the integrated plant safety  
9 assessment.

10 So some of their comments even in this case  
11 are on a draft, and this thing is a continuing process.  
12 For Dresden 2 and Millstone 1, there are only four  
13 consultants. Bob Budnitz I believe had some kind of a  
14 conflict on it. And those reports have been passed out  
15 to you. I only got them yesterday and I haven't read  
16 them all.

17 MR. MOELLER: What I wanted to know, for  
18 example, each consultant in essentially every case and  
19 particularly in Zenon's case, they have raised a list of  
20 questions. Like on page 3, Zenon Zudans' review of  
21 Dresden, he has a whole list of questions. And it would  
22 be helpful to me to have the Staff tell us --

23 MR. SIESS: We will arrange that. The  
24 Subcommittee did not have a chance to explore those,  
25 because as I said we got them yesterday. I will ask Mr.



1 Russell, the rest of them here -- Chris is here. Chris  
2 Grimes I think can address Zudans' questions, can't  
3 you?

4 MR. RUSSELL: Yes. I would only like to make  
5 one comment. The report that the consultants review is  
6 identical to the report which the ACRS is reviewing.  
7 The consultants' reviews were completed prior to the  
8 Committee's review today, so that you would have the  
9 benefit of their views on the Staff's document as well.

10 In each case, the Staff has provided a  
11 specific response to each of the questions raised by the  
12 consultants. That is sent back to the consultants and  
13 the licensee and that is incorporated in the final  
14 integrated assessment report.

15 And we are prepared to address all of the  
16 questions. I can't say that we will be able to address  
17 every one satisfactorily, but we will address each one  
18 in writing.

19 MR. SIESS: Now, the two NUREG's you have,  
20 0824 and 0823, are what the Subcommittee had to review.  
21 We were updated on a number of items. As I say, this is  
22 a continuing process. What you get today will not agree  
23 exactly with what is in the NUREG's, but it will be more  
24 recent in many, many cases.

25 The agenda says that we will take a brief



1 description from the Licensee, Dresden 2 first and then  
2 Millstone, and then the Staff will take it over and we  
3 will go through on this parallel process of the two  
4 plants, with questions from the full Committee. And  
5 then at the end we have asked the Licensees if they  
6 wish, depending on the length of it, they could comment  
7 on the beginning, on their perceptions of the SEP and  
8 how it is operated and how successful it is.

9 I have asked them to do that for a couple of  
10 reasons. I think we're interested in knowing what they  
11 think about it, but there is also an issue that will be  
12 coming to us some time in the future as to whether the  
13 SEP should be continued into a phase three with another  
14 group of plants and maybe a phase four, et cetera, et  
15 cetera.

16 These five plants provide probably the best  
17 basis for getting some feeling about that, since they  
18 are of more recent vintage than the five you are going  
19 to start seeing next year.

20 Are there any questions?

21 (No response.)

22 MR. SIESS: Okay, I'll call on the  
23 representative of Commonwealth Edison, then, first. Are  
24 you going to use the lectern with some slides?

25 MR. RAUSCH: Yes. I have the same handouts

1 again, Dr. Siess.

2 MR. SIESS: That's fine.

3 MR. RAUSCH: The full Committee hasn't seen  
4 them.

5 (Slide.)

6 MR. RAUSCH: Good morning. My name is Tom  
7 Rausch. I represent Commonwealth Edison, Dresden Unit  
8 2. We have a small group of people with us who will  
9 attempt to answer any type of questions you may have  
10 about the design of our plant or some operating  
11 history.

12 I'm handing out a small packet of material.  
13 I'm not going through all of these. I have slides on  
14 all of what I'm handing out. But basically what you  
15 have there is some simple one-line diagrams of some of  
16 the unique features of our plant versus other BWR's.

17 We are a rather typical BWR-3. Our rated  
18 thermal power is 2527 and 834 megawatts electric gross.  
19 We're located on the confluence of the Kankakee-Illinois  
20 Rivers about 30 miles southwest of Chicago, Illinois.  
21 We use the river -- we have used the rivers as a  
22 once-through cooling until 1971, at which time we  
23 completed installation of a large cooling lake,  
24 1275-acre cooling lake.

25 Very recently, we now are allowed to run on

1 once-through cooling with the river, using the lake to  
2 cool the discharge before it goes back to the river in  
3 the summer months, after which our efficiency went up  
4 quite markedly.

5           We are a three-unit site. In 1959 Dresden 1  
6 received its operating license. Dresden 2, the  
7 construction permit didn't come until 1965. The fuel  
8 load began in December of 1969, in a short time period,  
9 less than four years. We were critical, in 1970,  
10 January. We began retrospectively what we called  
11 commercial service in 1970, in August. Dresden 3 began  
12 operation in January of 1971, so there was not much lag  
13 between the two units.

14           We made our timely application for the  
15 full-term operating license conversion in 1972, and here  
16 we are ten years almost to the date and maybe we'll be  
17 getting it.

18           Some of the more major modifications are  
19 pointed out on here. In 1973 we completed installation  
20 of the modified offgas system, which has a rather  
21 dramatic reduction in gaseous effluents, essentially  
22 recombiners, charcoal bed system.

23           In 1979 we had a large augmentation in our  
24 security. That was ongoing for several years, but we're  
25 up around 100 guards now, 130 if you count all the

1 supervisory.

2           We're still in the process of completing TMI  
3 mods. The major ones are completed: the technical  
4 support center, high radiation sampling systems,  
5 emergency operating facility. And another one of the  
6 big ones we're doing right now: We will be changing out  
7 process computers and putting in much larger and  
8 redundant computers to support some of the fancy  
9 monitoring.

10           Yes, sir?

11           MR. MARK: From a purely practical point of  
12 view, what difference does it make to you whether you  
13 have a full-term operating license or an interim  
14 license?

15           MR. RAUSCH: Very little, assuming the Staff  
16 doesn't allow it to expire. It's a minor nuisance when  
17 you are attempting to receive nuclear material or things  
18 you are required to have a license for. We don't like  
19 to refer to that license. We refer to our Dresden 3  
20 license. A lot of vendors are more comfortable with the  
21 real full license. Practically speaking, there is no  
22 difference.

23           The last major modification that is still in  
24 the process of being installed is our high-density spent  
25 fuel racks. It was a contested case. We're very near

1 completion now with this. We would already be at the  
2 point where we could not have a full core discharge and  
3 we could not even undergo refueling if we did not have  
4 these modifications. With the mod, it'll let us go to  
5 roughly the year 2,000.

6 (Slide.)

7 This is just a simple plant layout that'll  
8 give you a little idea of what we look like. You'll  
9 note the river, the Kankakee, is in this direction.  
10 Unit 1 is the 1950-vintage here. Unit 2 and 3 reactor  
11 buildings are side by side. The control room is in  
12 between Unit 1 and Unit 2. It's a three-unit control  
13 room.

14 We have had to add an administrative  
15 building. The staff is much larger than we anticipated  
16 in the early seventies. It's uniquely located outside  
17 the security areas. It makes a nice to have people be  
18 able to come into the sites.

19 These diesel generators are separated in this  
20 end of the turbine building for Unit 3. Unit 2 is up  
21 over here, and the common 2-3 diesel generators are  
22 located in the middle of the reactor building. I'm  
23 pointing that out because that is one of the open issues  
24 we are still attempting to resolve, that is tornado  
25 missiles on diesel generator exhaust systems.

1           MR. EBERSOLE: Since you have transverse  
2 units, are you in good shape as regards 180 percent  
3 speed missile problems out of the turbine?

4           MR. RAUSCH: Are you talking about the turbine  
5 missile issue?

6           MR. EBERSOLE: Yes.

7           MR. RAUSCH: How did we answer that, Neil? Do  
8 you recall?

9           MR. EBERSOLE: What I don't want to hear is  
10 that you disallow the 180 percent missile.

11          MR. SIESS: I don't think the Staff agrees  
12 with you, Jesse.

13          MR. EBERSOLE: Are they going to allow them to  
14 postulate all failures at a single speed?

15          MR. SIESS: Let the Staff answer that. This  
16 is being handled the same as the others.

17          MR. RUSSELL: The approach that the Staff has  
18 taken is to look at two aspects, to look at the material  
19 properties of the discs, the inspection program for the  
20 discs, and allow an inspection schedule to be developed  
21 based upon the results of the current inspections which  
22 have recently been done on the various units.

23                 That addresses the failure from overspeed up  
24 to the normal overspeed. It's not the destructive 180  
25 percent overspeed.

1           With respect to the higher overspeed, the  
2 Staff has chosen to look at the reliability and  
3 redundancy in testing of the overtrip speed mechanisms  
4 rather than addressing the much higher RPM. So it is  
5 the current approach that we are using both on new  
6 plants and on the SEP plants.

7           MR. EBERSOLE: Is this to say that as a  
8 generic basis the Staff is now permissive of the concept  
9 of 180 percent failure? In other words, it's depending  
10 on the reliability of the steam interception system?

11           MR. RUSSELL: That's correct. We feel that  
12 the emphasis should be on the redundancy, reliability,  
13 and testability of the overspeed trip mechanisms to  
14 assure that you do not get to the destructive  
15 overspeed.

16           MR. EBERSOLE: Well, that focuses on the main  
17 steam stop valve precisely, and I don't think the Staff  
18 has any --

19           MR. RUSSELL: No, it could be the control  
20 valves, governing valves, and overspeed trips on the  
21 turbine itself.

22           MR. EBERSOLE: On the turbine motor ejection,  
23 you need to stop that; am I incorrect?

24           MR. RAUSCH: You're correct.

25           MR. EBERSOLE: You're solely dependent on the



1 stop valve. Any delay in its function and you've had  
2 it. And that valve is not a regulated engineering  
3 design feature. For instance, my last --

4 MR. RUSSELL: We'll have to get somebody from  
5 the Staff to come down. We'll call back and get a more  
6 specific response. I generally characterized what we're  
7 looking at. We have not, to the best of my knowledge,  
8 looked at timing of main steam stop valve closure, for  
9 example.

10 MR. EBERSOLE: You haven't even looked at the  
11 structural design.

12 MR. RUSSELL: That's correct.

13 MR. SIESS: But now let me get something  
14 straight. Did I hear you say, Bill, that these are  
15 current criteria?

16 MR. RUSSELL: That's correct.

17 MR. SIESS: And your conclusion is that with  
18 the inspection the plant then meets current criteria,  
19 and that Mr. Ebersole's argument then is not with the  
20 SEP for Dresden but with the current criteri..?

21 MR. RUSSELL: That's correct. We have been  
22 using this to provide assurance that the historical  
23 probability of generation of turbine missiles is  
24 appropriate, and we are not doing the detailed  
25 probability analysis of P-1 through P-4.

1 MR. EBERSOLE: Have the other plants which  
2 have accommodated the 180 percent missile been relieved  
3 of this?

4 MR. RUSSELL: I can't answer that question. I  
5 don't know.

6 MR. EBERSOLE: Well, I think it is generic, as  
7 Chet said.

8 MR. SIESS: I think there will be a number of  
9 opportunities to see what current criteria are, because  
10 we are looking at more things here.

11 MR. OKRENT: I don't know what you mean when  
12 you say these are current criteria.

13 MR. SIESS: The object of the SEP is to  
14 determine the extent to which these plants meet current  
15 criteria.

16 MR. OKRENT: I don't recall seeing a paper  
17 from the Staff which says these are the current  
18 criteria.

19 MR. SIESS: We'll ask Mr. Russell to tell us  
20 what constitutes current criteria.

21 MR. OKRENT: For turbine missile questions.  
22 I'm trying to find out in fact --

23 MR. SIESS: Let's ask Mr. Russell where we  
24 would find the current criteria at, the standard review  
25 plan or a reg guide or where?

1           MR. RUSSELL: Generally, it is contained in  
2 the standard review plan, NUREG-0800. In the case of  
3 the turbine missile issue, this approach is being used  
4 on recent OL's, and I am not aware of the status of the  
5 revision to the standard review plan to reflect this  
6 change.

7           MR. OKRENT: I'm sorry, but --

8           MR. RUSSELL: We can have somebody come down  
9 and, by reference to the SER's that are being used in  
10 new dockets which address this issue --

11           MR. OKRENT: I'm sorry, there is an unresolved  
12 safety issue we were just talking about yesterday  
13 morning on turbine missiles. If it's an unresolved  
14 safety issue, I have to assume that this term "current  
15 criteria" is a vague thing. There may be something that  
16 the Staff is accepting, but that does not state criteria  
17 to me.

18           MR. SIESS: If there's an unresolved safety  
19 issue, it's not supposed to be part of the SEP if it's a  
20 generic issue.

21           MR. RUSSELL: It is a generic issue, but to  
22 the best of my knowledge it is not a USI. The issue on  
23 turbine cracking is generic to Westinghouse. We have  
24 required a number of inspections. We have had  
25 additional work done on General Electric. The position

1 on Westinghouse has been in place for nearly a year, to  
2 the best of my knowledge. The GE position is following  
3 the approach that was taken by Westinghouse, and GE is  
4 now proposing and has proposed to the Staff generic  
5 methods to be used to develop turbine inspection  
6 frequencies based upon results of previous inspection  
7 material properties.

8 MR. SHEWMON: But 180 percent is likely to go  
9 --

10 MR. OKRENT: It doesn't matter.

11 MR. SHEWMON: I think there are probably two  
12 different issues here.

13 MR. BENDER: Well, the impression that at  
14 least I developed, and I think they would agree with me,  
15 is that the Staff is trying to shift its position. But  
16 in fact, we have not heard the case for deciding to back  
17 away from this requirement.

18 MR. OKRENT: Right. It may be that this is  
19 going to be all right or whatever, but I was just having  
20 a problem understanding what the term "current criteria"  
21 means. And it is true, at least at the meeting  
22 yesterday morning, it was called the meeting on generic  
23 issues. And this may not be a USI, but it is in this  
24 list of things.

25 MR. SIESS: I think that's a good point,

1 Dave. And I believe one way of saying what current  
2 criteria means as far as the SEP is concerned is that  
3 these reviews were made initially by the same technical  
4 reviewers that are reviewing other plants. They  
5 reviewed it according to what they considered current  
6 criteria, whether it was the standard review plan or  
7 Staff policy. If they say it meets current criteria,  
8 then the SEP staff accepted it.

9 MR. OKRENT: In fact, in a letter we wrote  
10 recently -- I don't remember on which case -- we asked  
11 that the Staff tell us how in the end they are going to  
12 resolve the turbine missile issue so that we can at  
13 least see what it is they're going to do. Because  
14 usually they say we're going to handle this and tell you  
15 in some future SER, which is usually a one-liner.

16 MR. SIESS: Our follow-up system isn't  
17 working, I guess.

18 MR. OKRENT: I don't think they've written the  
19 detailed description of the basis for resolution.

20 MR. MOELLER: On this same item, this is one  
21 that Zenon Zudans addressed. I wonder if --

22 MR. SIESS: I think we're getting ahead of  
23 ourselves, gentlemen. The items will be flashed up  
24 later for you to take up. Right now we are asking the  
25 Licensee just to give us a plant description, so keep

1 that in mind.

2 MR. SHEWMON: We're trying to.

3 MR. RAUSCH: I haven't much to go here.

4 Briefly, some of the unique features of our plant, maybe  
5 not necessarily unique, but we have a two-loop  
6 recirculation system, flow control, three electric  
7 feedwater pumps. The containment is a Mark I type  
8 torus, suppression pool and water source. Water source  
9 is available for emergency core cooling as well as  
10 suppressing the pressure during a loss of coolant  
11 accident.

12 We have a typical ECCS system. The high  
13 pressure coolant injection system is steam-driven. We  
14 have four 33-1/3 capacity LPCI pumps, two 100 percent  
15 core spray pumps. Our automatic depressurization system  
16 uses four electromagnetic relief valves, plus a combined  
17 safety relief valve.

18 Dr. Siess has asked me twice. Our type is not  
19 the type that had the actuation problems that were  
20 experienced about five years ago. I believe it is a  
21 three-stage.

22 We have an isolation condenser, which we are  
23 probably one of the few BWR's. Millstone has one also.  
24 We use that for the passive decay heat removal for our  
25 condenser. It's a very reliable system, very simple.

1 One valve turns it on. It comes in quite handy.

2 Looking at safe shutdown analyses, it's  
3 essentially full heat removal capability five minutes  
4 after scram. We also have a separate shutdown cooling  
5 system. We do not use -- we do not have the typical  
6 RCIS and LPCI RHR modes, although we can use in extreme  
7 circumstances some ECCS for decay heat removal also. So  
8 we have a rather unusual flexibility in the ways we shut  
9 down the plant.

10 I have a slide of each of these type of  
11 systems later on, if you want to look through them. I  
12 don't plan on flashing them up.

13 MR. EBERSOLE: May I ask the Staff a  
14 question? This is one of the few plants which has  
15 electric main feedwater pumps, or boilers, that is,  
16 boiling water plants. Do these plants have a potential  
17 for thermal shock in the primary vessel as a result of  
18 overrun of the electric-driven pumps to a state of solid  
19 fill?

20 They can develop full feedwater pressure  
21 without any steam, which is not exactly a desirable  
22 feature. Is my question clear?

23 MR. RUSSELL: Yes, it is. We're just getting  
24 the answer.

25 Dresden has a feedwater pump trip that was



1 installed after the event, and I believe the other  
2 aspect of your question relates to the applicability of  
3 the pressurized thermal shock issue?

4 MR. EBERSOLE: Yes.

5 MR. RUSSELL: I can't address that one.  
6 That's related to the USI. I just don't know the  
7 answer.

8 MR. SHEWMON: You'll never get the fluence up  
9 in a boiler.

10 MR. EBERSOLE: You don't get the fluence?

11 MR. RUSSELL: We discussed that earlier, and  
12 the fluence is significantly less because of the jet  
13 pump and because of the amount of water and the  
14 effective thermal shields. But the specific answer to  
15 your question is being looked at. There are detailed  
16 answers. I believe it's not a problem, but I can't give  
17 you the answer as to why it's not.

18 MR. BENDER: Unless the fracture toughness was  
19 low to begin with, there is no reason to think it's  
20 going to get any lower, because the fluence in these  
21 BWR's really doesn't get up to the threshold of damage.

22 MR. EBERSOLE: Is that to say you can develop  
23 a full feedwater pressure with the system and it'll be  
24 all right?

25 MR. RAUSCH: It would take a couple of

1 failures to get that to happen.

2 MR. EBERSOLE: Oh, I'm sure.

3 MR. RUSSELL: We can't answer that question.

4 What we have done is to reduce the probability of that  
5 occurring by having the feedwater trips.

6 MR. EBERSOLE: Is that a safety-grade trip?

7 MR. RUSSELL: The Licensee is indicating it  
8 is. I can't answer that question.

9 MR. RAUSCH: Likely it would use the same  
10 water level instrumentation that was used for the  
11 safety-grade trips.

12 Just quickly, my last slide is just a rundown  
13 of our availability and capacity factors for the life of  
14 the plant. A couple of things you can notice on this.  
15 In the mid-seventies we went to 18-month cycles. As a  
16 result, we had some years with rather high  
17 availabilities.

18 Our capacity factor tends to be a little bit  
19 low compared to the domestic BWR's. I believe we're  
20 about tenth out of 22, life of the plant, domestic BWR's  
21 capacity factor. That is because we have made a  
22 practice for a number of years of using extended  
23 coastdowns. We've found it more economical to run the  
24 plant a longer time, even though we had reduced power.

25 Availability. Cumulative, I believe we're

1 about sixth out of 22, so that's a pretty good record.  
2 In 1980 we were the highest in the entire world for a  
3 nuclear plant, 93.3 percent.

4 MR. BENDER: Would you clarify why 1981 has  
5 that difference?

6 MR. RAUSCH: That was a very long refueling  
7 outage. We installed our triple-clad feedwater feed  
8 spargers. We had the seismic modifications, IE Bulletin  
9 79-14. We also had extensive Mark I containment work.  
10 I think it was close to a five-month outage.

11 MR. SIESS: I don't know why you call those  
12 refueling outages, when the refueling is the least thing  
13 you do. They are maintenance outages.

14 MR. RAUSCH: That's right.

15 MR. MARK: How do you decide to go to an  
16 18-month cycle when you have previously been at some  
17 other cycle?

18 MR. RAUSCH: We had several economic studies  
19 that were performed.

20 MR. CARBON: Do you up the enrichment of the  
21 fuel?

22 MR. RAUSCH: Yes. Basically what's happened  
23 since the early seventies is, the vendors become more  
24 comfortable with putting in higher amounts of galinea in  
25 the fuel initially and raising the enrichments. When

1 you start, you really don't have much limit to what you  
2 can do as soon as you understand your neutronics with  
3 the galinea in there. So we have a lot of galinea and  
4 the enrichments are getting very high. We're on the  
5 order of 2.8 percent, 3 percent average enrichments.

6 MR. MARK: That allows you to run longer, and  
7 then your fuel goes to 30,000 megawatts instead of 25?

8 MR. RAUSCH: That can happen also. It  
9 depends. You have a lot of variables on how you  
10 discharge the fuel, but in the end you're going to get  
11 some higher exposure also.

12 MR. SHEWMON: The old limits were also  
13 partially determined on the assumption you were going to  
14 reprocess the fuel, and that it has become more likely  
15 that it's economic to go to longer cycles.

16 MR. RAUSCH: Especially if you have a long  
17 outage, if you have them every 18 to 20 months as  
18 opposed to 24 months.

19 MR. SHEWMON: He's learns very quickly. That  
20 is a maintenance outage now.

21 Would you tell us roughly how Dresden 3  
22 compares to that?

23 MR. RAUSCH: I have a few figures on Dresden  
24 3. The capacity factor for Dresden 3 cumulative is less  
25 than a percent difference.

1 MR. SHEWMON: Above or below?

2 MR. RAUSCH: A little bit lower. Dresden 3  
3 had some bad fuel failure problems in the early  
4 seventies.

5 MR. SHEWMON: I don't want to get into that as  
6 much. If that is your last slide, would you tell me the  
7 main differences between Dresden 3 and Dresden 2? And  
8 what I have in mind to ask the Staff later is, whatever  
9 they are going to require on this, why is Dresden 3 fit  
10 to keep operating without them, or vice versa?

11 MR. RAUSCH: We have taken the position that  
12 we are applying directly anything we do on Dresden 2 to  
13 Dresden 3, and to the extent applicable to Quad Cities  
14 Unit 1 and 2. A lot of the more immediate issues were  
15 of a procedural nature, and obviously we have common  
16 procedures between the units and they have been  
17 backfitted immediately.

18 There are varying stages of modification  
19 implementation, but we take the position that if we  
20 agree something is needed on Unit 2 then we agree it's  
21 needed on Unit 3. There are very little differences  
22 between the two units outside of the fuel, and we use  
23 Exxon fuel now and Dresden 2 is getting its first reload  
24 of Exxon fuel coming up in January.

25 MR. SHEWMON: And Dresden 3 has been on

1 Exxon?

2 MR. RAUSCH: It's just had its first refuel of  
3 Exxon about a year ago.

4 MR. SIESS: Any other questions?

5 MR. SHEWMON: You have liners in the fuel. Is  
6 that Dresden 1?

7 MR. RAUSCH: Quad Cities is undergoing an  
8 extensive change.

9 MR. SHEWMON: That's Quad Cities?

10 MR. RAUSCH: Yes.

11 MR. SIESS: In between, let me mention a  
12 couple of things I forgot. In the notebook there were  
13 letters, there are letters, from two consultants we had  
14 at the meeting, Ivan Catton and Walt Lipinski. You may  
15 want to look at those.

16 And then I think it might be appropriate to  
17 point out in between a difference between Dresden and  
18 Millstone. Both are three-unit sites. You just heard  
19 what is at the Dresden site. And there are some shared  
20 components between Dresden 2 and Dresden 3. Millstone  
21 is also a three-unit site, but Millstone 1 is a boiler,  
22 Millstone 2 is an operating PWR, and Millstone 3 is a  
23 BWR under construction.

24 You just heard Commonwealth say they are  
25 making the fixes on four almost identical BWR's. At

1 Millstone, they believe in diversity.

2           Okay, let's hear from Northeast Nuclear.

3 Richard Casig from Northeast Utilities.

4           MR. KACICH: Richard Casig from Northeast  
5 Utilities. I just thought I'd take a second to identify  
6 the people we have from Northeast Utilities this  
7 morning. In addition to myself, in the licensing group  
8 there is Mike Vain, who works in licensing, who's been  
9 following the SEP topics on a day to day basis. We have  
10 Jan Rader from our reactor engineering branch, Bob  
11 Christie from our radiological assessment branch, and Ed  
12 Berry from our plant station. He holds an SRC license  
13 and is a shift supervisor, and he's going to be giving  
14 our plant presentation history.

15           MR. BERRY: Thank you.

16           As Rick said, I'm Ed Berry. I'm a shift  
17 supervisor at Millstone Unit 1. I've held the positio  
18 for four years. I've been at Millstone for 12.

19           You've seen most of the modifications that  
20 have gone into effect and also seen how well they work.  
21 In the first vugraph --

22           (Slide.)

23           -- we have a one-line diagram showing Unit 1.  
24 As was mentioned earlier, we are a three-unit site.  
25 Millstone 2 is a Combustion Engineering pressurized



1 water reactor, Millstone 3 is a Westinghouse. We do  
2 share one system throughout the site and that's the  
3 water system. We have three pumps that pump into that.  
4 It's a closed loop.

5 We also share some of the air systems, some of  
6 the makeup water systems. There are no safety-related  
7 systems shared as such. We have the ability to  
8 cross-tie some electrical power. If Unit 2 needs it,  
9 you could transfer it from Unit 3.

10 (Slide.)

11 We are a GE BWR-3. We are very similar to  
12 Dresden. One of the few things we don't have at  
13 Dresden, they have a HPCI system, we have a feedwater  
14 coolant injection system which utilizes our feedwater  
15 system and a gas turbine. We're rated 2,011 megawatt  
16 thermal, 680 megawatts electric. We're a Mark I  
17 pressure suppression containment. We were constructed  
18 by Ebasco.

19 We have two recirc loops with 20 jet pumps,  
20 and it's a once-through cooling system with the Long  
21 Island Sound. We have the on-site emergency power  
22 system, which consists of a diesel generator and a gas  
23 turbine generator, which I guess most of you people are  
24 aware of or have heard of.

25 We have the typical BWR-3 emergency core

1 cooling systems, with the exception of the KWCI system.  
2 We also have an isolation condenser, and we're unique in  
3 the fact that we have a 100 percent turbine bypass  
4 capability. So the plant will ride out a full load  
5 reject without a scram. This has been tested, and also  
6 we have had several full load rejects and we have a  
7 success rate of around 60 percent on that.

8 (Slide.)

9 For the history on Millstone, the construction  
10 start date was May 1966. Initial on-line was November  
11 29th, 1970, and we declared commercial operations  
12 December 1970. 100 percent power was obtained January  
13 3rd, 1971. The procedure in the major outages -- we've  
14 had several long outages. The first one was attributed  
15 to a chloride intrusion incident. It was approximately  
16 a six-month outage. Then we had the first feedwater  
17 sparger replacement in the industry in 1973.

18 The next long outage was the seventh refuel.  
19 That was October 1980. That was our ten-year ISI  
20 program. We just came out of the eighth refueling about  
21 a month ago. It was a fairly typical refueling outage.

22 (Slide.)

23 Okay. Unit performance: Megawatt electric  
24 generated to date is 45 million; capacity factor of  
25 about 63.3 percent, which is kind of low and attributed

1 to those two long outages. And the last one we were  
2 only running about 90 percent due to a forced last stage  
3 turbine wheel that was damaged on startup after the last  
4 refueling.

5 (Slide.)

6 Here we have the Millstone Unit 2 systematic  
7 assessment of the Licensee performance. Overall, we  
8 find the management attention at our facilities is  
9 aggressively oriented toward nuclear safety and  
10 effective use of ample resources has resulted in a high  
11 level of performance in operational safety and  
12 construction activities.

13 (Slide.)

14 Here is some more of that. The only area we  
15 got category two in was security and safeguards, and  
16 offhand I really don't know the reason for that.

17 That's about all I have. Are there any  
18 questions?

19 MR. SHEWMON: Would you tell me what your  
20 experience has been on stress corrosion cracking of the  
21 main piping?

22 MR. BERRY: I'd like to address that to Rick.  
23 I get involved after it's found out and we go replace  
24 the piping.

25 MR. SHEWMON: Have you gotten involved? Have

1 you replaced anything?

2 MR. BERRY: Yes, we have replaced piping. We  
3 replaced the core spray piping. We thought we had  
4 attributed it to the isolation condenser tube rupture.  
5 I believe that happened in 1976. We attributed that  
6 partly to chloride stress corrosion cracking.

7 MR. SHEWMON: Chloride? You're on seawater?  
8 Your coolant is seawater?

9 MR. BERRY: Our coolant is seawater to the  
10 main condenser. The isolation condenser uses fire water  
11 for makeup. During that chloride intrusion incident, we  
12 did have high conductivity in the reactor vessel and we  
13 had the isolation condenser for service.

14 MR. ETHERINGTON: Well, you retubed your  
15 condenser, didn't you?

16 MR. BERRY: Yes, we did.

17 MR. CARBON: This is a little bit aside from  
18 some of the technical experience. What experience has  
19 Northeast or Millstone had with intervenors or people  
20 who have objecting from the local neighborhood?

21 MR. BERRY: Very few that I'm aware of. We've  
22 been lucky so far. We're fairly close to Seabrook.  
23 Compared to Seabrook, we've had none.

24 MR. MACICH: In fact the answer is none,  
25 fortunately.

1           MR. CARBON: Do you know why? Do you have a  
2 particularly complacent set of people living around  
3 there.

4           MR. BERRY: No. The Navy has its submarine  
5 base right there. We have General Dynamics. So it's  
6 very used to nuclear.

7           MR. KACICH: Part of the reason I think is  
8 timing. Both Millstone 1 and 2 had received their  
9 operating licenses before it became particularly  
10 popular to get into that sort of thing, and Millstone 3  
11 has yet to reach the operating license stage. So  
12 there's a potential for that to occur at that time.

13           MR. CARBON: Do you expect that to be realized  
14 or not?

15           MR. KACICH: It would not surprise me if it  
16 happened. Let me put it that way.

17           MR. BERRY: Also, demonstrations have really  
18 fizzled out. They'll start and they don't get too many  
19 people showing up.

20           MR. REMICK: A related question along that  
21 line. Am I correct that some of the taxes go back  
22 directly to the local communities?

23           MR. BERRY: To Waterford. Yes, Waterford is  
24 very happy about that.

25           MR. EBERSOLE: You've got this great

1 old-fashioned thing called an ice condenser. Would you  
2 be unhappy if somebody took it away from you?

3 MR. BERRY: I definitely would. That is one  
4 of the best pieces of equipment we have.

5 MR. EBERSOLE: But you could get along without  
6 it?

7 MR. BERRY: We have, yes.

8 MR. EBERSOLE: What pressure rating is that?  
9 Do you have to blow down to use it?

10 MR. BERRY: It's full pressure 10, 15 seconds,  
11 then it goes into service. The operators really fall  
12 back on that. It's a really nice piece of equipment to  
13 have.

14 MR. EBERSOLE: That's great.

15 Do you have to have accessory electric  
16 equipment to DC/AC, et cetera, to run a long-term  
17 shutdown? To what degree of independence? Does this  
18 run into an electrical failure problem?

19 MR. BERRY: No electrical power is required  
20 whatsoever. The initiating valve is a DC-operated  
21 valve.

22 MR. EBERSOLE: Wouldn't you lose the seals on  
23 the pumps first?

24 MR. BERRY: The isolation condenser has no  
25 pumps.



1 MR. EBERSOLE: There might be other things if  
2 you held pressure up.

3 MR. BERRY: If we held pressure up, we could  
4 isolate the recirc pump seals and stay right there.

5 MR. EBERSOLE: Do you think it's been a  
6 progressive move on the part of GE to abandon isolation  
7 condensers?

8 MR. BERRY: My personal opinion, I'm very  
9 strongly in favor of an isolation condenser from an  
10 operator's standpoint.

11 MR. EBERSOLE: I always thought it would be  
12 regressive to go away from it and I still do. Thank  
13 you.

14 MR. REMICK: To get makeup to the isolation  
15 condenser, that's what, fire water?

16 MR. BERRY: Yes.

17 MR. REMICK: Is it diesel-operated?

18 MR. BERRY: Yes, it is. Initially, if we use  
19 fire water, since fire water is city water, after we  
20 take it out of service it will drain down the south side  
21 and put demineralized water into it.

22 MR. SIESS: Other questions?

23 MR. MOELLER: Yes. We had presented for  
24 Millstone the results of the SALP. I wondered if the  
25 Dresden people could just quickly tell us the results



1 there.

2 MR. RAUSCH: Yes. We haven't had an SALP. We  
3 haven't received our final report. The results go back  
4 to, I believe, '80 and '81. We did not get quite the  
5 number of category ones that Millstone did. I believe  
6 we had four or five category ones, and the remainder  
7 were category twos, as an average. I believe we had one  
8 or two category threes. One I recall for sure was in  
9 the health physics area, because we had an overexposure  
10 event.

11 MR. MOELLER: Thank you.

12 MR. EBERSOLE: A question. Does your 100  
13 percent bypass give you a substantial advantage in the  
14 bypass case?

15 MR. BERRY: It definitely does.

16 MR. EBERSOLE: Do you have any problems with  
17 bypass pressure? Is it challenged?

18 MR. BERRY: I believe Dresden has like 45  
19 percent bypass capability, and they would rely on their  
20 relief valves putting energy into the torus or the  
21 suppression chamber, whereas our bypass system will go  
22 right down into the condenser, not into the  
23 containment.

24 MR. EBERSOLE: Well, with your relief valves,  
25 what capacity relief valve systems do they have? It's

1 not reduced, is it? It belongs to the old generation  
2 where you have 100 percent relief?

3 MR. BERRY: We have 100 pounds per hour and we  
4 have 60, so it's not quite.

5 MR. EBERSOLE: Not quite.

6 MR. SIESS: Other questions?

7 (No response.)

8 MR. SIESS: Thank you.

9 I will now turn it over to the Staff. Who's  
10 going to start? Chris Grimes, and you are going to  
11 handle both, right, Chris?

12 MR. GRIMES: Yes, sir.

13 MR. SIESS: I've asked the Staff to start off  
14 at a fairly rapid pace on the items that have been  
15 deleted and gradually to get into more and more details,  
16 but we are stoppable at any point for expansion. I  
17 would suggest, however, that since our time is limited  
18 and somewhat more limited than I have asked for, that  
19 you would probably have more questions and more  
20 interesting questions the farther down the list you  
21 get. So pace yourself.

22 (Slide.)

23 MR. SIESS: Raise your slides as high as you  
24 can on that thing, Chris. If you can, get your back to  
25 the wall. If Dr. Okrent doesn't complain, that's all

1 right, and he can move you back if he wants to.

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1           MR. GRIMES: Good morning. My name is Chris  
2 Grimes. I am a system leader in the Program Assessment  
3 Branch. I have with me today Greg Cwalina, the  
4 Integrated Assessment Project manager for Dresden 2, and  
5 Drew Persinko, the project manager for Millstone Unit 1.

6           As section leader, I was nominated to provide  
7 a presentation for both plants simultaneously which is a  
8 statistical feat in itself, trying to keep the 72 issues  
9 for Dresden and the 87 issues identified on Millstone 1,  
10 and put them together without getting them confused, but  
11 I will attempt to do so.

12           The first slide identifies the topic  
13 statistics for the two plants. I will go through each  
14 of the categories of topics and identify where there  
15 were differences. Then I will make a presentation on  
16 the issues addressed by the integrated assessment, and  
17 when I go into the integrated assessment, I will convert  
18 from topics to individual issues.

19           The statistics are separated because the  
20 individual topics can have a number of issues associated  
21 with them.

22           (Slide.)

23           MR. GRIMES: Where I can, I will also identify  
24 those issues which were common to Oyster Creek, but I  
25 will not dwell on the resolution of the issues for

1 Oyster Creek because they were presented at the last  
2 full committee meeting.

3 (Slide.)

4 MR. GRIMES: Here is an outline of the agenda  
5 for the way the topics and issues in the integrated  
6 assessments will be addressed. The further evaluation  
7 issues will be discussed prior to the technical  
8 specification change procedural or hardware issues,  
9 because they might lead to procedure or hardware  
10 backfits.

11 (Slide.)

12 MR. GRIMES: With regard to the topics that  
13 were generically deleted, the list for Dresden and  
14 Millstone were identical, with the exception of Topic  
15 5-4. During the course of the topic reviews, the issue  
16 on furnace sensitized safe ends was raised. Dresden had  
17 not yet made -- taken a corrective action in accordance  
18 with the generic program, so the issue was reviewed in  
19 part for Dresden.

20 (Slide.)

21 MR. GRIMES: With regard to the topics that  
22 weren't applicable, the bulk were not site related or  
23 applicable to BWR's. The list is identical with the  
24 exception of 24E iam integrity. The iam didn't relate  
25 to either Millstone 1 or Oyster Creek, because they are

1 ocean sites. Also, I would like to point out that if  
2 you are trying to do a comparison of the tables, they  
3 match well for Dresden and Millstone but not so well for  
4 Oyster Creek because the integrated assessment project  
5 manager elected to take some things which were excluded  
6 on a generic basis for PWR's and put them on a generic  
7 list. In either case, they were either excluded on the  
8 basis of generic activity or because they didn't apply.  
9 Whichever reason you want to use gets it on the list of  
10 topics to be deleted, so we didn't pay much attention to  
11 that.

12 MR. EBERSOLE: Is 1517 strictly true for PWR's  
13 that have isolation condensers?

14 MR. GRIMES: That is true, because the issue  
15 to be reviewed was one of the transient events that  
16 occur for tube failure in the isolation condenser, as I  
17 recall, because there are upstream isolation valves, it  
18 is an isolatable and terminatable event. Therefore it  
19 doesn't fall into the same category as the issue that  
20 was raised with regard to the PWR case.

21 MR. EBERSOLE: Are you saying it is not a  
22 required heat detection source?

23 MR. GRIMES: It is not a transient event of  
24 concern, because it is isolatable.

25 MR. SIESS: You can do that without affecting

1 heat removal?

2 MR. GRIMES: Yes, because you can go to ADS.  
3 You can go to steam dump to the torus and use a feed and  
4 bleed approach with high pressure injection.

5 (Slide.)

6 MR. GRIMES: Now I will go into the topics  
7 which meet current criteria or are acceptable on another  
8 defined basis. The definition there is one of, if we  
9 were reviewing this issue on a new plant and it did not  
10 meet explicitly the criteria today but they had an  
11 alternative that was equally acceptable to the staff, we  
12 would document it and put it in the SER and everything  
13 was fine.

14 That is another defined basis that was used in  
15 the topic evaluations to conclude that they were  
16 acceptable.

17 (Slide.)

18 MR. GRIMES: First, I will present those that  
19 were common to both Dresden and Millstone. The topics  
20 that are asterisked are those that were found acceptable  
21 on another defined basis. The list is generally the  
22 same for Oyster Creek, except for a number of issues  
23 that were reviewed at the integrated assessment. The  
24 number is small.

25 If you want me to go through that comparison,



1 I will, but I don't really think it is that  
2 significant.

3 (Slide.)

4 MR. GRIMES: Here is a continuation of the  
5 same list.

6 (Slide.)

7 MR. GRIMES: If you see any topic on there  
8 that you are interested in, we will discuss it.

9 MR. SIESS: Was this list a whole lot  
10 different for the boilers than it was for the  
11 pressurized water reactors?

12 MR. GRIMES: I knew you would ask me a  
13 question that I wasn't prepared for. I didn't do a  
14 comparison. I would say that in general they are fairly  
15 comparable, but I haven't done it in detail.

16 MR. SIESS: Are there any outstanding things  
17 boilers didn't meet criteria on that PWR's did, or vice  
18 versa? That is all right.

19 MR. RUSSELL: There is only one area where the  
20 boilers came substantially closer to meeting current  
21 criteria than the PWR's, and they had to do a steam  
22 isolation. The General Electric design generally came  
23 closer to the GDC's for containment isolation than was  
24 the case on either Pallasades or Ginna.

25 MR. GRIMES: That is a good point. In boilers

1 we often find isolation valves outside containment  
2 because of the cramped environment and use of check  
3 valves are more predominant.

4 (Slide.)

5 MR. GRIMES: With regard to the topics that  
6 were found acceptable or equivalent that were unique,  
7 the reason for the difference in this list is  
8 principally because there were issues raised on Dresden  
9 that were considered in the integrated assessment or on  
10 Millstone that were considered in the integrated  
11 assessment and closed out in the topic evaluation.

12 There were two issues on Dresden that were not  
13 applicable to Millstone, and those were both of the  
14 issues that I just alluded to in the deletion list, the  
15 dam integrity and the piping.

16 MR. EBERSOLE: You mentioned check valves  
17 inside containment. I believe it has been the practice  
18 of GE to always put exercisers on their check valves,  
19 yet in the PWR regime, which uses borated coolant, there  
20 are no such exercisers. What is the reason for this  
21 difference, and how does the Staff look at this  
22 difference? These are devices that move the check valve  
23 periodically --

24 MR. GRIMES: Positive acting check valves.

25 MR. EBERSOLE: -- to see that it is working.

1 None of the PWR's have it, yet they presumably have a  
2 greater chance of having trouble because of the use of  
3 borated coolant. What is the Staff's view on this? Or  
4 does it make any difference? It is a lot of trouble to  
5 put them on.

6 MR. GRIMES: I am not sure that the Staff has  
7 a particular view on it other than it enhances the  
8 capability to do in service inspection for operability  
9 of valves.

10 MR. EBERSOLE: You always made GE do it. That  
11 was the story I got from you a long time ago.

12 MR. GRIMES: That may be true. If we made GE  
13 do it, I don't know why we made the PWR's do it.

14 MR. EBERSOLE: I don't, either. Does anybody  
15 know?

16 MR. SIESS: Chris, why is reactor vessel  
17 integrity an item on Dresden and not on Millstone?

18 MR. GRIMES: Because the furnace sensitized  
19 safe end issue was resolved on Millstone in a generic  
20 sense. It was picked up by SEP because they had not yet  
21 made the safe end change.

22 MR. SIESS: Thank you.

23 (Slide.)

24 MR. GRIMES: Now I will go through the topics  
25 and issues which were addressed by PRA.

1 MR. SIESS: Will you take two seconds and  
2 explain the difference between topics and issues for the  
3 benefit of the committee?

4 MR. GRIMES: Yes, sir. A topic is a general  
5 category that was reviewed. The issues are the specific  
6 differences from current criteria that were identified  
7 from the topic evaluation. So, as we go through the  
8 integrated assessment results, there will be a number of  
9 cases where I identify a topic that falls into one or  
10 more categories of no action, procedural change,  
11 hardware change, or further evaluation.

12 MR. SIESS: Think of issues as subtopics.

13 MR. GRIMES: The results of the risk  
14 perspective inputs that were provided to the integrated  
15 assessment are summarized here in the fashion that they  
16 were summarized in the reports that are presented in  
17 Appendix E for Dresden and Millstone. For Dresden, the  
18 PRA evaluation used a modified Millstone IREP approach,  
19 and therefore, like Pallisades and Ginna, we have a  
20 limited risk perspective based on extrapolation of  
21 another PRA.

22 They categorized the risk of the issue in  
23 accordance with the difference from current criteria as  
24 either being low, medium, or high in the context of  
25 contribution to core melt. For Millstone, there was a

1 plant specific IREP. The results are summarized in  
2 Appendix D in a ratio of a new risk to an old risk, the  
3 risk change being represented by making the plant  
4 modification from different current criteria.

5 At this time, Mr. Spulak from Sandia will give  
6 you a brief presentation on the difference between  
7 having a limited and a plant specific PRA, unless you  
8 have any specific questions about the lists of the  
9 issues, topics and issues.

10 MR. EBERSOLE: The first item, please. Do  
11 these plants have a fully pressurized main steam supply  
12 to the high pressure core injection pumps maintained at  
13 full pressure at all times outward of the isolation  
14 condenser? In other words, they maintain full steam  
15 pressure up against the stop valves?

16 MR. GRIMES: I don't know the answer to that  
17 question.

18 MR. EBERSOLE: Let's assume they do. If they  
19 do, one then has the problem of HPCI feed line failure  
20 and the requirement in almost an absolute context that  
21 you intercept steam flow. What is the reliability of  
22 those valves intercepting failed pipe steam flow? Do  
23 you follow me?

24 MR. GRIMES: Yes, sir. I will have to go back  
25 and check. As I recall, it is not up to the stop

1 valve. It is in the inside containment.

2 MR. EBERSOLE: Is it?

3 MR. GRIMES: I believe so, but let me check.

4 MR. EBERSOLE: That changes the whole picture,  
5 if that is the case.

6 MR. MOELLER: Excuse me. For example, on that  
7 list, the first item, III-5.B, 55, and 511A, Dr. Zudans  
8 raised questions on each of those. Now, will we hear  
9 that later?

10 MR. GRIMES: They are addressed in the context  
11 of either requiring no action, requiring further  
12 evaluation. I will go into each of the issues in terms  
13 of the integrated assessment results after you  
14 understand how we were given a risk perspective on each  
15 of the issues.

16 MR. SIESS: We will now hear from Mr. Spulak  
17 on how they used the PRA. You are next. Are we going  
18 to hear from you on the PRA or not?

19 MR. ERNST: I would like to say a couple of  
20 words before we start on the PRA. It will come out  
21 during the PRA presentation that there were a number of  
22 rather low risk sequences identified that seemed to have  
23 some potential hardware fixes associated with them. In  
24 that regard, I think a few introductory remarks are  
25 worthwhile.



1           First, as was pointed out for Millstone, this  
2 was the first time that there has been a quantitative  
3 assessment of the SEP potential fixes versus the  
4 qualitative matrix kind of approach that was used  
5 before. For a number of -- a half-dozen or so of these  
6 issues, DST did take a look at the risk reduction, and  
7 did, based on some judgments that were provided to us,  
8 made some judgments on cost effectiveness. We found a  
9 couple of things.

10           As I mentioned, a number of them did appear to  
11 have rather small or insignificant risk reduction  
12 potential. Some of these did appear to have some  
13 potential hardware fixes associated with them, based on  
14 a reading of the NUREG. I think there are some points  
15 to be made.

16           First, the PRA's are uncertain, as all of us  
17 are well aware. Secondly, in a number of cases, as we  
18 understand it, the licensee desires to make some  
19 changes, for whatever reason, whether it be risk or some  
20 other reason. And we understand also that the end  
21 result is that some of the potential hardware fixes may  
22 not eventually take place anyway.

23           The final point, I guess, is that making  
24 judgments on the usefulness of hardware fixes, I think  
25 PRA is one consideration, but certainly not the



1 determinative consideration. There are some useful PRA  
2 insights, namely, that in most if not all of these, the  
3 risks are at least on the order of or less than a couple  
4 orders of magnitude less than the safety goal, the core  
5 melt proposed safety goal.

6           If one takes a look at the individual risk  
7 reduction potential and some numbers on cost, whether or  
8 not thoroughly documented, may argue that such changes  
9 are worthwhile. It seems to me that there is a point,  
10 and I don't know exactly what that point is, but there  
11 is a point where the residual risk reduction potential  
12 probably is not worth the ball game of looking at it too  
13 hard, even if the alleged costs were very small.

14           And I do question whether very small so-called  
15 changes in hardware don't have somewhat large costs  
16 associated with them anyway. You just can't do too much  
17 for a little bit of money. But I just want a little bit  
18 of perspective that the PRA is not determinative. There  
19 are other considerations. And DST just looked at it  
20 basically from a risk reduction potential, and made some  
21 judgments that there were some marginally defensible  
22 hardware fixes, and those hardware fixes did take place.

23           There are two issues that remain, I think,  
24 looking towards the future, not just Millstone. That is  
25 the policy question of how much initiative should there

1 be to consider hardware fixes for potentially very small  
2 risk reduction sequences, and if so, there should be  
3 some cutoff point at which you just do not pursue  
4 hardware changes any more based on your risk assessment  
5 of what would that cutoff point be.

6 I think this is something we have to look at  
7 in the future.

8 Secondly, with respect to Millstone, there are  
9 a couple of residual issues that were outside the scope  
10 of the SEP program that were identified in the PRA  
11 analysis. One of these involves a more reliable  
12 depressurization because this particular part of the  
13 safety of the plant was paramount in about five dominant  
14 accident sequences.

15 Secondly, apparently, if one loses instrument  
16 power, one also has the potential of losing containment  
17 shutdown cooling systems. I think these issues need to  
18 be addressed. The mechanism of address, since it is  
19 outside the scope of the SEP, and perhaps even outside  
20 the licensing requirements, is a question that needs to  
21 be addressed, and in a broader sense, I guess, addressed  
22 to the safety goal implementation plan, and how do you  
23 use PRA in any future safety goals and making decisions  
24 on that.

25 I just wanted a few moments for a little bit

1 of perspective for the PRA part. Thank you.

2 MR. EBERSOLE: May I ask a question? Under  
3 reliability of the depressurization process which you  
4 suggest was very important, and I certainly agree with  
5 that, was any of that associated with environmental  
6 qualification problems with the solenoid valves that  
7 operate the depressurization system?

8 MR. SPULAK: We have problems with the work  
9 time.

10 MR. EBERSOLE: I want to know if one of the  
11 major contributors to the unreliability of blowdown is  
12 due to a weakness in the solenoid valve design which is  
13 inside a hostile environment.

14 MR. AMICO: Paul Amico from SAI. No, it would  
15 not be dominated by the operator failing to initiate the  
16 manual blow down process.

17 MR. EBERSOLE: Did you find qualification of  
18 the solenoid valves adequate?

19 MR. AMICO: We didn't go into that much  
20 detail.

21 MR. EBERSOLE: If you didn't go into it, you  
22 don't know.

23 MR. AMICO: We used the data available.  
24 Exactly what is included in that data is supposedly the  
25 actual failures. I am unaware of any other.

1 MR. EBERSOLE: Those are type tested. They  
2 are never in situ tested. Thank you.

3 MR. OKRENT: What do you mean when you say you  
4 use the data that are available?

5 MR. AM1 The data that was available in the  
6 IREP study.

7 MR. OKRENT: Yes, but it seems to me when you  
8 answer a question, you should answer the question that  
9 is being asked, to say we didn't do that.

10 MR. AMICO: We personally did not do that.

11 MR. OKRENT: Fair enough. That is an answer.

12 MR. SIESS: Now, I wasn't quite sure what you  
13 were telling us. Were you apologizing for requiring  
14 hardware backfits where there was no reduction in risk?  
15 Or were you disagreeing with the SEP staff for either  
16 requiring them or not requiring them when they were  
17 cheap and there was no reduction in risk?

18 MR. ERNST: I think there are a number of  
19 questions where if hardware fixes are finally the  
20 resolution for the issue and there is some question in  
21 most of these cases and there are also some cases where  
22 apparently the licensee wants to make the change --

23 MR. SIESS: That is his business.

24 MR. ERNST: That is his business, yes, but if  
25 it becomes a resolution in any area where there is a

1 requirement rather than the licensee saying he wants to  
2 do it, and this appears to have a very small risk  
3 reduction, I think in that case from a PRA and cost  
4 benefit standpoint we would say that it does not appear  
5 to be justified.

6 MR. SIESS: I can think of cases where there  
7 is a very small risk reduction, but also a very small  
8 cost. So the cost benefit may look high. And I think  
9 there are some instances like that. Maybe you can just  
10 point them out when we get to them. That would be  
11 better.

12 MR. ERNST: I think this is a policy  
13 question. Maybe it should be applied at Millstone.  
14 Maybe not. But looking ahead, I think one needs to say  
15 how small a level of risk reduction do we worry about.

16 MR. SIESS: I think there are some specific  
17 examples that will help bring this out.

18 Okay, Mr. Spulak. Let's see. Are you going  
19 to be able to give us the relationship between the  
20 numbers and the words? Is that a part of your  
21 presentation? Or will that have to come from Mr.  
22 Russell or Mr. Grimes?

23 MR. SPULAK: I am not sure I understand what  
24 you mean.

25 MR. SIESS: We were told at the subcommittee

1 meeting that low was .9921.

2 MR. GRIMES: Dr. Siess, if I might clarify  
3 that, that is a part of Mr. Spulak's presentation, our  
4 definition of low, medium, and high, and what the ratios  
5 represent. So far as the relationship --

6 MR. SIESS: That is fine. I couldn't remember  
7 which end that came from. So proceed.

8 MR. SPULAK: I am going to briefly discuss the  
9 methodologies and some of the results for our risk  
10 analysis of the SEP issues, and concentrating on Dresden  
11 2 and Millstone 1, and I will emphasize the differences  
12 in the methodologies which were used, the differences  
13 being that for Dresden we used a qualitative approach,  
14 since we didn't have a plant specific PRA, and for  
15 Millstone we had a plant specific PRA as a result of the  
16 IREP study.

17 Therefore, we actually calculated how  
18 resolution of the issue would affect the calculation of  
19 risk as calculated by the IREP study.

20 (Slide.)

21 MR. SPULAK: In both cases, the basis of the  
22 evaluation from a risk perspective was -- this slide  
23 reiterates what I just said, that for Oyster Creek and  
24 Dresden 2 in this case we did a qualitative analysis of  
25 the impact resolution of each issue, and for Millstone 1



1 we did a quantitative analysis. For Millstone 1, we  
2 tried to give as broad a base as possible for  
3 interpretation of the results by calculating the change  
4 in core melt frequency, the changes in exposure, that  
5 is, man rems per reactor year to the public, and the  
6 change in risk which was total fatalities per reactor  
7 year.

8 For the qualitative analysis, we were not able  
9 to provide such a broad perspective. We were  
10 essentially looking at core melt sequences and the  
11 impact of resolution of the issues on core melt  
12 sequences.

13 (Slide.)

14 MR. SPULAK: The IREP Millstone PRA was used  
15 for the base case in both the qualitative analysis and  
16 the quantitative analysis. It was felt that the Dresden  
17 and Oyster Creek plants were fairly similar to Millstone  
18 1, approximately the same vintage BWR's, and so forth.

19 For the qualitative analysis, we took the FSAR  
20 plant drawings and so forth for the plant we were  
21 looking at, either Dresden or Oyster Creek, and actually  
22 went in and changed the Millstone IREP fault trees to  
23 represent failures of the other plant systems. We  
24 weren't able to solve those fault trees and come up with  
25 cut sets or numbers and things like that, because that



1 would have involved a great deal of effort. That would  
2 have essentially been doing a PRA on that plant.

3 But what we did do was use these modified  
4 fault trees, system fault trees, to make qualitative  
5 judgments about how resolution of the issues would  
6 impact the core melt sequences through the system fault  
7 trees. Of course, the IREP -- Millstone 1 IREP applies  
8 directly to Millstone 1.

9 To go into a little more detail about the  
10 qualitative analysis and what we mean by high, medium,  
11 and low when we classified the issues, this table gives  
12 the criteria which we used for these classifications.  
13 An issue was classified as low, starting at the bottom  
14 and going up, if by calculating a change in a component  
15 unavailability or calculating a change at whatever level  
16 the issue affected the system fault trees that we did --  
17 that we developed for the plant.

18 We could detect no change in the component  
19 availability or, if we calculated a change in component  
20 unavailability and did the system fault trees and  
21 determined that there was just no way that that change  
22 in component unavailability could change the top of any  
23 of the system fault trees that appeared in any dominant  
24 sequences, we classified that issue as low.

25 What we meant by dominant sequences were

1 sequences which based on the IREP Millstone PRA and the  
2 Brown's Ferry PRA, which is being published, I think, or  
3 soon to be published, and other PRA's of BWR's, we could  
4 reasonably expect to be dominant accident sequences.  
5 Mostly we looked at the Millstone PRA.

6 An issue was called of medium importance to  
7 risk if the issue would impact but not dominate the top  
8 event of a system level fault tree that would appear in  
9 a dominant accident sequence. An issue was called high  
10 if the resolution of the issue dominated the value of a  
11 system level fault tree based on our judgment which  
12 would appear in a dominant accident sequence.

13 These are the criteria we used to classify the  
14 issues as low, medium, and high importance to risk.

15 (Slide.)

16 MR. SPULAK: Now, the two methodologies that  
17 we used -- of course, the other methodology was a  
18 quantitative methodology. We recalculated the IREP  
19 Millstone PRA incorporating the changes in the plant and  
20 the fault trees to represent resolution of the issues.

21 The differences in the methodologies give rise  
22 to some differences in results. In this slide here, I  
23 have chosen four examples to discuss these differences  
24 in results. Two of these examples are the same across  
25 all three plants. The results are the same, and two of

1 the examples, the results appear to have changed across  
2 the three plants.

3           The first issue is loose parts monitoring.  
4 For all three plants, we evaluated this issue in more or  
5 less the same way. From a PRA perspective, loose parts,  
6 the concern with loose parts is, they can cause damage  
7 within the reactor coolant system and cause transient  
8 events. Based on historical data of loose parts events,  
9 we find that the contribution of loose parts to  
10 transient events is very, very low, and in fact  
11 negligible.

12           So, both from a qualitative point of view and  
13 a quantitative point of view, loose parts contribute  
14 negligibly to risk to the plant.

15           The next issue is bypassing the thermal  
16 overload trips on motor operated valves during emergency  
17 conditions. For Dresden 2, we looked at the valve  
18 failure data and we looked at the failure data for the  
19 thermal overload trips which -- there are similar types  
20 of instrumentation and so forth.

21           And we determined that bypassing the thermal  
22 overload trips could decrease the unavailability of the  
23 motor-operated valve by some small amount, I think about  
24 14 percent or something.

25           So, based on the fact that the system level

1 fault trees that we had had motor-operated valves in  
2 them, and the component data that went into the fault  
3 trees wasn't changed, we decided that the top event  
4 could be affected by this change in data, but it wasn't  
5 going to be dominated by that.

6           So, we classified this as medium for Millstone  
7 3 and Dresden 2. When we actually requantified the  
8 accident sequences at Millstone 1, using the data,  
9 changing the data generated by bypassing the thermal  
13 overload trips, we found that the total core melt  
11 frequency was reduced by about 1 percent.

12           The SEP branch, I think, has come up with some  
13 sort of way or judgment on their part as to what low,  
14 medium, and high would mean for Millstone. I think they  
15 say low is anything less than 1 percent; medium is 1 to  
16 10 percent, and high is anything above 10 percent  
17 change. So, in this case this would be a low issue on  
18 the low end of things, whereas because of the cruder  
19 methodology at Dresden 2, we judged it medium.

20           Now, the qualitative methodology has a couple  
21 of built-in conservatisms because it is qualitative.  
22 This is an example of one of those conservatisms. That  
23 is that we assume that if we look at the system level  
24 fault trees, and we can detect a change in the top based  
25 on a qualitative judgement, we could detect a change in

1 the top of the fault tree due to resolution of the  
2 issue. We have to assume that that change is  
3 non-negligible. We can't quantify the change.

4 In this case, the change is almost  
5 negligible. The 14 percent change in the component data  
6 translates to a 1 percent change in the total core melt  
7 frequency.

8 MR. OKRENT: I am sorry. Did you say that the  
9 SEP branch treats 1 to 10 percent change in core melt  
10 frequency as of medium importance?

11 MR. RUSSELL: We received some recommendations  
12 from DST as to when an issue should be considered, the  
13 thought being that if it was less than a 1 percent  
14 change in core melt, that that was two orders of  
15 magnitude lower than the core melt, and the change  
16 probably should not be considered. If it is in the  
17 category of one order of magnitude less, that is, a  
18 change of 1 to 10 percent of the core melt, it should be  
19 considered, but very carefully, and if it was 10 percent  
20 or greater based upon reduction in risk, that that was  
21 an issue that should be pursued.

22 MR. OKRENT: Is that the policy that --

23 MR. RUSSELL: No, this was just guidance. It  
24 was input. Basically, it was one order of magnitude or  
25 two orders of magnitude less than core melt.

1 MR. OKRENT: I guess I will ask Mr. Ernst. Is  
2 this what you were recommending as policy?

3 MR. SIESS: For what, new plants, or SEP?

4 MR. OKRENT: For any plants at the moment. I  
5 am just trying to understand.

6 MR. ERNST: This for Millstone was the kind of  
7 judgmental approach that we were considering in trying  
8 to come up with some kind of an idea of how much does  
9 one really want to look at sequences that are very small  
10 in risk reduction potential. Clearly, the 1 percent is  
11 right on the borderline between should one really  
12 dismiss it or should one give it some further  
13 consideration.

14 So, to say if it is above 1 percent we clearly  
15 consider it and below 1 percent we don't is clearly far  
16 beyond the state of the art. We are struggling with the  
17 point of at what point do we stop worrying too much  
18 about the benefit cost aspect and just say on the basis  
19 of residual risk reduction it doesn't seem to be worth a  
20 trip to the store.

21 MR. OKRENT: I would like to talk about the  
22 point for a moment, Mr. Chairman. In the first place, I  
23 have a problem using core melt and not the release  
24 category. For example, if that 1 percent were reactor  
25 vessel failure, gross reactor vessel failure, I suspect



1 it would be looked at as something of some considerable  
2 importance, but there are other kinds of accidents that  
3 have related not far different release categories. So I  
4 am just using that as something you can visualize.

5           Secondly, our knowledge of this 1 percent and  
6 10 percent, it seems to me, have to be part of the  
7 consideration, and if you think you do not know things  
8 very well, that has to enter into the thing. I myself  
9 would say that contribution -- let me pick a number  
10 between 1 and 10 percent -- 5 percent of the core melt  
11 frequency to me is a big number, and you are just  
12 putting it into the thing that might be considered not  
13 something to be pursued.

14           What I am bothered by is the development of  
15 some kind of an ad hoc policy within the staff based  
16 upon crude estimates of core melt frequency which will  
17 grow into a pattern that this is what we no longer  
18 follow, and so forth. I would suggest in fact that you  
19 write something down, Mr. Ernst, and put it out for  
20 extensive comment so that in fact it can be a  
21 well-discussed issue instead of something that grows  
22 insidiously.

23           MR. ERNST: If I might take a minute, I am  
24 sympathetic to all your points, Dr. Okrent, particularly  
25 the last one. I do think we need to not have things



1 grow insidiously. With regard to the 5 percent  
2 question, I perceive no difference between considering  
3 and pursuing. What we are really judgmentally saying  
4 is, if it is in the 10 percent or larger range, it is  
5 something that needs to be done, and in the other range  
6 of considering is taking a closer look at the problem,  
7 at cetera.

8           On the risk question, I agree wholeheartedly.  
9 I think the question is coming a little more  
10 simplistically than it was. We considered not only core  
11 melt, but reduction in risk in making judgments on the  
12 releases from the accident sequences. So the 1 percent  
13 sort of applied to both.

14           MR. AXTMANN: What sort of limits do you have  
15 in mind qualitatively for the reality of the overall  
16 core melt frequencies that you started with?

17           MR. ERNST: In my view, the 1 and 10 percent  
18 numbers are certainly not hard and fast. They are sort  
19 of developed taking a look at the estimated --

20           MR. AXTMANN: I am talking about 10 percent of  
21 what, and how good is that.

22           MR. ERNST: I am trying to get there. We took  
23 a look at from Millstone not only the core melt  
24 frequency advertised in the PRA but also the man rem,  
25 and these numbers were sort of all hard numbers based on

1 Millstone itself. If you had a situation with an  
2 entirely different risk of core melt profile, the  
3 judgments may be somewhat different, but it is sort of  
4 considering what may be coming forth in a safety goal as  
5 you look at the advertised numbers in Millstone and make  
6 some kind of a judgment of sort of where might your  
7 decision breaks be, that kind of a thing.

8           So, we did consider the Millstone risk and  
9 core melt as advertised in the PRA and came up with  
10 these numbers. It could well be different if you had a  
11 different situation.

12           MR. EBERSOLE: May I ask a question, please?  
13 As a means of testing the application of this  
14 methodology, if you were to apply it to TMI 2, say, a  
15 year before the problem, do you think the findings would  
16 have intercepted what eventually happened there, that  
17 you would have detected what were the causative factors  
18 that led to the TMI 2 meltdown, and something would have  
19 been done about it?

20           MR. SIESS: Are you talking about the PRA or  
21 the SEP?

22           MR. EBERSOLE: The kind of methodology.

23           MR. ERNST: I don't quite know how to answer  
24 that, because I think in the PRA methodology if one  
25 considered the circumstances that actually occurred at

1 TMI, and you would carry that more than likely before  
2 the fact, you would carry that to a core melt with  
3 substantially different off-site consequences, I think,  
4 in the PRA world, but I am not sure what you were --

5 MR. EBERSOLE: I am saying application of your  
6 methodology, if it were stylish at that time, do you  
7 think it would have prevented TMI 2?

8 MR. ERNST: First, you would have to describe  
9 and fully understand --

10 MR. EBERSOLE: I know.

11 MR. ERNST: -- the sequence, and then I don't  
12 know where the number at TMI would fall. Clearly, the  
13 consequences might have been the 2,000 person rem or  
14 whatever the consequences were --

15 MR. OKRENT: To answer the question directly,  
16 I think if you take the approach currently used in the  
17 PRA's with regard to estimating the likelihood of  
18 operator error, given seven people in the control room,  
19 the answer is, it would have been a very unlikely event.

20 MR. EBERSOLE: Yes.

21 MR. OKRENT: If we did it now, knowing  
22 everything that happened, but using the kind of things  
23 one sees in the current PRA with regard to the chance of  
24 operator -- not just one person, but several people.

25 MR. SIESS: Given eight people and two hours.

1           MR. ERNST: That is true, but if you took the  
2 existing situation as an historical event and then tried  
3 to calculate --

4           MR. SIESS: That was not the question.

5           MR. SHEWMON: But the obvious conclusion from  
6 that is, we need more PRA, not less? Is that correct?

7           (General laughter.)

8           MR. EBERSOLE: I won't draw that conclusion.

9           MR. SIESS: Gentlemen, I may be anticipating a  
10 little bit, but I think you have got some idea from the  
11 previous reviews of how the Staff was using these sort  
12 of indirect PRA's in their SEP judgments. I don't  
13 believe they used the Millstone IREP PRA any more  
14 extensively or any more strictly than they used the  
15 indirect PRA's. They applied an awful lot of judgment  
16 on top of it, or in spite of them, I am not sure which.

17           MR. OKRENT: I might comment, I looked at the  
18 PRA discussions, and most of the issues that are dealt  
19 with here are small issues. I guess I would classify  
20 them as not difficult issues involving both a large  
21 chance or a relatively large percentage of the overall  
22 risk of core melt and also a very expensive fix, and so  
23 forth.

24           So, I think in the end, I think the PRA tended  
25 to agree with their intuitive judgment for the most

1 part. It was useful to do that. The issue I was  
2 raising was maybe that the philosophy will be applied  
3 elsewhere in things that are more substantive, and  
4 before that is done, I think the philosophy has to be  
5 examined in depth.

6 MR. SIESS: I agree. Okay, Mr. Spulak.

7 MR. SPULAK: The next issue on the slide,  
8 which is containment isolation, points up or at least  
9 illustrates one of the concerns Dr. Okrent raised. That  
10 is, that there is a difference between core melt and  
11 risk. For the purposes of this discussion, I prepared  
12 this slide with the numbers from core melt. The  
13 containment isolation would have a minimal effect on the  
14 core melt frequency in any case, no matter how bad it  
15 was or how good it was, but it could have a large effect  
16 on off-site doses and therefore risk.

17 MR. SIESS: But it didn't.

18 MR. SPULAK: No, that is true.

19 MR. SIESS: I happen to have another table  
20 that gives other numbers in them.

21 MR. EBERSOLE: In that connection, aren't  
22 these old plants susceptible to reduction of NPSH  
23 availability if you lose containment isolation?

24 MR. SPULAK: From the recirculation, you  
25 mean?

1 MR. EBERSOLE: Yes. The case I recall  
2 required retention of the atmosphere fraction inside  
3 containment to maintain NPSH on the pumps, to maintain  
4 suction. You need atmospheric components. You couldn't  
5 just let it leak off and have steam in the containment.  
6 Is that true of these plants?

7 MR. SPULAK: I don't know.

8 MR. EBERSOLE: How do you know that  
9 containment isolation is not important?

10 MR. SPULAK: It wasn't identified as important  
11 in the Millstone IREP study.

12 MR. RUSSELL: Can I answer the question? That  
13 does not affect these plants. The issue of whether you  
14 use containment pressure to provide adequate net  
15 positive suction protection for the pumps was looked  
16 at. I believe the event you are concerned about is one  
17 we discussed in detail, the situation that came up on  
18 Beaver Valley with the subatmospheric containment.

19 MR. EBERSOLE: Yes.

20 MR. RUSSELL: We do not have that problem for  
21 any of the plants we have looked at thus far in the  
22 SEP. That minimum positive suction head was looked at  
23 on those plants as part of the abnormal occurrence  
24 follow-up when that event was recorded.

25 MR. EBERSOLE: Well, that problem doesn't go



1 away with non-below atmospheric plants.

2 MR. RUSSELL: That's correct. It does not,  
3 but we have not considered credit for the positive  
4 pressure in containment in calculating the minimum  
5 suction head requirement for these plants.

6 MR. EBERSOLE: Thank you.

7 MR. OKRENT: I am sorry. My memory tells me  
8 it was Millstone 1 we were talking about when the issue  
9 of net positive suction head became, let's say --

10 MR. SIESS: Maybe that is why it is no  
11 problem.

12 MR. OKRENT: No, again, at Millstone 1 it was  
13 not clear that at least for some events that they didn't  
14 need some pressure, so I would like to know, is my  
15 memory wrong or not? Are there any accident situations  
16 where they in fact are counting on some containment  
17 pressure for the pumps to work?

18 MR. RUSSELL: The event in the resolutions I  
19 was discussing were about 1976, '77, involved Beaver  
20 Valley, North Anna, Surrey. I don't know about  
21 Millstone 1.

22 MR. OKRENT: This arose before Beaver Valley.  
23 This was in '66.

24 MR. SIESS: The question is, does it exist  
25 now. Isn't that it, Dave, on Millstone 1?



1 MR. OKRENT: Did it exist, and does it exist?

2 You have to live with it.

3 MR. SIESS: Let's ask the licensee, who  
4 certainly has done the analyses for his plant. Do you  
5 have the question?

6 MR. KACICH: I have the question. I don't  
7 know if I know the answer. I don't recall any specific  
8 incident unique to Millstone where this would have  
9 received any more attention than it would at any other  
10 facility. To the best of my knowledge, I agree with  
11 Bill's statement. Our analyses did not take any credit  
12 for assumed containment pressure. That is part of the  
13 calculation. We assumed atmospheric pressure.

14 MR. OKRENT: All right. Would you --

15 MR. SHEWMON: He will return.

16 MR. OKRENT: Would you confirm that that is  
17 the case? You may well be right.

18 MR. KACICH: Yes, sir.

19 MR. OKRENT: I will reserve judgment.

20 MR. KACICH: Yes, sir.

21 MR. SIESS: Onward.

22 MR. SPULAK: The reason that we assessed the  
23 containment isolation wasn't important to risk or core  
24 melt was because the pressure generated by the steam  
25 non-condensable gases during core melt would always be

1 great enough to fail the containment even if no other  
2 type of failure occurred first, or if no other type of  
3 failure occurred first, such as a steam explosion.

4           So, the effect of failing containment  
5 isolation is minimal compared to the overpressure of  
6 failure and rupture by steam explosion.

7           MR. OKRENT: I read that, and I must say it  
8 seems to me that that is a case where you may have used  
9 PRA results directly without asking yourselves could  
10 there be other kinds of sequences which you ignore in  
11 the PRA because they do not seem to contribute very much  
12 in the same way as someone saying, well, at Three Mile  
13 Island you wouldn't have gotten to full core melt, and  
14 it didn't.

15           MR. SPULAK: I agree entirely. However, we  
16 were using the IREP PRA as our base case, so we didn't  
17 want to extrapolate for this specific case.

18           MR. OKRENT: I don't think you are on very  
19 solid ground on that particular argument myself.

20           MR. EBERSOLE: It seems to me you have ignored  
21 the set of accidents wherein failure of containment  
22 isolation results in degradation of equipment, which  
23 then produces core melt, which is the inverse sequence.

24           MR. SPULAK: There were not any of those kinds  
25 of sequences that have dominated Millstone.

1 MR. EBERSOLE: I asked about the failure of  
2 the HPCI steam line, which could have been the case,  
3 except I was told the pressure was not maintained  
4 outboard of the isolation valve. Do you look at this?

5 MR. SPULAK: I am going to ask Paul Amico, who  
6 is principal investigator for the IREP PRA, because he  
7 is much more familiar with the details, to answer that  
8 question.

9 MR. EBERSOLE: You did tell me that you found  
10 the plants did not maintain full pressure outboard of  
11 the interior isolation valves, didn't you?

12 MR. AMICO: I didn't tell you that. I am not  
13 sure exactly what you are talking about.

14 MR. EBERSOLE: I am talking about the failures  
15 on isolation system failures and ultimately that lead to  
16 core melt because of equipment degradation.

17 MR. AMICO: Secondary effects of pipe breaks  
18 outside containment.

19 MR. EBERSOLE: Right, which runs your  
20 equipment down to a failsafe state so you can't pump  
21 water any longer.

22 MR. AMICO: No, we did not do environmental  
23 effects. , The only thing we did do is, we did look into  
24 the probability of an unisolated pipe break outside  
25 containment, and found that to be a negligible frequency

1 event.

2 MR. EBERSOLE: I imagine it is a negligible  
3 frequency event, irrespective of its consequence.

4 MR. AMICO: Correct. There is a certain point  
5 at which we cut off the analysis. We couldn't analyze  
6 all the way down to 10<sup>-12</sup> or anything like that, so  
7 there is a point below which an event was said to not be  
8 important even if just the occurrence of that event  
9 caused core melt because there were other combinations  
10 of events or something that were two or three orders of  
11 magnitude higher than the cutoff failure.

12 MR. SHEWMON: Gentlemen, let me remind you  
13 that as soon as we can leave this interesting topic, we  
14 can have a break.

15 (General laughter.)

16 MR. RUSSELL: If I might make one comment,  
17 there were a number of areas which we identified that  
18 were related to SEP issues which were not addressed  
19 explicitly or even considered in the PRA. The spatial  
20 dependency of pipe breaks, for example. Whether a  
21 component can function as designed. Does the relief  
22 valve have sufficient capacity that you do not have to  
23 worry about the event?

24 The issue you just brought up is the question,  
25 can the valve shut to isolate the break? The assumption

1 in the PRA only looks at random failures of a valve, and  
2 does not look at quality of that valve or its ability to  
3 function under those design events. We tried to  
4 consider those issues and describe what the concerns  
5 were in our use of the PRA for the SEP issue, for the  
6 issue of concern.

7           This is why in some areas, for instance, the  
8 leakage detection of pipe breaks inside containment, we  
9 tended to not use the PRA results for arguing that  
10 nothing more needed to be done on leakage detection.

11           So, I think we will see some cases like that  
12 as we go through the specific issues that were looked  
13 at, where the approach from PRA looks at random failures  
14 but not at the ability to function, and whether there is  
15 an underlying basic problem with the design.

16           MR. SIESS: Onward.

17           MR. SPULAK: The last issue that I have chosen  
18 to discuss illustrates another type of conservatism in  
19 the qualitative analysis that we did. This is DC  
20 instrumentation. The concern here is that some battery  
21 failures or DC bus breaker failures, and so forth, may  
22 be detectable immediately with adequate instrumentation  
23 in the control room, rather than weekly or monthly or  
24 however often that particular component is tested, and  
25 this should reduce the unavailability of the DC power

1 system.

2           For Dresden 2 and Oyster Creek, our  
3 qualitative methodology said, well, yes, if you can  
4 detect a significant fraction of the failures  
5 immediately instead of at test intervals, you could have  
6 a significant, perhaps dominant effect on the  
7 unavailability of the DC power system, and since DC  
8 power is a system which appears in dominant event  
9 sequences at other kinds of plants similar to Dresden  
10 and Oyster Creek, we rated that issue as high and  
11 important to risk.

12           On Millstone 1, when we changed the DC power  
13 fault trees to reflect the fact that you could detect  
14 some failures immediately, rather than waiting for  
15 testing, we found that it made a very small effect on  
16 the overall core melt frequency. The reason is that  
17 even though the DC power system does plug in or  
18 contribute to dominant core melt sequences, it senses  
19 the support system. The failures of DC don't appear in  
20 many dominant cut sets of those sequences.

21           There are other kinds of failures other than  
22 failures of DC which contribute to the core melt  
23 sequences. So that is another kind of conservatism.

24           In our ignorance about the exact way that DC  
25 power would contribute to core melt sequences at the



1 other plants, we have to conclude that it could  
2 contribute significantly.

3 MR. EBERSOLE: Didn't that neglect the fact  
4 that one of these plants at Millstone has a bypass  
5 condenser for shutdown heat removal and the other  
6 doesn't? One plant doesn't need DC as much as the  
7 other. Did you account for the relative needs of these  
8 things in the plant design?

9 MR. SPULAK: I guess I would have to say no,  
10 although like I said, we are conservative in that we  
11 assume that at the other plants DC would be required.

12 MR. RUSSELL: Dr. Ebersole, all three of these  
13 units have isolation condensers. We did not have that  
14 particular aspect.

15 MR. SIESS: Dave?

16 MR. OKRENT: I would like to read a few lines  
17 from a letter written on January 15, 1970, from the ACRS  
18 to Dr. Seeborg concerning Millstone Nuclear Power  
19 Station Unit 1. It says, and I quote, "One design  
20 change, however, involved the reduction in the capacity  
21 of each of the redundant containment cooling systems.  
22 This alteration requires placing greater reliance on the  
23 heat capacity of the torus water for temporary storage  
24 of heat energy in the unlikely event of a hypothetical  
25 loss of coolant accident. The increase of the torus



1 water temperature to 203 degrees F. under certain  
2 degraded conditions is an additional concern because of  
3 its potential effects on the performance of the  
4 emergency pumps. These include the direct effect of  
5 high temperatures on the pumps and the dependence on  
6 containment pressure to assure adequate net positive  
7 suction head." End of quote.

8           Now, I don't know. The situation may be  
9 different now. But that is what was in the committee  
10 letter in 1970.

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. SIESS: You still want to know what the  
2 situation is now, right?

3 MR. OKRENT: I don't think it's vital to the  
4 SEP review, but I am curious.

5 MR. SIESS: You want to get historical  
6 accuracy. Mike?

7 MR. BAIN: Mike Bain, Northeast Utilities. I  
8 think I can answer that question. That concern came up  
9 before the plant was originally licensed. It  
10 subsequently had an amendment to the SAR, which was a  
11 result of some tests which were conducted prior to  
12 initial operation of the plant.

13 What was done initially was a test to  
14 determine the capability of the ECCS pumps to operate  
15 with the torus water temperature of 230<sup>o</sup> and also a  
16 loss of ventilation in the rooms. That did relate to an  
17 SEP topic on ventilation systems. We have just recently  
18 provided some documentation with those test results.

19 MR. OKRENT: Let's see, that would be 203<sup>o</sup> F  
20 water at atmospheric pressures?

21 MR. BAIN: Yes, that's right.

22 MR. OKRENT: Okay, that's fine. Thank you.

23 MR. SIESS: Here is another demonstration of  
24 Dr. Okrent's memory.

25 MR. SPULAK: This about concludes my

1 discussion unless there are questions.

2           In summary, I tried to show the differences  
3 between the qualitative methodology that we used for  
4 Dresden and the quantitative methodology we used in  
5 incorporating the IREP PRA for Millstone and to show  
6 how, you know, the different methodologies require  
7 different types of interpretation in order to provide  
8 the results of the analyses.

9           MR. SIESS: The remainder of your handout is  
10 an answer to our questions.

11           MR. SPULAK: That's right.

12           MR. SIESS: Are there any further questions on  
13 how this was done by the Sandia people? We will hear a  
14 little more from the SEP staff on the number of grains  
15 of salt with which they took these results.

16           MR. AXTMANN: Perhaps I'm the only one who is  
17 mystified by the last column in the table X-1 of the  
18 Millstone report. The new risk divided by the old  
19 risk. Where do those numbers come from?

20           MR. SPULAK: The IREP PRA did not do  
21 consequence analysis. They did not say okay, if we have  
22 a release, how many people are going to die. What they  
23 did do is they placed the various accident probabilities  
24 into various release categories. The release category  
25 gives the measure of the accident.

1                   What was done was to take accident  
2 calculations for the various release categories, which  
3 were done for Northeast, River Valley composite site and  
4 weight the releases in the various release categories by  
5 their relative consequences. This we used as the  
6 measure of risk.

7                   The consequences were total fatalities.

8                   MR. AXTMANN: So the 550 man rem per reactor  
9 year is in case of a release; is that right?

10                  MR. SPULAK: That is a different number,  
11 okay? That was calculated using the expected man rem  
12 exposure per release in a given release category. The  
13 risk and the exposure reported in that table are two  
14 different things, although they turn out -- the percent  
15 changes turn out to be just about the same.

16                  MR. AXTMANN: Thank you.

17                  MR. SIESS: Any other questions for Mr. Spulak?

18                  (No response.)

19                  Thank you, and we will take a break for ten  
20 minutes, if that's all right with the super-Chairman.

21                  (A short recess was taken.)

22                  MR. SHEWMON: Onward.

23                  MR. SIESS: Okay, Chris, you're on again.

24                  MR. GRIMES: I would like to start my  
25 presentation by first making a clarification about the

1 consultants' comments. You have been provided with  
2 copies of the consultants' comments on Dresden and  
3 Millstone. For all three boiling water reactors, we  
4 only had four. It was not an issue of Dr. Budnitz  
5 having any conflicts; he had a different contractual  
6 arrangement. It was more difficult to try to restart in  
7 the beginning of the fiscal year and we haven't gotten  
8 it restarted yet. Hopefully, he will be on the next  
9 review, which is Yankee. For the time being, we settled  
10 for four.

11 MR. SIESS: The trouble is Office of Contracts  
12 got -- not the legal office.

13 MR. GRIMES: That's correct.

14 MR. SIESS: I don't know which is worse.

15 (Laughter.)

16 MR. GRIMES: This is just a list of issues  
17 that were identified during the reviews that are common  
18 to both plants. A clarification there -- the  
19 commonality from plant to plant was my judgment. If  
20 they came reasonably close to being an issue, if they  
21 involved slightly different systems or if it was the  
22 same kind of issue, I called them common. For example,  
23 on unisolatable breaks outside containment, the reactor  
24 water cleanup system in both cases, by the related  
25 systems are not identical. The systems are the same.

1 The rationale for concluding no action is required is  
2 the same.

3           Dr. Zudans, in relation to the question that  
4 Dr. Moeller raised before, Dr. Zudans indicated in his  
5 comments that he felt that stresses in accordance with  
6 the Mechanical Engineering Branch technical position  
7 would be desirable. The staff concluded that the effort  
8 required to develop those stresses was not necessary  
9 because of the low probability of the unisolatable break  
10 in relation to the probability of simultaneous failure  
11 of both isolation valves.

12           Another comment was made by Dr. Bush regarding  
13 the ESF piping supports on both plants. We concluded  
14 that that issue was being adequately dealt with, but by  
15 I&E bulletin 79-14, Dr. Bush made the comment that he  
16 felt they were going in the wrong direction. But  
17 nevertheless, we feel the resolution of Bulletin 79-1'  
18 will resolve this issue and we don't need to pursue it.

19           MR. SIESS: His disagreement was really with  
20 79-14, not the review.

21           MR. GRIMES: That's correct.

22           MR. SIESS: He thought you were more likely to  
23 make a better judgment than 79-14, I think.

24           Just for the committee's benefit, 79-14 has to  
25 do with pipe supports. Bush feels like it is leading to

1 more and more pipe supports and he thinks that direction  
2 is wrong; that we should have fewer pipe supports and  
3 more flexible systems. A view that the staff has not  
4 yet agreed with.

5 He expressed a particular concern that the  
6 staff is considering this as an industry program, and he  
7 was concerned that we make these people put in more pipe  
8 supports and two years later come along and tell them to  
9 take them out. And worse, he has to tell them they  
10 should take them out, a not unheard of occurrence.

11 The SEP staff has simply said this is somebody  
12 else's business, we've got to let somebody else do it.  
13 It's an industry-wide generic issue, and under your  
14 rules, you have to pass that on.

15 MR. GRIMES: That's right. We have no ability  
16 to change other programs. But where other programs will  
17 resolve issues identified in the SEP topic evaluations,  
18 we defer to those other programs.

19 Another example of that would be safe shutdown  
20 procedures where the TMI symptom-oriented procedures  
21 will resolve the issues related to safe shutdown, and we  
22 have deferred certain matters related to procedures to  
23 that generic program.

24 MR. SIESS: I'm not sure whether the committee  
25 understands completely the notation on here, but the



1 alphabet soup on the left is a topic designation, and  
2 the numbers beginning with 4 are the numbers beginning  
3 in Chapter 4 of the NUREG, which is where these things  
4 are correct.

5 MR. GRIMES: That's correct. For your  
6 convenience, I have identified the common issues and the  
7 sections from the three integrated assessment reports  
8 from Oyster Creek, Dresden-2 and Millstone-1. OT is  
9 Oyster Creek, D2 is Dresden-2 and M1, Millstone-1. The  
10 asterisks on individual sections indicate that that is a  
11 issue that is being addressed in a different section.

12 For example, on the three sets, on Dresden-2,  
13 part of the issue was deferred to 79-14. Another part  
14 of the issue that was identified specifically during our  
15 seismic evaluation regarding the recirculation coolant  
16 pump and their supports with regard to the seismic  
17 capability is being addressed under further evaluation.

18 MR. SIESS: Okay, now, these lists we're going  
19 to put up and let people decide whether they want to  
20 know why -- whether there's anything they want explained  
21 as to why no backfit was required.

22 MR. GRIMES: That's correct. And before you  
23 decide what you would like a clarification of, there's a  
24 green separator sheet behind the handouts. In that, all  
25 of the issues are organized by topic number with a

1 detail of the issue, the specific sections involved and  
2 a brief discussion of the resolution of the issue.

3           We will use those sheets to answer any  
4 questions to explain the staff's position. Any items on  
5 this. Jesse?

6           MR. EBERSOLE: Yes. The first item up there,  
7 I take it that was looked at in the context of dosage  
8 from small lines primarily that were not isolatable?

9           MR. GRIMES: No, sir, that was an issue where  
10 there was no stress data available to demonstrate  
11 compliance with the Chemical Engineering Branch  
12 technical position for super-pipe between containment  
13 and isolation valves outside containment. The  
14 resolution, as we see it, is that the probability of a  
15 pipe break combined with a random failure of the  
16 end-board valve assuming that the outboard valve fails  
17 or the outboard valve breaks between the containment and  
18 the containment isolation valve -- the probability of  
19 both valves simultaneously or randomly failing together,  
20 given that a pipe break occurs.

21           MR. EBERSOLE: But do you have any background  
22 data about how well that operates in the presence of  
23 full flow?

24           MR. GRIMES: No.

25           MR. EBERSOLE: So you don't really know how

1 well the valve operates in the first place. The only  
2 valves we've really tested in this context are the main  
3 steam isolation valves, and that was years ago.

4 MR. GRIMES: An issue was recently raised on  
5 purge valves, and it's being looked at in the context I  
6 think of the dynamic loading on piping systems in  
7 general.

8 MR. EBERSOLE: Are these small lines?

9 MR. GRIMES: The reactor water cleanup system  
10 I believe is on the order of 12 to 14 inches. The line  
11 that you mentioned previously, the HPSI line, was not a  
12 line specifically identified in our evaluation as  
13 susceptible to this problem. The steam line to the  
14 isolation condenser was. And in the staff's judgment,  
15 because they could not generate stress data to show that  
16 they've got a piece of super-pipe in there, the fact  
17 that the pipes are being restrained, the restraints are  
18 being reviewed. The fact that dynamic testing of valves  
19 has become an issue and is being pursued, we felt that  
20 it was not worth demonstrating compliance with the  
21 stress data, given all of the other investigatory  
22 pursuits along with the fact that there are design  
23 aspects that we did look at.

24 And therefore, we concluded no further action  
25 was required.

1 MR. EBERSOLE: Is full steam pressure  
2 maintained somewhere along the pipe outside containment?

3 MR. GRIMES: Probably. You want to keep it  
4 warm so you don't get a thermal shock.

5 MR. EBERSOLE: Under full flow potential, do  
6 you have a length of pipe outside containment?

7 MR. SIESS: That is addressed to both  
8 licensees, I assume, since this is a common problem.

9 MR. GRIMES: A common problem would be the  
10 isolation condenser steam line, I would expect.

11 MR. SIESS: Did you understand? The first one  
12 that understands the question can answer.

13 MR. EBERSOLE: We're looking towards equipment  
14 degradation.

15 MR. RAUSCH: I'm not sure I understand the  
16 question.

17 MR. EBERSOLE: Do you carry full steam  
18 pressure, full steam flow, outboard of the primary  
19 containment ?

20 MR. RAUSCH: Yes, we carry full pressure up to  
21 the isolation condenser.

22 MR. EBERSOLE: How many feet or so? Is that  
23 10, 15, 20 feet?

24 MR. RAUSCH: At least 100.

25 MR. EBERSOLE: If I blow that line, --

1 MR. RAUSCH: The line isolates if either valve  
2 works.

3 MR. EBERSOLE: So this is some distance  
4 outside the main steam line. It requires the function  
5 of one of the other valves.

6 MR. RAUSCH: That's right.

7 MR. EBERSOLE: And that's in the presence of  
8 not too good knowledge about the valve.

9 MR. SIESS: Pipe break and two valve failures.

10 MR. RAUSCH: In our case, the lines run  
11 through the reactor building but not in the immediate  
12 vicinity.

13 MR. SIESS: Any other questions on steam flow?

14 MR. GRIMES: Isolation steam valves is an  
15 example; it's not the only one involved.

16 (Slide.)

17 On the next page, with regard to topic VII.2  
18 -- this is on the no-action list because the  
19 modifications that resolved the issue were actually  
20 implemented before the integrated assessment and may  
21 have been implemented without SEP, so we're crediting  
22 them in both cases in the no-action section and in the  
23 hardware section just to make sure we have every base  
24 covered.

25 MR. EBERSOLE: Let me return to the

1 non-isolatable failure. A recent PWR that I looked at  
2 had applied hydraulic delays or controls to the main  
3 steam flow check valves, which was obviously done in  
4 view of the concern that the sudden closure of these  
5 valves would disintegrate the valve and you would have  
6 an unisolatable break.

7           At this point in time, what proof do you have  
8 that your main feedwater flow checks will, in fact,  
9 intercept a reverse loss if you get a feedline failure  
10 upstream of the feedwater check valves? Do you have  
11 tests, do you have analyses? What is the quality of  
12 these? Do you know that the design basis is adequate to  
13 postulate that they will function considering the abrupt  
14 reversal and the violence of the reverse flow?

15           (Pause.)

16           MR. GRIMES: The licensees are trying to  
17 decide how they approach it. I would like to point out,  
18 as I did before, the concept of dynamic loading on  
19 valves, which really came to light with the purge valve  
20 issue, is being pursued in the context of equipment  
21 qualification. As you noted before, General Electric  
22 has, either voluntarily or through some design practice,  
23 come up with positive acting checks. I believe that the  
24 feedwater lines are also positive acting checks.

25           MR. EBERSOLE: They are not positive acting;



1 they are just exercises to see that the pivot line  
2 doesn't lock. They still depend on the mode of power.  
3 They didn't do that to the feedwater, anyway.

4 MR. SIESS: Let's go on, and when the  
5 licensees think they have an answer, they'll raise their  
6 hand and somebody will see them. The next list, Chris.

7 MR. GRIMES: That's the last of the common  
8 issues. Now for the specific issues for what action is  
9 warranted. I'll take this a half at a time, the top  
10 half first.

11 Here you will note that on topic III.1 for the  
12 fracture toughness data and topic III.4.A with regard to  
13 the tornado issues for service water condition and  
14 batteries, there's selection of the issues for which the  
15 staff concluded no further action was warranted. You  
16 will note that under the fracture toughness data, it is  
17 for reactor water cleanup, reactor building closed  
18 cooling water, and I can't recall what RSCS is. I was a  
19 little too liberal with my acronyms.

20 With regard to the tornado initial issues, the  
21 staff reviewed those selected systems. You will find,  
22 however, in the further evaluation section, the common  
23 issue with regard to providing protection of at least  
24 one train for tornado missiles.

25 MR. MOELLER: Would you comment on IX.5, which



1 is not quite shown?

2 MR. SIESS: He was doing it a half a page at a  
3 time.

4 MR. GRIMES: With regard to IX.5, Millstone is  
5 asterisked because it, I believe, is under the further  
6 evaluation section. Yes, it's under the further  
7 evaluation section. It was a question of the  
8 consequences of a single failure causing a loss of  
9 ventilation for low pressure coolant injection of core  
10 spray systems. The pumps, specifically.

11 For Dresden, there was sufficient information  
12 available for us to conclude that the consequences were  
13 acceptable for a lack of ventilation for those systems.  
14 For Millstone, that information was not available and  
15 it's being pursued under further evaluation.

16 MR. SIESS: The next page.

17 MR. GRIMES: Now for the Millstone-specific  
18 issues for which no action is required. The one issue  
19 that might occur on this list but in my bookkeeping  
20 system did not show up was topic IX.3, station service  
21 water. That is an issue that will be ultimately  
22 resolved by the topic II.4.F foundation issue. The  
23 common line for the service water system is supported on  
24 peat material. Whether or not that material is  
25 sufficient to maintain the integrity of the pipe is an

1 issue that once resolved, resolves IX.3 So IX.3 is  
2 actually a no-action issue because it refers back.

3 Are there any other issues on here? I also  
4 would like to point out on topic VII.3, we identified an  
5 issue related to the results from the PRA. In doing  
6 their evaluation they concluded that removal of  
7 automatic bus transfers would automatically lead to a  
8 design change for a redundant instrument bus. That  
9 reduced substantially the core melt frequency.

10 We indicated in our integrated assessment that  
11 the resolution of the automatic bus transfers did not  
12 necessarily mean a complete removal, so we are  
13 evaluating the PRA results from the standpoint of the  
14 potential improvement for a redundant instrument bus.  
15 And we intend on reporting on that in the final report.

16 MR. EBERSOLE: With respect to item VI.4,  
17 instrument lines, did you find that these three BWRs are  
18 in that unfortunate group that has common instrument  
19 headers, which if they fail throws both the indicating  
20 and response equipment to disarray so that neither of  
21 these safety systems or the operators know what is going  
22 on?

23 MR. GRIMES: No, sir. When you raised this  
24 question on a BWR-6 review about eight months ago, we  
25 were able to quickly determine that there were separate

1 instrument caps for a BWR-6. I have not had as much  
2 success with the BWR-3s and 4s, but I do know that based  
3 on the instrumentation reviews, there is adequate  
4 instrumentation to cause a shutdown, even if you are to  
5 lose a complete train of a common type of instrument.

6 MR. EBERSOLE: Does that mean that if you lose  
7 that train in that particular place, then you are  
8 susceptible to the single-failure criterion; that you  
9 have to survive on a single functional channel?

10 MR. GRIMES: No, sir.

11 MR. EBERSOLE: You have redundant channels  
12 after the instrument line failures?

13 MR. GRIMES: Yes, sir.

14 MR. EBERSOLE: Thank you. Is that true of all  
15 PWRs that you've looked at?

16 MR. GRIMES: To the best of my knowledge,  
17 that's true. I don't know if I could answer that  
18 question for somebody like LaCrosse.

19 MR. RUSSELL: It's true for LaCrosse. We put  
20 in a separate water tap level.

21 MR. SIESS: Before we leave this item, do we  
22 have an answer to the question that was asked before?  
23 And if so, will you repeat the question? Let them  
24 repeat it and then we'll know.

25 MR. RAUSCH: You were asking about the dynamic

1 capability of feedwater check valves and the reverse  
2 direction.

3 MR. EBERSOLE: Yes.

4 MR. RAUSCH: We do check. I believe everybody  
5 tests them in accordance with either the IST program or  
6 the LSJ requirements. They are leak tested. They are  
7 probably leak tested at accident pressure, not in full  
8 reverse pressure. However, that's not the point of leak  
9 tests.

10 All I can say is that it is a standard  
11 industry check valve that is a higher grade than any  
12 used anywhere else. This is not a unique issue to the  
13 nuclear power plant.

14 MR. EBERSOLE: You have no quantitative data  
15 that they will not disintegrate and fail?

16 MR. RAUSCH: We don't have quantitative data,  
17 but we have a number of events where you get  
18 instantaneous pressure reduction but that is very  
19 rare.

20 MR. EBERSOLE: You don't have any, because it  
21 requires a pipe break.

22 MR. RAUSCH: You can have large pressure  
23 changes in pumps starting transients.

24 MR. EBERSOLE: But that's gradual.

25 MR. RAUSCH: Somewhat gradual.

1 MR. SHEWMON: This is one of your wonderful  
2 instantaneous pipe breaks, too, Jess; is that right?

3 MR. EBERSOLE: Whatever it is.

4 MR. SHEWMON: That's never been observed,  
5 either. And let me add, never will.

6 MR. EBERSOLE: The graduality of the failure  
7 is fine.

8 MR. RAUSCH: That's just my opinion. I would  
9 think that's what would happen.

10 MR. EBERSOLE: I've never seen an analysis of  
11 its competence.

12 MR. SHEWMON: I'm looking for an analysis of  
13 if the pipe can break that way.

14 MR. EBERSOLE: However the pipe can break,  
15 there should be competence shown for these reverse  
16 feedwater checks. I never see that; what is that?

17 MR. SIESS: You haven't asked the question  
18 before.

19 MR. EBERSOLE: I've asked it a dozen times.

20 MR. RAUSCH: And there's also three valves.  
21 You have a propagating pressure wave but it would be  
22 reduced as you go through the valves.

23 MR. EBERSOLE: We have the parts of the  
24 upstream valves also going down to the second and third.

25 MR. RAUSCH: But the large pressure changes

1 are seen in pumps burnout transients. They may not be  
2 the same.

3 MR. EBERSOLE: The same degree.

4 MR. RAUSCH: It will be over a few seconds.

5 MR. EBERSOLE: I think I would be inclined to  
6 want to know more about that.

7 MR. SHEWMON: Let's leave it at that.

8 MR. SIESS: Can Northeast add anything to the  
9 confusion?

10 MR. KACICH: I'm afraid not.

11 MR. SIESS: Okay. Chris, on to the next list.

12 MR. RUSSELL: Before we leave the last one, I  
13 don't want to leave a misimpression with the committee  
14 on the issue of redundant instrumentation in the control  
15 room or a redundant bus. That issue is being looked at  
16 partially with respect to Reg Guide 1.97,  
17 instrumentation to follow the course of an accident, and  
18 the need for redundancy.

19 We, in our review, determined that failure of  
20 the instrument bus in the control room -- while you  
21 would no longer have all the instrumentation in the  
22 control room for shutdown, there was adequate local  
23 instrumentation to accomplish the shutdown from outside  
24 the control room.

25 The issue of whether the staff will require



1 reifundant instrumentation in the control room or not is  
2 being looked at as part of the generic program, and I  
3 would not expect or would not recommend that that be  
4 considered as a part of the SEP. That is a broader  
5 issue affecting a large number of plants. It's also a  
6 very costly issue from the standpoint that many of these  
7 control rooms do not have room for additional  
8 instrumentation. So it should be looked at very  
9 carefully. So we would not get ahead of the generic  
10 program and make a decision on that in SEP.

11           The current criteria for these plants are met  
12 from the standpoint of the failure of the instrument bus  
13 for the vital AC bus and the ability to shut down for  
14 single failures.

15           The PRA issue looks at the reliability of  
16 various components and therefore assumes many failures  
17 and, therefore, is looked at in the PRA. We will be  
18 looking at that and the actions associated with it to  
19 determine what further action should be taken, if any.

20           MR. GRIMES: Now I'll go on to those issues  
21 requiring further evaluation with the potential for some  
22 sort of corrective action.

23           (Slide.)

24           These are the issues that are common to both  
25 Dresden and Millstone. To make another clarifying point



1 with regard to the way these are organized, the  
2 commonality is only for Dresden and Millstone. In some  
3 cases, you will find issues on the list where they are  
4 not common to Oyster. Again, I have an issue here where  
5 it is selected -- I pointed out before there are certain  
6 aspects of radiology and fracture toughness that were  
7 considered. No action required in Dresden. The balance  
8 of them are covered here, under the further evaluation  
9 section.

10 I would also like to point out, in trying to  
11 pick up the consultants' comments, Dr. Hendrie in all  
12 cases made the comment that he felt that this was not  
13 worth pursuing. We responded on Oyster Creek and we  
14 will respond on Dresden and Millstone that the staff's  
15 information regarding the margins of safety associated  
16 with the design of these components is information that  
17 is valuable, especially as issues arise where you want  
18 to know how well qualified the safety systems are. So  
19 we feel it is worth the exercise required to go through  
20 and document the degree or the extent to which the  
21 changes in codes impact margins of safety.

22 Dr. Zudans remarked on topic II.4.B whether or  
23 not full closure of the turbine control valves is  
24 reasonable. The reason that it was worded the way it  
25 was, especially in Millstone's case where it's something

1 that is being pursued, is it is our best understanding  
2 that that is a feasible test and it provides a better  
3 demonstration of the functional performance of these  
4 valves. So we have asked that the licensees evaluate it.

5 MR. SIESS: Chris, there are a couple of items  
6 here that we heard a lot about on Oyster Creek, and if  
7 they appear only in this list, I think we would like to  
8 have you say something about them. One is III.4.A and  
9 the other is IV.5.

10 MR. GRIMES: All right.

11 MR. SIESS: If they appear in later items,  
12 I'll defer, but if this is the only place they appear --  
13 what about III.4.A?

14 MR. GRIMES: III.4.A is the same issue that  
15 was raised on Oyster Creek.

16 MR. SIESS: But it wasn't in this category in  
17 Oyster Creek because you had a position --

18 MR. GRIMES: That's correct. The licensee  
19 disagreed in the Oyster Creek case. Eventually, the  
20 licensee did agree. Both Dresden and Millstone made the  
21 same argument that the separation and redundancy,  
22 especially with the diversity associated with  
23 Millstone-2, provided support to Millstone-1 and should  
24 be sufficient to conclude that no further protection  
25 from turbine missiles is required.

1           Based on the arguments that we heard at Oyster  
2 Creek and based on the arguments of Dresden and  
3 Millstone going back and looking at what would be  
4 entailed in such a further evaluation or such a  
5 demonstration, the licensees in both cases have orally  
6 agreed that they will provide a demonstration that they  
7 can safely shut down the plant with one protected train.

8           Oyster's recommended resolution resolved two  
9 of their issues. They're going to put in a portable  
10 pump, provide a tap to the torus so they have a  
11 protected path to resolve the tornado missile issue.  
12 They managed to kill two birds with one stone.

13           In the case of Dresden, there were certain  
14 aspects of the tornado missile protection that we  
15 concluded no further action was required, in looking at  
16 specific systems that were not protected from tornado  
17 missiles, and those are identified here.

18           MR. SIESS: So if Dresden boils down to the  
19 diesel generator intake exhaust as being all that has to  
20 be looked at --

21           MR. GRIMES: That's true.

22           MR. SIESS: -- everything else is protected.

23           MR. GRIMES: Generally everything else is  
24 protected.

25           MR. SIESS: Dade?

1 MR. MOELLER: Going back -- and I didn't want  
2 to interrupt, but going back on the turbine missile  
3 thing, --

4 MR. SIESS: Let's see if anybody has any  
5 questions about this.

6 (No response.)

7 MR. MOELLER: You mentioned Zudans's comments,  
8 but he also said -- and I did not hear your response --  
9 he asked the question can the main steam valves be  
10 subjected to this test without experiencing an  
11 undesirable transient.

12 MR. GRIMES: It's our understanding it can.  
13 The licensee did not initially agree with that. They  
14 were not sure if they could do it. That's why it ended  
15 up in a further evaluation section. We asked the  
16 licensees specifically in the case of Millstone to  
17 evaluate it.

18 MR. BAIN: If I could add a little bit to  
19 that, apparently, there is a misinterpretation between  
20 the types of valves. We presently do take the main  
21 steam stop valves fully closed once a week. We have to  
22 come down in power to 90 percent to do that. It's the  
23 control valves that give us a problem.

24 The problem is when you start closing them,  
25 the bypass valves start opening, and you essentially

1 have to take a very severe power reduction if not down  
2 to zero to fully close the control valves. You  
3 essentially just keep dumping the steam to the condenser  
4 everytime you close the valves.

5 MR. SIESS: So what's the resolution?  
6 Obviously, the staff does not want to require something  
7 that produces a severe transient.

8 MR. GRIMES: That's correct.

9 MR. SIESS: And yet, you do want these valves  
10 tested to assure against 180 percent overspeed of the  
11 turbine.

12 MR. GRIMES: That's correct.

13 MR. SIESS: So if they cannot be tested  
14 without causing a severe transient, what is the solution?

15 MR. GRIMES: We have asked the licensees to  
16 demonstrate why their testing program is sufficient in  
17 view of the difference that has been proposed, which is  
18 full valve failure. And we accept whatever program they  
19 feel is sufficient.

20 MR. SIESS: Suppose it comes out that they  
21 cannot satisfy you that they can prove reliably that  
22 they can get to overspeed with some low probability?  
23 What is the possible fix, or have you looked that far  
24 ahead yet?

25 MR. GRIMES: We haven't looked that far

1 ahead. We feel, based on the generic discussions that  
2 have been going on with GE on the turbine missile issue,  
3 along with the discussions we have had with the  
4 licensees, that we will be able to work out an  
5 acceptance inspection program to insure sufficient  
6 overspeed protection.

7 MR. SIESS: Are these plants different in any  
8 significant way from any other boiling water reactor, in  
9 terms of protecting the turbine against overspeed?

10 MR. GRIMES: I would like the licensee to  
11 respond to that.

12 MR. SIESS: Commonwealth ought to know,  
13 because they have got a couple of other BWRs around.

14 MR. BAIN: I don't believe that the overspeed  
15 protection system itself is that dramatically  
16 different. However, the whole control system where it  
17 controls the turbine is very much different than what  
18 you would see on a newer plant.

19 We have an almost entirely mechanical system.  
20 The control valves are all mechanically connected to the  
21 bypass valves, so that means as soon as you close the  
22 control valve you start opening the bypass valves. The  
23 big difference just lies in the whole turbine control  
24 system. Mike Bain.

25 MR. EBERSOLE: In view of the latest approach



1 to this 180 percent problem, is the staff now going to  
2 look in detail at the electro-hydraulic and other systems  
3 that have been formally out of bounds, in their view,  
4 regarded as control systems so to speak and not really  
5 safety systems?

6 MR. RUSSELL: The SEP has not been just to  
7 look at one system; it's to look at all systems that  
8 would cause the function.

9 MR. EBERSOLE: There's a point here --

10 MR. RUSSELL: We'll come back and speak to the  
11 180 percent overspeed.

12 MR. EBERSOLE: There's a quick case in point.  
13 Is the electro-hydraulic control system. Does it  
14 require direct current to execute its trip function?

15 MR. BAIN: I don't think we can answer for the  
16 electro-hydraulic control system because that's not the  
17 system we have.

18 MR. EBERSOLE: Whatever system you have.

19 MR. BAIN: The system we have does require  
20 direct power.

21 MR. EBERSOLE: Where is that drive? Is it not  
22 from the non-safety battery; just a station battery?

23 MR. BAIN: From the station batteries.

24 MR. EBERSOLE: Therefore, it's not seismically  
25 competent, to begin with.

1 MR. BAIN: Yes, they are.

2 MR. EBERSOLE: The turbines are seismically  
3 competent? They come from the 1E batteries?

4 MR. BAIN: Yes.

5 MR. EBERSOLE: I see, thank you.

6 MR. GRIMES: Before I leave this slide, I'd  
7 also like to make a comment on topic III.5.A with regard  
8 to pipe whip effects. Dr. Zudans made a comment about  
9 the unreasonableness of the assumptions made by the  
10 licensee, and that is part of the reason for its further  
11 evaluation.

12 (Slide.)

13 The next slide is a continuation of the list  
14 for further evaluation, and I will discuss the topic  
15 V.5, thermal overload setpoints and bypass. I might  
16 also note it is an issue identical to Oyster Creek.

17 Topic V.5, the resolution we described on  
18 Oyster Creek is the same resolution we are pursuing on  
19 Dresden and Millstone.

20 MR. SIESS: That is a reliable --

21 MR. GRIMES: That's a reliable leak detection  
22 system that is predicated on pipe breaks inside  
23 containment. The III.5.A evaluation was recently  
24 submitted for Dresden, and whether or not we can take  
25 that evaluation and deduce the proper sensitivity for

1 the system is something that we are getting to right  
2 now. We believe it can be readily resolved. Both  
3 licensees have orally agreed to evaluate leakage  
4 detection in the context of the III.5.A evaluation.

5 MR. SIESS: Chris, would it be a correct  
6 characterization of your position here that you are  
7 applying performance criteria rather than prescriptive  
8 criteria?

9 MR. GRIMES: Yes, sir.

10 MR. SIESS: And you would expect them to tell  
11 you how they meet the performance you're asking for and  
12 you will evaluate that response?

13 MR. GRIMES: Yes, sir.

14 MR. MOELLER: And again here, the question  
15 raised by Zudans is just part of the general idea.

16 MR. GRIMES: When we issued the draft report  
17 we said SSE qualifications should be one GPM in an hour,  
18 which was a target provided by Reg Guide 1.45. We  
19 concluded that trying to take such a system all the way  
20 up to Reg Guide 1.45 is not a fruitful exercise. These  
21 are the desired goals that we are really seeking, so we  
22 will pursue these goals.

23 I believe comments made by all the consultants  
24 with regard to this topic are resolved by that approach.

25 MR. SIESS: Thank you. Chris?

1 MR. GRIMES: Going back to the common issues  
2 for further evaluation, are there any other issues you  
3 would like to discuss specifically?

4 MR. SIESS: I had pointed out the ones we  
5 explored in some detail on Oyster Creek. Are there any  
6 others in that category on here? I didn't recognize  
7 them.

8 MR. GRIMES: I don't see any that -- of  
9 course, I've got the Oyster Creek agreements fresh in my  
10 mind, and I've managed to get the disagreements out and  
11 I don't recall -- .

12 MR. SIESS: A very healthy attitude. Okay,  
13 let's go on to --

14 MR. GRIMES: I would like to make a comment  
15 about VI.4, the leakage detection. That was an issue on  
16 Oyster Creek, that was a misunderstanding. The  
17 evaluation part of it will be to evaluate leakage  
18 detection capabilities that could be used to identify  
19 when to close the isolation valve. Coupled with that,  
20 procedures for the operator, to tell him what to look  
21 for in terms of the capability that is provided to know  
22 when to isolate the valves in those systems.

23 MR. SIESS: VI.4, -- what is the general title?

24 MR. GRIMES: It's the remote manual isolation  
25 capability. In the IPSARs it's identified as remote

1 valves. It's a containment isolation issue.

2 MR. SIESS: Just containment isolation. Okay.

3 MR. GRIMES: I would also like to note that  
4 Dr. Bush agreed with the staff's approach to resolving  
5 topic VI.5, the leakage detection capability, and  
6 disagreed with the PRA's conclusion that it was not  
7 significant. That's the same basis we used to pursue  
8 the issue.

9 Now for the Dresden-specific evaluation. For  
10 the Dresden-unique evaluation issues, as I noted before,  
11 the common issue of providing protection from tornado  
12 missiles applies to Dresden, but there is a subset issue  
13 of the effects of tornado missiles on service water  
14 systems and the diesel generator and intake exhaust.  
15 That will probably be folded into the bigger issue and  
16 resolved there.

17 I also noted before the recirculation pump and  
18 supports seismic capability is a subset of the further  
19 evaluation of seismic-related issues.

20 MR. EBERSOLE: I have a question. Since you  
21 have the isolation condensers, why does this get to be  
22 so important, since shutdown potential seems to be  
23 vested in them? Is it that the isolation condenser  
24 components including the water supply is not protected  
25 either? Don't you have an independent shutdown

1 capability in the isolation condenser which alleviates  
2 the --

3 MR. RUSSELL: The issue for the isolation  
4 condenser is your ability to make up to the isolation  
5 condenser so you can boil off. In this case, condensate  
6 transfer pumps and pumps associated with providing the  
7 fluid up to the isolation condenser were all exposed.  
8 They proposed going to a portable pump which would be  
9 inside the reactor building, which would be protected  
10 such that they would have that make-up capability. It  
11 was the pump, not necessarily the water supply.

12 MR. EBERSOLE: You also used diesel pump  
13 supply.

14 MR. RUSSELL: That's correct, but the diesel  
15 was a fire pump and it was outside and it was exposed.

16 MR. EBERSOLE: It was exposed, too?

17 MR. RUSSELL: Correct. There were no  
18 protective pumps to provide water.

19 MR. GRIMES: If there aren't any other  
20 questions on the Dresden-uniques, I'll go on to the  
21 Millstone uniques. An interesting phenomenon occurred  
22 when I put this list together, it was obvious by the way  
23 the categories worked out that you can see that  
24 Millstone has an engineering analysis and Dresden fixes  
25 by procedure. I don't know whether that was just



1 coincidence or that's the way the long list ended up.

2           A significant point here is a point that I had  
3 previously made about the II.4.F resolves topic IX.3.  
4 On topic II.3 on PNP\*, roof loads, for both Dresden and  
5 Millstone.

6           MR. SIESS: I mentioned it.

7           MR. GRIMES: Are there any questions on the  
8 Millstone --

9           MR. MOELLER: A comment on the last item.

10          MR. GRIMES: The jet expansion model? That  
11 was an issue relating to -- let me get the slide.

12                   (Slide.)

13          The staff's review of the jet impingement  
14 models used for Millstone concluded that the approach  
15 that Millstone used in its evaluation may be  
16 non-conservative. There were specific issues related to  
17 jet theory. The licensee agreed to go back and address  
18 each of the specific issues regarding the methods by  
19 which the model was applied.

20          The staff concluded that that would acceptably  
21 resolve that issue.

22          MR. SIESS: What is the issue? The forces  
23 exerted by the jet, or the angle of the jet, what area  
24 it covers, or both?

25          MR. GRIMES: A little bit of both. It was a

1 lot of how to take jet theory and apply it to pipes and  
2 components. It is not all that exciting, but there were  
3 a lot of little holes that looked like they could be  
4 easily filled.

5 MR. SIESS: You know, it seems to me that the  
6 two most serious problems the SEP staff had was first,  
7 making considered judgments and the other was just  
8 bookkeeping.

9 MR. GRIMES: Bookkeeping has been a  
10 substantial job in preparing for this meeting.

11 MR. SIESS: Do you have this on the computer?

12 MR. GRIMES: No, sir, I should have. We do  
13 have all of the topic SERs on the computer, though.  
14 Those are easily traced.

15 Part of the problem with these issues is the  
16 categorization. Which category does it fall in  
17 sometimes changes from day to day. Are there any other  
18 questions about the Millstone-1 specific evaluation  
19 issues?

20 MR. MOELLER: If you would comment on the  
21 first one on the next page, V.12.A.

22 MR. GRIMES: The issue there was with regard  
23 to reviewing the capacity of the reactor water cleanup  
24 and condensate demineralizers with regard to limiting  
25 conditions for operation in the tech spec. That's why

1 it's identified as a T.S., tech spec, issue.

2           The licensee has agreed to go back and  
3 evaluate this minimum reserve capacity requirements and  
4 evaluate that in the context of the tech spec limits,  
5 and to propose a tech spec change or justify not having  
6 to make a tech spec change.

7           We concluded that that would adequately  
8 resolve this issue.

9

10

11

12

13

14

15.

16

17

18

19

20

21

22

23

24

25

1 MR. SIESS: That is the end of the category.  
2 Those are things that presumably will be looked at at  
3 the full-term operating license review.

4 MR. GRIMES: Now I will go into those issues  
5 with procedural or technical specification changes.

6 (Slide.)

7 As I get into both procedures and hardware,  
8 especially with regard to the procedural aspects, there  
9 are two issues that will be discussed under the  
10 "Licensee disagrees" list. So if you do not see them,  
11 we will get to them.

12 MR. SIESS: These are only the ones where  
13 there is no disagreement?

14 MR. GRIMES: That's correct.

15 MR. SIESS: The disagreements are lumped  
16 together at the end of this thing.

17 MR. GRIMES: First with regard to those issues  
18 that are common for both Dresden and Millstone, I  
19 pointed out before the remote manual isolation with  
20 regard to containment isolation has two parts to it, the  
21 evaluation leakage detection capability and procedures  
22 to provide for remote manual operation. So it's listed  
23 here again.

24 The battery out of service time issue is one  
25 with regard to the technical specification limits on

1 having batteries out of service or inoperable. It was  
2 an issue that evolved out of the topic reviews out of  
3 Dresden and out of the PRA on Millstone. Both of them  
4 came together and we concluded that this was one where  
5 the Licensee should look at his tech spec limit,  
6 evaluate the actual time that he needs to have the  
7 battery out of service, and propose a limit for battery  
8 out of service time that is a little more reasonable.

9 MR. SIESS: Like two hours instead of seven  
10 days?

11 MR. GRIMES: Like hours instead of days. I  
12 really don't think we need to have two hours, but we  
13 certainly need to have something on that order of  
14 magnitude.

15 MR. EBERSOLE: Chris, when you look at the  
16 battery out of service time, do you also look in a  
17 matrix sense that all other safety functions which are  
18 serviced by the other battery had better not be in  
19 maintenance when that battery is out of maintenance?

20 MR. GRIMES: That's a bigger issue than just  
21 this issue. We tried to consider it in the context of  
22 the corrective actions that we have dealt with, but we  
23 have not got our arms around the bigger picture.

24 MR. RUSSELL: I must comment on that. The  
25 interpretation of operability for other comments

1 includes the support systems necessary for the  
2 operability of that component. So in this instance we  
3 would say when a system that relies on the battery goes  
4 out of service, then that system has its own limiting  
5 condition for operation and allowable outage time. The  
6 battery also being out of service, it has its own limit,  
7 and whichever one is more restrictive would govern the  
8 battery because possibly of other systems in service.

9           The question you're asking, if this battery A  
10 is out of service, if something on train B which is  
11 needed is also out of service, whether that is looked  
12 at.

13           MR. EBERSOLE: Yes.

14           MR. RUSSELL: That is the generic issue that  
15 Chris has referred to. To the best of my knowledge, we  
16 don't specify interdependencies across trains. We look  
17 at the system and what's needed to support that  
18 particular system, but not multiple things being out at  
19 one time.

20           MR. EBERSOLE: This results in the fact that  
21 you can be totally incompetent and never know it. And I  
22 wonder when we are going to go back some 10 or 12 years  
23 and fix up what should have been done in the matrix  
24 system that far back and stop this nonsense.

25           MR. RUSSELL: Clearly it is an issue when you



1 walk in and see a lot of red tags hanging on because  
2 there are components out of service, and the cumulative  
3 effect of all those components out of service at one  
4 time is to the best of my knowledge --

5 MR. SIESS: Let me get that clear. Suppose  
6 I've got a component that is in train A and train B, and  
7 the component in train A is out of service because it  
8 depends on the battery in train A and the battery is out  
9 of service. Do you mean I could go in and take that  
10 component out of service for maintenance?

11 MR. RUSSELL: No, not if they're the same  
12 component. For instance, if you're talking about the  
13 service water pump in train A and the service water pump  
14 in train B and you've got a diesel out of service,  
15 obviously you have to have service water and you've got  
16 to have the support systems for service water. Those  
17 are the same systems.

18 But if it's service water is in one system and  
19 that's in another system, and the PRA states it could  
20 serve as the function water, let's say condensate  
21 transfer for makeup, that is not looked at. But clearly  
22 the system function, you cannot have both trains of a  
23 system out, whether it's a pump or it's a supporting  
24 system to it.

25 So I don't know whether I've confused it or

1 not.

2 MR. SIESS: I understand.

3 MR. EBERSOLE: The tech specs as presently  
4 handled do not embody system analysis to determine the  
5 true degradation of functions. They look in a  
6 compartmentalized sense.

7 MR. RUSSELL: That's correct. They look at  
8 the system function and not train function.

9 MR. EBERSOLE: They look at component and  
10 equipment function. They don't even look at components  
11 sometimes.

12 MR. RUSSELL: They require the system --

13 MR. EBERSOLE: I can have a relay beam  
14 maintained and I'll be dead in the water and never know  
15 it with the present system, because there is no system  
16 that's cross-relating these disabilities.

17 MR. RUSSELL: That activity puts the system  
18 out of service. Then you would fall into the tech spec  
19 requirement of having to maintain the system in  
20 service. The issue I was trying to describe is where  
21 you have one train, say, of system one and another tran  
22 of system two; in a PRA or a heat removal function those  
23 may be related, and you may have redundancy of function  
24 but not redundancy of system. And that is not looked  
25 at.

1 MR. SIESS: I think he disagreed with you,  
2 Jesse.

3 MR. WARD: Could I ask a question, Bill?  
4 Although this sort of thing apparently is not covered  
5 completely in the tech specs, to what extent might it be  
6 covered in individual Licensee's plant procedures? Do  
7 you have any idea at all?

8 MR. RUSSELL: I can only give those examples  
9 where I have been involved. In some cases the licensees  
10 are extremely cautious or conservative with respect to  
11 taking things out of service and what the effect is.  
12 The one that easily comes to mind was Shipping Port,  
13 where you had -- involved in that was more the Navy  
14 philosophy. I can't speak in general, but I believe  
15 that that aspect was looked very carefully at in the  
16 maintenance programs and taking things out of service to  
17 make sure you're not coming into a limiting condition  
18 for operation, and that is in fact a function of the  
19 onsite review committees and some of the aspect of  
20 turnover, which systems do you have, which systems do  
21 you not have.

22 So I believe it's looked at very carefully by  
23 the licensee. But the earlier statement that we look at  
24 it on a system level or a component level for it being  
25 out of service, for instance, there's one action

1 specified if you have one diesel out of service, there's  
2 another action specified if you have another diesel out  
3 of service. Or if a diesel's out of service, you can't  
4 start the other one, you consider it out of service  
5 also.

6 MR. GRIMES: If there aren't any further  
7 questions, I'll go on to the Dresden specifics.

8 (Slide.)

9 Here I would like to specifically note that  
10 I'll discuss the primary coolant activity limits in the  
11 context that the Licensee disagrees on Millstone. Are  
12 there any questions about any of these issues?

13 (No response.)

14 Did you want to talk about paralleling the  
15 batteries?

16 MR. SIESS: I don't. Does anybody want to  
17 talk about paralleling the batteries?

18 MR. SHEWMON: Hurry on, please.

19 MR. GRIMES: The Millstone specific list.

20 (Slide.)

21 This was the coolant conductivity and chloride  
22 limits, was an issue on Oyster Creek that we resolved,  
23 and we've resolved it as well, I believe, on Millstone.  
24 The Licensee is currently evaluating the procedure that  
25 he uses in his present tech specs in relation to the

1 limits required by Reg Guide 1.56, and he will propose a  
2 corrective action.

3 MR. SHEWMON: What's the status of the  
4 in-service inspection on Millstone's plant? Do they  
5 have a ten-year commitment to inspect the piping in a  
6 meaningful way in the primary, and when does that come  
7 about?

8 MR. BAIN: Yes, we just completed our first  
9 ten-year ISI during the 1980 refueling outage. That was  
10 one of the points noted during the plant description,  
11 and the results of the ISI were partly responsible for  
12 the long duration of the outage.

13 MR. SHEWMON: I see. I apparently asked the  
14 wrong question about what experience you had, because  
15 that didn't come up. Thank you.

16 MR. GRIMES: Are there any other questions  
17 about the Millstone specific procedural or tech spec  
18 issues?

19 (No response.)

20 If not, I'll go on to the hardware backfits.

21 (Slide.)

22 These are the issues for which we concluded  
23 hardware modifications either have been proposed or are  
24 being considered. A point to make here is, as I  
25 mentioned earlier, I doublecounted the diesel or turbine

1 annunciators because that was a modification that was  
2 instituted prior to the integrated assessment and is  
3 complete. It may or may not have resulted from the  
4 integrated assessment review if they hadn't made that  
5 modification.

6           Another point to make is that on Millstone,  
7 with regard to the status indication alarms, they are  
8 currently evaluating a hardware modification and its  
9 impact on the reliability of the system and they are to  
10 come up with a proposed course of action, which may or  
11 may not involve additional indication and alarms.

12           MR. EBERSOLE: You're referring to 8.3?

13           MR. GRIMES: 8.3.B, yes, DC status indication  
14 and alarms.

15           MR. EBERSOLE: Does this mean we have at least  
16 got a status indication that gives us battery charge  
17 status?

18           MR. GRIMES: Yes, sir, we have battery charger  
19 status indication.

20           MR. EBERSOLE: No, I didn't say that. I said  
21 battery charge.

22           MR. RUSSELL: It does not indicate gravity.  
23 We have looked at the aspect of battery gravity on these  
24 plants. They do have pilot cells. They do weekly  
25 gravity tests. Either monthly or quarterly -- it varies



1 between plants -- they check all the cell gravities.  
2 They also have procedures for checking the other  
3 gravities.

4           What we're talking about now is supervision on  
5 the breakers to make sure that you have a continuous  
6 circuit between the charger and the battery, the battery  
7 is in fact connected, and looking at DC voltage on the  
8 output of the charger, the amperage on the output of the  
9 charger, DC bus voltage if you run the battery, for  
10 instance, if you had a failure of the charger breaker or  
11 the charger itself, and wide-range battery amperage.

12           Those are essentially the issues we're looking  
13 at. We found rather substantial differences from plant  
14 to plant as to what is available. For instance, on  
15 Millstone we concluded they had the capability to  
16 monitor essentially all, with the exception of battery  
17 amperage, based on the existing design. And at the  
18 other case which was an extreme, they only had DC  
19 voltage and because of limitation of space in their  
20 control room they went to a local panel with an alarming  
21 function that alerted the operator to look at the level  
22 panel.

23           MR. EBERSOLE: But in the long run, you're  
24 still back to specific gravity observation on the pilot  
25 cell?

1           MR. RUSSELL: That's correct. From the  
2 standpoint of detecting state of charge of the battery,  
3 you have to use pilot cell gravity.

4           MR. EBERSOLE: Like from 50 years back or  
5 100.

6           MR. SIESS: Tried and true.

7           MR. EBERSOLE: Tried and untrue.

8           Anything else on that list?

9           MR. RUSSELL: I might comment with respect to  
10 that. There's one additional thing we've identified in  
11 the SEP that is battery testing, in addition to  
12 gravities. We found that in half of the plants reviewed  
13 out of the ten plants we looked at, five of those ten  
14 were not adequately testing batteries, either by virtue  
15 of not performing a service discharge test or a test  
16 discharge to determine actual battery capacity.

17           In one case, upon testing they found that the  
18 battery did have cells which required replacement. That  
19 was at Ginna. At Dresden we concluded their testing was  
20 on a more frequent basis and the testing they are  
21 performing is comparable to the test discharge. So that  
22 we have looked at both aspects of DC systems.

23           MR. EBERSOLE: When they tested these, do you  
24 recall that they went along and laid their hands on  
25 something on the bus power connectors and determined

1 that they were getting adequate conductivity? Normally  
2 these things sit on triple charge. They can degrade  
3 over months and you never know it until you need them.

4 MR. RUSSELL: The issue of high resistance  
5 connection from the standpoint of supervision of the  
6 breakers is looked at. It depends on how they hook up  
7 the discharge box, if they're using a resistor bank or  
8 how they're actually performing the test discharge and  
9 where they hook up. In some cases they actually hook up  
10 to the battery terminals; in other cases they hook up to  
11 a convenient location on the DC bus to discharge.

12 So that varies from plant to plant. When we  
13 look at testing, we only look at the battery capacity  
14 and the individual cell voltages and whether the cells  
15 reverse or not.

16 MR. SHEWMON: Jess, we're scheduled to go to  
17 4:00 o'clock Saturday and I would love to make up a  
18 little time in this part and be able to have a quorum at  
19 3:00 on Saturday.

20 MR. EBERSOLE: Okay.

21 MR. GRIMES: If there are no further questions  
22 on the common hardware backfits, I'll go to the Dresden  
23 specifics. As I mentioned before, the installation of  
24 scuppers to relieve ponding on the roof is common to  
25 Dresden and Oyster. Millstone is evaluating it in their

1 integrated assessment.

2           Another interesting issue was on topic VI-4 on  
3 containment isolation. The Staff concluded that  
4 isolation valves on an ESF system should be leak-tested  
5 and they were excluded from leak-testing under Appendix  
6 J by definition. Licensee has agreed to perform tests  
7 on the valves in question.

8           Are there any questions on Dresden specifics?

9           (Slide.)

10           MR. GRIMES: If not, I'll go on to the  
11 Millstone specific. The high-low pressure interface  
12 issue between the reactor water cleanup system and the  
13 primary system; in the case of Oyster Creek and Dresden,  
14 it was an evaluation resolution on the relief capacity  
15 in the reactor water cleanup system.

16           Millstone has proposed to install an  
17 interlock.

18           (Slide.)

19           If there are not any questions about that  
20 issue, I'll go along to the "Licensee Disagrees" list.  
21 Both of those issues relate to technical specification  
22 requirements. I will discuss the reactor trip  
23 surveillance first, topic 10.A. The Staff's review  
24 concluded that the sliding scale surveillance  
25 requirement, if you will, in the tech specs for

1 Millstone, which allowed them on the basis of a  
2 reliability goal based on exposure time to go from a  
3 monthly surveillance to a quarterly surveillance, did  
4 not conform with current practice or the current tech  
5 specs.

6           When we addressed this issue to the  
7 Subcommittee we identified the issue, indicated it was  
8 under further evaluation. We have since gone back and  
9 determined that it applies equally to at least all of  
10 the three SEP boilers and maybe even a larger fraction  
11 of the operating BWR plants.

12           We indicated at the Subcommittee meeting that  
13 we do not really have a philosophical disagreement. We  
14 agree with the concept of a reliability-based  
15 surveillance interval, but there were some problems with  
16 its application. Because of the relaxation of the  
17 frequency, which is quite some time in the future, if  
18 ever, because the application of this change in  
19 frequency would require a certain exposure time without  
20 any failures and because it was only a concern related  
21 to how this is applied, as opposed to the concept that  
22 it was being proposed, the Staff is going to withdraw  
23 its recommendation and allow the procedure, if you will,  
24 to continue.

25           Part of the Staff's basis for accepting it in

1 the first place, even though it wasn't an explicit  
2 acceptance nor was it an explicit rejection on the newer  
3 plants, was the fact that this was an approach which was  
4 desirable and we should go out and gather data and  
5 experience to be used to develop reliability-based  
6 surveillance frequencies.

7           The data that has been compiled to date  
8 supports the one-month interval that currently is  
9 required for all plants, PWR's and BWR's, for all plant  
10 protection systems. On the basis that the Licensee  
11 would have to amend his procedures to change the  
12 surveillance frequency and that that is something which  
13 could be reviewed in the context of a 50.59 change, we  
14 have concluded that we will allow the Licensee to  
15 continue with his current technical specification  
16 limits. Therefore, this issue should no longer be an  
17 issue of disagreement.

18           Are there any questions?

19           MR. SIESS: The Licensee can't change his  
20 frequency without getting NRC approval?

21           MR. GRIMES: No, sir. He can make a change,  
22 but the change would involve procedures, a change of  
23 procedures for performing tests. Currently it's one  
24 month intervals and the tech specs allow him to go to a  
25 quarterly test once he's reached his exposure time. He



1 would have to in some fashion document his conclusion  
2 that he's met his criteria in order to go to the test.

3           A 50.59 change would be filed in his annual  
4 summary and it could be picked up at that time in terms  
5 of his Staff review, the basis for his conclusion, and  
6 the issues associated with the problems of  
7 applicability. Some of the problems we noted is, this  
8 is kind of a one-sided criteria. It says you go from  
9 one to three months. If you apply the data strictly,  
10 you could go from one month back to eight hours.

11           Another issue related in its application is,  
12 you compare data from like components. Does that mean  
13 all pressure sensors, does that mean all Berdone tubes,  
14 does it mean all relays, or just relays manufactured by  
15 a specific manufacturer with one model number?

16           Those are some of the problems that have led  
17 the Staff to conclude that the approach isn't acceptable  
18 for new plants. We do not believe that those issues  
19 warrant the burden of revising the technical  
20 specifications until such time as he can compile the  
21 experience for the application of this proposal.

22           MR. SIESS: So the Staff, and that means not  
23 just the SEP Staff, thinks this reliability-based  
24 frequency is a good idea, but it ought to be made a  
25 little more sophisticated after they get enough data.

1 MR. GRIMES: That's correct.

2 MR. SIESS: So he essentially meets current  
3 criteria as they are being developed.

4 MR. GRIMES: If a proposal were made on a new  
5 plant today using the same approach, it would be  
6 rejected for lack of experience, for lack of a  
7 demonstration that it could be applied properly.

8 MR. RUSSELL: I might add two points. One,  
9 Chris, if you could pass out -- it came up at the  
10 Subcommittee -- the paper by Jacobs which establishes  
11 the criteria. This was something that was requested.  
12 Also --

13 MR. SHEWMON: It's in a box on the other side  
14 of the table.

15 MR. RUSSELL: The other comment is, in this  
16 instance in looking at it the Staff concerns about  
17 application appear to be based upon concerns without  
18 experience that they are real. That is, the level of  
19 detail to which you provide like components, what is a  
20 failure, what is an unsafe failure, what is instrument  
21 drift -- all those issues were issues which were not  
22 answered well.

23 And while we don't have specific experience to  
24 say it's going to be misapplied, we don't have the  
25 experience that says it's going to be applied properly,

1 either. In this instance I think the Staff assumes the  
2 burden of demonstrating what is there should not be  
3 there, as compared to -- it's like a change, and in this  
4 case we don't have specific facts that show that this is  
5 wrong or this is something which is unsafe.

6 It is a difference from current practice,  
7 however. In this case I think it should remain, rather  
8 than be deleted from the technical specifications.

9 MR. SIESS: That is, you have an option. You  
10 could arbitrarily refer to current practice, and you're  
11 not sure it's any better than what he's doing. And if  
12 you had the burden of telling him what he ought to do,  
13 you don't know.

14 MR. RUSSELL: That's correct.

15 MR. SIESS: And as I recall, the Licensee said  
16 that he had never reached the limit where he could go to  
17 the quarterly level. He is still testing monthly and is  
18 likely to stay there for quite a while.

19 MR. GRIMES: It appears from a recent LER he  
20 may have had to restart his clock.

21 MR. CASIG: We had to stay at the same  
22 restart, but that's correct.

23 MR. SIESS: So whether or not you did anything  
24 here is not going to change how the plant is operated  
25 for the next few years.

1 MR. GRIMES: That's correct.

2 MR. SIESS: Maybe the next ten, I don't know.

3 MR. GRIMES: Another point I would like to  
4 make with regard to this issue is that in the Jacobs  
5 paper which you've just been provided copies of, one  
6 feature which was not considered in his reliability  
7 aspect was the point brought up by Dr. Lipinski. The  
8 increased surveillance affecting potential failures in  
9 the system is not part of his reliability evaluation.  
10 Therefore, it is not appropriate to apply it downward to  
11 an increased frequency.

12 MR. SIESS: Lipinski made the point that  
13 operating experience shows there are mistakes made doing  
14 testing and so forth and have a significant contribution  
15 to risk, and that there had to be some kind of a  
16 tradeoff between too frequent testing, too frequent  
17 maintenance, and opportunities for mistakes, and  
18 reliability on demand. And nobody really approached  
19 this thing, and that is a generic issue that I think we  
20 ought to pass on to Mr. Ray's Subcommittee and then  
21 follow it up sometime.

22 MR. GRIMES: Oh, it's on the Licensee  
23 disagreement list because as of 5:00 o'clock yesterday  
24 afternoon we still had not issued a formal position. We  
25 were going to take it off of the Licensee disagreements

1 list and indicate that this is an issue for which no  
2 further action is required, and document in the final  
3 report the basis.

4           The other issue of disagreement which was  
5 raised regards primary coolant activity limits. This  
6 was discussed extensively before the Oyster Creek  
7 Subcommittee. It's an issue that we have come to a  
8 resolution with Dresden. They have agreed to adopt the  
9 limits for equilibrium iodine and maximum iodine dose  
10 equivalent, and they will propose a sampling program to  
11 go along with that.

12           I apologize to the Millstone representatives  
13 if I stole their thunder on the previous issue, and I'll  
14 allow them to get back at me here.

15           (Slide.)

16           The issue in summary is the calculated offsite  
17 doses for a small line break, and in accordance with the  
18 standard review plan they exceed current criteria by a  
19 small fraction. For Millstone, they exceed Part 100, a  
20 little less for Oyster Creek.

21           The PRA concluded that the risk from this  
22 break was negligible. The PRA found that all LOCA's  
23 were negligible. The Staff felt that the limit on  
24 primary coolant activity that the Licensee did have  
25 really didn't do anything, it really should have a

1 better basis, but that that basis need not be a  
2 plant-specific evaluation, as the Licensee proposes, but  
3 simply adopting the item limits in the standard tech  
4 specs and developing a plant-specific action to go along  
5 with those would be sufficient.

6           There are conservatisms in the analysis, and  
7 if you sharpen your pencil and quantify the  
8 conservatisms you can demonstrate much smaller doses.  
9 The issue is one of how much pencil-sharpening do you  
10 do, how much negotiation goes on in terms of what those  
11 conservatisms mean, and how they should be quantified.

12           That was an issue we thought was just not  
13 worth pursuing. So we have proposed and two out of the  
14 three plants have accepted the limits. And now I will  
15 allow Millstone to provide their counterproposal.

16           MR. BAIN: I would just like to add a couple  
17 of comments here. I would like to qualify the term  
18 "Licensee Disagrees." The reason it is "Licensee  
19 Disagrees" right now is not that we disagree with the  
20 revised tech spec iodine concentration; it's just that  
21 we have not yet agreed on what the appropriate value for  
22 that would be.

23           Just a matter of a couple of weeks ago, we  
24 received the NRC's SER for the failure of small line  
25 analyses. It's presently under review now. We think



1 just from an initial look at it that there are a number  
2 of areas where we could make improvements on it.

3           For example, as you will see on the sheet  
4 being handed around now, we are presently looking at the  
5 break flow that was assumed. We would like to verify  
6 that that's accurate. We are going to evaluate the  
7 effect of the break on pressurization of the reactor  
8 building and consequently losing the effectiveness of  
9 the standby gas treatment system, which in itself will  
10 give you quite a substantial dose reduction.

11           One of those things we are looking at is the  
12 fact that the Staff assumed a four-hour cooldown  
13 following break. We would like to take a harder look at  
14 that with respect to our new emergency procedures  
15 guidelines. We would like to know what exactly is the  
16 operator action we would expect under those  
17 circumstances.

18           We may be in the situation where the  
19 recognizes that he has an unisolable break and he may  
20 elect to do alternative methods. Until we have a good  
21 handle on exactly what we think the operator would do,  
22 we are unable to determine what the realistic dose would  
23 be.

24           MR. SIESS: Now, if you're going to go at this  
25 with what Chris called a sharpened pencil, I guess, are

1 you going to propose iodine limits such that when you  
2 analyze it you take into account more realistic  
3 assumptions and you will meet the 30 rem?

4 MR. BAIN: Well, in our first attempt at  
5 reaching agreement on this we are going to use the 10  
6 percent guideline of Part 100 or 30 rem.

7 MR. SIESS: Okay. And if you cannot make the  
8 30 rem, you would like to try to argue that something  
9 else is acceptable?

10 MR. BAIN: Yes. I guess the philosophy behind  
11 the ten percent guideline is it is applied on an event  
12 that is not as unlikely as say the double-ended LOCA. I  
13 think our position is, if you're postulating the failure  
14 of an instrument line within say a six or eight-inch  
15 section, that in itself is so unlikely we think it's  
16 inappropriate to apply the ten percent guideline. But  
17 as the first cut, we will try to meet the 30 rem dose  
18 guideline.

19 MR. SIESS: It seems to me there are two  
20 approaches here. The Staff is saying, take the tech  
21 spec iodine limits and let the doses fall where they  
22 may, we will just assume there are conservatisms and we  
23 won't worry whether it's 30 or 300 or something of that  
24 order.

25 The other approach is to make a realistic

1 analysis up to a point, I suspect that it's not  
2 realistic after it gets outside of the building. I  
3 don't know how many assumptions you want to correct  
4 there. But to make a realistic analysis and say, I can  
5 meet the current criteria, which is a small fraction of  
6 the Part 100 dose, which the standard review plan says a  
7 small fraction and that is 10 percent or 30 rem.

8 I suppose I can see the two approaches. I  
9 don't think I can see anything in between them. One is  
10 a purely judgmental, sort of arbitrary, and the other  
11 one is an analysis. But I have the feeling when you  
12 make the analysis then you ought to come out with the  
13 answer that --

14 MR. GRIMES: It's quite conceivable that the  
15 analysis can be just as arbitrary.

16 MR. SIESS: Don't say that, Chris.

17 MR. GRIMES: The problem that we have with the  
18 concept is, one, that the assumptions that the Licensee  
19 intends to look at more carefully are the assumptions  
20 required for new plants today. They are assumptions  
21 which correspond with the acceptance criteria that is  
22 being used.

23 When we start backing off from those, we end  
24 up arguing specifics, and we felt that effort was not  
25 worth pursuing.

1 MR. SIESS: You're carrying my two cases a lot  
2 farther. You're saying you need to be completely  
3 arbitrary, which is what your proposal is, or you just  
4 --

5 MR. GRIMES: Individually arbitrary.

6 MR. SIESS: Selectively arbitrary.

7 MR. EBERSOLE: May I ask a question?

8 MR. SIESS: Yes.

9 MR. EBERSOLE: While you're analyzing the  
10 steam environment for dose effects out in the auxiliary  
11 building, I believe it is fair to say that you obtain a  
12 general purpose box.

13 MR. BAIN: No, that's not correct. It's as a  
14 result of our environmental equipment. We can close in  
15 all of our equipment.

16 MR. EBERSOLE: Was that done recently?

17 MR. BAIN: It's been done over the last couple  
18 of years.

19 MR. EBERSOLE: So now what sort of -- these  
20 are currently being called mild environments in our  
21 environmental qualification program. What do you call  
22 your environment?

23 MR. CASIG: That's essentially what we did  
24 with these enclosures. We effectively put this  
25 equipment in a mild environment by providing its own

1 unique ventilation system in an airtight steel seismic  
2 enclosure.

3 MR. EBERSOLE: You made it a mild environment,  
4 haven't found out it wasn't that way.

5 MR. CASIG: Yes, sir. That was our  
6 alternative to replacing the equipment. So that is to  
7 my knowledge a one of a kind feature which to some  
8 degree influences our approach here.

9 MR. EBERSOLE: Did you do that around the  
10 switches?

11 MR. CASIG: Motor controls, instrument  
12 switches.

13 MR. EBERSOLE: Boxed it up? Well, that's very  
14 interesting, isn't it, Jerry.

15 Thank you.

16 MR. SIESS: Does that conclude your  
17 presentation?

18 MR. BAIN: Yes, it does.

19 MR. SIESS: Any other questions to the  
20 Licensee or Mr. Grimes on the single area of  
21 disagreement?

22 MR. GRIMES: Are there any other questions? I  
23 didn't --

24 MR. RUSSELL: There are two aspects that you  
25 should probably be highlighting. One is, we reviewed

1 the last few years worth of data from Millstone with  
2 respect to what kind of activities they have actually  
3 been experiencing. Those activity levels are less than,  
4 by a reasonable margin, the current limitations which  
5 would be imposed based upon the standard tech spec  
6 iodine limits. That is, the .2 microcuries per gram and  
7 4 microcuries per gram peak.

8           The second point is that activity in the  
9 coolant is indicative of degraded performance of the  
10 fuel. That is the only place you can get this kind of  
11 iodine activity. While current criteria backs into an  
12 activity limit from the standpoint of a conservative  
13 calculation, not unlike the Appendix K ECCS evaluations  
14 where you have conservatism, it is a deterministic  
15 cookbook by which the Staff determines what is  
16 acceptable.

17           The position we've taken is, we have argued  
18 that the current limits are sufficient, that is, we need  
19 not go below that, which if we followed the current  
20 deterministic approach, since we are calculating greater  
21 than Part 100, and the current criteria is a fraction of  
22 that, we've already relaxed by a factor of ten by  
23 considering that the standard technical specification  
24 limits are sufficient.

25           Based upon looking at past performance, we



1 feel that would not create an operational restriction  
2 upon the facility, and if they were to reach those  
3 limits it would be indicative of some type of fuel  
4 failure which would have longer term effects from the  
5 standpoint of doses, for maintenance activity in the  
6 coolant system, as well as the consequence for an  
7 accident which released the activity contained in the  
8 coolant system.

9           Those are some of the issues which are side  
10 issues which are related to this level, and we feel that  
11 there should be some limit, realistic limit on reactor  
12 coolant activity. The present limit we do not feel is  
13 realistic. It is quite high and it would reach an  
14 offgas limit first.

15           It does need to be looked at, and we feel in  
16 this instance the limit associated with the standard  
17 technical specifications which are being used on the new  
18 plants today is appropriate.

19           MR. SIESS: Okay. The last item we have on  
20 the agenda is to give the two Licensees an opportunity  
21 to give us their opinions on the value, problems, et  
22 cetera, with the SEP integrated assessment. I will call  
23 on Commonwealth Edison first.

24           MR. SMITH: My name is Neal Smith from  
25 Commonwealth Edison.

1 I will go through the slides rather rapidly  
2 because most of the items have already been covered  
3 today. As was pointed out, the original scope of the  
4 SEP was to be a three-year review of 11 plants.

5 I think one of the major things we have  
6 learned from this review, which was supposed to have  
7 been done by the NRC Staff totally and we were just  
8 supposed to go along for the ride and enjoy it, was that  
9 the Staff needs a great deal of assistance from the  
10 Licensee in order to perform these reviews. It is not  
11 and cannot be a straight Staff-alone type review and  
12 update of our information.

13 (Slide.)

14 Dresden's present status, since we always like  
15 to go through bookkeeping, is we're basically in  
16 agreement with the Staff on all the topics. There are  
17 some open topics, but we think we know where we're  
18 going.

19 At this point in time Commonwealth Edison has  
20 made four modifications from the SEP already. We have  
21 committed to six additional modifications and five  
22 procedure changes.

23 (Slide.)

24 To be specific, the modifications we have  
25 made, we have gone through and tied down all our

1 electrical equipment at all four plants. That we also  
2 did up at Zion.

3           We changed our procedures and control panels  
4 for the normal bypass run mode in the plant. We've  
5 added 125-volt disconnect buses and we've split the  
6 buses apart a little bit. Additional separation will be  
7 provided once the new buses arrive, and we will get them  
8 in completely separate fire zones.

9           The modifications we've committed to: We are  
10 going to upgrade the battery racks at Dresden 2.  
11 They've already been upgraded at Dresden 3 and Quad  
12 Cities. Dresden 2 has yet to be completed. Diesel  
13 generator protective trip bypasses are in the process of  
14 being put in. We will install roof parapets, scuppers.  
15 Additional DC monitoring in the control room will be  
16 installed in the process computers.

17           Installation of redundant isolation valves,  
18 which is something that Chris talked about earlier.  
19 Installation of an additional set of breakers. When we  
20 were reviewing the DC system, we wanted to make them  
21 more reliable by putting in additional breakers.

22           The procedures that we've committed to include  
23 revised flood procedures. We're going to modify our  
24 safe shutdown procedures. We've committed to system  
25 interlock shutdown cooling. We are including additional

1 valves in our locked-closed list, and we've modified our  
2 in-service inspection of water control structures.

3 (Slide.)

4 We've done a number of major analyses and so  
5 has the Staff as a result of the SEP, and that's just a  
6 listing of the various ones we've done and the Staff.  
7 Unique with Dresden 2 was the SSRP, senior seismic  
8 review plan. As a result, the Staff has done a major  
9 portion, or their consultants have done a major portion,  
10 of the seismic reanalysis at Dresden 2, which has been  
11 borne by the utilities at most of the other units.  
12 There has been a great deal of interaction on that  
13 particular subject.

14 (Slide.)

15 Our experience to date is, we have spent  
16 approximately \$2.6 million for studies and modifications  
17 which have been made to Dresden 2, and Dresden 3 and  
18 Quad Cities 1 have cost us approximately \$1.3 million so  
19 far and that is for all four units. We project that our  
20 studies, when we get the final bill, will reach  
21 somewhere in the neighborhood of \$3.6 million and that  
22 we will have spent Commonwealth Edison engineering  
23 man-years of about 10-1/2 man-years on the project.

24 MR. SHEWMON: Is that separate than the \$3  
25 million you're talking about? That's out of the

1 company?

2 MR. SMITH: That's out of the company money.

3 MR. MOELLER: I find it interesting that you  
4 cost it more to study it than to fix it. Am I  
5 interpreting that correctly?

6 MR. SMITH: You've read that quite correctly.  
7 The statement was made earlier that Edison was going  
8 along in the process of fixing rather than analysis. We  
9 have done a lot of analysis. We have done a lot of work  
10 to convince the Staff that what we had at our units was  
11 in fact adequate. We probably would have spent our  
12 money quicker and gotten into it earlier than other  
13 people, because our philosophy is that they are safe to  
14 operate, they're safe to run, and rather than modify our  
15 plant, with our philosophy of, if we modify it at  
16 Dresden 2 we're going to do it at the four others, we  
17 would prefer to spend a few extra dollars with analysis  
18 to try to show that it really is not a problem. And in  
19 fact that is what we have been doing.

20 MR. MOELLER: Thanks.

21 MR. SMITH: I would just like to make a strong  
22 statement on Bill Russell's behalf. The program sort of  
23 floundered along until he took over and we went to the  
24 lead topic concept and we got the utilities heavily  
25 involved. At that point in time, the program really

1 started to move forward, and because of that and the  
2 fact that Bill would cause people to make reasoned  
3 judgments, instead of having a standard review plan and  
4 saying, you don't meet point number 27, what are you  
5 going to do about fixing it, Bill would say, who cares,  
6 it's not an important point in the overall context of  
7 the plant.

8           He caused his reviewers, with his strong  
9 project management, to do some reasoned judgment, and I  
10 think the Staff has learned a lot by that. And in fact  
11 strong project management is a necessary item that we  
12 should be having.

13           (Slide.)

14           We are still performing some work on a number  
15 of topics. It has pretty well tapered down. Our  
16 tornado missiles we will do on a probabilistic study.  
17 For the intake and exhaust, we have committed to do a  
18 number of studies, and that's basically what these items  
19 are.

20           Our overall feelings are, we have spent quite  
21 a bit of money and for what we've got, which is  
22 basically this list, that there's got to be better ways  
23 of going about fixing and modifying the plants. A  
24 number of these procedure changes and modifications,  
25 when you look at them, are not very major. As you saw,



1 we are not projecting huge dollars for total  
2 modifications to the plant.

3 MR. SHEWMON: I'm not sure what that last  
4 statement means. It seems to me one attitude for the  
5 utility would be, gee, if we now get our license it's  
6 good for the rest of the life of the plant or it's good  
7 for ten years, or we ought to do it every year. At some  
8 place, what are you saying with regard to future action  
9 in this area, given plants that may have to be looked at  
10 like this again over their 40-year life?

11 MR. SMITH: We feel that, given all the effort  
12 we have put forth for this program, that the amount of  
13 safety significant problems that we have found is  
14 extremely minimal. We also feel that, given the various  
15 generic activities that are being conducted -- the TMI  
16 activities, fire protection -- that in general almost  
17 all of these items -- the only one we don't think would  
18 have been picked up is the equipment anchorage, although  
19 I suspect that A-46 would have eventually picked that up  
20 also.

21 MR. SHEWMON: You're saying other activities  
22 of the NRC would have picked up almost all of these  
23 items?

24 MR. SMITH: That is correct, the NEC or the  
25 utilities as we go through our reviews.

1 MR. SHEWMON: Fine, thank you.

2 MR. AXTMANN: Does either the Staff or the  
3 utility try to compute a cost-benefit ratio on this  
4 exercise?

5 MR. SMITH: We have not.

6 MR. SIESS: Bill?

7 MR. RUSSELL: We are just now getting to the  
8 point where we have the data to do that. It is my view  
9 at this point that a number of issues were identified as  
10 a result of SEP's that are not being looked at in other  
11 programs, and we are collecting that data now based upon  
12 the five reviews we have completed to date.

13 We also feel that the approach we have used of  
14 looking at a hierarchy of action, that is looking at  
15 credit for non-safety systems, using procedures,  
16 augmented surveillance, other alternatives to hardware  
17 fixes, are appropriate, and I think some of that has  
18 contributed to the low impact of the cost, and the bulk  
19 of the improvement has been made in the procedures area  
20 generally in the case of the boiling water reactors.

21 That is not true, for instance, at Ginna,  
22 where we found that the original design did not consider  
23 wind loads beyond building code, 70 miles an hour, for  
24 that structure. They are in a much more costly program  
25 in evaluating their structural upgrading.

1           So I think there is merit in the reviews that  
2 have been conducted.

3           MR. SHEWMON: Dave, let me pursue one other  
4 thing in this. Chet, one of the things that comes up or  
5 will come up is what we do with regard to what is called  
6 SEP-III or something.

7           MR. SIESS: Right.

8           MR. SHEWMON: Which it seems is what we're  
9 talking about now, in a sense. What are the plans for  
10 bringing this up again on that?

11          MR. SIESS: I'll let Bill Russell tell us what  
12 the status is on SEP Phase III and what he wants us to  
13 do about it.

14          MR. RUSSELL: SEP Phase III would be subjected  
15 to review by the Committee and by the Committee for  
16 Review of Generic Requirements. We have not yet  
17 presented to the Commission the results of these five  
18 plant reviews. We are proposing to do that next week.

19          MR. SHEWMON: I guess my question is, is  
20 SEP-III in the planning stage or is it committed to?

21          MR. RUSSELL: It's still in the planning  
22 stage. There's been no commitment to it. The  
23 Commission has not yet had a proposal presented by the  
24 Staff. We will present that proposal to the Committee  
25 and to the Committee for Review of Generic Requirements

1 prior to going before the Commission.

2 MR. SHEWMON: Are you scheduled for that or is  
3 it in limbo?

4 MR. RUSSELL: We estimate we would be ready to  
5 do that in the first quarter of the calendar year, with  
6 CRGR some time in the spring, and the ACRS Committee in  
7 the spring.

8 MR. SHEWMON: That's the '83 calendar year?

9 MR. RUSSELL: That's correct.

10 MR. SHEWMON: Dave?

11 MR. OKRENT: When you are looking at  
12 cost-benefit considerations, it seems to me one of the  
13 things that will enter is whether the uncertainty in  
14 one's knowledge of the risk has been changed by the  
15 process. If in fact having done it there is a  
16 considerable reduction in uncertainty in some areas,  
17 this represents in my opinion a reduction in risk, if  
18 you will.

19 In other words, your expected value will come  
20 out smaller, and that is a non-trivial benefit in my  
21 opinion. So one has to look at things besides the  
22 actual changes that were made.

23 For example, as Mr. Russell just indicated,  
24 until they looked they did not know whether any or all  
25 of the plants had some anomaly like he just referenced

1 at Ginna vis a vis protection against wind. I am just  
2 saying that there are a variety of factors that have to  
3 be included in this.

4 MR. MOELLER: I wanted to follow up on the  
5 comment that SEP-III would be taken before the CRGR. In  
6 Dr. Isben's comments on, I believe, the Dresden 2 SEP  
7 review, he says, "Provision should be made for the  
8 active participation of the SEP Staff before the CRGR."

9 Am I then to understand that CRGR has not been  
10 involved in SEP-II?

11 MR. RUSSELL: That's correct. The CRGR has  
12 not been involved in the plant-specific reviews for SEP  
13 Phase II. They would be involved in a continuation of  
14 SEP, whether that's done by rulemaking or some other  
15 vehicle.

16 MR. MOELLER: Thank you.

17 MR. AXTMANN: Dave, in reply to your reply,  
18 does that not suggest that the ALARA considerations need  
19 to have two levels?

20 MR. OKRENT: You'll have to explain the  
21 question.

22 MR. AXTMANN: Well, I think the numbers are  
23 there to probably go through the exercise of the cost  
24 per reduction -- the cost per man-rem averted, right?  
25 And you are suggesting that the uncertainty in this is

1 equally valuable, so --

2           MR. OKRENT: Let me put it this way. I could  
3 have postulated before the study that if we hadn't  
4 looked, there were several areas in which there might be  
5 in fact large risks. We don't know. At least, the  
6 uncertainty in our knowledge of these risks is large,  
7 and therefore if I put some kind of a distribution  
8 around a median and I did a calculation of the risks I  
9 would end up having a relatively large expected value of  
10 core melt or release or whatever you want to say, due to  
11 a variety of things that based on my existing knowledge  
12 I could not say how they had been dealt with.

13           When you have looked and you have satisfied  
14 yourself, for example, as they have, for example, that  
15 Dresden is reasonably close to what they might do today  
16 with regard to design for an earthquake, after you set  
17 the design basis knowing that they can reduce the  
18 uncertainty with regard to that potential contributor,  
19 and so you calculate a reduction in the risk from  
20 whatever it was you had before.

21           That is a non-trivial question. One of the  
22 big problems we face is the uncertainty in our  
23 knowledge, and there was a certain kind of uncertainty  
24 that affected these older plants, namely a lack of  
25 knowledge of quite what was in them.



1 MR. SIESS: Did Commonwealth finish?

2 MR. SMITH: Yes.

3 MR. SIESS: You can sit down. I don't think  
4 you're involved in this discussion right now.

5 Can we hear from Northeast Utilities?

6 MR. CASIG: Before I get into the vugraphs, I  
7 just want to make an observation. Not unlike  
8 Commonwealth, we have spent a number of internal  
9 man-hours to get to the point where we are. But I think  
10 it is worth noting that we started with 137 topics,  
11 boiled it down to one issue that we might have  
12 disagreement with the Staff on. And even if it comes  
13 down to a disagreement and we end up accepting the  
14 standard tech spec limit, in the big scheme of things I  
15 do not consider that particularly significant as an  
16 issue or a big ticket item, and I doubt that we could  
17 come up with any other list of 137 issues that we've  
18 discussed with the NRC Staff with that level of  
19 agreement.

20 The first vugraph I have just has a couple of  
21 notes with respect to the conduct of Phase II being  
22 different from our original expectations, the first one  
23 being that it was going to be largely an NRC Staff  
24 program; the second being that it was our understanding  
25 that there would be some amount of protection from what

1 I call interim backfits unless there was a safety  
2 problem; the third one being that we would be excluded  
3 from certain other NRC initiatives. As the program has  
4 evolved, I think the only item that fell into that  
5 category was the postponement of our update.

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1           We also have a footnote in the vu-graph to the  
2 effect that this program was not formalized in the  
3 regulations.

4           (Slide.)

5           MR. KACICH: My purpose in presenting the next  
6 vu-graph is just to refresh everyone's memory of the  
7 original SEP objectives. There were five of them, and  
8 everyone can see them. I won't bother to read them off.

9           The last one is one of my own, to improve the  
10 basis for POL conversions. I have a vu-graph that gets  
11 back to our suggested answers to these. There was a  
12 question of whether we met these objectives. Also, in  
13 the interest of history, this has more or less been  
14 covered earlier today. I would summarize what I call  
15 the stages of SEP Phase 2, the first one being that it  
16 was an NRC program that lasted for approximately three  
17 years. During this period, not a whole lot was  
18 accomplished, probably due to the TMI 2 accident.

19           The next stage, the lead plant was proposed in  
20 the fall of 1980. That lasted for about three months,  
21 at which time the SEP licensees responded with the lead  
22 topic approach, which has essentially been since that  
23 point in time. The actual program has been a hybrid of  
24 the lead plant and lead topic in that most plants have  
25 been able to share individual information, and of course

1 the plants are being taken through an integrated  
2 assessment in sequence and not as a group.

3           We make the observation that increased  
4 licensee involvement has been a key factor in  
5 accelerated rate of progress that has taken place since  
6 the fall of 1980, and that the licensees have benefitted  
7 significantly by evaluating topics concurrently and  
8 sharing information.

9           (Slide.)

10           MR. KACICH: In terms of what has happened  
11 thus far for Millstone, this vu-graph is essentially a  
12 summary of the different forms of what you have seen  
13 earlier today. The plant modifications that we have  
14 completed thus far, the first one is the seismic  
15 anchorage issue. That is common to virtually all of the  
16 SEP plants. The second one is some structural  
17 modifications regarding turbine building bracing that we  
18 have completed, and the installation of some new battery  
19 racks.

20           We have listed four modifications that we have  
21 committed to at this time, tornado missile protection,  
22 redundant pressure, interlock on reactor water cleanup  
23 systems, some additional isolation valves, and some  
24 blocking devices for some existing isolation valves.

25           Then I have a list of about half a dozen

1 various procedural or tech spec changes we have  
2 committed to, which really have already been discussed  
3 previously this morning.

4 (Slide.)

5 MR. KACICH: Some general observations on  
6 Phase 2. Again, it was a relatively large resource  
7 expenditure as compared to our original expectations,  
8 some 30,000 internal man hours, or approximately 15 man  
9 years. Our consultant costs to date have totalled  
10 approxiately \$1 million, and the hardware modifications  
11 that I mentioned previously cost \$1.5 million.

12 In both the latter two categories, those costs  
13 are almost exclusively in the seismic area. Note that  
14 the schedule has been extended significantly beyond what  
15 we originally projected.

16 On the next point, the fact that the  
17 integration concept which in our view is a very positive  
18 concept and element of SEP was limited to strictly the  
19 SEP topics. Various attempts that we had made during  
20 the past couple of years to identify overlaps with other  
21 regulatory initiatives with SEP issues didn't generally  
22 meet with much success.

23 The next point I have noted is one that has  
24 been mentioned by most of the other utilities, that of  
25 strong management on the current SEP branch. We

1 generally found if we could advance sound technical  
2 reasons to justify deviations from current criteria,  
3 that this branch was willing to listen to those.

4           As a logical outgrowth of that, we found that  
5 the judgments that were reached were based upon nuclear  
6 safety and not SRP criteria. We also found that there  
7 was a definite opportunity for consideration of plant  
8 unique features, and especially with these older general  
9 plants. I think that it is safe to say that they have  
10 more unique or one of a kind features in the industry.

11           Last, we have noted there were provisions for  
12 the licensee to utilize knowledge of the plant to  
13 implement the integration concept. I have to emphasize  
14 again there were limitations on this because there was  
15 an SEP bound put around where you could implement  
16 integration and where you could not, but in the concept  
17 of SEP we thought that was favorable.

18           MR. SIESS: I believe you told us at the  
19 subcommittee meeting what your resource expenditure had  
20 been on some other activities. Was it 7914 you  
21 mentioned?

22           MR. KACICH: I believe the information I had  
23 then was some statistics on initial capital cost, which  
24 is approximately \$100 million, and the cost of backfits  
25 to date, which is approximately \$173 million, and I



1 contrast that with the \$1.5 million.

2 MR. SIESS: I thought you spelled out one  
3 particular program in 7914. But that's all right.  
4 Don't bother.

5 MR. KACICH: You are right, Dr. Siess. I  
6 mentioned for both in 7902 and 14 anchor bolts and as  
7 built verification. We have expended \$59 million thus  
8 far. We are almost done with it.

9 (Slide.)

10 MR. KACICH: Okay. The next vu-graph has our  
11 proposed answers to the objectives of the SEP. Did we  
12 create a documentation base? The answer is generally  
13 yes. Information is much more retrievable now than when  
14 we started the program. I think we did a reasonable job  
15 in getting a handle on where these plants are.

16 Did we provide the capability for integrated  
17 and balanced backfitting decisions? Again, in the  
18 context of SEP issues only, I think the objective has  
19 been met and is being met, and especially in light of  
20 our integrated structural evaluation program. I  
21 anticipate that it will continue to be met.

22 Did we identify any immediate safety  
23 concerns? It would be our opinion that there were not  
24 too many of them to find, but the opportunity existed  
25 within the program to do that, and the one example that

1 comes to mind that I think is common to all the SEP  
2 plants is the seismic anchorage issue.

3           Did we reassess the safety adequacy of the  
4 plants? I have to answer that partially not. I have  
5 found this was the most difficult question to answer. I  
6 think that the SEP did a very good job of evaluating the  
7 issues that are summarized in the integrated assessment  
8 report, but there are a lot of other issues such as the  
9 TMI's and the USI's and the environmental qualification  
10 in the SER that were specifically eliminated from the  
11 scope of this review.

12           I think that comment is applicable to all of  
13 the SEP plants. One factor unique to Millstone was, it  
14 was the only plant that was in IREP and SEP. IREP had  
15 the same objective of the SEP in many respects in terms  
16 of assessing safety. And while we intended to use that  
17 data and the staff did use the data presented earlier, I  
18 don't know that we could make a statement anything  
19 beyond partially on did we actually assess the safety  
20 adequacy of the plant.

21           Did we efficiently use the available  
22 resources? Our answer to that is not really. Fifteen  
23 internal man years to us was a lot to find the issues we  
24 found.

25           MR. OKRENT: Do you have a proposal as to how

1 one could have accomplished the objectives and  
2 efficiently use the available resources?

3 MR. KACICH: I think it is a lot easier to  
4 Monday morning quarterback.

5 MR. OKRENT: Even on Monday morning it could  
6 be helpful, in view of what you see, and if you are  
7 going to look on Monday morning, it would be well to  
8 look at ten plants, five plants, not only one, because  
9 there will be different views.

10 MR. STESS: How many of those 15 man years  
11 were used up in that first phase before you were on the  
12 lead topic part? If you had been on lead topic from the  
13 beginning, how much time?

14 MR. KACICH: I think in the neighborhood of 70  
15 to 75 percent of that time, if we had had the current  
16 structure from the beginning, so it wasn't that high a  
17 percentage of it that was spent in the initial three  
18 years when we really didn't accomplish all that. There  
19 were a lot of bookkeeping efforts on our part.

20 MR. BENDER: Recognizing that there are lots  
21 of things in these other categories, do you think that  
22 the significance of the things that were looked at as  
23 compared with those you are still working on under other  
24 programs represent a major assessment of the status of  
25 the plant?

1           In other words, have we screened out so much  
2 in these other programs so that this part of it did not  
3 deal with the real issues?

4           MR. KACICH: Well, one piece of insight you  
5 can gain is the fact that if we spent \$173 million on  
6 backfits for everything and only 1.5 of that was for  
7 SEP, either it wasn't a very good part or we were doing  
8 the wrong things.

9           I think the answer to that is a little bit of  
10 both. I think the other, as I contrast the SEP branch,  
11 our experience with the other technical branches is that  
12 here is a cookbook, go to it, and there wasn't much  
13 opportunity to either justify alternate approaches or to  
14 say, let's integrate this so that when we have a  
15 transmitter first we environmentally qualify it, then we  
16 seismically qualify it, then we bring it up so it  
17 doesn't get submerged, then we decide that it needs more  
18 redundancy.

19           We find there are cases when we backfit the  
20 same thing over and over again. So again, if we had had  
21 an opportunity to fix all of these issues now, we would  
22 not have had to spend \$173 million to get there from  
23 here.

24           MR. BENDER: All right.

25           MR. KACICH: Dr. Okrent, I realized I hadn't

1 responded to your question. Perhaps that was because it  
2 was the toughest one. Certainly, if we had an  
3 opportunity to start over, knowing what we know now, we  
4 could be smarter about which topics are not really worth  
5 looking at at all. I think the results of what we have  
6 found send some signals about if we are going to look  
7 any further, where we should look.

8 I just had one more vu-graph I would throw up  
9 by way of conclusion.

10 (Slide.)

11 MR. KACICH: One message that we got out of  
12 this program was, we would like to see the positive  
13 elements of Phase 2 incorporated into the regulatory  
14 process in general. The ones being the SRP is a  
15 starting point. If you meet it, fine. You are done.  
16 If you don't, that doesn't send a signal out to get the  
17 backfit mechanism going, but only that you should look  
18 harder and make a careful assessment of the situation.

19 The second one is, strong project management  
20 is a very important element in the regulatory interface  
21 process.

22 The second bullet I have listed is, we believe  
23 that integration should consider all plant  
24 modifications, not merely those that are SEP topics, and  
25 we would like to find a better way programmatically to

1 be able to implement that concept.

2           The last point I wanted to mention was that if  
3 there is to be any extension of the existing program, I  
4 think it would be beneficial to formalize it by  
5 regulation.

6           MR. OKRENT: I would like to ask --

7           MR. SIESS: Do you really believe that?

8           MR. KACICH: Yes, sir.

9           MR. OKRENT: I would like to ask a question  
10 along the following lines. When the SEP program was  
11 first proposed, it had two parts from the philosophical  
12 point of view. One was this integrated approach, not  
13 making decisions unless they were really urgent  
14 questions until the end. The other was that the staff  
15 was going to do the work, and I can remember talking to  
16 Stello on this.

17           I questioned at that time whether it would be  
18 the staff that did this or it should be the licensee,  
19 because in fact back in around 1966, when the ACRS  
20 suggested that something like this might make some sense  
21 at some future time, we envisaged that it might be the  
22 licensees who were the ones who had the responsibility  
23 of looking at their plant to see that things are all  
24 right.

25           Now, let me ask, you think it would have been



1 workable for SEP too, or it could be workable for some  
2 future kind of similar, not identical program, to put it  
3 in the hands of the licensees, and with only general  
4 guidelines agreed upon and, I guess, a time schedule  
5 agreed on, and that realistically the licensees would  
6 have come up with similar evaluations that we are  
7 getting, and have identified at least the bulk of the  
8 things that seemed to have been agreed upon by both,  
9 that these are worth doing, and so forth?

10           MR. KACICH: I think the answer to your  
11 question is, it is a matter of degree. How much control  
12 does the licensee have versus the NRC staff? I think  
13 the way it has worked out over the last several months,  
14 in particular, is pretty close to optimum, where we get  
15 a model of one plant in the NRC and that gives guidance  
16 to the rest of the utilities about the scope of the  
17 evaluation to be conducted.

18           I think an analogy that may have been used  
19 before is the case where we are the pilot or NRC is the  
20 copilot, or vice versa. It doesn't make any difference,  
21 as long as we are in the same plane. And as long as  
22 there is an understanding and a periodic check point to  
23 make sure both parties are in agreement as to how the  
24 program is being carried out, that that process would  
25 allow us to get the job done.

1 I think the way it has been handled, like I  
2 say, over the last few months, is probably fairly close  
3 to optimum.

4 MR. SIESS: I know in that period most of the  
5 safety evaluations have been done by the licensee.

6 MR. KACICH: On a percentage basis, that is  
7 true.

8 MR. SIESS: Some of the words you see in that  
9 NUREG are taken verbatim from the licensee's safety  
10 evaluation.

11 MR. RUSSELL: I might comment, if I could also  
12 coment on Dr. Okrent's question, I think that there are  
13 two occurrences which make me believe that the licensees  
14 can do the job, and that they should do it. First, we  
15 have been going along, and for the first four plants,  
16 the integrated assessments were done essentially by the  
17 staff with a lot of negotiation or discussion back and  
18 forth with the licensees.

19 In Millstone's case, the staff identified the  
20 differences, the things that flowed from the topic  
21 reviews. They had approximately 90 days, and at the end  
22 of that they made a submittal where they proposed what  
23 they felt was appropriate to do for their plant. There  
24 were also meetings going on in between and discussions,  
25 but essentially that process or the licensee looking at

1 his plant and proposing came out very close to what the  
2 final document describes.

3           That is, there were very few areas that needed  
4 to be supplemented by additional submittals. Our audit  
5 review of that work indicated that we were looking at  
6 the same issues with the same perspective as to the  
7 relative importance. We have four more plants that are  
8 doing this, that are doing that now.

9           I think the test will be how well those  
10 reviews turn out and whether an audit of those reviews  
11 is sufficient.

12           With respect to the other part of the  
13 question, the quality of the safety analysis performed  
14 by the licensees, we had some initial false starts.  
15 There was some difficulty getting it going, but toward  
16 the end, we found that the quality was quite high, and  
17 that we could revert in fact to an audit role rather  
18 than a role of performing it. That is particularly  
19 important in SEP, where you are looking at a hierarchy  
20 of action, where you are considering non-safety systems  
21 because they are there and they can fulfill the function  
22 when you are looking at plant procedures and  
23 surveillance, and you are looking at the plant as a  
24 whole.

25           The only one who knows that plant well is the

1 guy who runs it and operates it, and we found it was  
2 extremely important to have on the audit team the  
3 perspective of the resident inspector who is there on a  
4 daily basis and seen the plant. It was useful to have  
5 the perspective of the risk assessment analyst as well  
6 as the operating project manager and the project manager  
7 from my branch.

8           So, I think that what we are seeing is that  
9 licensees can do the job, and that the staff could move  
10 into an audit role. We also found out that the staff  
11 cannot do the job by itself, that you do not have  
12 sufficient knowledge of the plant or documentation of  
13 what exists. The plants are changing such that the  
14 documentation was not keeping up with what physically is  
15 in the plants.

16           MR. SIESS: Would the updated FSAR help you,  
17 or would that still not give you the knowledge of the  
18 plant to do what you need to do?

19           MR. RUSSELL: I think the FSAR update would  
20 help in areas that are potentially fruitful to look  
21 into. From the standpoint of identifying what has been  
22 done and what exists to prioritize areas that you look  
23 at, but I think you still need to have the involvement  
24 of the licensee and his operators, and particularly the  
25 operating staff.

1           We found that in most cases in meetings with  
2 the licensees, and particularly in the integrated  
3 assessment process, that the perspective of the  
4 operator, the operations supervisor, and in some cases  
5 the shift supervisors we met with, was a very good  
6 perspective to have to understand how they really  
7 operate.

8           I think the areas of procedural revision that  
9 have been described are a major improvement. In fact,  
10 some of the things which people sit back and talk about  
11 that go between licensing at the NRC and licensing on  
12 the part of the licensee's staff of how to do things  
13 which are ad hoc, when you translate that into a  
14 procedure that an operator who, when he is faced with  
15 the problem, who has had the benefit of somebody  
16 thinking about how to do it, is very useful.

17           The concept of using water from the spent fuel  
18 pool to use as makeup if you need it and the procedures  
19 for how to get it and the reliability for water supplies  
20 that we saw in the revisions at Pallsades and Ginna, I  
21 think, are very useful contributions.

22           MR. SIESS: Mr. Chairman, I think the  
23 subcommittee is ready to turn this back to you. I would  
24 like to make a couple of comments first. I would like  
25 to thank the licensees for their presentations today.



1 And I would especially like to thank Chris for putting  
2 it all together and not getting lost and not getting us  
3 lost too much.

4 I will have draft letters on the two plants  
5 later this afternoon, if you wish to take them up.

6 I will turn the meeting back to you, and  
7 donate one hour and 15 minutes. Does that mean that I  
8 can leave at 12:30 on Saturday?

9 MR. SHEWMON: Well, I was just about to get to  
10 that. I thank you very much, and I thank the  
11 participants for moving along in a timely manner.

12 Before we break for lunch, what I would like  
13 to do is, basically, we have got an hour and a half in  
14 schedule. After lunch, we will start at 2:00, and we  
15 will actually take what is scheduled from 2:00 to 3:30  
16 on Saturday, but due to some things that are not quite  
17 ready with the staff, we will do it in inverse order, so  
18 we will start with prioritization of generic items with  
19 Mike Bender.

20 We will then go on to Jerry Ray for a  
21 memorandum of understanding, and then get to Dade  
22 Moeller's things. Then we will go back on the regular  
23 3:30 to 6:45 schedule that is in the agenda after that.

24 (Whereupon, at 1:05 p.m., the Committee was  
25 recessed, to reconvene at 2:00 p.m. of the same day.)



## 1 AFTERNOON SESSION

2 (3:30 p.m.)

3 MR. SHEWMON: Could we begin. Would people  
4 sit down so we can begin.

5 On the advice of my chief counsel on schedule  
6 matters, we are moving the Zimmer plant item up to 3:30  
7 and we will then, I guess, bump things down and to go to  
8 Subcommittee activities and such things on our own time  
9 after that.

10 Mike, do you want to introduce this?

11 MR. BENDER: Sure.

12 MR. SHEWMON: I would only admonish you and  
13 the speaker that this is scheduled for half an hour  
14 total, and that means that their comments are scheduled  
15 for 15, and we promise to fill up the rest of the time.

16 MR. BENDER: We're not planning on a long  
17 time.

18 THE REPORTER: I can't hear you.

19 MR. BENDER: Can you hear me now?

20 THE REPORTER: Yes, sir.

21 MR. BENDER: This matter of the Zimmer plant  
22 has been going on for a long time. I reported, I think  
23 last month, the Staff was contemplating some kind of  
24 regulatory action because of difficulties that appear to  
25 have shown up with the Zimmer plant. There is a long

1 history, as you know, of this particular installation  
2 having difficulties in establishing a good inspection  
3 record and showing that the plant had been constructed  
4 in accordance with the agreements which it had made with  
5 the Regulatory Staff.

6           Recently, the NRC issued an order, a  
7 show-cause order, which is included in your folders  
8 under Tab 4.4. I'm not going to read through it, but I  
9 will just draw your attention to what I think is Section  
10 4 of the show-cause order, which gives the reasons why  
11 the Zimmer plant should be shut down. Basically, it's a  
12 matter of getting the management to take a more  
13 responsible position on what they're doing, and I'm not  
14 going to go beyond that.

15           We have representatives from the I&E  
16 organization, I guess from Region III. Is that right?

17           MR. WARNICK: Right.

18           MR. BENDER: Bob Warnick from Region III is  
19 here to tell us what the situation is, and I think I'll  
20 just turn the subject matter over to him and ask him for  
21 a report.

22           (Slide.)

23           MR. WARNICK: Good afternoon, Mr. Chairman and  
24 members of the Committee. I'm Robert Warnick. I'm  
25 Director of the Office of Special Cases in Region III,

1 and I'm responsible for Zimmer and Midland. With me is  
2 Darwin Hunter. He is the section chief in charge of  
3 Zimmer. We will try to be brief and keep within the  
4 time frame.

5           The first slide we have is a review of the  
6 chronology of major events that have occurred since the  
7 Subcommittee meeting was held in the Cincinnati Airport  
8 in February of '82.

9           MR. KERR: Excuse me. Is there some way that  
10 the man who is handling those slides can make it  
11 possible for those of us on the other side to see?

12           MR. SHEWMON: Please go on.

13           MR. WARNICK: In May, towards the end of May,  
14 May 27th, there were three quality control inspectors  
15 that were foused with water. CG&E stopped work because  
16 of that. This was on a Friday and they resumed work the  
17 following Monday after making all the workers at the  
18 plant sign a statement acknowledging the law we have on  
19 intimidation and harassment.

20           Then that was followed up with additional  
21 allegations of intimidation and harassment, and we ended  
22 up interviewing some 50 QC inspectors, approximately  
23 50. And Mr. Kepler ended up by going down to the site  
24 and talking to the people at the site about this  
25 problem.

1           We have appeared at Congressional hearings in  
2 June and September, towards the end of June. And in  
3 July we received allegations regarding welders'  
4 qualifications, and we looked into these and as a result  
5 of that there were some 100 active welders that we  
6 required to be retested to prove their qualification.

7           MR. KERR: How many of the 100 passed the  
8 examination?

9           MR. WARNICK: All but two.

10          MR. KERR: Thank you.

11          MR. EBERSOLE: Had those two produced  
12 important welds that were not impossible of being  
13 validated?

14          MR. HUNTER: Generally, they had produced  
15 welds that need to be dispositioned. They're in the  
16 process now of identifying all the work that these  
17 individuals performed, all the work that all the  
18 individuals performed also.

19          MR. WARNICK: What we did, we said even if you  
20 passed the tests, we want you to go back and take a look  
21 at some of the work they did, to validate that they  
22 didn't learn while they were doing the work. So they're  
23 going back to look at the work of all the people.

24          MR. EBERSOLE: Is it not true that there is no  
25 nondestructive checking method available which will give

1 you satisfactory evidence if the welders did it wrong,  
2 that there is no inspection technique that will show  
3 it's been improperly welded? That is, you cannot in the  
4 absence of knowledge of procedures qualify a weld by  
5 simple non-destructive testing?

6 For instance, you don't see the heat treatment  
7 or you don't see the temperature distributions or a host  
8 of other things; that none of this will show?

9 MR. SHEWMON: They're fusion welds, Jess, and  
10 I don't think there is any particular heat treatment on  
11 the ferritic materials involved.

12 MR. EBERSOLE: Isn't it true that NDT can be  
13 performed which will make it unnecessary to know how the  
14 weld was fabricated?

15 MR. HUNTER: One of the considerations that is  
16 being given is to develop a program to identify the  
17 first welds the individual put in and then do  
18 destructive testing of the first welds, determining  
19 whether or not they were qualified by a destructive test  
20 method, and then maintaining their qualifications  
21 through a continuation of the process through their  
22 lifetime on site.

23 This is being considered by the Licensee and  
24 when they have this program established, then we will  
25 review it and our people will review it to agree or

1 disagree with that technique.

2 MR. EBERSOLE: Well, that's a destructive  
3 test.

4 MR. HUNTER: Yes, sir. I can't respond to the  
5 nondestructive tests. I might agree with you that that  
6 would be difficult, to provide destructive tests for a  
7 structural weld. That is not really -- NT may be  
8 difficult. NT may be impossible. UT may in fact not  
9 tell you what the consistency of the weld is.

10 MR. BENDER: We need to get this in the  
11 context. As I understand it, there are several kinds of  
12 welds that are being considered. Some are piping welds,  
13 some are structural welds. Are there any others?

14 MR. HUNTER: Generally, the site is built to  
15 ASME and AWS. The heating-ventilation is a slight  
16 difference in acceptance criteria, but it's generally an  
17 AWS type.

18 MR. BENDER: What you're trying to do is  
19 establish that the welders are qualified. Is there also  
20 an issue about whether they used the right materials?

21 MR. HUNTER: Yes, sir. The weld rod control  
22 is in question, also weld procedures historically have  
23 had problems.

24 MR. BENDER: So you have three things to  
25 consider. Even if the welders are qualified, if they



1 used the wrong procedures they could be in trouble.  
2 They could be unqualified and use the right procedures  
3 and get good welds. So it is possible that the issue is  
4 procedures and materials and secondarily qualified  
5 welders. I don't know what the order is.

6 MR. SHEWMON: Harold, were you trying to say  
7 something to this?

8 MR. ETHERINGTON: No, I pass.

9 MR. SHEWMON: Chet?

10 MR. SIESS: If you went to another site under  
11 construction and picked 100 welders at random and gave  
12 them another test, how many do you think would fail?

13 MR. HUNTER: Our position was that they would  
14 all pass. We used the code requirements for  
15 qualifications and allowed them to come out of the  
16 field, step into an ideal situation in the test booth  
17 and qualify. And we gave them two coupons to qualify  
18 on. They should have passed within the two coupons.  
19 Some of the fellows were given three and passed, and  
20 then some of the fellows, of course, who didn't pass,  
21 two particular individuals, took more than three.

22 MR. SIESS: That's very interesting, but it  
23 wasn't the question.

24 MR. BENDER: Dr. Siess wanted to know whether,  
25 if you took 100 welders at some other site, would they

1 have been qualified if you requalified them again?  
2 nI would anticipate that unless they had developed some  
3 type of eye problem or some other physical problem, that  
4 they should have passed.

5 MR. BENDER: Do you have any history to base  
6 that on?

7 MR. SIESS: It would seem to me 98 percent  
8 passing was a good figure. These were people that had  
9 not been tested before, and 98 percent of them passed?

10 MR. HUNTER: No, they'd been tested before.

11 MR. BENDER: They just hadn't requalified, as  
12 I understand it.

13 MR. SIESS: Why, if these people had been  
14 qualified once and they failed the requalification, why  
15 are you so confident that another 100 from another site  
16 would all pass?

17 MR. SHEWMON: They had concern about the  
18 original qualification. Wasn't that why you went back?

19 MR. WARNICK: Yes. There were questions on  
20 the documentation of their qualification. That is why  
21 we questioned it and made them go back to retest.

22 MR. KERR: I guess I'm puzzled now. I thought  
23 in answer to his question you said all these were  
24 qualified welders.

25 MR. WARNICK: They were. They had been

1 certified by the Licensee's QA program saying that they  
2 were qualified. But we found problems with the  
3 documentation they reviewed.

4 MR. KERR: You were convinced that they were  
5 qualified, but you were convinced that the documentation  
6 was no good?

7 MR. WARNICK: No. We didn't know. The  
8 Licensee maintained that they were qualified.

9 MR. SHEWMON: "Qualified" is in quotes.

10 MR. WARNICK: Their documentation didn't  
11 support it and we told them they would have to go back  
12 and prove that they were qualified.

13 MR. ETHERINGTON: Does the code permit or  
14 provide for procedural deviations?

15 MR. WARNICK: Darwin, do you know the answer?

16 MR. HUNTER: Ask it again, sir?

17 MR. ETHERINGTON: Does the code make any  
18 provision for a procedure on deviations, like the weld  
19 was made with a liquid metal weld but it was not  
20 qualified?

21 MR. HUNTER: The prerequisite is that they  
22 comply with the code, and in some cases it's more  
23 restrictive than ASME.

24 MR. ETHERINGTON: Even though the welds are  
25 good, they have to be redone? Is that the position or

1 not?

2 MR. HUNTER: If they cannot show qualification

3 --

4 MR. ETHERINGTON: They have to show prior  
5 qualification?

6 MR. HUNTER: Yes, sir. And if it wasn't in a  
7 test booth, which is required by ASME, then they could  
8 provide the same testing in a destructive test of an  
9 initial weld and they could be qualified through the  
10 process from then on.

11 MR. ETHERINGTON: So then all the welds made  
12 would have to be redone?

13 MR. HUNTER: No, sir. The program would go  
14 back and determine the first welds they had performed,  
15 destruct potentially the first weld or welds. Then they  
16 would be qualified by their own process from then on.  
17 So it would only be a limited number of welds in most  
18 cases.

19 MR. SHEWMON: Max?

20 MR. CARBON: How do you decide whether to give  
21 them one coupon or two or three in order to qualify?

22 MR. HUNTER: We generally used the guidance in  
23 the ASME code. The ASME allows more than two, but with  
24 somebody who is in the field actively welding and  
25 pulling him into this shop where he's in a set of ideal

1 conditions, he has all of the ideal conditions, two  
2 coupons we felt were adequate.

3 We might consider three coupons without a  
4 problem. Two coupons should have been adequate to  
5 qualify the individual.

6 MR. EBERSOLE: It seems the focus of the  
7 problem is who qualified these people.

8 MR. SHEWMON: There's more than this problem.  
9 Let's let him get through.

10 MR. WARNICK: Yes, I'd like to go through the  
11 chronology quickly, and then I'd like Mr. Hunter to talk  
12 about the deficiencies that have been identified.

13 The National Board of Boiler and Pressure  
14 Vessel Inspectors were invited to come in by the State  
15 of Ohio to conduct inspections on their behalf. They  
16 have conducted many inspections and their findings have  
17 been consistent with ours, or ours have been consistent  
18 with theirs.

19 On October 19th, we met with CG&E to discuss  
20 the problems we had identified during our inspections  
21 regarding catalytic incorporated.

22 (Slide.)

23 Darwin will talk more about these when he  
24 talks more about the deficiencies.

25 Because of our concerns identified at this

1 point, the Licensee also recognized their problems and  
2 started scaling down their work effort. They laid off  
3 450 craftsmen on October 6th.

4 We issued the order suspending construction on  
5 November the 12th. That was late on Friday. Then the  
6 following Monday they laid off 1240 personnel, of which  
7 1,087 were craftsmen.

8 One part of the -- at that point, we are to  
9 the order. What I would like to do here is let Darwin  
10 talk about the deficiencies, and then I will come back  
11 and talk about the order of time permits, and then  
12 conclude by giving you the current status of the plant  
13 today. Darwin?

14 (Slide.)

15 MR. HUNTER: The slide indicates deficiencies  
16 that were continued to be identified. Realizing that  
17 the quality confirmation program, what I call the  
18 verification program, was designed to identify  
19 deficiencies, I would like to point out a couple of  
20 significant deficiencies that had impact. And to be  
21 very candid, we don't know as yet the overall impact of  
22 some of these deficiencies.

23 The first one on the list is weld procedures.  
24 There have been a number of problems with weld  
25 procedures, where essential variables were historically



1 not controlled adequately. That includes the procedure,  
2 thickness of the weld, the thickness the individual was  
3 welding to, the temperature control of the weld, preheat  
4 requirements, current of the weld machine and voltage.  
5 These things are being specifically reviewed by the  
6 Licensee to establish impact.

7           The third item down is electrical cable tray  
8 and support installations.

9           MR. KERR: Excuse me. I can't tell whether  
10 you are saying that you know all of these things were  
11 done incorrectly or there are no records that exist to  
12 tell you whether they were or not. Which is the case?

13           MR. HUNTER: In this particular case as an  
14 example, they had 90 weld procedures. They reviewed the  
15 weld procedures. The weld procedures they used  
16 themselves in the field and trained the people to did  
17 not include all of the appropriate criteria required to  
18 do that weld in accordance with the codes and  
19 specifications.

20           MR. BENDER: Excuse me. If I were to go to  
21 other nuclear plants, would I find that the others are  
22 laid out chapter and verse?

23           MR. HUNTER: In my limited inspection of, in  
24 my case, modifications that were performed at operating  
25 facilities and looking at weld procedures and welding

1 under that condition and talking with the technical  
2 people in my office, yes, sir, the weld procedures are  
3 laid out chapter and verse, step by step, because the  
4 code is very stringent on the way to install welds at  
5 the plant.

6           When I say codes and specs, I mean ASME and  
7 AWS. And they would in fact put their welds in in  
8 accordance with their procedures, yes. My answer is  
9 yes, we would find that.

10           MR. BENDER: You're telling me that  
11 information on the temperature of the interpasses and on  
12 the weld currents are all recorded and available?

13           MR. HUNTER: Yes, sir. Normally in a pre-weld  
14 setup on a checksheet of some sort that QC reviews, that  
15 would show that essential variables were controlled  
16 during the welding activity.

17           MR. SHEWMON: Let's let him get on, please.

18           MR. BENDER:    o ahead.

19           MR. HUNTER: Electrical cable tray and support  
20 installations, specifically actually hardware holding  
21 the cable trays together and then also support welds and  
22 also support installations, which includes Nelson studs,  
23 have shown deficiencies.

24           Sacrificial shield welds, the next item, the  
25 radiographs, there's a problem with technique. But even

1 moreso, obviously the welds themselves have problems  
2 with a slag inclusion that are in the welds, and the  
3 radiographs in some cases were performed in the  
4 as-welded condition and the radiographs are not adequate  
5 to really show the condition of the welds.

6           These were done with a piece of steel laying  
7 on the ground out in the field. They are now used as  
8 concrete forms. The radiograph is no longer -- the  
9 technique of radiograph of these particular welds is no  
10 longer available, because they are installed.

11           Now, whether or not they will decide to do  
12 UT's or NT's or what technique they will use to satisfy  
13 the code requirements of those welds, I don't know at  
14 this time.

15           Control rod drive systems, of course design  
16 control -- they are rebuilding generally the control rod  
17 drive hangers, and that system is being rebuilt now.

18           MR. BENDER: That's structural welds.

19           MR. HUNTER: Seismic upgrade and structural.

20           Electrical cable separation is a problem.

21 It's not been completely identified yet, but they have  
22 problems with the specifications and also they're doing  
23 field walkdowns to determine the impact of the total  
24 problem.

25           Fire protection system seismic upgrade was

1 done in 1979 and there is no evidence of QA nor Sargent  
2 & Lundy engineering involvement. That is being reviewed  
3 now. I'm not saying that the engineering cannot be  
4 provided today and it will not be a problem, but the  
5 fire protection system was mounted by Ginnel on the  
6 seismic class one cable tray supports and just clamped  
7 on there, and that needed to be a controlled activity  
8 and it was not.

9 MR. EBERSOLE: Pardon me. It's a good idea, I  
10 guess, but it's the first time I've heard about seismic  
11 fire protection requirements. The Staff has in general  
12 not required that.

13 MR. HUNTER: Their system was upgraded in 1979  
14 so it wouldn't fall on something else.

15 MR. EBERSOLE: Oh, thank you.

16 MR. HUNTER: It in itself is not class one,  
17 but it is supported as a common mode failure item.

18 There's a problem with concrete and steel  
19 coatings, the application of the materials in the  
20 environmental material when they installed the coatings  
21 back in late 1970.

22 (Slide.)

23 Those generally show construction deficiencies  
24 that these people have identified that have been built  
25 into the facility, and they're going to have to be

1  dispositioned.

2           Now, I got involved in Zimmer in January when  
3 we started an inspection program, which I haven't  
4 finished. But I looked at personnel qualifications and  
5 certifications in January of '82, and we had a problem  
6 with that. They weren't meeting all their own  
7 commitments and that is so documented in an inspection  
8 report.

9           We were having trouble with them identifying  
10 items and then taking appropriate corrective actions.  
11 We were having trouble with them not only with welder  
12 qualifications, but maintaining welder qualifications on  
13 their onsite welders. Today there's a problem still  
14 with upgrading of records. Then there's a problem, as  
15 indicated by this gentleman over here, weld material  
16 control, weld rod material control.

17           Then in August we looked at a specific  
18 subcontractor who was going to do rework activity and  
19 some other punchlist activities for continuing  
20 construction. We sent three people out and spent about  
21 three weeks, and when we had finished our audit of that  
22 group, realizing that they were under specific control  
23 of CG&E, under special controls established again by us  
24 in late 1981, we came back with findings relative to  
25 classification of essential work.

1           They had done work and they hadn't properly  
2 classified it. Therefore, the QC was not being  
3 performed in the manner we felt it should be. They  
4 lacked inspection and surveillance activities in some of  
5 those activities these people were doing. These people  
6 were reworking all the structural steel welds in the  
7 control room, for example. And these types of problems  
8 we found with their rework activity and removal of fire  
9 protection material so they could rework items and  
10 inspect items.

11           MR. SHEWMON: They were reworking them why?

12           MR. HUNTER: Because the structural steel  
13 welds generally had never been inspected after they'd  
14 been installed back in the seventies by Bristoe. After  
15 our investigation, we required them to inspect all  
16 structural welds. The welds would not meet ASME. They  
17 would not meet structural requirements, and they were  
18 having to rework them to bring them into the specs.

19           MR. BENDER: That's AWS requirements?

20           MR. HUNTER: Yes, in this particular case.

21           We had a couple more problems with  
22 identification and corrective action again, similar to  
23 not identifying something and not correcting it timely  
24 and not correcting it generically. Then we had some  
25 problems with records and audits. CG&E didn't actually



1 audit this group prior to allowing them to go out in the  
2 field and work.

3 (Slide.)

4 MR. ETHERINGTON: What do you mean by  
5 "rework"?

6 MR. HUNTER: Rework? Okay. Part of the  
7 investigation of '81 required CG&E to perform certain  
8 activities where we had found problems. One of the  
9 areas where we found significant problems was in the AWS  
10 structural steel welding program. They were required to  
11 re-inspect all of the structural welds, generally  
12 speaking.

13 Then, speaking of the control room, it  
14 includes the drywell, the suppression pool, the control  
15 room, the reactor building. They have in fact, and  
16 they're in the process of re-inspecting some more, but  
17 generally they've completed re-inspection of the welds,  
18 and they found that these welds did not meet the specs  
19 they had committed to in their license.

20 MR. BENDER: Structural welds were originally  
21 inspected?

22 MR. HUNTER: That was based on the man being  
23 qualified, the man being right, and it being performed  
24 in accordance with the specifications.

25 MR. SIESS: In a physical sense, were they not

1 in conformance? The wrong size?

2 MR. HUNTER: A number of items. Those are  
3 laid out in the monthly report that we've sent up.

4 MR. SIESS: Just give me one example.

5 MR. HUNTER: Overlap and lack of fusion, about  
6 20 percent of the welds. That's the two that were  
7 unacceptable to the NRC. The profile, some undercuts,  
8 some minor things could be cut away, but we considered  
9 that very, very important.

10 The Kaiser head in fact bypassed an authorized  
11 nuclear inspection that they were doing in the field,  
12 and the ASME code requires that they be involved in the  
13 ASME code work up front, so that he can set up the hold  
14 points. They bypassed him by using a procedure that was  
15 not in accordance with their QA plan.

16 They had had stop work orders issued. CG&E  
17 issued stop work orders in the October-November time  
18 frame. The electrical cable installation, they are  
19 still having problems today. They were laying  
20 non-essential cables without adequate controls and they  
21 were getting them into essential cable trays without  
22 loading and separation, that type of thing.

23 Application of coatings are still a problem  
24 today. This is on concrete and structural steel. They  
25 weren't adequately controlling the temperatures, the

1 mixtures, that type of thing.

2           Special process procedures. Even after they  
3 had reviewed all of their weld procedures toward the end  
4 of '81, they came up and re-reviewed them again and  
5 ended up with ten additional special weld procedures  
6 that had problems in them. Then they stopped that  
7 particular activity.

8           The National Board findings, as Bob mentioned,  
9 paralleled ours and showed problems in a number of  
10 areas, including procurement procedures, QC/QA  
11 involvement, that type of thing.

12           And then I spoke about rework activities.  
13 Generally, the major rework was the structural steel,  
14 although there was some work going on in ASME. Our  
15 position was, rework without knowing the original welder  
16 qualifications, the potential is that they're adding new  
17 overweld material that they may have to disposition  
18 later.

19           The main thing is the quality program. The  
20 verification program wasn't finished.

21           MR. BENDER: Evidently, you found this through  
22 your inspection. Who else is inspecting them?

23           MR. HUNTER: The National Board is doing ASME  
24 piping, and they're finding procurement problems. And  
25 of course the NRC is inspecting ASME and structural.

1           MR. BENDER: CG&E has some structural welding  
2 inspectors?

3           MR. HUNTER: Yes, sir. They have a specific  
4 group of certified weld inspectors.

5           MR. BENDER: Have they been letting shoddy  
6 work go through, CG&E inspectors, or do you know?

7           MR. HUNTER: I think after the first of the  
8 year, the response after the first of '82 is that the  
9 work is not what you would call shoddy. I think they  
10 lacked technical review to establish some criteria on  
11 welds and other things, and it was just getting ahead of  
12 them.

13           By stopping work, it will allow them to  
14 reassess the procedures, as an example, and they can  
15 restart this activity at some point in time with the  
16 appropriate controls established. Then the QC can do  
17 their job.

18           MR. BENDER: Thank you.

19           MR. KERR: Tell me a little something about  
20 welding. I get the impression that every organization  
21 who does welding has to write up their own procedures  
22 and these are all different, everybody has a different  
23 set. Is that right?

24           MR. HUNTER: Generally, that to some degree is  
25 true. ASME and AWS, the code has specific types of

1 processes that are reviewed and approved by the site  
2 ASME. Generally, Sargent & Lundy would issue a  
3 specification saying that, the sacrificial shield welds  
4 would be put in a certain way, and then prior to the  
5 commencement of that job back in the late seventies in  
6 that case, they were required to write the special  
7 process procedures that could control those welds.

8 MR. KERR: Why are so many different  
9 procedures used? Why does everybody set up their own  
10 procedures? The ASME code says you have to have a  
11 procedure. It doesn't tell you what code you're  
12 supposed to have.

13 MR. HUNTER: It just says, if it falls in a  
14 certain category each major contractor like Kaiser would  
15 have their procedures written.

16 MR. KERR: How can you tell them that 10 or 12  
17 procedures are missing when you go and look, because  
18 earlier you had found that some procedures were not  
19 there that should have been there, I thought.

20 MR. HUNTER: We found that there were some  
21 parts of some procedures that should have been there  
22 that weren't there. The weld procedures did not control  
23 all the essential variables required by ASME or the AWS  
24 code specs. When you take the procedure and weigh it  
25 against the evaluation sheets, you look for these seven

1 points.

2 MR. KERR: This has been written by people who  
3 didn't know a bunch about the ASME code?

4 MR. HUNTER: This we will have to find out.  
5 We will decide. They were written by H.A. Kaiser as an  
6 example and reviewed by CG&E and reviewed and approved  
7 by Sargent & Lundy. They were required by spec to  
8 review all the processes, heat welding, et cetera.

9 MR. KERR: You have to assume they are  
10 ignorant, or they don't take ASME procedures seriously?

11 MR. HUNTER: They were either careless or not  
12 attentive to their job or something, yes, sir. If you  
13 get a bad weld, there are basically three people you can  
14 blame. The welder shouldn't have put it in in the first  
15 place. The supervisor shouldn't have allowed it --

16 MR. KERR: I'm not talking about welds, I'm  
17 talking about procedures. It's conceivable to me that a  
18 welder could do a good weld without having read a  
19 written procedure.

20 MR. HUNTER: He's trained to that in the test  
21 shop, so he knows all of the things to handle that. The  
22 point being that some of the voltages they were using,  
23 as some of the welds in the field would indicate, that I  
24 would not say a "welder" -- and I'm going to put that in  
25 quotes -- a welder couldn't put those in. A welder



1 wouldn't put those in. He wouldn't walk away and leave  
2 that kind of work.

3 MR. BENDER: I don't want to cut this off, but  
4 I did make a commitment to the Chairman that we were  
5 going to do this in a half an hour. So I would like to  
6 have you just go ahead if you would.

7 MR. SHEWMON: Maybe to your conclusion. Go  
8 ahead.

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1           MR. WARNICK: We are prepared to talk about  
2 the order if you would like us to. If you are running  
3 short of time, we will spend it any way you would like  
4 it. We have the order. Then we've got a slide showing  
5 what the status is today, and then we can take  
6 questions.

7           MR. SHEWMON: Mike?

8           MR. BENDER: Why don't you show us the status  
9 today, and then there is a couple of questions I would  
10 like to ask, and I imagine there are others.

11           MR. WARNICK: Following the issuance of the  
12 order, the first part of the order called for them to  
13 immediately stop work. Then the next step was to obtain  
14 an independent review organization, and they have  
15 obtained Bechtel to be their independent review  
16 organization. They have made a submittal to us, and we  
17 are in the process of reviewing that submittal. It has  
18 to be reviewed by the regional administrator. That is  
19 going on at the present time.

20           They have submitted a letter to us asking for  
21 clarification of some of the activities that they would  
22 like to proceed with, and in a meeting we held just  
23 after the issuing of the order, we told them that is the  
24 way we wanted them to do it. We wanted them to put any  
25 gray areas in writing. We would respond to them in

1 writing, to keep it clear as to what they could and  
2 could not do. They submitted such a letter on November  
3 22nd. We responded, approving eight activities,  
4 declining four activities, and then two activities they  
5 didn't give us enough information, so we said we will  
6 approve them on a case by case basis.

7           The only work that is going on in quality  
8 confirmation work and non-safety related work. They  
9 have currently -- Henry Kaiser has gone from about 2,000  
10 people to about 800, and CG&E is down to about 750  
11 people right now.

12           MR. BENDER: When we were out there in  
13 February of this year, we had the understanding then  
14 that I&E had reached an agreement with CG&E to do a  
15 certain amount of reinspection, and take whatever  
16 corrective measures were needed on account of that, and  
17 I had the distinct impression then that that program was  
18 going well, and that I&E was pretty comfortable with  
19 it. What happened?

20           MR. WARNICK: Yes, that is correct. We back  
21 in April of '81 -- one of the requirements that we  
22 imposed on the licensee was that they do what we call  
23 100 percent reinspection. Kaiser QC would inspect.  
24 CG&E had to hire their own group of inspectors. They  
25 had to go out and inspect the same item. That went very

1 well. They identified the problems. It proceeded until  
2 about, I think -- that was on the chronology slide. I  
3 believe that was around August.

4           They asked for relief in July to back down  
5 from 100 percent reinspection, and we concurred in that,  
6 and authorized them to back down, and they are currently  
7 at about -- it depends on what area, but on an average,  
8 they are out about 25 percent reinspection, and on a  
9 surveillance program, which is the normal way to do  
10 business, of about 10 percent.

11           We didn't have a problem with it. They were  
12 identifying problems and documenting problems.

13           MR. BENDER: Well, this particular action I  
14 wouldn't necessarily call precipitous, but it certainly  
15 seems like a reversal of the circumstance, and it  
16 suggests to me that there either was a breakdown in the  
17 organizational arrangement or somebody did not  
18 understand the situation to begin with. Which was it?

19           MR. WARNICK: I guess it was kind of -- you  
20 can't put your finger on any one thing. It is  
21 accumulation of effects. It was the fact that the  
22 quality confirmation program was identifying that they  
23 had a lot of hardware problems, they were trying to  
24 rework problems as they went, and we were not very  
25 comfortable with that, and then we went in and performed

1 a new inspection on Catalytic and found they had some  
2 basic, fundamental problems that they had back in '81.

3 And from all of these things accumulating, we  
4 just said, we have got to take some drastic action to  
5 get their attention.

6 MR. BENDER: While I know that it is the  
7 expected practice to have these procedures well defined  
8 and to put enough quality control into the system and to  
9 make sure they are carefully followed, just from my  
10 familiarity with other plants, it is my suspicion that  
11 this is not the only plant that has gone through the  
12 mill and has some limitations like this. If I were to  
13 go to other plants, would I always find that the level  
14 of record that you are asking for here exists?

15 MR. WARNICK: I think that you would find it  
16 to a much greater degree. You might not find it 100  
17 percent, but you would find it to a much greater degree  
18 than we found Zimmer. Yes, sir.

19 For instance, Midland, which you recognize.  
20 We have had problems there. We have not found the  
21 records problems at Midland that we found at Zimmer,  
22 like as a comparison.

23 MR. BENDER: Midland went through a somewhat  
24 similar kind of agonizing experience, maybe not from the  
25 standpoint of requiring reorganization, but I can think

1 back as far as Dresden 1, for example, where I think  
2 even the controls were not exercised on some of the  
3 plants that are running.

4 My reason for asking does not have to do with  
5 what you are doing. You may very well have to. But I  
6 think it is important to understand that in putting  
7 these requirements into the plant, we are implying that  
8 the safety of the plant may be in jeopardy because you  
9 cannot re-establish quality. I would really like to  
10 know what your position is. Are you going to be able to  
11 establish the quality of this plant to the degree that  
12 is necessary by today's standards?

13 MR. WARNICK: What we are going to be able to  
14 do by the program that has been laid out, we are going  
15 to be able to identify whether problems do or do not  
16 exist, and the licensee is going to be required to  
17 resolve those problems that do exist.

18 MR. BENDER: Are they resolvable?

19 MR. WARNICK: Well, I imagine that -- I don't  
20 know, because they haven't identified them all, but we  
21 are monitoring that as it goes along.

22 MR. BENDER: Are the ones you have found so  
23 far resolvable? Let me put it that way.

24 MR. WARNICK: Well, I would say that is a hard  
25 question to answer. Yes, they are resolvable by either



1 cutting out the work and redoing it or by some kind of  
2 testing program, or possibly an engineering evaluation,  
3 so I would say they are resolvable. It just might be  
4 expensive and time-consuming.

5 MR. BENDER: I see. Okay. Other questions?

6 MR. EBERSOLE: Isn't what you are saying is,  
7 you cannot just resolve it by non-destructive testing  
8 techniques? You have to have procedures, material  
9 usage, and history to get the qualification you need?

10 MR. WARNICK: First of all, we have to  
11 identify what the problems are. Then each problem has  
12 to be treated based on its own merits.

13 MR. EBERSOLE: Given the batch of welds for  
14 which I have no record of procedures or welder  
15 qualifications, but everything else looks good, do I  
16 have an acceptable set of welds?

17 MR. WARNICK: I don't know.

18 MR. EBERSOLE: I gather you would have said  
19 no, I don't have an acceptable set.

20 MR. WARNICK: It depends on what they do to  
21 prove that they have got an acceptable set of welds. In  
22 other words, what we are trying to do is not reach a  
23 conclusion prematurely.

24 MR. EBERSOLE: Well, is a necessary ingredient  
25 to a set of welds a history of the fabrication of the

1 weld, including procedure and qualification?

2 MR. WARNICK: I don't think it is, but Darwin,  
3 do you want to expound on that?

4 MR. EBERSOLE: I think that is an issue that  
5 nobody agrees on very well.

6 MR. WARNICK: Somehow they have to be able to  
7 demonstrate that weld is good. There is more than one  
8 way to do that probably, but I am not the welding  
9 expert, so I really shouldn't be voicing an opinion in  
10 this area. That is why we have got our welding.

11 MR. BENDER: Is there anything in the record  
12 that says what kind of proof of adequacy is to be  
13 required?

14 MR. WARNICK: No, we haven't specified that.  
15 What we said is, you build the plant according to your  
16 commitments, according to your codes and standards, and  
17 we expect you to be able to demonstrate that it was  
18 built that way.

19 MR. BENDER: You can do that prior to the  
20 building of the plant, but the plant is what, 90 percent  
21 built?

22 MR. HUNTER: Ninety-eight, according to the  
23 licensee.

24 MR. BENDER: I think I have to ask whether  
25 there is any practicality to saying that a large part of

1 it has to be redone. If a small part of it has to be  
2 redone, then I guess I would accept that you can follow  
3 the premise you are working under. But if a large part  
4 of it has to be redone, it looks to me like the  
5 practicality of doing it almost rules it out.

6 MR. WARNICK: I would agree with you.

7 MR. PENDER: So we are asking how you are  
8 going to establish, as is Mr. Ebersole. We are not  
9 asking different questions.

10 MR. HUNTER: As an example, we have examples  
11 where, let's say, they haven't met the ASME code.  
12 Basically, that is their license commitment, and we  
13 don't need to go any further than that. Also, it is an  
14 Ohio state law, and we don't need to go any further than  
15 that.

16 But let's say, for instance, that the quality  
17 confirmation program establishes the fact that material  
18 traceability is not there. Okay, and that is a  
19 requirement of the law, that is a requirement of 10 CFR  
20 50 Part B at Criterion 8, and I know it is a problem  
21 that is looming, and we are looking it in the face. But  
22 let's say it's not there, or it could be welders are not  
23 qualified adequately, or it could be any number of  
24 things.

25 The first step, of course, is for the licensee

1 to identify all those condition. where he does not meet  
2 his license. Now, he may after he goes through this  
3 have to make a hard decision. He may have identified  
4 enough that that decision will be very difficult. But  
5 to decide whether or not he should go further, that is  
6 his decision.

7 Our point of view is, he will decide where he  
8 did not do it in accordance with the law and his  
9 commitments, and where he did not, he has to provide a  
10 comprehensive, detailed program to us to show us how he  
11 is going to meet equal to or greater than what he  
12 committed to for safety, or meet an adequate program.  
13 He may have to degrade safety, but NRR will have to  
14 prove that. The staff will have to prove that. Then it  
15 will go through all the throes.

16 MR. SHEWMON: A minute ago we were talking  
17 about materials whose spec couldn't be traced or welds  
18 whose pedigree couldn't be traced, and now you are  
19 talking about a procedure, not a program. I am  
20 confused. Procedure sounds to me like what they are  
21 going to do in the future, but it is all done. The  
22 question is, what do you do after it is all done?

23 MR. HUNTER: You establish what you did not do  
24 when you put in the structural steel. That is a  
25 verification program. You establish where you are.

1 Then, when you find out what you have not done in  
2 accordance with your commitment, then they have to show  
3 an alternate program of some type. It may include  
4 engineering analysis, NDT. After they provide that to  
5 us, then we --

6 MR. SHEWMON: Thank you.

7 MR. BENDER: Can I ask, how much is Sargent  
8 and Lundy involved in this thing? When we were out  
9 there early in the year, it appeared that Sargent and  
10 Lundy appeared on the scene when CG&E rang the bell.

11 MR. HUNTER: Sargent Lundy is still the AE and  
12 they are still imminently involved in engineering and  
13 any disposition that is being taken. Basically, as the  
14 AE, they are the licensee's authorized agent in its  
15 construction permit, if you will, in the FSAR, to make  
16 engineering evaluations. Unless they hire additional  
17 people or somebody else to take their place, generally,  
18 it is Sargent and Lundy, and then their own engineering  
19 group gets involved.

20 Generally, they are right on the scene.

21 MR. BENDER: I understood for a long time the  
22 construction by Kaiser was doing their own assessment  
23 and corrective actions?

24 MR. HUNTER: I am not sure I can respond to  
25 that yet, because it is a leading question trying to say

1 who made the decisions on identifying non-conformances  
2 and at what level, and how does it occur.

3 MR. BENDER: There is a piece of paper I have  
4 seen that says that.

5 MR. HUNTER: We have got all levels of  
6 problems where they even voided identified problems.  
7 Then they were dispositioned locally without engineering  
8 input in some cases. In some cases, the engineering  
9 input was not adequate. It is a combination of those.

10 MR. BENDER: Mr. Chairman, I think we have  
11 heard enough to get a flavor of the situation. I don't  
12 think this is the place to go into it in great detail.

13 MR. SHEWMON: Greater detail.

14 MR. BENDER: I thought it would be wise for  
15 the Committee to hear firsthand as much of the  
16 information as we could, but I suspect we don't need to  
17 hear more today.

18 MR. SHEWMON: Thank you very much for the  
19 presentation.

20 That says 4:20, doesn't it? I see members of  
21 the Staff here. Forrest, can you handle the item on  
22 proposed NRC Reg. reform legislative requirements?

23 (Thereupon, at 4:25 p.m., the Committee went  
24 into Executive Session, to reconvene in open session  
25 this same day.)





1           Now, I can give my personal response to what  
2 we have heard. This starts with the feeling that there  
3 has been a lot of good and persuasive work on the  
4 efficacy of igniters at Fenwal, at Livermore, at  
5 Whiteshell, and I believe also by -- I'm not sure if  
6 it's INPO or one of the industrial groups. Igniters  
7 work. They work apparently reliably on the order of 8  
8 percent hydrogen mixtures, perhaps less, if the air is  
9 quiet. They work at smaller, leaner mixtures if the air  
10 is turbulent and stirred up. There is nothing terribly  
11 surprising about that.

12           The Sequoyah people who had a year or a year  
13 and a half ago a thing they called an interim  
14 distributed ignition source, IDIS, have moved toward  
15 what they call a permanent hydrogen mitigation system,  
16 PHMS, which differs from the interim one in a couple of  
17 respects. One is having more data behind them. The  
18 other is, they have changed the gadget to be used for  
19 the igniter from a General Motors glow plug to a thing  
20 they call Tayco, which I guess means the Taylor Company  
21 -- I'm not sure -- coil.

22           They like that for reasons which they will  
23 perhaps make clear to us, but I believe partly it is  
24 because it works at 120 volts, and that is a little more  
25 convenient. It has a lower specific energy density per

1 unit area on the thing that does the igniting. It has  
2 more surface, and consumes somewhat higher power, total  
3 power. It is a tiny little gadget. It is about the  
4 size of a --

5 MR. SIESS: A what?

6 MR. MARK: It is about three inches long and  
7 an inch in diameter, and a coil of wire which is brought  
8 up to some fairly high surface temperature. The surface  
9 temperature has been measured on the outside of the  
10 coil. If it is at 1,500 degrees, everybody agrees that  
11 it ignites fairly lean mixtures of hydrogen.

12 MR. SHEWMON: Is this F?

13 MR. MARK: F. It probably ignites at lower  
14 temperatures, but the Staff is not quite so happy with  
15 the lower temperatures. They plan to distribute these  
16 things -- I have forgotten the exact number; it is 90 or  
17 so -- in the lower compartment, in the ice condenser, in  
18 the upper plenum of the ice condenser, and in the upper  
19 containment.

20 I think they have quite persuasive data that  
21 some of the pathological conditions one has heard about,  
22 such as accelerating flames down pipes, causing  
23 detonation in lean mixtures, which shouldn't detonate  
24 but might if you run a flame down a pipe and confine it,  
25 but those situations do not really exist in Sequoyah,

1 and probably not in other reactor geometries either.

2           The detonation even of a detonable mixture is  
3 not the normal response to one of these rather gentle  
4 igniters. This, I think, is not surprising, either. In  
5 order to get a detonation, you have to start a shock  
6 wave, and these don't start a shock wave, and so what  
7 you get with even 20 percent hydrogen mixture is a  
8 deflagration, burning at some velocity, rather than  
9 detonation.

10           But, of course, even if you had a detonation  
11 in a finite fraction of the total atmosphere, this  
12 probably does not matter, with the possible exception of  
13 the effect of equipment that might be impinged by the  
14 high pressure wave. There has been a fair amount of  
15 study of the survivability of equipment essential for  
16 reaching cold shutdown. That sounds as if it was pretty  
17 important, but when you take a look at the containment,  
18 there isn't very much equipment that is essential for  
19 such a shutdown.

20           One of the main things are the igniters  
21 themselves. Do their cables stand up, and do the  
22 gadgets themselves stand up? And I think that part, at  
23 least, has been pretty well demonstrated. My own  
24 conclusion from what we have heard and what will be run  
25 through in a few moments is that a distributed ignition

1 system is a reasonable approach to attempting to control  
2 the burning of hydrogen in case there should be a lot of  
3 hydrogen.

4           The rate at which the hydrogen comes can be  
5 varied from rather slow to quite fast, up to rates as  
6 fast as anyone can think of any excuse for, and that  
7 they can handle that. If you will remember, a year or  
8 two ago, there were suggestions that in addition to  
9 looking at such a system as this, people should also be  
10 careful to look at fogs, post-accident inerting with  
11 either halon or carbon dioxide or other stunts. I think  
12 it ought to be expected that one should be able to drop  
13 the need for people looking at alternatives unless they  
14 feel like it.

15           That is, if we say we want to use the set of  
16 igniters, we ask what evidence they have that they will  
17 work, and that they are placed correctly, and so forth,  
18 and not insist. I hope the Staff will get around to  
19 being able to drop their insistence on please study fogs  
20 or halon as well.

21           There is, therefore, to that extent, at least,  
22 something generic about the thoughts. I think we may  
23 have and perhaps even I am not sure to what extent  
24 the words we might use in commenting on the permanent  
25 mitigation system for Sequoyah. We are being asked to

1 write a letter, because this is a condition on the  
2 Sequoyah license, that the Commission needs to be  
3 assured that Sequoyah has a system which may go on being  
4 used after their refueling outage which is, I think,  
5 within a matter of less than a month.

6 Excuse me, Paul. You had a question?

7 MR. SHEWMON: Yes. I was a little curious.  
8 We will hear about whether these things are to be run  
9 continuously or turned on on demand, and what that  
10 decision is? I get a nod.

11 MR. MARK: Yes, of course. I think questions  
12 of that sort and so forth, either the TVA people or the  
13 Staff will be able to tell us how they feel about them.

14 MR. SHEWMON: Fine.

15 MR. MARK: Unless there are other points --

16 MR. PLESSET: I have a point. What energy  
17 source will be used? There is a change in voltage now.

18 MR. MARK: There is a question there, and it  
19 will be discussed, and in the draft letter it is brought  
20 out. These things depend upon a source of alternating  
21 current. They are not rated that they may be run off of  
22 batteries. They will not work in the event of a  
23 blackout of AC power.

24 MR. PLESSET: Has that been taken account of?

25 MR. MARK: I think it needs to be given more



1 thought than perhaps it may have yet been given. On the  
2 other hand, I think it is also true that they don't have  
3 to work like a bunch of control rods have to work to  
4 head off an ATWS.

5 MR. KERR: I am puzzled, because I thought the  
6 GM glow plugs ran off of AC, too, except they used  
7 transformers. So I don't see that there is any  
8 difference.

9 MR. MARK: There may not be any difference. I  
10 think it is merely a fact that one needs to --

11 MR. KERR: The implication Milt raised was,  
12 you ran these off of batteries, and I think you could,  
13 but I don't think TVA was proposing to do that.

14 MR. MARK: I think you are right. They could  
15 have run on 14 volts. These things take 120. They take  
16 a little more power than you would like to latch onto  
17 the batteries for any extended period of time. They  
18 also need to work very suddenly.

19 Chet, did you have points that you thought  
20 should have been brought out at this stage?

21 MR. SISS: I guess there was one. I am not  
22 sure how pertinent it is, since we are only looking at  
23 Sequoyah, but there are some -- I think Sequoyah right  
24 now is the only licensee that has proposed to use other  
25 than the glow plug, so that is unique to Sequoyah.

1           MR. MARK: Some of the others are sticking  
2 with glow plugs.

3           MR. SIESS: I thought all the others were.

4           MR. NOVAK: Except for Watts Bar. I think TVA  
5 is --

6           MR. SIESS: But Cook is sticking with glow  
7 plugs, and FNP is in a different category.

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. BENDER: Are we going to hear from them?

2 MR. SHEWMON: I suspect so, if we get to it.

3 MR. MARK: Jesse?

4 MR. EBERSOLE: With respect to the use of  
5 these glow plugs, is there -- I presume as hydrogen  
6 concentration rises, it gets to a point where combustion  
7 will occur with these glow plugs. Are there competitive  
8 ignition systems, which may be singular, which are more  
9 efficient in igniting hydrogen and will ignite in a  
10 common fashion a concentration of hydrogen lower than  
11 the glow plugs will ignite, and in essence scratch the  
12 distributed function of ignition?

13 MR. MARK: There may be, but I don't think one  
14 cares. There may be sparks which can ignite, perhaps  
15 all the way down to 5 percent.

16 MR. EBERSOLE: Let's say one big arc some  
17 place.

18 MR. MARK: Even a small spark may ignite  
19 hydrogen possibly to a level as low as 5 percent  
20 hydrogen, but then the pressure that goes with that is  
21 not a concern.

22 MR. EBERSOLE: David?

23 MR. OKRENT: If we have a permanent system  
24 that depends on AC, does that then put the complete  
25 blackout of AC power accident into a position of

1 introducing the possibility of a sufficiently strong  
2 single burning of hydrogen for this type of containment  
3 that you might both open up a sizable opening, and also  
4 release substantial amounts of fission products, and  
5 thereby affect people's deliberations on source term and  
6 a variety of things of this sort?

7           MR. MARK: I do believe that the question of  
8 the state one would be in in the event of an altering  
9 current blackout has not been discussed as much as it  
10 may need to be. Obviously, if the matter of the rate of  
11 hydrogen buildup in the absence of sparks and in the  
12 absence of glow plugs is a factor in what one wants to  
13 think about the state one is in, I think we are talking  
14 of being okay for hours, but I think that needs to be  
15 discussed, and I do not think it has been gone through  
16 to the extent that it may need to be.

17           So, I am not in disagreement. I think it is a  
18 good point.

19           MR. OKRENT: It could be that if this route is  
20 followed, one has to think of one kind of a source term  
21 for a large dry containment and another source term --

22           MR. MARK: If the hydrogen gets up to 15 or 18  
23 percent, it is going to get up to a pressure that the  
24 containment is not built for.

25           MR. ETHERINGTON: Couldn't you run these

1 things off the AC bus?

2 MR. KERR: You are okay if the emergency AC is  
3 there.

4 MR. ETHERINGTON: I thought you meant off-site  
5 power.

6 MR. OKRENT: I said all AC power.

7 MR. MARK: Total AC. They will run off the  
8 diesels just fine.

9 MR. RAY: Well, how big is the power  
10 requirement? Will we hear that?

11 MR. MARK: We will hear it. It is about 500  
12 watts per igniter, and there is about 90 of them.

13 MR. ETHERINGTON: You want no batteries,  
14 either?

15 MR. OKRENT: What I heard was that a  
16 particular system requires AC, and one of the low  
17 probability sequences that leads to core melt at one  
18 point or another is loss of AC for a sufficiently long  
19 time, which varies among reactors, but I am saying this  
20 could have ramifications that are broader than --

21 MR. SHEWMON: Why don't we get on to the  
22 presentation?

23 MR. MARK: I think we can present the  
24 presentations. They have heard this, and it would be  
25 very appropriate to comment.

1 MR. SHEWMON: Harold, were you trying to  
2 comment?

3 MR. ETHERINGTON: No.

4 MR. SHEWMON: Okay, let's get on.

5 MR. MARK: I think we proposed to have the TVA  
6 people present their position, and keep it in a tidy  
7 package. I will call on Larry Mills.

8 MR. MILLS: Thank you, Dr. Mark.

9 We previously stated that the operating  
10 license for both Unit 1 and 2 for Sequoyah Nuclear Plant  
11 has a condition requiring TVA to instal an alternate  
12 hydrogen control system following the first refueling  
13 outage of each unit.

14 Since October, 1981, at our last subcommittee  
15 meeting, we have made 12 major submittals to the NRC  
16 Staff in the form of quarterly reports in response to  
17 Staff questions. These various submittals have been  
18 made to support TVA's effort to support the hydrogen  
19 issue, and Unit 1 is now scheduled to restart on January  
20 2nd, 1983, following the first refueling outage.

21 Today, you will be provided a general overview  
22 of our permanent hydrogen mitigation system and a  
23 description of the system. David Renfro, from our  
24 engineering design organization, will present the bulk  
25 of our material, and while David is talking, I do have



1 one of the interim igniters, the glow plug, and I also  
2 have one of the coils that we are proposing for our  
3 permanent system, and if you all would like I can pass  
4 them around the table.

5 MR. SHEWMON: Please do.

6 MR. MOELLER: Would you repeat quickly which  
7 is which now?

8 MR. MILLS: The little one that Mr. Bender is  
9 holding in his hand there is the glow plug, which is  
10 part of our interim system. The one that Dr. Kerr has  
11 is the Tayco igniter, which is being proposed for our  
12 permanent system.

13 MR. MOELLER: Thanks.

14 MR. SHEWMON: Please begin.

15 MR. RENFRO: I am David Renfro, from TVA.

16 TVA has designed a permanent hydrogen  
17 mitigation system, as you have just heard. We have done  
18 a significant amount of research and analysis in support  
19 of this system over the past two years or so. Today we  
20 have been asked to present information on that system  
21 and on the research.

22 I would like to restrict the scope of my  
23 presentation to those two areas, and not discuss the  
24 analyses that we have done, because of the limited time  
25 available. I will try to condense my presentation. I

1 think the time we were allowed has decreased somewhat  
2 from the original allotment, but I will try to answer  
3 all the questions that you have raised up to now.

4 I would like to spend about a minute  
5 discussing each of these things, for the permanent  
6 hydrogen mitigation system.

7 (Slide.)

8 MR. RENFRO: The concept, alternatives that we  
9 looked at, what the igniter looks like, the functional  
10 capability, how it is laid out, the fact that it is  
11 redundant, seismic, a little about the operating  
12 procedure, some of the testing that we will subject the  
13 igniter to in the plant, and finally, a mention of the  
14 tech specs.

15 (Slide.)

16 MR. RENFRO: First, I would just like to  
17 review the operating principle of deliberate ignition.  
18 It is basically very simple. The igniters do not  
19 operate all the time, but they are energized before any  
20 hydrogen will be released. This will be on an  
21 indication of inadequate core cooling. When the  
22 igniters are energized, if hydrogen is released, they  
23 will ignite lean mixtures of hydrogen and air. This is  
24 in order to achieve periodic or continuous burning, to  
25 improve the effectiveness of the heat sinks by smoothing

1 out the peaks, and to avoid global burns.

2           If we are successful in this, moderate  
3 containment pressurization will be the result, instead  
4 of larger spikes from global burns.

5           (Slide.)

6           MR. RENFRO: This is a cutaway view of the  
7 igniter that is being passed around. Basically, it is a  
8 120 volt igniter. TVA was the first utility to instal  
9 an igniter system. We recognized at that time that it  
10 was to be an interim system. We were using an existing  
11 circuit, and we plan to follow up with a more permanent  
12 system. Since we were designing a system from scratch,  
13 we set out to also develop an igniter from scratch. We  
14 specified 120 volts as one of the design criteria for  
15 that igniter, basically to avoid using the transformer  
16 that is associated with the lower voltage igniter and to  
17 simplify the design of the system.

18           It works on the same principle as the GM glow  
19 plug. They are both thermal igniters. They get hot,  
20 transfer the heat to the surrounding gas, causing  
21 ignition. The voltage is really the only big  
22 difference.

23           The igniter, as you can see, is larger. It is  
24 shaped in a coil, and it does require more power, but it  
25 does work on the same principle.

1 MR. MARK: Could you correct whatever I said  
2 about the power? What is it?

3 MR. RENFRO: Tayco is 120 watts.

4 MR. BENDER: What is the heating element?

5 MR. RENFRO: Microm wire.

6 MR. SHEWMON: And this is 500 per igniter?

7 MR. RENFRO: Yes, sir.

8 MR. SHEWMON: How many will you have?

9 MR. RENFRO: We currently have 64 planned.  
10 The Staff has requested that we add four more, so I  
11 guess we see an outside number of 68, so that would be  
12 30 or 35 kilowatts.

13 MR. SHEWMON: I guess to somebody like TVA  
14 that is not a lot of power.

15 MR. RENFRO: It may not be a lot of power if  
16 you have all the 13 interties that we have, but if you  
17 were required to look at diesel backup -- excuse me, at  
18 DC backup, that is a lot of power.

19 MR. SHEWMON: Yes.

20 MR. AXTMANN: Why must they be energized  
21 before the hydrogen release?

22 MR. RENFRO: We would like to have them  
23 energized so that when any hydrogen is released, these  
24 things will be distributed throughout the containment,  
25 as I will go over in a minute, but we expect to be able

1 to burn locally before the entire compartments fill up  
2 to that concentration, that uniform concentration that  
3 would give us a global burn.

4           We would like to have smaller, periodic burns  
5 rather than global burns. That is why we have the  
6 number of igniters we do. That is why we want to have  
7 them on before any hydrogen can be released. There are  
8 no adverse consequences to turning them on if you don't  
9 release hydrogen. So that is one of the advantages of  
10 the igniter system. The operator can feel free to turn  
11 them on whereas with an inerting system he may feel some  
12 constraints about purposely increasing containment  
13 pressure.

14           MR. MOELLER: Excuse me. What is the voltage  
15 for the glow plug?

16           MR. RENFRO: The GM glow plug runs on either  
17 12 or 14 volts. This is a cartoon representation of the  
18 igniter assembly.

19           (Slide.)

20           MR. RENFRO: Basically, it is located in a  
21 junction box. The connections are made internally. We  
22 have a spray shield on top. The spray shield is  
23 actually about four times the area shown here, for those  
24 igniters that are located in the upper compartment and  
25 are exposed to the spray environment.

1           Let me briefly run through where we have  
2 igniters located and the number.

3           (Slide.)

4           MR. RENFRO: Basically, the hydrogen will be  
5 released in the lower compartment. This is where the  
6 reactor coolant system is located. We have located 22  
7 igniters in this region. They are distributed at the  
8 different elevations. They are distributed radially.  
9 It is not shown very well here, but these igniters are  
10 distributed radially around the compartment.

11           The hydrogen, as I said, this is the primary  
12 region of burning. The hydrogen will first see this  
13 region. The mixture will flow through the ice  
14 condenser, lower inlet doors, through the ice bed, into  
15 this empty region at the top, empty of ice, I mean.  
16 There are 16 igniters located there.

17           Any steam that is present in this mixture will  
18 be removed in the ice bed so that the relative hydrogen  
19 concentration will be released in this upper plenum.  
20 So, our analyses and engineering common sense tells us  
21 that this will be the region where the hydrogen first  
22 becomes flammable. Our analyses have shown that most of  
23 the burns occur here, and in this compartment here  
24 (indicating).

25           However, we have to continue the good spatial



1 coverage throughout the containment. We have included  
2 ten igniters in the upper compartment or in the dome, or  
3 in an intermediate elevation at these two lower above  
4 the air return fans to complete that loop.

5 In addition, there are 16 igniters located  
6 here in these dead-ended regions.

7 MR. MARK: Which of the ones you have just  
8 mentioned are exposed to spray?

9 MR. RENFRO: Currently, I said we had ten.  
10 These four are located above the spray headers, so these  
11 six, these four, and these two are not -- are. They are  
12 exposed to the spray, these six (indicating). These  
13 four are not.

14 MR. MARK: The ones in the top of the ice beds  
15 are not. The ones downstairs are just exposed to steam,  
16 not spray.

17 MR. RENFRO: That is correct.

18 The Staff has asked that we add four more  
19 igniters in roughly this elevation, two on this side,  
20 two on this side.

21 MR. SHEWMON: What brings the hydrogen down  
22 there in the eyes of the Staff or in the eyes of your  
23 analysis?

24 MR. RENFRO: This mixture is going to be cool  
25 when it comes out, so it may tend to fall here. The

1 sprays are going, so there is some turbulence. There  
2 would be some current set up here, so we don't believe  
3 that necessarily all the hydrogen will immediately go up  
4 here. In fact, we think this is going to be a fairly  
5 well mixed region, but we did locate igniters here to  
6 try to catch it as it came out.

7           However, we believe that this is the most  
8 important place to locate igniters.

9           MR. SHEWMON: Okay.

10           MR. RENFRO: As I said, we feel like this is a  
11 fairly well mixed region. We don't feel that four more  
12 igniters are really required, but we have responded to  
13 the Staff's concern to increase the spatial coverage.

14           MR. EBERSOLE: Is this sort of a miniature cal  
15 rod heater? Is this exposed? It is a miniature cal rod  
16 heater. That is, the heating wire is internal.

17           MR. RENFRO: Yes, it is in the sheet with the  
18 nicrom wire inside, and it glow red hot.

19           MR. SHEWMON: Probably spaced by some  
20 magnesium oxide or something?

21           MR. RENFRO: Yes, there is some kind of  
22 insulator.

23           MR. EBERSOLE: What is the environmental  
24 qualification on the junction box?

25           MR. RENFRO: The junction box is a standard

1 Nema junction box, and I am not familiar with the  
2 particular environmental --

3 MR. EBERSOLE: Will it take the developed  
4 pressures in the containment?

5 MR. RENFRO: Yes.

6 MR. EBERSOLE: Where is the pressure  
7 breakdown? Is it at the box?

8 MR. RENFRO: I am not sure I understand what  
9 you mean by break.

10 MR. EBERSOLE: When you develop pressure in  
11 the containment, is the interior of the box not  
12 pressurized?

13 MR. RENFRO: No, the box is sealed.

14 MR. EBERSOLE: So the pressure breakdown is at  
15 the box?

16 MR. RENFRO: Yes.

17 In conclusion, I would like to say that based  
18 on the design of the system, the fact -- I had better  
19 not draw the conclusions until I am finished. Let's get  
20 back to the first slide.

21 (Slide.)

22 MR. RENFRO: It showed you where the system  
23 is. Now let me tell you a little bit about how it  
24 operates. The system is redundant. It has Train A,  
25 Train B as far as power goes. Two independent trains of

1 controls. It is AC powered. It is backed by the  
2 diesels. There are only two igniters per circuit, so we  
3 feel like that adds another measure of independence. We  
4 don't feel like it is practical to place the batteries  
5 as backup for these igniters. We do not feel like the  
6 Sequoyah blackout is a likely event. We feel like there  
7 are other considerations in addition to hydrogen that  
8 would have to be dealt with for the station blackout, so  
9 we have chosen not to address that for the system.

10           The system is seismically supported. I went  
11 over the operating procedure just briefly at the  
12 beginning. It will be turned on before any hydrogen is  
13 released. The system operation is fairly  
14 straightforward. The controls are in the main control  
15 room. The operator is expected to be able to turn the  
16 system off manually when cold shutdown is achieved.

17           The system has undergone a preoperational  
18 testing. We have used 1,600 degrees Fahrenheit as the  
19 acceptance criterion. However, we have seen that both  
20 of the igniters are actually measuring around 700  
21 degrees Fahrenheit or above. We feel like based on the  
22 research that we conducted, that there is plenty of  
23 margin in that circuit's criterion.

24           MR. SHEWMON: Would you tell me again what you  
25 just said about the temperature needed for ignition? Or

1 did you say?

2 MR. RENFRO: I haven't said that.

3 MR. SHEWMON: Would you say it before you  
4 start saying what the right temperatures are then?

5 MR. RENFRO: Our testing has shown that in dry  
6 mixtures with no steam, the Tayco igniter had to reach a  
7 surface temperature of 1,200 degrees Fahrenheit. With  
8 high steam concentrations, it had to reach a temperature  
9 of 1,350 degrees Fahrenheit.

10 MR. SHEWMON: Where do you get 16 to 17 then?

11 MR. RENFRO: Sixteen was what TVA imposed as  
12 the acceptance criterion. We believe the igniter will  
13 operate at more than that, so we selected that to just  
14 make sure we didn't have any obvious problems with the  
15 hookup of the system. This is a preop test conducted in  
16 the plant.

17 MR. SHEWMON: The 17 number comes from where?

18 MR. RENFRO: The 1,700 is proposed by the NRC  
19 Staff as the acceptance criterion in the preop test.

20 MR. SHEWMON: I hope the Staff doesn't get too  
21 carried away with the wonders of high temperature,  
22 because the reliability of these things has to get worse  
23 as it goes up there, and they do oxidize, and I would  
24 encourage you not to really push any higher than you  
25 need to, but let's push on.

1           MR. RENFRO: The system is designed for 120  
2 volts. The maximum voltage it will see is around 130  
3 volts. And we have conducted tests both above and below  
4 those voltage levels, so we believe we understand how  
5 the igniters would work at those voltage levels. We are  
6 not concerned about --

7           MR. SHEWMON: You missed my point. The point  
8 is, long-term degradation, not what it takes overnight.

9           MR. RENFRO: I understand that.

10          MR. MARK: Could you remind me, you think you  
11 will ignite in dry air hydrogen mixtures as low as 1,200  
12 degrees. What kind of a mixture will you ignite at 6  
13 percent, 5 percent, 10 percent?

14          MR. RENFRO: I don't think the percent mixture  
15 makes a lot of difference. We have shown ignition at  
16 several mixtures. The importance is how much moisture  
17 is there, how much steam is there. We have shown  
18 ignition in lean mixtures of 5 to 6 percent at the 1,200  
19 degrees as long as the conditions are dry.

20          MR. MARK: Now you say you need to go to 1,350  
21 when there is steam. How much steam?

22          MR. RENFRO: About 50 percent.

23          MR. MARK: One five?

24          MR. RENFRO: Fifty, five oh.

25          MR. MARK: That is about as high as you can



1 burn it no matter what temperature.

2 MR. RENFRO: That is right. The 1,350 was the  
3 asymptote we talked about yesterday. That is about as  
4 high as you need for any flammable mixture.

5 MR. MARK: If you go to 60 percent steam, you  
6 tend to ignite it no matter what.

7 MR. RENFRO: That is correct.

8 MR. EBERSOLE: How do you know the boxes are  
9 hermetically sealed?

10 MR. RENFRO: They are sealed when they are  
11 installed. I am not familiar with the procedure. I  
12 don't believe they are pressure tested. We don't  
13 believe that even if they leak a little bit, that that  
14 is really of significant concern. They are really  
15 pressure sensitive components there. There is only an  
16 electrical connection made.

17 MR. SHEWMON: Why is it you want to go to  
18 1,600 to operate these things?

19 MR. RENFRO: For margin. The margin under  
20 cooling conditions, either with air flow, steam flow,  
21 spray flow. These tests, the preoperational tests where  
22 we try to achieve the 16 or the 1,700 degrees are  
23 conducted in ambient atmospheres with no cooling, so  
24 that is to provide margins under accident conditions  
25 where cooling may take place.

1 MR. AXTMANN: How long have you tested them at  
2 such conditions, at 1,600?

3 MR. RENFRO: The longest test we have run are  
4 a week at 120 volts, followed by a week at 135 volts.  
5 We have done conduction tests up to 24 hours' duration.

6 MR. AXTMANN: There is no real long-term test?

7 MR. RENFRO: Not longer than one week. The  
8 same igniter has been exposed to a number of tests, so  
9 cumulatively it would be over a period of several weeks,  
10 but we have not tested any for months at a time, for  
11 example. We don't believe the hydrogen situation, any  
12 kind of conceivable accident is going to stretch on over  
13 a very extended period of time.

14 MR. AXTMANN: No, but they could wear out in  
15 the meantime.

16 MR. RENFRO: They are not even energized until  
17 we feel like we get what we call an energized event.

18 MR. SHEWMON: Have you decided how many weeks  
19 a year they have to be tested, once they are installed?

20 MR. RENFRO: No, not weeks per year. I  
21 believe the current proposed technical specifications  
22 require surveillance testing to be performed quarterly.

23 MR. SHEWMON: That means you turn them on,  
24 make sure they take the right current, and turn them  
25 off, or what?

1           MR. RENFRO: Yes. The preoperational test  
2 includes measuring the voltage and the current and the  
3 temperature. That is difficult to get access to all of  
4 these igniters. As I said, some are in the dome. We  
5 have to have scaffolding built on the crane, things like  
6 that. You have to get pretty close to them to measure  
7 their temperature.

8           MR. SHEWMON: Why?

9           MR. RENFRO: We are using optical temperature  
10 measurement techniques, and the instruments that we have  
11 been using, you have to be within five or ten feet. The  
12 plugs are not very big.

13           MR. EBERSOLE: The heatup time constant for  
14 these heaters is much shorter than that of the  
15 original. How many successive ignitions are you  
16 designing for? Because each time you ignite, they will  
17 go to a peak temperature and come back before they  
18 reignite. What is the peak temperature after each  
19 hypothetical ignition beyond the 1,700 degrees that you  
20 start with? A hundred degrees? Two hundred degrees?  
21 Three hundred?

22           MR. RENFRO: It is not very much. I don't  
23 believe we have seen very much temperature rise during  
24 the combustion, but certainly no more than 100.

25           MR. EBERSOLE: This represents the duration?

1 MR. RENFRO: Yes. As I said, we have done  
2 tests up to 24 hours in duration in flowing mixtures.

3 MR. EBERSOLE: No, no, I am talking about  
4 igniting.

5 MR. RENFRO: I am talking about in combustible  
6 mixtures, in ignition.

7 MR. EBERSOLE: You mean constant ignition?

8 MR. RENFRO: Constant or periodic ignition in  
9 constant mixtures.

10 MR. RAY: Are these custom designed for this  
11 purpose, or are they used elsewhere in the industry?

12 MR. RENFRO: They were developed from existing  
13 igniter technology by Tayco Engineering, who has  
14 developed heaters for application in outer space.

15 MR. RAY: So it is a unique application?

16 MR. RENFRO: This is a unique application of  
17 that technology. I am getting behind schedule.

18 MR. SHEWMON: We thought you were about done.

19 MR. RENFRO: We could drop the research  
20 completely. I am at your pleasure. I can show one or  
21 two slides on the research if you would like to hear  
22 that.

23 MR. SHEWMON: That is fine.

24 MR. RENFRO: Let me just conclude about the  
25 system. Based on the design of the system, the number

1 and location of igniters we have, the fact that it is  
2 refundant and seismic, has a straightforward operating  
3 procedure, it has been tested before and after operation  
4 in the plant, we believe it is an improvement over the  
5 interim system, and it is TVA's conclusion that it is an  
6 adequate hydrogen control system for Sequoyah.

7 (Slide.)

8 MR. RENFRO: Let me change gears here just a  
9 little bit and talk about research. Let me just show  
10 the first slide and the last slide.

11 MR. SHEWMON: Yes, and let us ask questions.

12 MR. RENFRO: Basically, we conducted research  
13 at six facilities in cooperation with Duke Power and  
14 American Electric Power. We did some experiments in  
15 1980 at Fenwal on the GM igniter. These were the first  
16 experiments we did. We basically were trying to answer  
17 the question, does thermal ignition work in the kind of  
18 hydrogen concentration mixtures, and accident  
19 environments that we might see, and the answer was, yes,  
20 it does for reasonable mixtures.

21 In cooperation with the same two utilities,  
22 and EPRI, we sponsored experiments at four facilities.  
23 At Whiteshell in Canada, we did two series of  
24 experiments. We looked again at igniter performance  
25 similar to Fenwal. This was of the GM and the Tayco

1 igniter.

2           In a different vessel, a larger vessel, we  
3 looked at combustion phenomena. At Factory Mutual in  
4 Massachusetts, we did some small-scale tests on microfog  
5 effects. This was in preparation for further testing at  
6 Acurex in a larger vessel, where we looked at the  
7 effects of microfog and the effects of igniter location.

8           At Hanford, we did a set of containment  
9 atmospheric mixing, no combustion experiments in order  
10 to represent the lower compartment of an ice condenser  
11 plant scale geometrically. Scaled the blowdown. We  
12 used hydrogen steam blowdowns, and looked at the effects  
13 of natural circulation and forced circulation from the  
14 jet and from the fans that were sent to simulate the air  
15 circulation fans.

16           TVA has sponsored research at its Singleton  
17 Laboratory in the area of igniter durability.

18           MR. MOELLER: What is a microfog?

19           MR. RENFRO: I am not sure if microfog is a  
20 good technical term, but basically the experiments we  
21 ran were using several different nozzles in order to  
22 achieve droplets on the order of two to fifteen microns,  
23 so they are very small droplets when compared to regular  
24 containment sprays, fire protection nozzles, things like  
25 that.



1 MR. MOELLER: Thank you.

2 (Slide.)

3 MR. SHEWMON: These would tend to quench  
4 flames more easily than big drops?

5 MR. RENFRO: Yes. The experiments were  
6 carried out --

7 MR. SHEWMON: That is all. Thank you.

8 MR. RENFRO: We did see the larger the drops,  
9 the less effect on the flammability limits.

10 MR. MOELLER: I gather the microfog stays  
11 suspended.

12 MR. RENFRO: It would more than larger drops,  
13 but we really didn't study anything about suspension  
14 time.

15 Let me just summarize. From all of these six  
16 facilities, the conclusions of our research have shown  
17 the following, that igniters would burn lean mixtures in  
18 containment environments, that the effects of steam and  
19 turbulence are beneficial in reducing the pressure, that  
20 data from these experiments is self-consistent and does  
21 not conflict with the literature, that the pressure  
22 rises were always less than theoretical adiabatic, that  
23 minimum pressure rises were observed during transient  
24 tests where the flammable mixtures were introduced  
25 during the tests as they would be in a plant accident

1 environment.

2           No detonations were observed, even at  
3 stoichametric and above stoichametric concentrations.  
4 Mixing in the lower compartment as modeled was good.  
5 Igniters are durable.

6           The overall conclusion of our research, we  
7 believe that the results of the research support  
8 deliberate ignition as an adequate method of hydrogen  
9 control. The overall conclusion of the analysis system  
10 development and research is that TVA believes that since  
11 the permanent hydrogen mitigation system is an adequate  
12 hydrogen control system that is supported by research  
13 and analysis, the Sequoyah operating license conditions  
14 have been satisfied.

15           Are there any questions?

16           MR. MARK: One question. Do you happen to  
17 know if we take one of the imagined accidents like S2D  
18 or whatever, how long a period is required to bring the  
19 total air volume up to a 10 percent hydrogen mixture,  
20 for example?

21           MR. RENFRO: I would really prefer not to talk  
22 about the analysis.

23           MR. MARK: Do you have a feeling for that? It  
24 is not in a matter of a minute or two.

25           MR. RENFRO: Oh, no, certainly not. It would

1 be on the order of a couple of hours or three hours  
2 probably.

3 MR. MARK: It is that number that I was  
4 believing to be the case.

5 MR. RENFRO: We have seen release rates on the  
6 order of a pound a second, something like that. One or  
7 two pounds a second.

8 MR. MARK: And you can stand a global burn of  
9 10 percent.

10 MR. RENFRO: The reason we had the distributed  
11 ignition was to prevent global burns.

12 MR. MARK: I understand, but your AC might be  
13 off for a while, and if you get to 10 percent and have a  
14 global burn, I think you are still alive. That is a  
15 question, not a statement.

16 MR. RENFRO: We have not analyzed that event.  
17 Global burns in the upper compartment, unless they are  
18 mitigated by the sprays, which are also on the diesel,  
19 would probably overpressurize the Sequoyah containment.

20 MR. MARK: Well, you are not overpressurized  
21 at 36 pounds, or perhaps even at 50. Ten percent will  
22 only give you about 50.

23 MR. SHEWMON: Is that adiabatic?

24 MR. MARK: That is adiabatic, and you don't  
25 get adiabatic pressures because of the radiation.

1 MR. RENFRO: That is correct. We haven't  
2 analyzed that particular accident.

3 MR. RAY: Let's suppose the extreme happens,  
4 and you have a blackout with hydrogen generation. How  
5 long would it take TVA to get a portable gasoline driven  
6 generator up to 3,500 kilowatts from somewhere else in  
7 the distribution system? More than an hour?

8 MR. RENFRO: I can't answer that. I don't  
9 know if there is anyone in the audience that can.

10 MR. RAY: I should think you have 'em  
11 available for emergency distribution purposes.

12 MR. KERR: What is the power requirement?

13 MR. RAY: Thirty-five kilowatts. You can buy  
14 one from Sears and get it.

15 MR. RENFRO: We don't believe that station  
16 blackout is a likely event.

17 MR. RAY: I know, but it is nice to have a  
18 trump card in case the hand goes that way.

19 MR. RENFRO: If we had a station blackout, I  
20 am not sure the hydrogen igniters would be the most  
21 important thing we would want to repower anyway. I  
22 think we would be more concerned about adding water to  
23 the core and preventing hydrogen.

24 MR. RAY: Well, you can't buy a portable  
25 generator for that purpose. It is miniscule.

1           MR. BENDER: The quarterly testing plan is  
2 what? You just turn them on and measure the power input  
3 to them, or what?

4           MR. RENFRO: What TVA has proposed is that we  
5 do just that. In the preop tests, we were going to  
6 record the voltage and the current at each of these 32  
7 circuits, and also record the temperature. Now, in the  
8 surveillance test that will be done quarterly, we will  
9 go back and remeasure that voltage and current in each  
10 one of the circuits to compare that with the baseline  
11 measurements that were taken during the original preop  
12 test. We ion't propose to go back and actually measure  
13 the temperature in each igniter because of the  
14 accessibility problem.

15           MR. BENDER: I am not arguing that you need  
16 to.

17           MR. SHEWMON: Has the Staff agreed to that  
18 plan?

19           MR. RENFRO: The Staff's last version of the  
20 SER agrees to the plan and goes on to say the Staff may  
21 require temperature of igniters to be measured at  
22 specified intervals. So in essence they have agreed  
23 partially, but have gone beyond that requirement.

24           MR. YERR: What is the color of these things  
25 at operating temperature?

1 MR. RENFRO: Redish orange.

2 MR. SHEWMON: Very red?

3 MR. KERR: I don't think it is very difficult  
4 to measure that. Why don't you look at them?

5 MR. SHEWMON: The oldest known optical. I  
6 don't know if the Staff would accept it or not.

7 MR. RENFRO: What we are using in the test is  
8 an optical pyrameter.

9 MR. MOELLER: Your presentation, of course,  
10 presents the conclusion that you have the problem  
11 solved. I am curious. I am sure you have a staff  
12 within TVA that has looked at this. I was wondering if  
13 this was the unanimous opinion of all those who are  
14 working on the problem, or if you have any of your  
15 scientific staff who have questions about the  
16 conclusions that you have presented to us.

17 MR. RENFRO: We haven't taken an opinion poll,  
18 but I don't believe there are any dissenting opinions.  
19 I believe that all the engineering staff believes this  
20 is an adequate control system. We do not foresee any  
21 major problems with its application for Sequoyah.

22 MR. MOELLER: Thank you.

23 MR. MARK: Thank you, Mr. Renfro. I think we  
24 had best move on, and call on Carl Stahle, who will  
25 introduce the rebuttal by the Staff.



1           MR. STAHLER: This is Carl Stahle. I am the  
2 NRC project manager. I will dispense with the few  
3 slides I have with respect to background, but I would  
4 like to make a few introductory comments before the  
5 principal review.

6           I want to emphasize a number of points. First  
7 of all, when Unit 1 and Unit 2 were licensed for power,  
8 there was a mandate from the Commissioners themselves  
9 with respect to the hydrogen issue. I must emphasize  
10 again that it says that the Commission, as I read from  
11 this, must confirm that an adequate hydrogen control  
12 system for the plant is installed and will perform its  
13 intended function in a manner that provides adequate  
14 safety margins. That will be the subject of the meeting  
15 on December the 15th, and of course the Europeans'  
16 opinion on this will be of interest to ourselves as well  
17 as to the Commission.

18           I point out two documents that I think are of  
19 importance. One is provided by TVA. It is their  
20 executive summary report.

21  
22  
23  
24  
25

1           It is a summary of a vast amount of  
2 information and analysis that's been provided, and it is  
3 an executive summary report. The other document, of  
4 course, is our own SER supplement number 6 that states  
5 quite clearly our opinion and evaluation of the adequacy  
6 of the system.

7           I turn your attention to the last portion of  
8 supplement number 6; that is the conclusions. You will  
9 hear today a summary of the review, and there are two  
10 items that we consider open. One is, of course, the  
11 number of igniters in the compartment. We have  
12 suggested four additional igniters in the upper  
13 compartment, and we understand that TVA will go along  
14 with that recommendation.

15           The second portion deals with further tests  
16 that will be needed with respect to those igniters in  
17 the upper compartment itself. We do not believe there  
18 has been sufficient data accumulated on the igniters'  
19 performance in the kind of environment that they will  
20 during an accident. The staff will, of course, provide  
21 more detail on this as we go along.

22           With those few introductory remarks, I'll pass  
23 it on to the principal reviewer, Charlie Tinkler, who  
24 will give us a presentation of the staff's view on these  
25 matters.

1 MR. SHEWMON: Since you went over this at the  
2 subcommittee, please walk on up. Just develop what you  
3 need for the conclusions, and not all of it.

4 MR. TINKLER: This list represents our  
5 proposed agenda for this discussion. Briefly, we intend  
6 to go over a summary of the review areas, those  
7 remaining open items, confirmatory items that the staff  
8 sees. We will tell you what's new since January 81,  
9 what have we learned from the research, a comparison of  
10 the permanent hydrogen mitigation system versus the  
11 interim distributive ignition system. We will briefly  
12 discuss AC power dependence of the PHMS and overall  
13 staff conclusions.

14 (Slide.)

15 This viewgraph summarizes the major areas of  
16 the staff review for which favorable findings have been  
17 reached subject to the satisfactory resolution of two  
18 items. These include the nature of the PHMS design,  
19 hydrogen control research conducted by both the industry  
20 and the NRC, the consideration of the spectrum of the  
21 degraded core accidents, containment hydrogen analysis,  
22 structural capacity of Sequoyah and essential equipment  
23 survivability.

24 (Slide.)

25 And all of these things are on the slide. As

1 previously stated, the staff sees two remaining open  
2 items which we would hope to address by license  
3 conditions. The first is a requirement to increase the  
4 number of igniters by four in the upper compartment.  
5 The intent is to improve the coverage in that region of  
6 the containment. We would propose that with staff prior  
7 approval of location, that this work be completed by  
8 startup upon the second refueling outage.

9           The second item is a requirement to perform  
10 additional testing of the Tayco igniter. We feel that  
11 additional testing should be required to demonstrate  
12 that Tayco igniters will reliably ignite lean mixtures  
13 of hydrogen in a spray environment, and we would expect  
14 that testing to be completed by September of 83.

15           MR. KERR: Is there some reason to think that  
16 any igniter will ignite in a spray environment?

17           MR. TINKLER: The vast bulk of combustion and  
18 igniter testing performed in the past two years has been  
19 performed with either a spark igniter or the GM glow  
20 plug igniter, and those igniters have performed in  
21 combustion tests in spray environments.

22           MR. SHEWMON: What do you mean by spray as  
23 opposed to fog? If you play a hose on it, it probably  
24 won't work.

25           MR. TINKLER: What we mean by spray is a spray

1 environment representative of the Sequoyah upper  
2 compartment.

3 MR. SHEWMON: Is that a nozzle aimed at it, or  
4 having a fog around it?

5 MR. TINKLER: We would expect that the  
6 majority of the spray droplets would have reached  
7 terminal velocity, that the spray pattern would be  
8 relatively uniform and that there would be turbulence  
9 induced by de-acceleration of spray droplets.

10 MR. BENDER: What is the source of the  
11 droplets? Are you presuming this is in the steam  
12 environment?

13 MR. TINKLER: These are the containment spray  
14 droplets; the 500 microns. I'm not referring to  
15 micro-fog; I'm referring to the droplets produced by the  
16 containment spray nozzles.

17 MR. SHEWMON: So presumably these things won't  
18 be located in the direct path of the spray? But you  
19 want to know whatever turbulence would bring to them of  
20 this is of concern to you? Is that right?

21 MR. TINKLER: That is correct.

22 MR. MARK: Let's see, the four you're asking  
23 for will be directly in the path of the spray.

24 MR. TINKLER: Well, they're not directly in  
25 the path in that there are spray shields over all the

1 igniters located below the spray headers. Now, if one  
2 were to compute a supposed angle of spray trajectory, I  
3 suppose you could determine a certain percentage that  
4 they directly impinge, but that would presume knowing  
5 conditions much better than we think anyone does.

6 MR. MARK: There will at least be a half a  
7 dozen or so igniter. that are not in the line of any  
8 spray.

9 MR. TINKLER: There are four igniters above  
10 the spray header.

11 MR. MARK: And the air in the upper  
12 compartment will be beautifully mixed by the action of  
13 the spray so the upper igniters will really have a very  
14 good chance to work.

15 MR. TINKLER: That is true. And we are not  
16 proposing that the unit not start up because of  
17 uncertainties regarding spray tests with igniters. We  
18 believe there is a level of confidence that says those  
19 igniters, or at least some of those igniters in that  
20 region will work to reliably ignite lean mixtures.

21 But given that this is a principal component  
22 of the hydrogen mitigation system, we feel like the  
23 majority of the igniters in that upper compartment  
24 should be demonstrated to work.

25 MR. MARK: I'm just thinking that with the



1 nice mixing with the spray you almost only need one.

2 What do you mean by a lean mixture?

3 MR. TINKLER: Six percent or less.

4 MR. MARK: Less than six?

5 MR. TINKLER: The test data that has been  
6 compiled to date, the tests that have been compiled and  
7 performed to date indicate that the mixtures for dynamic  
8 test with the continuous injection of hydrogen and steam  
9 almost certainly ignites hydrogen before six percent is  
10 reached. I hate to cite six percent as a dividing  
11 line. It may be -- I'm quite sure one could tolerate  
12 the combustion of seven percent hydrogen, but I cite  
13 that number in comparison to 10 percent.

14 MR. KERR: But you must know what you want TVA  
15 to demonstrate. What sort of mixture must they  
16 demonstrate?

17 MR. TINKLER: I would cite as a target six  
18 percent hydrogen. Now, if one could demonstrate through  
19 analysis that you could tolerate the combustion of a  
20 mixture not quite so lean, then that would be an  
21 acceptable alternative.

22 MR. MOELLER: When you tested the plugs and  
23 igniters, were they covered with a spray shield?

24 MR. TINKLER: Yes. In one instance the  
25 utility reported to us that the glow plug igniter simply

1 was turned upside down in the vessel with the sprays  
2 operating and with the injection of hydrogen and steam.  
3 But in general, they were in vessels with a spray shield.

4 MR. MOELLER: I guess what my thought was, I  
5 wondered if this interferes with the circulation of air  
6 around the plug.

7 MR. TINKLER: There were some concerns stated  
8 over that matter by, I believe, consultants to the ACRS.

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 (6:00 p.m.)

2 MR. TINKLER: The staff is inclined to believe  
3 that in the upper compartment the mixing would be rather  
4 vigorous and the effects of the spray shield would  
5 probably not be too large.

6 MR. MOELLER: It would probably not be too  
7 large, but it's an assumption.

8 MR. TINKLER: Well, --

9 MR. MOELLER: I'm just curious. Have tests  
10 been done to really show --

11 MR. TINKLER: Tests have been done with the  
12 spray shield in place. It did not indicate that the  
13 spray shield had any damaging effects or limiting  
14 effects on the combustion process.

15 MR. MOELLER: That's what I wanted to hear.

16 MR. SHEWMON: Please go on.

17 (Slide.)

18 MR. TINKLER: We listed several confirmatory  
19 items in the SER. I'd like to briefly go over the items  
20 and the programs we expect would address them. Local  
21 detonations -- the staff has stated that we agree with  
22 TVA that the probability of detonations is remote in the  
23 Sequoyah containment and need not serve as a licensing  
24 basis for the PHMS.

25 But we do intend to perform some additional

1 confirmatory work to determine the consequences of  
2 presumed detonations. We expect that we will continue  
3 to look at the various containment codes and their  
4 capability to calculate combustion events.

5 (Slide.)

6 We expect to continue investigation of  
7 equipment survivability for various accidents and  
8 analytical assumptions, review the performance of  
9 large-scale combustion tests at the Nevada test site as  
10 an important confirmatory item, as well as the continued  
11 study of combustion phenomena by the Office of Research  
12 through Sandia National Laboratory.

13 (Slide.)

14 What is new since January 81? Probably not a  
15 whole lot new. Most of the items we cite are merely  
16 confirmations of things we believed to be true before.  
17 That is, we can achieve reliable ignition of lean  
18 hydrogen-air steam mixtures under dynamic conditions.  
19 The tests have provided confirmation that containment  
20 mixing is adequate. Further confirmation that the  
21 threats from detonations are small. This confirmation  
22 is derived from experience in several areas. The  
23 above-cited reliable ignition and mixing, continued  
24 Sandia investigation of detonations has demonstrated the  
25 difficulty in initiating and propagating detonations

1 under a variety of conditions.

2 Earlier calculations on assumed upper plenum  
3 detonations have been revised. Earlier Sandia performed  
4 calculations published in NUREG 2385, which indicated  
5 that containment pressure loadings exceeded acceptable  
6 impulsive load values for the containment based on a  
7 conservative structural model. Refined calculations  
8 indicate that containment integrity is not threatened.

9 We repeat, this is with an assumed detonation;  
10 not one that was calculated to occur.

11 MR. MOELLER: Are the fans in the containment  
12 on emergency power?

13 MR. TINKLER: Yes, sir.

14 MR. EBERSOLE: Do you not have large amounts  
15 of polyurethane insulation in your ice rack containment  
16 area? Is that fully encapsulated?

17 MR. TINKLER: Yes, it is.

18 MR. EBERSOLE: Does it breathe with respect to  
19 the containment atmosphere?

20 MR. TINKLER: It does not directly breathe  
21 with respect to the containment atmosphere, I believe.

22 MR. EBERSOLE: Would you argue that hydrogen  
23 combustion in the area where the ice pack is now would  
24 not communicate with that polyurethane?

25 MR. TINKLER: It is extremely unlikely.

1 During the review of the interim ignition system and the  
2 interim distributive ignition system some very  
3 conservative calculations were performed which assumed a  
4 flame to stand at one location for 45 minutes. Which is  
5 fairly preposterous.

6 MR. EBERSOLE: There would be no pressure  
7 differential on that.

8 MR. TINKLER: In the calculations --

9 MR. EBERSOLE: I'm thinking about a puff of  
10 flame igniting -- it has one important polyurethane --

11 MR. TINKLER: We have no reason to believe  
12 that's a problem. As an additional measure we have  
13 required all ice condenser owners to terminate actuation  
14 of the air handling systems which cool the ice  
15 condensers so that hot mixtures would not be drawn in  
16 the cooling ducts of the ice condenser itself, and that  
17 is a part of the emergency procedures guidelines.

18 MR. MARK: The main effect of burning your  
19 polyethylene, Jesse, would be to exhaust the oxygen so  
20 you couldn't burn any hydrogen.

21 MR. SIESS: Please go on.

22 (Slide.)

23 MR. TINKLER: A comparison of the permanent  
24 versus the interim hydrogen igniter systems shows a  
25 difference in the power distribution systems. The PHMS



1 has two trains, 16 circuits per train, two igniters per  
2 circuit, actuated from the main control room. The IDIS  
3 can off the three emergency lighting circuits, 15  
4 igniter circuits controlled from the aux building.

5 To briefly summarize the igniter  
6 characteristics and a comparison of the igniter  
7 locations.

8 (Slide.)

9 A very short viewgraph on dependence. The  
10 staff's position is that the power supply to the PHMS is  
11 acceptable, and specifically that a backup battery  
12 system for the PHMS is not required. The basis is that  
13 the PHMS is designed for most recoverable severe  
14 accidents, and that a loss of all AC power is not a  
15 dominant contributor to risk.

16 MR. MOELLER: When you say not dominant, how  
17 much of a contributor is it?

18 MR. TINKLER: Perhaps Dr. Butler would like to  
19 address this.

20 MR. BUTLER: We were relying on some of the  
21 results from the RSNAP studies which concluded that the  
22 dominant contributors were four or five items including  
23 the S2D sequence. None of these dominant ones included  
24 in the loss of all AC power. The loss of all AC power  
25 situation, we are about a decade down in probability.

1           MR. KERR: Did that take into account that the  
2 loss of all AC power could trigger early containment  
3 rupture? This is not your conventional loss of AC  
4 power, necessarily.

5           For example, you wouldn't get this in the  
6 large dry containment at all.

7           MR. BUTLER: It might be helpful to follow  
8 through briefly a sequence where you have loss of all AC  
9 power. TVA has done some analysis of this in response  
10 to a staff request, and as the vessel water level dries  
11 up where the water starts, just beginning to uncover the  
12 core, if you take that as your time zero and follow  
13 through the sequence after that, it takes around another  
14 15 minutes or 20 minutes beyond that for the water level  
15 in the core to come down to about one-third of core  
16 height.

17           At about that time, you start overheating the  
18 upper section of the fuel and will probably just begin  
19 to produce metal-water reaction in the core.

20           Now, you have around 15 minutes or so of that  
21 kind of activity, beyond which you will experience the  
22 core slump scenario. We consider that clearly no longer  
23 a recoverable situation and beyond the design  
24 requirements of this mitigation system.

25           Now, in that 15-minute period, the water level

1 going from one-third down to core slump, the amount of  
2 hydrogen that escapes from the primary system through  
3 the PORV or high point vents into the containment has  
4 been calculated by TVA to be a little over 30 pounds.

5           Now, if that were to be ignited by an  
6 inadvertently-activated ignition system, that produces  
7 quite a tolerable pressure rise.

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1           MR. KERR: You're telling me, then, that the  
2 hydrogen that will be produced by itself would not  
3 overpressure the containment?

4           MR. BUTLER: For those recoverable sequences.  
5 If the amount of hydrogen that is transferred into the  
6 containment is beyond what can be tolerated by the  
7 containment, those sequences are not recoverable anyway  
8 in the sense that you would have proceeded to full core  
9 melt.

10           MR. KERR: But it seems to me this could have  
11 a significant effect on risk. That's why I asked if you  
12 had looked at it. The time at which you get containment  
13 rupture it seems to me is likely to have some  
14 significant effect on risk, and if you can burn the  
15 hydrogen it seems to me you are likely, even though you  
16 may get complete core melt, to contain fission products  
17 for a while and give them a chance to decay, whereas if  
18 you get an overpressurization early on it seems to me  
19 that that might have an influence on risk.

20           I certainly haven't done the calculation, but  
21 that's why I asked the question. It appears to me that  
22 there could be a difference.

23           MR. NOVAK: This is Tom Novak on the Staff.

24           We did discuss this specific point with the  
25 consultants at Sandia. It is my understanding that the

1 difference in the time periods between loss of  
2 containment is relatively small. In other words, if you  
3 assume I am not going to have any AC and I'm going to  
4 have a full core melt and I just say, what's the  
5 difference on whether I fail it because I worry about  
6 the hydrogen or not, that difference in time is not  
7 important.

8 MR. KERR: You've looked at it. I am puzzled  
9 that there's not more difference in that.

10 MR. NOVAK: Perhaps because of the specific  
11 application at Sequoyah, the difference in time you buy  
12 between worrying about the containment going or not  
13 going because of hydrogen is something less than an  
14 hour.

15 MR. KERR: If that's the case, fine.

16 MR. SHEWMON: Onward.

17 MR. MARK: Do you have anything else, Mr.  
18 Tinkler?

19 (Slide.)

20 MR. TINKLER: My summary conclusion slide says  
21 that the PHMS is acceptable for an interim period  
22 pending completion of ignition testing with the Tayco  
23 igniters and is subject to installation of four more  
24 igniters in the upper compartment. I would like to  
25 repeat that further confirmatory testing by the Staff

1 and the EPRI is needed and will be performed at the  
2 Nevada test site.

3 MR. MARK: What will be the objective of this  
4 further testing that is needed?

5 MR. TINKLER: To resolve any concerns --

6 MR. MARK: The spray business?

7 MR. TINKLER: That arise as a result of most  
8 of our combustion testing and equipment survivability  
9 testing having been performed in small-scale vessels.

10 MR. MARK: I forget if you actually mentioned  
11 your conclusion with respect to equipment  
12 survivability. Does the Staff have one? Perhaps I just  
13 missed it.

14 MR. TINKLER: I stated earlier that, with the  
15 exception of two open items, the Staff has reached  
16 favorable findings on all of those items.

17 MR. MARK: I think that is all we had  
18 planned.

19 Paul?

20 MR. NOVAK: Dr. Shewmon, I have one more  
21 comment. I know the Committee has not yet had an  
22 opportunity for an early submittal of discussions  
23 earlier. I do feel I would just like to point out for  
24 the Committee's benefit -- it will just take a moment or  
25 two -- that the Staff has re-evaluated its position as



1 it was expressed earlier in the week.

2           If you would look at the presentation in terms  
3 of the required testing, when we talked to the  
4 Subcommittee on Tuesday of this week we were looking for  
5 a demonstration that the Tayco heaters, the ones planned  
6 to be installed, be shown to maintain the surface  
7 temperature on the order of 1300 degrees in a spray  
8 environment that we would predict or expect to be there  
9 in the upper containment of Seguoyah.

10           My view is that the Subcommittee and  
11 consultants gave us enough to think about with regard to  
12 whether or not this Tayco heater would be even subject  
13 to quenching in that environment, we went back and we  
14 looked at our own position and the data that we had that  
15 suggested that simply running a spray test and showing  
16 that for those environments you would maintain 1500  
17 degrees.

18           We modified our view to the point that it  
19 said, if you believe these igniters are going to work,  
20 ignition is the proof of principle. So if you look at  
21 it some time later and see a difference in our position,  
22 it is in fact that, that we believe now that the most  
23 straightforward way to demonstrate the useability of  
24 this ignition system is to demonstrate that the Tayco  
25 igniter would operate in an environment, in an accident

1 environment, that is under a spray environment.

2 MR. SHEWMON: Would you also look when you get  
3 into that whether or not somebody could stand, once he  
4 had voltage and current readings, with a pair of  
5 binoculars and see if it was just there and if it might  
6 work as well for a temperature indication?

7 MR. NOVAK: I'm sure we're open to those  
8 suggestions.

9 MR. MARK: Is there a place in which this  
10 ignition check that you just described, Tom, can  
11 straightforwardly be done?

12 MR. NOVAK: Yes, there is. In fact, we did  
13 talk to our research people and there are facilities  
14 available in an early time frame at Sandia National  
15 Laboratories for spray tests of the Tayco igniter which  
16 could be performed.

17 MR. MARK: And one could put on a hat of the  
18 sort TVA is thinking about and simply ask the question,  
19 with the sprays turned on does it kick off six or seven  
20 percent hydrogen?

21 MR. NOVAK: Yes. But let me caution you,  
22 because it is very difficult to get one simple test run  
23 where you do take all the conditions. People will argue  
24 about you have the exact spray that you are looking for,  
25 do you have the distribution you are looking for. It is

1 going to be a give and take.

2 I don't think I can say quickly I can run a  
3 test that will quickly demonstrate it unless you can  
4 stick it on a pot of water.

5 MR. MARK: You have a chamber within which  
6 spray can be introduced, igniters can be introduced, you  
7 can demonstrate that in the course of a few weeks.

8 MR. NOVAK: In my judgment, that's what I'm  
9 looking for, yes, sir.

10 MR. RENFRO: Mr. Chairman, if I could have  
11 just one moment to show one more slide that relates to  
12 this.

13 MR. SHEWMON: Fine.

14 MR. RENFRO: I really didn't want to get back  
15 up here, but I figured you all hadn't seen any examples  
16 of my artwork, so I would let you.

17 (Slide.)

18 This summarizes an argument that I will try to  
19 lead you through and tell you what spray testing TVA has  
20 done, so that you can know what the situation is. We  
21 are talking about doing tests in a spray environment  
22 that simulates the upper compartment. I guess there is  
23 some question about how turbulent the upper compartment  
24 really is.

25 TVA made an effort to run small-scale tests

1 using a single nozzle and an igniter assembly, with  
2 turbulence simulated by a fan, to simulate the upper  
3 compartment conditions, and was unsuccessful in  
4 satisfying the Staff with these types of tests. So I  
5 don't believe we're going to be able to run a simple  
6 test, as might have been described just a few moments  
7 ago, and truly simulate upper compartment turbulence.

8           Let me tell you what we have done. We have  
9 run tests -- even though the igniter has a spray shield,  
10 we have run tests to look at the cooling effect from  
11 turbulence that may swirl these fairly high containment  
12 spray droplets up underneath the spray shield. We've  
13 done tests both with the spray shield in place, using  
14 fans to provide this turbulence. We were unable to  
15 satisfy the Staff that we had accurately simulated the  
16 upper compartment turbulence levels.

17           We have done other -- being unable to do this,  
18 we've done other tests where we completely removed the  
19 spray shields, the direct impingement spray shields on  
20 the igniters. We feel like we have a good handle on the  
21 cooling effects of spray due to direct impingement.  
22 These numbers are shown over here on the side.

23           MR. SHEWMON: Would you back out of in front  
24 of the numbers. Thank you.

25           MR. RENFRO: If one removes the spray shield,

1 this is the mass flux expected in the containment.  
2 Taking the total flow rate divided by the area, you get  
3 about one gpm per square foot. If you take that mass  
4 flux, using a single nozzle at the right elevation to  
5 simulate that flux, pass it directly over the igniter  
6 without any spray shield, we saw these temperature  
7 results:

8           At 120 volts AC, which as I said this is the  
9 minimum this system will operate at -- we expect  
10 slightly higher voltage during normal operation. But at  
11 any rate, the system could tolerate 20 percent direct  
12 spray where 100 percent was the containment condition  
13 and still maintain the Staff-proposed surface  
14 temperature of 1500 degrees, which has quite a bit of  
15 margin in it.

16           We can take 60 percent direct spray, maintain  
17 the 1350 which would seem to be the maximum temperature  
18 required even at high steam environments. We believe  
19 the temperature is actually somewhat lower at which  
20 ignition would actually occur, so we believe there is  
21 some margin even in this 1350.

22           IVA also in addition during these direct spray  
23 tests modified the spray shield. As I said earlier, the  
24 spray shield used to cover an angle of about 20 or 25  
25 degrees. We have enlarged it to cover an angle of 50

1 degrees. So any spray in either turbulence would have  
2 to come in at an angle that's more horizontal than  
3 vertical.

4           We have shown that even given this spray  
5 shield and a more horizontal than vertical turbulence,  
6 up to 60 percent of the total vertical possible mass  
7 flux could be tolerated and still maintain the 1350. So  
8 we feel we've done direct spray tests which tell us how  
9 the igniter cools, we've been responsive in enlarging  
10 the spray shield to what we believe according to our  
11 engineering judgment, given the location and the  
12 expected turbulence levels in containment, would more  
13 than adequately protect the igniter in the spray  
14 environment. And we believe it would continue to  
15 function.

16           MR. SHEWMON: Do you feel you understand what  
17 it is the Staff would require for additional tests?

18           MR. RENFRO: We have some information on the  
19 tests that Mr. Novak was referring to. That information  
20 showed that the flow rates achievable in the particular  
21 vessel were not as high as 100 percent and the velocity  
22 --

23           MR. SHEWMON: It's not as high as 100  
24 percent?

25           MR. RENFRO: No, which we were able to achieve



1 in our tests.

2 In addition, the velocity at the igniter plane  
3 was higher than the terminal velocity, which was another  
4 concern. The Staff-proposed facility had two of the  
5 shortcomings that the Staff has found in our own tests.

6 We feel like small-scale tests that would  
7 adequately simulate upper compartment turbulence, which  
8 is the real matter at hand, would be difficult to define  
9 or difficult to carry out with reasonable acceptance.

10 MR. KERR: Do I take it your answer is no or  
11 yes?

12 MR. RENFRO: I'm sorry, maybe I missed the  
13 question.

14 MR. KERR: I thought he asked whether you  
15 understood what the Staff wanted you to test.

16 MR. RENFRO: We understand that. The Staff  
17 would like us to simulate the upper compartment  
18 turbulence. I don't believe that was the question,  
19 though.

20 MR. SHEWMON: One of the jokes around here  
21 is: Go get me a rock. I don't know what a rock is, but  
22 bring me something and I'll tell you if it's a rock.

23 Now, the question is, have you been sent out  
24 after a rock? Your last answer was, we're supposed to  
25 simulate turbulence, and that is a rock.

1           MR. RENFRO: We brought back about a half a  
2 dozen rocks and the Staff has proposed rock number three  
3 or rock number four.

4           We admit that it is a difficult problem to  
5 simulate upper compartment turbulence due to spray in a  
6 small-scale test. That is where we find the concern.  
7 We could conduct such a test, but we are not convinced  
8 that an acceptance criterion could be defined that would  
9 really mean anything.

10          MR. SHEWMON: Does the Staff want this done on  
11 a facility they have more familiarity with?

12          MR. NOVAK: Let me explain. The question was  
13 asked of me, did the Staff -- was there a facility that  
14 the Staff knew about today where you could perform a  
15 Tayco ignition test. I didn't mean to suggest that the  
16 capability of that scale test would solve all of the  
17 questions that were put on the table.

18          What I was trying to say and suggesting is  
19 that when we looked at the residual question regarding  
20 the efficacy of this Tayco heater to work, the question  
21 was in the spray environment. And I think one has to  
22 recognize that this spray environment is truly a header  
23 spray with all the containment sprays on. I think one  
24 comes away with the feeling that this is really a rain  
25 shower.

1 MR. SHEWMON: And as you turn some off --

2 MR. NOVAK: You need sprays for good mixing.  
3 You don't want to turn the sprays off. You want to  
4 demonstrate --

5 MR. SHEWMON: I didn't say all; I said some.

6 MR. NOVAK: The question then is, is there a  
7 way we can get to the bottom answer of the question.  
8 Can we get a test that suggests that these Tayco heaters  
9 would in fact ignite lean mixtures of hydrogen in the  
10 environment post-accident?

11 I am not convinced that the Staff would say  
12 that the facility that we have available to us at Sandia  
13 would answer our question. What we're saying is we  
14 believe there is a range of testing that could be done,  
15 and we have suggested that you have until September of  
16 '83 to accomplish these things.

17 In response to Dr. Mark, I was talking about  
18 tests --

19 MR. SHEWMON: Can you tell what the  
20 specifications for this rock would be ahead of time, or  
21 are they going to bring in three more rocks?

22 MR. NOVAK: You have your rocks and I have my  
23 rocks.

24 I'm not suggesting that this is not a  
25 difficult phenomena to understand.

1 MR. SHEWMON: It sounds like you're saying, I  
2 don't know what the rock would look like yet.

3 MR. NOVAK: Let me say this. Let me say if I  
4 look at two or three different rocks I've got a  
5 sensitivity study and I will make a judgment based on  
6 that.

7 MR. KERR: Well, Mr. Novak, what is the  
8 deficiency in the tests that TVA has run up to now?

9 MR. NOVAK: I would like Dr. Butler to answer  
10 that.

11 MR. KERR: You said you were going to make  
12 some judgments on the basis of new tests. Are you also  
13 going to ask him to tell you what your judgments are  
14 once you do those?

15 MR. NOVAK: You asked me what was my judgment  
16 with regard to what would be an acceptable test.

17 MR. KERR: No, I say what is the deficiency in  
18 the test that TVA has run in your view.

19 MR. NOVAK: Would you accept --

20 MR. KERR: I would be interested in your  
21 view. I would be interested in his, too, but maybe the  
22 Staff's view is monolithic on this. If so, I'm willing  
23 to listen to a spokesman.

24 MR. NOVAK: All right, I'll give you my view.  
25 My view is, when I look and listen to the arguments on

1 both sides of the table, the technical arguments, the  
2 people that are looking at this thing have been looking  
3 at it long and hard for a year, and I come away with the  
4 view that if you can get away from the argument I think  
5 that a demonstration test of the Tayco heater in a spray  
6 environment will solve our questions today and next  
7 year.

8           That is the way I look at it. I didn't want  
9 to get into -- I can't at this time specify the  
10 specifics. But I just think that from a resolution  
11 point of view we could be here next year argument.

12           MR. BENDER: Wasn't the test that TVA  
13 described in a spray environment? What's different  
14 about it and the one you want them to run?

15           MR. NOVAK: There are differences.

16           MR. BENDER: Maybe we ought to get that  
17 clarified.

18           MR. SHEWMON: You sounded like you didn't  
19 think they'd run any spray environment tests yet.

20           MR. BENDER: Mr. Chairman, let's just get the  
21 differences.

22           MR. SHEWMON: I don't think he can give them.

23           MR. MARK: The tests run have measured  
24 temperature of the igniter without having the hydrogen  
25 around to check ignition. I believe that what Tom is

1 telling us is he'd like to see a spray on, the heck with  
2 the temperature; does it or does it not ignite.

3 MR. KERR: Is that the issue? These were run  
4 without hydrogen?

5 MR. NOVAK: The ones with the Tayco --

6 MR. KERR: The TVA tests were run without  
7 hydrogen, so they did not test ignition; is that right?

8 MR. MARK: They tested cooling.

9 MR. KERR: Some are saying yes and some are  
10 saying no, if I interpret the test correctly.

11 MR. RENFRO: The TVA test did study cooling.  
12 It measured cooling with a thermocouple. No hydrogen  
13 was present.

14 MR. KERR: You haven't measured actual  
15 ignition?

16 MR. RENFRO: We correlated the surface  
17 temperature in the spray tests and they were measured in  
18 combustion tests.

19 MR. KERR: Is that the problem as far as  
20 you're concerned, Mr. Novak, that they didn't actually  
21 measure ignition?

22 MR. NOVAK: I would agree that to reach  
23 resolution I would prefer to go with an ignition test  
24 and a number of additional tests to measure temperatures  
25 of the heating element.



1 MR. SHEWMON: Do we know what a spray is? Is  
2 that easy to specify? There seem to be sprays and  
3 sprays. Some tests are sprays and others aren't  
4 adequate sprays.

5 MR. NOVAK: I think there is a spray test that  
6 we could specify that would satisfy our requirements.

7 MR. SHEWMON: But you haven't yet.

8 MR. NOVAK: Well, we haven't put it down on a  
9 piece of paper, but I do think we're very close to  
10 having it. We have worked hard with TVA. We are very  
11 close to a range of additional tests that we thought  
12 would do it. So it isn't a question of us going back  
13 and thinking about it. I think we're very close to  
14 having what we consider to be a range of spray that  
15 would cover a reasonable estimate of what the  
16 environment would be in the upper compartment of an ice  
17 condenser.

18 MR. SHEWMON: Carson, I guess as Chairman of  
19 the Subcommittee and the one who has to draft this  
20 letter, do you wish to hear the Staff discussion of the  
21 inadequacies of the TVA spray test, or did you hear that  
22 in the Subcommittee?

23 MR. MARK: Oh, look. I think we have really  
24 heard as much as is useful, Paul.

25 TVA tests with spray measured temperature. If

1 they had managed to measure a temperature of 1500  
2 degrees, the Staff would have gone home happy because  
3 they think 1500 is the magic number. They admit that  
4 under some circumstances you can ignite at lower  
5 temperatures, and TVA found lower temperatures and TVA  
6 cannot prove that the temperature will not be affected  
7 by the spray and go down, and in fact it will. They  
8 think it will still ignite at 1350. I guess I imagine  
9 it will, too, but I don't really know.

10 Tom's last statement, which was new and not, I  
11 believe, gone over with the Subcommittee, was that they  
12 can think of a test with a variety of sprays, that they  
13 would probably like to try two or three intensities, and  
14 if the Tayco thing ignites, cooled to whatever extent it  
15 might be by that spray, then they would feel that really  
16 covers the point that needs to be covered.

17 MR. NOVAK: Hopefully for all time.

18 MR. MARK: And if they have an apparatus --  
19 and that's why I asked the question that way -- an  
20 apparatus in which this could be done, I think it would  
21 be a very worthwhile thing to do, so that everybody  
22 comes out saying, that's fine.

23 I believe that TVA is not well prepared to  
24 combine spray and ignition in the apparatus that they  
25 have in their hands. Am I right, Mr. Mills?

1 MR. MILLS: Yes.

2 MR. MARK: They can measure temperature of the  
3 spray, they can turn enough water on, higher or lower,  
4 and they have done a lot of ignition things, but not  
5 where they have the facility.

6 MR. SHEWMON: Okay. Are there any more  
7 things? I can see on the agenda, "TVA-NRC Comments."  
8 Have we covered that or not?

9 MR. MILLS: We don't have any additional  
10 comments, Dr. Shewmon, unless there's questions.

11 MR. EBERSOLE: Why as a practical matter, on  
12 this troublesome topic of the sprays, was this allowed  
13 to arise? That would just set the whole flap to rest.

14 MR. MARK: You have to burn the hydrogen  
15 outside the tube.

16 MR. MILLS: I did mean to mention, Mr.  
17 Ebersole, but if you recall the looks of this Tayco  
18 igniter, the temperatures that we were talking about are  
19 surface temperatures. When you look at it and talk  
20 about a tube, that's almost a tube. We know the  
21 temperatures inside of those coils are higher than they  
22 are on the surface, anyway.

23 MR. EBERSOLE: Sure. That depends on the  
24 refined calculation of the differential, of course. But  
25 if you had the damn thing in a tube in the first place,

1 you'd solve a lot of problems.

2 MR. SHEWMON: Let's not re-engineer it at  
3 6:30.

4 MR. RENFRO: This is David Renfro.

5 We did try to have a compromise between  
6 overshielding the igniters, so you wouldn't see the  
7 containment environment, and shielding of the overhead  
8 spray.

9 MR. SHEWMON: Okay. Do you have any closing  
10 comments?

11 MR. NOVAK: No, sir. I think we've tried to  
12 express our views. We have some technical comments, but  
13 I think it's too late in the evening.

14 (Laughter.)

15 MR. MARK: So far as the Staff is concerned,  
16 it is prepared to take its recommendation to the  
17 Commission that the PHMS or whatever it's called may be  
18 put in action at Sequoyah and go back to work?

19 MR. NOVAK: Yes.

20 MR. MARK: There are still a few things you'd  
21 like to see done?

22 MR. NOVAK: Yes. We strongly support the  
23 concept. We think it will work. We just would like to  
24 make sure that we don't have to come back here later.

25 MR. MARK: I think that brings us as far as I

1 suppose we could get, Paul.

2 MR. SHEWMON: Okay. Do I feel a groundswell  
3 to read some letters or a groundswell to quit?

4 Why don't we take that as enough groundswell  
5 and adjourn for the day.

6 (Whereupon, at 6:35 p.m., the meeting was  
7 adjourned.)

8

\* \* \*

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the

---

in the matter of: ACRS/272nd General Meeting

Date of Proceeding: December 9, 1982

Docket Number: \_\_\_\_\_

Place of Proceeding: Washington, D. C.

were held as herein appears, and that this is the original transcript thereof for the file of the Commission.

Jane N. Beach

Official Reporter (Typed)

Jane N. Beach

Official Reporter (Signature)



COMMONWEALTH EDISON COMPANY

DRESDEN UNIT 2

TYPE: GE BWR-3

RATED THERMAL POWER: 2527 Mwt


RATED ELECTRICAL OUTPUT: 834 MWE GROSS

COOLING MODE: ONCE THROUGH KANKAKEE/ILLINOIS RIVER;  
AFTER 1971 COOLING LAKE

HISTORY:	NOVEMBER 1959	DRESDEN 1 OPERATING LICENSE
	JANUARY 1966	CONSTRUCTION PERMIT ISSUANCE
	DECEMBER 1969	PROVISIONAL OPERATING LICENSE, BEGIN FL
	JANUARY 1970	INITIAL CRITICAL
	AUGUST 1970	COMMERCIAL SERVICE
	JANUARY 1971	DRESDEN 3 OPERATING LICENSE
	AUGUST 1971	1275 ACRE COOLING LAKE IN-SERVICE
	NOVEMBER 1972	APPLICATION FOR FTOL CONVERSION
	1973	MODIFIED OFF GAS SYSTEM
	1979	SECURITY
	1980-83	TMI MODS
	1982	HIGH DENSITY SPENT FUEL RACKS

FOR: ACRS FULL COMMITTEE MEETING - DECEMBER 9, 1982  
T. J. RAUSCH

TO ILLINOIS RIVER



PLOT PLAN

COMMONWEALTH EDISON

DRESDEN UNIT 2

PLANT FEATURES

BWR-3 - 2 LOOP 20JP RECIRCULATION SYSTEM MG SET FLOW CONTROL  
3 ELECTRIC FW PUMPS

MARK I CONTAINMENT - TORUS SUPPRESSION POOL AND WATER SOURCE

TYPICAL ECCS - HPCI STEAM DRIVEN

4 - 33 1/3% LPCI PUMPS

2 - 100% CORE SPRAY PUMPS

ADS - 4EMR + COMBINED S/RV

ISOLATION CONDENSER - PASSIVE DECAY HEAT REMOVAL

SEPARATE SHUTDOWN COOLING SYSTEM

5309N

COMMONWEALTH EDISON

OPERATING HISTORY OF DRESDEN 2

MWE HRS. GENERATED - LIFE OF PLANT = 51,828,113

CAPACITY FACTOR 57.249

AVAILABILITY 78.06%

<u>YEAR</u>	<u>AVAILABILITY</u>	<u>MWE HRS.</u>	<u>CAP. FAC.</u>
1970 (AS OF APRIL 13 @ 2325)	47.79%	1,252,204	24.82%
1971	65.01%	2,806,520	38.41%
1972	59.67%	3,370,476	46.00%
1973	87.58%	5,256,417	71.94%
1974	63.79%	3,594,104	42.19%
1975	55.13%	3,130,632	42.65%
1976	76.01%	4,610,359	62.93%
1977	71.90%	3,760,955	51.47%
1978	94.15%	6,013,057	82.30%
1979	81.56%	5,211,895	71.33%
1980	93.32%	4,866,244	66.42%
1981	60.09%	3,610,449	49.41%
1982 (THRU SEPT.)	91.71%	4,344,801	79.52%

FOR THE YEAR OF 1980, THE AVAILABILITY OF UNIT 2 AT DRESDEN WAS THE HIGHEST PERCENTAGE IN THE ENTIRE WORLD FOR A NUCLEAR PLANT.





Figure 2. Recirculation System Schematic



*Primary and Secondary Containment Systems*



COMMONWEALTH EDISON

DRESDEN UNIT 2

EMERGENCY CORE COOLING SYSTEM SUMMARY

Function	Number of Pumps	Design Coolant Flow	Effluent Pressure Range	Required Electrical Power	Additional Backup Systems
Core Spray <sup>1</sup>	2-100%	4500 gpm @ 90 psid (1 Pump)	260 psig to 0 psig	Normal aux power or emer diesel generator	2nd core spray subsystem and LPCI subsystem
LPCI <sup>1</sup>	4-33%	8000 gpm @ 200 psid 14,500 gpm @ 20 psid (3 pumps)	275 psig to 0 psig	Normal aux power or emer diesel generator	Core spray subsystems and 4th LPCI pump
HPCI <sup>2</sup>	1-100%	5600 gpm constant	1125 psig to 150 psig	DC battery system for control <sup>3</sup>	Automatic pressure relief plus core spray and LPCI


<sup>1</sup> Automatic start-up of the core spray and LPCI systems is initiated by: (1) reactor low-low water level and reactor low pressure, or (2) drywell high pressure.

<sup>2</sup> Automatic start-up of the HPCI system is initiated by: (1) reactor low-low water level, or (2) drywell high pressure.

<sup>3</sup> Reactor steam-driven pump.


- ADS - 4 Electromatic Relief Valves plus Target Rock Combined S/RV
- Initiates on (1) drywell high pressure, (2) reactor low-low water level, (3) 120 second timer (4) CS or LPCI running
  - Also provides Automatic Pressure Relief on Reactor High Pressure.

DRESDEN UNIT-2  
L.P. COOLANT INJECTION  
TORUS COOLING MODE




06-10-82

- Shown in Suppression Pool Water or Spray Cooling Mode
- LPCI Reflood Capability through Unbroken Recirculation Piping (Not Shown)
- Also can provide Drywell Spray Cooling (Not Shown)



DRESDEN UNIT-2  
H.P. COOLANT INJECTION





SHUTDOWN COOLING - PIPING DIAGRAM




FIGURE 8.2.2:3 AUXILIARY ELECTRICAL SYSTEM - 4160 VOLT AND 480 VOLT






FIGURE 8.2.2:1 250 V DC STATION BATTERY SYSTEM




FIGURE 8.2.2:2 125 VDC SYSTEM

ACRS FULL COMMITTEE

DECEMBER 9, 1982

MILLSTONE UNIT NO. 1

NORTHEAST UTILITIES


T2

# Millstone I

**NORTHEAST UTILITIES**



1000 WEST STREET, BRIDGEWATER, N.J. 08807  
TELEPHONE 908-527-1000  
TELETYPE 908-527-1000  
FACSIMILE 908-527-1000  
MAILING ADDRESS: NORTHEAST UTILITIES, P.O. BOX 1000, BRIDGEWATER, N.J. 08807



## MILLSTONE UNIT 1

### PLANT FEATURES

- o GENERAL ELECTRIC BWR-3
  - 2011 MW THERMAL, 680 MW ELECTRIC
  - MARK 1 PRESSURE SUPPRESSION CONTAINMENT
  - CONSTRUCTED BY EBASCO
  - 2 LOOPS WITH JET PUMPS
  - 3 ELECTRIC FEEDWATER PUMPS
  - ONCE-THRU COOLING WITH LONG ISLAND SOUND
  
- o ONSITE EMERGENCY POWER SYSTEM
  - DIESEL GENERATOR
  - GAS TURBINE GENERATOR (POWER FOR FWCI)
  
- o EMERGENCY CORE COOLING SYSTEMS
  - FEEDWATER COOLANT INJECTION SYSTEM (FWCI)
  - TWO 100% CORE SPRAY PUMPS
  - FOUR 33% LPCI PUMPS
  - AUTOMATIC PRESSURE RELIEF SYSTEM (4 APR VALVES)
  - ISOLATION CONDENSER
  
- o 100% TURBINE BYPASS CAPABILITY
  - PLANT WILL RIDE OUT FULL LOAD REJECT WITHOUT SCRAM
  - TURBINE RUNBACK TO HOUSE LOAD

MILLSTONE UNIT 1 SEP

UNIT HISTORY

CONSTRUCTION AND OPERATION

CONSTRUCTION START:	MAY 1966
INITIAL CRITICAL:	OCTOBER 26, 1970
INITIAL ON-LINE:	NOVEMBER 29, 1970
COMMERCIAL OPERATION:	DECEMBER 1970
100% POWER:	JANUARY 3, 1971
APPLICATION FOR FTOL	SEPTEMBER 1, 1972

MAJOR OUTAGES

	<u>START DATE</u>	<u>DURATION (DAYS)</u>
FIRST REFUEL:	SEPTEMBER 1, 1972	189
1ST. F.W. SPARGER REPLACEMENT	APRIL 18, 1973	102
SECOND REFUEL:	SEPTEMBER 1, 1974	63
THIRD REFUEL:	SEPTEMBER 14, 1975	35
FOURTH REFUEL:	OCTOBER 1, 1976	60
FIFTH REFUEL:	MARCH 10, 1978	36
SIXTH REFUEL:	APRIL 28, 1979	61
SEVENTH REFUEL:	OCTOBER 4, 1980	197
TURBINE OUTAGE:	APRIL 21, 1981	57
EIGHTH REFUEL:	SEPTEMBER 11, 1982	69



MILLSTONE UNIT 1 SEP  
UNIT PERFORMANCE

<u>PERFORMANCE STATISTICS</u>	<u>(LIFE TO DATE)</u>
MWE GENERATED:	45,077,796 (GROSS)
CAPACITY FACTOR:	63.3%
AVAILABILITY:	71.9%

ANNUAL CAPACITY FACTORS

<u>YEAR</u>	<u>CAPACITY FACTORS (%)</u>	<u>INDUSTRY AVERAGE</u>
1970 (DEC. ONLY)	25.9	----
1971	63.2	58.9
1972	54.9	54.3
1973	33.2	57.2
1974	63.1	57.5
1975	68.4	58.6
1976	65.6	56.8
1977	83.4	62.9
1978	80.5	65.2
1979	73.0	58.9
1980	58.5	56.0
1981	43.6 <sup>(1)</sup>	59.9
1982 (TO 10/82)	79.5 <sup>(2)</sup>	60.0 (EST.)

(1) DUE TO BOTH REFUELING AND TURBINE OUTAGES.

(2) ACHIEVED WITHOUT LP TURBINE 'A' & 'B' 14TH STAGE BUCKETS INSTALLED.

MILLSTONE UNIT 1 SEP  
UNIT PERFORMANCE

PERFORMANCE STATISTICS (LIFE TO DATE)

MWE GENERATED: 45,077,796 (GROSS)  
CAPACITY FACTOR: 63.3%  
AVAILABILITY: 71.9%

ANNUAL CAPACITY FACTORS

<u>YEAR</u>	<u>CAPACITY FACTORS (%)</u>	<u>INDUSTRY AVERAGE</u>
1970 (DEC. ONLY)	25.9	----
1971	63.2	58.9
1972	54.9	54.3
1973	33.2	57.2
1974	63.1	57.5
1975	68.4	58.6
1976	65.6	56.8
1977	83.4	62.9
1978	80.5	65.2
1979	73.0	58.9
1980	58.5	56.0
1981	43.6 <sup>(1)</sup>	59.9
1982 (TO 10/82)	79.5 <sup>(2)</sup>	60.0 (EST.)

(1) DUE TO BOTH REFUELING AND TURBINE OUTAGES.

(2) ACHIEVED WITHOUT LP TURBINE 'A' & 'B' 14TH STAGE BUCKETS INSTALLED.

MILLSTONE UNIT 1

SYSTEMATIC ASSESSMENT OF LICENSEE PERFORMANCE (SALP)

SALP RESULTS - JULY, 1982 AND OCTOBER, 1982

"OVERALL, WE FIND THE MANAGEMENT ATTENTION AT YOUR FACILITIES IS AGGRESSIVELY ORIENTED TOWARD NUCLEAR SAFETY."

AND

"EFFECTIVE USE OF AMPLE RESOURCES HAS RESULTED IN A HIGH LEVEL OF PERFORMANCE IN OPERATIONAL SAFETY AND CONSTRUCTION ACTIVITIES."

## MILLSTONE UNIT 1

### SYSTEMATIC ASSESSMENT OF LICENSEE PERFORMANCE (SALP)

SALP RESULTS - OCTOBER 1982

<u>FUNCTIONAL AREA</u>	<u>CATEGORY 1</u>	<u>CATEGORY 2</u>	<u>CATEGORY 3</u>
1. PLANT OPERATIONS	X		
2. RADIOLOGICAL CONTROLS	X		
3. MAINTENANCE	X		
4. SURVEILLANCE	X		
5. FIRE PROTECTION	X		
6. EMERGENCY PREPAREDNESS	X		
7. SECURITY AND SAFEGUARDS		X	
8. REFUELING	X		
9. LICENSING ACTIVITIES	X		

CATEGORY 1: REDUCED NRC ATTENTION MAY BE APPROPRIATE. LICENSEE MANAGEMENT ... AGGRESSIVE AND ORIENTED TOWARD NUCLEAR SAFETY ... HIGH LEVEL OF PERFORMANCE WITH RESPECT TO OPERATIONAL SAFETY IS BEING ACHIEVED.

CATEGORY 2: NRC ATTENTION SHOULD BE MAINTAINED AT NORMAL LEVELS. LICENSEE RESOURCES ARE ADEQUATE ... SATISFACTORY PERFORMANCE WITH RESPECT TO OPERATIONAL SAFETY IS BEING ACHIEVED.

CATEGORY 3: BOTH NRC AND LICENSEE ATTENTION SHOULD BE INCREASED. ... WEAKNESSES ARE EVIDENT ... MINIMAL SATISFACTORY PERFORMANCE ... IS BEING ACHIEVED.

XV-16 & 18 PRIMARY COOLANT ACTIVITY LIMITS

DRESDEN 2 - 4.31 & 32  
MILLSTONE 1 - 4.35 & 36  
OYSTER CREEK - 4.36 & 37

- DOSE RESULTS (SRP) EXCEED CRITERIA
- PRA CONCLUDED RISK NEGLIGIBLE - LOCA DOES NOT DOMINATE
- STAFF POSITION - ADOPT BWR STS IODINE LIMITS AND ESTABLISH PLANT-SPECIFIC ACTION REQUIREMENTS
- CONSERVATISM IN ANALYSIS TECHNIQUE DOES NOT WARRANT HARDWARE OR FURTHER EVALUATION
- MILLSTONE DISAGREES - ESTABLISH PLANT-SPECIFIC LIMITS BASED ON MORE REALISTIC CALCULATION

XV-3

M CPR ANALYSIS WAS BASED ON AN INITIAL  
POWER OF 100% INSTEAD OF 102%

MILLSTONE 1 - 4.34

- THE LICENSEE HAS ANALYZED THIS TRANSIENT FOR RELOAD 8 USING THE NRC-APPROVED ODYN CODE. ALTHOUGH THE INITIAL POWER LEVEL USED WAS 100%, AN UNCERTAINTY FACTOR OF 1.044 WAS USED.
- NO ACTION REQUIRED



XV-1

FEEDWATER CONTROLLER FAILURE MAY BE A  
LIMITING TRANSIENT FOR FUEL DESIGN LIMITS  
REQUIRING OPERABILITY LIMITS FOR TURBINE  
BYPASS

DRESDEN 2 - 4.30  
MILLSTONE 1 - 4.33  
OYSTER CREEK - 4.35

- WILL BE HANDLED AS PART OF THE RELOAD.
- PRA INDICATES LOW IMPORTANCE TO RISK
- NO ACTION REQUIRED

EFFECTS OF LOSS OF VENTILATION ON EQUIPMENT  
FUNCTION AND HYDROGEN ACCUMULATION

DRESDEN 2 - 4.29.1 & 2  
MILLSTONE 1 - 4.32.1-4  
OYSTER CREEK - 4.34(3) & (4)

- DRESDEN WILL EVALUATE THE BATTERY ROOM (H<sub>2</sub> ACCUMULATION) AND DIESEL GENERATOR ROOM FOR CONSEQUENCES - IDENTIFY CORRECTIVE ACTION, AS NECESSARY
- DRESDEN LPCI/CORE SPRAY ROOM VENTILATION CAN BE MANUALLY RESTORED - NO ACTION REQUIRED
- MILLSTONE WILL PROVIDE ADDITIONAL INFORMATION AND ANALYSES TO JUSTIFY NO LOSS OF FUNCTION FOR LPCI/CORE SPRAY PUMP, FWCI, AND DIESEL GENERATOR ROOMS AND MANUAL REINITIATION IN THE TURBINE BUILDING
- MILLSTONE WILL EVALUATE CONSEQUENCES FOR INTAKE STRUCTURE/SERVICE WATER SYSTEM AND ANY NECESSARY CORRECTIVE ACTIONS

VIII-3.B

DC/BATTERY INDICATIONS AND ALARMS IN  
CONTROL ROOM ARE INADEQUATE

DRESDEN 2 - 4.23.3 (4.28)  
MILLSTONE 1 - 4.30  
OYSTER CREEK - 4.32

- PRA CONCLUDED RISK SIGNIFICANCE HIGH FOR DRESDEN AND LOW FOR MILLSTONE (SYSTEM DIFFERENCES)
- BATTERY CURRENT IDENTIFIES LOADING CONDITIONS DURING AN EVENT
- LICENSEES AGREED TO INSTALL INDICATIONS AND ALARMS

VIII-3.B

TECHNICAL SPECIFICATION LIMIT FOR A FAILED OR "OUT OF SERVICE" BATTERY ARE NOT CONSISTENT WITH THE STS - MILLSTONE PRA CONCLUDED A 50% REDUCTION IN OUTAGE WOULD REDUCE CORE MELT FREQUENCY ABOUT 2.5%

DRESDEN 2 - 4.21.4  
MILLSTONE 1 - 4.30

- LICENSEES HAVE AGREED TO PROVIDE APPROPRIATE OUTAGE LIMITS WHICH CONSIDER TIME REQUIRED FOR MAINTENANCE AND CORRECTIVE ACTION

VIII-3.A

BATTERY SERVICE TESTS DO NOT CONFORM TO  
IEEE 450-1975, IEEE 308-1974, BTP ICSB-6,  
AND THE STS

DRESDEN 2 - 4.27  
MILLSTONE 1 - 4.29

- MILLSTONE WILL MODIFY THE EXISTING TECHNICAL SPECIFICATION TESTING REQUIREMENTS
- DRESDEN WILL DEMONSTRATE EXISTING TEST EQUIVALENT OR MORE SEVERE (COMPLETE 12/06/82)

VIII-2

OPERATIONAL AND TESTING EXPERIENCE INDICATE  
TURBINE GENERATOR FAILURES ARE ASSOCIATED  
WITH MAINTENANCE PROBLEMS

MILLSTONE 1 - 4.28.3

- LICENSEE HAS AGREED TO REVIEW MAINTENANCE PROGRAM AND, IF NECESSARY, MODIFY TO INCLUDE PREVENTIVE MAINTENANCE



VIII-2

DIESEL AND TURBINE GENERATORS HAVE INADEQUATE ANNUNCIATORS AND DO NOT BYPASS PROTECTIVE TRIPS DURING ACCIDENT CONDITIONS

DRESDEN 2 - 4.26.1 & 2  
MILLSTONE 1 - 4.28.1, 2, 4 & 5  
OYSTER CREEK - 4.31(1) & (2)

- ANNUNCIATOR MODIFICATION COMPLETE - NO ACTION REQUIRED
- TRIPS THAT PREVENT DAMAGE NEED NOT BE BYPASSED
- PRA CONCLUDED RISK SIGNIFICANCE LOW
- LICENSEES AGREED TO INSTALL SPECIFIED BYPASSES ON OTHER TRIPS

VIII-2

EMERGENCY AC POWER ANNUNCIATORS DO NOT  
MEET IEEE 279-1971 CRITERIA

DRESDEN 2 - 4.26.1  
MILLSTONE 1 - 4.28.5  
OYSTER CREEK - 4.31(1)

- MODIFICATIONS PREVIOUSLY REVIEWED AND COMPLETED
- NO FURTHER ACTION REQUIRED

VII-3

LOSS OF THE INSTRUMENT AC (IAC) BUS WOULD RESULT IN LOSS OF INDICATION IN THE CONTROL ROOM OF FLOW, TEMPERATURE LEVEL, AND/OR PRESSURE OF SYSTEMS REQUIRED TO SHUT DOWN THE REACTOR

MILLSTONE 1 - 4.26

- ISSUE REVIEWED IN RESPONSE TO IE BULLETIN 79-27 - SUFFICIENT INSTRUMENTATION LEFT FOR SAFE SHUTDOWN
- PRA CONCLUDED REMOVAL OF ABTs WITH A REDUNDANT IAC BUS WOULD RESULT IN A 10% REDUCTION IN CORE MELT FREQUENCY - UNDER EVALUATION

VIII-1.A

OPERATING PROCEDURES SHOULD BE DEVELOPED TO PROTECT CLASS 1E SYSTEMS UNDER NON-ACCIDENT CONDITIONS IF A DEGRADED GRID VOLTAGE CONDITION OCCURS

MILLSTONE 1 - 4.27

- LICENSEE AGREED TO DEVELOP SUCH PROCEDURES
- BALANCE OF ISSUES WILL BE ADDRESSED BY MPA B-23 (DEGRADED GRID PROTECTION)

VII-3

SHUTDOWN COOLING SUSCEPTIBLE TO SINGLE  
FAILURE OF SHARED DIESEL AND SPES TEMPERATURE  
INTERLOCK NOT TESTED

DRESDEN 2 - 4.25.3 & 4

- PROCEDURES REVIEWED IN SHARED SYSTEMS  
EVALUATION (VI-10.B) - NO ACTION REQUIRED
- LICENSEE COMMITTED TO TEST INTERLOCK  
(PRA - AVAILABILITY INCREASE 15%)

VII-1.A

RPS CHANNELS ARE NOT ISOLATED FROM THEIR  
RESPECTIVE POWER SUPPLIES

DRESDEN 2 - 4.24.3  
MILLSTONE 1 - 4.25.2  
OYSTER CREEK - 4.27(2)

- LICENSEES HAVE AGREED TO PROVIDE CLASS 1E  
PROTECTION



VII-1.A

FLUX MONITORING SIGNALS (IRM, LPRM, AND APRM)  
ARE NOT ISOLATED FROM THE PROCESS RECORDERS  
INDICATORS AND COMPUTER (IEEE 279-1971)

DRESDEN 2 - 4.24.1 & 2  
MILLSTONE 1 - 4.25.1  
OYSTER CREEK - 4.27(1)

- LICENSEES WILL DEMONSTRATE ADEQUATE ISOLATION  
TO ASSURE FAULTS WILL NOT DISABLE FLUX  
MONITORS
- MILLSTONE WILL DEMONSTRATE BY TEST

VI-10.B

NO INTERLOCKS TO PREVENT PARALLEL OPERATION  
OF SHARED BATTERY SYSTEMS AND BYPASS OF DG  
2/3

DRESDEN 2 - 4.23.1

- LICENSEE AGREED TO PROVIDE PROCEDURES TO PREVENT PARALLELING DURING PLANT OPERATION
- MAY PROPOSE APRALLELING FOR HIGH-RESISTANCE FAULT DETECTION BECAUSE OF DETECTION EQUIPMENT LIMITATIONS (POTENTIAL DISAGREEMENT)
- PROCEDURES MODIFIED TO PREVENT DG 2/3 BYPASS

VI-10.A

RTS CHANNEL CHECKS, FUNCTIONAL TESTS AND  
CALIBRATION FREQUENCIES DIFFER FROM THE  
STS

MILLSTONE 1 - 4.24

- RELIABILITY GOAL BASED ON "EXPOSURE TIME"  
FOR LIKE COMPONENTS
- ONE-SIDED CRITERIA - FREQUENCY ONLY DECREASES
- FLAWS IN APPLICATION
- APPLIES TO ALL BWRs

VI-10.A

NOT ALL SENSORS OR COMPLETE CHANNEL RESPONSE  
TIMES ARE TESTED (BETWEEN CHANNEL TRIP AND  
DE-ENERGIZATION OF THE SCRAM RELAY)

DRESDEN 2 - 4.22  
MILLSTONE 1 - 4.24.3  
OYSTER CREEK - 4.26.1

- LIMITED PRA INDICATED THAT THE ISSUE HAS  
LOW SAFETY SIGNIFICANCE BECAUSE THE TESTING  
IS CONCERNED WITH EVENTS ON THE ORDER OF  
SECONDS AND PRA HAS SHOWN THAT RESPONSE TIMES  
ON THE ORDER OF MINUTES IS SUFFICIENT.
- NO ACTION REQUIRED

VI-7.C.1

DISCONNECT LINKS AND TIE BREAKERS CONNECT  
REDUNDANT BUSES

DRESDEN 2 - 4.21.2 & 3

NON-CLASS 1E SWITCHGEAR (480V #27) RECEIVES  
POWER FROM A CLASS 1E SOURCE (DIV I #24)

DRESDEN - 4.21.5

- LICENSEE WILL PROVIDE PROCEDURES AND ADMINISTRATIVE CONTROLS TO ASSURE ISOLATION OF REDUNDANT BUSES
- LICENSEE WILL EVALUATE THE CLASS 1E/ NON CLASS 1E CONNECTION WITH A SHORT-CIRCUIT ANALYSIS TO ASSURE COORDINATED BREAKER FUNCTION

VI-7.C.1

AUTOMATIC AND MANUAL BUS TRANSFERS EXIST  
WHICH COULD ALLOW TRANSFER OF FAULTED  
LOADS

DRESDEN 2 - 4.21.1  
MILLSTONE 1 - 4.23.1 & 2  
OYSTER CREEK - 4.25(1)

- LICENSEES WILL EVALUATE EXISTING DESIGNS AND IDENTIFY ANY NECESSARY CORRECTIVE ACTIONS
- DRESDEN WILL VERIFY PROTECTIVE RELAYS FOR SHARED SYSTEMS AND PERFORM SHORT-CIRCUIT ANALYSES



VI-7.A.4

TEST DATA (JAPAN) SUGGESTS CENTRAL FUEL BUNDLES OF A BWR-3 CORE MAY RECEIVE LOW SPRAY FLOW

DRESDEN 2 - 4.20  
MILLSTONE 1 - 4.22  
OYSTER CREEK - 4.26.1

- THE ISSUE IS BEING REVIEWED INDEPENDENTLY OF SEP AS A MATTER RELATED TO GENERIC ISSUE A-16.
- THE JAPANESE DATA FOR A BWR/5 MAY ONLY BE APPLICABLE TO A BWR/4 AND A BWR/5 BECAUSE THEIR NOZZLE DESIGN IS SIMILAR AND IS DIFFERENT FROM A BWR/3 NOZZLE.
- GE HAS INFORMED THE STAFF THAT ANALYSES CAN BE PERFORMED TO SHOW THAT EVEN FOR LIMITING CASES OF A BWR/3 WITH CORE SPRAY ASSUMED TO FLOW DOWN PERIPHERAL CHANNELS, THE CALCULATED PEAK CLAD TEMPERATURES WILL NOT EXCEED THE 10 CFR 50.46 LIMIT OF 2200°F.
- NO ACTION REQUIRED

VI-7.A.B

CORE SPRAY ROOM COOLER TESTING IS NOT REQUIRED  
IN THE TECHNICAL SPECIFICATIONS

MILLSTONE 1 - 4.21.1

LPCI TESTING DOES NOT DEMONSTRATE EMERGENCY  
SERVICE WATER SYSTEM (ESWS) WILL START TO  
COOL HEAT EXCHANGERS

MILLSTONE 1 - 4.21.2

- LICENSEE WILL PROVIDE EVALUATION DEMONSTRATING  
CS PUMP COOLING IS NOT ESSENTIAL.
- THE ESWS IS MANUALLY INITIATED.
- TECHNICAL SPECIFICATION 3/4-5.B AND STATION  
PROCEDURE SP623.19 ESTABLISH SURVEILLANCE  
REQUIREMENTS OF THE ESWS TO MAINTAIN A HIGH  
SYSTEM AVAILABILITY.
- STATION PROCEDURE OP506 DIRECTS THE OPERATOR  
TO PLACE THE ESWS IN OPERATION, IN ACCORDANCE  
WITH OPERATING PROCEDURE 322, WHEN THE  
SUPPRESSION CHAMBER TEMPERATURE APPROACHES  
90°F AND PLANT LOAD CONDITIONS PERMIT.
- ACCORDING TO 1REP LOCA SEQUENCE 2 (THE  
CONTAINMENT HEAT REMOVAL FAILS AND ALL OTHER  
FUNCTION SUCCEED). THE OPERATOR WILL HAVE  
ABOUT 20 HOURS TO START THE CONTAINMENT HEAT  
REMOVAL FUNCTION, THAT IS, START THE ESWS, TO  
AVOID CONTAINMENT OVERPRESSURE AND CONSEQUENT LOSS  
OF CORE-COOLING CAPABILITY.
- NO ACTION REQUIRED

VI-6

EXEMPTIONS FOR RBCCW AND AIRLOCK LEAK TESTING

DRESDEN 2 - 4.19

- BEING REVIEWED AS PART OF APPENDIX J,  
10 CFR 50
- CORRECTIVE ACTION INDEPENDENT OF SEP

VI-4

LOCAL MANUAL ISOLATION VALVES AND LACK OF  
EXCESS FLOW CHECKS

MILLSTONE 1 - 4.20.5  
OYSTER CREEK - 4.22.4

- LINES MONITOR ESSENTIAL CONTAINMENT  
PARAMETERS
- PRA CONCLUDES LEAKAGE NEGLIGIBLE TO RISK
- NO ACTION REQUIRED

VI-4

LOCKS ARE NOT PROVIDED FOR MANUAL ISOLATION VALVES

DRESDEN 2 - 4.18.1  
MILLSTONE 1 - 4.20.1  
OYSTER CREEK - 4.22.1

SAME TEST, VENT AND DRAIN LINES HAVE ONLY A SINGLE ISOLATION VALVE OR A VALVE AND CAP

DRESDEN 2 - 4.18.6  
MILLSTONE 1 - 4.20.2

RBCOW ISOLATION VALVES ARE NOT LEAK TESTED

DRESDEN 2 - 4.18.2

INSUFFICIENT INFORMATION TO ESTABLISH ISOLATION PROVISIONS FOR SPECIFIED BRANCH LINES

MILLSTONE 1 - 4.20.7

- LICENSEES HAVE AGREED TO PROVIDE LOCKS AND REDUNDANT ISOLATION VALVES FOR SPECIFIED LINES
- DRESDEN WILL INSTALL TEST TAPS FOR LEAK TESTING
- MILLSTONE WILL EVALUATE ISOLATION PROVISIONS ON BRANCH LINES AND IDENTIFY ANY NECESSARY CORRECTIVE ACTION

LEAKAGE DETECTION CAPABILITY FOR REMOTE  
MANUAL VALVES

DRESDEN 2 - 4.18.2  
MILLSTONE 1 - 4.20.3  
OYSTER CREEK - 4.22.2

ADMINISTRATIVE CONTROLS FOR LOCKED-CLOSED VALVES

DRESDEN 2 - 4.18.1  
MILLSTONE 1 - 4.20.1

- LICENSEES WILL EVALUATE LEAKAGE DETECTION CAPABILITIES
- LICENSEE WILL PROVIDE PROCEDURES FOR REMOTE MANUAL OPERATION AND ADMINISTRATIVE CONTROLS FOR LOCKED-CLOSED VALVES
- DRESDEN REVIEW IDENTIFIED ISOLATION VALVES (RBCCW) EXCLUDED FROM LEAKAGE TESTING - LICENSEE AGREED TO INSTALL TEST TAPS



VI-4

TWO CHECK VALVES IN SERIES ARE USED FOR CONTAINMENT ISOLATION OF THE FEEDWATER SYSTEM VICE MOTOR-OPERATED VALVE OUTSIDE CONTAINMENT

BOTH ISOLATION VALVES OUTSIDE CONTAINMENT

DRESDEN 2 - 4.18.4 & 5  
MILLSTONE 1 - 4.20.6 & 4  
OYSTER CREEK - 4.22.5 & 3

- HIGH PRESSURE HEATER DISCHARGE VALVES PROVIDE BACKUP ISOLATION CAPABILITY.
- EXISTING FEEDWATER CHECK VALVES ARE SUBJECT TO LOCAL LEAK RATE TESTING TO INSURE THEIR FUNCTIONABILITY.
- LIMITED PRA FOR PALISADES CONCLUDED LITTLE IMPROVEMENT WOULD BE OBTAINED BY HAVING ONE VALVE INSIDE AND ONE OUTSIDE BECAUSE THE PROBABILITY OF FAILURE OF BOTH VALVES IS GREATER THAN THE PROBABILITY OF PIPE FAILURE BETWEEN THE CONTAINMENT AND THE FIRST ISOLATION VALVE.
- ISOLATION RELIABILITY WOULD NOT BE SIGNIFICANTLY IMPROVED BY ADDING A REMOTE MANUAL VALVE.
- NO ACTION REQUIRED

V-12.A

REQUIREMENTS TO ASSURE MINIMUM RESERVE  
CAPACITY IN RWCU AND CONDENSATE DEMINERALIZERS  
SHOULD BE INCLUDED IN THE TECHNICAL  
SPECIFICATIONS

MILLSTONE 1 - 4.19.2

- LICENSEE WILL EVALUATE RESERVE CAPACITY  
AND PROPOSE TS CHANGE OR JUSTIFY NOT  
DOING SO.

V-12.A

TECHNICAL SPECIFICATIONS DO NOT MEET THE LIMITS ESTABLISHED IN REGULATORY GUIDE 1.56 FOR CONDUCTIVITY AND CHLORIDES OF THE REACTOR VESSEL WATER AND CONDUCTIVITY OF THE FEEDWATER

MILLSTONE 1 - 4.19.1  
OYSTER CREEK - 4.20

- THE LICENSEE HAS PROPOSED TO REVISE THE EXISTING TECHNICAL SPECIFICATIONS FOR CHLORIDES AND CONDUCTIVITY TO BE CONSISTENT WITH REGULATORY GUIDE 1.56 OR WILL PROVIDE JUSTIFICATION FOR NOT DOING SO.

V-11.A

RWCV SYSTEM DOES NOT INCLUDE INTERLOCKS  
TO PREVENT OVERPRESSURE FROM RCS

DRESDEN 2 - 4.16  
MILLSTONE 1 - 4.18  
OYSTER CREEK - 4.19

- DRESDEN HAS DEMONSTRATED SUFFICIENT RELIEF CAPACITY AND ACCEPTABLE CONSEQUENCES OF STUCK-OPEN VALVE - NO ACTION REQUIRED
- MILLSTONE WILL INSTALL INTERLOCK

V-10.B

SAFE SHUTDOWN PROCEDURES - SHUTDOWN OUTSIDE  
THE CONTROL ROOM AND SHUTDOWN USING SAFETY  
SYSTEMS

DRESDEN 2 - 4.25.1 & 2  
MILLSTONE 1 - 4.17  
OYSTER CREEK - 4.18

- SHUTDOWN OUTSIDE THE CONTROL ROOM ADDRESSED  
BY APPENDIX R (FIRE PROTECTION) REVIEW
- OTHER PROCEDURAL CHANGES WILL BE RESOLVED BY  
TMI I.C.1 GENERIC SYMPTOM - ORIENTED  
PROCEDURES

V-6

REACTOR VESSEL MATERIAL SURVEILLANCE AND  
UPPER SHELF ENERGY

DRESDEN 2 - 4.14

OYSTER CREEK - 4.17

- CEC<sub>o</sub> REQUEST FOR TS CHANGE BEING REVIEWED  
AS A ROUTINE LICENSING ACTION
- NO FURTHER ACTION REQUIRED



V-5

INSUFFICIENT INFORMATION TO CONCLUDE ON  
CONTROL OF INTERSYSTEM LEAKAGE

MILLSTONE 1 - 4.16.2  
OYSTER CREEK - 4.16.3

- PRA FOR DRESDEN 2 AND OYSTER CREEK CONCLUDED THAT THIS WAS NOT A SIGNIFICANT CONTRIBUTOR TO RISK.
- MILLSTONE 1 HAS ACTIVITY MONITORS ON THE CCW SYSTEM AND EFFLUENT MONITORS TO IDENTIFY SUCH LEAKAGE.
- NO ACTION REQUIRED

V-5

PRIMARY COOLANT LEAKAGE DETECTION SYSTEMS ARE  
NOT TESTED IN ACCORDANCE WITH CURRENT CRITERIA

DRESDEN 2 - 4.13.3  
MILLSTONE 1 - 4.16.1  
OYSTER CREEK - 4.16.2

- PROCEDURES DEMONSTRATE OPERABILITY
- NO ACTION REQUIRED

V-5

LEAKAGE DETECTION SYSTEMS DO NOT MEET  
SENSITIVITY OR SEISMIC DESIGN CRITERIA  
(SSE)

DRESDEN 2 - 4.13.1 & 2  
MILLSTONE 1 - 4.16.1  
OYSTER CREEK - 4.16.1

STAFF POSITION

- EVALUATE SENSITIVITY IN CONJUNCTION WITH III-5.A
- DEMONSTRATE RELIABLE SYSTEM
- PROVIDE PROCEDURES FOR SEISMIC EVENTS (MINIMUM)
- LICENSEES HAVE AGREED TO EVALUATE IN CONJUNCTION WITH III-5.A
- DRESDEN ORALLY AGREES IN CONCEPT - SPECIFICS TO BE DETERMINED

IV-2

INSUFFICIENT INFORMATION TO COMPLETE SINGLE -  
FAILURE ANALYSIS OF THE CONTROL ROD SYSTEM

MILLSTONE 1 - 4.15  
OSYTER CREEK - 4.15

- ADDITIONAL INFORMATION PROVIDED
- DRESDEN 2 ANALYSIS SHOWS XV-8 TRANSIENTS BOUNDING
- NO ACTION REQUIRED

III-10.A

ESF VALVES NOT IN EMERGENCY POSITION DO NOT  
BYPASS THERMAL OVERLOAD PROTECTION DEVICES

DRESDEN 2 - 4.12.1  
MILLSTONE 1 - 4.14  
OYSTER CREEK - 4.14(1)

LIMIT SWITCH MUST BYPASS TORQUE SWITCH  
TO INITIATE VALVE MOVEMENT

DRESDEN 2 - 4.12.2  
OYSTER CREEK - 4.14(1)

- LICENSEE WILL EVALUATE TRIP SETPOINTS  
AND ADJUST OR BYPASS AS NECESSARY
- DRESDEN ORALLY INDICATED EVALUATION COMPLETE
- TORQUE SWITCHES - CURRENT CRITERIA MET

III-8.A

NO LOOSE-PARTS MONITORING PROGRAM FOR  
PRIMARY SYSTEM

DRESDEN 2 - 4.11  
MILLSTONE 1 - 4.13  
OYSTER CREEK - 4.14(1)

- 31 LOOSE PARTS INCIDENTS RESULTED IN  
DAMAGE IN 9 CASES AND NEGLIGIBLE  
CONSEQUENCES
- LOOSE PARTS CAN USUALLY BE DETECTED DURING  
REFUELING
- PRA CONCLUDED NEGLIGIBLE EFFECT ON RISK
- BACKFITTING WILL BE CONSIDERED IN  
IMPLEMENTATION OF RG 1.133
- NO ACTION REQUIRED



III-7.B

SIGNIFICANCE OF IDENTIFIED CODE CHANGES  
AND COMBINATIONS OF LOADS

DRESDEN 2 - 4.10

MILLSTONE 1 - 4.12

OYSTER CREEK - 4.12

- LICENSEES WILL EVALUATE SPECIFIC CHANGES IDENTIFIED ON SAMPLING BASIS
- MILLSTONE WILL ADDRESS WITH AN "INTEGRATED STRUCTURAL ASSESSMENT" TO RESOLVE ISSUES FROM FROM II-3.B, II-4.F, III-2, III-3.A, III-4.A, AND III-6.

III-6

LPCI AND CONTAINMENT SPRAY HEAT EXCHANGERS  
MAY NOT BE ADEQUATELY RESTRAINED FOR SEISMIC  
EVENTS

MILLSTONE 1 - 4.11.3

ANCHORS FOR TRANSFORMERS AND CONTROL ROOM  
PANELS MAY PREVENT SLIDING OR OVERTURNING

MILLSTONE 1 - 4.11.4  
OYSTER CREEK - 4.LL(3)

- NNECo PROVIDED ADDITIONAL INFORMATION TO  
JUSTIFY THE ADEQUACY OF THE DESIGN
- STAFF IS CURRENTLY REVIEWING THE ELECTRICAL  
ANCHORAGE SUBMITTAL
- NO ACTION REQUIRED

III-6

SEISMIC QUALIFICATION OF CABLE TRAYS

DRESDEN 2 - 4.9.3  
MILLSTONE 1 - 4.11.6  
OYSTER CREEK - 4.11(5)

- SEP OWNER'S GROUP PROGRAM TO DEFINE ANALYTICAL METHODS
  
- PLANT-SPECIFIC IMPLEMENTATION

III-6

FUNCTIONALITY OF SAFETY-RELATED ELECTRICAL  
EQUIPMENT

DRESDEN 2 - 4.9.4  
MILLSTONE 1 - 4.11.5  
OYSTER CREEK - 4.11(4)

- SEP OWNER'S GROUP PROGRAM FOR EQUIPMENT QUALIFICATION WILL BE INTEGRATED INTO THE DEVELOPMENT AND IMPLEMENTATION OF USI A-46.
- NO ACTION REQUIRED

III-6

SEISMIC CAPABILITY OF MOTOR-OPERATED VALVES

DRESDEN 2 - 4.9.2(1)  
MILLSTONE 1 - 4.11.2

SEISMIC CAPABILITY OF REACTOR INTERNALS

DRESDEN 2 - 4.9.2(2)  
MILLSTONE 1 - 4.11.8  
OYSTER CREEK - 4.11(2)

- LICENSEES WILL EVALUATE CAPACITIES AND SUBMIT RESULTS
- DRESDEN WILL DEMONSTRATE APPLICABILITY OF OYSTER CREEK ANALYSIS

III-6

SEISMIC CAPABILITY OF ESF PIPING SUPPORTS

DRESDEN 2 - 4.9.1 & 2  
MILLSTONE 1 - 4.11.7  
OYSTER CREEK - 4.11(1)

- ISSUE BEING RESOLVED IN CONJUNCTION WITH IE BULLETIN 79-14 - NO ACTION REQUIRED
- DRESDEN - EVALUATION OF SEISMIC CAPABILITY OF THE RECIRCULATION PUMPS AND THEIR SUPPORTS - LICENSEE HAS ORALLY AGREED TO ANALYZE FOR NRC LOADING CONDITION



III-5.B

JET EXPANSION MODEL FOR ISOLATION CONDENSER  
BREAK EFFECTS MAY BE NON-CONSERVATIVE

MILLSTONE 1 - 4.10.2

- LICENSEE AGREED TO EVALUATE THE SPECIFIC CONCERNS AND SUBMIT RESULTS

III-5.B

MODERATE ENERGY PIPE BREAKS WOULD CAUSE EXCESSIVE FLOODING IN THE REACTOR AND TURBINE BUILDINGS

MILLSTONE 1 - 4.10.1

- AN ANALYSIS OF THE MODERATE ENERGY SYSTEMS INDICATES THAT:
  - FLOODING IN THE TURBINE BUILDING (CONDENSER BAY) WOULD AFFECT THE FEEDWATER COOLANT INJECTION SYSTEM, BUT THE REST OF THE ECCS WOULD REMAIN AVAILABLE FOR PLANT SHUTDOWN.
  - FLOODING IN THE REACTOR BUILDING (CORNER ROOMS) DOES NOT PREVENT SAFE SHUTDOWN.
- THE WETTING OR SPRAYING OF SAFETY-RELATED ELECTRICAL EQUIPMENT IS BEING ADDRESSED GENERICALLY AS PART OF THE ENVIRONMENTAL QUALIFICATION PROGRAM OF ELECTRICAL EQUIPMENT (USI A-24).
- NO ACTION REQUIRED

III-5.B

NO STRESS DATA PROVIDED FOR CONTAINMENT PENETRATION PIPE SEGMENT - PIPE BREAKS IN THIS SEGMENT OR A BREAK DOWNSTREAM DAMAGING THE OUTBOARD ISOLATION VALVE WITH A FAILURE OF THE INBOARD VALVE WOULD BE UNISOLABLE.

DRESDEN 2 - 4.8  
MILLSTONE 1 - 4.10.3  
OYSTER CREEK - 4.10(1)

- PRA CONCLUDED LOCA FREQUENCY OF THIS TYPE IS ABOUT  $2 \times 10^{-7}$ /RY - RANDOM VALVE FAILURES DOMINATE
- NO ACTION REQUIRED

III-5.A

INADEQUATE EVALUATION OF JET IMPINGEMENT  
AND PIPE WHIP EFFECTS

DRESDEN 2 - 4.7.1 , 2 & 4  
MILLSTONE - 4.9.2 & 3  
OYSTER CREEK - 4.9(2) & (3)

- LICENSEES WILL EVALUATE SPECIFIC ISSUES  
IDENTIFIED AND SUBMIT RESULTS

III-4.B

TURBINE DISASSEMBLY AND INSPECTIONS ARE NOT  
CONDUCTED AT APPROXIMATELY THREE YEAR INTERVALS

DRESDEN 2 - 4.6  
MILLSTONE 1 - 4.8  
OYSTER CREEK - 4.7

- GE GENERIC INSPECTION FREQUENCY PROGRAM  
UNDER REVIEW
- PROPOSE FREQUENCY BASED ON TEST RESULTS
- DRESDEN PROPOSAL SUBMITTED
- MILLSTONE TO EVALUATE TESTING OF THE TURBINE  
CONTROL VALVES

III-4.A

SYSTEMS REQUIRED FOR SAFE SHUTDOWN ARE NOT  
PROTECTED FROM TORNADO MISSILES

DRESDEN 2 - 4.5  
MILLSTONE 1 - 4.7  
OYSTER CREEK - 4.6

- PROVIDE AT LEAST ONE PROTECTED TRAIN TO  
ACHIEVE SAFE SHUTDOWN - EVALUATE AND  
IDENTIFY ANY NECESSARY CORRECTIVE ACTION

DRESDEN 2

- ESWS WILL BE ADDRESSED BY TMI III.D.3.4
- BATTERIES IN PROTECTED AREA (CONCRETE BLOCK)
- ASSURE DG LOSS OF INTAKE OR EXHAUST WILL NOT  
IMPAIR FUNCTION



III-3.C

INSPECTION FREQUENCY OF INTAKE/DISCHARGE  
STRUCTURES AND FLOW REGULATING STATION  
DO NOT COMP'Y WITH CURRENT CRITERIA

DRESDEN 2 - 4.4.2  
OYSTER CREEK - 4.5.1

- II-4.D CONCLUDED ROCK FOUNDATION FOR INTAKE/DISCHARGE STRUCTURES IS SOUND
- FLOW REGULATING STATION IS NOT SAFETY-RELATED
- NO ACTION REQUIRED

III-3.C

INSPECTION OF WATER CONTROL STRUCTURES IS NOT FORMALIZED, DOES NOT PROVIDE FOR INSPECTIONS AFTER EXTREME EVENTS, OR CONDUCTED BY QUALIFIED ENGINEERING PERSONNEL

DRESDEN 2 - 4.4.3  
MILLSTONE 1 - 4.6.3  
OYSTER CREEK - 4.5.4

- LICENSEES AGREED TO MAKE APPROPRIATE MODIFICATIONS TO EXISTING INSPECTION PROCEDURES

III-3.A

PMH WAVE ACTION MAY CAUSE STRUCTURAL DAMAGE

MILLSTONE 1 - 4.5.1

INSUFFICIENT INFORMATION TO DETERMINE WHETHER  
GROUNDWATER LOADS WERE CONSIDERED IN CORRECT  
LOAD COMBINATIONS

MILLSTONE 1 - 4.5.2

- STRUCTURAL EFFECTS WILL BE ADDRESSED IN  
III-7.B
- LOAD COMBINATIONS WILL BE EVALUATED ON A  
SAMPLING BASIS

III-2

INSUFFICIENT INFORMATION TO DETERMINE EFFECTS  
OF FAILURE OF NON-QUALIFIED STRUCTURES ON  
OTHER STRUCTURES

MILLSTONE 1 - 4.4.3  
OYSTER CREEK - 4.3.3

- LICENSEE WILL EVALUATE EFFECTS OF FAILURE  
AND IDENTIFY ANY NECESSARY CORRECTIVE  
ACTION

III-2

NO EVALUATION OF TORNADO WIND LOADS ON  
COMPONENTS OUTSIDE QUALIFIED STRUCTURES

DRESDEN 2 - 4.3.3  
MILLSTONE 1 - 4.4.4  
OYSTER CREEK - 4.3.4

NO EVALUATION OF ROOF CAPACITIES FOR TORNADO  
WIND LOADS

DRESDEN 2 - 4.3.4  
MILLSTONE 1 - 4.4.5  
OYSTER CREEK - 4.3.6

UNABLE TO DETERMINE HOW WIND LOADS WERE  
INCLUDED IN LOAD COMBINATIONS

DRESDEN 2 - 4.3.5  
MILLSTONE 1 - 4.4.6  
OYSTER CREEK - 4.3.8

- LICENSEES WILL EVALUATE STRUCTURAL CAPACITIES,  
OR, IF NECESSARY, FAILURE CONSEQUENCES
- MILLSTONE WILL ADDRESS IN III-7.B

III-2

CAPABILITY OF VENTILATION STACK TO WITHSTAND  
DESIGN-BASIS TORNADO WIND LOADS (360 MPH)

DRESDEN 2 - 4.3.2  
MILLSTONE 1 - 4.4.2  
OYSTER CREEK - 4.3.2

- MILLSTONE WILL EVALUATE CAPABILITY IN  
CONJUNCTION WITH III-7.B
- DRESDEN MINIMUM CAPABILITY APPROXIMATELY  
255 MPH ( $2 \times 10^{-6}$ ) PLUS CONSEQUENCES LIMITED  
NO ACTION REQUIRED



III-2

CAPABILITY OF REACTOR BUILDING SUPERSTRUCTURE  
TO WITHSTAND DESIGN-BASIS TORNADO WIND LOADS  
(360 MPH)

DRESDEN 2 - 4.3.1  
MILLSTONE 1 - 4.4.1  
OYSTER CREEK - 4.3.1

- MILLSTONE WILL EVALUATE CAPABILITY IN  
CONJUNCTION WITH III-7.B
- DRESDEN MINIMUM CAPABILITY APPROXIMATELY  
160 MPH ( $3 \times 10^{-5}$ ) PLUS CONSEQUENCES  
LIMITED - NO ACTION REQUIRED

III-1

INSUFFICIENT INFORMATION TO CONCLUDE STRESS LIMITS AND PRESSURE/TEMPERATURE RATINGS FOR VALVES, PUMP DESIGN REQUIREMENTS AND TANK STRESS REQUIREMENTS ARE COMPARABLE TO CURRENT REQUIREMENTS.

MILLSTONE 1 - 4.3.3-5  
OYSTER CREEK - 4.2

- LICENSEE WILL EVALUATE MARGINS OF SAFETY BASED ON DIFFERENCES ON A SAMPLING BASIS
- DESIGN BASIS TO BE INCLUDED IN FSAR UPDATE

III-1

INSUFFICIENT INFORMATION TO CONCLUDE ON  
FRACTURE TOUGHNESS AND RADIOGRAPHY

DRESDEN 2 - 4.2.1 & 2  
MILLSTONE 1 - 4.3.1 & 2  
OYSTER CREEK - 4.2

- PROVIDE EVALUATION IN FSAR UPDATE

DRESDEN 2 - RSCS, RBCCW, AND RWCV (4.2.2(1))

- SYSTEMS ARE OF LOW IMPORTANCE TO SAFETY
- FRACTURE TOUGHNESS DATA UNAVAILABLE
- NO ACTION REQUIRED

II-4.F

BUILDING PILE CAPACITY AND SSE EFFECTS ON  
THE SOIL STRENGTH FOR THE TURBINE AND  
GAS TURBINE BUILDINGS

MILLSTONE 1 - 4.2.1 & 2

SWS & ESWS COMMON PIPE SUPPORTED ON  
UNSUITABLE PEAT MATERIAL

MILLSTONE 1 - 4.2.3

- LICENSEE WILL EVALUATE IN III-7.B  
INCLUDING ANY NECESSARY SOIL INVESTIGATIONS

II-3.B

DESIGN BASIS GROUNDWATER INCREASED FROM  
514 TO 517 FT. MSP

DRESDEN 2 - 4.1.1  
OYSTER CREEK- 4.4(2)

- SEP TOPIC III-3.A CONCLUDED STRUCTURAL INTEGRITY WOULD BE MAINTAINED AT WATER LEVELS UP TO 517 FT. MSL.
- NO ACTION REQUIRED

II-3

PMH FLOOD LEVEL AND WAVE EFFECTS MAY CAUSE  
INLEAKAGE OR STRUCTURAL DAMAGE

MILLSTONE 1 - 4.1.1 & 2  
OYSTER CREEK - 4.1(7)

PMP MAY CAUSE EXCESSIVE ROOF LOADS

DRESDEN 2 - 4.1.3  
MILLSTONE 1 - 4.1.7  
OYSTER CREEK - 4.1(9)

- LICENSEE WILL EVALUATE EFFECTS OF  
INLEAKAGE ON SAFE SHUTDOWN CAPABILITY
- MILLSTONE STRUCTURAL EFFECTS WILL BE  
EVALUATED IN III-7.B
- DRESDEN WILL INSTALL SCUPPERS TO PREVENT  
ROOF PONDING

II-3

FLOOD EMERGENCY PLANS DO NOT ADEQUATELY  
PROVIDE SAFE SHUTDOWN PROCEDURES

DRESDEN 2 - 4.1.4

MILLSTONE 1 - 4.1.6

OYSTER CREEK- 4.1(4) & (6)

- LICENSEE WILL MODIFY FLOOD EMERGENCY PLAN TO ASSURE CAPABILITY TO ACHIEVE SAFE SHUT-DOWN IN EVENT OF SEVERE FLOODING CONDITIONS OR UPON LOSS OF ULTIMATE HEAT SINK.



PONDING, LOCAL FLOODING AND WAVE EFFECTS  
MAY CAUSE A LOSS OF SYSTEMS IN THE RADWASTE,  
CONTROL AND GAS TURBINE BUILDING AND THE  
DIESEL FUEL OIL TRANSFER PUMPS

MILLSTONE 1 - 4.1.3-5

- CREDIT FOR EXISTING FLOODGATES
- SAFETY-RELATED SYSTEMS ELEVATED WITH LOCAL FLOOR GRATES
- SYSTEMS IN WATER-TIGHT ROOMS
- SHUTDOWN CAN BE ACHIEVED AND MAINTAINED BY USE OF THE ISOLATION CONDENSER AND DIESEL-DRIVEN FIRE PUMPS. (FLOOD PROTECTED WITH SUPPLY FOR 12 HOURS.)
- THE FUEL OIL TRANSFER PUMPS ELECTRICAL MOTORS ARE ONLY 1.3 FT. BELOW THE CONSERVATIVELY ESTIMATED PMH WAVE ACTION HEIGHT.
- UNDER SECTION 4.1.6, FLOOD EMERGENCY PROCEDURES WILL BE REVISED TO ADDRESS SHUTDOWN WITH A LOSS OF OFFSITE POWER AND FAILURE OF THE FUEL OIL TRANSFER PUMPS.
- NO ACTION REQUIRED

ISSUE SUMMARIES\*

DRESDEN 2  
&  
MILLSTONE 1

\* INCLUDES COMMON OYSTER CREEK ISSUES

LICENSEE DISAGREES

MILLSTONE 1

VI-10.A REACTOR TRIP SYSTEM SURVEILLANCE FREQUENCIES  
(4.24)

XV-16 & PRIMARY COOLANT ACTIVITY LIMITS  
XV-18 (4.35 & 36)

MILLSTONE 1

V-11.A HIGH/LOW PRESSURE INTERLOCK (RWCU)  
OC-4.19, D2-4.16\*, M1-4.18

DRESDEN 2

II-3 PMP ROOF LOADS - INSTALL SCIPPERS  
OC-4.1(9), D2-4.1.3, M1-4.1.7\*

VI-4 LEAKAGE TEST TAPS  
D2-4.18.2

## HARDWARE

### COMMON

- VI-4            LOCKS FOR MANUAL ISOLATION VALVES  
OC-4.22.1, D2-4.18.1 & 3, M1-4.20.1
- VI-4            SECOND ISOLATION VALVE  
D2-4.18.6, M1-4.20.2
- VII-1.A        ISOLATE RPS FROM POWER SUPPLY  
OC-4.27(2), D2-4.24.3, M1-4.25.2
- VIII-2         DIESEL/TURBINE GENERATOR ANNUNCIATORS (COMPLETE)  
OC-4.31(1), D2-4.26.1\*, M1-4.28.5\*
- VIII-2         DIESEL/TURBINE GENERATOR TRIP BYPASSES  
OC-4.31(2), D2-4.26.2, M1-4.28.1, 2 & 4
- VIII-3.B       BATTERY/DC STATUS INDICATION AND ALARMS  
OC-4.32, D2-4.28 & 4.23.3, M1-4.30

ISSUES WITH HARDWARE BACKFITS



MILLSTONE 1

V-12.A COOLANT CONDUCTIVITY & CHLORIDE LIMITS (TS)  
OC-4.20, MI-4.19.1

VIII-1.A DEGRADED GRID PROTECTION FOR CLASS 1E  
MI-4.27

VIII-2 TURBINE GENERATOR MAINTENANCE  
MI-4.28.3

DRESDEN 2

- VI-7.C.1 DISCONNECT LINK PROCEDURES AND ADMINISTRATIVE CONTROLS FOR BREAKERS  
D2-4.21.2 & 3
  
- VI-10.B ADMINISTRATIVE CONTROLS TO PREVENT PARALLELING DC SYSTEMS AND  
"BYPASS" DG 2/3 DURING OPERATION  
D2-4.23.1 & 2
  
- VII-3 SHUTDOWN COOLING INTERLOCK TESTS  
D2-4.25.4
  
- XV-16 & PRIMARY COOLANT ACTIVITY LIMITS  
XV-18 OC-4.36 & 37, D2-4.31 & 32, M1-4.35 & 36\*

PROCEDURES & TECHNICAL SPECIFICATIONS

COMMON

- II-3 FLOODING EMERGENCY PROCEDURES  
OC-4.1(4) & (6), D2-4.1.4, M1-4.1.6
- III-3.C WATER CONTROL STRUCTURE INSPECTIONS  
OC-4.5.4, D2-4.4.3, M1-4.6.3
- VI-4 VALVE LOCK ADMINISTRATIVE CONTROLS  
D2-4.18.1, M1-4.20.1
- VI-4 PROCEDURES FOR REMOTE MANUAL ISOLATION  
OC-4.22.2, D2-4.18.2\*, M1-4.20.3\*
- VIII-3.A BATTERY SERVICE TESTS (TS)  
D2-4.27, M1-4.29
- VIII-3.B BATTERY "OUT OF SERVICE" TIME (TS)  
D2-4.21.4, M1-4.30

ISSUES WITH PROCEDURAL  
OR TECHNICAL SPECIFICATION  
CHANGES

V-12.A RWCU/CONDENSATE DEMINERALIZER CAPACITY (TS)  
MI-4.19.2

VI-4 BRANCH LINE ISOLATION CAPABILITY  
MI-4.20.7

VI-7.A.3 CS PUMP COOLER TESTING  
MI-4.21.1

IX-5 INTAKE/SWS LOSS OF VENTILATION  
MI-4.32.4

## MILLSTONE 1

- II-3        EVALUATE CONSEQUENCES OF PMH FLOOD LEVEL  
            OC-4.1(7), M1-4.1.1 & 2
  
- II-3        PMP ROOF LOADS  
            OC-4.1(9), D2-4.1.3\*, M1-4.1.7
  
- II-4.F     CAPABILITY OF PILE SUPPORTS  
            M1-4.2.1 & 2
  
- II-4.F     SWS & ESWS BURIED PIPING  
            M1-4.2.3
  
- III-1      DESIGN LIMITS FOR VALVES, PUMPS, AND TANKS  
            OC-4.2, M1-4.3.3-5
  
- III-2      REACTOR BUILDING SUPERSTRUCTURE - WIND LOADS  
            OC-4.3.1, D2-4.3.1\*, M1-4.4.1
  
- III-2      VENTILATION STACK - WIND LOADS  
            OC-4.3.2, D2-4.3.2\*, M1-4.4.2
  
- III-2      EVALUATE FAILURE OF NON-QUALIFIED STRUCTURES  
            OC-4.3.3, M1-4.4.3
  
- III-3.A    EVALUATE STRUCTURAL DAMAGE FROM PMH WAVE ACTION  
            M1-4.5.1
  
- III-3.A    GROUNDWATER LOAD COMBINATIONS  
            M1-4.5.2
  
- III-5.B    JET EXPANSION MODEL  
            M1-4.10.2

DPESDEN 2

III-4.A TORNADO MISSILES - SVS & DG INTAKE/EXHAUST  
D2-4.5.1(2) & 4.5.3

III-6 RECIRCULATION PUMP & SUPPORTS  
D2-4.9.2(3), M1-4.11.7\*

VI-7.C.1 CLASS 1E ISOLATION  
D2-4.21.5



III-10.A THERMAL OVERLOAD SETPOINTS/BYPASS  
OC-4.14(1), D2-4.12.1, M1-4.14

V-5 LEAKAGE DETECTION RELIABILITY & SENSITIVITY  
OC-4.16.1, D2-4.13.1/2 & 4.7.3, M1-4.16.1 & 4.9.1

VI-4 REMOTE MANUAL ISOLATION VALVE LEAK DETECTION  
OC-4.22.2, T2-4.18.2\*, M1-4.20.3\*

VI-7.C.1 AUTOMATIC TRANSFER OF FAULTED LOADS  
OC-4.25(1), D2-4.21.1, M1-4.23.1 & 2

VII-1.A FLUX MONITORING ISOLATION  
OC-4.27(1), D2-4.24.1 & 2, M1-4.25.1 (TEST)

IX-5 BATTERY VENTILATION - HYDROGEN  
OC-4.34(4), D2-4.29.1, M1-4.32.2

IX-5 LPCI/CS/FWCI/DG-LOSS OF VENTILATION EFFECTS  
OC-4.34(3), D2-4.29.2, M1-4.32.1, 2 & 3

## FURTHER EVALUATION

### COMMON

- III-1      EVALUATE RADIOGRAPHY AND FRACTURE TOUGHNESS  
OC-4.2, D2-4.2.1 & 4.2.2(2)\*, M1-4.3.1 & 4.3.2
- III-2      EVALUATE FAILURE OF COMPONENTS OUTSIDE QUALIFIED STRUCTURES  
OC-4.3.4, D2-4.3.3, M1-4.4.4
- III-2      EVALUATE CAPACITY OF ROOF DECKS  
OC-4.3.6, D2-4.3.4, M1-4.4.5
- III-2      COMBINATION OF WIND LOADS  
OC-4.3.8, D2-4.3.5, M1-4.4.6
- III-4.A    ENSURE SAFE SHUTDOWN CAPABILITY FOR TORNADO MISSILES  
OC-4.6.4, D2-4.5.4, M1-4.7
- III-4.B    TURBINE INSPECTION PROGRAM  
OC-4.7, D2-4.6, M1-4.8
- III-5.A    JET IMPINGEMENT REEVALUATION  
OC-4.9(2), D2-4.7.1, M1-4.9.2
- III-5.A    PIPE WHIP EFFECTS  
OC-4.9(3), D2-4.7.2 & 4, M1-4.9.3
- III-6      MOTOR OPERATED VALVE SEISMIC CAPABILITY  
D2-4.9.2(1), M1-4.11.2
- III-6      RPV INTERNALS SEISMIC CAPABILITY  
OC-4.11(2), D2-4.9.2(2), M1-4.11.8
- III-6      QUALIFICATION OF CABLE TRAYS  
OC-4.11(5), D2-4.9.3, M1-4.11.6
- III-7.B    EVALUATE DIFFERENCES IN ORIGINAL DESIGN CRITERIA  
OC-4.12, D2-4.10, M1-4.12

ISSUES REQUIRING  
ADDITIONAL EVALUATION  
WITH POTENTIAL FOR  
BACKFIT

MILLSTONE 1

- II-3 LOCAL FLOODING  
MI-4.1.3, 4.1.4, 4.1.5
- III-5.B MODERATE ENERGY PIPE BREAK EFFECTS  
MI-4.10.1
- III-6 LPCI/CSS HEAT EXCHANGER RESTRAINTS  
MI-4.11.3
- III-6 ELECTRICAL EQUIPMENT ANCHORS  
OC-4.11(3), MI-4.11.4
- IV-2 REACTIVITY CONTROL SINGLE FAILURE  
OC-4.15, MI-4.15
- V-5 INTERSYSTEM LEAKAGE  
OC-4.16.3, MI-4.16.2
- VI-4 INSTRUMENT LINES  
OC-4.22.4, MI-4.20.5
- VI-7.A.3 ESWS TESTING  
MI-4.21.2
- VII-3 LOSS OF INSTRUMENT BUS  
MI-4.26 (UNDER EVALUATION)
- XV-3 LOSS OF LOAD INITIAL POWER  
MI-4.34

DRESDEN 2

- II-3.B DESIGN BASIS GROUNDWATER (514 TO 517 FT. MSL)  
OC-4.4(2), D2-4.1.1
- III-1 FRACTURE TOUGHNESS DATA (RSCS, RBCCW, RWCU)  
OC-4.2(2), D2-4.2.2(1), M1-4.3.2\*
- III-2 REACTOR BUILDING SUPERSTRUCTURE - WIND LOADS  
OC-4.3.1, D2-4.3.1, M1-4.4.1\*
- III-2 VENTILATION STACK - WIND LOADS  
OC-4.3.2, D2-4.3.2, M1-4.4.2\*
- III-3.C INTAKE & DISCHARGE INSPECTION FREQUENCY  
OC-4.5.1, D2-4.4.2
- III-4.A SWS VENTILATION - TORNADO MISSILES  
OC-4.6.4, D2-4.5.1(1), M1-4.7\*
- III-4.A BATTERIES - TORNADO MISSILES  
D2-4.5.2, M1-4.7\*
- III-10.A TORQUE SWITCH BYPASS  
OC-4.14, D2-4.12.2
- V-6 REACTOR VESSEL MATERIAL SURVEILLANCE  
OC-4.17, D2-4.14
- V-11.A HIGH/LOW PRESSURE INTERLOCKS (RWCU)  
OC-4.19, D2-4.16, M1-4.18\*
- VI-6 RBCCW & AIRLOCK LEAK TESTING  
D2-4.19
- VII-3 SAFE SHUTDOWN - SINGLE FAILURE  
D2-4.25.3
- IX-5 LPCI/CS VENTILATION - SINGLE FAILURE  
OC-4.34(3), D2-4.29.2(1), M1-4.32.1\*

VIII-2

AC ANNUNCIATORS IEEE STD. 279-1971 (MODS COMPLETE)  
OC-4.31(1), D2-4.26.1\*, M1-4.28.5\*

XV-1

TURBINE BYPASS FOR FEEDWATER CONTROLLER FAILURE  
OC-4.35, D2-4.30, M1-4.33

NO ACTION

COMMON

- III-5.B UNISOLABLE BREAKS OUTSIDE CONTAINMENT  
OC-4.10(1), D2-4.8, M1-4.10.3
- III-6 ESF ELECTRICAL EQUIPMENT FUNCTIONALITY  
OC-4.11(4), D2-4.9.4, M1-4.11.5
- III-6 ESF PIPING SUPPORTS  
OC-4.11(1), D2-4.9.1\*, M1-4.11.7
- III-8.A LOOSE-PARTS MONITORING  
OC-4.14(1), D2-4.11, M1-4.13
- V-5 LEAKAGE DETECTION TESTABILITY  
OC-4.16.2, D2-4.13.3, M1-4.16.1
- V-10.B SAFE SHUTDOWN PROCEDURES  
OC-4.18, D2-4.25.1 & 2, M1-4.17
- VI-4 TWO CHECK VALVES FOR ISOLATION (FEEDWATER)  
OC-4.22.5, D2-4.18.4, M1-4.20.6
- VI-4 BOTH VALVES OUTSIDE CONTAINMENT  
OC-4.22.3, D2-4.18.5, M1-4.20.4
- VI-7.A.4 CORE SPRAY NOZZLE EFFECTIVENESS  
OC-4.24, D2-4.20, M1-4.22
- VI-10.A RESPONSE TIME TESTING  
OC-4.26.1, D2-4.22, M1-4.24.3



ISSUES NOT  
REQUIRING BACKFIT  
AS A RESULT OF SEP REVIEW

MILLSTONE

V-10.B (4.17) - SHUTDOWN PROCEDURES  
1.0

VI-7.A.3 (4.21) - CSS/ESW TESTING  
1.0

VI-7.C.1/VII-3 (4.23) - BUS TRANSFERS, LOSS OF INSTRUMENT BUS  
0.84

VI-10.A (4.24) - RPS TESTING  
1.0

IX-3 (4.31) - SERVICE WATER NONREDUNDANT PIPE FAILURE  
1.0

XV-3 (4.34) - LOSS OF LOAD INITIAL POWER  
1.0

DRESDEN 2

V-11.B (4.17) - SHUTDOWN COOLING INTERLOCK TESTING

MEDIUM

VI-7.C.1 (4.21) - DISCONNECT/LINK BREAKERS PROCEDURES

LOW

VI-10.B (4.23) - PARALLELING BATTERIES

LOW

VII-3 (4.25) - SHUTDOWN PROCEDURES

LOW

XV-16 (4.31) - SMALL LINE BREAK CONSEQUENCES

LOW

VII-1.A RPS ISOLATION  
DRESDEN (4.24) - LOW  
MILLSTONE (4.25) - 1.0

VIII-2 DIESEL/TURBINE ANNUNCIATORS AND BYPASSES  
DRESDEN (4.26) - LOW  
MILLSTONE (4.28.5) - 0.995

VIII-3.A BATTERY TESTING  
DRESDEN (4.27) - HIGH (IF EXISTING TEST INADEQUATE)  
MILLSTONE (4.29) - BEYOND SCOPE (QUALITATIVE)

VIII-3.B DC SYSTEM MONITORING  
DRESDEN (4.28) - HIGH  
MILLSTONE (4.30) - 0.987

IX-5 LOSS OF VENTILATION  
DRESDEN (4.29) - LOW  
MILLSTONE (4.32) - 1.0

XV-1 FEEDWATER CONTROLLER FAILURE WITHOUT BYPASS  
DRESDEN (4.30) - LOW  
MILLSTONE (4.33) - 1.0

XV-18 MAIN STEAM BREAK CONSEQUENCES  
DRESDEN (4.32) - LOW  
MILLSTONE (4.36) - 1.0

ISSUES ADDRESSED BY PRA\*

III-5.B UNISOLATABLE PIPE BREAK OUTSIDE CONTAINMENT  
DRESDEN (4.8) - LOW  
MILLSTONE (4.10) - INFORMATION NOT AVAILABLE

III-8.A LOOSE PARTS MONITORING  
DRESDEN (4.11) - LOW  
MILLSTONE (4.13) - 1.0

III-10.A THERMAL OVERLOAD BYPASSES  
DRESDEN (4.12) - MEDIUM  
MILLSTONE (4.14) - 0.996

V-5 PRIMARY COOLANT LEAKAGE DETECTION  
DRESDEN (4.13) - LOW  
MILLSTONE (4.16.1) - 0.98

V-11.A HIGH/LOW PRESSURE ISOLATION (RWCU)  
DRESDEN (4.16) - LOW (IF RELIEF WORKS)  
MILLSTONE (4.18) - 0.991

VI-4 CONTAINMENT ISOLATION  
DRESDEN (4.18) - LOW  
MILLSTONE (4.20) - 1.0

VI-10.A RESPONSE TIME TESTING  
DRESDEN (4.22) - LOW  
MILLSTONE (4.24.3) - 1.0

\* DRESDEN CHARACTERIZED AS LOW, MEDIUM OR HIGH  
MILLSTONE RATIO OF NEW TO OLD RISK

DRESDEN 2

II-4.E	DAM INTEGRITY
II-4.F	SETTLEMENT OF FOUNDATIONS
III-3.A	EFFECTS OF HIGH WATER LEVEL ON STRUCTURES
IV-2	REACTIVITY CONTROL SYSTEMS
V-4	PIPING AND SAFE-END INTEGRITY
V-12.A	WATER PURITY AND BWR PRIMARY COOLANT
VI-7.A.3	ECCS ACTUATION SYSTEM
VIII-1.A	POTENTIAL EQUIPMENT FAILURES ASSOCIATED WITH DEGRADED GRID VOLTAGE
IX-3	STATION SERVICE AND COOLING WATER SYSTEMS
XV-3	LOSS OF EXTERNAL LOAD, TURBINE TRIP, LOSS OF CONDENSER VACUUM, CLOSURE OF MAIN STEAM ISOLATION VALVE

MILLSTONE 1

V-6	REACTOR VESSEL INTEGRITY
V-11.B	RESIDUAL HEAT REMOVAL SYSTEM INTERLOCK REQUIREMENTS
VI-6	CONTAINMENT LEAK TESTING
VI-10.B	SHARED ENGINEERED SAFETY FEATURES

- XV-13 SPECTRUM OR ROD DROP ACCIDENTS (BWR)
- XV-14 INADVERTENT OPERATION OF EMERGENCY CORE COOLING SYSTEM AND CHEMICAL AND VOLUME CONTROL SYSTEM MALFUNCTION THAT INCREASES REACTOR COOLANT INVENTORY
- XV-15 INADVERTENT OPENING OF A PWR PRESSURIZER SAFETY/RELIEF VALVE OR A BWR SAFETY/RELIEF VALVE
- XV-19 LOSS-OF-COOLANT ACCIDENTS RESULTING FROM SPECTRUM OF POSTULATED PIPING BREAKS WITHIN THE REACTOR COOLANT PRESSURE BOUNDARY
- XV-20 RADIOLOGICAL CONSEQUENCES OF FUEL-DAMAGING ACCIDENTS (INSIDE AND OUTSIDE CONTAINMENT)
- XVII OPERATIONAL QUALITY ASSURANCE PROGRAM



- VII-2 ENGINEERED SAFETY FEATURES SYSTEM CONTROL LOGIC AND DESIGN
- VII-6 FREQUENCY DECAY
- VIII-4 ELECTRICAL PENETRATIONS OF REACTOR CONTAINMENT (DRESDEN EQUIVALENT)
- IX-1 FUEL STORAGE (MILLSTONE EQUIVALENT)
- IX-6 FIRE PROTECTION
- XIII-2 SAFEGUARDS/INDUSTRIAL SECURITY
- XV-4 LOSS OF NONEMERGENCY AC POWER TO THE STATION AUXILIARIES
- XV-5 LOSS OF NORMAL FEEDWATER FLOW
- XV-7 REACTOR COOLANT PUMP ROTOR SEIZURE AND REACTOR COOLANT PUMP SHAFT BREAK
- XV-8 CONTROL ROD MISOPERATION (SYSTEM MALFUNCTION OR OPERATOR ERROR)
- XV-9 STARTUP OF AN INACTIVE LOOP OR RECIRCULATION LOOP AT AN INCORRECT TEMPERATURE, AND FLOW CONTROLLER MALFUNCTION CAUSING AN INCREASE IN BWR FLOW RATE
- XV-11 INADVERTENT LOADING AND OPERATION OF A FUEL ASSEMBLY IN AN IMPROPER POSITION (BWR)

- III-10.C SURVEILLANCE REQUIREMENTS ON BWR RECIRCULATION PUMP AND DISCHARGE VALVES
- IV-1.A OPERATION WITH LESS THAN ALL LOOPS IN SERVICE
- IV-3 BWR JET PUMP OPERATING INDICATIONS
- V-10.A RESIDUAL HEAT REMOVAL SYSTEM HEAT EXCHANGER TUBE FAILURES
- VI-1 ORGANIC MATERIALS AND POST ACCIDENT CHEMISTRY
- VI-2.D MASS AND ENERGY RELEASE FOR POSTULATED PIPE BREAK INSIDE CONTAINMENT (MILLSTONE EQUIVALENT)
- VI-3 CONTAINMENT PRESSURE AND HEAT REMOVAL CAPABILITY (MILLSTONE EQUIVALENT)
- VI-7.C EMERGENCY CORE COOLING SYSTEM (ECCS) SINGLE-FAILURE CRITERION AND REQUIREMENTS FOR LOCKING OUT POWER TO VALVES, INCLUDING INDEPENDENCE OF INTERLOCKS ON ECCS VALVES
- VI-7.C.2 FAILURE MODE ANALYSIS (EMERGENCY CORE COOLING SYSTEM)
- VI-7.D LONG-TERM COOLING PASSIVE FAILURES (E.G., FLOODING OF REDUNDANT COMPONENTS)
- VII-1.B TRIP UNCERTAINTY AND SETPOINT ANALYSIS REVIEW OF OPERATING DATA BASE

<u>TOPIC</u>	<u>TITLE</u>
II-1.A*	EXCLUSION AREA AUTHORITY AND CONTROL
II-1.B	POPULATION DISTRIBUTION
II-1.C	POTENTIAL HAZARDS OR CHANGES IN POTENTIAL HAZARDS DUE TO TRANSPORTATION, INSTITUTIONAL, INDUSTRIAL, AND MILITARY FACILITIES
II-2.A	SEVERE WEATHER PHENOMENA
II-2.C	ATMOSPHERIC TRANSPORT AND DIFFUSION CHARACTERISTICS FOR ACCIDENT ANALYSIS
II-3.A	HYDROLOGIC DESCRIPTION
II-4	GEOLOGY AND SEISMOLOGY
II-4.A*	TECTONIC PROVINCE
II-4.B	PROXIMITY OF CAPABLE TECTONIC STRUCTURES IN PLANT VICINITY
II-4.C*	HISTORICAL SEISMICITY WITHIN 200 MILES OF PLANT
II-4.D	STABILITY OF SLOPES
III-4.C	INTERNALLY GENERATED MISSILES
III-4.D	SITE-PROXIMITY MISSILES (INCLUDING AIRCRAFT)
III-7.D	CONTAINMENT STRUCTURAL INTEGRITY TESTS
III-8.C	IRRADIATION DAMAGE, USE OF SENSITIZED STAINLESS STEEL, AND FATIGUE RESISTANCE

TOPICS WHICH MEET  
CURRENT CRITERIA OR  
ARE ACCEPTABLE ON  
"ANOTHER DEFINED BASIS"\*

\* THESE TOPICS ARE IDENTIFIED BY ASTERISKS

## TOPICS NOT APPLICABLE (CONT.)

SEP Topic No.	SEP title	Reason for deletion of topic
XI-2	Radiological (Effluent and Process) Monitoring Systems	Being resolved under generic activities A-02, "Appendix I." (See "Basis for Deletion" in Appendix A under Topic XI-2.)
XV-2	Spectrum of Steam System Piping Failures Inside and Outside Containment (PWR)	Not applicable to BWRs.
XV-6	Feedwater System Pipe Breaks Inside and Outside Containment (PWR)	Not applicable to BWRs.
XV-10	Chemical and Volume Control System Malfunction That Results in a Decrease in Boron Concentration in the Reactor Coolant (PWR)	Not applicable to BWRs.
XV-12	Spectrum of Rod Ejection Accidents (PWR)	Not applicable to BWRs.
XV-17	Radiological Consequences of Steam Generator Tube Failure (PWR)	Not applicable to BWRs.
XV-23	Multiple Tube Failures in Steam Generators	Not applicable to BWRs.
XVI	Technical Specifications	Will be addressed after completion of the integrated assessment.

## TOPICS NOT APPLICABLE

SEP Topic No.	SEP title	Reason for deletion of topic
* II-4.E	Dam Integrity	Not applicable to site.
III-3.B	Structural and Other Consequences (e.g., Flooding of Safety-Related Equipment in Basements) of Failure of Underdrain Systems	Not applicable to site because site does not have a system whose function is to lower the groundwater table.
III-7.A	Inservice Inspection, Including Prestressed Concrete Containments With Either Grouted or Ungouted Tendons	Not applicable to this unit's containment design.
III-7.C	Delamination of Prestressed Concrete Containment Structures	Not applicable to this unit's containment design.
III-8.B	Control Rod Drive Mechanism Integrity	Review published as NUREG-0479, "Report on BWR Control Rod Drive Failures."
III-10.B	Pump Flywheel Integrity	Not applicable to BWRs.
V-1	Compliance With Codes and Standards	Reviewed under inservice inspection/inservice test program.
V-2	Applicability of Code Cases	Not applicable at this time; to be reviewed for any future modifications using references to Code Cases.
V-3	Overpressurization Protection	Not applicable to BWRs, based on operating experience.
V-7	Reactor Coolant Pump Overspeed	Not applicable to BWRs.
V-8	Steam Generator Integrity	Not applicable to BWRs.
V-9	Reactor Core Isolation Cooling System (BWR)	Not applicable to this facility design.
VI-2.C	Ice Condenser Containment	Not applicable to this unit's containment design.
VI-7.A.1	Emergency Core Cooling System Reevaluation To Account for Increased Reactor Vessel Upper-Head Temperature	Not applicable to BWRs.
VI-7.A.2	Upper Plenum Injection	Not applicable to BWRs.
VI-7.B	Engineered Safety Feature Switchover From Injection to Recirculation Mode (Automatic Emergency Core Cooling System Realignment)	Not applicable to BWRs.
VI-7.C.3	Effect of PWR Loop Isolation Valve Closure During a Loss-of-Coolant Accident on Emergency Core Cooling System Performance	Not applicable to BWRs.
VI-7.F	Accumulator Isolation Valves Power and Control System Design	Not applicable to BWRs.
VI-9	Main Steam Line Isolation Seal System (BWR)	Not applicable to this facility design.
VII-7	Acceptability of Swing Bus Design on BWR-4 Plants	Not applicable to this facility design.
IX-4	Boron Addition System (PWR)	Not applicable to BWRs.
X	Auxiliary Feedwater System	Not applicable to BWRs.
XI-1	Appendix I	Being resolved under generic activities A-02, "Appendix I," and B-35, "Confirmation of Appendix I Models." (See "Basis for Deletion" in Appendix A under Topic XI-1.)



## GENERIC TOPICS DELETED

SEP Topic No.	SEP Title	TMI, USI, or SEP No.	TMI, USI, or SEP Title
II-2.B	Onsite Meteorological Measurements Program	TMI II.F.3 TMI III.A.1	Instrumentation for Monitoring Accident Conditions Improve Licensee Emergency Preparedness - Short Term
II-2.D	Availability of Meteorological Data in the Control Room	TMI II.F.3 TMI III.A.1 TMI I.D.1	Instrumentation for Monitoring Accident Conditions Improve Licensee Emergency Preparedness - Short Term Control Room Design Reviews
III-8.D	Core Supports and Fuel Integrity	USI A-2	Asymmetric Blowdown Loads on Reactor Primary Coolant System
III-9	Support Integrity	USI A-12 USI A-7 USI A-24 USI A-46 SEP III-6 SEP V-1	Fracture Toughness of Steam Generator and Reactor Coolant Pump Supports Mark I Containment Long-Term Program Environmental Qualification of Safety-Related Equipment Seismic Qualification of Equipment in Operating Plants Seismic Design Considerations Compliance With Codes and Standards (10 CFR Part 50, Section 50.55a)
III-11	Component Integrity	USI A-46 USI A-2 SEP III-6	Seismic Qualification of Equipment in Operating Plants Asymmetric Blowdown Loads on Reactor Primary Coolant Seismic Design Considerations
III-12	Environmental Qualification of Safety-Related Equipment	USI A-24	Qualification of Safety-Related Equipment
* V-4	Piping and Safe-End Integrity	USI A-42	Pipe Cracks in Boiling Water Reactors
V-13	Waterhammer	USI A-1	Waterhammer
VI-2.A	Pressure-Suppression-Type BWR Containments	USI A-7	Mark I Containment Long-Term Program
VI-2.B	Subcompartment Analysis	USI A-2	Asymmetric Blowdown Loads on Reactor Primary Coolant System
VI-5	Combustible Gas Control	TMI II.B.7 USI A-48	Analysis of Hydrogen Control Hydrogen Control Measures and Effects of Hydrogen Burns on Safety Equipment
VI-7.E	Emergency Core Cooling System Sump Design and Test for Recirculation Mode Effectiveness	USI A-43	Containment Emergency Sump Reliability
VI-8	Control Room Habitability	TMI III.D.3.4	Control Room Habitability Requirements
VII-4	Effects of Failure in Nonsafety-Related Systems on Selected Engineered Safety Features	USI A-47 USI A-17	Safety Implications of Control Systems Systems Interactions in Nuclear Power Plants
VII-5	Instruments for Monitoring Radiation and Process Variables During Accidents	TMI II.F.1 TMI II.F.2 TMI II.F.3	Additional Accident Monitoring Instrumentation Identification of and Recovery From Conditions Leading to Inadequate Core Cooling Instruments for Monitoring Accident Conditions
IX-2	Overhead Handling Systems (Cranes)	USI A-36	Control of Heavy Loads Near Spent Fuel Pool
XIII-1	Conduct of Operations	TMI I.C.6 TMI III.A.1 TMI III.A.2	Procedures for Verification of Correct Performance of Operating Activities Improve Licensee Emergency Preparedness - Short-Term Improving Licensee Emergency Preparedness - Long-Term
XV-21	Spent Fuel Cask Drop Accidents	USI A-36	Control of Heavy Loads Near Spent Fuel Pool
XV-22	Anticipated Transients Without Scram	USI A-9	Anticipated Transients Without Scram
XV-24	Loss of All AC Power	USI A-44	Station Blackout



SEP SUMMARY\*

DRESDEN 2 & MILLSTONE 1

- TOPICS DELETED
- TOPICS MEETING OR EQUIVALENT TO CURRENT CRITERIA
- TOPICS ADDRESSED BY PRA
  
- INTEGRATED ASSESSMENT
  - ISSUES REQUIRING NO BACKFIT
  - ISSUES REQUIRING FURTHER EVALUATION
  - ISSUES REQUIRING PROCEDURAL OR TECHNICAL SPECIFICATION CHANGES
  - ISSUES REQUIRING HARDWARE BACKFITS
  - ISSUES WITH DISAGREEMENT

\* COMMON AND UNIQUE TO DRESDEN 2 & MILLSTONE 1

SUMMARY

PHASE II TOPICS - 137

	<u>DRESDEN 2</u>	<u>MILLSTONE 1</u>
GENERIC TOPICS DELETED	19	20
PLANT SPECIFIC DELETED	30	31
TOPICS REVIEWED	88	86
TOPICS ACCEPTABLE	54	48
<u>INTEGRATED ASSESSMENT</u> TOPICS	34	38
ISSUES	72	87

RISK ANALYSIS OF OYSTER CREEK,  
DRESDEN-2, AND MILLSTONE-1  
SEP ISSUES

SANDIA NATIONAL LABORATORIES

ROBERT G. SPULAK, JR.  
PAUL AMICO, SAI  
DANIEL GALLAGHER, SAI

74

## BASIS OF EVALUATION

- OYSTER CREEK AND DRESDEN-2:

QUALITATIVE ANALYSIS OF IMPACT OF RESOLUTION OF EACH ISSUE ON DOMINANT CORE MELT SEQUENCES.

- MILLSTONE-1:

QUANTITATIVE ANALYSIS OF CHANGE IN CORE MELT FREQUENCY, EXPOSURE, AND RISK FROM RESOLUTION OF EACH ISSUE.

IREP MILLSTONE-1 PRA USED FOR BASE CASE:

- APPLIES DIRECTLY TO MILLSTONE-1.
- OYSTER CREEK AND DRESDEN-2 FAIRLY SIMILAR TO MILLSTONE-1. CHANGES MADE TO MILLSTONE-1 FAULT TREES TO REPRESENT OTHER PLANTS FOR QUALITATIVE CONSIDERATION.

OYSTER CREEK/DRESDEN-2 CLASSIFICATION  
OF ISSUE IMPORTANCE

CLASSIFICATION

CRITERION

HIGH

RESOLUTION OF ISSUE  
DOMINATES VALUE OF TOP  
EVENT OF A DOMINANT "PLANT"  
FAULT TREE OR DOMINANT  
SEQUENCE EVENT.

MEDIUM

RESOLUTION OF ISSUE IMPACTS  
BUT DOES NOT DOMINATE VALUE  
OF DOMINANT FAULT TREE OR  
DOMINANT SEQUENCE EVENT.

LOW

RESOLUTION OF ISSUE HAS NO  
IMPACT ON VALUE OF TOP  
EVENT OF DOMINANT FAULT  
TREE OR DOMINANT SEQUENCE  
EVENT.

## SEP COMPARATIVE RISK RESULTS

ISSUE	IMPORTANCE			MILLSTONE-1 ( $\Delta$ CORE MELT)
	DRESDEN-2	OYSTER CREEK		
III-8.A LOOSE PARTS	LOW	LOW		0%
III-10.A MOV THERMAL OVERLOAD BYPASS	MEDIUM	MEDIUM		1%
VI-4 CONTAINMENT ISOLATION	LOW	LOW		0%
VIII-3.B DC INSTRUMENTATION	HIGH	HIGH		0.6%




OBJECTIVE:

EVALUATE THE SEP ISSUES FOR OYSTER CREEK,  
DRESDEN-2, AND MILLSTONE-1 BASED ON THE IMPACT  
THEIR RESOLUTION WOULD HAVE ON PROBABILISTIC  
CALCULATIONS OF RISK.

SCOPE:

THOSE ISSUES WHICH WERE WITHIN THE SCOPE OF WELL  
ESTABLISHED PRA TECHNIQUES.

# OYSTER CREEK/DRESDEN-2 METHODOLOGY



"PLANT" = DRESDEN-2 OR OYSTER CREEK

DOMINANT FAULT TREE OR EVENT WOULD  
APPEAR IN DOMINANT ACCIDENT SEQUENCES.

MILLSTONE-1 ANALYSIS:

RE-CALCULATED RESULTS OF IREP MILLSTONE-1 PRA  
INCORPORATING RESOLUTION OF EACH SEP ISSUE.

## CATEGORIES OF MILLSTONE-1 ISSUE ANALYSIS

<u>CATEGORY</u>	<u>DESCRIPTION</u>
DATA	ISSUE AFFECTS ONLY BASIC EVENT DATA. NEW CUT SETS NOT REQUIRED.
MODELING	ISSUE AFFECTS DESIGN OF SYSTEM AND SYSTEM FAULT TREE. NEW CUT SETS WERE GENERATED.
BROAD	ISSUE NOT ANALYZED WITH IREP ACCIDENT SEQUENCES. ASSESSMENT MADE ON GENERAL PRINCIPLES OR INVENTION OF NEW SEQUENCES.

MILLSTONE-1 METHODOLOGY

PROPOSED  
SEPB  
IMPROVE-  
MENT

CAN ISSUE BE  
ANALYZED WITH  
IREP DOMINANT  
SEQUENCES?

YES

DATA CHANGES  
ONLY?

NO

MODIFY IREP  
MILLSTONE-1  
FAULT TREES

NO

YES

CAN ISSUE BE  
SHOWN TO BE  
NEGLECTABLE  
ON GENERAL  
PRINCIPLES?

YES

MODIFY IREP  
MILLSTONE-1  
DATA

MODIFY DATA

NO

INVENT NEW  
ACCIDENT  
SEQUENCE

RE-QUANTIFY  
DOMINANT  
SEQUENCES

RE-SOLVE  
DOMINANT  
SEQUENCES

RE-QUANTIFY  
NEW ACCIDENT  
SEQUENCE

CALCULATE  
CHANGE IN  
OVERALL  
MILLSTONE-1  
CORE MELT  
FREQUENCY/  
RISK

BROAD

DATA

MODELING



RESULTS OF MILLSTONE-1 ANALYSIS

<u>ISSUE</u>	<u>CONCERN</u>	<u>DECREASE IN CORE MELT FREQUENCY (1) (R-YR)<sup>-1</sup></u>	<u>DECREASE IN EXPOSURE (2) (MAN-REM/R-YR)</u>	<u>NEW RISK/ OLD RISK</u>
III-5.B	PIPE BREAK OUTSIDE CONTAINMENT	(3)		
III-8.A	LOOSE PARTS	0.0	0.0	1.0
III-10.A	MOV THERMAL OVERLOAD PROTECTION	$3 \times 10^{-6}$	3	0.996
V-5	LEAK DETECTION	$3 \times 10^{-6}$	16	0.98
V-10.B	COLD SHUTDOWN	0.0	0.0	1.0
V-11.A	RWCU LOCA	$4 \times 10^{-7}$	3	0.991
VI-4	CONTAINMENT PENETRATIONS	0.0	0.0	1.0
VI-6	CONTAINMENT LEAK TESTING	0.0	0.0	1.0
VI-7.A.3	TESTING OF ECCS	0.0	0.0	1.0
VI-7.C.1	} REDUNDANCY OF ELECTRICAL BUSES	$3 \times 10^{-5}$	90	0.84
VII-3				
VI-10.A	TESTING OF RPS	0.0	0.0	1.0
VII-1.A	ISOLATION OF RPS	0.0	0.0	1.0
VIII-2	BYPASSING GAS TURBINE TRIPS	$1 \times 10^{-6}$	3	0.995
VIII-3.A	BATTERY TESTING	(4)		

RESULTS OF MILLSTONE-1 ANALYSIS (Cont.)

<u>ISSUE</u>	<u>CONCERN</u>	<u>DECREASE IN CORE MELT FREQUENCY (1) (R-YR)<sup>-1</sup></u>	<u>DECREASE IN EXPOSURE (2) (MAN-REM/R-YR)</u>	<u>NEW RISK/ OLD RISK</u>
VIII-3.B	DC BUS INSTRUMENTATION	1.7x10 <sup>-6</sup> (5) 7.4x10 <sup>-6</sup> (6)	2 (5) 8 (6)	0.997 (5) 0.987 (6)
IX-3	PIPE BREAK SINGLE FAIL- URE IN SWS, TBSCCW	0.0	0.0	1.0
IX-5	VENTILATION	0.0	0.0	1.0
XV-1	TRANSIENTS WITH TURBINE BYPASS UNAVAILABLE	0.0	0.0	1.0
XV-3	MCPR, LOSS OF EXTERNAL LOAD	0.0	0.0	1.0
XV-18	MAIN STEAM LINE BREAK	0.0	0.0	1.0

- (1) TOTAL CORE MELT FREQUENCY =  $3 \times 10^{-4}$  / REACTOR-YEAR.
- (2) TOTAL EXPECTED EXPOSURE = 550 MAN-REM/REACTOR-YEAR.
- (3) INFORMATION TO ANALYZE THIS ISSUE NOT RECEIVED FROM UTILITY.
- (4) ISSUE COULD REDUCE BATTERY UNAVAILABILITY, AT MOST, BY A FACTOR OF 16. EFFECT ON RISK OUTSIDE SCOPE OF THIS ANALYSIS.
- (5) WITHOUT DECREASE IN MAINTENANCE UNAVAILABILITY.
- (6) WITH DECREASE IN MAINTENANCE UNAVAILABILITY.

RESULTS OF DRESDEN-2 ANALYSIS

<u>Issue</u>	<u>System/Component</u>	<u>Change in Unavailability <math>Q_{new}/Q_{old}</math></u>	<u>Appears in Dominant Fault Tree/Event</u>	<u>Affects Top Event</u>	<u>Importance</u>
III-5.B	Pipe break outside containment	---	No	No	Low
III-8.A	Transients	1.0 (transient frequency)	Yes	No	Low
III-10.A	Valves in all ECCS	0.86 (1 valve)	Yes	Yes	Medium
V-5	Small LOCA	1.0 (LOCA frequency)	No	No	Low
V-11.A	RWCU LOCA	$1.2 \times 10^{-6}$	No	---	Low*
V-11.B	Shutdown Cooling	0.85 (shutdown cooling)	Yes	Yes	Medium
VI-4	Containment integrity	---	No	---	Low
VI-6	Containment integrity	---	No	---	Low
VI-7.C.1	AC and DC power	1.0 (AC or DC)	Yes	No	Low
VI-10.A	Reactor Trip System, Engineered Safety Features	1.0 (RTS)	Yes	No	Low
VI-10.B	AC and DC power	1.0 (DC power)	Yes	No	Low

\*If pressure relief valve sufficiently sized. High importance if not sufficiently sized.

## RESULTS OF DRESDEN-2 ANALYSIS

<u>Issue</u>	<u>System/Component</u>	<u>Change in Unavailability <math>Q_{new}/Q_{old}</math></u>	<u>Appears in Dominant Fault Tree/Event</u>	<u>Affects Top Event</u>	<u>Importance</u>
VII-1.A	Reactor Trip System	1.0 (RTS)	Yes	No	Low
VII-3	Cooldown procedures	---	No	No	Low
VIII-2	AC power	0.98 (1 Diesel)	Yes	No	Low
VIII-3.A	DC power	$6.5 \times 10^{-2}$ ** (1 battery)	Yes	Yes	High
VIII-3.B	DC Power	0.19 (1 bus)	Yes	Yes	High
IX-5	Ventilation	---	No	No	Low
XV-1	Power Conversion System	1.0	Yes	No	Low
XV-16	Offsite doses	---	No	---	Low
XV-18	Offsite doses	---	No	---	Low

\*\*If present battery testing is totally ineffective.

RESULTS OF OYSTER CREEK ANALYSIS

<u>Issue</u>	<u>System/Component</u>	<u>Change in Unavailability <math>Q_{new}/Q_{old}</math></u>	<u>Appears in Dominant Fault Tree/Event</u>	<u>Affects Top Event</u>	<u>Importance</u>
III-8.A	Transients	1.0 (Transient Frequency)	Yes	No	Low
III-10.A	Valves in Most Systems	0.86 (1 valve)	Yes	Yes	Medium
IV-2	Reactor Trip System	1.0	Yes	No	Low
V-5	Small LOCA	$\geq 0.24$ (LOCA Frequency)	No	---	Low
V-10.B	Residual Heat Removal Procedures	1.0 (RHR)	Yes	No	Low
V-11.A	Interfacing Systems LOCA	---	No	---	Low
VI-4	Containment Integrity	---	No	---	Low
VI-7.A.3	Emergency Condensers	1.0 (Emergency Condensers)	Yes	No	Low
VI-7.C.1	AC Power	0.85 (AC Power)	Yes	Yes	Medium

RESULTS OF OYSTER CREEK ANALYSIS

<u>Issue</u>	<u>System/Component</u>	<u>Change in Unavailability <math>Q_{new}/Q_{old}</math></u>	<u>Appears in Dominant Fault Tree/Event</u>	<u>Affects Top Event</u>	<u>Importance</u>
VI-10.A	Reactor Trip System, Engineered Safety Features	1.0 (RTS)	Yes	No	Low
VII-1.A	Reactor Trip System	1.0 (RTS)	Yes	No	Low
VII-1.B	Setpoints for Several Systems	0.93 (1 Sensor)	Yes	No	Low
VII-2	Breakers for Several Systems	0.71 (1 Breaker)	Yes	No	Low
VII-3	Vital Instrumentation	0.36 - $1.2 \times 10^{-4}$ (Vital AC Panel)	Yes	No	Low
VIII-2	AC Power	0.98 (1 Diesel)	Yes	No	Low
VIII-3.B	DC Power	~0.25 (1 Bus)	Yes	Yes	High
VIII-4	Containment Integrity	---	No	---	Low
XV-16	Offsite Doses	---	No	---	Low
XV-18	Offsite Doses	---	No	---	Low
XV-19	Offsite Doses	---	No	---	Low

# Control and Instrumentation

Edited by C. S. Walker

## Reliability of Engineered Safety Features as a Function of Testing Frequency

By I. M. Jacobs\*

[Editor's Note: *Nuclear Safety* is pleased to present this paper by Mr. Jacobs in that it is a significant and original contribution that endeavors to lead the way to more reliable design of all safety systems.]

*Abstract: The reliability of an engineered safety system is highly dependent on the frequency of tests performed to demonstrate its operability. Thus the frequency of tests becomes a design consideration of almost importance. When the system is new, the operator must rely primarily on the designer's recommended test frequency. With actual in-service experience, the operator is able to regulate the test frequencies to attain an overall reliability goal. Under certain limiting conditions, there is clearly an optimum test frequency; more frequent or less frequent testing will degrade reliability. Techniques of modeling have been developed to solve safety-system reliability problems. The models serve as the means to bridge the gap between the uncertainty of design decisions and the stark reality of actual application.*

Engineered safety systems are standby systems. They are tested periodically to confirm that they are operable and then returned to standby status. Although some failures of components in standby systems are self-annunciating, there are other unsafe failures that are not revealed until the next periodic test. The longer the interval between tests, the higher the probability that a failure has occurred since the last test. However, testing the system too frequently may

take it out of service too much or even wear it out, both of which lead to decreased reliability.

Recently there have been reliability goals proposed on critical systems. To be meaningful these proposed goals must be in force throughout the lifetime of the nuclear power plant. Accordingly the goals are of concern to the design engineer at the conceptual stage, as well as to the plant operator, who must demonstrate continued conformance.

This paper deals with the general subject of testing of engineered safety systems and specifically with the following areas:

1. The time interval between tests as a design consideration.
2. Optimizing the availability by proper selection of the time interval between tests.
3. Adjusting the time interval between tests on the basis of field failure-rate information to assure conformance to a reliability goal over the nuclear power plant lifetime.

The terms "reliability" and "availability" are used throughout this paper. When reliability is used in a qualitative sense, it implies quality and integrity. When reliability is used in a quantitative sense, it refers to the classic definition, which embraces the concept of probability of survival for a finite time. Availability is the probability that a given system is operational at some unspecified future instant in time, and it takes account of downtime for repair work. The two terms are interrelated, and frequently availability may be treated as an average reliability. The meanings will be clarified as used here in their proper context.

### Testing Frequency as a Design Consideration

A good designer chooses his basic components wisely and applies them conservatively within their

\*I. M. Jacobs was graduated from the University of Washington in 1944 with a B.S. degree in Electrical Engineering. After a brief tour in the U. S. Navy, he joined the General Electric Company at Hanford, Wash., where he developed several primary radiation detectors and low-level logarithmic amplifiers for application in the monitoring and control of nuclear reactors and processes. In 1955 Mr. Jacobs joined the Atomic Power Equipment Department of the General Electric Company at San Jose, Calif.; he was responsible for the design of standard nuclear instruments and products for use throughout General Electric's power reactors. Mr. Jacobs is currently responsible for design analysis, reliability, and safety criteria for reactor protection and engineered safety systems for new reactor applications.



ratings. In the interest of overall reliability, he endeavors to keep his design simple, easy to understand, and easy to test. In the interest of economy, he strives to keep the system in reasonable balance from the standpoint of reliability. Finally, he tries to imagine his system as it will be installed in an operating reactor plant and adjusts his design to the environments that exist there throughout the useful lifetime of the plant.

In addition, the design engineer must be the first one to be concerned with the thoroughness and frequency of system tests. First, he must design the system so that it can be adequately tested. The ease with which the test can be performed must in some measure be commensurate with the expected frequency of the test, and the designer must accordingly

make provisions for the tests. Second, the recommendations of the designer as to the testing program must be passed along to the plant operator. This helps to assure that the design intent for the system is not thwarted before the operator can accumulate operating and failure-rate experience on his plant.

THE MODEL

Perhaps the concept of testing frequency as a design consideration can best be conveyed through the medium of an example problem. For this we assume that the designer is given the task of designing a reactor protection system with a goal of  $10^{-5}$  or less probability of failure. His first conceptual design may be the simple reactor protection system of Fig. 1.




Fig. 1 A simple reactor protection system for monitoring two parameters.

normally called a two-out-of-three, or majority, logic system. In Fig. 1 three channels of bistable sensors are shown monitoring parameter No. 1. Parameter No. 2 is monitored by three other channels, each channel consisting of a sensor, an amplifier with its associated power supply, and a bistable trip circuit. In both cases the channel output to the logic is a signal that deenergizes an individual relay coil whose many contacts are arranged in the two-out-of-three logic. When both monitored parameters are within preassigned limits, all relay coils are energized, all the relay contacts are closed, and power is furnished to all four scram buses. Under those conditions the control rods are restrained from scrambling. If the measured parameter falls outside preassigned limits, all three channels detect this change, all three bistable trip circuits assume their safe or relaxed state, the relay coils deenergize, the relay contacts open, all four scram buses are deenergized, and the control rods scram. There is an obvious redundancy. The system is tolerant of failure of at least two devices are operable in each circuit or system.

#### THE ASSUMPTIONS

To formulate a tractable model, the problem must have definite bounds. The following assumptions are therefore made:

1. The three channels from sensor through the relay magnetic circuit are independent; i.e., a failure in one channel in no way changes the probability of failure in another channel.
2. All relay contacts are independent of everything except the state of the relay coil itself, i.e., energized or deenergized.
3. The individual control rods are independent. Failure of sufficient independent control rods to be of significance from the standpoint of safety has such a low probability as to be of no concern.
4. The control rods are distributed between the four scram buses so that loss of any two buses (failure to scram) is of no concern.
5. Based on the monitored parameter being outside preassigned limits, the system is successful if the voltage on two or more buses drops to zero.
6. Component parts have a constant failure rate.
7. Immediately following a test, there are no failures in the system.

#### THE MATHEMATICS

There are three channels. The probability that a channel is "good" for the interval between tests is  $p$ . The probability that it is "failed" is  $q$ , where  $p + q = 1$ . Use of the binomial expansion of

$$(p + q)^3 = 1 \quad (1)$$

yields

$$p^3 + 3p^2q + 3pq^2 + q^3 = 1 \quad (2)$$

where  $p^3$  = probability that exactly three channels are good

$3p^2q$  = probability that exactly two channels are good and exactly one is failed

$3pq^2$  = probability that exactly one channel is good and exactly two are failed

$q^3$  = probability that exactly three channels are failed

It is more convenient to calculate the probability of system failure than the probability of system success. Therefore, based on the rules of conditional probability, the expression for the probability of system failure is

$$\text{Prob}(F) = \text{Prob}(F|q^3)q^3 + \text{Prob}(F|3pq^2)3pq^2 + \text{Prob}(F|3p^2q)3p^2q + \text{Prob}(F|p^3)p^3 \quad (3)$$

where  $\text{Prob}(F|q^3)$  is the probability of system failure given that exactly three channels have failed.

If exactly three channels have failed, system failure is a certainty. Therefore

$$\text{Prob}(F|q^3) = 1 \quad (4)$$

Likewise, if exactly two channels have failed and exactly one is good, failure is still a certainty. Therefore

$$\text{Prob}(F|3pq^2) = 1 \quad (5)$$

If exactly one channel has failed and exactly two are good, two particular relay contacts must open in each scram bus in order for that bus to successfully scram. If each contact has a reliability of  $r$ , the probability that a particular bus will scram is  $r^2$  and the probability that it will fail to scram is  $(1 - r^2)$ . There are four scram buses; so all the possible combinations can be evaluated by forming a binomial expansion of

$$[r^2 + (1 - r^2)]^4 = 1 \quad (6)$$

which yields

$$(r^2)^4 + 4(r^2)^3(1 - r^2) + 6(r^2)^2(1 - r^2)^2 + 4r^2(1 - r^2)^3 + (1 - r^2)^4 = 1 \quad (7)$$

where  $(1 - r^2)^4$  is the probability that exactly four buses fail to scram and  $4r^2(1 - r^2)^3$  is the probability that exactly three buses fail to scram. Thus

$$\text{Prob}(F|3p^2q) = (1 - r^2)^4 + 4r^2(1 - r^2)^3 \quad (8)$$

since failure is defined as three or more buses failing to scram.

Finally, we consider the case where all three channels are known to be good. The probability that both of a given pair of contacts will fail to open is  $(1-r^2)$ . The probability that all three pairs of contacts will fail to open is  $(1-r^2)^3$ . Then, forming a binomial expansion of

$$\{(1-r^2)^3 + [1 - (1-r^2)^3]\}^4 = 1 \quad (9)$$

yields

$$[(1-r^2)^3]^4 + 4[(1-r^2)^3]^3[1 - (1-r^2)^3] + \dots = 1 \quad (10)$$

where  $(1-r^2)^3$  is the probability of exactly four buses failing to scram and  $4[(1-r^2)^3]^3[1 - (1-r^2)^3]$  is the probability of exactly three buses failing to scram. Thus

$$\text{Prob}(F|p^3) = [(1-r^2)^3]^4 + 4[(1-r^2)^3]^3[1 - (1-r^2)^3] \quad (11)$$

Now the expression for the probability of failure may be written as

$$\text{Prob}(F) = q^3 - 3pq^2 + [(1-r^2)^4 + 4r^2(1-r^2)^3]3p^2q + \{[(1-r^2)^3]^4 + 4[(1-r^2)^3]^3[1 - (1-r^2)^3]\}p^3 \quad (12)$$

by substituting the results of Eqs. 4, 5, 8, and 11 in Eq. 3.

#### THE ALLOCATION

Prob( $F$ ) in Eq. 12 may be evaluated for various values of  $r$  and  $q$  since  $p$  is the complement of  $q$ . The results of the evaluation are shown in Fig. 2 as plotted on a log-log scale. The Prob( $F$ ) is shown as the ordinate and  $q$ , the probability of a channel failure, as the abscissa for a family of values of  $r$ , the probability that a relay contact successfully opens its circuit.

Two things of importance become evident from the plot. If the design goal is  $10^{-5}$  or less for Prob( $F$ ), values of  $r$  less than approximately 0.87 are totally unacceptable. Furthermore, values of  $r$  greater than approximately 0.98 do not improve system reliability in the vicinity of  $10^{-5}$  probability of system failure. Thus any pair of compatible values for  $r$  and  $q$  that can be selected from the shaded area is acceptable. Inasmuch as an  $r$  of 0.98 for a relay contact is probably readily achievable, point A is a reasonable choice for a design point. This corresponds to an  $r$  of 0.98 and a  $q$  of  $1.65 \times 10^{-3}$  or a  $p$  of 0.99835.

At this point the designer must make a tentative selection of a relay and a bistable sensor that satisfies the performance requirements of his system and determine the failure rate that applies to each. We assume for the purposes of this example that the relay contact has an unsafe failure rate,  $\lambda_r$ , of  $0.01 \times 10^{-6}$ /hr and the bistable sensor, including the asso-




Fig. 2 Graph of Prob( $F$ ) as function of  $q$  for various values of  $r$ .

ciated relay coil, has an unsafe failure rate,  $\lambda_s$ , of  $10 \times 10^{-6}$ /hr. The unsafe failure rate is the overall failure rate multiplied by a factor to adjust for the decimal fraction of the failure modes that are unsafe to the application under study.

The designer is now prepared to examine the test intervals that are compatible with his circuit and component selection. If the failure rate is  $\lambda$  and the interval between tests is  $\tau$ , the average reliability for the interval is  $1 - \lambda(\tau/2)$  for small values of  $\lambda(\tau/2)$ . From this relation the time interval between tests ( $\tau_r$ ) for the relay to have a required reliability of 0.98 becomes

$$1 - \frac{\lambda_r \tau_r}{2} = 0.98$$

and thus

$$\tau_r = 4 \times 10^6 \text{ hr}$$

or 456 years between tests of the relay contact. For the bistable sensor with a required reliability of 0.99835, that is

$$1 - \frac{\lambda_s \tau_s}{2} = 0.99835$$

the interval between tests is

$$\tau_1 = 330 \text{ hr}$$

At this point the designer must make a judgment. He must weigh the operational difficulties that may be associated with performing a test every 330 hr against the alternate opportunities for improved bistable sensors with lower failure rates. He may wish to reconsider his original system configuration to see whether another logic choice is more appropriate. Finally, when he does select a test interval, he must make provisions so that the test can be performed at that frequency without undue burden on the plant operator.

Other design trade-offs are attractive. Consider, for example, the use of the sensor-amplifier-bistable combination shown in Fig. 1 in place of the single bistable sensor. The sensor-amplifier portion of the circuit is characterized by the fact that it puts out a continuous signal. Furthermore, if the channel fails in an unsafe mode, this fact would either be alarmed or become readily apparent by virtue of the fact that its reading disagreed with the readings of the other two channels monitoring the same parameter. An unsafe failure in such a channel should be discovered almost as soon as it occurs, certainly within an hour. The failure rate of the sensor-amplifier combination may be substantially higher than that of the simpler bistable sensor it replaces. We will assume for the purposes of this illustration that the analog sensor-amplifier (including power supply) portion of the channel has an unsafe failure rate of  $\lambda_1$ , where  $\lambda_1$  is  $100 \times 10^{-6}$ /hr, and an equivalent test interval,  $\tau_1$ , of 1 hr. We will also assume that the failure rate of the associated bistable trip circuit is  $\lambda_2$ , where  $\lambda_2$  is  $10 \times 10^{-6}$ /hr. The test interval for the trip circuit,  $\tau_2$ , is to be determined. The reliability equation is

$$\left(1 - \frac{\lambda_1 \tau_1}{2}\right) \left(1 - \frac{\lambda_2 \tau_2}{2}\right) = 0.99835$$

and from this it can be approximated that

$$\frac{\lambda_1 \tau_1}{2} + \frac{\lambda_2 \tau_2}{2} = 0.00165$$

Solving for  $\tau_2$  gives

$$\tau_2 = \frac{0.00330 - \lambda_1 \tau_1}{\lambda_2} = 320 \text{ hr}$$

between tests of the bistable trip circuit.

The benefit of the trade-off is that the bistable trip circuit may be designed for convenient and simple electrical testing, whereas the bistable sensor, though simple and reliable, requires an actual perturbation

in the parameter being measured or the synthetic substitution of an equivalent signal, either of which may be very difficult to accomplish.

#### DISCUSSION

A comment about the design is in order at this point. The relay-contact matrix portion of the system may very well be overly complex in comparison with the balance of the circuit. There are many redundant relay contacts; in fact, there are so many that any one contact set is not really very important to the system. The 456-year interval between tests is, of course, absurd, and the designer may wish to investigate other alternate systems with the view of taking more advantage of the inherent high reliability of the components. The three safety channels are probably the ultimate limitation on system reliability. For this reason the logic portions of the circuit should have a high order of reliability in order to realize the full reliability potential of the safety channels.

A comment about the mathematical model is also in order. The relay contacts were assumed to be independent of each other. The designer should satisfy himself that this is true; for example, he should be sure that a given relay contact could stick closed and not in any way influence another contact on the same relay to stick closed also. In addition, it was assumed that there was no way for power to be applied to a scram bus except through relay contacts. Other inadvertent short-circuit paths around each contact matrix should be considered as having some probability, and the test should be devised so that they can be detected.

The particular design of Fig. 1 is not represented as being a good or even practical design. As it stands it suffers from false scrams due to loss of power from the power supply to the scram bus. The design was chosen because its mode of operation is clearly self-evident and it serves as a convenient illustration of the analysis technique. The actual design process is an iterative one. The designer, having learned about the trade-off potentials in this example, must evaluate other designs in order to choose the one that best satisfies all the constraints that are imposed on him.

A mathematical model can be developed to calculate either the average reliability over the test interval or the minimum reliability expected at the end of the test interval. If the various components in a system undergo tests at different frequencies, as is often the case, the concept of average reliability as used in the foregoing example leads to a much more realistic and tractable model than the model based on minimum reliability. The maximum effect on the expected probability of failure is a factor of 2. If this is considered to be significant, the reliability goal should be adjusted accordingly and the average reliability concept used throughout the model.



### Optimum Test Interval

The availability of a system is a function of the length of the interval between thorough tests performed on the system. In general, the more frequent the tests, the higher the availability because the system is not allowed to remain in a failed state for long periods of time. However, it is sometimes necessary or desirable to disable the system during the actual test. For example, the sensor may have to be disconnected from the real process variable and a dummy signal substituted. Or, for emergency cooling systems, it may be necessary to exercise the system by pumping water but bypass the water to a sump. In a one-out-of-two reactor protection system, it may be necessary to actually bypass a channel to test it. The Institute of Electrical and Electronics Engineers' Criteria for Nuclear Power Plant Protection Systems, No. 279, makes allowance for such a contingency.

Where any portion of the system is disabled in order to perform a test, an immediate conflict of purpose develops. If the test requires a fixed time to perform and the frequency of the test is increased, the point may be reached where more frequent testing will take the system out of service more total time than that time which could accumulate from unrevealed failures. This suggests that there may be an optimum interval between tests, and such is indeed the case.

#### THE PROBLEM

Figure 3 illustrates the effect of testing on system availability. In part *a* of Fig. 3, the system is tested once each  $\tau_1$  hours. The test requires  $t$  hours to complete, and during that time the system is rendered inoperative. The system fails at a constant rate  $\lambda$ . The availability is unity immediately following a test and decreases exponentially until the next test, at which time the availability falls to zero for the duration of the test.




Fig. 3 Example of the effect of test interval on availability.

In part *b* of Fig. 3, the interval between tests is shortened to  $\tau_2$ , but the duration of the test remains constant. Because the failure rate is constant, availability degrades along the same curve as part *a* of Fig. 3, but it does not degrade to as low a level.

Obviously, if the interval between tests is shortened until it is equal to the time to perform the test, the system would be on test all the time and the availability would be zero. If the interval between tests is extremely long, the system is allowed to degrade to a very low level of availability and to remain there for a long time, and this leads to low overall availability. Intuitively, this suggests that there may be a test interval that is optimum for a given system failure rate and test duration to maximize availability.

#### THE SOLUTION

We will consider exactly one cycle of the repeating operation shown in Fig. 4. The availability of the sys-




Fig. 4 One cycle of test interval.

tem is the probability that the system will be operational at any point in future time. The probability that the system is good can be written as

$$P(S) = P(S|A) P(A) + P(S|B) P(B) \quad (13)$$

where  $P(S)$  is the probability that the system is good,  $P(S|A)$  is the probability that the system is good given that the random point in future time falls in time domain A,  $P(A)$  is the probability that the random point in future time falls in time domain A, etc. The probability that the system is good if the random point in future time is in time domain B is zero because the system is known to be inoperative during test. Thus

$$P(S|B) = 0 \quad (14)$$

The probability that the random point in future time falls in time domain A is

$$P(A) = \frac{\tau - t}{\tau} \quad (15)$$

since all times are equally probable.

The probability that the system is good if the random point in future time is in time domain  $A$  is taken to be the average reliability over the interval given by

$$P(S|A) = \frac{1}{\tau - t} \int_0^{\tau-t} e^{-\lambda x} dx \quad (16)$$

Integration and evaluation yield

$$P(S|A) = \frac{1}{\lambda(\tau - t)} [1 - e^{-\lambda(\tau - t)}] \quad (17)$$

Substitution of Eqs. 14, 15, and 17 in Eq. 13 yields

$$P(S) = \frac{1}{\lambda\tau} [1 - e^{-\lambda(\tau - t)}] \quad (18)$$

Equation 18 shows the availability of the system to be a function of the three parameters  $\lambda$ ,  $\tau$ , and  $t$ , as expected. Figure 5 shows a plot of Eq. 18 evaluated for two cases: (1)  $\lambda = 10^{-4}$ /hr,  $t = 1$  hr, and (2)  $\lambda = 10^{-5}$ /hr,  $t = 1$  hr. The unavailability,  $1 - P(S)$ , is plotted rather than  $P(S)$  in order to show the results better. The curves dip through a minimum, indicating that under the conditions specified there is a test interval that leads to the optimum availability. As the failure rate decreases, the optimum test interval becomes longer.

#### OPTIMIZATION

The optimum test interval can be determined more expeditiously than by plotting the curve of unavailability vs. test interval, as was done in Fig. 5. We assume that  $\lambda$  and  $t$  are known, fixed constants of the




Fig. 5 Unavailability vs. test interval.

system, differentiate Eq. 18 with respect to  $\tau$ , and set the result equal to zero. Thus

$$\frac{dP(S)}{d\tau} = \frac{1}{\lambda\tau^2} [e^{-\lambda(\tau-t)} (1 + \lambda\tau)] - \frac{1}{\lambda\tau^2} = 0 \quad (19)$$

This transcendental equation is not readily solved explicitly for  $\tau$ . However, it can be manipulated to the form shown in the following equation and evaluated:

$$e^{-\lambda\tau} + \lambda\tau e^{-\lambda\tau} = e^{-\lambda t} \quad (20)$$

The result of this evaluation is shown in Fig. 6, where  $M$  is plotted against  $\lambda\tau$ . If  $\lambda$  and  $t$  are known, the value of  $\tau$  for optimum availability can be determined. For example, if  $\lambda$  is  $10^{-4}$  failure per hour and  $t$  is 1 hr, the product  $M$  is  $10^{-4}$ . The value of  $\lambda\tau$  corresponding to a  $M$  of  $10^{-4}$  is  $1.4 \times 10^{-2}$ , and  $\tau$  is 140 hr. This corresponds to the apparent minimum point on the curve for  $\lambda = 10^{-4}$  shown in Fig. 5.

Equation 20 can be solved explicitly for  $\tau$  if the exponential terms are approximated by the series

$$e^x = 1 + x + \frac{x^2}{2!} + \frac{x^3}{3!} + \dots \quad (21)$$

Approximating Eq. 20 by the series and neglecting all terms higher than second order yield

$$\tau^2 = 2t \left( \frac{1}{\lambda} - \frac{t}{2} \right) \quad (22)$$

In general,  $1/\lambda \gg t$ , so with little error

$$\tau = \sqrt{\frac{2t}{\lambda}} \quad (23)$$

Equation 23 is an approximate solution for the optimum  $\tau$ . The  $M$  vs.  $\lambda\tau$  curve derived from Eq. 23 is plotted in Fig. 6 and labeled "Approximate Solution." It compares very favorably with the "Exact Solution" for values of  $\lambda\tau$  less than 0.1. At  $\lambda\tau = 0.1$ , the error is 6.7%. For most practical values of  $\lambda$ ,  $\tau$ , and  $t$ , the approximate solution for  $\tau$  found in Eq. 23 is adequate.

#### DISCUSSION

The result applies to any nonredundant system directly. Examples are systems that must be bypassed in order to perform the test. In this case the bypass could be an electrical bypass that prevented the sensors monitoring the chosen parameter from transmitting their signal or it could be an electrical bypass at the output that prevented the final safety device from actuating. The bypass need not be electrical, however; for example, a flow of cooling water or a hydraulic actuating fluid might be diverted during test and rendered incapable of performing its function.

The result applies equally well to any redundant system in which the level of redundancy is reduced




Fig. 6 Plot of  $\lambda t$  vs.  $\lambda\tau$ .

during test. For example, if one channel of a one-out-of-two system is bypassed for test, it becomes a one-out-of-one system, and safety is impaired for the duration of the test. In any one-out-of- $n$  system, the availability is highest when the availability of each channel is the highest; so the results can be applied to each channel independently.

In majority logic situations, bypassing in order to test is unusual. If a two-out-of-three system is tested, it usually becomes a one-out-of-two system for the duration of the test. In this condition safety is enhanced slightly, and the results of Eq. 23 do not apply.

Perhaps the most interesting observation is that there is truly a test interval that is optimum on a system that is disabled during test. With this in mind, it is not conservative to formulate the test interval on the assumption of a higher than expected failure rate, and once the test interval is properly formulated, it is not conservative to test more frequently. A reexamination of Fig. 5 illustrates the point. If a best estimate of the failure rate is  $\lambda = 10^{-5}/\text{hr}$ , assuming a failure rate of  $\lambda = 10^{-4}/\text{hr}$  for the sake of a "conservative" estimate of the test interval actually leads to a lower availability.

The straight line of Fig. 5 represents the envelope or limit for all the family of curves having the same test time ( $t$ ) but various failure rates. In other words, for a fixed duration of test ( $t$ ), once the test interval ( $\tau$ ) is chosen, an upper limit on the availability that can be obtained is automatically set, even if the failure rate for the system is zero.

Some consideration should be given to the test duration ( $t$ ) since keeping it short increases availability. Consideration must be given during design to the methods of testing to keep the test duration short; however, it must not be shortened unduly so as to encroach on thoroughness.

### Field Failure Data and Test Intervals

When engineered safety equipment is installed in the field, the plant operator has responsibility for conducting the tests recommended by the designer. These tests present an opportunity to verify the design and add to the store of information on actual in-service failures. If the tests are properly designed and the data carefully recorded, the results can be used to

1. Certify that a given reliability allocation has been met.
2. Provide a basis for lengthening (or shortening) the interval between tests.
3. Provide a useful source of in-service data that can be fed back to the designer to strengthen his basis for reliability prediction.

### UTILIZATION OF FIELD DATA

For this discussion of field data, we will assume that there are many identical bistable trip circuits throughout the reactor plant. When a failure is observed, the failed unit is repaired or replaced so that the number of trip circuits in service remains constant. The operator records the number of failures, and, after the plant has been in operation for a while, he can draw some conclusions from his data. If there are  $n$  identical trip units that have each operated for an elapsed time  $T$  with a grand total of  $r$  failures, the expected failure rate is approximately

$$\lambda = \frac{r}{nT} \quad (24)$$

The result is not very satisfying or useful unless many failures have been observed, which is usually not the case.

If the concept of confidence limit is introduced, useful results can be obtained even with zero failures. The failure rate can be obtained by the formula<sup>1</sup>

$$\lambda_0 = \frac{\chi^2_{2, \alpha} + 2.0}{2nT} \quad (25)$$



where  $n$  = total number of units in service  
 $T$  = time the equipment has been in service  
 $\alpha$  = confidence limit on the parameter  $\lambda$   
 $\lambda$  = failure rate of the unit  
 $r$  = total number of failures  
 $\chi^2_{2r+2, \alpha}$  = chi-square distribution evaluated at  $2r + 2$  degrees of freedom at the  $\alpha$  confidence limit

*Example 1:* Fifty identical trip units have operated for 10,000 hr with no failures. What is the failure rate that will not be exceeded 95% of the time?

*Solution:* From tables of the  $\chi^2$  distribution, the  $\chi^2$  statistic with two degrees of freedom at the 95% level is 5.99. Therefore

$$\lambda_{0.95} = \frac{5.99}{(2)(50)(10,000)} = 5.99 \times 10^{-6}/\text{hr}$$

*Example 2:* After 10,000 hr with no failures, one failure is incurred in the next 10,000 hr. The  $\chi^2$  statistic with four degrees of freedom at the 95% level is 9.49. Therefore

$$\lambda_{0.95} = \frac{9.49}{(2)(50)(20,000)} = 4.75 \times 10^{-4}/\text{hr}$$

Note that the failure rate decreased even though a failure occurred in the interval.

At this point the operator can compare the observed failure rate with that predicted by the designer. If the observed failure rate is higher than the designer predicted on a component that was the limiting item on the reliability of the system, the operator may choose to shorten the interval between tests. If the observed failure rate is substantially less than the predicted failure rate, the operator may rightfully petition to increase the interval between tests in the overall interest of availability and economy.

#### GRAPHICAL AID

The solution to the problem can be simplified and reduced to a graphical procedure. If the designer expects the component to have an average reliability (availability) of  $R$ ,

$$R = 1 - \frac{\lambda \tau}{2} \quad (26)$$

In the case where  $\lambda \tau \ll 1$ ,  $\lambda$  is the failure rate, and  $\tau$  is one-half the interval between tests. Solving for  $\lambda$  gives

$$\lambda = \frac{2(1 - R)}{\tau} \quad (27)$$

Substituting  $2(1 - R)/\tau$  for  $\lambda$  in Eq. 25 and solving for the expression  $nT(1 - R)$  yield

$$nT(1 - R) = \frac{\tau \chi^2_{2r+2, \alpha}}{4} \quad (28)$$

Figure 7 is a plot of the number of failures against  $M$ , where

$$M = nT(1 - R) \quad (29)$$

for a family of values of  $\tau$  with a confidence level of 0.95. Values for  $r$ ,  $n$ , and  $T$  are obtained from operational records. Given  $R$ , the design reliability goal, the value of the factor  $M$  is calculated and plotted against  $r$ . For example, if the reliability goal is 0.992 and three components have operated for 2000 hr with no failures,  $M$  is approximately 50, and point 1 of Fig. 7 is plotted accordingly.

With the elapse of time, more points can be plotted. If the plotted points are connected, they form a stair-step curve that always moves up and to the right. The position of the last plotted point is significant in determining the allowable interval between tests. For example, point 1, plotted very early in plant life, falls just to the right of the  $\tau = 24$ -hr curve; so a test every 24 hr is acceptable. Point 3 falls to the right of the  $\tau = 336$ -hr curve; so the operator can, with the same degree of confidence that his reliability goal is being met, lengthen the test interval to 2 weeks. Finally, at point 7 and beyond, the test interval can be stretched to 1 month. If each independent channel or component meets its goal, the overall goal will also be met.

The curves of Fig. 7 can be applied to any group of items under test which are believed to be from the same population and which follow the exponential failure law. For a particular test in which the reliability goal and the number of components on test are fixed, the scale of the curve can be adjusted so that the number of failures is plotted directly against time to simplify the data-reduction process still further.

#### DISCUSSION

In compiling the data for the plot, only unsafe failures are of concern. Safe failures, by definition, do not prevent the equipment from functioning. In addition, safe failures, even on standby equipment, usually are self-annunciating and thus are not concealed until the next periodic test.

The larger the population of components under test, the sooner significant results can be inferred from the data. For this reason it would be highly desirable to pool all the failures and total the exposure hours on all identical devices used throughout the industry before using Eq. 25 to calculate a failure rate. Of course, good judgment must be exercised to assure that the components are truly from the same population and that they operate in similar environments and with similar stresses.

Without recourse to a mathematical model of the system, demonstration of compliance with a  $10^{-5}$  probability of failure goal for a reactor protection system would be a formidable task. For a single system,  $n$  is unity. When using the relation  $M = nT(1 - R)$ ,




Fig. 7 Graphical aid in the selection of an adequate interval between tests.

operational data would have to be accumulated for a period of  $10^{-6}$  hr (114 years) before  $M$  would be 10, the lowest value plotted on the scale of Fig. 7. If there were no failures in 114 years of operation, the operator might be justified in reducing the test frequency of the whole system to approximately once every 8 hr. System failure in this case is a true failure in its capability to scram, not the failure of an individual component or channel. Statisticians several hundred years from now may be able to draw some binding conclusions from centuries of operational data, but this is not very gratifying to today's plant operator, who must make decisions and exercise judgment now. Confidence in the system must be gained by having confidence in the failure rates of the components making up the system and by having confidence that the mathematical model truly represents the interrelations between the components and the system.

Confidence in the mathematical model is increased if the system is inherently easy to represent mathematically. Frequently this end is best served by constructing the mathematical model first and then designing the system to emulate the model. In general, this practice leads to simple, uncluttered systems with the highest degree of independence of failure events, and thus the predictions based upon the mathematical model are more credible.

Nuclear Safety, Vol. 9, No. 4, July-Aug. 1968

## Conclusions

Plant safety starts with good designs, and good design is the proper application of knowledge. Testing is the means by which new knowledge is generated. Thus it behooves the designer to consider the testing program for his system from the outset of design.

The testing program serves a dual function:

1. It assures that the inherent reliability the designer intended for his system is maintained throughout the plant lifetime.
2. It serves as a source of in-service field-failure data much needed by the designer to guide each new design.

The reliability analyst should be prepared to challenge the traditional ways of establishing testing programs to see whether they are indeed optimum for a well-integrated system design. The real payoff comes when greater safety is achieved simultaneously with simpler systems and less demanding testing programs.

## Reference

1. ARINC Research Corporation, *Reliability Engineering*, Prentice-Hall, Inc., Englewood Cliffs, N. J., 1964.

COMMONWEALTH EDISON

SYSTEMATIC EVALUATION PROGRAM

DRESDEN 2

PURPOSE: NRC WAS TO REVIEW 11 NUCLEAR PLANTS (OLDEST PLANTS AND THOSE WITH POL'S) AGAINST SAFETY CONCERNS EXPRESSED IN THE STANDARD REVIEW PLAN. COMPLETION OF SEP IS TO FORM A DOCUMENTATION BASIS FOR SAFETY ASPECTS OF PLANT.

STARTED: NOVEMBER 1977 WITH 137 TOPICS

- 47 TOPICS DELETED - NOT APPLICABLE OR BEING RESOLVED GENERICALLY.
  
- 90 TOPICS REVIEWED DURING SEP

ACRS FULL COMMITTEE MEETING ON SEP  
DECEMBER 9, 1982  
NEIL P. SMITH

PRESENT STATUS

DRESDEN IS PRESENTLY IN THE INITIAL PHASES OF INTEGRATED ASSESSMENT. THE PRESENT TOPIC STATUS IS:

COMPLETE AGREEMENT	72	TOPICS
TENETENTIVE AGREEMENT		
PENDING CE SUBMITTAL	2	TOPICS
CE PERFORMING STUDIES	6	TOPICS
NRC TO REVIEW CE SUBMITTAL	8	TOPICS
<u>OPEN</u>	<u>2</u>	TOPICS
TOTAL	90	TOPICS

RESULTS FROM TOPIC REVIEWS DONE TO DATE

COMMONWEALTH EDISON HAS:

MADE 4 MODIFICATIONS

COMMITTED 6 ADDITIONAL MODIFICATIONS

5 PROCEDURE CHANGES

COMMONWEALTH EDISON

DRESDEN

MODIFICATION MADE:

ELECTRICAL EQUIPMENT ANCHORAGE  
NORMAL-BYPASS SWITCH TO NORMAL-NORMAL  
125V D.C. DISCONNECT ADDED  
125V D.C. BUS SEPARATION

MODIFICATIONS COMMITTED TO:

BATTERY RACK SEISMIC UPGRADE  
DIESEL GENERATOR PROTECTIVE TRIP BYPASS  
ROOF PARAPETS TO PREVENT PONDED WATER ACCUMULATION  
ADDITIONAL D.C. SYSTEM MONITORING IN THE CONTROLROOM  
INSTALLATION OF REDUNDANT ISOLATION VALVES  
INSTALLATION OF ADDITIONAL 125V D.C. BATTERY BREAKERS.

PROCEDURES CHANGE COMMITTED TO:

REVISE FLOOD PROCEDURES  
MODIFY SAFE SHUTDOWN PROCEDURES  
TEST SHUTDOWN COOLING INTERLOCKS  
INCLUDE MORE VALVES ON LOCKED CLOSED LIST  
MODIFY INSERVICE INSPECTION OF WATER CONTROL STRUCTURES

MAJOR ANALYSES

DRESDEN 2

1. MASS AND ENERGY RELEASE TO CONTAINMENT FOLLOWING STEAM LINE BREAK
2. CONTAINMENT LINER INTEGRITY ANALYSIS
3. CONTAINMENT ELECTRICAL PENETRATIONS FAULT STUDY.
4. SHORT CIRCUIT AND FAILURE ANALYSES OF CLASS IE SYSTEMS.
5. REACTOR PROTECTION SYSTEM ISOLATION DEVICES.
6. TORNADO MISSILE ANALYSES.

NRC

1. SEISMIC CAPABILITY OF STRUCTURES.
2. SEISMIC ANALYSIS OF VARIOUS PIPING SYSTEMS AND COMPONENTS.
3. ENGINEERED SAFETY FEATURES DESIGN.
4. VENTILATION SYSTEMS.
5. WIND AND TORNADO LOADINGS.
6. CODE CHANGES FOR STRUCTURES AND COMPONENTS.
7. ATMOSPHERIC TRANSPORT AND DIFFUSION CHARACTERISTICS.

EXPERIENCE TO DATE

COMMONWEALTH EDISON HAS SPENT APPROXIMATELY 2.6 MILLION DOLLARS FOR STUDIES TO SUPPORT THE SYSTEMATIC EVALUATION PROGRAM. THE MODIFICATIONS WHICH HAVE BEEN MADE TO DRESDEN 2 AS A RESULT OF SEP HAVE ALSO BEEN OR ARE BEING MADE AT DRESDEN 3 AND QUAD CITIES 1 AND 2, IF APPLICABLE.

MODIFICATIONS RESULTING FROM SEP HAVE COST COMMONWEALTH EDISON 1.3 MILLION DOLLARS.

COMMONWEALTH EDISON BELIEVES THE STRONG PROJECT MANAGEMENT OF MR. RUSSELL HAS CAUSED SEP TO MOVE FORWARD AND FOR THE STAFF TO MAKE REASONED JUDGMENTS.



TOPICS COMMONWEALTH EDISON  
STILL PERFORMING WORK ON

<u>TOPIC NO</u>	<u>TITLE</u>
III-4.A	TORNADO MISSILES
III-6	SEISMIC DESIGN CONSIDERATIONS
III-10.A	THERMAL-OVERLOAD PROTECTION FOR MOTORS OF MOTOR-OPERATED VALVES
VI-7.C.1	APPENDIX K - ELECTRICAL INSTRUMENTATION AND CONTROL (EI&C) RE-REVIEWS
VI-10.B	SHARED ENGINEERED SAFETY FEATURES, ONSITE EMERGENCY POWER, AND SERVICE SYSTEMS FOR MULTIPLE-UNIT FACILITIES
VII-1.A	ISOLATION OF REACTOR PROTECTION SYSTEM FROM NON-SAFETY SYSTEMS, INCLUDING QUALIFICATION OF ISOLATION DEVICES
IX-5	VENTILATION SYSTEMS
XV-16	RADIOLOGICAL CONSEQUENCES OF FAILURE OF SMALL LINES CARRYING PRIMARY COOLANT OUTSIDE CONTAINMENT

MILLSTONE UNIT 1

SEP TOPIC XV-16, FAILURE OF SMALL LINES OUTSIDE CONTAINMENT

- o NRC SER DATED NOVEMBER 10, 1982 PRESENTLY UNDER REVIEW. POTENTIAL AREAS FOR REFINEMENT OF DOSE CALCULATIONS INCLUDE:
  - ESTIMATE OF BREAK FLOW
  - EFFECTIVENESS OF STANDBY GAS TREATMENT SYSTEM
  - POSSIBLE ALTERNATE OPERATOR ACTION
  - DURATION OF RELEASE

T8

ACRS FULL COMMITTEE

DECEMBER 9, 1982

MILLSTONE UNIT NO. 1

NORTHEAST UTILITIES

T8

CONDUCT OF PHASE II SIGNIFICANTLY  
DIFFERENT FROM ORIGINAL PLANS

- o NRC STAFF PROGRAM vs. LICENSEE PROGRAM
- o PROTECTION FROM INTERIM BACKFITS ABSENT IMMEDIATE SAFETY PROBLEM
- o EXCLUDED FROM OTHER NRC INITIATIVES
  
- o PROGRAM NOT FORMALIZED IN THE REGULATIONS

## ORIGINAL SEP OBJECTIVES

- o CREATE DOCUMENTATION BASE
  
- o CAPABILITY FOR INTEGRATED AND BALANCED BACKFITTING DECISIONS
  
- o IDENTIFY IMMEDIATE SAFETY CONCERNS
  
- o REASSESS SAFETY ADEQUACY
  
- o EFFICIENTLY USE AVAILABLE RESOURCES
  
- o IMPROVE BASIS FOR POL CONVERSIONS

## STAGES OF SEP PHASE II

- o NRC PROGRAM (3 YEARS)
- o LEAD PLANT (3 MONTHS)
- o LEAD TOPIC (2 YEARS SO FAR)
- o ACTUAL PROGRAM HAS BEEN HYBRID OF LEAD PLANT AND LEAD TOPIC
- o INCREASED LICENSEE INVOLVEMENT KEY FACTOR IN ACCELERATED RATE OF PROGRESS
- o LICENSEES HAVE BENEFITTED SIGNIFICANTLY BY EVALUATING TOPICS CONCURRENTLY

## MILLSTONE 1

### PLANT MODIFICATIONS

#### COMPLETED

- o SEISMIC ANCHORAGE
- o SEISMIC STRUCTURAL MODIFICATIONS
- o NEW BATTERY RACKS

#### COMMITTED

- o TORNADO MISSILE PROTECTED SHUTDOWN METHOD
- o REDUNDANT PRESSURE INTERLOCK ON RWCU SYSTEM
- o ADDITIONAL ISOLATION VALVES
- o LOCKING DEVICES FOR ISOLATION VALVES

#### PROCEDURE OR TECH SPEC CHANGES

- o KEEP FLOOD DOOR TO GT BUILDING CLOSED
- o REVISED ISI FOR WATER CONTROL STRUCTURES
- o REVISED FLOOD EMERGENCY PROCEDURE
- o REVISE PROCEDURE FOR SHUTDOWN FROM OUTSIDE CONTROL ROOM
- o TECH SPECS FOR WATER QUALITY
- o REVISED BATTERY TESTING



## OBSERVATIONS ON PHASE II

- o LARGE RESOURCE EXPENDITURE
  - INTERNAL MANHOURS - 30,000
  - CONSULTANT COSTS - \$1.0 MILLION
  - HARDWARE MODIFICATIONS - \$1.5 MILLION
  
- o EXTENDED SCHEDULE
  
- o "INTEGRATION" CONCEPT LIMITED TO APPLICABLE SEP TOPICS
  
- o STRONG PROJECT MANAGEMENT
  
- o JUDGMENTS BASED UPON NUCLEAR SAFETY, NOT SRP CRITERIA
  
- o CONSIDERATION OF PLANT UNIQUE FEATURES
  
- o PROVISIONS FOR LICENSEE TO UTILIZE ITS KNOWLEDGE OF THE PLANT TO IMPLEMENT "INTEGRATION" CONCEPT

## ORIGINAL SEP OBJECTIVES

- o CREATE DOCUMENTATION BASE
  - GENERALLY YES
- o CAPABILITY FOR INTEGRATED AND BALANCED BACKFITTING DECISIONS
  - IN THE CONTEXT OF SEP ISSUES ONLY, OBJECTIVE IS BEING MET
- o IDENTIFY IMMEDIATE SAFETY CONCERNS
  - GENERALLY YES
- o REASSESS SAFETY ADEQUACY
  - PARTIALLY MET
- o EFFICIENTLY USE AVAILABLE RESOURCES
  - NOT MET
- o IMPROVE BASIS FOR POL CONVERSIONS
  - GENERALLY YES

## CONCLUSIONS

- o INCORPORATE POSITIVE ELEMENTS OF PHASE II INTO THE REGULATORY PPOCESS
  - SRP IS ONLY A STARTING POINT
  - STRONG PROJECT MANAGEMENT
  
- o INTEGRATION SHOULD CONSIDER ALL PLANT MODIFICATIONS, NOT ONLY SEP TOPICS
  
- o FORMALIZE ANY POTENTIAL NEW PROGRAM BY REGULATION

CHRONOLOGY OF EVENTS SINCE ACRS SUBCOMMITTEE MEETING ON FEBRUARY 18, 1982  
AT CINCINNATI AIRPORT

FEBRUARY 24, 1982	CIVIL PENALTY PAID
MAY 27, 1982	THREE QC INSPECTORS DOUSED
MAY 28, 1982	CG&E STOPPED CONSTRUCTION BECAUSE OF DOUSING
JUNE 1, 1982	WORK RESUMED AFTER WORKERS ACKNOWLEDGED LAW
JUNE 10, 1982	CONGRESSIONAL HEARING
JUNE 29, 1982	ALLEGED CONTINUING INTIMIDATION AND HARASSMENT - MEETING WITH QA/QC INSPECTORS
JULY 1982	ALLEGATIONS RE WELDER QUALIFICATIONS
AUGUST 1, 1982	REDUCE 100% REINSPECTION EFFORT
AUGUST 4, 1982	OI ASSUMED RESPONSIBILITY FOR INVESTIGATION
AUGUST 10, 1982	NATIONAL BOARD MEETING - DISCUSSED INTERIM REPORTS

AUGUST 25, 1982	FIRST MONTHLY STATUS REPORT PREPARED (FOR JULY)
SEPTEMBER 14, 1982	CONGRESSIONAL HEARING
SEPTEMBER 16, 1982	CINCINNATI ENVIRONMENTAL ADVISORY COMMITTEE HEARING
OCTOBER 19, 1982	MEETING WITH CG&E TO DISCUSS INSPECTION FINDINGS RE CATALYTIC, INC.
OCTOBER 26, 1982	CG&E LAID OFF 450 CRAFTSMEN
NOVEMBER 12, 1982	ISSUED ORDER TO SHOW CAUSE AND ORDER IMMEDIATELY SUSPENDING CONSTRUCTION
NOVEMBER 15, 1982	CG&E LAID OFF 1,240 PERSONNEL (1,087 CRAFTSMEN)
NOVEMBER 17, 1982	MEETING WITH CG&E RE ORDER
NOVEMBER 26, 1982	CG&E RESPONSE TO ORDER - REQUESTS APPROVAL OF BECHTEL
DECEMBER 2, 1982	CG&E SUBMITTAL AND REQUEST FOR COMMENTS TRANSMITTED TO INTERESTED PARTIES
DECEMBER 7, 1982	CG&E CONSENTED IN WRITING TO THE ORDER

DEFICIENCIES THAT CONTINUE

IDENTIFIED BY LICENSEE QUALITY VERIFICATION PROGRAM

- . WELD PROCEDURES
  
- . MATERIAL TRACEABILITY
  
- . ELECTRICAL CABLE TRAY AND SUPPORT INSTALLATIONS
  
- . SACRIFICIAL SHIELD WELD RADIOGRAPHS AND WELDS
  
- . DESIGN CONTROL
  
- . CONTROL ROD DRIVE SYSTEM HANGERS
  
- . ELECTRICAL CABLE SEPARATION
  
- . FIRE PROTECTION SYSTEM SEISMIC UPGRADE
  
- . CONTROL PANEL WIRING SEPARATION
  
- . SEISMIC CLEARANCE
  
- . SMALL BORE PIPING DYNAMIC ANALYSIS
  
- . CONCRETE AND STEEL COATINGS

IDENTIFIED BY NRC INSPECTION

- . PERSONNEL QUALIFICATIONS AND CERTIFICATIONS
- . CORRECTIVE ACTION SYSTEM AND PROCEDURES
- . MAINTENANCE OF WELDER QUALIFICATIONS
- . RECORDS CONTROL
- . WELD MATERIAL CONTROL
- . CG&E MANAGEMENT CONTROLS - CATALYTIC, INC. (STOP WORK ORDER ISSUED)

INITIATION AND CLASSIFICATION OF ESSENTIAL WORK

INSPECTION AND SURVEILLANCE

NONCONFORMING CONDITIONS AND CORRECTIVE ACTIONS

RECORDS AND AUDITS



OTHER ITEMS

. AUTHORIZED NUCLEAR INSPECTOR (ANI) INVOLVEMENT WITH ASME WORK

. STOP WORK ORDERS

ELECTRICAL CABLE INSTALLATION (10/12/82)

APPLICATION OF COATINGS (10/12/82)

SPECIAL PROCESS PROCEDURES - ADDITIONAL (11/1/82)

. NATIONAL BOARD FINDINGS

. REWORK ACTIVITIES

ORDER IMMEDIATELY SUSPENDING CONSTRUCTION

IV.A. STOP SAFETY RELATED CONSTRUCTION

IV.B. (1) INDEPENDENT ORGANIZATION TO PERFORM REVIEW OF MANAGEMENT  
OF ZIMMER PROJECT

(A) INDEPENDENT ORGANIZATION TO BE APPROVED BY REGIONAL  
ADMINISTRATOR

(B) RECOMMEND COURSE OF ACTION BASED ON INDEPENDENT  
REVIEW (TO BE APPROVED BY R.A.)

(2) (A) SUBMIT UPDATED COMPREHENSIVE PLAN TO VERIFY  
QUALITY OF CONSTRUCTION (TO BE APPROVED BY R.A.)

(B) SUBMIT COMPREHENSIVE PLAN FOR CONTINUATION OF  
CONSTRUCTION (TO BE APPROVED BY R.A.)

(3) R. A. MAY RELAX SECTION IV,B

CURRENT ZIMMER ACTIVITIES

NOVEMBER 22, 1982 CG&E REQUEST FOR CLARIFICATION OF SCOPE OF  
ACTIVITIES SUSPENDED BY THE ORDER AND CONCURRENCE  
OF 14 ACTIVITIES

NOVEMBER 30, 1982 REGION III RESPONSE TO ABOVE REQUEST FOR  
CONCURRENCE

EIGHT ACTIVITIES APPROVED

TWO ACTIVITIES TO BE REVIEWED CASE BY CASE

FOUR ACTIVITIES NOT ALLOWED AT THIS TIME

ONGOING QUALITY CONFIRMATION PROGRAM -- NO REWORK

NON SAFETY RELATED WORK CONTINUES

PERSONNEL H. J. KAISER AS OF DECEMBER 8, 1982

237 CRAFTS

567 NON-MANUAL

ACRS MTG ON  
SEQUOYAH

- I. SUMMARY OF REVIEW AREAS
- II. OPEN ITEMS/NEW LICENSE CONDITIONS
- III. CONFIRMATORY ITEMS
- IV. WHAT'S NEW SINCE JANUARY 1981
- V. PHMS vs IDIS
- VI. AC POWER DEPENDENCE OF PHMS
- VII. CONCLUSION

T15

SEQUOYAH PERMANENT HYDROGEN  
MITIGATION SYSTEM (PHMS)

REVIEW ELEMENTS

- o PHMS DESIGN
- o HYDROGEN CONTROL RESEARCH
  - o COMBUSTION
  - o MIXING
  - o DETONATIONS
- o DEGRADED CORE ACCIDENTS & HYDROGEN GENERATION
- o CONTAINMENT HYDROGEN ANALYSIS
- o SEQUOYAH STRUCTURAL CAPACITY
- o ESSENTIAL EQUIPMENT SURVIVABILITY

## OPEN ITEMS/NEW LICENSE CONDITIONS

### I. REQUIREMENT TO INCREASE NUMBER OF IGNITERS (4) IN UPPER COMPARTMENT

- o IMPROVED COVERAGE
- o WITH STAFF PRIOR APPROVAL OF LOCATION, TO BE COMPLETED BY STARTUP FOLLOWING THE SECOND REFUELING OUTAGE

### II. REQUIREMENT TO PERFORM ADDITIONAL TESTING OF THE TAYCO IGNITER

- o DEMONSTRATION THAT TAYCO IGNITERS WILL RELIABLY IGNITE LEAN MIXTURES OF H<sub>2</sub> IN A SPRAY ENVIRONMENT BY SEPTEMBER 1983

CONFIRMATORY ITEMS  
RES/NRR/EPRI PROGRAMS

1) LOCAL DETONATIONS

- o RES - HYDROGEN BEHAVIOR PROGRAM (4Q 83)
  - o ASSESS POTENTIAL FOR AND CONSEQUENCES OF LOCAL  
DETONATIONS, INCLUDING MISSILE GENERATION (CSQ CODE)
- o NRR - REVIEW OF GRAND GULF HYDROGEN IGNITER SYSTEM II  
(2Q 83)
- o CSQ CALCULATIONS FOR ICE CONDENSER SUBCOMPARTMENTS

2) CLASIX/COMPARE CODE WORK

- o NRR - CONTAINMENT HYDROGEN ANALYSIS REVIEW (4Q 83)
  - o DEVELOP STANDARD PROBLEM SET FOR EVALUATING COMPUTER  
CODE FOR DEGRADED CORE ACCIDENTS
- o RES - HYDROGEN BEHAVIOR PROGRAM (4Q 83)
  - o HECTR/COMPARE/CLASIX BENCHMARK CALCULATIONS
  - o EVALUATION OF MODELS AND ASSUMPTIONS



### 3) EQUIPMENT SURVIVABILITY FOR SPECTRUM OF ACCIDENTS

- o RES - HYDROGEN BEHAVIOR PROGRAM (4Q 83)
  - o HECTR-BASED P/T PROFILES
- o RES - HYDROGEN BURN SURVIVABILITY (4Q 83)
  - o EVALUATIONS OF THERMAL AND PRESSURE LOADINGS ON EQUIPMENT
- o NRR - HYDROGEN BURN SURVIVAL PROGRAM (SNL) (3Q 83)
  - o ANALYTICAL ASSESSMENT OF THERMAL RESPONSE MODELS FOR VARIOUS SAFETY EQUIPMENT

### 4) COMBUSTION EFFECTS AT LARGE SCALE

- o RES/EPRI - HYDROGEN COMBUSTION AND CONTROL DEMONSTRATION EXPERIMENTS (1Q 84)
  - o EVALUATION OF COMBUSTION EFFECTS IN NTS FACILITY, INCLUDING TAYCO IGNITER PERFORMANCE AND EQUIPMENT SURVIVABILITY

### 5) COMBUSTION PHENOMENA

- o RES - HYDROGEN BEHAVIOR PROGRAM (1Q 84)
  - o FLAME ACCELERATION STUDIES AT SANDIA "FLAME" FACILITY

## RESULTS OF RECENT RESEARCH

- o CONFIRMATION OF RELIABLE IGNITION OF LEAN H<sub>2</sub>-AIR-STEAM MIXTURES UNDER DYNAMIC CONDITIONS
- o CONFIRMATION THAT WITH FANS AND SPRAYS OPERABLE CONTAINMENT MIXING IS ADEQUATE
- o CONFIRMATION THAT THREATS FROM DETONATIONS ARE SMALL
  - o RELIABLE IGNITION AND MIXING
  - o CONTINUED SANDIA INVESTIGATION OF DETONATIONS
  - o UPPER PLENUM DETONATION CONSEQUENCES RE EVALUATED
    - o NUREG/CR-2385 EXCEEDED ACCEPTABLE IMPULSIVE LOAD VALUE BASED ON CONSERVATIVE STRUCTURAL MODEL
    - o REFINED CALCULATIONS INDICATE CONTAINMENT INTEGRITY NOT THREATENED

## PERMANENT vs INTERIM HYDROGEN IGNITER SYSTEMS

### IGNITER POWER DISTRIBUTION

- o PHMS - 2 TRAINS, 16 CIRCUITS/TRAIN,  
2 IGNITERS/CIRCUIT, ACTUATED FROM  
MAIN CONTROL ROOM
  
- o IDIS - 3 EMERGENCY LIGHTING CIRCUITS,  
15 IGNITERS/CIRCUIT, CONTROLLED FROM  
AUX. BUILDING

### IGNITER CHARACTERISTICS

<u>PARAMETERS</u>	<u>TAYCO</u>	<u>GM GLOW PLUG</u>
POWER SUPPLY	120 VOLTS	14 VOLTS
SURFACE AREA	10.9 IN <sup>2</sup>	0.6 IN <sup>2</sup>
POWER DENSITY	48 W/IN <sup>2</sup>	200 W/IN <sup>2</sup>
SURFACE TEMP	1710 °F	1850 °F
POWER/IGNITER	500 WATTS	120 WATTS

### IGNITER LOCATIONS

	<u>PHMS</u>	<u>IDIS</u>
LOWER COMP.	22	12
UPPER PLENUM	16	4
UPPER COMP.	10	16 (3)
DEAD ENDED COMP.	<u>16</u>	<u>13</u>
	64	45

DEPENDENCE OF PHMS ON A.C. POWER

STAFF POSITION

BACK-UP BATTERY SYSTEM FOR THE PHMS IS NOT REQUIRED

BASES

- o PHMS - DESIGNED FOR MOST RECOVERABLE SEVERE ACCIDENTS
- o LOSS OF ALL A.C. POWER - NOT A DOMINANT CONTRIBUTOR TO RISK

## CONCLUSION

- o PHMS IS ACCEPTABLE FOR INTERIM PERIOD PENDING COMPLETION OF IGNITION TESTING WITH TAYCO IGNITERS AND SUBJECT TO INSTALLATION OF FOUR MORE IGNITERS IN UPPER COMPARTMENT
  
- o ALSO, FURTHER CONFIRMATORY TESTING BY STAFF AND EPRI IS NEEDED AND WILL BE PERFORMED

## BRIEFING OUTLINE

- I. CHRONOLOGY
- II. REVIEW OF PERMANENT HYDROGEN  
MITIGATION SYSTEM
- III. OPEN ISSUES
- IV. CONFIRMATORY ITEMS
- V. LICENSE CONDITIONS

CHRONOLOGY

SER ISSUED

MARCH 1979

LOW POWER LICENSE ISSUED

FEBRUARY 29, 1980

FULL POWER LICENSE ISSUED

SEPTEMBER 17, 1980

TVA EXECUTIVE SUMMARY

REPORT ISSUED

SEPTEMBER 27, 1982

SSER #6 ISSUED

DECEMBER 1982



ORIGINAL LICENSE CONDITION

HYDROGEN CONTROL MEASURES (SECTION 22.2.II.B.7)

- (1) BY JANUARY 31, 1981, TVA SHALL BY TESTING AND ANALYSIS SHOW TO THE SATISFACTION OF THE NRC STAFF THAT AN INTERIM HYDROGEN CONTROL SYSTEM WILL PROVIDE WITH REASONABLE ASSURANCE PROTECTION AGAINST BREACH OF CONTAINMENT IN THE EVENT THAT A SUBSTANTIAL QUANTITY OF HYDROGEN IS GENERATED.
- (2) FOR OPERATION OF THE FACILITY BEYOND JANUARY 31, 1982, THE COMMISSION MUST CONFIRM THAT AN ADEQUATE HYDROGEN CONTROL SYSTEM FOR THE PLANT IS INSTALLED AND WILL PERFORM ITS INTENDED FUNCTION IN A MANNER THAT PROVIDES ADEQUATE SAFETY MARGINS.
- (3) DURING THE INTERIM PERIOD OF OPERATION, TVA SHALL CONTINUE A RESEARCH PROGRAM ON HYDROGEN CONTROL MEASURES AND THE EFFECTS OF HYDROGEN BURNS ON SAFETY FUNCTIONS AND SHALL SUBMIT TO THE NRC QUARTERLY REPORTS ON THAT RESEARCH PROGRAM.

CURRENT LICENSE CONDITION

HYDROGEN CONTROL MEASURES (SECTION 22.2.11.B.7)

- (1) PRIOR TO STARTUP FOLLOWING THE FIRST REFUELING OUTAGE, THE COMMISSION MUST CONFIRM THAT AN ADEQUATE HYDROGEN CONTROL SYSTEM FOR THE PLANT IS INSTALLED AND WILL PERFORM ITS INTENDED FUNCTION IN A MANNER THAT PROVIDES ADEQUATE SAFETY MARGINS.
- (2) DURING THE INTERIM PERIOD OF OPERATION, TVA SHALL CONTINUE A RESEARCH PROGRAM ON HYDROGEN CONTROL MEASURES AND THE EFFECTS OF HYDROGEN BURNS ON SAFETY FUNCTIONS AND SHALL SUBMIT TO THE NRC QUARTERLY REPORTS ON THAT RESEARCH PROGRAM.
  - (A) TVA SHALL AMEND ITS RESEARCH PROGRAM ON HYDROGEN CONTROL MEASURES TO INCLUDE, BUT NOT BE LIMITED TO, THE FOLLOWING ITEMS:
    - 1) IMPROVED CALCULATIONAL METHODS FOR CONTAINMENT TEMPERATURE AND ICE CONDENSER RESPONSE TO HYDROGEN COMBUSTION.
    - 2) RESEARCH TO ADDRESS THE POTENTIAL FOR LOCAL DETONATION.
    - 3) CONFIRMATORY TESTS ON SELECTED EQUIPMENT EXPOSED TO HYDROGEN BURNS.
    - 4) NEW CALCULATIONS TO PREDICT DIFFERENCES BETWEEN EXPECTED EQUIPMENT TEMPERATURE ENVIRONMENTS AND CONTAINMENT TEMPERATURES.

5) EVALUATE AND RESOLVE ANY ANOMALOUS RESULTS OCCURRING DURING THE COURSE OF ITS ONGOING TEST PROGRAM.

(B) A SCHEDULE FOR CONFIRMATORY TESTS SHALL BE PROVIDED BY TVA CONSISTENT WITH THE REQUIREMENT TO MEET SECTION (22)D.(2) OF THE LICENSE.

PERMANENT HYDROGEN MITIGATION  
SYSTEM

PRINCIPAL REVIEW AREAS

- o PHMS DESIGN
- o HYDROGEN CONTROL RESEARCH
  - COMBUSTION
  - MIXING
  - DETONATIONS
- o DEGRADED CORE ACCIDENTS & HYDROGEN GENERATION
- o CONTAINMENT HYDROGEN ANALYSIS
- o SEQUOYAH STRUCTURAL CAPACITY
- o ESSENTIAL EQUIPMENT SURVIVABILITY

### OPEN ISSUES

- PERFORMANCE OF TAYCO IGNITERS IN  
CONTAINMENT UPPER COMPARTMENT
- NUMBER AND LOCATION OF IGNITERS IN  
UPPER COMPARTMENT



CONFIRMATORY ITEMS

ANALYTICAL

LOCAL DETONATIONS

CLASIX/COMPARE CODE WORK

EXPERIMENTAL

EQUIPMENT SURVIVABILITY

COMBUSTION EFFECTS AT LARGE SCALE

COMBUSTION PHENOMENA

PROPOSED LICENSE CONDITIONS

FOR UNIT 1

FOUR (4) ADDITIONAL IGNITER UNITS SHALL BE INSTALLED IN THE SEQUOYAH UNIT 1 CONTAINMENT UPPER CONTAINMENT COMPARTMENT IN LOCATIONS ACCEPTABLE TO THE NRC STAFF PRIOR TO STARTUP FOLLOWING THE SECOND REFUELING OUTAGE.

ADDITIONAL TESTS SHALL BE PERFORMED ON THE TAYCO IGNITER TO DEMONSTRATE THAT THE IGNITERS WILL MAINTAIN AN ADEQUATE SURFACE TEMPERATURE IN A SPRAY ENVIRONMENT SUCH AS THAT EXPECTED IN THE UPPER COMPARTMENT OF THE ICE CONDENSER CONTAINMENT. THESE TESTS SHALL BE COMPLETED BY SEPTEMBER 1983.



PERMANENT HYDROGEN MITIGATION SYSTEM

CONCEPT

ALTERNATIVES

TAYCO IGNITER/ASSEMBLY

FUNCTIONAL CAPABILITY

SYSTEM LAYOUT

REDUNDANT/SEISMIC

OPERATING PROCEDURE

PREOP TEST


SURVEILLANCE TEST

TECH SPECS


T13

## **OPERATING PRINCIPLE**


- ENERGIZED BEFORE H<sub>2</sub> RELEASE**
- IGNITE LEAN H<sub>2</sub> - AIR MIXTURES**
- ACHIEVE PERIODIC/CONTINUOUS BURNING**
- IMPROVE EFFECTIVENESS OF HEAT SINKS**
- MODERATE CONTAINMENT PRESSURIZATION**



TAYCO THERMAL IGNITER



TAYCO IGNITER ASSEMBLY



ELEVATION VIEW - IGNITERS

CONCLUSION

THE PERMANENT HYDROGEN MITIGATION SYSTEM IS  
AN ADEQUATE HYDROGEN CONTROL SYSTEM FOR SEQUOYAH

ICE CONDENSER UTILITY-SPONSORED RESEARCH

FENWAL - GM IGNITER COMBUSTION PROOF-TESTING

ICE CONDENSER UTILITY/EPRI-SPONSORED RESEARCH

WHITESHELL - TAYCO/GM IGNITER PERFORMANCE  
- INTERMEDIATE SCALE COMBUSTION PHENOMENA

FACTORY MUTUAL - MICROFOG EFFECTS

ACUREX - IGNITER LOCATION  
- MICROFOG EFFECTS

HANFORD - CONTAINMENT ATMOSPHERIC MIXING

TVA-SPONSORED RESEARCH

SINGLETON - IGNITER DURABILITY



FEMAL

GM IGNITER COMBUSTION PROOF-TESTING

PARAMETERS:

134 FT<sup>3</sup> SPHERICAL VESSEL

PREMIXED/TRANSIENT

STEAM/SPRAY

FAN

P/T/GAS SAMPLING

H<sub>2</sub>: 5-12 V/O

STEAM: 0-40 V/O

FENWAL

G1 IGNITER COMBUSTION PROOF-TESTING

CONCLUSIONS:

G1 IGNITER RELIABLE

IGNITION IN STEAM/SPRAY

$\Delta P$  LESS THAN ADIABATIC

MINIMUM  $\Delta P$  DURING TRANSIENT INJECTION (SEQUENTIAL BURNS)

NO DETONATION

WHITESHELL

TAYCO/GM IGNITER PERFORMANCE

PARAMETERS:

17 L SPHERICAL VESSEL

PREMIXED

STEAM/NO SPRAY

FAN

P/T, IGNITER SURFACE T/GAS SAMPLING

H<sub>2</sub>: 4-15 V/O

STEAM: 0-60 V/O

WHITESHELL

CONCLUSIONS:

TAYCO AND GM IGNITERS RELIABLE

IGNITION IN UP TO 60 V/O STEAM

TURBULENCE ENHANCES LEAN BURNING

$\Delta P$  LESS THAN ADIABATIC

CONSIDERABLE MARGIN BETWEEN REQUIRED IGNITION TEMPERATURE  
AND NORMAL OPERATING TEMPERATURE FOR BOTH IGNITERS

WHITESHELL

INTERMEDIATE-SCALE COMBUSTION PHENOMENA

1. LEAN MIXTURES
2. LAMINAR SPHERICAL DEFLAGRATIONS
3. EFFECTS OF FAN- AND GRATING-INDUCED TURBULENCE
4. EXTENDED GEOMETRY

COMMON PARAMETERS:

SPARK IGNITER

223 FT<sup>3</sup> SPHERICAL VESSEL

OR SPHERE ATTACHED TO 20 FT BY 1 FT PIPE

PREMIXED

STEAM/NO SPRAY

FAN

VARIABLE IGNITER LOCATION

P/T/GAS SAMPLING

WHITESHELL

INTERMEDIATE-SCALE COMBUSTION PHENOMENA

CONCLUSIONS:

OBSERVED LFLs AGREE WITH LITERATURE

$\Delta P$  LESS THAN ADIABATIC

HIGH CONCENTRATIONS OF STEAM REDUCE  $\Delta P$

TURBULENCE ENHANCES LEAN BURNING

NO DETONATION EVEN AT STOICHIOMETRIC MIXTURES AND ABOVE

FACTORY MUTUAL

SMALL-SCALE EVALUATION OF VARIOUS MICROFOG DROPLET SIZE, DENSITY,  
AND TEMPERATURE EFFECTS ON LFL IN PREPARATON FOR ACUREX  
INTERMEDIATE-SCALE TESTS

PARAMETERS:

SPARK/GM IGNITER

8 FT<sup>3</sup> CYLINDRICAL TUBE (3.5 FT HIGH x 0.5 FT DI)

MICROFOG NOZZLES

FLAME DETECTION/DROPLET DENSITY/GAS SAMPLING

DROPLET SIZE: 2-15 MICRONS

CONCENTRATION: 0.002-3 V/O

TEMPERATURE: 20-70°C



FACTORY MUTUAL

CONCLUSIONS:

AT ROOM TEMPERATURE, DENSE MICROFOGS CAUSE ONLY A SLIGHT  
INCREASE IN LFL

AT ELEVATED TEMPERATURES, MICROFOGS CAUSE LARGER INCREASE IN  
LFL

MICROFOGS WITH LARGER DROPLETS MUST BE MUCH MORE EFFECTIVE TO  
HAVE SAME EFFECT ON LFL

ACUREX

PHASE 1 - IGNITER LOCATION

PHASE 2 - MICROFOG EFFECTS

COMMON PARAMETERS:

GM IGNITER

630 FT<sup>3</sup> CYLINDER (17 FT HIGH x 7 FT DIAM)

STEAM

NO FAN

T/P/FLAME DETECTION/GAS SAMPLING

ACUREX

CONCLUSIONS:

$\Delta P$  LESS WHEN IGNITER WAS LOWER (NEARER SOURCE) OR IN  
TURBULENCE

IN PREMIXED TESTS, MICROFOG DID NOT REDUCE  $\Delta P$  - HEAT  
SINK EFFECT INSIGNIFICANT

IN TRANSIENT TESTS, MICROFOG DID REDUCE  $\Delta P$  -  
TURBULENCE ENHANCED LEAN BURNING

HANFORD

CONTAINMENT ATMOSPHERIC MIXING

PARAMETERS:

NO COMBUSTION

He USED INSTEAD OF H<sub>2</sub> IN MOST TESTS

30,000 FT<sup>3</sup> CYLINDRICAL VESSEL

LOWER COMPARTMENT OF ICE CONDENSER CONTAINMENT MODELLED

SMALL BREAK LOCA MODELLED

- 2" PIPE BREAK - HORIZONTAL

- 10" PRESSURIZER RELIEF TANK VENT - VERTICAL

T/VELOCITY/GAS SAMPLING

HANFORD

CONTAINMENT ATMOSPHERIC MIXING

CONCLUSIONS:

MIXING IN POSTACCIDENT CONDITIONS IS VERY GOOD

- 2-3 V/O MAXIMUM DIFFERENCE DURING RELEASE PERIOD
- < 1 V/O MAXIMUM DIFFERENCE 20 MINUTES AFTER  
RELEASE PERIOD

JET MIXING IS MOST IMPORTANT EFFECT

FORCED AND NATURAL CIRCULATION ALSO CONTRIBUTE TO  
MIXING

SINGLETON

IGNITER DURABILITY

PARAMETERS:

CYCLING

ENDURANCE

COMBUSTION

SPRAY

SINGLETON

CONCLUSIONS:

TAYCO IGNITER DURABLE

TAYCO IGNITER WOULD BE OPERABLE IN ACTUAL SPRAY  
ENVIRONMENT



## RESEARCH CONCLUSIONS

IGNITERS WOULD BURN LEAN MIXTURES IN CONTAINMENT ENVIRONMENTS

EFFECTS OF STEAM AND TURBULENCE ARE BENEFICIAL

DATA IS CONSISTENT AND DOES NOT CONFLICT WITH LITERATURE

PRESSURE RISES WERE LESS THAN THEORETICAL

MINIMUM PRESSURE RISES OBSERVED DURING TRANSIENT TESTS

NO DETONATIONS WERE OBSERVED

MIXING IS GOOD

IGNITERS ARE DURABLE

CONCLUSION

RESULTS OF RESEARCH SUPPORT DELIBERATE IGNITION AS AN  
ADEQUATE METHOD OF HYDROGEN CONTROL

OVERALL CONCLUSION:

SINCE THE PERMANENT HYDROGEN MITIGATION SYSTEM IS AN ADEQUATE  
HYDROGEN CONTROL SYSTEM SUPPORTED BY RESEARCH AND ANALYSIS,  
THE SEQUOYAH OPERATING LICENSE CONDITIONS HAVE BEEN SATISFIED.