

OPERATING DATA REPORT

DOCKET NO. 50-364
 DATE January 8, 1991
 COMPLETED BY D. N. Morey
 TELEPHONE (205)899-5156

OPERATING STATUS

1. Unit Name: Joseph M. Farley - Unit 2
2. Reporting Period: November 1990
3. Licensed Thermal Power (MWt): 2,652
4. Nameplate Rating (Gross MWe): 860
5. Design Electrical Rating (Net MWe): 829
6. Maximum Dependable Capacity (Gross MWe): 868.6
7. Maximum Dependable Capacity (Net MWe): 828.2
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons: N/A
9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

Note:
 1) Cumulative data since 7-30-81, date of commercial operation.

	This Month	Yr-to-Date	Cumulative
11. Hours In Reporting Period	720	8,016	81,865
12. Number Of Hours Reactor Was Critical	0.0	6,501.1	70,384.2
13. Reactor Reserve Shutdown Hours	0.0	0.0	138.0
14. Hours Generator On-Line	0.0	6,479.2	69,551.2
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	0.0	16,947,682	177,203,949
17. Gross Electrical Energy Generated (MWH)	68	5,539,364	58,205,906
18. Net Electrical Energy Generated (MWH)	-3,728	5,260,120	55,203,510
19. Unit Service Factor	0.0	80.8	85.0
20. Unit Availability Factor	0.0	80.8	85.0
21. Unit Capacity Factor (Using MDC Net)	N/A	79.2	82.3
22. Unit Capacity Factor (Using DER Net)	N/A	79.2	81.3
23. Unit Forced Outage Rate	0.0	1.4	4.2
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): <u>N/A</u>			

25. If Shut Down At End Of Report Period, Estimated Date of Startup: December 31, 1990
26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY	05/06/81	05/08/81
INITIAL ELECTRICITY	05/24/81	05/25/81
COMMERCIAL OPERATION	08/01/81	07/30/81