



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555-0001

GULF STATES UTILITIES COMPANY\*\*  
CAJUN ELECTRIC POWER COOPERATIVE AND  
ENERGY OPERATIONS, INC.  
DOCKET NO. 50-458  
RIVER BEND STATION, UNIT 1  
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 72  
License No. NFF-47

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Gulf States Utilities\* (the licensee) dated December 8, 1993, as supplemented by letter dated February 3, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and


---

\* EOI is authorized to act as agent for Gulf States Utilities Company, which has been authorized to act as agent for Cajun Electric Power Cooperative, and has exclusive responsibility and control over the physical construction, operation and maintenance of the facility.

\*\*Gulf States Utilities Company, which owns a 70 percent undivided interest in River Bend, has merged with a wholly owned subsidiary of Entergy Corporation. Gulf States Utilities Company was the surviving company in the merger.

- E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment; and Paragraph 2.C.(2) of Facility Operating License No. NPF-47 is hereby amended to read as follows:
- (2) Technical Specifications and Environmental Protection Plan
- The Technical Specifications contained in Appendix A, as revised through Amendment No. 72 and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. EOI shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.
3. The license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Suzanne C. Black, Director  
Project Directorate IV-2  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: February 18, 1994

ATTACHMENT TO LICENSE AMENDMENT NO. 72

FACILITY OPERATING LICENSE NO. NPF-47

DOCKET NO. 50-458

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change. The overleaf pages are provided to maintain document completeness.

REMOVE

INSERT

3/4 3-1	3/4 3-1
3/4 3-6	3/4 3-6
3/4 3-7	3/4 3-7
3/4 3-8	3/4 3-8
3/4 3-9	3/4 3-9
3/4 3-11	3/4 3-11
3/4 3-24	3/4 3-24
3/4 3-25	3/4 3-25
3/4 3-26	3/4 3-26
3/4 3-27	3/4 3-27
3/4 3-29	3/4 3-29
3/4 3-30	3/4 3-30
3/4 3-30a	3/4 3-30a
3/4 3-40	3/4 3-40
3/4 3-41	3/4 3-41
3/4 3-42	3/4 3-42
3/4 3-43	3/4 3-43
3/4 3-59	3/4 3-59
3/4 3-63	3/4 3-63
3/4 3-64	3/4 3-64
3/4 3-76	3/4 3-76
3/4 3-80	3/4 3-80
3/4 3-81	3/4 3-81
3/4 3-84	3/4 3-84
3/4 3-107	3/4 3-107
3/4 3-111	3/4 3-111
3/4 6-31	3/4 6-31
3/4 6-33	3/4 6-33
3/4 6-34	3/4 6-34
3/4 6-35	3/4 6-35
3/4 6-36	3/4 6-36
3/4 6-37	3/4 6-37
3/4 6-47	3/4 6-47
3/4 8-15	3/4 8-15
3/4 8-16	3/4 8-16
3/4 8-18	3/4 8-18
3/4 8-35	3/4 8-35

### 3/4.3 INSTRUMENTATION

#### 3/4.3.1 REACTOR PROTECTION SYSTEM INSTRUMENTATION

##### LIMITING CONDITION FOR OPERATION

3.3.1 As a minimum, the reactor protection system instrumentation channels shown in Table 3.3.1-1 shall be OPERABLE with the REACTOR PROTECTION SYSTEM RESPONSE TIME as shown in Table 3.3.1-2.

APPLICABILITY: As shown in Table 3.3.1-1.

##### ACTION:

- a. With the number of OPERABLE channels less than required by the Minimum OPERABLE Channels per Trip System requirement for one trip system, place the inoperable channel(s) and/or that trip system in the tripped condition\* within one hour.
- b. With the number of OPERABLE channels less than required by the Minimum OPERABLE Channels per Trip System requirement for both trip systems, place at least one trip system\*\* in the tripped condition within one hour and take the ACTION required by Table 3.3.1-1.

##### SURVEILLANCE REQUIREMENTS

4.3.1.1 Each reactor protection system instrumentation channel shall be demonstrated OPERABLE by the performance of the CHANNEL CHECK, CHANNEL FUNCTIONAL TEST and CHANNEL CALIBRATION operations for the OPERATIONAL CONDITIONS and at the frequencies shown in Table 4.3.1.1-1.#

4.3.1.2 LOGIC SYSTEM FUNCTIONAL TESTS and simulated automatic operation of all channels shall be performed at least once per 18 months.\*\*\*

4.3.1.3 The REACTOR PROTECTION SYSTEM RESPONSE TIME of each reactor trip functional unit shown in Table 3.3.1-2## shall be demonstrated to be within its limit at least once per 18 months. Each test shall include at least one channel per trip system such that all channels are tested at least once every N times 18 months where N is the total number of redundant channels in a specific reactor trip system.

\* An inoperable channel need not be placed in the tripped condition where this would cause the Trip Function to occur. In these cases, the inoperable channel shall be restored to OPERABLE status within 2 hours or the ACTION required by Table 3.3.1-1 for that Trip Function shall be taken.

\*\* The trip system need not be placed in the tripped condition if this would cause the Trip Function to occur. When a trip system can be placed in the tripped condition without causing the Trip Function to occur, place the trip system with the most inoperable channels in the tripped condition; if both systems have the same number of inoperable channels, place either trip system in the tripped condition. The requirement to place a trip system in the tripped condition does not apply to Functional Units 6 and 10 of Table 3.3.1-1.

\*\*\*Logic System Functional Test period may be extended as identified by note 'p' on Table 4.3.1.1-1.

# Channel Calibration period may be extended as identified by notes 'o' and 'q' on Table 4.3.1.1-1.

## Response Time test period may be extended as identified by note '##' on Table 3.3.1-2.

TABLE 3.3.1-1  
REACTOR PROTECTION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>APPLICABLE OPERATIONAL CONDITIONS</u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM (a)</u>	<u>ACTION</u>
1. Intermediate Range Monitors:			
a. Neutron Flux - High	2 3 5 <sup>(b)</sup> 4	3 3 3	1 2 3
b. Inoperative	2 3, 4 5	3 3 3	1 2 3
2. Average Power Range Monitor <sup>(c)</sup> :			
a. Neutron Flux - High, Setdown	2 3 5 <sup>(b)</sup> 4	3 3 3	1 2 3
b. Flow Biased Simulated Thermal Power - High	1	3	4
c. Neutron Flux - High	1	3	4
d. Inoperative	1, 2 3, 4 5	3 3 3	1 2 3
3. Reactor Vessel Steam Dome Pressure - High	1, 2 <sup>(d)</sup>	2	1
4. Reactor Vessel Water Level - Low, Level 3	1, 2	2	1
5. Reactor Vessel Water Level-High, Level 8	1 <sup>(e)</sup>	2	4
6. Main Steam Line Isolation Valve - Closure	1 <sup>(e)</sup>	4	10
7. Main Steam Line Radiation - High	1, 2 <sup>(d)</sup>	2	5
8. Drywell Pressure - High	1, 2 <sup>(f)</sup>	2	1

RIVER BEND - UNIT 1

3/4 3-2

TABLE 3.3.1-1 (Continued)

REACTOR PROTECTION SYSTEM INSTRUMENTATION

TABLE NOTATIONS

- (a) A channel may be placed in an inoperable status for up to 2 hours for required surveillance without placing the trip system in the tripped condition provided at least one OPERABLE channel in the same trip system is monitoring that parameter.
- (b) Unless adequate shutdown margin has been demonstrated per Specification 3.1.1, the "shorting links" shall be removed from the RPS circuitry prior to and during the time any control rod is withdrawn".
- (c) An APRM channel is inoperable if there are less than 2 LPRM inputs per level or less than 11 LPRM inputs to an APRM channel.
- (d) This function is not required to be OPERABLE when the reactor pressure vessel head is removed per Specification 3.10.1.
- (e) This function shall be automatically bypassed when the reactor mode switch is not in the Run position.
- (f) This function is not required to be OPERABLE when DRYWELL INTEGRITY is not required.
- (g) With any control rod withdrawn. Not applicable to control rods removed per Specification 3.9.10.1 or 3.9.10.2.
- (h) This function shall be automatically bypassed when turbine first stage pressure is  $< 187$  psig,\*\* equivalent to THERMAL POWER less than 40% of RATED THERMAL POWER.

\*Not required for control rods removed per Specification 3.9.10.1 or 3.9.10.2.  
\*\*To allow for instrumentation accuracy, calibration and drift, a setpoint of  $\leq 177$  psig turbine first stage pressure shall be used.

TABLE 3.3.1-2

REACTOR PROTECTION SYSTEM RESPONSE TIMES

<u>FUNCTIONAL UNIT</u>	<u>RESPONSE TIME (Seconds)</u>
1. Intermediate Range Monitors:	
a. Neutron Flux - High	NA
b. Inoperative	NA
2. Average Power Range Monitor*:	
a. Neutron Flux - High, Setdown	NA
b. Flow Biased Simulated Thermal Power - High	<0.09**##
c. Neutron Flux - High	<0.09##
d. Inoperative	NA
3. Reactor Vessel Steam Dome Pressure - High	<0.35##
4. Reactor Vessel Water Level - Low, Level 3	<1.05
5. Reactor Vessel Water Level - High, Level 8	<1.05
6. Main Steam Line Isolation Valve - Closure	<0.09
7. Main Steam Line Radiation - High	NA
8. Drywell Pressure - High	NA
9. Scram Discharge Volume Water Level - High	
a. Level Transmitter	NA
b. Float Switches	NA
10. Turbine Stop Valve - Closure	<0.06
11. Turbine Control Valve Fast Closure, Valve Trip System Oil Pressure - Low	<0.07#
12. Reactor Mode Switch Shutdown Position	NA
13. Manual Scram	NA

\*Neutron detectors are exempt from response time testing. Response time shall be measured from the detector output or from the input of the first electronic component in the channel.

\*\*Not including simulated thermal power time constant specified in the COLR.

#Measured from start of turbine control valve fast closure.

##Response Time testing may be performed during the fifth refueling outage scheduled to begin April 16, 1994.

TABLE 4.3.1.1-1

## REACTOR PROTECTION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

FUNCTIONAL UNIT	CHANNEL CHECK	CHANNEL FUNCTIONAL TEST	CHANNEL CALIBRATION <sup>(a)</sup>	OPERATIONAL CONDITIONS IN WHICH SURVEILLANCE REQUIRED
1. Intermediate Range Monitors:				
a. Neutron Flux - High	S/U,S,(b) S	S/U <sup>(c)</sup> , W W	R R	2 3, 4, 5
b. Inoperative	NA	W	NA	2, 3, 4, 5
2. Average Power Range Monitor: <sup>(f)</sup>				
a. Neutron Flux - High, Setdown	S/U,S,(b) S	S/U <sup>(c)</sup> , W W	SA SA	2 3, 4, 5
b. Flow Biased Simulated Thermal Power - High	S,D <sup>(h)</sup>	S/U <sup>(c)</sup> , W	W <sup>(d)</sup> (e), SA <sup>(o)</sup> (q), R <sup>(i)</sup> (q)	1
c. Neutron Flux - High	S	S/U <sup>(c)</sup> , W	W <sup>(d)</sup> , SA	1
d. Inoperative	NA	W	NA	1, 2, 3, 4, 5
3. Reactor Vessel Steam Dome Pressure - High	S	M	R <sup>(g)</sup> (p)(q)	1, 2 <sup>(j)</sup>
4. Reactor Vessel Water Level - Low, Level 3	S	M	R <sup>(g)</sup>	1, 2
5. Reactor Vessel Water Level - High, Level 8	S	M	R <sup>(g)</sup>	1
6. Main Steam Line Isolation Valve - Closure	NA	M	R	1
7. Main Steam Line Radiation - High	S	M	R	1, 2 <sup>(j)</sup>
8. Drywell Pressure - High	S	M	R <sup>(g)</sup>	1, 2 <sup>(l)</sup>

RIVER BEND - UNIT 1

3/4 3-7

Amendment 3,8,9, 72



TABLE 4.3.1.1-1 (Continued)

REACTOR PROTECTION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

FUNCTIONAL UNIT	CHANNEL CHECK	CHANNEL FUNCTIONAL TEST	CHANNEL CALIBRATION	OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED
9. Scram Discharge Volume Water Level - High				
a. Level Transmitter	S	M	R <sup>(g)</sup> (p)	1, 2, 5 <sup>(k)</sup>
b. Float Switch	NA	Q	R	1, 2, 5 <sup>(k)</sup>
10. Turbine Stop Valve - Closure	S <sup>(m)</sup>	M <sup>(n)</sup>	R <sup>(g)</sup> (n)	1
11. Turbine Control Valve Fast Closure, Trip Oil Pressure - Low	S <sup>(m)</sup>	M <sup>(n)</sup>	R <sup>(g)</sup> (n)	1
12. Reactor Mode Switch Shutdown Position	NA	R	NA	1, 2, 3, 4, 5
13. Manual Scram	NA	M	NA	1, 2, 3, 4, 5

- (a) Neutron detectors may be excluded from CHANNEL CALIBRATION.
- (b) The IRM and SRM channels shall be determined to overlap for at least 1/2 decade during each startup after entering OPERATIONAL CONDITION 2 and the IRM and APRM channels shall be determined to overlap for at least 1/2 decade during each controlled shutdown, if not performed within the previous 7 days.
- (c) Within 24 hours prior to startup, if not performed within the previous 7 days.
- (d) This calibration shall consist of the adjustment of the APRM channel to conform to the power values calculated by a heat balance during OPERATIONAL CONDITION 1 when THERMAL POWER >25% of RATED THERMAL POWER. Adjust the APRM channel if the absolute difference is greater than 2% of RATED THERMAL POWER. Any APRM channel gain adjustment made in compliance with Specification 3.2.2 shall not be included in determining the absolute difference.
- (e) This calibration shall consist of the adjustment of the APRM flow biased channel to conform to a calibrated flow signal.

TABLE 4.3.1.1-1 (Continued)

REACTOR PROTECTION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

- (f) The LPRMs shall be calibrated at least once per 1000 effective full power hours (EFPH) using the TIP system.
- (g) Calibrate Rosemount trip unit setpoint at least once per 31 days.
- (h) Verify measured drive flow to be less than or equal to established drive flow at the existing flow control valve position.
- (i) This calibration shall consist of verifying the simulated thermal power time constant is within the limits specified in the COLR.
- (j) This function is not required to be OPERABLE when the reactor pressure vessel head is removed per Specification 3.10.1.
- (k) With any control rod withdrawn. Not applicable to control rods removed per Specification 3.9.10.1 or 3.9.10.2.
- (l) This function is not required to be OPERABLE when DRYWELL INTEGRITY is not required per Specification 3.10.1.
- (m) Verify the Turbine Bypass Valves are closed when THERMAL POWER is greater than or equal to 40% RATED THERMAL POWER.
- (n) The CHANNEL FUNCTIONAL TEST and CHANNEL CALIBRATION shall include the turbine first stage pressure instruments.
- (o) The CHANNEL CALIBRATION shall exclude the flow reference transmitters; these transmitters shall be calibrated at least once per 18 months, except that this test may be performed during the fifth refueling outage scheduled to begin April 16, 1994.
- (p) This period may be extended to the completion of the fifth refueling outage scheduled to begin April 16, 1994.
- (q) CHANNEL CALIBRATION may be performed during the fifth refueling outage scheduled to begin April 16, 1994.

## INSTRUMENTATION

### 3/4.3.2 ISOLATION ACTUATION INSTRUMENTATION

#### LIMITING CONDITION FOR OPERATION

---

3.3.2 The isolation actuation instrumentation channels shown in Table 3.3.2-1 shall be OPERABLE with their trip setpoints set consistent with the values shown in the Trip Setpoint column of Table 3.3.2-2 and with ISOLATION SYSTEM RESPONSE TIME as shown in Table 3.3.2-3.

APPLICABILITY: As shown in Table 3.3.2-1.

ACTION:

- a. With an isolation actuation instrumentation channel trip setpoint less conservative than the value shown in the Allowable Values column of Table 3.3.2-2, declare the channel inoperable until the channel is restored to OPERABLE status with its trip setpoint adjusted consistent with the Trip Setpoint value.
- b. With the number of OPERABLE channels less than required by the Minimum OPERABLE Channels per Trip System requirement for one trip system, place the inoperable channel(s) and/or that trip system in the tripped condition\* within one hour.
- c. With the number of OPERABLE channels less than required by the Minimum OPERABLE Channels per Trip System requirement for both trip systems, place at least one trip system\*\* in the tripped condition within one hour and take the ACTION required by Table 3.3.2-1.

---

\*An inoperable channel need not be placed in the tripped condition where this would cause the Trip Function to occur. In these cases, the inoperable channel shall be restored to OPERABLE status within 2 hours or the ACTION required by Table 3.3.2-1 for that Trip Function shall be taken.

\*\*The trip system need not be placed in the tripped condition if this would cause the Trip Function to occur. When a trip system can be placed in the tripped condition without causing the Trip Function to occur, place the trip system with the most inoperable channels in the tripped condition; if both systems have the same number of inoperable channels, place either trip system in the tripped condition.

## INSTRUMENTATION

### SURVEILLANCE REQUIREMENTS

---

4.3.2.1 Each isolation actuation instrumentation channel shall be demonstrated OPERABLE by the performance of the CHANNEL CHECK, CHANNEL FUNCTIONAL TEST and CHANNEL CALIBRATION operations for the OPERATIONAL CONDITIONS and at the frequencies shown in Table 4.3.2.1-1.\*\*

4.3.2.2 LOGIC SYSTEM FUNCTIONAL TESTS and simulated automatic operation of all channels shall be performed at least once per 18 months.\*

4.3.2.3 The ISOLATION SYSTEM RESPONSE TIME of each isolation trip function shown in Table 3.3.2-3 shall be demonstrated to be within its limit at least once per 18 months.\*\*\* Each test shall include at least one channel per trip system such that all channels are tested at least once every N times 18 months,\*\*\* where N is the total number of redundant channels in a specific isolation trip system.

---

\* Logic System Functional Testing period may be extended as identified by note c on Table 4.3.2.1-1.

\*\* Channel Calibration period may be extended as identified by note 'd' on Table 4.3.2.1-1.

\*\*\*Response Time test period may be extended as identified by note 'c' on Table 3.3.2-3.

TABLE 3.3.2-1

ISOLATION ACTUATION INSTRUMENTATION

<u>TRIP FUNCTION</u>	<u>VALVE GROUPS OPERATED BY SIGNAL***</u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM (a)</u>	<u>APPLICABLE OPERATIONAL CONDITION</u>	<u>ACTION</u>
<u>1. PRIMARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level- Low Low, Level 2	1, 7, 8, 9 <sup>(b)(c)(j)</sup> , 15, 16	2	1, 2, 3	20
b. Drywell Pressure - High	1, 3, 8 <sup>(b)(c)(j)</sup>	2	1, 2, 3	20
c. Containment Purge Isolation Radiation - High	8	1	1, 2, 3	21
<u>2. MAIN STEAM LINE ISOLATION</u>				
a. Reactor Vessel Water Level- Low Low Low, Level 1	6	2	1, 2, 3	20
b. Main Steam Line Radiation - High	6, 9 <sup>(d)</sup>	2	1, 2, 3	23
c. Main Steam Line Pressure - Low	6	2	1	24
d. Main Steam Line Flow - High	6	2/MSL	1, 2, 3	23
e. Condenser Vacuum - Low	6	2	1, 2**, 3**	23
f. Main Steam Line Tunnel Temperature - High	6	2	1, 2, 3	23
g. Main Steam Line Tunnel Δ Temperature - High	6	2	1, 2, 3	23
h. Main Steam Line Area Temperature High (Turbine Building)	6	2/area	1, 2, 3	23

TABLE 3.3.2-2 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
6. <u>RHR SYSTEM ISOLATION</u> (Cont'd)		
e. Reactor Vessel (RHR Cut-in Permissive) Pressure - High	$\leq 135$ psig	$\leq 150$ psig
f. Drywell Pressure - High	$\leq 1.68$ psig	$\leq 1.88$ psig
7. <u>MANUAL INITIATION</u>	NA	NA

---

\* See Bases Figure B 3/4 3-1.

TABLE 3.3.2-3  
ISOLATION SYSTEM INSTRUMENTATION RESPONSE TIME

<u>TRIP FUNCTION</u>	<u>RESPONSE TIME (Seconds)#</u>
<u>1. PRIMARY CONTAINMENT ISOLATION</u>	
a. Reactor Vessel Water Level - Low Low Level 2	< 10 <sup>(a)(c)</sup>
b. Drywell Pressure - High	< 10 <sup>(a)(c)</sup>
c. Containment Purge Isolation Radiation - High <sup>(b)</sup>	NA
<u>2. MAIN STEAM LINE ISOLATION</u>	
a. Reactor Vessel Water Level - Low Low Low Level 1	< 1.0 * / < 10 <sup>(a)**(c)</sup>
b. Main Steam Line Radiation - High <sup>(b)</sup>	< 1.0 * / > 10 <sup>(a)**(c)</sup>
c. Main Steam Line Pressure - Low	< 1.0 * / > 10 <sup>(a)**(c)</sup>
d. Main Steam Line Flow - High	< 0.5 * / > 10 <sup>(a)**(c)</sup>
e. Condenser Vacuum - Low	NA
f. Main Steam Line Tunnel Temperature - High	NA
g. Main Steam Line Tunnel Δ Temperature - High	NA
h. Main Steam Line Area Temperature - High (Turbine Bldg)	NA
<u>3. SECONDARY CONTAINMENT ISOLATION</u>	
a. Reactor Vessel Water Level - Low Low Level 2	< 10 <sup>(a)(c)</sup>
b. Drywell Pressure - High	< 10 <sup>(a)(c)</sup>
c. Fuel Building Ventilation Exhaust Radiation - High <sup>(b)</sup>	NA
d. Reactor Building Annulus Ventilation Exhaust Radiation - High <sup>(b)</sup>	NA
<u>4. REACTOR WATER CLEANUP SYSTEM ISOLATION</u>	
a. Δ Flow - High	< 10 <sup>(a)##(c)</sup>
b. Δ Flow Timer	NA
c. Equipment Area Temperature - High	NA
d. Equipment Area Δ Temperature - High	NA
e. Reactor Vessel Water Level - Low Low Level 2	< 10 <sup>(a)(c)</sup>
f. Main Steam Line Tunnel Ambient Temperature - High	NA
g. Main Steam Line Tunnel Δ Temperature - High	NA
h. SLCS Initiation	NA
<u>5. REACTOR CORE ISOLATION COOLING SYSTEM ISOLATION</u>	
a. RCIC Steam Line Flow - High	< 10 <sup>(a)###</sup>
b. RCIC Steam Line Flow-High Timer	NA
c. RCIC Steam Supply Pressure - Low	< 10 <sup>(a)</sup>
d. RCIC Turbine Exhaust Diaphragm Pressure - High	NA
e. RCIC Equipment Room Ambient Temperature - High	NA
f. RCIC Equipment Room Δ Temperature - High	NA
g. Main Steam Line Tunnel Ambient Temperature - High	NA
h. Main Steam Line Tunnel Δ Temperature - High	NA

TABLE 3.3.2-3 (Continued)

ISOLATION SYSTEM INSTRUMENTATION RESPONSE TIME

<u>TRIP FUNCTION</u>	<u>RESPONSE TIME (Seconds)#</u>
i. Main Steam Line Tunnel Temperature Timer	NA
j. RHR Equipment Room Ambient Temperature - High	NA
k. RHR Equipment Room Δ Temperature - High	NA
l. RHR/RCIC Steam Line Flow - High	NA
m. Drywell Pressure - High	NA
n. Manual Initiation	NA
<u>6. RHR SYSTEM ISOLATION</u>	
a. RHR Equipment Area Ambient Temperature - High	NA
b. RHR Equipment Area Δ Temperature - High	NA
c. Reactor Vessel Water Level - Low Level 3	≤ 10 <sup>(a)</sup>
d. Reactor Vessel Water Level - Low Low Low Level 1	≤ 10 <sup>(a)(c)</sup>
e. Reactor Vessel (RHR Cut-in Permissive) Pressure - High	NA
f. Drywell Pressure - High	NA
<u>7. MANUAL INITIATION</u>	NA

- (a) Isolation system instrumentation response time specified includes the diesel generator starting and sequence loading delays.
- (b) Radiation detectors are exempt from response time testing. Response time shall be measured from detector output or the input of the first electronic component in the channel.
- (c) Response Time testing may be performed during the fifth refueling outage scheduled to begin April 16, 1994.
- \* Isolation system instrumentation response time for MSIVs only. No diesel generator delays assumed.
- \*\* Isolation system instrumentation response time for associated valves except MSIVs.
- # Isolation system instrumentation response time specified for the Trip Function actuating each valve group shall be added to isolation time shown in Tables 3.6.4-1 and 3.6.5.3-1 for valves in each valve group to obtain ISOLATION SYSTEM RESPONSE TIME for each valve.
- ## Time delay of 45-47 seconds.
- ### Time delay of 3-13 seconds.



TABLE 4.3.2.1-1

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS IN WHICH SURVEILLANCE REQUIRED</u>
1. <u>PRIMARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level - Low Low Level 2	S	M	R <sup>(b)</sup>	1, 2, 3
b. Drywell Pressure - High	S	M	R <sup>(b)</sup>	1, 2, 3
c. Containment Purge Isolation Radiation - High	S	M	R	1, 2, 3
2. <u>MAIN STEAM LINE ISOLATION</u>				
a. Reactor Vessel Water Level - Low Low Low Level 1	S	M	R <sup>(b)</sup>	1, 2, 3
b. Main Steam Line Radiation - High	S	M	R	1, 2, 3
c. Main Steam Line Pressure - Low	S	M	R <sup>(b)</sup>	1
d. Main Steam Line Flow - High	S	M	R <sup>(b)</sup>	1, 2, 3
e. Condenser Vacuum - Low	S	M	R <sup>(b)</sup>	1, 2**, 3**
f. Main Steam Line Tunnel Temperature - High	S	M	R	1, 2, 3
g. Main Steam Line Tunnel Δ Temperature - High	S	M	R	1, 2, 3
h. Main Steam Line Area Temperature-High (Turbine Building)	S	M	R <sup>(b)</sup>	1, 2, 3

RIVER BEND - UNIT 1

3/4 3-26

Amendment 8, 9,

TABLE 4.3.2.1-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS IN WHICH SURVEILLANCE REQUIRED</u>
<u>3. SECONDARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level - Low Low Level 2	S	M	R <sup>(b)</sup>	1, 2, 3
b. Drywell Pressure - High	S	M	R <sup>(b)</sup>	1, 2, 3
c. Fuel Building Ventilation Exhaust Radiation - High	S	M	R	*
d. Reactor Building Annulus Ventilation Exhaust Radiation - High	S	M	R	1, 2, 3
<u>4. REACTOR WATER CLEANUP SYSTEM ISOLATION</u>				
a. $\Delta$ Flow - High	S	M	R <sup>(c)</sup>	1, 2, 3
b. $\Delta$ Flow Timer	NA	M	Q <sup>(c)</sup>	1, 2, 3
c. Equipment Area Temperature - High	S	M	R <sup>(c)</sup>	1, 2, 3
d. Equipment Area $\Delta$ Temperature - High	S	M	R <sup>(c)</sup>	1, 2, 3
e. Reactor Vessel Water Level - Low Low Level 2	S	M	R <sup>(b)(c)</sup>	1, 2, 3
f. Main Steam Line Tunnel Ambient Temperature - High	S	M	R <sup>(c)</sup>	1, 2, 3
g. Main Steam Line Tunnel $\Delta$ Temperature - High	S	M	R <sup>(c)</sup>	1, 2, 3
h. SLCS Initiation	NA	M <sup>(a)</sup>	NA <sup>(c)</sup>	1, 2, 3

TABLE 4.3.2.1-1 (Continued)

## ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

TRIP FUNCTION	CHANNEL CHECK	CHANNEL FUNCTIONAL TEST	CHANNEL CALIBRATION	OPERATIONAL CONDITIONS IN WHICH SURVEILLANCE REQUIRED
5. REACTOR CORE ISOLATION COOLING SYSTEM ISOLATION				
a. RCIC Steam Line Flow - High	S	M	R <sup>(b)</sup>	1, 2, 3
b. RCIC Steam Line Flow-High Timer	NA	M	Q	1, 2, 3
c. RCIC Steam Supply Pressure - Low	S	M	R <sup>(b)</sup>	1, 2, 3
d. RCIC Turbine Exhaust Diaphragm Pressure - High	S	M	R <sup>(b)</sup>	1, 2, 3
e. RCIC Equipment Room Ambient Temperature - High	S	M	R	1, 2, 3
f. RCIC Equipment Room Δ Temperature - High	S	M	R	1, 2, 3
g. Main Steam Line Tunnel Ambient Temperature - High	S	M	R	1, 2, 3
h. Main Steam Line Tunnel Δ Temperature - High	S	M	R	1, 2, 3
i. Main Steam Line Tunnel Temperature Timer	NA	M	Q	1, 2, 3
j. RHR Equipment Room Ambient Temperature - High	S	M	R	1, 2, 3
k. RHR Equipment Room Δ Temperature - High	S	M	R	1, 2, 3
l. RHR/RCIC Steam Line Flow-High	S	M	R <sup>(b)</sup>	1, 2, 3
m. Drywell Pressure-High	S	M	R <sup>(b)</sup>	1, 2, 3
n. Manual Initiation	NA	R	NA	1, 2, 3

TABLE 4.3.2.1-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS IN WHICH SURVEILLANCE REQUIRED</u>
6. <u>RHR SYSTEM ISOLATION</u>				
a. RHR Equipment Area Ambient Temperature - High	S	M	R	1, 2, 3
b. RHR Equipment Area $\Delta$ Temperature - High	S	M	R	1, 2, 3
c. Reactor Vessel Water Level - Low Level 3	S	M	R <sup>(b)</sup>	1, 2, 3
d. Reactor Vessel Water Level - Low Low Low Level 1	S	M	R <sup>(b)</sup>	1, 2, 3
e. Reactor Vessel (RHR Cut-in Permissive) Pressure - High	S	M	R <sup>(b)(c)(d)</sup>	1, 2, 3
f. Drywell Pressure - High	S	M	R <sup>(b)</sup>	1, 2, 3
7. <u>MANUAL INITIATION</u>	NA	M	NA	1, 2, 3

\*When handling irradiated fuel in the Fuel Building.

\*\*When the reactor mode switch is in Run and/or any turbine stop valve is open.

(a) Each train or logic channel shall be tested at least every other 31 days.

(b) Calibrate trip unit setpoint at least once per 31 days.

(c) May be performed during the fifth refueling outage scheduled to begin April 16, 1994.

(d) CHANNEL CALIBRATION may be performed during the fifth refueling outage scheduled to begin April 16, 1994.

## INSTRUMENTATION

### 3/4.3.3 EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION

#### LIMITING CONDITION FOR OPERATION

---

3.3.3 The emergency core cooling system (ECCS) actuation instrumentation channels shown in Table 3.3.3-1 shall be OPERABLE with their trip setpoints set consistent with the values shown in the Trip Setpoint column of Table 3.3.3-2 and with EMERGENCY CORE COOLING SYSTEM RESPONSE TIME as shown in Table 3.3.3-3.

APPLICABILITY: As shown in Table 3.3.3-1.

#### ACTION:

- a. With an ECCS actuation instrumentation channel trip setpoint less conservative than the value shown in the Allowable Values column of Table 3.3.3-2, declare the channel inoperable until the channel is restored to OPERABLE status with its trip setpoint adjusted consistent with the Trip Setpoint value.
- b. With one or more ECCS actuation instrumentation channels inoperable, take the ACTION required by Table 3.3.3-1.
- c. With either ADS trip system "A" or "B" inoperable, restore the inoperable trip system to OPERABLE status:
  1. Within 7 days, provided that the HPCS and RCIC systems are OPERABLE, or
  2. Within 72 hours, provided either the HPCS or the RCIC system is inoperable.

Otherwise, be in at least HOT SHUTDOWN within the next 12 hours and reduce reactor steam dome pressure to less than or equal to 100 psig within the following 24 hours.

#### SURVEILLANCE REQUIREMENTS

---

4.3.3.1 Each ECCS actuation instrumentation channel shall be demonstrated OPERABLE by the performance of the CHANNEL CHECK, CHANNEL FUNCTIONAL TEST and CHANNEL CALIBRATION operations for the OPERATIONAL CONDITIONS and at the frequencies shown in Table 4.3.3.1-1.##

4.3.3.2 LOGIC SYSTEM FUNCTIONAL TESTS and simulated automatic operation of all channels shall be performed at least once per 18 months.##

---

##Channel Calibration and Logic System Functional testing period may be extended as identified by note b on Table 4.3.3.1-1.

## INSTRUMENTATION

### 3/4.3.3 EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION

#### SURVEILLANCE REQUIREMENTS

---

4.3.3.3 At least once per 18 months##, the ECCS RESPONSE TIME of each ECCS trip function shown in Table 3.3.3-3 shall be demonstrated to be within the limit. Each test shall include at least one channel per trip system such that all channels are tested at least once every N times 18 months##, where N is the total number of redundant channels in a specific ECCS trip system. |

##ECCS Response time testing period may be extended as identified by note A on Table 3.3.3-3. |

TABLE 3.3.3-2 (Continued)

EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
D. <u>LOSS OF POWER</u> (continued)		
2. <u>Division III</u>		
a. 4.16 kv Standby Bus Undervoltage (Sustained Undervoltage)	a. 4.16 kv Basis - 3045 ± 153 volts	3045 ± 214 volts
	b. 3 ± 0.3 sec. time delay	3 ± 0.33 sec. time delay
b. 4.16 kv Standby Bus Undervoltage (Degraded Voltage)	a. 4.16 kv Basis - 3777 ± 30 volts	3777 ± 75 volts
	b. 60 ± 6 sec. time delay (w/o LOCA)	60 ± 6.6 sec. time delay
	c. 3 ± 0.3 sec. time delay (w/LOCA)	3 ± 0.33 sec. time delay

\*See Bases Figure B 3/4 3-1.

\*\* (Bottom of CST is at EL 95'1".) The levels are measured from the instrument zero level of EL 98'6".

# (Bottom of suppression pool is at EL 70'.) The levels are measured from the instrument zero level of EL 89'9".

## These are inverse time delay voltage relays or instantaneous voltage relays with a time delay. The voltages shown are the maximum that will not result in a trip. Lower voltage conditions will result in decreased trip times.

TABLE 3.3.3-3

EMERGENCY CORE COOLING SYSTEM RESPONSE TIMES

<u>ECCS</u>	<u>RESPONSE TIME (Seconds)</u>
1. LOW PRESSURE CORE SPRAY SYSTEM	≤ 37 <sup>(A)</sup>
2. LOW PRESSURE COOLANT INJECTION MODE OF RHR SYSTEM	
a. Pumps A and B	≤ 37 <sup>(A)</sup>
b. Pump C	≤ 37 <sup>(A)</sup>
3. AUTOMATIC DEPRESSURIZATION SYSTEM	NA
4. HIGH PRESSURE CORE SPRAY SYSTEM	≤ 27 <sup>(A)</sup>
5. LOSS OF POWER	NA

<sup>(A)</sup> Response time testing may be extended to the completion of the fifth refueling outage scheduled to begin April 16, 1994.



TABLE 4.3.3.1-1

## EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
<b>A. DIVISION I TRIP SYSTEM</b>				
<b>1. RHR-A (LPCI MODE) AND LPCS SYSTEM</b>				
a. Reactor Vessel Water Level - Low Low Low Level 1	S	M	R(a)	1, 2, 3, 4*, 5*
b. Drywell Pressure - High	S	M	R(a)	1, 2, 3
c. LPCS Pump Discharge Flow-Low	S	M	R(a)	1, 2, 3, 4*, 5*
d. Reactor Vessel Pressure-Low (LPCS/LPCI Injection Valve Permissive)	S	M	R(a)	1, 2, 3, 4*, 5*
e. LPCI Pump A Start Time Delay Relay	NA	M	Q	1, 2, 3, 4*, 5*
f. LPCI Pump A Discharge Flow-Low	S	M	R(a)	1, 2, 3, 4*, 5*
g. LPCS Pump Start Time Delay Relay	NA	M	Q	1, 2, 3, 4*, 5*
h. Manual Initiation	NA	R(b)	NA	1, 2, 3, 4*, 5*
<b>2. AUTOMATIC DEPRESSURIZATION SYSTEM TRIP SYSTEM "A" #</b>				
a. Reactor Vessel Water Level - Low Low Low Level 1	S	M	R(a)	1, 2, 3
b. Drywell Pressure-High	S	M	R(a)	1, 2, 3
c. ADS Timer	NA	M	Q	1, 2, 3
d. Reactor Vessel Water Level - Low Level 3	S	M	R(a)	1, 2, 3
e. LPCS Pump Discharge Pressure-High	S	M	R(a)	1, 2, 3
f. LPCI Pump A Discharge Pressure-High	S	M	R(a)	1, 2, 3
g. ADS Drywell Pressure Bypass Timer	NA	M	Q	1, 2, 3
h. ADS Manual Inhibit Switch	NA	M	NA	1, 2, 3
i. Manual Initiation	NA	R	NA	1, 2, 3

TABLE 4.3.3.1-1 (Continued)

EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
<b>B. <u>DIVISION II TRIP SYSTEM</u></b>				
<b>1. <u>RHR B AND C (LPCI MODE)</u></b>				
a. Reactor Vessel Water Level - Low Low Low Level 1	S	M	R(a)	1, 2, 3, 4*, 5*
b. Drywell Pressure - High	S	M	R(a)	1, 2, 3
c. Reactor Vessel Pressure-Low (LPCI Injection Valve Permissive)	S	M	R(a)	1, 2, 3, 4*, 5*
d. LPCI Pump B Start Time Delay Relay	NA	M	Q	1, 2, 3, 4*, 5*
e. LPCI Pump Discharge Flow-Low	S	M	R(a)	1, 2, 3, 4*, 5*
f. LPCI Pump C Start Time Delay Relay	NA	M	Q	1, 2, 3, 4*, 5*
g. Manual Initiation	NA	R(b)	NA	1, 2, 3, 4*, 5*
<b>2. <u>AUTOMATIC DEPRESSURIZATION SYSTEM TRIP SYSTEM "B" #</u></b>				
a. Reactor Vessel Water Level - Low Low Low Level 1	S	M	R(a)	1, 2, 3
b. Drywell Pressure-High	S	M	R(a)	1, 2, 3
c. ADS Timer	NA	M	Q	1, 2, 3
d. Reactor Vessel Water Level - Low Level 3	S	M	R(a)	1, 2, 3
e. LPCI Pump B and C Discharge Pressure-High	S	M	R(a)	1, 2, 3
f. ADS Drywell Pressure Bypass Timer	NA	M	Q	1, 2, 3
g. ADS Manual Inhibit Switch	NA	M	NA	1, 2, 3
h. Manual Initiation	NA	R	NA	1, 2, 3

TABLE 4.3.3.1-1 (Continued)  
EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

TRIP FUNCTION	CHANNEL CHECK	CHANNEL FUNCTIONAL TEST	CHANNEL CALIBRATION	OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED
<b>C. DIVISION III TRIP SYSTEM</b>				
<b>1. HPCS SYSTEM</b>				
a. Reactor Vessel Water Level - Low Low Level 2	S	M	R <sup>(a)</sup>	1, 2, 3, 4*, 5*
b. Drywell Pressure-High	S	M	R <sup>(a)</sup>	1, 2, 3
c. Reactor Vessel Water Level-High Level 8	S	M	R <sup>(a)</sup>	1, 2, 3, 4*, 5*
d. Condensate Storage Tank Level - Low	S	M	R <sup>(a)</sup>	1, 2, 3, 4*, 5*
e. Suppression Pool Water Level - High	S	M	R <sup>(a)</sup>	1, 2, 3, 4*, 5*
f. Pump Discharge Pressure-High	S	M	R <sup>(a)</sup>	1, 2, 3, 4*, 5*
g. HPCS System Flow Rate-Low	S	M	R <sup>(a)</sup> (b)	1, 2, 3, 4*, 5*
h. Manual Initiation	NA	R	NA	1, 2, 3, 4*, 5*
<b>D. LOSS OF POWER</b>				
<b>1. Divisions I and II</b>				
a. 4.16 kv Standby Bus Under-voltage (Sustained Under-voltage)	S	M	R <sup>(b)</sup>	1, 2, 3, 4**, 5**
b. 4.16 kv Standby Bus Under-voltage (Degraded Voltage)	S	M	R <sup>(b)</sup>	1, 2, 3, 4**, 5**
<b>2. Division III</b>				
a. 4.16 kv Standby Bus Under-voltage (Sustained Under-voltage)	S	NA	R	1, 2, 3, 4**, 5**
b. 4.16 kv Standby Bus Under-voltage (Degraded Voltage)	S	M	R	1, 2, 3, 4**, 5**

# Not required to be OPERABLE when reactor steam dome pressure is less than or equal to 100 psig.

\* When the system is required to be OPERABLE per Specification 3.5.2.

\*\* Required when ESF equipment is required to be OPERABLE.

(a) Calibrate trip unit setpoint at least once per 31 days.

(b) May be extended to the completion of the fifth refueling outage, scheduled to begin April 16, 1994.

## INSTRUMENTATION

### 3/4.3.4 RECIRCULATION PUMP TRIP ACTUATION INSTRUMENTATION

#### ATWS RECIRCULATION PUMP TRIP SYSTEM INSTRUMENTATION

##### LIMITING CONDITION FOR OPERATION

---

3.3.4.1 The anticipated transient without scram recirculation pump trip (ATWS-RPT) system instrumentation channels shown in Table 3.3.4.1-1 shall be OPERABLE with their trip setpoints set consistent with values shown in the Trip Setpoint column of Table 3.3.4.1-2.

APPLICABILITY: OPERATIONAL CONDITION 1.

ACTION:

- a. With an ATWS-RPT system instrumentation channel trip setpoint less conservative than the value shown in the Allowable Values column of Table 3.3.4.1-2, declare the channel inoperable until the channel is restored to OPERABLE status with the channel trip setpoint adjusted consistent with the Trip Setpoint value.
- b. With the number of OPERABLE channels one less than required by the Minimum OPERABLE Channels per Trip System requirement for one or both trip systems, restore the inoperable channel to OPERABLE status within 30 days or be in at least STARTUP within the next 6 hours.
- c. Otherwise, restore at least one inoperable channel in each trip system to OPERABLE status within 72 hours or be in at least STARTUP within the next 6 hours.

##### SURVEILLANCE REQUIREMENTS

---

4.3.4.1.1 Each ATWS-RPT system instrumentation channel shall be demonstrated OPERABLE by the performance of the CHANNEL CHECK, CHANNEL FUNCTIONAL TEST, and CHANNEL CALIBRATION operations at the frequencies shown in Table 4.3.4.1-1.

4.3.4.1.2 LOGIC SYSTEM FUNCTIONAL TESTS and simulated automatic operation of all channels shall be performed at least once per 18 months.

## INSTRUMENTATION

### 3/4.3.6 CONTROL ROD BLOCK INSTRUMENTATION

#### LIMITING CONDITION FOR OPERATION

---

3.3.6 The control rod block instrumentation channels shown in Table 3.3.6-1 shall be OPERABLE with their trip setpoints set consistent with the values shown in the Trip Setpoint column of Table 3.3.6-2.

APPLICABILITY: As shown in Table 3.3.6-1.

#### ACTION:

- a. With a control rod block instrumentation channel trip setpoint less conservative than the value shown in the Allowable Values column of Table 3.3.6-2, declare the channel inoperable until the channel is restored to OPERABLE status with its trip setpoint adjusted consistent with the Trip Setpoint value.
- b. With the number of OPERABLE channels less than required by the Minimum OPERABLE Channels per Trip Function requirement, take the ACTION required by Table 3.3.6-1.

#### SURVEILLANCE REQUIREMENTS

---

4.3.6 Each of the above required control rod block trip systems and instrumentation channels shall be demonstrated OPERABLE by the performance of the CHANNEL CHECK, CHANNEL FUNCTIONAL TEST and CHANNEL CALIBRATION operations for the OPERATIONAL CONDITIONS and at the frequencies shown in Table 4.3.6-1.#

---

#Channel Calibration period may be extended as identified by notes 'c' and 'g' on Table 4.3.6-1.

TABLE 3.3.6-1  
CONTROL ROD BLOCK INSTRUMENTATION

<u>TRIP FUNCTION</u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP FUNCTION</u>	<u>APPLICABLE OPERATIONAL CONDITIONS</u>	<u>ACTION</u>
1. <u>ROD PATTERN CONTROL SYSTEM</u>			
a. Low Power Setpoint	2	1, 2	60
b. High Power Setpoint	2	1	60
2. <u>APRM</u>			
a. Flow Biased Neutron Flux - Upscale	6	1	61
b. Inoperative	6	1, 2, 5	61
c. Downscale	6	1	61
d. Neutron Flux - Upscale, Startup	6	2, 5	61
3. <u>SOURCE RANGE MONITORS</u>			
a. Detector not full in <sup>(a)</sup>	3 2**	2 5	61 62
b. Upscale <sup>(b)</sup>	3 2**	2 5	61 62
c. Inoperative <sup>(b)</sup>	3 2**	2 5	61 62
d. Downscale <sup>(c)</sup>	3 2**	2 5	61 62
4. <u>INTERMEDIATE RANGE MONITORS</u>			
a. Detector not full in	6	2, 5	61
b. Upscale	6	2, 5	61
c. Inoperative	6	2, 5	61
d. Downscale <sup>(d)</sup>	6	2, 5	61
5. <u>SCRAM DISCHARGE VOLUME</u>			
a. Water Level-High	2	1, 2, 5*	62
6. <u>REACTOR COOLANT SYSTEM RECIRCULATION FLOW</u>			
a. Upscale	2	1	62

TABLE 4.3.6-1

CONTROL ROD BLOCK INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u> <sup>(a)</sup>	<u>OPERATIONAL CONDITIONS IN WHICH SURVEILLANCE REQUIRED</u>
1. <u>ROD PATTERN CONTROL SYSTEM</u>				
a. Low Power Setpoint	S <sup>(f)</sup>	S/U <sup>(b)</sup> (e) M <sup>(e)</sup>	SA <sup>#</sup>	1, 2
b. High Power Setpoint	S <sup>(f)</sup>	S/U <sup>(b)</sup> (e) M <sup>(e)</sup>	SA <sup>#</sup>	1**
2. <u>APRM</u>				
a. Flow Biased Neutron Flux - Upscale	NA	S/U <sup>(b)</sup> , M	SA <sup>(g)</sup>	1
b. Inoperative	NA	S/U <sup>(b)</sup> , M	NA	1, 2, 5
c. Downscale	NA	S/U <sup>(b)</sup> , M	SA	1
d. Neutron Flux - Upscale, Startup	NA	S/U <sup>(b)</sup> , M	SA	2, 5
3. <u>SOURCE RANGE MONITORS</u>				
a. Detector not full in	NA	S/U <sup>(b)</sup> , W	NA	2, 5
b. Upscale	NA	S/U <sup>(b)</sup> , W	SA	2, 5
c. Inoperative	NA	S/U <sup>(b)</sup> , W	NA	2, 5
d. Downscale	NA	S/U <sup>(b)</sup> , W	SA	2, 5
4. <u>INTERMEDIATE RANGE MONITORS</u>				
a. Detector not full in	NA	S/U <sup>(b)</sup> , W	NA	2, 5
b. Upscale	NA	S/U <sup>(b)</sup> , W	SA	2, 5
c. Inoperative	NA	S/U <sup>(b)</sup> , W	NA	2, 5
d. Downscale	NA	S/U <sup>(b)</sup> , W	SA	2, 5
5. <u>SCRAM DISCHARGE VOLUME</u>				
a. Water Level-High	NA	M	R <sup>#</sup> (c)	1, 2, 5*
6. <u>REACTOR COOLANT SYSTEM RECIRCULATION FLOW</u>				
a. Upscale	NA	S/U <sup>(b)</sup> , M	SA <sup>(g)</sup>	1

TABLE 4.3.6-1 (Continued)

CONTROL ROD BLOCK INSTRUMENTATION SURVEILLANCE REQUIREMENTS

NOTES:

- a. Neutron detectors may be excluded from CHANNEL CALIBRATION.
- b. Within 24 hours prior to startup, if not performed within the previous 7 days.
- c. CHANNEL CALIBRATION may be extended to the completion of the fifth refueling outage scheduled to begin April 16, 1994.
- d. [DELETED]
- e. Includes reactor manual control multiplexing system input.
- f. Verify the Turbine Bypass valves are closed when THERMAL POWER is greater than 20% RATED THERMAL POWER.
- g. The CHANNEL CALIBRATION shall exclude the flow reference transmitters; these transmitters shall be calibrated at least once per 18 months, except that this test may be extended to the completion of the fifth refueling outage scheduled to begin April 16, 1994.
- \* With any control rod withdrawn. Not applicable to control rods removed per Specification 3.9.10.1 or 3.9.10.2.
- # Calibrate trip unit setpoint once per 31 days.
- \*\* With THERMAL POWER greater than low power setpoint.



TABLE 4.3.7.3-1

METEOROLOGICAL MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>
a. Wind Speed		
1. Elev. 30 ft.	D	SA
2. Elev. 150 ft.	D	SA
b. Wind Direction		
1. Elev. 30 ft.	D	SA
2. Elev. 150 ft.	D	SA
c. Air Temperature Difference		
1. Elev. 30/150 ft.	D	SA

## INSTRUMENTATION

### REMOTE SHUTDOWN MONITORING INSTRUMENTATION AND CONTROLS

#### LIMITING CONDITION FOR OPERATION

---

3.3.7.4 The remote shutdown monitoring instrumentation channels and controls shown in Table 3.3.7.4-1 and 3.3.7.4-2 shall be OPERABLE.

APPLICABILITY: OPERATIONAL CONDITIONS 1 and 2.

#### ACTION:

- a. With the number of OPERABLE remote shutdown monitoring instrumentation channels less than required by Table 3.3.7.4-1, restore the inoperable channel(s) to OPERABLE status within 7 days or be in at least HOT SHUTDOWN within the next 12 hours.
- b. With the number of OPERABLE remote shutdown system controls less than required by Table 3.3.7.4-2, restore the inoperable control(s) to OPERABLE status within 7 days or be in at least HOT SHUTDOWN within the next 12 hours.
- c. The provisions of Specification 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

4.3.7.4.1 Each of the above required remote shutdown monitoring instrumentation channels shall be demonstrated OPERABLE by performance of the CHANNEL CHECK and CHANNEL CALIBRATION operations at the frequencies shown in Table 4.3.7.4-1.#

4.3.7.4.2 Each of the above required remote shutdown system control circuits shall be demonstrated OPERABLE by verifying, at least once per 18 months, its capability to perform its intended function(s).

---

#Channel Calibration may be extended as identified by note 'a' on Table 4.3.7.4-1.

TABLE 3.3.7.4-2 (Continued)

## REMOTE SHUTDOWN SYSTEM CONTROLS

	MINIMUM CHANNELS OPERABLE	
	RSP1	RSP2
22. RHR Shutdown Cooling MOV (1E12*MOVFO06A, 6B)	2 <sup>(a)</sup>	NA
23. RHR Outboard Shutdown Isolation MOV (1E12*MOVFO08)	1	NA
24. RHR Inboard Shutdown Isolation MOV (1E12*MOVFO09)	1	NA
25. RHR Hx Flow to Suppression Pool MOV (1E12*MOVFO11A, B)	1	1
26. RHR Reactor Head Spray MOV (1E12*MOVFO23)	1	NA
27. RHR Test Line MOV (1E12*MOVFO24A, B)	1	1
28. Deleted		
29. RHR Injection Shutoff MOV (1E12*MOVFO27A, B)	1	1
30. RHR Upper Pool Cooling Shutoff MOV (1E12*MOVFO37A, B)	1	1
31. RHR Injection MOV (1E12*MOVFO42A, B, C)	1	2 <sup>(a)</sup>
32. RHR Hx Shell Side Inlet MOV (1E12*MOVFO47A, B)	1	1
33. RHR Hx Shell Side Bypass MOV (1E12*MOVFO48A, B)	1	1
34. RHR Discharge to Radwaste MOV (1E12*MOVFO40)	1	NA
35. Deleted		
36. RHR Injection MOV (1E12*MOVFO53A, B)	1	1
37. RHR Pump Minimum Flow MOV (1E12*MOVFO64A, B, C)	1	2 <sup>(a)</sup>
38. RHR Hx Water Discharge MOV (1E12*MOVFO68A, B)	1	1
39. Safety Relief Valves (1B21*RVF051C, G, D)	3 <sup>(a)</sup>	3 <sup>(a)</sup>
40. SSW Pump (1SWP*P2A, 2C, <sup>(b)</sup> 2B, 2D)	1	2 <sup>(a)</sup>
41. Normal Service Water Isolation MOV (1SWP*MOV96A, B)	1	1
42. SSW Cooling Tower Inlet MOV (1SWP*MOV55A, B)	1	1
43. SSW Component Cooling Water Inlet MOV (1SWP*MOV510A, B)	1	1
44. SSW Component Cooling Water Outlet MOV (1SWP*MOV504A, B)	1	1

(a) One per control equipment.

(b) SSW pump 1SWP\*P2C is provided on panel 1EGS\*PNL4C.

TABLE 4.3.7.4-1

REMOTE SHUTDOWN MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>
1. Reactor Vessel Pressure	M	R (a)
2. Reactor Vessel Water Level	M	R (a)
3. Safety/Relief Valve Demand Position	M	NA
4. Suppression Pool Water Level	M	R
5. Suppression Pool Water Temperature	M	R
6. Drywell Pressure	M	R
7. Drywell Temperature	M	R
8. RHR System Flow: Loop A	M	R
Loop B	M	R
Loop C	M	R
9. RHR Hx Cooling Water System Flow: Loop A	M	R
Loop B	M	R
10. RCIC System Flow	M	R
11. RCIC Turbine Speed	M	R

(a) May be extended to be performed during the fifth refueling outage scheduled to begin April 16, 1994.

## INSTRUMENTATION

### ACCIDENT MONITORING INSTRUMENTATION

#### LIMITING CONDITION FOR OPERATION

---

3.3.7.5 The accident monitoring instrumentation channels shown in Table 3.3.7.5-1 shall be OPERABLE.

APPLICABILITY: As shown in Table 3.3.7.5-1.

#### ACTION:

With one or more accident monitoring instrumentation channels inoperable, take the ACTION required by Table 3.3.7.5-1.

#### SURVEILLANCE REQUIREMENTS

---

4.3.7.5 Each of the above required accident monitoring instrumentation channels shall be demonstrated OPERABLE by performance of the CHANNEL CHECK and CHANNEL CALIBRATION operations at the frequencies shown in Table 4.3.7.5-1.#

---

#Channel Calibration period may be extended as identified by note (a) on Table 4.3.7.5-1.

TABLE 3.3.7.5-1

ACCIDENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>REQUIRED NUMBER OF CHANNELS</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE OPERABLE CONDITIONS</u>	<u>ACTION</u>
1. Reactor Vessel Pressure	2	1	1,2,3	80
2. Reactor Vessel Water Level				
a. Wide Range	2	1	1,2,3	80
b. Fuel Zone	2	1	1,2,3	80
3. Suppression Pool Water Level	2	1	1,2,3	80
4. Suppression Pool Water Temperature	2/sector	1/sector	1,2,3	80
5. Primary Containment Pressure	2	1	1,2,3	80
6. Drywell Pressure	2	1	1,2,3	80
7. Drywell Air Temperature	2	1	1,2,3	80
8. Drywell and Primary Containment Hydrogen Concentration Analyzer and Monitor	2	1	1,2,3	80
9. Area Radiation <sup>#</sup>				
a. Primary Containment Area	2	1	1,2,3	81
b. Drywell Area	2	1	1,2,3	81

<sup>#</sup>High range gross gamma monitors.

Table 3.3.7.5-1 (Continued)

ACCIDENT MONITORING INSTRUMENTATIONS

ACTION STATEMENTS

- ACTION 80 -
- a. With the number of OPERABLE accident monitoring instrumentation channels less than the Required Number of Channels shown in Table 3.3.7.5-1, restore the inoperable channel(s) to OPERABLE status within 7 days or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
  - b. With the number of OPERABLE accident monitoring instrumentation channels less than the Minimum Channels OPERABLE requirements of Table 3.3.7.5-1, restore the inoperable channel(s) to OPERABLE status within 48 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- ACTION 81 -
- With the number of OPERABLE Channels less than required by the Minimum Channels OPERABLE requirement, either restore the inoperable Channel(s) to OPERABLE status within 72 hours, or:
- a. Initiate the preplanned alternate method of monitoring the appropriate parameter(s), and
  - b. Prepare and submit, within 14 days following the event, a Special Report to the Commission, pursuant to Specification 6.9.2, outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the system to OPERABLE status.

TABLE 4.3.7.5-1

## ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

INSTRUMENT	CHANNEL CHECK	CHANNEL CALIBRATION	APPLICABLE OPERATIONAL CONDITIONS
1. Reactor Vessel Pressure	M	R <sup>(a)</sup>	1, 2, 3
2. Reactor Vessel Water Level			
a. Wide Range	M	R	1, 2, 3
b. Fuel Zone	M	R	1, 2, 3
3. Suppression Pool Water Level	M	R	1, 2, 3
4. Suppression Pool Water Temperature	M	R	1, 2, 3
5. Primary Containment Pressure	M	R	1, 2, 3
6. Drywell Pressure	M	R	1, 2, 3
7. Drywell Air Temperature	M	R	1, 2, 3
8. Drywell and Primary Containment Hydrogen Concentration Analyzer and Monitor	M	Q*	1, 2, 3
9. Area Radiation <sup>#</sup>			
a. Primary Containment Area	M	R**	1, 2, 3
b. Drywell Area	M	R** (a)	1, 2, 3

\*Using sample gas containing:

- One volume percent hydrogen, balance nitrogen.
- Four volume percent hydrogen, balance nitrogen.

\*\*The CHANNEL CALIBRATION shall consist of an electronic calibration of the channel, not including the detector, for range decades above 10 R/hr and a one point calibration check of the detector below 10 R/hr with an installed or portable gamma source.

<sup>#</sup>High range gross gamma monitors.

(a)May be extended to be performed during the fifth refueling outage scheduled to begin April 16, 1994.



## INSTRUMENTATION

### 3/4.3.9 PLANT SYSTEMS ACTUATION INSTRUMENTATION

#### LIMITING CONDITION FOR OPERATION

---

3.3.9 The plant systems actuation instrumentation channels shown in Table 3.3.9-1 shall be OPERABLE with their trip setpoints set consistent with the values shown in the Trip Setpoint column of Table 3.3.9-2.

APPLICABILITY: As shown in Table 3.3.9-1.

#### ACTION:

- a. With a plant system actuation instrumentation channel trip setpoint less conservative than the value shown in the Allowable Values column of Table 3.3.9-2, declare the channel inoperable and take the ACTION required by Table 3.3.9-1.
- b. With one or more plant systems actuation instrumentation channels inoperable, take the ACTION required by Table 3.3.9-1.

#### SURVEILLANCE REQUIREMENTS

---

4.3.9.1 Each plant system actuation instrumentation channel shall be demonstrated OPERABLE by the performance of the CHANNEL CHECK, CHANNEL FUNCTIONAL TEST and CHANNEL CALIBRATION operations for the OPERATIONAL CONDITIONS and at the frequencies shown in Table 4.3.9.1-1. #

4.3.9.2 LOGIC SYSTEM FUNCTIONAL TESTS and simulated automatic operation of all channels shall be performed at least once per 18 months. #

---

#Channel Calibration and Logic System Functional test period may be extended as identified by note (b) on Table 4.3.9.1-1.

TABLE 3.3.9-1

PLANT SYSTEMS ACTUATION INSTRUMENTATION

<u>TRIP FUNCTION</u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM</u>	<u>APPLICABLE OPERATIONAL CONDITIONS</u>	<u>ACTION</u>
1. <u>PRIMARY CONTAINMENT VENTILATION SYSTEM - UNIT COOLER A AND B</u>			
a. Drywell Pressure-High	2	1, 2, 3	150
b. Containment-To-Annulus $\Delta P$ High	3	1, 2, 3	151
c. Reactor Vessel Water Level-Low Low Low Level 1	2	1, 2, 3	150
d. Timers	1	1, 2, 3	152
2. <u>FEEDWATER SYSTEM/MAIN TURBINE TRIP SYSTEM</u>			
a. Reactor Vessel Water Level-High Level 8	3	1	153

TABLE 4.3.9.1-1

PLANT SYSTEMS ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS IN WHICH SURVEILLANCE REQUIRED</u>
1. <u>PRIMARY CONTAINMENT VENTILATION SYSTEM - UNIT COOLER A AND B</u>				
a. Drywell Pressure-High	D	M	R <sup>(a)#</sup>	1, 2, 3
b. Containment-to-Annulus $\Delta P$ -High	D	M	R <sup>(a)</sup>	1, 2, 3
c. Reactor Vessel Water Level-Low Low Low Level 1	D	M	R <sup>(a)#</sup>	1, 2, 3
d. Timer	NA	M	R	1, 2, 3
2. <u>FEEDWATER SYSTEM/MAIN TURBINE TRIP SYSTEM</u>				
a. Reactor Vessel Water Level-High Level 8	D	M	R <sup>(b)</sup>	1

(a) Calibrate trip unit setpoint once per 31 days.

(b) May be performed during the fifth refueling outage scheduled to begin April 16, 1994.

# The specified 18 month interval during the first operation cycle may be extended to coincide with completion of the first refueling outage, scheduled to begin 9-15-87.

TABLE 3.6.4-1 (Continued)

CONTAINMENT AND DRYWELL ISOLATION VALVES

<u>SYSTEM</u>	<u>VALVE NUMBER</u>	<u>PENETRATION NUMBER</u>	<u>VALVE GROUP</u> <sup>(1)</sup>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>	<u>SECONDARY CONTAINMENT BYPASS PATH (Yes/No)</u>
a. <u>Automatic Isolation Valves</u>					
1. <u>Primary Containment</u> <sup>(a)</sup> (Continued)					
RWCU Disch. to Condenser#	1G33*MOV028	1KJB*Z4	15	20.9	Yes <sup>(f)</sup>
RWCU Return to FW#	1G33*MOV040	1KJB*Z6	15	24.2	No
RWCU Pump Suction#	1G33*MOV001 <sup>(b)</sup>	1KJB*Z7	16	19.8	No
RWCU Pump Disch. #	1G33*MOV053	1KJB*Z129	15	5.5	No
RWCU Disch. to Condenser#	1G33*MOV034	1KJB*Z4	15	20.9	Yes <sup>(f)</sup>
RWCU Return to FW#	1G33*MOV039	1KJB*Z6	15	24.2	No
RWCU Pump Suction#	1G33*MOV004	1KJB*Z7	7	6.6	No
RWCU Pump Disch. #	1G33*MOV054	1KJB*Z129	15	5.5	No
RWCU Backwash Disch. #	1WCS*MOV178	1KJB*Z5	1	12.1	Yes <sup>(f)</sup>
RWCU Backwash Disch. #	1WCS*MOV172	1KJB*Z5	1	12.6	Yes <sup>(f)</sup>
HPCS Test Return-Supp. Pool	1E22*MOV023(j)	1KJB*Z11	1	50	No
RHR A Return-Supp. Pool	1E12*MOV024A(j)	1KJB*Z24A	10	63.8	No
RHR A Hx Dump-Supp. Pool	1E12*MOV011A(j)	1KJB*Z24A	10	34.1	No
LPCS Test Return-Supp. Pool	1E21*MOV012(j)	1KJB*Z24A	10	57.2	No
RHR B Return-Supp. Pool	1E12*MOV024B(j)	1KJB*Z24B	10	63.8	No
RHR B Hx Dump-Supp. Pool	1E12*MOV011B(j)	1KJB*Z24B	10	30.8	No
RHR C Return-Supp. Pool	1E12*MOV021(j)	1KJB*Z24C	10	97.9	No
Fuel Pool C&C Disch.	1SFC*MOV119	1KJB*Z26	1	68	No
Fuel Pool C&C Suction	1SFC*MOV120	1KJB*Z27	1	62.7	No
Fuel Pool C&C Suction	1SFC*MOV122	1KJB*Z27	1	63.8	No
Fuel Pool Purif. Suction	1SFC*MOV139	1KJB*Z28	1	39.6	No
Fuel Pool Purif. Suction	1SFC*MOV121	1KJB*Z28	1	39.6	No

RIVER BEND - UNIT 1

3/4 6-33

Amendment No. 1, 72

TABLE 3.6.4-1 (Continued)

CONTAINMENT AND DRYWELL ISOLATION VALVES

<u>SYSTEM</u>	<u>VALVE NUMBER</u>	<u>PENETRATION NUMBER</u>	<u>VALVE GROUP</u> <sup>(1)</sup>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>	<u>SECONDARY CONTAINMENT BYPASS PATH (Yes/No)</u>
a. <u>Automatic Isolation Valves</u>					
1. <u>Primary Containment</u> <sup>(a)</sup> (Continued)					
Floor Drain Disch.	1DFR*AOV102(b)	1KJB*Z35, 1DRB*Z36	1	N/A	No
Floor Drain Disch.	1DFR*AOV101 <sup>(b)</sup>	1KJB*Z35, 1DRB*Z36	1	N/A	No
Equip. Drain Disch.	1DER*AOV127 <sup>(b)</sup>	1KJB*Z38, 1DRB*Z39	1	N/A	No
Equip. Drain Disch.	1DER*AOV126 <sup>(b)</sup>	1KJB*Z38, 1DRB*Z39	1	N/A	No
Fire Protection Hdr.	1FPW*MOV121	1KJB*Z41	1	34.1	Yes <sup>(f)</sup>
Service Air Supply	1SAS*MOV102	1KJB*Z44	1	22.0	Yes <sup>(f)</sup>
Instr. Air Supply	1IAS*MOV106	1KJB*Z46	1	18.7	Yes <sup>(f)</sup>
RPCCW Supply	1CCP*MOV138	1KJB*Z48	1	22.0	No
RPCCW Return	1CCP*MOV158	1KJB*Z49	1	23.1	No
RPCCW Return	1CCP*MOV159	1KJB*Z49	1	24.2	No
Service Water Return	1SWP*MOV5A	1KJB*Z53A	1	50.6	No
Service Water Return	1SWP*MOV5B	1KJB*Z53B	1	53.9	No
Vent. Chilled Water Rtn.	1HVN*MOV102	1KJB*Z131	1	31.9	Yes <sup>(f)</sup>
Vent. Chilled Water Rtn.	1HVN*MOV128	1KJB*Z131	1	28.6	Yes <sup>(f)</sup>
Vent. Chilled Water Sup.	1HVN*MOV127	1KJB*Z132	1	27.5	Yes <sup>(f)</sup>
Condensate Makeup Supply	1CNS*MOV125	1KJB*Z134	1	22.0	Yes <sup>(f)</sup>

TABLE 3.6.4-1 (Continued)

CONTAINMENT AND DRYWELL ISOLATION VALVES

<u>SYSTEM</u>	<u>VALVE NUMBER</u>	<u>PENETRATION NUMBER</u>	<u>VALVE GROUP</u> <sup>(1)</sup>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>	<u>SECONDARY CONTAINMENT BYPASS PATH (Yes/No)</u>
a. <u>Automatic Isolation Valves</u>					
1. <u>Primary Containment</u> <sup>(a)</sup> (Continued)					
RHR & RCIC Steam Sup.	1E51*MOVFO63 <sup>(b)</sup>	1KJB*Z15	2	9.9	No
RHR & RCIC Steam Sup.	1E51*MOVFO76 <sup>(b)(m)</sup>	1KJB*Z15	2	13.4	No
RHR & RCIC Steam Sup.	1E51*MOVFO64	1KJB*Z15	2	9.9	No
RCIC Pump Suc.-Supp. Pool	1E51*MOVFO31 <sup>(j)</sup>	1KJB*Z16	2	30.5	No
RCIC Turbine Exh.-Supp. Pool	1E51*MOVFO77	1KJB*Z17	3	14.2	No
RCIC Turbine Exh. Vac. Bkrs.	1E51*MOVFO78	1KJB*Z18B,C	3	16.5	No
Cont./Drywell Purge Sup.	1HVR*AOV165	1KJB*Z31	8	3	No
Cont./Drywell Purge Sup.	1HVR*AOV123	1KJB*Z31	8	3	No
Cont./Drywell Purge Outlet	1HVR*AOV128	1KJB*Z33	8	3	No
Cont./Drywell Purge Outlet	1HVR*AOV166	1KJB*Z33	8	3	No
Post-Accident Samp. Sup.	1SSR*SOV130	1KJB*Z601B	10	3	No
Post-Accident Samp. Sup.	1SSR*SOV131	1KJB*Z601B	10	3	No

RIVER BEND - UNIT 1

3/4 6-35

Amendment No. 2, 9, 72

TABLE 3.6.4-1 (Continued)

CONTAINMENT AND DRYWELL ISOLATION VALVES

<u>SYSTEM</u>	<u>VALVE NUMBER</u>	<u>PENETRATION NUMBER</u>	<u>VALVE GROUP</u> <sup>(1)</sup>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>	<u>SECONDARY CONTAINMENT BYPASS PATH (Yes/No)</u>
a. <u>Automatic Isolation Valves</u>					
2. <u>Drywell</u> <sup>(k)</sup>					
Cont./Drywell Purge Sup.	1HVR*AOV147	1DRB*Z32	1	3	No
RPCCW Supply	1CCP*MOV142	1DRB*Z50	1	30	No
RPCCW Return	1CCP*MOV144	1DRB*Z51	1	30	No
RPCCW Return	1CCP*MOV143	1DRB*Z51	1	30	No
Service Water Supply	1SWP*MOV4A	1DRB*Z54	1	52.8	No
Service Water Supply	1SWP*MOV4B	1DRB*Z54	1	51.7	No
Service Water Return	1SWP*MOV5A	1DRB*Z55	1	50.6	No
Service Water Return	1SWP*MOV5B	1DRB*Z55	1	53.9	No
Recirc. Flow Control	1RCS*MOV58A	1DRB*Z152	1	11.0	No
Recirc. Flow Control	1RCS*MOV59A	1DRB*Z153	1	10.6	No
Recirc. Flow Control	1RCS*MOV60A	1DRB*Z154	1	6.3	No
Recirc. Flow Control	1RCS*MOV61A	1DRB*Z155	1	8.6	No
Recirc. Flow Control	1RCS*MOV58B	1DRB*Z156	1	10.6	No
Recirc. Flow Control	1RCS*MOV59B	1DRB*Z157	1	10.8	No
Recirc. Flow Control	1RCS*MOV60B	1DRB*Z158	1	6.38	No
Recirc. Flow Control	1RCS*MOV61B	1DRB*Z159	1	8.9	No
Cont./Drywell Purge Sup.	1HVR*AOV125	1DRB*Z32	1	3	No
Cont./Drywell Purge Rtn.	1HVR*AOV126	1DRB*Z34	1	3	No
Cont./Drywell Purge Rtn.	1HVR*AOV148	1DRB*Z34	1	3	No

TABLE 3.6.4-1 (Continued)

CONTAINMENT AND DRYWELL ISOLATION VALVES

<u>SYSTEM</u>	<u>VALVE NUMBER</u>	<u>PENETRATION NUMBER</u>	<u>VALVE GROUP</u> <sup>(1)</sup>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>	<u>SECONDARY CONTAINMENT BYPASS PATH (Yes/No)</u>
a. <u>Automatic Isolation Valves</u>					
2. <u>Drywell</u> <sup>(k)</sup> (Continued)					
Hydrogen Mixing Line Inlet	1CPM*MOV2A	1DRB*Z57A	10	33	No
Hydrogen Mixing Line Inlet	1CPM*MOV4A	1DRB*Z57A	10	33	No
Hydrogen Mixing Line Inlet	1CPM*MOV2B	1DRB*Z57B	10	33	No
Hydrogen Mixing Line Inlet	1CPM*MOV4B	1DRB*Z57B	10	33	No
Hydrogen Mixing Line Exhaust	1CPM*MOV3A	1DRB*Z58A	10	33	No
Hydrogen Mixing Line Exhaust	1CPM*MOV1A	1DRB*Z58A	10	33	No
Hydrogen Mixing Line Exhaust	1CPM*MOV3B	1DRB*Z58B	10	33	No
Hydrogen Mixing Line	1CPM*MOV1B	1DRB*Z58B	10	33	No
Reactor Plant Sampling	1B33*A0VF019	1DRB*Z449	9	5	No
Reactor Plant Sampling	1B33*A0VF020	1DRB*Z449	9	5	No



TABLE 3.6.4-1 (Continued)

CONTAINMENT AND DRYWELL ISOLATION VALVES

<u>SYSTEM</u>	<u>VALVE NUMBER</u>	<u>PENETRATION NUMBER</u>	<u>SECONDARY CONTAINMENT BYPASS PATH (Yes/No)</u>
b. <u>Manual Isolation Valves</u>			
1. <u>Primary Containment</u> <sup>(a)</sup>			
LPCI A to Reactor	1E12*F099A	1KJB*Z21A	No
LPCI B to Reactor	1E12*F099B	1KJB*Z21B	No
Reactor Plant Vent. ΔP Trans.	1HVR*V8 <sup>(k)</sup>	1KJB*Z602A	No
Reactor Plant Vent. ΔP Trans.	1HVR*V10 <sup>(k)</sup>	1KJB*Z602B	No
PVLCS Pressure Transmitter	1LSV*V64 <sup>(k)</sup>	1KJB*Z602D	No
Reactor Plant Vent. ΔP Trans.	1HVR*V12 <sup>(k)</sup>	1KJB*Z602F	No
Cont. Leakage Monitor Press.	1LMS*V14	1KJB*Z603A	No
Cont. Leakage Monitor Press.	1LMS*V12	1KJB*Z603A	No
Cont. Leakage Monitor Press.	1LMS*V7	1KJB*Z603C	No
Cont. Leakage Monitor Press.	1LMS*V16 <sup>(k)</sup>	1KJB*Z603C	No
Cont. Monitor Press. Sensing	1CMS*V2 <sup>(k)</sup>	1KJB*Z605A	No
Cont. Monitor Press. Sensing	1CMS*V3 <sup>(k)</sup>	1KJB*Z605B	No
Reactor Plant Vent. ΔP Trans.	1HVR*V14 <sup>(k)</sup>	1KJB*Z606A	No
Reactor Plant Vent. ΔP Trans.	1HVR*V16 <sup>(k)</sup>	1KJB*Z606B	No
Cont. Monitor Press. Sensing	1CMS*V16 <sup>(k)</sup>	1KJB*Z606C	No
Cont. Monitor Press. Sensing	1CMS*V15 <sup>(k)</sup>	1KJB*Z606D	No
PVLCS Pressure Transmitter	1LSV*V65 <sup>(k)</sup>	1KJB*Z606E	No
Reactor Plant Vent. ΔP Trans.	1HVR*V18 <sup>(k)</sup>	1KJB*Z606F	No
LPCI A to Reactor	1E12*VF044A	1KJB*Z21A	No
LPCI B to Reactor	1E12*VF044B	1KJB*Z21B	No
SW Rtn Vacuum Release	1SWP*SOV522A <sup>(e)</sup>	1KJB*Z53A	No
SW Rtn Vacuum Release	1SWP*SOV522B <sup>(e)</sup>	1KJB*Z53B	No
SW Rtn Vacuum Release	1SWP*SOV522C <sup>(e)</sup>	1KJB*Z53A	No
SW Rtn Vacuum Release	1SWP*SOV522D <sup>(e)</sup>	1KJB*Z53B	No

TABLE 3.6.4-1 (Continued)

CONTAINMENT AND DRYWELL ISOLATION VALVES

NOTES

- (a) Subject to a Type C leak rate test at a test pressure of 7.6 psig except as otherwise noted.
- (b) Also isolates the drywell.
- (c) Testable check valve.
- (d) Isolates on MS-PLCS air line high flow or MS-PLCS air line header to Main Steam Line low differential pressure.
- (e) Receives a remote manual isolation signal.
- (f) This line is sealed by the penetration valve leakage control system (PVLCS). The combined leakage from valves sealed by the PVLCS is not included in 0.60 La Type B and C test total.
- (g) This valve sealed by the main steam positive leakage control system (MS-PLCS). Valves sealed by the MS-PLCS are tested in accordance with Surveillance Requirement 4.6.1.3.f to verify that leakage does not exceed the limit specified in Specification 3.6.1.3.c. This leakage is not included in the 0.60 La Type B and C test total.
- (h) Not subject to Type C leakage tests. Valve(s) will be included in the Type A test.
- (j) Valve is hydrostatically leak tested at a test pressure of 8.36 psig (1.1 Pa). The leakage from hydrostatically tested valves is not included in the 0.60 La Type B and C test total.
- (k) Not subject to a Type A, B, or C leak rate test.
- (l) Valve groups listed are designated in Table 3.3.2-1.
- (m) Value 1E51\*MOVFO76 is not required to be OPERABLE through October 4, 1986.

#The specified 18 month automatic isolation valve actuation may be performed during the fifth refueling outage scheduled to begin April 16, 1994.

## CONTAINMENT SYSTEMS

### 3/4.6.5 SECONDARY CONTAINMENT

#### SECONDARY CONTAINMENT INTEGRITY - OPERATING

##### LIMITING CONDITION FOR OPERATION

---

3.6.5.1 SECONDARY CONTAINMENT INTEGRITY - OPERATING shall be maintained.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2, and 3.

ACTION:

Without SECONDARY CONTAINMENT INTEGRITY - OPERATING restore SECONDARY CONTAINMENT INTEGRITY - OPERATING within 4 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

##### SURVEILLANCE REQUIREMENTS

---

4.6.5.1 SECONDARY CONTAINMENT INTEGRITY - OPERATING shall be demonstrated by:

- a. Verifying at least once per 24 hours that the pressures within the Shield Building annulus, the Auxiliary Building and the Fuel Building are less than or equal to 3.0, 0.00, and 0.00 inches of vacuum water gauge, respectively.
- b. Verifying at least once per 31 days that:
  1. All secondary containment equipment hatch covers are installed.
  2. The door in each access to the secondary containment is closed, except during normal entry and exit.
  3. All secondary containment penetrations not capable of being closed by OPERABLE secondary containment automatic isolation dampers and required to be closed during accident conditions are closed by valves, blind flanges, or deactivated automatic dampers/valves secured in position.

## ELECTRICAL POWER SYSTEMS

### SURVEILLANCE REQUIREMENTS (Continued)

- b. At least once per 92 days, and within 7 days after a battery discharge with battery terminal voltage below 110 volts or after a battery overcharge with battery terminal voltage above 144 volts, by verifying that:
1. The parameters in Table 4.8.2.1-1 meet the Category B limits,
  2. There is no visible corrosion at either terminals or connectors, or the connection resistance of these items is less than  $150 \times 10^{-6}$  ohms, and
  3. The average electrolyte temperature of at least one out of six connected cells is above 60°F.
- c. At least once per 18 months# by verifying that:
1. The cells, cell plates and battery racks show no visual indication of physical damage or abnormal deterioration,
  2. The cell-to-cell and terminal connections are clean, tight, free of corrosion and coated with anti-corrosion material,
  3. The resistance of each cell-to-cell and terminal connection is less than or equal to  $150 \times 10^{-6}$  ohms and
  4. The battery charger will supply at least 300 amperes for chargers 1A and 1B and 50 amperes for charger 1C at a minimum of 130.2 volts for at least 8 hours.
- d. At least once per 18 months#, during shutdown, by verifying that either:
1. The battery capacity is adequate to supply and maintain in OPERABLE status all of the actual emergency loads for the design duty cycle when the battery is subjected to a battery service test, or
  2. The battery capacity is adequate to supply a dummy load of the following profile in accordance with IEEE 450 while maintaining the battery terminal voltage greater than or equal to 105 volts.
    - a) Division I
      - ≥ 671 amperes for the first 60 seconds
      - ≥ 270 amperes for the next 9 minutes
      - ≥ 336 amperes for the next 60 seconds
      - ≥ 270 amperes for the next 228 minutes
      - ≥ 451 amperes for the last 60 seconds

#May be extended to the completion of the fifth refueling outage scheduled to begin April 16, 1994.

ELECTRICAL POWER SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

---

- b) Division II
  - ≥ 502 amperes for the first 60 seconds
  - ≥ 261 amperes for the next 9 minutes
  - ≥ 327 amperes for the next 60 seconds
  - ≥ 261 amperes for the next 228 minutes
  - ≥ 327 amperes for the last 60 seconds
  
- c) Division III
  - ≥ 53.2 amperes for the first 60 seconds
  - ≥ 15.4 amperes for the next 119 minutes
  
- e. At least once per 60 months## by verifying during shutdown that the battery capacity is at least 80% of the manufacturer's rating when subjected to a performance discharge test. Once per 60 month interval, this performance discharge test may be performed in lieu of the battery service test.
  
- f. At least once per 18 months, during shutdown, performance discharge tests of battery capacity shall be given to any battery that shows signs of degradation or has reached 85% of the service life expected for the application. Degradation is indicated when the battery capacity drops more than 10% of rated capacity from its average on previous performance tests, or is below 90% of the manufacturer's rating.

---

##For Division III, may be extended to the completion of the fifth refueling outage scheduled to begin April 16, 1994.

TABLE 4.8.2.1-1

BATTERY SURVEILLANCE REQUIREMENTS

Parameter	CATEGORY A <sup>(1)</sup>		CATEGORY B <sup>(2)</sup>	
	Limits for each designated pilot cell	Limits for each connected cell	Limits for each connected cell	Allowable <sup>(3)</sup> value for each connected cell
Electrolyte Level	>Minimum level indication mark and $\leq \frac{1}{8}$ " above maximum level indication mark	>Minimum level indication mark and $\leq \frac{1}{8}$ " above maximum level indication mark	>Minimum level indication mark and $\leq \frac{1}{8}$ " above maximum level indication mark	Above top of plates and not overflowing
Float Voltage	$\geq 2.13$ volts	$\geq 2.13$ volts <sup>(c)</sup>	$\geq 2.13$ volts <sup>(c)</sup>	$\geq 2.07$ volts
Specific Gravity <sup>(a)</sup>	$\geq 1.200$ <sup>(b)</sup> (Div. I&II) $\geq 1.195$ <sup>(b)</sup> (Div. III)	$\geq 1.195$ (Div. I&II) $\geq 1.190$ (Div. III)	Average of all connected cells $\geq 1.205$ (Div. I&II) $\geq 1.200$ (Div. III)	Not more than .020 below the average of all connected cells Average of all connected cells $\geq 1.195$ <sup>(b)</sup> (Div. I&II) $\geq 1.190$ <sup>(b)</sup> (Div. III)

- (a) Corrected for electrolyte temperature and level.
- (b) Or battery charging current is less than 2 amperes when on float charge.
- (c) May be corrected for average electrolyte temperature.
- (1) For Category A parameters outside the limits shown, the battery may be considered OPERABLE provided that within 24 hours all the Category B measurements are taken and found to be within their allowable values, and provided all Category A and B parameters are restored to within limits within the next 6 days.
- (2) For Category B parameters outside the limits shown, the battery may be considered OPERABLE provided that the Category B parameters are within their allowable values and provided the Category B parameters are restored to within limits within 7 days.
- (3) Any Category B parameter not within its allowable value indicates an inoperable battery.

## ELECTRICAL POWER SYSTEMS

### D.C. SOURCES - SHUTDOWN

#### LIMITING CONDITION FOR OPERATION

---

3.8.2.2 As a minimum, division I or division II and, when the HPCS system is required to be OPERABLE, division III, of the D.C. electrical power sources shall be OPERABLE with:

- a. Division I consisting of:
  1. 125 volt battery 1A.
  2. 125 volt full capacity Class 1E source charger.
- b. Division II consisting of:
  1. 125 volt battery 1B.
  2. 125 volt full capacity Class 1E source charger.
- c. Division III consisting of:
  1. 125 volt battery 1C.
  2. 125 volt full capacity Class 1E source charger.

APPLICABILITY: OPERATIONAL CONDITIONS 4, 5 and \*.

#### ACTION:

- a. With less than the division I and/or division II battery and/or charger of the above required D.C. electrical power sources OPERABLE, suspend CORE ALTERATIONS, handling of irradiated fuel in the primary containment or Fuel Building, and operations with a potential for draining the reactor vessel.
- b. With division III battery and/or charger of the above required D.C. electrical power sources inoperable, declare the HPCS system and the C SSW pump inoperable and take the ACTION required by Specifications 3.5.2, 3.5.3 and 3.7.1.1.
- c. The provisions of Specification 3.0.3 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

4.8.2.2 At least the above required battery and charger shall be demonstrated OPERABLE per Surveillance Requirement 4.8.2.1.#

---

\*When handling irradiated fuel in the primary containment or Fuel Building.

#May be extended as identified by notes '#' and '##' in Surveillance Requirement 4.8.2.1.

## ELECTRICAL POWER SYSTEMS

### REACTOR PROTECTION SYSTEM ELECTRIC POWER MONITORING

#### LIMITING CONDITION FOR OPERATION

3.8.4.3 Two RPS electric power monitoring channels for each in-service RPS MG set or alternate power supply shall be OPERABLE.

APPLICABILITY: At all times.

#### ACTION:

- a. With one RPS electric power monitoring channel for an in-service RPS MG set or alternate power supply inoperable, restore the inoperable power monitoring channel to OPERABLE status within 72 hours or remove the associated RPS MG set or alternate power supply from service.
- b. With both RPS electric power monitoring channels for an in-service RPS MG set or alternate power supply inoperable, restore at least one electric power monitoring channel to OPERABLE status within 30 minutes or remove the associated RPS MG set or alternate power supply from service.

#### SURVEILLANCE REQUIREMENTS

4.8.4.3 The above specified RPS electric power monitoring channels shall be determined OPERABLE:

- a. By performance of a CHANNEL FUNCTIONAL TEST each time the unit is in COLD SHUTDOWN for a period of more than 24 hours, unless performed within the previous six months, and
- b. At least once per 18 months\* by demonstrating the OPERABILITY of over-voltage, under-voltage and under-frequency protective instrumentation by performance of a CHANNEL CALIBRATION including simulated automatic actuation of the protective relays, tripping logic and output circuit breakers and verifying the following setpoints.
  1. Over-voltage  $\leq$  132 VAC, Bus A and B,
  2. Under-voltage  $\geq$  115 VAC, Bus A and B, and
  3. Under-frequency 57 Hz, + 2, - 0%, Bus A and B.

---

\*May be extended to the completion of the fifth refueling outage scheduled to begin April 16, 1994.



## ELECTRICAL POWER SYSTEMS

### A.C. CIRCUITS INSIDE CONTAINMENT

#### LIMITING CONDITION FOR OPERATION

---

3.8.4.4 At least the following A.C. circuits inside containment shall be de-energized\*:

<u>Equipment ID</u>	<u>Location</u>	<u>Device</u>
1MHR*CRN1	1EJS*LDC2A	ACB022
1F42-PNL003	1SCA-PNL8C1	Circuit Breaker 1
1F42-D002H	1SCA-PNL8C1	Circuit Breaker 15
1SFT-PNL106	1SCA-PNL8B2	Circuit Breaker 2
1SFT-PNL106	1SCA-PNL8B2	Circuit Breaker 10
1HVR*UC1AH	1SCV*PNL2A2	Circuit Breaker 5
1HVR*UC1BH	1SCV*PNL2B2	Circuit Breaker 12
1HVR-UC1CH	1SCA-PNL2C1	Circuit Breaker 9
1HVR-FN1AH	1SCA-PNL2A2	Circuit Breaker 3
1HVR-FN1BH	1SCA-PNL2F1	Circuit Breaker 6
1HVR-FN1CH	1SCA-PNL2E1	Circuit Breaker 1
1HVR-FN1DH	1SCA-PNL2B1	Circuit Breaker 6
1DRS-UC1AH	1SCA-PNL2E1	Circuit Breaker 2
1DRS-UC1BH	1SCA-PNL2F1	Circuit Breaker 3
1DRS-UC1CH	1SCA-PNL2E1	Circuit Breaker 2
1DRS-UC1DH	1SCA-PNL2F1	Circuit Breaker 3
1DRS-UC1EH	1SCA-PNL2E1	Circuit Breaker 2
1DRS-UC1FH	1SCA-PNL2F1	Circuit Breaker 3
1WCS-P5AH	1SCA-PNL2E1	Circuit Breaker 4
1WCS-P5BH	1SCA-PNL2F1	Circuit Breaker 2

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2 and 3.

#### ACTION:

With any of the above required circuits energized, trip the associated circuit breaker(s) in the specified location within 1 hour.

#### SURVEILLANCE REQUIREMENTS

---

4.8.4.4 Each of the above required A.C. circuits shall be determined to be de-energized by verifying at least once per 24 hours\*\* that the associated circuit breakers are in the tripped condition.

\*Except during entry into the containment.

\*\*Except at least once per 31 days if locked, sealed or otherwise secured in the tripped condition.