

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

December 10, 1982

Mr. R. C. Hanyes Director, Region 1 U.S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION LICENSEE EVENT REPORT 82-053/03L-0 ER 100450 FILE 841-23 PLA - 1432

Docket No. 50-387 License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 82-053/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.6, in that the "A" Chlorine detector for the control structure heating and ventilation failed to trip during a surveillance test.

H. W. Keiser

Superintendent of Plant-Susquehanna

DGM/jls

cc: A. Schwencer
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

R. Rhoads Resident Inspector U.S. Nuclear Regulatory Commission P.O. Box 52 Shickshinny, PA 18655