



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555-0001

BALTIMORE GAS AND ELECTRIC COMPANY

DOCKET NO. 50-318

CALVERT CLIFFS NUCLEAR POWER PLANT, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 162  
License No. DPR-69


1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Baltimore Gas and Electric Company (the licensee) dated November 1, 1993, as supplemented on February 1, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.2 of Facility Operating License No. DPR-69 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 162, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Capra, Director  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: March 1, 1994

ATTACHMENT TO LICENSE AMENDMENTS

AMENDMENT NO. 162 FACILITY OPERATING LICENSE NO. DPR-69

DOCKET NO. 50-318

Revise Appendix A as follows:

Remove Pages

3/4 4-29  
3/4 4-30  
3/4 4-32  
3/4 4-34  
B3/4 4-6  
B3/4 4-7

Insert Pages

3/4 4-29  
3/4 4-30  
3/4 4-32  
3/4 4-34  
B3/4 4-6  
B3/4 4-7

### 3/4.4 REACTOR COOLANT SYSTEM




FIGURE 3.4.9-1

CALVERT CLIFFS UNIT 2 HEATUP CURVE. for FLUENCE  $< 1.92 \times 10^{19}$  n/cm<sup>2</sup>  
REACTOR COOLANT SYSTEM PRESSURE TEMPERATURE LIMITS

### 3/4.4 REACTOR COOLANT SYSTEM




FIGURE 3.4.9-2

CALVERT CLIFFS UNIT 2 COOLDOWN CURVE, for FLUENCE  $< 1.92 \times 10^{19}$  n/cm<sup>2</sup>  
 REACTOR COOLANT SYSTEM PRESSURE TEMPERATURE LIMITS

### 3/4.4 REACTOR COOLANT SYSTEM

#### 3/4.4.9 PRESSURE/TEMPERATURE LIMITS

##### Overpressure Protection Systems

#### LIMITING CONDITION FOR OPERATION

3.4.9.3 The following overpressure protection requirements shall be met:

- a. One of the following three overpressure protection systems shall be in place:
  1. Two power-operated relief valves (PORVs) with a lift setting of  $\leq 430$  psia, or
  2. A single PORV with a lift setting of  $\leq 430$  psia and a Reactor Coolant System vent of  $\geq 1.3$  square inches, or
  3. A Reactor Coolant System (RCS) vent  $\geq 2.6$  square inches.
- b. Two high pressure safety injection (HPSI) pumps<sup>#</sup> shall be disabled by either removing (racking out) their motor circuit breakers from the electrical power supply circuit, or by locking shut their discharge valves.
- c. The HPSI loop motor operated valves (MOVs)<sup>#</sup> shall be prevented from automatically aligning HPSI pump flow to the RCS by placing their handswitches in pull-to-override.
- d. No more than one **OPERABLE** high pressure safety injection pump with suction aligned to the Refueling Water Tank may be used to inject flow into the RCS and when used, it must be under manual control and one of the following restrictions shall apply:
  1. The total high pressure safety injection flow shall be limited to  $\leq 210$  gpm OR
  2. A Reactor Coolant System vent of  $\geq 2.6$  square inches shall exist.
- e. When not in use, the above **OPERABLE** HPSI pump shall have its handswitch in pull-to-lock.

APPLICABILITY: When the RCS temperature is  $\leq 305^{\circ}\text{F}$  and the RCS is vented to  $< 8$  square inches.

---

<sup>#</sup> Except when required for testing.



### 3/4.4 REACTOR COOLANT SYSTEM

#### LIMITING CONDITION FOR OPERATION (Continued)

---

3. If a pressure limit was exceeded, take action in accordance with Specification 3.4.9.1.
- g. The provisions of Specification 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

4.4.9.3.1 Each PORV shall be demonstrated **OPERABLE** by:

- a. Performance of a **CHANNEL FUNCTIONAL TEST** on the PORV actuation channel, but excluding valve operation, within 31 days prior to entering a condition in which the PORV is required **OPERABLE** and at least once per 31 days thereafter when the PORV is required **OPERABLE**.
- b. Performance of a **CHANNEL CALIBRATION** on the PORV actuation channel at least once per 18 months.
- c. Verifying the PORV isolation valve is open at least once per 72 hours when the PORV is being used for overpressure protection.
- d. Testing in accordance with the inservice test requirements pursuant to Specification 4.0.5.

4.4.9.3.2 The RCS vent(s) shall be verified to be open at least once per 12 hours\* when the vent(s) is being used for overpressure protection.

4.4.9.3.3 All high pressure safety injection pumps, except the above **OPERABLE** pump, shall be demonstrated inoperable at least once per 12 hours by verifying that the motor circuit breakers have been removed from their electrical power supply circuits or by verifying their discharge valves are locked shut. The automatic opening feature of the high pressure safety injection loop MOVs shall be verified disabled at least once per 12 hours. The above **OPERABLE** pump shall be verified to have its handswitch in pull-to-lock at least once per 12 hours.

\*

Except when the vent pathway is locked, sealed, or otherwise secured in the open position, then verify these vent pathways open at least once per 31 days.

### 3/4.4 REACTOR COOLANT SYSTEM

#### BASES

the unit's yearly operating time since the activity levels allowed by Figure 3.4.8-1 increase the 2 hour thyroid dose at the **SITE BOUNDARY** by a factor of up to 20 following a postulated steam generator tube rupture.

Reducing  $T_{avg}$  to  $< 500^{\circ}\text{F}$  prevents the release of activity should a steam generator tube rupture since the saturation pressure of the primary coolant is below the lift pressure of the atmospheric steam relief valves. The surveillance requirements provide adequate assurance that excessive specific activity levels in the primary coolant will be detected in sufficient time to take corrective action. Information obtained on iodine spiking will be used to assess the parameters associated with spiking phenomena. A reduction in frequency of isotopic analyses following power changes may be permissible if justified by the data obtained.

#### 3/4.4.9 PRESSURE/TEMPERATURE LIMITS

All components in the Reactor Coolant System are designed to withstand the effects of cyclic loads due to system temperature and pressure changes. These cyclic loads are introduced by normal load transients, reactor trips, and **STARTUP** and shutdown operation. The various categories of load cycles used for design purposes are provided in Section 4.1.1 of the UFSAR. During **STARTUP** and shutdown, the rates of temperature and pressure changes are limited so that the maximum specified heatup and cooldown rates are consistent with the design assumptions and satisfy the stress limits for cyclic operation.

Operation within the appropriate heatup and cooldown curves assures the integrity of the reactor vessel against fracture induced by combinative thermal and pressure stresses. As the vessel is subjected to increasing fluence, the toughness of the limiting material continues to decline, and even more restrictive Pressure/Temperature limits must be observed. The current limits, Figures 3.4.9-1 and 3.4.9-2, are for up to and including a fluence of  $1.92 \times 10^{19}$  n/cm<sup>2</sup> at the inner surface of the reactor vessel, which corresponds to approximately 13.8 Effective Full Power Years.

The reactor vessel materials have been tested to determine their initial  $RT_{NDT}$ ; the results of these tests are shown in Section 4.1.5 of the UFSAR. Reactor operation and resultant fast neutron ( $E > 1$  Mev) irradiation will cause an increase in the  $RT_{NDT}$ . The actual shift in  $RT_{NDT}$  of the vessel material will be established periodically during operation by removing and evaluating reactor vessel material irradiation surveillance specimens installed near the inside wall of the reactor vessel in the core area. The number of reactor vessel irradiation surveillance specimens and the frequencies for removing and testing these specimens are provided in UFSAR Table 4-13 and are approved by the NRC prior to implementation in compliance with the requirements of 10 CFR Part 50, Appendix H.



### 3/4.4 REACTOR COOLANT SYSTEM

#### BASES

The shift in the material fracture toughness, as represented by  $RT_{NDT}$ , is calculated using Regulatory Guide 1.99, Revision 2. For a fluence of  $1.92 \times 10^{19}$  n/cm<sup>2</sup>, at the 1/4 T position, the adjusted reference temperature (ART) value is less than 171°F. At the 3/4 T position the ART value is 125°F. These values are used with procedures developed in the ASME Boiler and Pressure Vessel Code, Section III, Appendix G to calculate heatup and cooldown limits in accordance with the requirements of 10 CFR Part 50, Appendix G.

To develop composite pressure-temperature limits for the heatup transient, the isothermal, 1/4 T heatup, and 3/4 T heatup pressure-temperature limits are compared for a given thermal rate. Then the most restrictive pressure-temperature limits are combined over the complete temperature interval resulting in a composite limit curve for the reactor vessel beltline for the heatup event.

To develop a composite pressure-temperature limit for the cooldown event, the isothermal pressure-temperature limit must be calculated. The isothermal pressure-temperature limit is then compared to the pressure-temperature limit associated with a cooling rate and the more restrictive allowable pressure-temperature limit is chosen resulting in a composite limit curve for the reactor vessel beltline.

Both 10 CFR Part 50, Appendix G and ASME, Code Appendix G require the development of pressure-temperature limits which are applicable to inservice hydrostatic tests. The minimum temperature for the inservice hydrostatic test pressure can be determined by entering the curve at the test pressure (1.1 times normal operating pressure) and locating the corresponding temperature. This curve is shown for a fluence of  $1.92 \times 10^{19}$  n/cm<sup>2</sup> on Figures 3.4.9-1 and 3.4.9-2.

Similarly, 10 CFR Part 50 specifies that core critical limits be established based on material considerations. This limit is shown on the heatup curve, Figure 3.4.9-1. Note that this limit does not consider the core reactivity safety analyses that actually control the temperature at which the core can be brought critical.

The Lowest Service Temperature is the minimum allowable temperature at pressures above 20% of the pre-operational system hydrostatic test pressure (625 psia). This temperature is defined as equal to the most limiting  $RT_{NDT}$  for the balance of the Reactor Coolant System components plus 100°F, per Article NB 2332 of Section III of the ASME Boiler and Pressure Vessel Code.

The horizontal line between the minimum boltup temperature and the Lowest Service Temperature is defined by the ASME Boiler and Pressure Vessel Code as 20% of the pre-operational hydrostatic test pressure. The change in the line at 150°F on the cooldown curve is due to a cessation of RCP flow induced pressure deviation, since no RCPs are permitted to operate during a cooldown below 150°F.