

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | M | A | P | P | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 14 15 25 26 57 CAT 58

CON'T
0 1 | L | 6 | 0 | 5 | 0 | - | 0 | 2 | 9 | 3 | 7 | 1 | 1 | 1 | 5 | 8 | 2 | 8 | 1 | 2 | 1 | 0 | 8 | 2 | 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On 11/15/82, while conducting a surveillance test for the RCIC System the system
0 3 | isolated due to a high steam line flow. T.S. required actions were taken and an
0 4 | investigation started. The NRC was notified via ENS. This event did not create a
0 5 | threat to the public health and safety.
0 6 |
0 7 |
0 8 |

0 9 | C | E | 11 | E | 12 | F | 13 | I | N | S | T | R | U | 14 | P | 15 | Z | 16
7 8 9 10 11 12 13 18 19 20 21 22 23 24 26 27 28 29 30 31 32
17 | LER/RO REPORT NUMBER | 8 | 2 | 21 22 | - | 23 | 0 | 5 | 5 | 24 26 | / | 0 | 3 | 27 28 29 | L | 30 | - | 31 | 0 | 32
ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPRO-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER
A | 18 | Z | 19 | Z | 20 | Z | 21 | 0 | 0 | 0 | 0 | 22 | N | 23 | N | 24 | N | 25 | W | 2 | 9 | 0 | 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The cause of this event was the failure of a resistor (PN 8270-281) in the power
1 1 | supply to the EGM unit of the Woodward Governor turbine control. The resistor
1 2 | was replaced in-kind, the surveillance test completed and the RCIC returned to
1 3 | service. This is the first known occurrence of this resistor failing in the RCIC
1 4 | System since start-up.

1 5 | E | 28 | 1 | 0 | 0 | 29 | NA | 30 | B | 31 | Surveillance Test | 32
7 8 9 10 12 13 44 45 46 80

1 6 | Z | 33 | Z | 34 | NA | 35 | NA | 36
7 8 9 10 11 44 45 80

1 7 | 0 | 0 | 0 | 37 | Z | 38 | NA | 39
7 8 9 10 11 12 13 80

1 8 | 0 | 0 | 0 | 40 | NA | 41
7 8 9 10 11 12 80

1 9 | Z | 42 | NA | 43
7 8 9 10 80

2 0 | N | 44 | 8212210071 821210 | PDR ADOCK 05000293 | PDR | IA | NRC USE ONLY
7 8 9 10 58 69 80