

POWER AUTHORITY OF THE STATE OF NEW YORK
JAMES A. FITZPATRICK NUCLEAR POWER PLANT

DOCKET NO. 50-333

ATTACHMENT TO LER 82-030/03L-1

PAGE 1 of 1

Surveillance calibration test frequency was increased to once per month from once per three (3) months. From July to December, five increased surveillance tests have been completed satisfactory. Unit will be returned to the normal T.S. surveillance frequency by December 31, 1982. No further corrective action is required.