NRC FORM 366 **U.S. NUCLEAR REGULATORY COMMISSION** .(7.77) LICENSEE EVENT REPORT CONTROL BLOCK: (1)(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION) 0 0 0 0 0 0 -03 0 0 (2)01 CON'T REPORT 811 0 0 0 3 6 6 7 1 1 1 3 8 0 1 2 0 7 8 L (6) 0 5 SOURCE DOCKET NUMBER EVENT DATE REPORT DATE EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) While performing the "HYDROGEN AND OXYGEN ANALYZER FT&C" procedure, the 0 2 "A" Drywell H2 and O2 Analyzer was discovered to be inoperable. This 0 3 event is contrary to item 9 of Tech. Specs. Table 3.3.6.4-1. The 0 4 redundant "B" Drywell H2 and O2 Analyzer was operable. Plant operation 0 5 was placed in a 30-day LCO as required by Tech. Specs. 3.3.6.4, ACTION a., 0 6 The health and safety of the public were not affected by this non-0 7 repetitive event. 80 SYSTEM CODE CAUSE CAUSE COMP VALVE COMPONENT CODE SUBCODE U1(14 A (13) II NI SI RI | E | (12 TI SIE Z (16) I (15 SEQUENTIAL REPORT NO. OCCURRENCE REPORT REVISION EVENT YEAR CODE LER/RO TYPS NO REPORT 0 3 10 L NUMBER EFFECT ON PLANT SHUTDOWN ATTACHMENT COMPONENT ACTION TAKEN FUTURE NPRD-4 PRIME COMP. HOURS (22) FORM SUB SUPPLIER MANUFACTURER 18) Z (19 Z (21 Z (20 0 0 (23) B IN N A (25) D 10 (24) CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) The cause of this event was attributed to component failure, due to a 0 loose connection on the Indicator Power Supply. The loose connection was repaired and the component returned to normal operable status. The "HYDROGEN AND CXYGEN ANALYZER FT&C" procedure was satisfactorily completed. Tech. Specs. was satisfied and the LCO was cleared. 4 80 METHOD OF DISCOVERY FACILITY OTHER STATUS (30) % POWER DISCOVERY DESCRIPTION (32) 0 9 0 1 E (28) B (31) NA Surveillance Procedure 0 10 ACTIVITY CONTENT 80 AMOUNT OF ACTIVITY (35 LOCATION OF RELEASE (36) RELEASED\_OF RELEASE Z (33) Z (34) 6 NA NA 10 11 PERSONNEL EXPOSURES 80 DESCRIPTION (39) TYPE 0 0 0 (37) Z (38) NA PERSONNEL INJURIES 80 DESCRIPTION (41) NUMBER 0 0 0 (40) NA 80 LOSS OF OR DAMAGE TO FACILITY (43) DESCRIPTION Z (42) NA 80 PUBLICITY 8212210452 821207 DESCRIPTION (45 NRC USE ONLY PDR ADOCK 05000366 N (44) NA PDR 69 68. 80 NAME OF PREPARER S. B. Tipps (912) 367-7851 PHONE ..