

LIMERICK GENERATING STATION UNITS 1 & 2  
ENVIRONMENTAL REPORT - OPERATING LICENSE STAGE  
REVISION 8 PAGE CHANGES

The attached pages, tables, and figures are considered part of a controlled copy of the Limerick Generating Station EROL. This material should be incorporated into the EROL by following the instructions below.

REMOVE

INSERT

VOLUME 1

Table 2.1-5  
Table 2.1-8  
Table 2.1-12

Table 2.1-5  
Table 2.1-8  
Table 2.1-12

VOLUME 2

Pages 3.6-5 & -6

Pages 3.6-5 & -6

VOLUME 3

Table 6.1-45 (pg 1)  
Table 6.1-46 (pgs 2 & 5)

Table 6.1-45 (pg 1)  
Table 6.1-46 (pgs 2 & 5)

\*\*\*\*\*  
\*\* Remove from Volume 4 and insert in new volume 5: \*\*  
\*\* Tab 200 thru page E470.14-1 \*\*  
\*\*\*\*\*

VOLUME 5

-----  
-----  
Page E291.6-1  
Page E291.9-1  
Page E310.12-1  
Page E451.6-1

Summary Table of Contents  
(pgs i thru iv)  
Page E290.15-1  
Page E291.6-1 & Figure E291.6-1  
Page E291.9-1  
Page E310.12-1  
Page E451.6-1

---

Sector

N  
NNE  
NE  
ENE  
E  
ESE  
SE  
SSE  
S  
SSW  
SW  
WSW  
W  
WNW  
NW  
NNW

Total

---

## LGS EROL

TABLE 2.1-5

POPULATION DISTRIBUTION 0-10 MILES  
2000  
DISTANCE (MILES)

<u>0-1</u>	<u>1-2</u>	<u>2-3</u>	<u>3-4</u>	<u>4-5</u>	<u>5-10</u>	<u>10-Mile Total</u>
61	740	540	681	999	8,905	11,926
141	263	335	460	194	3,988	5,381
27	95	285	411	397	3,810	5,025
32	91	353	470	230	2,350	3,526
23	144	406	606	480	15,327	16,986
73	167	426	371	419	18,357	19,813
0	533	1,501	5,647	1,578	4,077	13,336
18	490	2,110	5,748	2,384	40,319	51,069
5	621	388	107	536	6,434	8,091
0	732	461	500	355	3,219	5,267
88	296	259	447	423	5,078	6,591
67	326	753	632	1,509	1,782	5,069
65	79	1,590	1,593	2,534	406	6,267
10	108	4,630	15,745	4,726	11,757	36,976
24	477	3,415	8,677	2,033	1,116	15,742
11	762	1,255	1,233	920	7,035	11,216
<hr/>	<hr/>	<hr/>	<hr/>	<hr/>	<hr/>	<hr/>
645	5,924	18,707	43,328	19,717	133,960	222,281

Rev. 8, 12/82

---

<u>SECTOR</u>	<u>0-10</u>	<u>10-20</u>
N	9,334	6,253
NNE	4,211	19,178
NE	3,933	21,396
ENE	2,759	38,121
E	13,294	52,056
ESE	15,505	131,917
SE	10,437	90,554
SSE	32,092	24,552
S	5,084	60,017
SSW	3,310	28,071
SW	4,142	4,060
WSW	3,185	7,472
W	4,690	3,644
WNW	26,001	123,107
NW	15,386	7,797
NNW	<u>9,939</u>	<u>9,816</u>
TOTAL	163,302	628,011

---

LGS EROL

TABLE 2.1-8

POPULATION DISTRIBUTION 10-50 MILES  
(1970)

DISTANCE (MILES)

<u>20-30</u>	<u>30-40</u>	<u>40-50</u>	<u>50-MILE TOTAL</u>
40,245	42,944	27,908	126,684
188,605	170,433	35,189	417,616
14,868	22,233	38,547	100,977
38,625	17,188	28,712	125,405
94,689	164,754	338,592	663,385
724,262	610,275	73,658	1,555,617
1,255,972	566,597	103,147	2,026,707
250,377	25,563	21,282	353,866
29,018	332,241	18,248	444,608
23,849	36,668	45,361	137,259
34,181	9,976	14,319	66,678
19,717	62,299	126,433	219,106
15,006	41,717	70,654	135,711
71,310	18,760	26,015	265,193
16,911	14,553	61,969	116,616
14,500	5,792	34,883	74,930
<u>2,832,135</u>	<u>2,141,993</u>	<u>1,064,917</u>	<u>6,830,358</u>

---

Sector

N  
NNE  
NE  
ENE  
E  
ESE  
SE  
SSE  
S  
SSW  
SW  
WSW  
W  
WNW  
NW  
NNW

Total

---

## LGS EROL

TABLE 2.1-12

POPULATION DISTRIBUTION 10-50 MILES  
2000  
DISTANCE (MILES)

<u>0-10</u>	<u>10-20</u>	<u>20-30</u>	<u>30-40</u>	<u>40-50</u>	<u>50-Mile Total</u>
11,927	6,829	46,286	46,773	25,174	136,989
5,381	25,272	215,644	183,280	37,574	467,151
5,026	32,778	23,802	31,732	52,752	146,090
3,526	52,418	61,837	25,372	39,811	182,964
16,987	66,515	140,102	263,769	476,933	964,306
19,812	168,561	747,667	699,313	105,747	1,741,100
13,336	116,919	1,252,024	724,448	143,256	2,249,983
51,068	38,367	269,704	35,137	29,640	423,916
8,090	95,506	39,132	436,266	24,908	603,902
5,268	44,671	37,951	52,662	68,035	208,587
6,591	6,461	52,976	13,528	20,704	100,260
5,069	11,030	23,711	74,921	152,049	266,780
6,268	3,932	17,805	49,845	79,117	156,967
36,978	132,836	76,946	20,317	26,559	293,636
15,742	8,414	18,249	14,247	51,353	108,005
11,216	10,593	15,770	5,735	29,634	72,949
<hr/>	<hr/>	<hr/>	<hr/>	<hr/>	<hr/>
222,281	821,102	3,039,606	2,677,345	1,363,246	8,123,585

## LGS EROL

that free available chlorine concentration does not exceed 0.5 mg/l. During and following chlorination, grab samples will be taken at the spray pond to monitor the chlorine concentration.

### 3.6.3 HOLDING POND EFFLUENT

A 400,000 gallon concrete-lined holding pond receives all wastewater from the Limerick Generating Station except cooling tower overflow, spray pond overflow, radwaste, sewage, and storm drainage. Holding pond inflows include low volume waste from nonradioactive floor, equipment, and sampling drains, as well as powerblock subdrainage sump pump flows and auxiliary boiler blowdown. The total holding pond inflow is expected to average 70,000 gpd, of which approximately one-half is water treatment facility waste-water from the settling basins, and approximately one-half is from miscellaneous sources. The total maximum holding pond inflow is expected to be 300,000 gpd. Two parallel 750 gpm gravity differential oil separators, located immediately upstream of the holding pond, treat all flows entering the holding pond, except for the floor dainage from the holding pond treatment enclosures, which is routed directly to the holding pond.

#### 3.6.3.1 Water Treatment Facility Wastewater from the Settling Basins

A major low volume waste source draining to the holding pond is the wastewater settling basin effluent. Raw water for the makeup water system is supplied by either the Schuylkill or the Perkiomen pumping stations. The makeup water treatment facility includes a clarification and filtration system, clarified water storage tank, ion exchange demineralization system, and demineralized water storage tank. The raw water treatment facility supplies lube water for the circulating water pump seal system, domestic water system, and demineralized water system.

Alum, polyelectrolyte, sodium hydroxide, and hypochlorite are added for clarification. Sulfuric acid and sodium hydroxide are used for regeneration of cation, anion, and mixed bed demineralizer units. Concentrated chemicals are pumped from storage tanks to system regenerant tanks, feed proportioned with dilution water, and passed through exhausted ion exchange resins. The spent regenerant chemicals are collected in a chemical waste sump, and then transferred to waste neutralizing tanks. Combined waste solutions are neutralized (pH 6.0-9.0) in two 15,000-gallon outside neutralizing tanks prior to release to the water treatment facility normal waste sump. The sulfuric acid and sodium hydroxide usages are expected to average 200 pounds per day and 150 pounds per day, respectively, for the two units. The alum usage is expected to average 50 pounds per day for the two units. The polyelectrolyte usage is expected to average 3 pounds per day for the two units.



## LGS EROL

All wastewater and floor drainage from the makeup water treatment facility is collected in a normal waste sump, and then transferred by either one or two 400 gpm sump pumps to the wastewater settling basins at a daily average rate of 9000 gpd from filter backwash, 7000 gpd from clarifier blowdown, 14,000 gpd from demineralizer regeneration, and 1000 gpd from floor, equipment, and sampling drains. Maximum wastewater flow from the water treatment facility is estimated to be 90,000 gpd.

The wastewater settling basins are arranged in parallel so that one can be cleaned while the other is still in operation. Each of the two parallel basins contains approximately 15,000 gallons, and is approximately 5 feet deep by 40 feet long by 10 feet wide, with an 8.7-foot long overflow weir. After leaving the wastewater settling basins, the chemical constituents of the wastewater from the water treatment facilities are primarily the same constituents withdrawn from the river, plus sodium sulfate that results from the neutralization reaction between sodium hydroxide and sulfuric acid. Suspended solids are reduced in the wastewater settling basin to approximately 30 mg/l in the effluent, although additional sedimentation is available at the holding pond. The dissolved solids concentration of the settling basin effluent is expected to average 1300 mg/l, resulting from demineralization of makeup water and neutralized sulfuric acid and caustic soda regenerant solutions. The wastewater settling basin effluent is routed through oil separators to the holding pond.

### 3.6.3.2 Circulating Water Pump Structure Sump Pump Effluent

Another low volume waste source draining to the holding pond is the circulating water pump structure sump pump effluent. The circulating water pump structure sumps collect circulating water pump floor drainage, chlorine feed facility drainage, acid feed facility drainage, and drainage from emergency and residual heat removal service water valve pits. The other floor, equipment, and sampling drainage that enters the sumps is expected to average 1000 gpd. From each of the two 450-gallon sumps in the circulating water pump structure, two 100 gpm sump pumps are available to transfer the water to normal waste yard piping, which drains through oil separators to the holding pond. The average and maximum daily flows from the sump pumps in the circulating water pump structure are expected to be 1,000 gpd and 10,000 gpd, respectively.

### 3.6.3.3 Auxiliary Boiler Blowdown

Three auxiliary boilers supply nonradioactive steam (45,000 pounds per hour maximum per boiler) for station heating with copper-tubed unit heaters during cold weather, and for various other services related to year-around station operation.

## PREOPERATIONAL R

<u>Year</u>	<u>Sample Type</u>	<u>No Sta</u>
1982	Direct Radiation	
(partial)	Air (Particulate & Iodine)	
	Surface Water	
	Drinking Water	
	Groundwater	
	Sediment	
	Fish	
	Vegetation	
	Milk	
	Small Game	
1983	Direct Radiation	
(partial)	Air (Particulate & Iodine)	

TABLE 6.1-45

(Page 1 of 3)

## RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

<u>Locations</u>	<u>Analysis</u>	<u>Frequency of Analysis</u>
48	Gamma Dose	Monthly
17	Radioiodine (I-131)	-----
	Gross Beta	Weekly
	Gamma Isotopic Composite	Monthly
5	Gamma Isotopic	Monthly
	Tritium Composite	Quarterly
	Gross Beta (soluble & insoluble)	Monthly
5	Gamma Isotopic	Monthly
	Tritium Composite	Quarterly
	Gross Beta (soluble & insoluble)	Monthly
2	Gamma Isotopic	Semi-annually
	Tritium	Semi-annually
3	Gamma Isotopic	Semi-annually
3	Gamma Isotopic	Semi-annually
1	Radioiodine	Monthly when available
2	Radioiodine (I-131)	Quarterly
	Gamma Isotopic	Quarterly
1	Gamma Isotopic	Annually
48	Gamma Dose	Monthly
17	Radioiodine (I-131)	-----
	Gross Beta	Weekly

## LGS EROL

TABLE 6.1-46

(Page 2 of 7)

<u>LOCATION DESCRIPTION</u>	<u>CODE</u>	<u>SECTOR</u>	<u>DISTANCE (MILES)</u>
<u>TLD (outer ring)</u>			
Ringling Rock Substation	35F1	N	4.2
Laughing Waters GSC	2E1	NNE	5.1
Neiffer Rd.	4E1	NE	4.6
Pheasant Rd. Game Farm Site	7E1	ENE	4.2
Transmission Corridor, Royersford Rd.	10E1	E	3.9
Trappe Substation	10F3	ESE	5.5
Vaughn Substation	13E1	SE	4.3
Pikeland Substation	16F1	SSE	4.9
Snowden Substation	19D1	S	3.6
Sheeder Substation	20F1	SSW	5.2
Porters Mill Substation	24D1	SW	3.9
Transmission Corridor, Hoffecker & Keim Sts.	25D1	WSW	4.0
Transmission Corridor, W. Cedarville Rd.	28D2	W	3.8
Prince St.	29E1	WNW	4.9
Poplar Substation	31D2	NW	3.9
Yarnell Rd.	34E1	NNW	4.6

## LGS EROL

TABLE 6.1-46

(Page 5 of 7)

<u>LOCATION DESCRIPTION</u>	<u>CODE</u>	<u>SECTOR</u>	<u>DISTANCE (MILES)</u>
<u>AIR PARTICULATE AND IODINE</u>			
Sanatoga Substation	2B1	NNE	1.5
Pottstown Landing Field	6C1	ENE	2.1
Reed Rd.	9C1	E	2.2
Keen Rd.	10S3	E	0.5
LGS Information Center	11S1	ESE	0.5
King Rd.	13C1	SE	2.9
2301 Market St., Phila.	13H4	SE	28.8
Longview Rd., SE Sector Site Boundary	14S1	SE	0.6
Spring City Substation	15D1	SE	3.2
Linfield Substation	17B1	S	1.6
Ellis Woods Rd.	20D1	SSW	3.1
Manor Substation	22G1	SW	17.6
Old Schuylkill Rd.	26B1	W	1.7
Yost Rd.	29B1	WNW	1.8
Lincoln Substation	31D1	NW	3.0
Met. Tower 1	34S2	NNW	0.6
Pleasantview Rd.	35B1	NNW	1.9

LGS EROL

SUMMARY TABLE OF CONTENTS

Section	Title	Volume
1	PURPOSE OF LIMERICK GENERATING STATION AND ASSOCIATED TRANSMISSION.....	I
1.1	System Demand and Reliability.....	I
1.2	Another Objective.....	I
1.3	Consequences of Delay.....	I
1.1A	Conservation of Energy Programs.....	I
1.1B	Energy Forecasting Methodology.....	I
1.1C	Annual Peak Demand Forecasting Method.....	I
2	THE SITE AND ENVIRONMENTAL INTERFACES.....	I
2.1	Geography and Demography.....	I
2.2	Ecology.....	I
2.3	Meteorology.....	II
2.4	Hydrology.....	II
2.4A	Appendix 2.4A - DRBC Approval.....	II
2.5	Geology.....	II
2.6	Regional Historic, Archaeological, and Natural Features.....	II
2.7	Noise.....	II
3	THE STATION	
3.1	External Appearance.....	II
3.2	Reactor and Steam-Electric System.....	II
3.3	Station Water Use.....	II
3.4	Heat Dissipation System.....	II
3.5	Radwaste Systems and Source Term.....	II
3.6	Chemical and Biocide Wastes.....	II
3.7	Sanitary and Other Waste Systems.....	II

LGS EROL

Section	Title	Volume
3.8	Reporting of Radioactive Material Movement.....	II
3.9	Transmission Facilities.....	II
4	ENVIRONMENTAL EFFECTS OF SITE PREPARATION, STATION CONSTRUCTION, AND TRANSMISSION FACILITY CONSTRUCTION.....	III
4.1	Site Preparation and Station Construction.....	III
4.2	Transmission Facilities Construction.....	III
4.3	Resources Committed During Construction.....	III
4.4	Radioactivity.....	III
4.5	Construction Impact Control Programs.....	III
5	ENVIRONMENTAL EFFECTS OF STATION OPERATION.....	III
5.1	Effects of Operation on Heat Dissipation System.....	III
5.2	Radiological Impact from Routine Operation.....	III
5.2A	Radiological Dose Model - Liquid Effluent.....	III
5.2B	Radiological Dose Model - Gaseous Effluent.....	III
5.2C	50-Mile Population and Contiguous Population Dose Model.....	III
5.3	Effects of Chemical and Biocide Discharges.....	III
5.4	Effects of Sanitary Waste Discharges.....	III
5.5	Effects of Operation and Maintenance of the Transmission Systems.....	III
5.6	Other Effects.....	III
5.7	Resources Committed.....	III
5.8	Decommissioning and Dismantling.....	III
5.9	The Uranium Cycle.....	III

LGS EROL

Section	Title	Volume
6	EFFLUENT AND ENVIRONMENTAL MEASUREMENTS AND MONITORING PROGRAMS.....	III
6.1	Applicant's Preoperational Environmental Programs.....	III
6.2	Applicant's Proposed Operational Monitoring Program.....	III
6.3	Related Environmental Measurement and Monitoring Programs.....	III
6.4	Preoperational Environmental Radiological Monitoring Data.....	III
7	ENVIRONMENTAL EFFECTS OF ACCIDENTS.....	IV
7.1	Station Accidents Involving Radioactivity.....	IV
7.2	Transportation Accidents Involving Radioactivity.....	IV
7.3	Other Accidents.....	IV
8	ECONOMIC AND SOCIAL EFFECTS OF STATION CONSTRUCTION AND OPERATION.....	IV
8.1	Benefits.....	IV
8.2	Costs.....	IV
9	ALTERNATIVE ENERGY SOURCES AND SITES.....	IV
10	STATION DESIGN ALTERNATIVES.....	IV
10.1	Alternative Circulating Systems.....	IV
10.2	Alternative Intake Systems.....	IV
10.3	Alternative Discharge Systems.....	IV
10.4	Alternative Chemical Waste Systems.....	IV
10.5	Alternative Biocide Treatment Systems.....	IV
10.6	Alternative Liquid Radwaste Systems.....	IV
10.7	Alternative Liquid Radwaste Systems.....	IV
10.8	Alternative Gaseous Radwaste Systems.....	IV



LGS EROL

Section	Title	Volume
10.9	Alternative Transmission Facilities.....	IV
11	SUMMARY BENEFIT-COST ANALYSIS.....	IV
11.1	Benefits.....	IV
11.2	Costs Incurred.....	IV
11.3	Conclusions.....	IV
12	ENVIRONMENTAL APPROVALS AND CONSULTATIONS.....	IV
13	REFERENCES.....	IV
.A	ENVIRONMENTAL TECHNICAL SPECIFICATIONS.....	IV

QUESTION E290.15

Provide a discussion on the potential environmental effects and/or hazards (excluding shocks) to biological systems from low-level electromagnetic fields generated from the transmission lines.

RESPONSE

No accepted evidence of harmful biological effects from electric or magnetic fields due to electric transmission lines has been demonstrated.


This includes over 1000 research projects as well as more than 50 years of experience with the operation of these lines.

QUESTION E291.6 (Section 3.4.2)

A statement in Section 3.4.2 mentions use of a cooling tower bypass line for the circulating water. Indicate whether the cooling towers are expected to be operated all year round. Describe those conditions and their expected frequency and duration under which the towers would be bypassed.

RESPONSE

The cooling towers are expected to operate on a year-round basis. The only time the bypass would be used would be during a winter startup after an extended shutdown, when the ambient air temperature and the basin water temperature meet the conditions shown in Figure E291.6-1. When the basin water temperature reaches the limit specified in Figure E291.6-1, bypass operation would cease and normal tower operation would resume. This type of operation is expected to occur less than 3 times a year for a period of approximately 30 hours each time.



LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 ENVIRONMENTAL REPORT

WINTER BYPASS CURVE

FIGURE E291.6-1

REV. 8, 12/82

LGS EROL

QUESTION E291.9 (Section 3.6.2)

Indicate what limitations, including monitoring, that are to be placed on discharges from the spray pond blowdown during and following chlorination to control algae.

RESPONSE

Section 3.6.2 has been changed to indicate that monitoring of chlorine concentrations is performed during and following chlorination by taking grab samples at the spray pond. If the free available chlorine concentration of the samples should exceed 0.5 mg/l, blowdown discharge will be curtailed by stopping the makeup to the spray pond until the chlorine concentration is no longer excessive.

LGS EROL

QUESTION E310.12 (Section 2.1.2.1)

Techniques used for estimating population within 10 miles of the station are described in Section 2.1.2.1 of the EROL. Meter counts form the basis of the estimates with factors of persons per residence used to determine total population. "A factor of 3.58 persons per residential meter in Philadelphia Electric Company territory, and a factor of 2.85 persons per residential meter for the Metropolitan Edison Company territory were used..." How were these factors obtained and why do you feel that a difference of 0.73 persons per meter exists within 10 miles of the site given electric company territory?

RESPONSE

The factor of persons per residential meter for use in Philadelphia Electric Company territory was obtained by taking the number of residential meters in the Philadelphia Electric service area Schuylkill Division, which includes the Limerick vicinity, and dividing that total into the population figures for the townships and boroughs served by the Schuylkill Division. A factor of 3.58 persons per residential meter was obtained based on data from a 1976 meter count and the 1970 census. This information was recently updated using data from a 1980 meter count and the 1980 census and a factor of 2.38 was obtained for the same area. Similarly, Metropolitan Edison calculated the factor of 2.85 persons per residential meter using 1970 census information and 2.70 persons per residential meter using 1980 census information for the townships and boroughs served by the Metropolitan Edison Central Division, which encompasses Berks County.

LGS EROL

QUESTION E451.6 (Section 2.3)

Section 2.3.1 of the ER provides a description of air quality in the vicinity of the site. Describe station sources of criteria air pollutants as defined by the Environmental Protection Agency, including estimated emissions, and compare these emissions to the DeMinimus criteria established by the Environmental Protection Agency (EPA). If station emissions are above the DeMinimus levels, provide a quantitative assessment of the impact of station emissions on local air quality using current EPA guidelines on atmospheric dispersion modeling.

RESPONSE

The only source of criteria pollutants at Limerick are produced from the operation of the auxiliary boilers. There is a total of three boilers, any two of which may be used depending on the operating status of the power plant.

There are three identical boilers in use at Peach Bottom Atomic Power Station (PBAPS). Because the operation of these boilers is similar to the planned operation of the Limerick boilers, the fuel consumption of the PBAPS boilers was used to produce the emission estimates. The following estimates are based on the last four years (1978-1981) average use of No. 2 fuel oil at PBAPS of  $1.3 \times 10^6$  gal/yr with a sulfur limit of 0.3% by weight.

<u>POLLUTANT</u>	<u>DEMINIMUS</u> (tons/year)	<u>ESTIMATED EMISSION</u> (tons/year)
SO <sub>2</sub>	40	28.2
NO <sub>x</sub>	40	14.3
Particulate	25	1.3
Ozone	40	0
Lead	0.6	0
CC	100	3.3

The estimated emission levels are below the DeMinimus levels; therefore, no quantitative assessment of the impact of these emissions is necessary.

**Environmental Report  
Operating License Stage**

**Limerick Generating Station**

**Units 1 & 2**

**PHILADELPHIA ELECTRIC COMPANY**

**Vol. 5**