

DEC 15 1982

MEMORANDUM FOR: Thomas A. Ippolito, Chief
 Operating Reactors Assessment Branch
 Division of Licensing

FROM: Cecil O. Thomas, Chief
 Standardization & Special Projects Branch
 Division of Licensing

SUBJECT: NUREG-0737 ITEMS REQUIRING TECHNICAL SPECIFICATIONS

Your memo of December 6, 1982, subject as above, requested review of and comments on a proposed generic letter and attached model technical specifications. Members of my staff have reviewed the requested material and we recommend that the Action Statement for Specification 3.6.5.1 (Hydrogen Monitors) be separated into two parts as follows:

- "a. With one hydrogen monitor inoperable, restore the inoperable monitor to OPERABLE status within 30 days or be in at least HOT STANDBY within the next 6 hours.
- b. With both hydrogen monitors inoperable, restore at least one monitor to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours."

151

Cecil O. Thomas, Chief
 Standardization & Special
 Projects Branch
 Division of Licensing

cc: C. Patel

DISTRIBUTION:
 Central Files
 NRC PDR
 PRC
 C. Thomas
 D. Brinkman
 SSPB R/F

8301040045 821215
 PDR NUREG
 0737 C PDR

*IDR-5
 TMI
 X L-4/1A.50
 REC-5/100*

OFFICE	DL:SSPB	DL:SSPB					
SURNAME	DBrinkman:cc	CThomas					
DATE	12/15/82	12/15/82					