

DEC 22 1982

DCD-0160

DISTRIBUTION:

Docket File

NRC PDR

L PDR

ORB#4 Rdg

DEisenhut

RIngram

GGears

Gray File-2

OELD

AEOD

IE-Harmon & Jordan

ACRS-10

Dockets Nos. 50-277
and 50-278

Mr. Edward G. Bauer, Jr.
Vice President and General Counsel
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Dear Mr. Bauer:

We have reviewed your submittal dated July 7, 1982 concerning a request to amend Section 6 of your Technical Specifications to reflect the addition of a Senior Health Physicist to your plant organization. Additional information, needed to complete this review, is identified in the enclosure. We request that PECO provide this information by January 21, 1983.

The reporting and/or recordkeeping requirements of this letter affect fewer than ten respondents; therefore, OIB clearance is not required under P. L. 96-511.

Sincerely,

*ORIGINAL SIGNED BY
JOHN F. STOLZ*

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Enclosure:
Request for Additional
Information

cc w/enclosure:
See next page

8301040074 821222
PDR ADOCK 05000277
P PDR

OFFICE	ORB#4:DL	C-ORB#4:DL				
SURNAME	GGears/cab	JStolz				
DATE	12/21/82	12/21/82				

Philadelphia Electric Company

cc w/enclosure(s):

Eugene J. Bradley
Philadelphia Electric Company
Assistant General Counsel
2301 Market Street
Philadelphia, Pennsylvania 19101

Troy B. Conner, Jr.
1747 Pennsylvania Avenue, N.W.
Washington, D. C. 20006

Regional Radiation Representative
EPA Region III
Curtis Building (Sixth Floor)
6th and Walnut Streets
Philadelphia, Pennsylvania 19106

M. J. Cooney, Superintendent
Generation Division - Nuclear
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Thomas A. Deming, Esq.
Assistant Attorney General
Department of Natural Resources
Annapolis, Maryland 21401

Philadelphia Electric Company
ATTN: Mr. W. T. Ullrich
Peach Bottom Atomic
Power Station
Delta, Pennsylvania 17314

Albert R. Steel, Chairman
Board of Supervisors
Peach Bottom Township
R. D. #1
Delta, Pennsylvania 17314

Mr. R. A. Heiss, Coordinator
Pennsylvania State Clearinghouse
Governor's Office of State Planning
and Development
P. O. Box 1323
Harrisburg, Pennsylvania 17120

Allen R. Blough
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Peach Bottom Atomic Power Station
P. O. Box 399
Delta, Pennsylvania 17314

Mr. Ronald C. Haynes, Regional Administrator
U. S. Nuclear Regulatory Commission, Region I
Office of Inspection and Enforcement
631 Park Avenue
King of Prussia, Pennsylvania 19406

REQUEST FOR ADDITIONAL INFORMATION CONCERNING THE
REORGANIZATION OF HEALTH PHYSICS FUNCTIONS FOR
PEACH BOTTOM UNITS NOS. 2 AND 3
DOCKETS NOS. 50-277 & 278

1. The organization proposed in your technical specifications does not show any technicians or other support reporting to the Senior Health Physicist. The health physics organization shown in Figure 6.2-2 of the technical specifications should be sufficient to demonstrate that the Senior Health Physicist can perform his assigned duties and meet his responsibilities, including those shown for the Radiation Protection Manager listed in Regulatory Guide 8.8 Rev. 3, 1978. Therefore, the organization shown in Figure 6.2-2 should be revised to include personnel who support the Senior Health Physicist and who meets the minimum qualifications of ANSI N18.1-1971 as specified in Section 6.3.1 of the plant's technical specifications.