



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

December 28, 1982

JAMES P. MCGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Containment to Auxiliary
Building Differential
Pressure not Verified at
Proper Frequencies
LER 82-149/03 L-0
AECM-82/637

A Quality Assurance audit revealed that the Containment to Auxiliary Building differential pressure was not verified at the frequency required by Technical Specification 4.6.1.7. In accordance with T.S.4.0.3 this is being reported pursuant to T.S.6.9.1.13.b. Attached is LER 82-149/03 L-0.

Yours truly,

James P. McGaughy, Jr.
FOR J.P. McGaughy, Jr.

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY

1522