



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 97 ■ PERRY, OHIO 44081 ■ TELEPHONE (216) 259-3737 ■ ADDRESS-10 CENTER ROAD

Serving The Best Location in the Nation

December 29, 1982

Mr. B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Perry Nuclear Power Plant
Docket Nos. 50-440; 50-441
Fire Protection - Confirmatory
Issue No. 36 and Miscellaneous
FPER Concerns

Dear Mr. Youngblood:

This letter is provided in response to the letter dated November 26, 1982, from A. Schwencer to D. R. Davidson regarding the confirmatory issue (#36) on the documentation or test of the 3-hour fire resistance of gypsum board walls.

As stated in our November 16, 1982 letter, we are pursuing an Underwriter's Laboratory (UL) evaluation of the configuration differences between the Perry wall design and the design tested by UL. This evaluation is expected by January 14, 1983, and will be forwarded to the staff as soon as it is available.

Additionally, this letter and its attachments provides clarification on the staff concerns regarding the hydraulic calculations for standpipe sizing and drainage for the switchgear rooms. Attachment 1 to this letter provides the design criteria and sample calculations to demonstrate the adequacy of the standpipe size to meet the hose station requirements of NFPA Standard 14. The calculation shows that the worst case flow requirements are within the fire pumps capability. Attachment 2 to this letter addresses the staff's concern about water accumulation in the switchgear rooms in the Control Complex Building. The justification that drainage is not needed was previously provided as the response to Question Topic 21 in our letter dated March 12, 1982.

3002


Mr. B. J. Youngblood

- 2 -

December 29, 1982

We believe that this information will enable the staff to resolve the hydraulic calculations for standpipes and drainage in the switchgear room in the next Supplement to the Safety Evaluation Report.

Sincerely,



Dalwyn R. Davidson
Senior Vice President

DRD:kh

cc: Jay Silberg, Esq.
John Stefano
Max Gildner
J. Stang

December 29, 1982

ATTACHMENT I

PURPOSE:

To demonstrate that the standpipe and hose system is designed to supply an adequate water flow and pressure at each hose station outlet in accordance with the requirements of NFPA Standard 14.

DESIGN CRITERIA:

1. The hydraulic calculation for the standpipe and hose system will be based on the worst case flow situation (greatest friction loss).
2. All interior pipe is assumed to be Schedule 40, C=120, except when utilizing "Automatic" Sprinkler Corporation of America (ASCOA) hydraulic reference points. These points are shown in the calculations and diagrams as "A-X: (X referring to point shown on ASCOA print no. 4549-70A-001-55-2, Equivalent Pipe Lengths). For interior pipe lengths using "A-X" points, C=100, and for exterior "A-X" points, use C=75.
3. All interior hose stations are designed for Class II service and sized for a minimum flow of 100 gallons per minute at 65 psi at the hose station outlet valve.
4. The calculations will be based on a total flow of 500 gpm from both internal (building) and external (yard hydrant system) hose streams.
5. When a hazard area is within reach of several internal hose streams, (utilizing 75' hose length except as noted) the calculations will include simultaneous water flow from multiple hose streams.
6. Water flow from hose streams will be based on hose stations located on the same floor level and within the same building as the area being protected, except as noted (hose will be included from another floor only when the isolated location of the station in question prevents simultaneous flow with at least one other interior hose station, in accord with NRC requirements).
7. The water flow from outside hose streams (yard hydrant system), is the difference between the 500 gpm (required allowance from all hose streams) and the internal (building) hose stream protection. Passage of hose through enclosed exit stairs or between adjacent buildings will not generally be addressed since this would negate the existing stairs or fire walls by allowing smoke, heat and fire to enter the enclosure or adjacent building, and/or create a possible tripping hazard.

8. The water supply for the standpipe and hose system will be based on rated capacity of the fire pumps. The maximum water pressure available will be based on the fire pump relief valve setting. Fire pump discharge outlets are located at El. 587'-10 $\frac{1}{2}$ ".
9. In areas of the plant where fixed fire suppression systems are located, the calculations will be based on a simultaneous operation of both the fixed fire suppression system and all fire hose stations whose hose streams will reach the area protected by the fixed fire suppression system.
 - a. The demand for the fixed water spray and automatic sprinkler systems will be based on "Automatic" Sprinkler Corporation of America (ASCOA) calculations, when available.
 - b. When ASCOA calculations are not available, the demand for sprinkler systems will be based on the density curves of NFPA 13, Table 2-2.1 (B) for the largest fire area within the protected area of the system, but, with an area of sprinkler operation not to exceed 3,000 square feet. These calculations will be shown on the "Conclusions" page for each case requiring them.
 - c. If the pressure required for the interior hose stations is less than that required by the ASCOA calculations for a fixed system (at the junction point), then further analysis of the standpipe/hose station is not required because the resultant flow and pressure will always be in excess of the hose requirements, (NFPA 14).
10. Assumptions:
 - a. Friction loss will be calculated for all flows in pipe less than 4" in diameter.
 - b. Friction loss will be calculated for flow greater than 200 GPM in 4" diameter pipe (unless otherwise noted).
 - c. Friction loss will be calculated for flow greater than or equal to 500 GPM in pipe larger than 4" in diameter (unless otherwise noted).
11. Conclusions for each hose station calculation are shown at the end of the individual sections (i.e., Intermediate Building or Control Complex).

ABBREVIATIONS/SYMBOLS:

- X X-alphanumeric, hydraulic reference point
- A-X X-number (1,2,3,...) hydraulic reference point from "Automatic" Sprinkler Corporation of America Drawing No. 4549-70A-001-55-2.
- Z Hydraulic Reference Point representing Fire Pump Discharge

"Automatic" Sprinkler Corporation of America - ASCOA

FSD - Fluid System Diagram

FPER - Fire Protection Evaluation Report

AUX. BLDG. - Auxiliary Building

INT. BLDG. - Intermediate Building

RAD. WASTE - Radioactive Waste Building



Gilbert Associates, Inc.


Reading, Pennsylvania

CALCULATION

SUBJECT	HOSE STATION PRESSURE CALC PUMP - UNIT 1			CISID	01-4549-310	PAGE	1
REV.	0	1	2	3		OF	
MICROFILMED						PAGES	7
ORIGINATOR							

DATE 8-27-82

TURBINE BLDG - UNITS 1



D645-ASCOA 19-1, D649, D650 - ASCOA SHT # 4549-70A-001-23-1
D652-ASCOA 18-3 D649, D651 - ASCOA SHT # 4549-70A-001-22-2




Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT	HOSE STATION PRESSURE CALC PNPP - UNIT I			CISID	04-4549-310	PAGE	2
REV.	0	1	2	3		OF	
MICROFILMED						PAGES	7
ORIGINATOR	SCM						
DATE	8-27-82						



FOR D691 - SEE
FOR D696 - SEE

ASCOA 4549-TDA-001-19-1

" " - 18-3

FOR D693, D694 - SEE " 22-2; FOR D695 - SEE ASCOA SHT 23-1



Gilbert Associates, Inc.
Reading, Pennsylvania

ANALYSIS/CALCULATION

SUBJECT HOSE STATION PRESSURE
CALC PNPP - UNIT 1

CISID

04-4549-310

PAGE

3

REV.

0

.

1

2

3

OF

7

PAGES

MICROFILMED

ORIGINATOR

DATE

8-30-82

WATER TREATMENT

1½"

(24)

D699, EL. 625-3"

1½"-37'3E, 1AV

3"-187'1HE, 2EE, 1T

NOTE: SEE D698.

1½

EL. 630-7"

(26)

2½" (25A) 1½"

(25)

D698, EL. 652-0"

1½"-2'1AV; 2½"-14'4E, 1T

3"-1.87'1HE, 2EE, 1T

NOTE: CALCS, PG #

, SHOW SIMULTANEOUS FLOW OF D 698 & D699

(HOSE STATIONS ARE IN ISOLATED LOCATIONS ON THEIR FLOORS - D698 WAS BROUGHT DOWN TO THE 625-3" LEVEL), W/ 300 GPM IN OUTSIDE HOSE.

EL. 649.4 1/4" 3"

(28)

(27)

1½"

(27)

D641 EL. 625-3"

1½"-11'1T, 1E, 1AV

NOTE: CALCS ON PG #45-6 SHOW FLOW OF D641, D694, D649, & D650 W/ 93 GPM IN OUTSIDE HOSE, AND TURB BLDG SPRKS (1040 GPM @ 63.5 PSI).

4"
6"
10"
10"
(A-17)

FOR D 641 - SEE ASCOA 70A-001-23-1

FOR D698, 699 - SEE " " 42-0



Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT HOSE STATION PRESSURE CALC
PNPA - UNIT 1

CISID

04-4549-310

PAGE 4

REV.

0

1

2

3

OF 7 PAGES

MICROFILMED

ORIGINATOR

DATE 9-29-82

NOZZLE TYPE & LOCATION	FLOW IN G.P.M.	PIPE SIZE	FITTING & DEVICES	PIPE EQUIV. LENGTH	FRICITION LOSS P.S.I./FT.	REQUIRED P.S.I.	HYD. REF. PT.	ELEV.	NOTES
------------------------------	----------------------	--------------	-------------------------	-----------------------	---------------------------------	--------------------	------------------	-------	-------

Q	TOT.	PE	
Q	1T-8 LGTH. 11	PT 65.0	3 629-3" TURB BLDG H.S.
D694 Q 100	ZE-8 FTG. 39	PF 15.9	
	IAV-23 TOT. 50	PE	
Q	1T-10 LGTH. 26	PT 80.9	7
Q 100	FTG. 10	PF 3.3	
	TOT. 36	PE	
Q	LGTH.	PT 84.2	8
Q 100	FTG.	PF NIL	
	TOT.	PE 18.9	
Q	LGTH.	PT 103.1	9 585-6"
	FTG.	PF	
Q	TOT.	PE	
D641 Q	1T-8 LGTH. 11	PT 65.0	27 625-3" TURB BLDG H.S.
Q 100	ZE-4 FTG. 35	PF 14.6	
	IAV-23 TOT. 46	PE	
Q	4" / 6" LGTH.	PT 79.6	28
Q 100	FTG.	PF NIL	
	TOT.	PE 17.2	
ADJ To Higher ↓	LGTH.	PT 96.8	9 585-6" $\frac{103.1(100)}{96.8 \leq 100}$
Pr No Change ≈ 100	FTG.	PF ↓	
D694+ Q 100	TOT.	PE ↓	
D641 Q 200	LGTH.	PT 103.1	9
	FTG.	PF NIL	
	TOT.	PE ≈ 12.3	
ADJ Flow To Q ↓	LGTH.	PT 100.8	A-17 590-936 $\frac{108'(200)}{100.8 \leq 207}$
HIGHER PT 6207	FTG.	PF ↓	
	TOT.	PT 108.0	A-17 ≈ 207



Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT HOSE STATION PRESSURE
CALC - PNPP UNIT 1

CISID 04-4549-310

PAGE 5
OF 7 PAGESREV. 0
MICROFILMED
ORIGINATOR *RM*
DATE 9-29-82

NOZZLE TYPE & LOCATION	FLOW IN G.P.M.	PIPE SIZE	FITTING & DEVICES	PIPE EQUIV. LENGTH	FRICTION LOSS P.S.I./FT.	REQUIRED P.S.I.	HYD. REF. PT.	ELEV.
TURB BLDG Q				LGTH.	.0094	PT 63.5	23	628.6"
SPRK SYST #1A	Q 1040	8"		FTG.		PF 1.7		
				TOT. 184		PE 15.4		
ADJ Q TO	Q			LGTH.		PT 80.6	A-18	592-1074
HIGHER PR	Q 1185			FTG.		PF ↓		
(FROM PG #6) Q				TOT.		PE ↓		
				LGTH.		PT 104.6	A-18	
				FTG.		PF		
				TOT.		PE		
				LGTH.		PT		
				FTG.		PF		
				TOT.		PE		
				LGTH.		PT		
				FTG.		PF		
				TOT.		PE		
				LGTH.		PT		
				FTG.		PF		
				TOT.		PE		
				LGTH.		PT		
				FTG.		PF		
				TOT.		PE		
				LGTH.		PT		
				FTG.		PF		
				TOT.		PE		
				LGTH.		PT		
				FTG.		PF		
				TOT.		PE		
				LGTH.		PT		
				FTG.		PF		
				TOT.		PE		
				LGTH.		PT		
				FTG.		PF		
				TOT.		PE		
				LGTH.		PT		
				FTG.		PF		
				TOT.		PE		
				LGTH.		PT		
				FTG.		PF		
				TOT.		PE		
				LGTH.		PT		
				FTG.		PF		
				TOT.		PE		
				LGTH.		PT		
				FTG.		PF		
				TOT.		PE		
				LGTH.		PT		
				FTG.		PF		
				TOT.		PE		
				LGTH.		PT		
				FTG.		PF		
				TOT.		PE		
				LGTH.		PT		
				FTG.		PF		
				TOT.		PE		
				LGTH.		PT		
				FTG.		PF		
				TOT.		PE		
				LGTH.		PT		
				FTG.		PF		
				TOT.		PE		
				LGTH.		PT		
				FTG.		PF		
				TOT.		PE		
				LGTH.		PT		
				FTG.		PF		
				TOT.		PE		
				LGTH.		PT		
				FTG.		PF		
				TOT.		PE		
				LGTH.		PT		
				FTG.		PF		
				TOT.		PE		



Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT HOSE STATION PRESSURE
CALC-PNPP UNIT I

CISID

04-4549-310

PAGE

6

OF

7

PAGES

REV.

0

1

2

3

MICROFILMED

ORIGINATOR

DATE 11-2-82

NOZZLE TYPE & LOCATION	FLOW IN G.P.M.	PIPE SIZE	FITTING & DEVICES	PIPE EQUIV. LENGTH	FRICITION LOSS P.S.I./FT.	REQUIRED P.S.I.	HYD. REF. PT.	ELEV.	NOTES
D650	Q	1 1/2"	4E-16	LGTH. 19		PT 65.0	14	629-3"	TURBINE BLDG. H.S.
Q100			IAV-23	FTG. 39 TOT. 58	.318	PF 18.4 PE (-) 1.7			
Q		2"	1T-10	LGTH. 1		PT 81.7	19	633-0	
Q100				FTG. 10 TOT. 11	.093	PF 1.0 PE			
ADJ Q TO PT	Q			LGTH.		PT 82.7	20		187.2" (100) 82.7 ≥ 100
PT	Q100			FTG.		PF ↓			
Q				TOT.		PT 87.2	20		
Q				LGTH.		PF			
D649	Q	1 1/2"	IAV-23	LGTH. 2		PT 65.0	15	625-3"	T.B. H.S.
Q100				FTG. 23 TOT. 25	.318	PF 8.0 PE			
Q		2"	12E-60	LGTH. 19		PT 73.0	15A		
Q100			1T-10	FTG. 70 TOT. 189	.093	PF 17.0 PE 18.4			
ADD D650	Q100			LGTH.		PT 87.2	20	633-0"	
	Q200	4" / 10"		FTG.		PF NIL			
				TOT.		PE 17.4			
CAMBINE TURB	Q1185	10"		LGTH.		PT 104.6	A-18	592-10 1/4	C = 100 CARRY FROM REF 5
STICK SYST	Q1385			FTG.		PF 2.5			
W/ H.S.				TOT. 353		PE .9			
ADD D694	Q207	10"		LGTH.		PT 108.0	A-17	590-9 3/8"	C = 100
D641, PG #4	Q1592			FTG.		PF 2.9			
				TOT. 316		PE			
Q		10"		LGTH.		PT 110.9	A-27		C = 75
Q1592				FTG.		PF 3.0			
				TOT. 193		PE			
OUTSIDE HOSE	Q 93	12"		LGTH.		PT 113.9	A-3		C = 75
HOSE	Q1685			FTG.		PF 3.8			
AT FIRE PUMP	Q			TOT. 518		PE 1.3			
Q				LGTH.		PT			
Q				FTG.		PF			
Q				TOT.		PE			
Q				LGTH.		PT			
Q				FTG.		PF			
Q				TOT.		PE			
Q				LGTH.		PT			
Q				FTG.		PF			
Q				TOT.		PE			
Q				LGTH.		PT			
Q				FTG.		PF			
Q				TOT.		PE			
Q				LGTH.		PT			
Q				FTG.		PF			
Q				TOT.		PE			
Q				LGTH.		PT			
Q				FTG.		PF			
Q				TOT.		PE			
Q				LGTH.		PT			
Q				FTG.		PF			
Q				TOT.		PE			
Q				LGTH.		PT			
Q				FTG.		PF			
Q				TOT.		PE			
Q				LGTH.		PT			
Q				FTG.		PF			
Q				TOT.		PE			



Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT	HOSE STATION PRESSURE CALC ANPP - UNIT 1			CISID	04-4549-310	PAGE	7
REV.	0	1	2	3		OF	
MICROFILMED						PAGES	7
ORIGINATOR	XO						
DATE	9-30-82						

CONCLUSIONS:

D695, D651 - WORST CASE FLOW CONDITION SHOWN ON PG# _____, D695 & D651 w/ 300 GPM IN OUTSIDE HOSE ON A COMMON HAZARD. CALC'S SHOW COMPLIANCE w/ NFPA 14.

(REF: FSD GAZ DWG D-914-002, LAYOUT DWG E-001-038)

D694, D641, D649, D650 - WORST CASE FLOW CONDITION SHOWN ON PG# 4,5,6, SIMULTANEOUS FLOW OF H.S. w/ TURBINE BLDG SPRK SYST (IA) AND OUTSIDE HOSE ON A COMMON HAZARD. COMPLIANCE SHOWN w/ NFPA 14.

(REF: FSD GAZ DWG D-914-002, LAYOUT DWG E-001-029)

D698, D699 - WORST CASE FLOW CONDITION SHOWN ON PG# _____, D698 & D699 w/ 300 GPM OF OUTSIDE HOSE. CALC'S SHOW COMPLIANCE w/ NFPA 14.

(REF: FSD GAZ DWG D-914-002, LAYOUT DWG E-001-038).

Attachment 2
December 29, 1982

Drainage for Switchgear Rooms.

RESPONSE

An evaluation of the equipment located in the switchgear rooms has determined that a maximum water level of 4 inches could be tolerated in the switchgear rooms without endangering the switchgear operation. It is anticipated that hose streams located outside the rooms would be used on fire in these areas only as the second line of defense. If two hose streams were used simultaneously a water flow of approximately 200 GPM could be predicted. Drainage in or adjacent to switchgear areas is such that the predicted water flow would not create any appreciable accumulation on the floor of these areas. In addition, water accumulation from fighting a fire or from a pipe break in any of the switchgear areas can not accumulate to a level which could endanger the redundant equipment which is located in another area.