

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | G | A | E | I | H | 2 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | | 5

CONT | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 6 | 6 | 7 | 0 | 6 | 1 | 9 | 8 | 0 | 8 | 1 | 2 | 2 | 3 | 8 | 2 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | With the reactor mode switch in run, the Reactor Building to Torus Vacuum
03 | um Breaker Isolation Valve failed to open on 6/19/80 and again on
04 | 6/27/80. There was no effect on safe plant operation. The redundant
05 | valve was operable. The health and safety of the public were not
06 | affected by this repetitive event as referenced on LER 50-366/1980-054.

09 | SYSTEM CODE | I | E | 11 | CAUSE CODE | E | 12 | CAUSE SUBCODE | E | 13 | COMPONENT CODE | I | N | S | T | R | U | 14 | COMP. SUBCODE | S | 15 | VALVE SUBCODE | Z | 16

17 | LER/RO REPORT NUMBER | 8 | 0 | 21 | EVENT YEAR | 8 | 0 | 22 | SHUTDOWN METHOD | | | 23 | SEQUENTIAL REPORT NO. | 0 | 9 | 6 | 24 | OCCURRENCE CODE | | | 25 | REPORT TYPE | X | 30 | REVISION NO. | 2 | 32

ACTION TAKEN | A | 18 | FUTURE ACTION | Z | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 | 0 | 0 | 0 | 37 | ATTACHMENT SUBMITTED | N | 23 | NPD-4 FORM SUB. | N | 24 | PRIME COMP. SUPPLIER | A | 25 | COMPONENT MANUFACTURER | S | 3 | 8 | 2 | 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The D-P Switch failed to actuate, thus precluding operation of the Reactor
11 | Building to Torus Vacuum Breaker Isolation Valve. The switch has
12 | been replaced. The switch and Vacuum Breaker Isolation Valve were
13 | satisfactorily tested and returned to service.

15 | FACILITY STATUS | E | 28 | % POWER | 0 | 9 | 8 | 29 | OTHER STATUS | NA | 30 | METHOD OF DISCOVERY | A | 31 | DISCOVERY DESCRIPTION | Operator Observation | 32

16 | ACTIVITY CONTENT | Z | 33 | RELEASED OF RELEASE | Z | 34 | AMOUNT OF ACTIVITY | NA | 35 | LOCATION OF RELEASE | NA | 36

17 | PERSONNEL EXPOSURES | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | NA | 39

18 | PERSONNEL INJURIES | 0 | 0 | 0 | 40 | DESCRIPTION | NA | 41

19 | LOSS OF OR DAMAGE TO FACILITY | Z | 42 | DESCRIPTION | NA | 43

20 | PUBLICITY | N | 44 | DESCRIPTION | 8301040129 821223
PDR ADOCK 05000366
S PDR

NAME OF PREPARER | S. B. Tipps

PHONE | (912) 367-7851