

February 8, 1991

Docket No. 50-344

Mr. James E. Cross
Vice President, Nuclear
Portland General Electric Company
121 S.W. Salmon Street
Portland, Oregon 97204

DISTRIBUTION

Docket File	NRC & LPDRs
PD5 Reading	BBoger
MVirgilio	DFoster
JBradfute	RBevan
OGC	DHagan
GHill (4)	WJones
JCalvo	ACRS (10)
GPA/PA	OC/LFMB
PD5 Gray File	Region V (4)

Dear Mr. Cross:

SUBJECT: TROJAN NUCLEAR PLANT - WITHDRAWAL OF LICENSE CHANGE APPLICATION
(LCA) 179 (TAC NO. 74837)

By letter dated September 21, 1990, you submitted Licensee Change Application (LCA) 203, Revision 1, which included a request to withdraw LCA 179 dated July 19, 1989. The withdrawn action revised the Trojan Technical Specification Table 3.6-1, "Containment Isolation Valves," by reclassifying the four main steam supply valves as air-operated valves rather than motor-operated valves. The proposed amendment (LCA 179) was then included in the approval of LCA 203, Revision 1, (Amendment No. 164 dated September 28, 1990). Based on these changes, LCA 179 is considered withdrawn in its entirety.

We have filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

Original Signed By:

Roby B. Bevan, Project Manager
Project Directorate V
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

OFC	:LA/PD5/DRPW	:PE/PD5/DRPW	:PM/PD5/DRPW	:D/PD5/DRPW	:	:
NAME	:DFoster <i>DF</i>	:JBradfute:sg	:RBevan <i>RB</i>	:JByer <i>JMB</i>	:	:
DATE	2/5/91	: 5/Feb/91	: 2/7/91	: 2/8/91	:	:

OFFICIAL RECORD COPY
Document Name: TROJAN AMD 74837

9102140273 910208
PDR ADOCK 05000344
P PDR

DF 1/11

Mr. James E. Cross
Portland General Electric Company

Trojan Nuclear Plant

cc:
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Trojan Nuclear Plant
Post Office Box 0
Rainier, Oregon 97048

Mr. Michael J. Sykes, Chairman
Board of County Commissioners
Columbia County
St. Helens, Oregon 97501

Mr. David Stewart-Smith
Oregon Department of Energy
Salem, Oregon 97310

Regional Administrator, Region V
U.S. Nuclear Regulatory Commission
1450 Maria Lane, Suite 210
Walnut Creek, California 94596