

UNITED STATES NUCLEAR REGULATORY COMMISSIONPORTLAND GENERAL ELECTRIC COMPANY, ET AL.DOCKET NO. 50-344TROJAN NUCLEAR PLANTNOTICE OF WITHDRAWAL OF AMENDMENT TO FACILITY OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (the Commission) has approved the withdrawal request by Portland General Company, et al., (the licensee) for an amendment to Facility Operating License No. NPF-1, issued to the licensee for operation of the Trojan Nuclear Plant, located in Columbia County, Oregon. Notice of Consideration of Issuance of this amendment was published in the FEDERAL REGISTER on August 22, 1990, (55 FR 34382).

The proposed amendment revised Trojan Technical Specification (TTS) Table 3.6-1. The change, which affects the four valves of the main steam supply to the auxiliary feedwater (AFW) pump turbine, reclassified the description of the turbine steam supply valves from motor-operated to air-operated.


This change has been combined with a subsequent request dated September 21, 1990, (License Change Application 203, Revision 1) and issued as Amendment No. 164 dated September 28, 1990. Therefore, the proposed amendment is considered withdrawn by the licensee.

For further details with respect to this action, see (1) the application for amendment dated September 21, 1990, and (2) the staff's letters dated September 28, 1990 and

These documents are available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, N.W., Washington D.C. 20555 and at the local public document room located in the Branford Price Millar Library, Portland State University, 934 S.W. Harrison Street, P.O. Box 1151, Portland, Oregon 97207.

Dated at Rockville, Maryland, this 8th day of February 1991.

FOR THE NUCLEAR REGULATORY COMMISSION



Roby B. Bevan, Project Manager
Project Directorate V
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation