



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

ENERGY OPERATIONS, INC.

DOCKET NO. 50-368

ARKANSAS NUCLEAR ONE, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 115
License No. NPF-6

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Energy Operations, Inc. (the licensee) dated December 11, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9102150188 910212
PDR ADOCK 05000368
P PDR

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-6 is hereby amended to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 115, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. The license amendment is effective as of 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Thomas P. Gwynn, Acting Director
Project Directorate IV-1
Division of Reactor Projects III, IV, and V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 12, 1991

ATTACHMENT TO LICENSE AMENDMENT NO. 115

FACILITY OPERATING LICENSE NO. NPF-6

DOCKET NO. 50-368

Revise the following page of the Appendix "A" Technical Specifications with the attached page. The revised page is identified by Amendment number and contains vertical lines indicating the area of change.

REMOVE PAGE

3/4 3-40

INSERT PAGE

3/4 3-40

TABLE 3.3-10

POST-ACCIDENT MONITORING INSTRUMENTATION

INSTRUMENT	MINIMUM CHANNELS OPERABLE
1. Containment Pressure (Normal Design Range)	2
2. Containment Pressure (High Range)*	2
3. Pressurizer Pressure	2
4. Pressurizer Water Level	2
5. Steam Generator Pressure	2/steam generator
6. Steam Generator Water Level	2/steam generator
7. Refueling Water Tank Water Level	2
8. Containment Water Level - Wide Range*	2
9. Emergency Feedwater Flow Rate	1/steam generator
10. Reactor Coolant System Subcooling Margin Monitor	1
11. Pressurizer Safety Valve Acoustic Position Indication	1/Valve
12. Pressurizer Safety Valve Tail Pipe Temperature	1/Valve

*If only one channel is inoperable and containment entry is required to restore the inoperable channel, the channel need not be restored until the following refueling outage.