7590-01

## U. S. NUCLEAR REGULATORY COMMISSION TOLEDO EDISON COMPANY, ET AL. DOCKET NO. 50-346

## NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 153 to Facility Operating License No. NPF-3, issued to The Toledo Edison Company, Centerior Service Company, and The Cleveland Electric Illuminating Company (the licensee), which revised the Technical Specifications for operation of the Davis-Besse Nuclear Power Station, Unit No. 1 (the facility) located in Cttawa County, Ohio. The amendment was effective as of the date of its issuance.

The amendment allowed the main steam safety valve (MSSV) setpoints and the required minimum number of valves to be more consistent with the requirements of ASME Boiler and Pressure Vessel Code. It also redefined the relationship between the total operable MSSV relieving capacity per steam generator and the reduced Reactor Protection System High Flux Trip setpoint.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment.

Notice of Consideration of Issuance of Amendment and Opportunity for Hearing in connection with this action was published in the FEDERAL REGISTER on May 24, 1988 (53 FR 18631). No request for hearing or petition for leave to intervene was filed following this notice.

For further details with respect to this action see (1) the application for amendment dated March 4, 1988, as supplemented May 4 and December 6, 1988, (2) Amendment No. 153 to License No. NPF-3, (3) the Commission's related Safety Evaluation dated February 8, 1991 and (4) the Environmental Assessment dated September 26, 1990 (55 FR 39329). All of these items are available for public inspection at the Commission's Public Document Room, 2120 L Street, N.W., Washington, D.C., and at the University of Toledo Library, Documents Department, 2801 Bancroft Avenue, Toledo, Ohio 43606.

A copy of items (2), (3) and (4) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Reactor Projects III/IV/V.

Dated at Rockville, Maryland, this 8th day of February 1991.

FOR THE NUCLEAR REGULATORY COMMISSION

Dominic C. Dilanni, Sr. Project Manager

Project Directorate III-3

Divisio Reactor Projects - III/IV/V Office uclear Reactor Regulation