	LICENSEE EVENT REPORT
	CONTROL BLOCK: [] [] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1 8	G A E I H 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5 5 HICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58
CON'T 0 1 7 8	REPORT LG 0 5 0 0 0 3 2 1 7 0 1 2 6 8 3 8 0 2 2 2 8 3 9 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10 While performing the "REACTOR HIGH PRESSURE (SHUTDOWN CCOLING MODE) INST-
0 3	RUMENT FT&C" procedure, personnel noted that the "B" reactor pressure
0 4	[instrument actuated at 164 psig. The acceptance criteria for this instru-
0 5	ment is ≤ 157.3 psig, (i.e., a 22.3 psig head correction factor plus the
0 6	≤ 135 psig T.S. limit as specified in Unit 1 T.S. Tables 3.2-1 and 3.2-5).
0 7	The redundant instrument was operable. The health and safety of the
0 8	public were not affected by this non-repetitive event.
7 8	SYSTEM CODE CODE SUBCODE COMPONENT CODE SUBCODE SUBCOD
	CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
10	The cause of this event has been attributed to setpoint drift. The "B"
	reactor pressure instrument was immediately recalibrated, satisfactorily
1 2	functionally tested per procedure and returned to operable status.
1 3	
	9 80
1 5	H 28 0 0 0 0 29 NA B 30 Normal surveillance OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 B 31 Normal surveillance 80 END STATUS 30 DISCOVERY DESCRIPTION 32
	ELEASED OF RELEASE AMOUNT OF ACTIVITY (35) DEFINITION OF RELEASE (36) NA LOCATION OF RELEASE (36) PERSONNEL EXPOSURES
1 7 8	NUMBER 0 0 0 37 Z 38 NA
1 8	NUMBER DESCRIPTION (41) NA 9 11 12 NA
1 9	LOSS OF OR DAMAGE TO FACILITY (43) TYPE DESCRIPTION NA B303150563 830222 PDR ADDCK 05000321 PDR
20	PUBLICITY ISSUED DESCRIPTION 45 NA NA NRC USE ONLY NA
7 8	The same of the sa