

SEP 28 1979

Mr. Thomas D. Keenan, Chairman
General Electric Operating Plant Owners' Group
Vermont Yankee Nuclear Power Corporation
Seventy-Seven Grove Street
Rutland, Vermont 05701

SUBJECT: ADDITIONAL INFORMATION REQUIRED TO EVALUATE NEDO-24708

Dear Mr. Keenan:

The Analysis Group of the Bulletins and Orders Task Force is reviewing your August 17, 1979 report, NEDO-24708, "Additional Information Required for NRC Staff Generic Report on BWR Reactors". In the review to date we have identified several areas in the loss of feedwater transient analyses in which we will require additional information or a formal clarification of the information contained in NUREG-24708.

Our specific requests for additional information are contained in the enclosure to this letter. In order for us to maintain our schedule, the requested information should be provided not later than October 1, 1979 as agreed to in our meeting on September 6, 1979. If you require any clarification of these matters, please contact W. F. Kane who may be reached at (301)492-7745.

Sincerely,

Original signed by:

D. F. Ross, Jr., Director
Bulletins and Orders Task Force
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc: See attached lists

REGULATORY DOCKET FILE COPY

7910120435 XA

RD-8-2
GE

| | | | | | | |
|-----------|-----------|-----------|--------|------------|--------|---|
| OFFICE ▶ | B&OTF | B&OTF | B&OTF | B&OTF | B&OTF | |
| SURNAME ▶ | W Kane:TK | Wheltemes | DRoss | ZRosztoczy | TNovak | C |
| DATE ▶ | 9/29/79 | 9/ /79 | 9/ /79 | 9/25/79 | 9/ /79 | |

7910120435

XA Copy Has Been Sent to PDR

REQUESTS FOR ADDITIONAL INFORMATION
NED 24708 TRANSIENT ANALYSES
ANALYSIS GROUP

1. Provide a detailed discussion of how the SAFE code simulates a transient such as loss of feedwater (LOFW). Describe all input parameters and output parameters used for determining the Sequence-of-Events tables in NEDO-24708. Provide a comparison of the results of a SAFE code simulation with the normal transient code (REDY/ODYN) for each reactor class. Describe all modifying assumptions made when using the SAFE code to simulate transients.
2. Provide details on how BWR-1 transients were derived from the BWR-2 analyses.
3. Provide a complete set of curves for the BWR-4 LOFW analyses. These should include: vessel level, vessel pressure, steam and feedwater flow, safety relief valve flow, ECC flows, steam line pressure, peak fuel temperature, bypass valve flow, wide range and narrow range sensed level, core inlet flow, drive flow; neutron flux. For other reactor classes provide vessel pressure, vessel level, SRV flow, ECCS flows, steam flow; feedwater flow.
4. Identify the representative plant in each reactor class and the rationale for selection. Describe how representative plants provide plant specific transient response when systems characteristics of plants differ within each reactor class.
5. For the BWR-1 reactor with LOFW and no control rod drive (CRD) flow, show that the operator has one hour to manually isolate the reactor before core uncover.
6. It is not apparent that additional failure in shutdown methods would not aggravate or change the course of a simulated transient as stated in NEDO-24708. Clarify.
7. For BWR-1 with no emergency condenser (EC) or CRD flow, provide the system response when the SRV recloses instead of remaining open. The pressure will rise again to the SRV set point and continue this cycling at high pressure while inventory is being depleted. If manual action is required, provide the instrumentation available to alert the operator and what actions are required to maintain acceptable core inventory.

8. For the BWR classes where the SRV cycle before decay heat is removed by ECCS, what happens to the vessel inventory. Provide plots of level, pressure, ECCS, and SRV flows.
9. It appears that a stuck open relief valve (SORV) combined with a LOFW and failure of high pressure systems is not as severe as a properly operating SRV or one that is partially stuck open. In determining the course of a LOFW transient a sensitivity study should be performed for determining operator action times for event recognition and proper mitigation.
10. Justify the assumptions used in the analyses to show operator action times as provided in the sequence of events. For example, justify the selection used for decay heat which varied for reactor class. How sensitive is the analysis to your assumptions.
11. It appears that operationally it is desired to manually restart a failed high pressure system prior to using the automatic depressurization system (ADS) for the low pressure (LPCI/LPCS) ECCS. However, the core inventory recovery is faster with ADS (no high pressure ECCS) and LPCI/LPCS. What will the guidelines suggest to the operator?
12. Supply curves to show the differences in SRV opening times and level recovery times for BWR-4 and BWR-5 reactors.
13. Provide the analyses and sequence of events for the LOFW coupled with a stuck open SRV and the following: loss of offsite power; loss of all A-C power; and loss of one train of D-C power with loss of offsite power. Provide the following time-dependent variables: SRV flow; vessel pressure; ECCS flows; vessel water level; and fuel temperatures. The initial conditions assumed in the analyses should be provided and the time at which stable conditions are reached. If core uncover results, provide the basis for assessing core damage.

OWNERS GROUP REPRESENTATIVES

A. Meyer
Iowa Electric Light & Power
P. O. Box 351
Madison Rapids, Iowa 52406

Jack S. B'itel
Commonwealth Edison Co.
72 West Adams, Room 2249
Chicago, Illinois 60603

A. Dömer
Tennessee Valley Authority
10 Chestnut Street Tower
Cattanooga, Tennessee 37401

Roger W. Huston
Consumers Power Company
Nuclear Operations Dept.
1945 West Parnall Road
Jackson, Michigan 49201

Chris K. Chitkara
Cincinnati Gas & Electric
P. O. Box 960
Cincinnati, Ohio 45201

Wayne Shamla
Northern States Power Company
Monticello Nuclear Plant
Monticello, Minnesota 53602

Paul J. McGuire
Boston Edison Company
Pilgrim Station
Rocky Hill Road
Plymouth, Mass. 02360

Peter W. Lyon
PASNY
10 Columbus Circle
New York, N. Y. 10019

J. J. Cooney
Philadelphia Electric
1301 Market Street
Philadelphia, Pennsylvania 19101

W. R. D'Angelo
Niagara Mohawk Power Corp.
300 Erie Boulevard West
Syracuse, N. Y. 13202

J. A. Widner
Georgia Power Company
Power Generation Department
Box 4545
70 Peachtree Street
Atlanta, Georgia 30302

D. B. Waters
Carolina Power & Light Co.
P. O. Box 1551
Raleigh, N. C. 27602

Thomas J. Dente
Northeast Utilities
P. O. Box 270
Hartford, Connecticut 06101

Jay M. Pilant
Nebraska Public Power District
P. O. Box 499
Columbus, Nebraska 68601

J. O'Connor
Mersey Central Power & Light Co.
Edison Avenue at Punchbowl Road
Bristown, New Jersey 07960

T. D. Keenan
Vermont Yankee Nuclear Power Corp.
77 Grove Street
Rutland, Vermont 05701

Pat Marriott
General Electric Company
175 Curtner Avenue, Mail Code 194
San Jose, California 95125

Taggart Rogers
Pacific Gas & Electric
One Post Street, Suite 2200
San Francisco, California 94104

GE OWNERS GROUP SPECIAL CONTACTS LIST

David Bixel
 Senior Licensing Administrator
 Consumers Power Company
 100 West Michigan Avenue
 East Lansing, Michigan 48820

Mr. W. G. Council, Vice-President
 Nuclear Engineering & Operations
 Northeast Nuclear Energy Company
 P. O. Box 270
 Hartford, Ct. 06101

Hugh G. Parris
 Manager of Power
 Tennessee Valley Authority
 100 Chestnut Street, Tower II
 Chattanooga, Tennessee 37401

Mr. L. O. Mayer, Manager
 Northern States Power Company
 414 Nicollet Mall - 8th Floor
 Minneapolis, Minnesota 55401

J. A. Jones
 Executive Vice-President
 Carolina Power & Light Company
 100 Fayetteville Street
 Raleigh, N. C. 27602

Mr. Donald P. Dise
 Vice President - Engineering
 Niagara Mohawk Power Corp.
 300 Erie Boulevard West
 Syracuse, New York 13202

J. M. Pilant, Director
 Licensing & Quality Assurance
 Nebraska Public Power District
 P. O. Box 499
 Columbus, Nebraska 68601

Mr. I. R. Finfrock, Jr.
 Vice President-Generation
 Jersey Central Power & Light Company
 Madison Avenue at Punch Bowl Road
 Morristown, N. J. 07960

Cordell Reed
 Assistant Vice President
 Commonwealth Edison Company
 P. O. Box 767
 Chicago, Illinois 60690

Mr. Edward G. Bauer, Jr., Esquire
 Vice-President & General Counsel
 Philadelphia Electric Company
 2301 Market Street
 Philadelphia, PA. 19101

Duane Arnold, President
 Iowa Electric Light & Power Company
 P. O. Box 351
 Cedar Rapids, Iowa 52406

Mr. G. Carl Andognini
 Boston Edison Company
 800 Boylston Street
 Boston, Massachusetts 02199

George T. Berry
 General Manager & Chief Engineer
 Power Authority of the State
 of New York
 100 Columbus Circle
 New York, New York 10019

Mr. Robert H. Groce, Licensing Engineer
 Yankee Atomic Electric Company
 20 Turnpike Road
 Westboro, Massachusetts 01581

Charles F. Whitmer
 Vice President-Engineering
 Georgia Power Company
 P. O. Box 4545
 Atlanta, GA 30302

Mr. Earl A. Borgmann
 Vice President - Engineering
 The Cincinnati Gas & Electric Co.
 P. O. Box 960
 Cincinnati, Ohio 45201

John C. Morrissey
 Vice-President & General Counsel
 Pacific Gas & Electric Company
 1000 Market Street
 San Francisco, CA 94106

Mr. Byron Lee, Jr., Vice-President
 Commonwealth Edison Company
 P. O. Box 767
 Chicago, Illinois 60690